

Inspection Report

(This Installation Test Report is to be certified by a Licensed Electrical Contractor. This is for reference of consumer.)

From: M/s..... (Wiring Contractor)

Reg. No.....

To: M/s. BSES Rajdhani Power Limited (Name of the Licensee)

Dear Sir,

We hereby inform that Electrical inspection at the premises bearing No. / situated on Road / Street (as per address given below) occupied by (as per Applicant's name and signature as given below) has been completed by us and is ready for your engineer to test and connect up with your mains (As per CEA measures relating to safety and electric supply) regulation 2023 was tested by us on date.....and the installation resistance as per regulation 36 was.....mega ohms.

ELCB (as per regulation 44) found installed: Yes () NO () Make: Capacity:

No. of circuits left to right on Distribution	Size of Conductor	Lamps		Fans		Plugs (5 Amp)		Plugs (15 Amp)		Other Domestic appliances		Total kW
		No	Watt	No	Watt	No	Watt	No	Watt	Description	Watt	
Circuit No. 1												
Circuit No. 2												
Circuit No. 3												
Circuit No. 4												
Circuit No. 5												
Circuit No. 6												
											Total	

Licensed wiring Contractor Name, Seal & Signature						License No.				Date		D	D	M	M	Y	Y	Y	Y		
Address																					
City																		PIN			
Name of the Applicant												S/o									
Address where supply is required																					
City																		PIN			
Address where bill is to be sent																					
City																		PIN			
Signature of Wiring Contractor:										Signature of Applicant:											
Date:																					

Note: As per notification no F.11(149)2004 Power/2386 & 2387, Use of ISI marked motor pump sets, power capacitors, Foot/Reflex Valves in Agriculture and use of CFL and electronic chokes in Govt. buildings/ Govt. aided institutions/ Boards/ Corporations is mandatory.

As per CEA 2023 Regulation 16 Suitable cut out should be provided at the consumer premises.

As per CEA 2023 Regulation 18 earth terminal on consumer premises.

As per CEA 2023 Regulation 44 earth leakage circuit breaker whose maximum earth leakage threshold for tripping should not exceed 30 milli amp. for domestic connection and 100 milli amp. for all other installation.