

Request No./CRN:

--	--	--	--	--	--	--	--	--	--

Inspection Report

(This installation Test Report in to be certified by a Licensed Electrical Contractor and to be submitted along with the Application)

Form : M/s (wiring contractor)

Reg.No.

To : M/s BSES Rajdhani Power Limited (Name of the Licensee)

Dear Sir,

We hereby inform that Electrical inspection at the premise bearing No. / situated on road/street (as per address given below) occupied by (as per applicant's name and signature as given below) has been completed by us and is ready for your engineer to test and connect up with your

mains (As per CEA measurs relating to safety and electric supply) regulation 2015 was tested by us on dateand the

installation resistance as per regulation 34 wasmega ohms.

ELCB (as per regulation 42) found installed : Yes () NO () Make : Capacity :

No. of circuits left to right on distribution	Size of conductor	Lamps		Fans		Plugs (5 Amp)		Plugs (15 Amp)		Other Domestic appliances		Total kw
		No	Watt	No	Watt	No	Watt	No	Watt	Description	Watt	
Circuit No . 1												
Circuit No . 2												
Circuit No . 3												
Circuit No . 4												
Circuit No . 5												
Circuit No . 6												
											Total	

Licensed Wiring Contractor Name ,seal & signature						License No .				Date		D	D	M	M	Y	Y	Y	Y
Address																			
City												Pin							

Name of the applicant											S/O								
Address where supply is required																			
City											pin								
Address where bill is to be Sent																			
City											Pin								
Signature of Wiring Contractor											Signature of Appliant								
Date :																			

Note : As per notification no F .11 (149)/2004Power/2386 & 2387 , Use of ISI marked motor pump sets , power capacitors, Foot/Reflex Valves in Agriculture Sectors and use of CFL and electronic Chokes in Govt. buildings/GovtAided institutions/ Boards / Corporations is mandatory.**As Per CEA guidline Regulation 14 suitable cut out should be provided at the consumer premises.****As per CEA guidline Regulation 16 earth terminal on consumer permises.****As per CEA guidline Regulation 42 earth leakage circuit breaker whose maximum earth leakage thershold fotripping should not exceed 30 milli amp. for domestic connection and 100 milli amp. for all other installation.**