

**SUPPLY, INSTALLATION OF DT SMART METERS & ITS INTEGRATION WITH HES AT BRPL NIT No.: CMC/BR/25-26/FK/PR/MS/1266**

**Amendment No. 2**

Sr. No.	Section	Page No.	Clause No.	Existing Clause	Amendment/Clarification
1.	2	17	15.04	<p>The Bidder, along with the bid documents has to submit four samples along with detailed GTP &amp; Drawings.</p> <p>Samples will be submitted at BRPL Meter Testing Laboratory, Savita vihar New Delhi or before the due date of tender submission</p>	<p><b>Amendment:</b> The Bidder, along with bid document has to submit <b>TWOSAMPLES</b> along with detail GTP, tamper thresholds and drawings.</p> <p>Samples will be submitted at BRPL Meter Testing Laboratory, Pushp Vihar Near substation no .15 , sector – 7 ,Saket ,New Delhi – 110017 or before the due date of tender submission</p>
2.	1	9	Part - I (TECHNICAL BID): Technical, Sr no. 13	<p>Sample of energy meters</p> <p>Samples required as per technical specifications to be submitted in BRPL Meter Testing lab, Savita Vihar, Delhi.</p>	<p><b>Amendment:</b> Samples required as per technical specifications to be submitted in BRPL Meter Testing lab, Pushp Vihar Near substation no .15 , sector – 7 , Saket ,New Delhi – 110017.</p>

**2.00 Qualification Criteria (a) Technical Criteria**

Sr. No.	Section	Page No.	Clause No.	Existing Clause	Amendment / Clarification
1.	1	6	2.00 (a) - 7(C)	<p><u>Meter Burn In system:</u> In order to ensure the reliability of components and that there is no drift in meter accuracy with time; the manufacturer should have burn in facility -- Running meter with load at elevated temperature.</p>	<b>Clause 7.c. stands deleted</b>
2.	1	6	2.00 (a)– 7(H)	-	<p><b>Clause Addition:</b> <b>7.h.-</b> The bidder should have in-house NABL (ISO:17025:2017) accredited Laboratory for acceptance test for the relevant IS</p>

**All other Terms &Conditions of the referred Request for Proposal (RFP)/ Tender and/or Amendments shall remain unchanged.**