CORRIGENDUM – 2 FOR NIT NO NIT NO CMC/BR/25-26/FK/PR/KG/1307 for Design, Engineering, Supply,
Installation, Testing, Commissioning and Comprehensive Operation & Maintenance (O&M) of Grid-Connected
Rooftop Solar PV systems with a cumulative capacity of approximately 2.2 MWp to be installed across 46 BRPL grid
stations & buildings.

CORRIGENDUM DATE: 16-12-2025

SL. NO.	DESCRIPTION	PROPOSED CLARIFICATION	RESPONSE
1	Pre-Bid Queries	Kindly clarify whether the solar power evacuation for all sites under this tender is to be done strictly at the LT level, as specified in the technical requirements. We seek this clarification since Annexure II (Pages 75–341) repeatedly mentions the parameter 'Distance from Solar to Transformer'. This parameter generally pertains to HT-side evacuation and does not appear to have any correlation with LT-based grid-connected rooftop systems. Please confirm the intended evacuation voltage level (LT or HT) and explain the purpose of indicating the transformer distance in the site details.	Evacuation Voltage Level is LT.
2	Site Visit		Vendor interested in visiting the site locations shall fill and submit the Attached Temporary Entry form by 17.12.2025 – 12:00 HRS via Email. Kunal.govil@reliancegroupindia.com Mayank.ahlawat@reliancegroupindia.com

Cluster-4 Vasant Kunj Sub-Division details have been updated in below table

Table no.1: Revised Cluster Details

SI. No.	Description	Cluster	Sub Division	Location	Estimated Capacity (in kWp)	Estimated Value (in Cr.)	EMD Value (in Rs.)
	Design, Engineering, Supply, Installation, Testing, Commissioning and Comprehensive Operation & Maintenance (O&M) of Grid-Connected Rooftop Solar PV systems with a cumulative capacity of approximately 2.2 MWp to be installed across 46 BRPL grid stations & buildings.	Cluster 1	Khanpur	Sangam Vihar	69	2.05	4,10,000
			NFC	33 KV Sarai Julena Grid	34		
				66 KV Jasola Grid	92		
				Jamia Grid	16		
				Mathura Road	35		
1				Sarita Vihar	52		
			RK Puram	33 KV RK Puram – II	60		
			Saket	C Dot	58		
				Malviya Nagar Grid	50		
			Sarita Vihar	66 KV MCIE Grid, Badarpur	45		
				66 KV Meethapur	24		
		Cluster 2	Alaknanda	33 KV Grid CR Park(CMC HR office)	34	2.10	4,20,000
				Okhla Phase-1	58		
			Bindapur	G-III, Bindapur POC 3	80		
			Dwarka	66 KV G1 Dwarka	70		
2				66 KV G4 Dwarka	100		
				Papankalan G5	70		
				Papankalan G6	70		
			Janakpuri	District Centre, Janak Puri	16		
				Enforcement Office,Hari Nagar	60		

3	Cluster 3	Hastsal	66 KV Hastsal Grid Dhansa Complaint	25	2.09	4,18,000
		Jafarpur	Centre	14		
		Sararpar	Ujwa Complaint Centre	7		
		Maya Enclave, Janakpuri	Hari Nagar District Building	38		
		Mitraon	Mitraon Grid	30		
		Mundka	66 KV TikriKalan, Mundka	50		
		Najafgarh	Nangloi Water Works	98		
			Daulatpur Complaint Centre	6		
		Hajargam	DJB Najafgarh	48		
		Nangloi	Nilothi	46		
		Punjabi Bagh	Record Store(Club Road),Punjabi Bagh	32	_	
			33 KV Chokhandi	36		
		Tagore Garden	66 KV Guru Gobind Singh	31		
			Mukherjee Park Grid	27		4,12,000
			33 KV IIT Grid	40		
		Hauz Khas	HUDCO Office Building &Grid(EHV office)	100	2.06	
			IGNOU Grid	90		
			Shivalik & associated buildings	60		
		Nehru Place	33 KV East of Kailash	22		
4	Cluster 4		66 KV Fatehpur Beri	52		
		Vasant Kunj	66 KV Palam	40		
			Vasant Kunj B Block Grid	25		
			Vasant Kunj C block	40		
			Vasant Kunj D Block Grid	35		
			Vasant Kunj Institutional area	41		
Total (exclusive of GST)			2192	8.28	16,56,000	

^{**}Note: Price Bids have to be submitted for the entire capacity (as mentioned in Table No.1) for each Location.