

CORRIGENDUM - I

Procurement of Insulated Aerial work Platform with tools for maintenance of overhead sections upto 11KV/ 33KV in various locations of BRPL

NIT NO: CMC/BR/26-27/FK/PR/SL/1349

Tender Date: 10.04.2026

BSES RAJDHANI POWER LTD (BRPL)

Corporate Identification Number: **U74899DL2001PLC111527**

Telephone Number: +91 11 3009 9999

Fax Number: +91 11 2641 9833

Website: www.bsesdelhi.com

Sr. No	Query Type Technical / Commercial	Page No	Clause No	BRPL Clause	Corrigendum - I
1	(Commercial)General	15	1.6	The company reserves the right to split the order among various successful bidders in any manner it chooses without assigning any reason whatsoever	Change of Clause no 1.6 page no 15 as per Clause no no 26 , page no 21, which is as below; "The Company will award the Contract to the successful Bidder whose Bid has been determined to be the lowest-evaluated responsive Bid, provided the Bidder has been determined to be qualified to satisfactorily perform the Contract. Company reserves the right to award order to other bidders in the tender, provided it is required for need of the work." The company intended to award the work to Lowest evaluated bidder through this tender & it will not be split.
4	(Technical) Annexure A	47	10	Slotted Rubber Blanket , Solid 22" X 22"	The size offered is higher than the mentioned size . Hence; Acceptable.
7	(Technical) Annexure A	50	3	Cover Blanket with Slotted Rubber: Small 22 inch x 22 inch	The size offered is higher than the mentioned size . Hence; Acceptable.
8	(Technical) Annexure A	52	27	FRP Triangular Unidirectional Telescopic Stick- 7 meter, 4 sections with extendable length of minimum 5 meters and closed height shall be less than 2.25 meters	The length of the offered stick should be 7 meters..
9	(Technical) Annexure A	53	44	Insulated Hanger for voltage class 36kV – Insulated parking stand for jumpers/ grounding clamps.	The item shall be tested at 36 KV and testing of equipment shall be as per IS/IEC/ANSI suitable for 33 kV voltage class.
10	(Technical) Annexure B	55	1	Leakage Current Clamp Meter (0-300µA/3mA/30mA)- CT diameter 35 mm	Makes are as under: 1)Multi measuring instruments - Japan 2)Megger 3) Sanwa 4) KOICO etc. Products are available ; vendor can explore suitable vendors accordingly.

11	(Technical) Annexure B	55	3	HV Clamp Meter with Harmonics Measurement, 1-3000A (Type U, Rating: Class 4, CT inside Diameter min. 50 mm)	Makes are as under: 1) Multi measuring instruments - Japan 2) Chance USA 3) Sensorlink 4) Megger etc. Products are available ; vendor can explore suitable vendors accordingly.
12	(Technical) Annexure B	55	5	Contact Voltage Detector (415 V- 36 kV) Sunrise link for universal head attachment with FRP Hotstick Voltage detection levels 11kV & 33 kV	Makes are as under: 1) Chance USA 2) Salisbury USA 3) Ritz 4) Hasegawa Japan 5) Megger etc. Products are available ; vendor can explore suitable vendors accordingly.
13	(Technical) Annexure B	55	7	Pole Leakage Current Meter (AC/DC range: 1mA to 300A) using flexible CT Sensor of 400 mm diameter.	Makes are as under: 1) Multi measuring instruments - Japan Products are available ; vendor can explore suitable vendors accordingly.
16	(Technical) Training	80		Note: With Tender document; cost of training per week to be provided	As per Revised Price Bid mentioned below. Separate line item provided for rate only purpose.
17	Commercial	14		The bidder shall sign a Non-Disclosure Agreement (NDA) in the format attached in tender document and submit along with its bid.	NDA format attached below
18	Technical	7	1	4. QUALIFYING REQUIREMENTS (QR) Details of orders along with order, invoices and payment details.	Tender conditions shall prevail However in case of payment details , completion certificate and material receipt documents will be consider.
19	Due date of Submission	1,5,12		Thursday, 23.04.2026; 15:15 Hrs	Thursday, 04.05.2026; 15:15 Hrs
20	Date Date of Opening	1,5,12		Thursday, 23.04.2026; 15:45 Hrs	Thursday, 04.05.2026; 15:45 Hrs

SECTION VI

REVISED PRICE BID

Corrigendum - 1 : BSES RAJDHANI POWER LIMITED NIT 1351

**SECTION VI
PRICE FORMAT**

Procurement of Insulated Aerial work Platform in BRPL	QTY	UOM	HSN Code	Make and Model	Basic Unit Rate without GST	GST in %	Unit Rate With GST	Amount (Qty X Unit Rate with GST)
Supply, Installation, testing, commissioning, RTO commercial Delhi registration (with all govt norms), training (One Month), GPS Tracking device of Vehicle with Insulated Aerial work Platform along with tools for maintenance of overhead sections upto 11KV/ 33KV in various locations of BRPL	1	Nos						
TOTAL WITH GST (A)								

ANNEXURE A: -TOOLS LIST (SUITABLE FOR 11 kV & 33 kV)

1) For 11 kV(Suitable for Dog, Wolf, Goat conductor)

S. No.	Description	UOM	Qty	HSN Code	Make and Model	Basic Unit Rate without GST	GST in %	Unit Rate With GST	Amount (Qty X Unit Rate with GST)
1	Flexible Rubber line hose; Length -4.5 feet, Coupler at one end	No	12						
2	Flexible Rubber Cover for Jumpers-Large ,Minimum Length -2.9 feet	No	2						
3	Flexible Rubber Cover for jumpers-small ,Length -1.25 feet	No	2						
4	Insulator Cover, 16"(L) x 6.5"(Dia)(Suitable for Porcelain –Pin type insulators)	No	4						
5	Round Covers (100 mm), Overall length: 300 mm and Voltage rating of 26.4 kV-Phase-to-Phase	No	3						
6	Round Covers (100 mm), Overall length: 600 mm and Voltage rating of 26.4 kV-Phase-to-Phase	No	3						

7	Rope lock assembly for securing pole covers on poles. Length shall be suitable to hold pole covers tight.	No	2						
8	Spiral Conductor Cover with Gripall Adapter; suitable for crossarm and insulators	No	2						
9	Blanket, Solid 36" X 36"	No	10						
10	Slotted Rubber Blanket , Solid 22" X 22"	No	5						
11	Rubber Glove - Blanket Clamp suitable for installation of rubber insulating blankets	No	18						
12	Klondlike Clamps / Large	No	6						
13	Protector ,Glove 14 Inch for Size 8.5	No	2						
14	Straight Cuff Gloves Color Yellow under Black(Size 8.5& Length 14 Inch)	No	2						
15	Arc Flash 12 Cal/cm2 Cover with Front Lift hood(Visor Dimensions:10" width & 8"Height)	No	2						
16	Special Grade Safety Harness for Live Line Work(Size :Medium, Height:5'8"-5'11" & Chest:36" to 40")	No	2						
17	Special Grade Safety Lanyard attachment (Type:1" tubular nylon Web with snaphook& loop end) for fall arrest	No	2						
18	Rubber Sleeves(Size : Large; Dipped Regular type)	No	4						
19	Blanket Cannister 37" with Handle, Diameter 7"	No	4						
20	Glove Bag 18", Cotton Canvas	No	4						
21	Sleeve Bag,Length: 15"	No	4						
22	Line hose Lifting Bag(Diameter:7" & Length 48")	No	1						
23	12 ft. 4/0 Primary Jumpers, 400 amps continuous current rating	No	3						

24	Insulated Hanger (Insulated parking stand for jumper/grounding clamps)	No	2						
25	Temporary Mechanical Jumper Holder (V-Notch design that securely holds jumpers preventing sliding) Fitment over bare conductors & class line hose up to 2.5"OD.	No	4						
26	Crossarm-mount temporary conductor support(Made up of aluminum),Maximum Workload: Rated for 65 kg.	No	3						
27	ø32mm grip-all Clamp sticks (shotgun) 8 feet long(include Jaw, Jaw holder, Safety stop, Lock bar& Latch)	No	1						
28	Lightweight telescopic stick with universal head(FRP Triangular Telescopic Rod with extendable length of min. 5 meters with 4 nos. of sections & closed height shall be less than 1.75 meters).	No	1						
29	Hoist Link Stick- Length 15", Diameter 1.25" Working load limit: 1814 kg	No	1						
30	Hot Stick Wiping Cloth	No	4						
31	Combination Tool Board & Tool Tray (only trays)	No	1						
32	Polymer Bucket hooks suitable to attach tool storage bags and hold the load of the hotline tools.	No	4						
33	Wire Gripper (Suitability upto 23 mm) ,Working load limit for 2268 kg.	No	1						
34	Insulated handle Bolt cutter / Hardware cutter	No	1						
35	Web Strap Hoists(Nylon Hoist) 1 ton	No	1						
36	Web slings endless single ply nylon slings capacity up to 4000 lbs	No	2						
37	Complete handline side opening hand line block with swivel hook) Complete handline made up of side opening block with swiveling hook & Safety snap ½ inch polypropylene rope – working height of 40 feet and rope length of 80 ft with handline hook and handline snap	Set	1						

38	Overhead Circular Saw- Hydraulic (Power Source: Truck) with suitable hose pipes. Insulated fiberglass extension tube , 100 kV tested with length of 2.1 meter, diameter circular blade with 9"	Set	1						
39	Glove Tester Pneumatic	Set	1						
40	Truck Grounding Kit with 10meter Cable metal or hard plastic cable reel with handle PVC cable of 16 sqmm and with 10 meter long earth spike of min. 1 foot.	Set	1						
40	Safety Helmet with glasses	Set	5						
41	Traffic Safety Cones with Plastic Chains(3 nos per set)	Set	2						
42	First Aid Kit(Metal box with all necessary first aid medicines and tools such as adhesive bandages, Sterile gauze pads, adhesive tape, Non-adherent dressings, Wound dressings, Roller bandages, Triangular bandages, safety pins, disposable gloves,scissors, Tweezers, Resuscitation Face Shield, First Aid Manual , Emergency blanket, Instant Cold Packs, over- the counter painrelievers, Hydrocortisone cream etc.)	No	1						
43	Tree Pruning Saw with Universal Fitting, Hook and Triple Chip Cutting Blade with Saw handle. Min. Length of blade -Min.330 mm Min. cutting area of blade-12 inches	No	4						
44	Complete Hand tools set including 1) Spanners (open-end & Ring type) with sizes Full metric (8mm to 24 mm) & SAE (1/4" to 1-1/8") sets. 2) Sockets (6 point deep and shallow) 3/8"&1/2" drive. 3) Ratchet (Reversible fine-tooth-72 tooth & 3",6"&10" locking extensions) 4) Screwdriver (Type 1,2,3 phillips& various Flat- Head widths) 5) Pliers (Type : Needle-nose(for cotter pins), Lineman's pliers)) 6) Torque wrench (Type 1/2" Drive click –type or digital with range 50 lb-ft to 250 lb-ft)	No	1						

	7) Allen/Hex-keys (Type:T Handle or socket-Head bits(long reach) Sizes 1/8" to 3/8") 8) Grease Gun								
45	Tools Bucket-Large(12"x15")	No	1						
46	Protector ,Glove 14 Inch for Size 9.5	No	2						
47	Straight Cuff Gloves Color Yellow under Black(Size 9.5 &Length 14 Inch)	No	2						
TOTAL WITH GST (B)									

• **For 33 kV(Suitable for Goat conductor, Zebra)**

S. No.	Description	UOM	Qty	HSN Code	Make and Model	Basic Unit Rate without GST	GST in %	Unit Rate With GST	Amount (Qty X Unit Rate with GST)
1	Cover Blanket with Solid Rubber: Large 35-36 inch x 35-36 inch	No	12						
2	Cover Blanket with Slotted Rubber: Large 35-36 inch x 35-36 inch	No	4						
3	Cover Blanket with Slotted Rubber: Small 22 inch x 22 inch	No	4						
4	Blanket Button	No	50						
5	Rubber Glove Clamp	No	24						
6	Flexible Rubber Stinger Cover for Jumpers - 36 inch long(Type II)	No	2						
7	Spiral Conductor Cover with Gripall Adapter (36.6kV) suitable for crossarm and insulators	No	2						
8	Ribbed Pole Cover (150 mm), Overall length: 300 mm and Voltage rating of 36.6 kV-Phase-to-Phase	No	4						
9	Ribbed Pole Cover (230 mm), Overall length: 300	No	1						

	mm and Voltage rating of 36.6 kV-Phase-to-Phase								
10	Ribbed Pole Cover (230 mm), Overall length: 600 mm and Voltage rating of 36.6 kV-Phase-to-Phase	No	1						
11	Locking Device for securing Pole Covers on poles. Length shall be suitable to hold pole covers tight	No	4						
12	Conductor Cover-36.6kV Voltage rating (Phase-to-Phase) with Grip all adaptor (Length :5 feet)	No	12						
13	Straight Cuff Rubber Gloves-(Size 8.5 & Length 14")	Pair	3						
14	Straight Cuff Rubber Gloves-(Size 9 & Length 16")	Pair	3						
15	Premium Leather Glove Protector (Size 8.5 & Length 14")	Pair	10						
16	Premium Leather Glove Protector (Size 9.5 & Length 14")	Pair	10						
17	Molded Rubber Insulating Sleeve, (36kV)- Dipped type	Pair	3						
18	Sleeve Straps with Buttons 15"	Pair	10						
19	Glove Protector Bag (Length 18")	No	6						
20	Sleeve Protector Bag (Size 30 x 13 inch)	No	5						
21	Live Line Wire Gripper- Suitable for size of 8 mm upto 20mm	No	1						
22	Live Line Wire Gripper- Suitable for size of 18 to 31mm	No	1						
23	Endless Single Ply Nylon Slings- Length 4 feet with width 2"	No	6						
24	Hoist Link Stick- Length: 15", Diameter 1.25" Working load limit: 1814 kg	No	1						
25	Nylon Strap Hoist- 2 Ton	No	1						
26	Grip All Clamp Stick- 8 Feet	No	1						

27	FRP Triangular Unidirectional Telescopic Stick- 7 meter, 4 sections with extendable length of minimum 5 meters and closed height shall be less than 2.25 meters.	No	1						
28	FRP Triangular Unidirectional Telescopic Stick- 2meter, 2 sections	No	1						
29	Set of RopeBlock-120ftrope 1)Two double blocks with 120 ft of ½ in Rope 2) Swivel Top	Set	1						
30	Tree Pruning Saw with Universal Fitting, Hook and Triple Chip Cutting Blade with Saw handle Min. Length of blade -Min.330 mm Min. cutting area of blade-12 inches	No	4						
31	Tree Trimmer- Hydraulic (Power Source: Truck) with suitable hose pipes. Insulated fiberglass extension tube , 100 kV tested with length of 2.1 meter, diameter circular blade with 9"	No	1						
32	Shepherd hook, Insulator Forks with universal link for stick attachment	Set	1						
33	Glove Tester: Inflator	No	1						
34	Temporary Jumper(36kV), Overall Length: 3.60 m, Rated Current: 350 A, HotStickClamp:4to29mm	Set	3						
35	Temporary Mechanical Jumper Holder/Cuff(V-Notch design that securely holds jumpers preventing sliding) Fitment over bare conductors & class line hose up to 2.5"OD.	Set	4						
36	Rubber Blanket Canister 37" with Handle, Diameter 7"	No	12						
37	Line hose Lifting Bag, 48inchlong,7 inch dia.	No	3						

38	Tarpaulin, 12ftx12ft	No	2					
39	Safety Helmet with glasses	Set	5					
40	ArcFlash 12Cal/cm2 Cover with Front Lifthood (Visor Dimensions: 10" width & 8" Height)	No	2					
41	Complete Hand tools set including 1) Spanners (open-end & Ring type) with sizes Full metric (8mm to 24 mm) & SAE (1/4" to 1-1/8") sets. 2) Sockets (6 point deep and shallow) 3/8" & 1/2" drive. 3) Ratchet (Reversible fine-tooth-72 tooth & 3", 6" & 10" locking extensions) 4) Screwdriver (Type 1, 2, 3 phillips & various Flat- Head widths) 5) Pliers (Type : Needle-nose (for cotter pins), Lineman's pliers)) 6) Torque wrench (Type 1/2" Drive click –type or digital with range 50 lb-ft to 250 lb-ft) 7) Allen/Hex-keys (Type: T Handle or socket-Head bits (long reach) Sizes 1/8" to 3/8") 8) Grease Gun	Set	1					
42	Bold/ Conductor Cutter with insulated handles	No	1					
43	Traffic Safety Cones with Plastic Chains (3 nos. per set)	Set	2					
44	Insulated Hanger for voltage class 36kV – Insulated parking stand for jumpers/ grounding clamps.	No	3					
45	Cross arm-mount Temporary Conductor Support (Made of aluminum), Maximum Workload: Rated for a 68 kg	No	3					

46	Insulator Cover, 16"(L)x6.5"(Dia), For Pin insulators	No	6					
47	Insulator Cover, 7"x16" suitable to use with line hose to cover post-type insulators	No	6					
48	Truck Grounding Kit with 10meter Cable metal or hard plastic cable reel with handle PVC cable of 16 sqmm and with 10 meter long earth spike of min. 1 foot.	No	1					
49	First Aid Kit(Metal box with all necessary first aid medicines and tools such as adhesive bandages, Sterile gauze pads, adhesive tape, Non-adherent dressings, Wound dressings, Roller bandages, Triangular bandages, safety pins, disposable gloves, scissors, Tweezers, Resuscitation Face Shield, First Aid Manual , Emergency blanket, Instant Cold Packs, over- the counter pain relievers, Hydrocortisone cream etc.)	No	1					
50	Special Grade Safety Harness for Live Line Work (Size :Medium, Height:5'8"-5'11" & Chest:36" to 40")	No	2					
51	Special Grade Safety Lanyard attachment (Type:1" tubular nylon Web with snaphook& loop end) for fall arrest	No	2					
52	Polymer bucket Hooks	No	5					
53	Tools Bucket- Large(12" x 15")	No	3					
54	Klondlike clamps/Large	No	8					
	TOTAL WITH GST (C)							

ANNEXURE B: -TESTING INSTRUMENTS/MEASURING INSTRUMENTS (SUITABLE FOR 11 kV & 33 kV)

S. No.	Description	UOM	Qty	HSN Code	Make and Model	Basic Unit Rate without GST	GST in %	Unit Rate With GST	Amount (Qty X Unit Rate with GST)
1	Leakage Current Clamp Meter (0-300µA/3mA/30mA)-CT diameter 35 mm	No	1						
2	Insulating Stick Tester	No	1						
3	HV Clamp Meter with Harmonics Measurement, 1-3000A (Type U, Rating: Class 4, CT inside Diameter min. 50 mm)	No	1						
4	Live-Line Insulator Weak/Faulty Detector	No	1						
5	Contact Voltage Detector (415 V- 36 kV) Sunrise link for universal head attachment with FRP Hotstick Voltage detection levels 11kV & 33 kV	No	1						
6	Temperature & Humidity Meter (Temperature measurement upto 100 deg C)	No	1						
7	Pole Leakage Current Meter (AC/DC range: 1mA to 300A) using flexible CT Sensor of 400 mm diameter.	No	1						
TOTAL WITH GST (D)									

GRAND TOTAL WITH GST (A+B+C+D)

Training Cost for Insulated Aerial work Platform in BRPL	QTY	UOM	Basic Unit Rate without GST	GST in %	Unit Rate With GST	Amount (Qty X Unit Rate with GST)
Training Cost per week as per Pg No 80 of NIT (Rate Only)	1	Week				

NOTE:

- 1) The prices quoted are inclusive of training of BRPL officials (as per spec)
- 2) The bidder shall, at its own, handle all imported equipment's and handle all formalities for custom clearances, port charges, etc. if any.
- 3) All Tools & Tackles, Consumables and Commissioning Spares required to complete the work shall be included in the quoted rates.
- 4) Any other item not mentioned above but are required for successful completion of the works shall be deemed to be included in the above quoted rate
- 5) The payment for these items would be based on actual delivery of materials wherever required.
- 6) The above quantities are indicative and may vary based on actual requirement while execution of work. The payment would be made as per actual.
- 7) Price Variation Clause: The prices shall remain firm during the entire contract period.
- 8) Price Breakup of above must be attached by bidder.
- 9) Reverse Auction (RA) is mandatory and RA will be done on over value of (A+B+C+D). The original price bids of the bidders shall be reduced on pro-rata basis against each line item of (A+B+C+D) & Training Cost based on the final all-inclusive prices offered during conclusion of the reverse auction event for arriving at order value.

Corrigendum - 1 : BSES RAJDHANI POWER LIMITED NIT 1349

NON DISCLOSURE AGREEMENT

THIS NON-DISCLOSURE AGREEMENT ("Agreement") is made and entered into at Delhi on the ____ day of _____, 2026

By And Between

M/s BSES Rajdhani Power Limited, a company registered under the Companies Act, 1956 and having its registered office at **BSES Bhawan, Nehru Place, New Delhi 110019** (hereinafter referred to as the "Disclosing Party" which expression shall unless repugnant to the meaning and context mean and include its successors and permitted assigns) of the FIRST PART

And

_____, a company incorporated under the Companies Act, 1956 and having its registered office at _____, (hereinafter referred to as the "Receiving Party" which expression shall unless repugnant to the meaning and context mean and include its successors and permitted assigns) of the OTHER PART

Disclosing Party and Receiving Party are hereinafter individually referred to as the "Party" and collectively as the "Parties".

WHEREAS the Disclosing Party is in discussions with the Receiving Party for Security Management Services ("Project") and the Disclosing Party may in conjunction with the aforesaid disclose to the Receiving Party information relating to their businesses which is confidential and sensitive in nature and the Receiving Party is willing to undertake to restrict the use and further disclosure of the information in accordance with the terms and conditions set out herein:

1. The "Receiving Party" acknowledges and confirms the confidential and sensitive nature of all information, documents and material relating to Persons and entities which may be accused of or related to the theft of electricity which is a penal offense under the provisions of the electricity act 2003As well as the various data and tools which may be available by way of documents as well as other modes of proof("Project") (i) that may be disclosed or made available to the Receiving Party by the Disclosing Party or its employees/ representatives/ advisors/ consultants; (ii)Receiving Party may gain or gather from any source; (iii) Receiving Party may process or arrive at during the course of the Project; (iv) Receiving Party may have come across during its discussions with any person in the course of the Project; and (v) all negotiations and discussions between the Parties relating to the Project (all the information referred to above is hereinafter referred to as the "Confidential Information").
2. Confidential Information is understood to include but is not limited to

information made available in written, machine recognizable, graphic or sample form including, without limitation, drawings, photographs, models, design or performance specifications, its analysis, compilations, studies, notes and all other information and data disclosed orally or visually which has been developed / is exclusive to the Disclosing Party and includes information provided in various meetings.

Provided, however, that Confidential Information shall not include information which (a) is, or becomes, publicly known, otherwise than through a wrongful act of the Receiving Party or its representatives; (b) is in the possession of the Receiving Party prior to receipt from the Disclosing Party or its representatives without an obligation of confidentiality; (c) is independently developed by the Receiving Party, provided that it was not derived from the Confidential Information; (d) is furnished to others by the Disclosing Party without restrictions, similar to those herein on the rights of such others to use or disclose; or (e) is approved in writing by the Disclosing Party for disclosure.

3. The Receiving Party shall not disclose the Confidential Information to any other person save and except with the express consent in writing given by the Disclosing Party. The Receiving Party, however, may disclose such part of the Confidential Information where (i) such disclosure is in response to a valid order of a court or any other governmental body having jurisdiction over this Agreement or (ii) such disclosure is otherwise required by law, provided that Receiving Party has given prior written notice to the Disclosing Party forthwith it came to learn about such disclosure requirement or the demand for such for disclosure and made all reasonable efforts to protect the Confidential Information in connection with such disclosure.
4. The Receiving Party shall with reference to the Confidential Information take all actions as may be necessary to (i) maintain the confidentiality thereof; (ii) limit its use of such Confidential Information solely for the purpose of the Project; (iii) avoid disclosure even to any of its employees that are not associated with the Project; (iv) avoid any dissemination or publication by any of its employees/ representatives associated with the Project; (v) avoid writing about sensitive information which is disclosed verbally and is sensitive to the operations; and (vi) safeguard the Confidential Information from being accessed by any unauthorized person. Such actions shall include but not be limited to obtaining appropriate non-disclosure undertakings from its employees directly or indirectly engaged in the Project.
5. The Receiving Party hereby agrees to indemnify and hold harmless the Disclosing Party and its directors and employees from and against any damage, loss, cost or liability (including all expenses and costs of enforcing rights under the Agreement) arising out of or resulting from (i) any use or

disclosure by the Receiving Party of Confidential Information in violation of the Agreement; (ii) any leakage of the Confidential Information at the end of the Receiving Party or its employees/ representatives; and (iii) breach or violation of any of the other covenants herein.

6. The Receiving Party will, promptly upon the request of the Disclosing Party, deliver to the Disclosing Party, the documents comprising the Confidential Information or any part thereof and will destroy any copies, notes, or extracts thereof, without retaining any copy thereof, except that any portion of the Confidential Information that consists of analysis and any written Confidential Information not so requested and returned, shall be retained and kept subject to the terms of this Agreement, or upon the Disclosing Party's request destroyed (such destruction to be confirmed in writing).
7. The term of this Agreement is 3 years from the date of execution of this Agreement. However, the obligation to maintain confidentiality of the Disclosing Party's information shall survive the termination of this Agreement. Any violation of this agreement may lead to termination of all the relations with the Receiving party and black listing/ debarring of the Agency for future engagements.
8. This Agreement shall be governed by the laws of India. Any dispute, difference or claim related to or arising under, out of or in connection with this Agreement shall be resolved subject to the jurisdiction of Delhi Courts.

For the Disclosing Party

Authorized Signatory

Name:

Designation:

For the Receiving party

Authorized Signatory

Name:

Designation: