

**RATE CONTRACT FOR SUPPLY OF SINGLE PHASE METER WITH BOX NIT No.: CMC/BR/26-27/FK/PR/MS/1325**

**Corrigendum-III**

Sr. No.	Section	Page No.	Clause No.	Existing Clause	Amendment/Clarification
1.	1	6	Clause No. 2.0 Qualification Criteria,  S. No.2 of B. Commercial Criteria	Bidder should have complete volume of type test reports as per IS 13779 (Including latest Amendments if any) and magnet test as per CBIP-88 from any NABL accredited lab. The type test report should not be older than 2 years as on the date of bid submission.	<b>Amended As:</b>  Bidder should have complete volume of type test reports as per IS 13779 (Including latest Amendments if any) and magnet test as per CBIP-304 from any NABL accredited lab. The type test report should not be older than 5 years as on the date of bid submission.
2.	1	8	Clause No.3.05, Sl. No.3 (Technical Offer)	It include clause by clause commentary, GTP, Type test report from CPRI / ERDA/NABL Lab (Not more than 2 year old), BIS report, Quality assurance plan, Deviation from the technical specifications, component deviation, undertaking of software protocol ,List of Plant and machinery, Testing facilities available at works and drawings, catalogues, manual and spare parts list etc. mentioned in our technical specifications enclosed	<b>Amended As:</b>  It include clause by clause commentary, GTP, Type test report from CPRI / ERDA/NABL Lab (Not more than 5 year old), BIS report, Quality assurance plan, Deviation from the technical specifications, component deviation, undertaking of software protocol ,List of Plant and machinery, Testing facilities available at works and drawings, catalogues, manual and spare parts list etc. mentioned in our technical specifications enclosed
3.	2	11	SUBMISSION OF BIDS Sl.No.15.01	One original & one duplicate Copy (hard copies) of all the Bid Documents shall be sealed and submitted to the Purchaser before the closing time for submission of the bid.	Bid to be submitted through Online SRM Portal.
4.	SECTION – V:	48	16.0 Document Submission: (Technical Specification for Single Phase Meter with Box	Samples of each type and rating offered.	02 Nos. samples are required for evaluation.

**All other Terms & Conditions of the referred Request for Proposal (RFP)/ Tender and/or Amendments shall remain unchanged.**