

S.no.	Tech. Specs clause no.	Description	Changes	Remarks
	MCCB			
1	----	Utilisation category of MCCB is not mentioned	Utilisation category of MCCB shall be Category A as per IEC 60947-II	Added
2	4.1.13	Short circuit breaking current capacity (Icu) -50kA	10kA	
3	4.1.14	Service Short circuit capacity (Ics)-50kA	10kA	
4	4.1.15	Rated short term withstand current for 1 sec at rated voltage – (Icw)-50kA	Not applicable	
5	4.1.28.1	As per tender specification, Microprocessor release is required	Required release shall be Thermal Magnetic type	
6	4.1.28.2	Electrical Protection Overload, Short Circuit & Earth fault	Electrical Protection shall be Over current	
7	4.2.3	Provision of Cable Entry	Incomer cable entry from bottom side & outgoing cable entry from top side	
8	4.2.4	Enclosure Dimensional clearances	Clearance mentioned in tech. Specs are not required Enclosure with most compact size shall be preferred Vendor shall submit sample of offered product considering above mentioned modifications alongwith technical bid submission	
	MCB			
1	4.1.12	Rated short term withstand current for 1 sec at rated voltage – (Icw)-10kA	Icw shall not be applicable for MCB	
1	4.2.3	Provision of Cable Entry	Incomer cable entry from bottom side & outgoing cable entry with top side	

2	4.2.4	Enclosure Dimensional clearances	Clearance mentioned in tech. Specs are not required Enclosure with most compact size shall be preferred Vendor shall submit sample of offered product considering above mentioned modifications alongwith technical bid submission	
---	-------	----------------------------------	--	--