

Corrigendum-2		
SUPPLY, LAYING, TESTING & COMMISSIONING OF 33 KV 3CX400 SQMM CABLES WITH REQUIRED ACCESSORIES ON SINGLE POINT RESPONSIBILITY BASIS AT KALKAJI DTC DEPOT.		
NIT NO CMC/BR/22-23/RB/PR/KG/1023		
S. No.	Pre-Bid Query	BRPL Reply
1	Please refer the Service BOQ point no. 49 “ETC of fire Extinguisher and Mat” Qty required is mentioned as Lot 1, Please confirm the required quantity with Dimensions, drawing and material required for Mat.	Qty required: 03 Nos (Extinguisher including mat as a set).
2	Please confirm that the supply of Extinguisher,FIRE,CO2;22.5 KG;TROLLEY MOUNTED to be consider in the ETC portion as there is no line item in the Supply BOQ for this item.	Supply shall be in bidder scope. Price for supply part shall be in-built in ETC part by bidder and same shall be submitted along with price bid.