

## Procurement of Insulated Aerial work Platform with tools for maintenance of overhead sections upto 11KV/ 33KV in various locations of BRPL

Sr. No	Query Type Technical / Commercial	Page No	Clause No	BRPL Clause	Bidder Query	BRPL comments
1	(Commercial) General	15	1.6	The company reserves the right to split the order among various successful bidders in any manner it chooses without assigning any reason whatsoever	If Order will be split by BSES than who will be responsible for training. In this case two training will be required one for tools and one Insulated Aerial work platform. For IAWP Trainer shall be given and certified by the OEM for IAWP. Without this Warranty and clause is not suitable. Further if two training will be given than BSES training expense will become double. It is also pertinent to mention training is 2nd most expensive item in this overall project. <b>BSES shall award the whole package to one single bidder for better accountability and responsibility of system to adhere the warranty terms as well.</b>	Change of Clause no 1.6 page no 15 as per Clause no no 26 , page no 21, which is as below; "The Company will award the Contract to the successful Bidder whose Bid has been determined to be the lowest-evaluated responsive Bid, provided the Bidder has been determined to be qualified to satisfactorily perform the Contract. Company reserves the right to award order to other bidders in the tender, provided it is required for need of the work." The company intended to award the work to Lowest evaluated bidder through this tender & it will not be splitted .
2	(Commercial) TERMS OF PAYMENT AND BILLING	27	8.0 A	90% payment within 45 days on satisfactory supply, installation, testing, commissioning, RTO Commercial Delhi Registration, Comprehensive Insurance – 1 Year + 3 Years Third Party, Road Tax, Delhi Permit, Govt Norms etc along with acceptance by BRPL for Machine and Tools and on submission of Bank Guarantee, bills duly certified by Engineer-In-Charge i.e., Head – CES, BRPL	90 % payment will be along with the supply of truck and tools at BSES stores.	Tender conditions shall prevail
3	(Commercial) TERMS OF PAYMENT AND BILLING	27	8.0 A	Rest 10% within 30 days after completion of training and successfully handover of materials duly certified by Engineer-In-Charge i.e., Head – CES, BRPL	Rest 10% after completion of training and successful handover of materials duly certified by Engineer-In-Charge i.e., Head – CES, BRPL & RTO commercial Delhi registration, because it will take 60 days at least for RTO Delhi Registration.	Tender conditions shall prevail
4	(Technical) Annexure A	47	10	Slotted Rubber Blanket , Solid 22" X 22"	We have big size blanket only 35 X 35.	The size offered is higher than the mentioned size . Hence; Acceptable.
5	(Technical) Annexure A	46	4	Insulator Cover, 16"(L) x 6.5"(Dia)(Suitable for Porcelain –Pin type insulators)	16" Length insulator cover not available with our OEM and it looks like one OEM specific. We can provide insulator cover suitable to cover pin insulator cover. Kindly make change instead of length just mention height and diameter of Pin Insulator.	Shall be as per tender specification only
6	(Technical) Annexure A	48	31	Combination Tool Board & Tool Tray (only trays)	Tool tray not required for hot line tools, BSES already have tool bag along with tool list and hotline maintenance tool bag not tool tray.Request to Delete the same.	Shall be as per tender specification only
7	(Technical) Annexure A	50	3	Cover Blanket with Slotted Rubber: Small 22 inch x 22 inch	We have big size blanket only 35 X 35	The size offered is higher than the mentioned size . Hence; Acceptable.
8	(Technical) Annexure A	52	27	FRP Triangular Unidirectional Telescopic Stick- 7 meter, 4 sections with extendable length of minimum 5 meters and closed height shall be less than 2.25 meters	with 4 sections we can not provide 7 mtr. We can provide Seven Mtrs with 6 sections with retracted length of 1.63 meters. Height of the stick. Also kindly explain length required 5 mtr or 7 mtr. Retracted length shall be as low as possible as this will make each section of shorter size which will prevent rod to bend when extended.	The length of the offered stick should be 7 meters.hence; acceptable.

## Procurement of Insulated Aerial work Platform with tools for maintenance of overhead sections upto 11KV/ 33KV in various locations of BRPL

Sr. No	Query Type Technical / Commercial	Page No	Clause No	BRPL Clause	Bidder Query	BRPL comments
9	(Technical) Annexure A	53	44	Insulated Hanger for voltage class 36kV – Insulated parking stand for jumpers/ grounding clamps.	We have insulated hanger of voltage 34.6 while BSES requirement is upto 33 KV	The item shall be tested at 36 KV and testing of equipment shall be as per IS/IEC/ANSI suitable for 33 kV voltage class.
10	(Technical) Annexure B	55	1	Leakage Current Clamp Meter (0-300µA/3mA/30mA)- CT diameter 35 mm	We are not able to find any suitable model as per specs. Kindly provide specific make or model which shall be neutral and every bidder can supply . Generally these type of equipment is not requirement for Hotline Maintenance however if BSES need these equipments than BSES can Purchase these items separately. AS items are costly and may affect overall budget of Project	Makes are as under: 1)Multi measuring instruments - Japan 2)Megger 3) Sanwa 4) KOICO etc. Products are available ; vendor can explore suitable vendors accordingly.
11	(Technical) Annexure B	55	3	HVClampMeterwithHarmonicsMeasurement,1-3000A (Type U, Rating: Class 4,CT inside Diameter min. 50 mm)	We are not able to find any suitable model as per specs. Kindly provide specific make or model which shall be neutral and every bidder can supply . Generally these type of equipment is not requirement for Hotline Maintenance however if BSES need these equipments than BSES can Purchase these items separately. AS items are costly and may affect overall budget of Project	Makes are as under: 1)Multi measuring instruments - Japan 2)Chance USA 3)Sensorlink 4)Megger etc. Products are available ; vendor can explore suitable vendors accordingly.
12	(Technical) Annexure B	55	5	Contact Voltage Detector (415 V- 36 kV) Sunrise link for universal head attachment with FRP Hotstick Voltage detection levels 11kV & 33 kV	We are not able to find any suitable model as per specs. Kindly provide specific make or model which shall be neutral and every bidder can supply . Generally these type of equipment is not requirement for Hotline Maintenance however if BSES need these equipments than BSES can Purchase these items separately. AS items are costly and may affect overall budget of Project	Makes are as under: 1)Chance USA 2)Salisbury USA 3)Ritz 4)Hasegawa Japan 5) Megger etc. Products are available ; vendor can explore suitable vendors accordingly.
13	(Technical) Annexure B	55	7	Pole Leakage Current Meter (AC/DC range: 1mA to 300A) using flexible CT Sensor of 400 mm diameter.	We are not able to find any suitable model as per specs. Kindly provide specific make or model which shall be neutral and every bidder can supply . Generally these type of equipment is not requirement for Hotline Maintenance however if BSES need these equipments than BSES can Purchase these items separately. AS items are costly and may affect overall	Makes are as under: 1)Multi measuring instruments - Japan Products are available ; vendor can explore suitable vendors accordingly.
14	(Technical)	74	Auxillary Power System	If the main source of power breaks down, all movements shall stop. There shall be an emergency source of power providing at least rotation of the turntable, as well as lifting and descent of the bucket. This emergency system shall be operated from the vehicle chassis and its operation should also be possible from the bucket	Our system will be based on ANSI standards. As per ANSI standards Lifting og bucket with auxillary power is not required. Only descent is required to lower the boom with battery as lifting the boom with battery is not suggested.	Shall be as per tender specification only.

## Procurement of Insulated Aerial work Platform with tools for maintenance of overhead sections upto 11KV/ 33KV in various locations of BRPL

Sr. No	Query Type Technical / Commercial	Page No	Clause No	BRPL Clause	Bidder Query	BRPL comments
15	(Technical) Training	80		<p>Bidder Shall provide 1 no. of certified trainer with one associate for minimum 30 days for training of our BRPL workers for Rubber Glove method (Min. Batch of 15 BRPL workers).</p> <p><b>Trainers shall be certified with OEM/Govt. recognized agency with minimum experience of 15 nos. of Trainings (On live line) executed in India/Abroad (Min. 5 nos. of trainings to be executed of Rubber glove method &amp; rest of other methods).</b></p> <p>After completion of training; Training certificates shall be issued to all trainees of BRPL by Training company.</p>	<p>1. IN our view BSES shall focus on training in rubber gloves method as BSES requirement is only for rubber gloves method. Experience of other methods does not make any sense.</p> <p>Rubber Gloves method is for 11KV and 33KV Hotstick Method is for 66 KV to 220KV Bare Hand Method is from Partial 220KV, 400 KV and 765 KV.</p> <p>2. Trainer shall be certified by OEM of Hotline Tools or Insulated Aerial work Platform. Generally Trainer is recommended by Hotline Tools Manufacturer.</p> <p>3. Nos. of training for Rubber Gloves method shall be reduced from 5 to 3, At the time of bidding we can try to find out the trainer with BSES requirement however still this will be difficult. It will be not possible for bidder to ensure that the trainer will be working with the training company at the time when BSES training will start.</p> <p>4. Also training experience shall be of training company not trainer as generally training companies provide training and issue training certificates and trainers work for them like employees, hence nos. of training mentioned by BSES as experience shall be of training not of trainer. IF OEM certify anyone as trainer this means he has sufficient experience of providing training.</p>	Tender conditions shall prevail
16	(Technical) Training	80		Note: With Tender document; cost of training per week to be provided	<p>1. We feel here BSES want to know to the cost of after sales training for reference on which BSES can place order for training after completion of project as and when required and may issue the training order on same price when required and not for Price calculation. Price Bid does not have any line item to mention this. Kindly arrange to provide line items in price bid enabling us to quote these prices.</p> <p>2. What should be validity of this price. IF we need to quote for 5 years validity same as of warranty period or something else.</p>	Revised Price Bid, Separate Line Item
17	Commercial	14		The bidder shall sign a Non-Disclosure Agreement (NDA) in the format attached in tender document and submit along with its bid.	Format Not Attached, Kindly provide the same	NDA format attached
18	Technical	7	1	4. QUALIFYING REQUIREMENTS (QR) Details of orders along with order, invoices and payment details.	In place of payment details completion certificate or commissioning MOM or material receipt document should be considered.	Tender conditions shall prevail However completion certificate or commissioning MOM or material receipt document may be submitted
19	Technical	87	ANNEXURE - B	Contact Voltage Detector (415V- 36 kV) Sunrise link for universal head attachment with FRP Hotsick Voltage detection levels 11kV & 33 kV	Contact type voltage detectors are available with voltage detection range starting from 1kV, not 415V. We are requesting you to accept Contact Voltage Detector with range 1 kV- 36kV.	Shall be as per tender specification only.