

Name of Distribution Licensee: BSES Rajdhani Power Limited												
Period of Outage: DECEMBER 2025												
Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1	01-12-2025	Part of : GANGOTRI ENCLAVE	430	Other Outage	Planned Outage	01-12-2025	11:06	01-12-2025	13:55	2:49	0.000939	INSTALLATION OF BUS BAR
2	01-12-2025	Part of : BLOCK F CHITTARANJAN PARK	457	Other Outage	Planned Outage	01-12-2025	11:01	01-12-2025	13:29	2:28	0.000000	REPLACEMENT OF HT BUSHING ROD
3	02-12-2025	Part of : A-BLOCK KALKA JI	470	Other Outage	Planned Outage	02-12-2025	11:31	02-12-2025	15:22	3:51	0.005775	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING
4	02-12-2025	Part of : GREATER KAILASH PART 3	166	Other Outage	Planned Outage	02-12-2025	11:30	02-12-2025	14:05	2:35	0.000861	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
5	02-12-2025	Part of : BLOCK A HARIJAN COLONY GOVINDPURI KALKAJI	673	Other Outage	Planned Outage	02-12-2025	11:03	02-12-2025	14:05	3:02	0.000000	REPLACEMET OF HT BUSHING ROD
6	03-12-2025	Part of : TEHKHAND VILLAGE	1150	Other Outage	Planned Outage	03-12-2025	11:01	03-12-2025	13:43	2:42	0.002700	REPLACEMET OF HT BUSHING ROD
7	03-12-2025	Part of : E-BLOCK MASJID MOTH	522	Other Outage	Planned Outage	03-12-2025	11:00	03-12-2025	13:42	2:42	0.000900	INSTALLATION OF HT BOOTS,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
8	03-12-2025	Part of : L2-BLOCK LIG KALKA JI	729	Other Outage	Planned Outage	03-12-2025	11:01	03-12-2025	13:43	2:42	0.000000	REPLACEMENT OF LT BUSHING ROD
9	04-12-2025	Part of : D-BLOCK CR PARK	336	Other Outage	Planned Outage	04-12-2025	12:33	04-12-2025	14:45	2:12	0.000550	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
10	04-12-2025	Part of : A-BLOCK KALKA JI	914	Other Outage	Planned Outage	04-12-2025	11:08	04-12-2025	13:43	2:35	0.003875	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
11	05-12-2025	Part of : G&H-BLOCK CR PARK,POCKET 52 CHITTARANJAN PARK,E-BLOCK CR PARK,NRI COLONY MANDAKINI ENCLAVE ALAKNANDA	2497	Other Outage	Planned Outage	05-12-2025	11:40	05-12-2025	13:48	2:08	0.000711	INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
12	06-12-2025	Part of : L2-BLOCK LIG KALKA JI	543	Other Outage	Planned Outage	06-12-2025	11:00	06-12-2025	13:43	2:43	0.000000	REPLACEMENT OF HT BUSHING ROD
13	06-12-2025	Part of : NEHRU ENCLAVE KALKA JI	371	Other Outage	Planned Outage	06-12-2025	11:38	06-12-2025	13:42	2:04	0.003100	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
14	06-12-2025	Part of : A-BLOCK CHITTARANJAN PARK	145	Other Outage	Planned Outage	06-12-2025	11:38	06-12-2025	13:43	2:05	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
15	07-12-2025	Part of : CONTAINER DEPOT (HT CONSUMER)	1	Other Outage	Planned Outage	07-12-2025	13:37	07-12-2025	16:37	3:00	0.002000	TIGHTENING OF HARDWARE FITTINGS
16	07-12-2025	Part of : DSIDC OKHLA PHASE-1	111	Other Outage	Planned Outage	07-12-2025	10:58	07-12-2025	14:05	3:07	0.002078	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
17	07-12-2025	Part of : B-BLOCK OKHLA PHASE-1	78	Other Outage	Planned Outage	07-12-2025	10:47	07-12-2025	14:44	3:57	0.003292	REPLACEMENT OF CROSS-ARMS AND POLES
18	07-12-2025	Part of : SHAHEED RAJIV GANDHI COLONY GOVINDPURI	941	Other Outage	Planned Outage	07-12-2025	11:37	07-12-2025	14:43	3:06	0.003100	REPLACEMENT OF SILICAGEL IN BREATHER
19	08-12-2025	Part of : H-BLOCK MASJID MOTH,	481	Other Outage	Planned Outage	08-12-2025	11:01	08-12-2025	14:00	2:59	0.000994	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
20	08-12-2025	Part of : L1-BLOCK LIG KALKA JI,	18	Other Outage	Planned Outage	08-12-2025	11:02	08-12-2025	13:34	2:32	0.000000	REPLACEMENT OF LT BUSHING ROD
21	09-12-2025	Part of : GOVINDPURI EXTENSION GOVINDPURI KALKAJI	1095	Other Outage	Planned Outage	09-12-2025	11:39	09-12-2025	13:42	2:03	0.004783	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
22	09-12-2025	Part of : H-BLOCK CR PARK	429	Other Outage	Planned Outage	09-12-2025	11:20	09-12-2025	13:40	2:20	0.000389	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
23	09-12-2025	Part of : L1-BLOCK LIG KALKA JI	980	Other Outage	Planned Outage	09-12-2025	11:08	09-12-2025	13:41	2:33	0.000000	REPLACEMENT OF LT BUSHING ROD
24	10-12-2025	Part of : ACHARYA NARENDRA DEV COLLEGE (HT CONSUMER)	1	Other Outage	Unplanned Outage	10-12-2025	06:23	10-12-2025	07:14	0:51	0.000708	FAULT IN HT CONSUMER PANEL (ACHARYA NARENDRA DEV COLLEGE)
25	10-12-2025	Part of : SHIVALIK APARTMENT	242	Other Outage	Planned Outage	10-12-2025	11:01	10-12-2025	13:34	2:33	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
26	10-12-2025	Part of : GREATER KAILASH PART-3	531	Other Outage	Planned Outage	10-12-2025	11:11	10-12-2025	14:07	2:56	0.000978	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
27	11-12-2025	Part of : ARAWALI APARTMENT	208	Other Outage	Planned Outage	11-12-2025	10:57	11-12-2025	13:29	2:32	0.000000	REPLACEMENT OF LT BUSHING ROD
28	11-12-2025	Part of : GOVINDPURI	876	Other Outage	Planned Outage	11-12-2025	11:26	11-12-2025	13:58	2:32	0.005067	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
29	12-12-2025	Part of : DDA SHED OKHLA PHASE-1,B-BLOCK OKHLA PHASE-1	703	Other Outage	Unplanned Outage	12-12-2025	07:37	12-12-2025	08:19	0:42	0.000000	HT SYSTEM FAULT
30	12-12-2025	Part of : NARMADA APARTMENT,YAMUNA APARTMENT,L1-BLOCK LIG KALKA JI,ARAWALI SHOPPING CENTRE	2362	Other Outage	Planned Outage	12-12-2025	11:12	12-12-2025	15:06	3:54	0.000000	REPLACEMENT OF LT BUSHING ROD
31	12-12-2025	Part of : S-BLOCK GK-2,	582	Other Outage	Planned Outage	12-12-2025	11:05	12-12-2025	15:06	4:01	0.002008	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
32	12-12-2025	Part of : D-BLOCK CR PARK,	343	Other Outage	Planned Outage	12-12-2025	11:05	12-12-2025	15:07	4:02	0.000000	3PH DB REPLACEMENT,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
33	13-12-2025	Part of : BLOCK D HARIJAN COLONY GOVINDPURI KALKAJI	1863	Other Outage	Planned Outage	13-12-2025	11:07	13-12-2025	13:48	2:41	0.005367	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
34	13-12-2025	Part of : C-BLOCK CR PARK	404	Other Outage	Planned Outage	13-12-2025	11:31	13-12-2025	13:47	2:16	0.000000	3PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
35	14-12-2025	Part of : B-BLOCK OKHLA PHASE-1	500	Other Outage	Planned Outage	14-12-2025	11:12	14-12-2025	14:16	3:04	0.003578	REPLACEMENT OF HT BUSHING ROD
36	15-12-2025	Part of : TIKONA PARK GK-2	339	Other Outage	Planned Outage	15-12-2025	11:01	15-12-2025	14:00	2:59	0.001243	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
37	15-12-2025	Part of : COMMUNITY CENTER CUM LIBRARY ALAKNANDA	7	Other Outage	Planned Outage	15-12-2025	10:58	15-12-2025	13:59	3:01	0.000000	REPLACEMENT OF LT BUSHING ROD
38	16-12-2025	Part of : TUGHLAKABAD EXTN,	2321	Other Outage	Planned Outage	16-12-2025	12:53	16-12-2025	14:27	1:34	0.000000	MAINTENANCE OF RMU
39	16-12-2025	Part of : E-BLOCK CR PARK,	324	Other Outage	Planned Outage	16-12-2025	12:53	16-12-2025	14:29	1:36	0.003200	MAINTENANCE OF TRANSFORMER
40	16-12-2025	Part of : W-BLOCK GK-2,	679	Other Outage	Planned Outage	16-12-2025	12:55	16-12-2025	14:28	1:33	0.000775	MAINTENANCE OF TRANSFORMER
41	16-12-2025	Part of : GANGA APARTMENT,	201	Other Outage	Planned Outage	16-12-2025	11:05	16-12-2025	14:27	3:22	0.000000	MAINTENANCE OF TRANSFORMER
42	17-12-2025	Part of : L1-BLOCK LIG KALKA JI	129	Other Outage	Planned Outage	17-12-2025	11:00	17-12-2025	13:46	2:46	0.000000	REPLACEMENT OF LT BUSHING ROD
43	17-12-2025	Part of : C-BLOCK CR PARK	353	Other Outage	Planned Outage	17-12-2025	11:17	17-12-2025	13:51	2:34	0.000000	DB REPLACEMENT,CONDUCTOR REPLACEMENT PER SPAN
44	18-12-2025	Part of : L1-BLOCK LIG KALKA JI	275	Other Outage	Planned Outage	18-12-2025	11:28	18-12-2025	13:24	1:56	0.000000	REPLACEMENT OF HT BUSHING ROD
45	18-12-2025	Part of : GOVINDPURI EXTENSION KALKAJI	3	Other Outage	Planned Outage	18-12-2025	11:17	18-12-2025	13:47	2:30	0.004167	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
46	19-12-2025	Part of : D-BLOCK OKHLA PHASE-1,SEWAGE PUMP OKHLA PHASE-1	165	Other Outage	Unplanned Outage	19-12-2025	16:37	19-12-2025	17:35	0:58	0.000306	CABLE FAULT
47	19-12-2025	Part of : DSIDC OKHLA PHASE-1	1850	Other Outage	Unplanned Outage	19-12-2025	13:16	19-12-2025	13:57	0:41	0.000638	CABLE FAULT
48	19-12-2025	Part of : YAMUNA APARTMENT	768	Other Outage	Planned Outage	19-12-2025	11:00	19-12-2025	14:19	3:19	0.000000	REPLACEMENT OF LT BUSHING ROD
49	19-12-2025	Part of : E-BLOCK CR PARK	602	Other Outage	Planned Outage	19-12-2025	11:20	19-12-2025	14:21	3:01	0.001508	INSTALLATION OF BUS BAR,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
50	20-12-2025	Part of : GOVINDPURI,	652	Other Outage	Planned Outage	20-12-2025	11:49	20-12-2025	13:54	2:05	0.004167	MAINTENANCE OF TRANSFORMER
51	20-12-2025	Part of : TUGHLAKABAD EXTN,	357	Other Outage	Planned Outage	20-12-2025	11:51	20-12-2025	13:56	2:05	0.000000	MAINTENANCE OF RMU
52	21-12-2025	Part of : F-BLOCK OKHLA PHASE-1	421	Other Outage	Planned Outage	21-12-2025	10:58	21-12-2025	13:42	2:44	0.005011	REPLACEMENT OF HT BUSHING ROD
53	22-12-2025	Part of : W-BLOCK GK-2	340	Other Outage	Planned Outage	22-12-2025	11:07	22-12-2025	13:53	2:46	0.001614	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
54	22-12-2025	Part of : J 3-BLOCK GOVINDPURI KALKAJI	887	Other Outage	Planned Outage	22-12-2025	10:59	22-12-2025	13:22	2:23	0.000000	REPLACEMENT OF HT BUSHING ROD
55	23-12-2025	Part of : S-BLOCK GK-2,M-BLOCK GK-2	1191	Other Outage	Planned Outage	23-12-2025	11:03	23-12-2025	13:45	2:42	0.000900	INSTALLATION OF HT BOOTS,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
56	23-12-2025	Part of : NEHRU ENCLAVE KALKA JI	317	Other Outage	Planned Outage	23-12-2025	11:03	23-12-2025	13:43	2:40	0.004444	REPLACEMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
57	23-12-2025	Part of : J2-BLOCK DDA FLAT KALKA JI	2212	Other Outage	Planned Outage	23-12-2025	11:02	23-12-2025	13:44	2:42	0.000000	REPLACEMENT OF LT BUSHING ROD
58	24-12-2025	Part of : MANGALA APARTMENT,	466	Other Outage	Planned Outage	24-12-2025	12:06	24-12-2025	14:43	2:37	0.003489	MAINTENANCE OF TRANSFORMER
59	24-12-2025	Part of : BLOCK E ENCLAVE 2 GREATER KAILASH,	270	Other Outage	Planned Outage	24-12-2025	12:03	24-12-2025	14:19	2:16	0.000756	MAINTENANCE OF TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
60	25-12-2025	Part of : E-BLOCK KALKA JI	976	Other Outage	Planned Outage	25-12-2025	11:14	25-12-2025	13:57	2:43	0.004528	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
61	26-12-2025	Part of : DJB ESI OKHLA PH-I	0	Other Outage	Unplanned Outage	26-12-2025	15:07	26-12-2025	15:59	0:52	0.000072	CABLE FAULT
62	26-12-2025	Part of : BLOCK E ENCLAVE 3 GREATER KAILASH	146	Other Outage	Planned Outage	26-12-2025	11:12	26-12-2025	13:56	2:44	0.000456	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
63	26-12-2025	Part of : J2-BLOCK DDA FLAT KALKA JI	477	Other Outage	Planned Outage	26-12-2025	10:58	26-12-2025	13:57	2:59	0.000000	REPLACEMENT OF HT BUSHING ROD
64	26-12-2025	Part of : C-BLOCK CR PARK	404	Other Outage	Planned Outage	26-12-2025	11:12	26-12-2025	13:54	2:42	0.000000	LT CIRCUIT MAINTENANCE
65	28-12-2025	Part of : DSIDC OKHLA PHASE-1,	1709	Other Outage	Planned Outage	28-12-2025	10:57	28-12-2025	13:57	3:00	0.002500	REPLACEMENT OF LT BUSHING ROD
66	29-12-2025	Part of : TARA APARTMENT	182	Other Outage	Planned Outage	29-12-2025	11:00	29-12-2025	13:19	2:19	0.000000	REPLACEMENT OF LT BUSHING ROD
67	29-12-2025	Part of : G-BLOCK CR PARK	259	Other Outage	Planned Outage	29-12-2025	11:42	29-12-2025	14:13	2:31	0.000629	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
68	30-12-2025	Part of : GANGOTRI ENCLAVE	198	Other Outage	Planned Outage	30-12-2025	11:02	30-12-2025	13:51	2:49	0.000704	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR
69	30-12-2025	Part of : ALAKNANDA SHOPPING COMPLEX	276	Other Outage	Planned Outage	30-12-2025	11:06	30-12-2025	13:51	2:45	0.000000	REPLACEMENT OF HT BUSHING ROD
70	30-12-2025	Part of : C-BLOCK CR PARK	353	Other Outage	Planned Outage	30-12-2025	11:00	30-12-2025	13:50	2:50	0.000000	LT CIRCUIT MAINTENANCE WORK
71	31-12-2025	Part of : D-BLOCK CR PARK	569	Other Outage	Planned Outage	31-12-2025	11:08	31-12-2025	14:32	3:24	0.000850	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE
72	01-12-2025	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR	183	Other Outage	Planned Outage	01-12-2025	12:01	01-12-2025	15:05	3:04	0.000511	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
73	01-12-2025	Part of : BHATI KALAN	448	Other Outage	Planned Outage	01-12-2025	11:37	01-12-2025	14:46	3:09	0.001575	FEEDER PILLAR CLEANING
74	01-12-2025	Part of : DLF FARMS	6	Other Outage	Planned Outage	01-12-2025	10:51	01-12-2025	14:37	3:46	0.000000	REPLACEMENT OF FAULTY END BOX
75	01-12-2025	Part of : CHANDAN HOLA	74	Other Outage	Planned Outage	01-12-2025	11:07	01-12-2025	14:13	3:06	0.002583	BUS BAR REPLACEMENT PER PHASE
76	01-12-2025	Part of : BLOCK A1 CHHATARPUR VILLAGE CHHATARPUR	774	Other Outage	Planned Outage	01-12-2025	10:34	01-12-2025	13:54	3:20	0.002778	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
77	01-12-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR	599	Other Outage	Planned Outage	01-12-2025	10:56	01-12-2025	14:21	3:25	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
78	02-12-2025	Part of : C-BLOCK CHHATARPUR EXTENSION	1715	Other Outage	Unplanned Outage	02-12-2025	10:14	02-12-2025	11:08	0:54	0.000840	BIRDAGE
79	02-12-2025	Part of : BHATI KALAN	607	Other Outage	Planned Outage	02-12-2025	13:12	02-12-2025	15:42	2:30	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION
80	02-12-2025	Part of : SULTANPUR	230	Other Outage	Planned Outage	02-12-2025	13:40	02-12-2025	15:43	2:03	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
81	02-12-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS	3551	Other Outage	Planned Outage	02-12-2025	10:52	02-12-2025	14:55	4:03	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
82	02-12-2025	Part of : POCKET D DR AMBEDKAR COLONY CHHATARPUR,RAJPUR KHURD VILLAGE	1536	Other Outage	Planned Outage	02-12-2025	10:13	02-12-2025	14:03	3:50	0.000000	GUARD WIRES SAGGING
83	02-12-2025	Part of : AYA NAGAR VILLAGE	1436	Other Outage	Planned Outage	02-12-2025	10:53	02-12-2025	15:06	4:13	0.000984	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
84	02-12-2025	Part of : BHATI KALAN	406	Other Outage	Planned Outage	02-12-2025	10:41	02-12-2025	13:15	2:34	0.000000	BUS BAR REPLACEMENT PER PHASE
85	03-12-2025	Part of : AYA NAGAR VILLAGE	772	Other Outage	Planned Outage	03-12-2025	14:33	03-12-2025	15:57	1:24	0.000000	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
86	03-12-2025	Part of : SAT BARI	148	Other Outage	Planned Outage	03-12-2025	10:48	03-12-2025	13:36	2:48	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION
87	03-12-2025	Part of : DR AMBEDKAR COLONY CHHATARPUR	1038	Other Outage	Planned Outage	03-12-2025	10:49	03-12-2025	13:02	2:13	0.000000	GUARD WIRES SAGGING PER SPAN
88	03-12-2025	Part of : JAUNAPUR VILLAGE	887	Other Outage	Planned Outage	03-12-2025	10:09	03-12-2025	15:02	4:53	0.000000	1PH DB REPLACEMENT,3PH DB REPLACEMENT
89	04-12-2025	Part of : ASOLA,BHATI KALAN,ASOLA WILD LIFE SANCTUARY ASOLA	618	Other Outage	Planned Outage	04-12-2025	14:18	04-12-2025	17:29	3:11	0.000106	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
90	04-12-2025	Part of : PHASE 2 CHHATARPUR ENCLAVE CHHATARPUR,CHHATARPUR ENCLAVE	972	Other Outage	Planned Outage	04-12-2025	10:43	04-12-2025	14:07	3:24	0.000000	GUARD WIRES SAGGING PER SPAN
91	04-12-2025	Part of : AYA NAGAR PHASE 1 AYA NAGAR	944	Other Outage	Planned Outage	04-12-2025	10:52	04-12-2025	16:03	5:11	0.000000	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
92	05-12-2025	Part of : BHATI KALAN,ASOLA,DERA VILLAGE	6563	Other Outage	Unplanned Outage	05-12-2025	07:58	05-12-2025	08:41	0:43	0.001851	BIRDAGE
93	05-12-2025	Part of : DR AMBEDKAR COLONY CHHATARPUR,MITTAL GARDEN SAINIK FARM,BUTTERFLY PARK QILA RAI PITHORA SAINIK FARM	3113	Other Outage	Planned Outage	05-12-2025	15:30	05-12-2025	16:25	0:55	0.000000	GUARD WIRES SAGGING PER SPAN
94	05-12-2025	Part of : CHHATARPUR	21	Other Outage	Planned Outage	05-12-2025	12:32	05-12-2025	15:19	2:47	0.000000	REPLACEMET OF HT BUSHING ROD
95	05-12-2025	Part of : PHASE 2 CHHATARPUR ENCLAVE CHHATARPUR	54	Other Outage	Planned Outage	05-12-2025	10:43	05-12-2025	14:14	3:31	0.000000	REPLACEMENT OF LT BUSHING ROD
96	05-12-2025	Part of : GADPUR FARM DLF FARMS	622	Other Outage	Planned Outage	05-12-2025	10:09	05-12-2025	13:56	3:47	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING
97	05-12-2025	Part of : AYA NAGAR VILLAGE AYA NAGAR	499	Other Outage	Planned Outage	05-12-2025	11:07	05-12-2025	13:50	2:43	0.000000	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
98	06-12-2025	Part of : RAJPUR KHURD EXTENSION,CHHATARPUR,JAUNAPUR VILLAGE	578	Other Outage	Unplanned Outage	06-12-2025	10:37	06-12-2025	11:43	1:06	0.001008	CABLE FAULT
99	06-12-2025	Part of : CHHATARPUR ENCLAVE PHASE 1	990	Other Outage	Planned Outage	06-12-2025	14:23	06-12-2025	16:29	2:06	0.000000	REPLACEMENT OF FAULTY END BOX
100	06-12-2025	Part of : G & E-BLOCK AYA NAGAR EXTENSION,ADARSH ENCLAVE AYA,AYA NAGAR PHASE 1,SULTANPUR,GADPUR FARM DLF FARMS,MANGLAPURI VILLAGE,AMBEDKAR COLONY	6235	Other Outage	Planned Outage	06-12-2025	11:12	06-12-2025	15:48	4:36	0.006900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
101	06-12-2025	Part of : AMBEDKAR COLONY,GADAIPUR DLF FARMS,AYA NAGAR PHASE 1,AYA NAGAR VILLAGE,ADARSH ENCLAV,G-BLOCK AYA NAGAR EXTENSION	2794	Other Outage	Planned Outage	06-12-2025	11:13	06-12-2025	15:49	4:36	0.003833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
102	06-12-2025	Part of : DR AMBEDKAR COLONY CHHATARPUR,RAJPUR KHURD VILLAGE	1536	Other Outage	Planned Outage	06-12-2025	10:56	06-12-2025	14:09	3:13	0.000000	GUARD WIRES SAGGING
103	06-12-2025	Part of : SULTANPUR	1270	Other Outage	Planned Outage	06-12-2025	10:37	06-12-2025	14:09	3:32	0.000000	LT CIRCUIT MAINTENANCE WORK
104	08-12-2025	Part of : FATEHPUR BERI,ASOLA	1796	Other Outage	Unplanned Outage	08-12-2025	08:16	08-12-2025	08:49	0:33	0.000770	ELECTROCUTION OF MONKEY
105	08-12-2025	Part of : BLOCK F AYA NAGAR EXTENSION AYA NAGAR,	941	Other Outage	Planned Outage	08-12-2025	15:07	08-12-2025	15:58	0:51	0.000000	INSTALLATION OF BUS BAR
106	08-12-2025	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR,	183	Other Outage	Planned Outage	08-12-2025	15:04	08-12-2025	15:57	0:53	0.000162	INSTALLATION OF BUS BAR
107	08-12-2025	Part of : SULTANPUR,	86	Other Outage	Planned Outage	08-12-2025	15:05	08-12-2025	15:59	0:54	0.000165	INSTALLATION OF BUS BAR
108	08-12-2025	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR,	927	Other Outage	Planned Outage	08-12-2025	15:02	08-12-2025	15:55	0:53	0.000162	INSTALLATION OF BUS BAR
109	08-12-2025	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR,	1314	Other Outage	Planned Outage	08-12-2025	15:01	08-12-2025	15:55	0:54	0.000165	INSTALLATION OF BUS BAR
110	08-12-2025	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR,	1070	Other Outage	Planned Outage	08-12-2025	15:03	08-12-2025	15:56	0:53	0.000162	INSTALLATION OF BUS BAR
111	08-12-2025	Part of : DERA VILLAGE,JAUNAPUR VILLAGE JAUNAPUR,NEW GAWALPAHARI VILLAGE,FATEHPUR BERI,ASOLA,	530	Other Outage	Planned Outage	08-12-2025	13:29	08-12-2025	14:12	0:43	0.000000	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING,GUARD WIRE LACS INSTALLTION PER SPAN
112	08-12-2025	Part of : AYA NAGAR VILLAGE AYA NAGAR,	220	Other Outage	Planned Outage	08-12-2025	11:31	08-12-2025	12:33	1:02	0.000189	INSTALLATION OF BUS BAR
113	08-12-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR,	567	Other Outage	Planned Outage	08-12-2025	11:06	08-12-2025	15:11	4:05	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
114	08-12-2025	Part of : AYA NAGAR VILLAGE AYA NAGAR,	827	Other Outage	Planned Outage	08-12-2025	10:47	08-12-2025	15:15	4:28	0.001042	3PH DB REPLACEMENT,3PH DB REVAMPING
115	08-12-2025	Part of : POCKET B DR AMBEDKAR COLONY CHHATARPUR,DR AMBEDKAR COLONY CHHATARPUR,POCKET A DR AMBEDKAR COLONY CHHATARPUR,	2676	Other Outage	Planned Outage	08-12-2025	11:07	08-12-2025	14:02	2:55	0.000000	3PH HT AB END TERMINATION REPLACEMENT
116	09-12-2025	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	675	Other Outage	Planned Outage	09-12-2025	10:55	09-12-2025	14:00	3:05	0.000000	REPLACEMENT OF FAULTY END BOX
117	09-12-2025	Part of : BHATI KALAN,ASOLA,DERA VILLAGE,FATEHPUR BERI	8831	Other Outage	Planned Outage	09-12-2025	10:58	09-12-2025	13:58	3:00	0.000000	GUARD WIRES SAGGING PER SPAN,HT SLEEVE INSTALLATION PER SPAN,JUMPER REPLACEMENT PER POLE,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
118	09-12-2025	Part of : GADPUR FARM DLF FARMS,GADAIPUR DLF FARMS,GADAIPUR JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,SULTANPUR	1494	Other Outage	Planned Outage	09-12-2025	10:55	09-12-2025	14:55	4:00	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
119	09-12-2025	Part of : AYA NAGAR VILLAGE AYA NAGAR	578	Other Outage	Planned Outage	09-12-2025	10:56	09-12-2025	14:54	3:58	0.000000	3PH DB REPLACEMENT,CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE
120	10-12-2025	Part of : SAT BARI,ANSAL VILLAS	3542	Other Outage	Planned Outage	10-12-2025	12:30	10-12-2025	13:19	0:49	0.000000	CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT,CONNECTING OF NEW EARTHING PER EARTHING
121	10-12-2025	Part of : AYA NAGAR EXTENSION PHASE-V	935	Other Outage	Planned Outage	10-12-2025	13:17	10-12-2025	14:26	1:09	0.000192	TIGHTENEING OF NUT BOLT
122	10-12-2025	Part of : AYA NAGAR EXTENSION PHASE-V	183	Other Outage	Planned Outage	10-12-2025	11:34	10-12-2025	13:17	1:43	0.000286	TIGHTENEING OF NUT BOLT
123	10-12-2025	Part of : F-BLOCK AYA NAGAR EXTENSION	953	Other Outage	Planned Outage	10-12-2025	11:34	10-12-2025	13:16	1:42	0.000283	TIGHTENEING OF NUT BOLT
124	10-12-2025	Part of : MITTAL GARDEN SAINIK FARM,DR AMBEDKAR COLONY CHHATARPUR	218	Other Outage	Planned Outage	10-12-2025	14:55	10-12-2025	17:22	2:27	0.000000	3PH HT AB CABLE REPLACEMENT
125	10-12-2025	Part of : POCKET D DR AMBEDKAR COLONY CHHATARPUR	211	Other Outage	Planned Outage	10-12-2025	12:54	10-12-2025	15:13	2:19	0.000000	REPLACEMENT OF HT/LT CLEATS
126	10-12-2025	Part of : C-BLOCK CHHATARPUR EXTENSION	167	Other Outage	Planned Outage	10-12-2025	10:24	10-12-2025	13:26	3:02	0.001011	REPLACEMENT OF HT BUSHING ROD
127	10-12-2025	Part of : SULTANPUR	1006	Other Outage	Planned Outage	10-12-2025	10:44	10-12-2025	14:18	3:34	0.000000	LT CIRCUIT MAINTENANCE
128	11-12-2025	Part of : BLOCK G AYA NAGAR EXTENSION	1078	Other Outage	Planned Outage	11-12-2025	14:27	11-12-2025	15:05	0:38	0.000106	TIGHTENEING OF NUT BOLT
129	11-12-2025	Part of : AYA NAGAR VILLAGE	223	Other Outage	Planned Outage	11-12-2025	14:26	11-12-2025	15:02	0:36	0.000100	TIGHTENEING OF NUT BOLT
130	11-12-2025	Part of : BLOCK G AYA NAGAR EXTENSION	1303	Other Outage	Planned Outage	11-12-2025	14:29	11-12-2025	15:04	0:35	0.000097	TIGHTENEING OF NUT BOLT
131	11-12-2025	Part of : BLOCK C CHHATARPUR EXTENSION,BLOCK A1,D & F CHHATARPUR VILLAGE	4578	Other Outage	Planned Outage	11-12-2025	10:52	11-12-2025	14:17	3:25	0.000000	3PH HT AB END TERMINATION REPLACEMENT
132	11-12-2025	Part of : SULTANPUR	564	Other Outage	Planned Outage	11-12-2025	10:57	11-12-2025	15:01	4:04	0.000949	3PH DB REVAMPING,LT AB SAGGING PER SPAN
133	11-12-2025	Part of : JAUNAPUR VILLAGE	601	Other Outage	Planned Outage	11-12-2025	12:31	11-12-2025	15:31	3:00	0.000000	3PH DB REPLACEMENT,INSULATOR REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
134	12-12-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,RAJPUR KHURD VILLAGE CHHATARPUR,	924	Other Outage	Planned Outage	12-12-2025	10:41	12-12-2025	11:01	0:20	0.000000	REPLACEMENT OF LT BUSHING ROD
135	12-12-2025	Part of : DLF FARMS,	20	Other Outage	Planned Outage	12-12-2025	14:21	12-12-2025	15:48	1:27	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
136	12-12-2025	Part of : AMBEDKAR COLONY AYA NAGAR,	271	Other Outage	Planned Outage	12-12-2025	11:45	12-12-2025	13:15	1:30	0.000250	TIGHTENEING OF NUT BOLT
137	12-12-2025	Part of : AYA NAGAR PHASE 1 AYA NAGAR,	28	Other Outage	Planned Outage	12-12-2025	11:44	12-12-2025	13:15	1:31	0.000253	TIGHTENEING OF NUT BOLT
138	12-12-2025	Part of : SULTANPUR,	87	Other Outage	Planned Outage	12-12-2025	11:44	12-12-2025	13:13	1:29	0.000247	TIGHTENEING OF NUT BOLT
139	12-12-2025	Part of : GADPUR FARM DLF FARMS,	517	Other Outage	Planned Outage	12-12-2025	10:40	12-12-2025	14:28	3:48	0.000000	3PH DB REPLACEMENT
140	12-12-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,	221	Other Outage	Planned Outage	12-12-2025	10:44	12-12-2025	14:02	3:18	0.000000	3PH HT AB END TERMINATION REPLACEMENT
141	12-12-2025	Part of : SULTANPUR,JAUNAPUR VILLAGE JAUNAPUR,RADHEY MOHAN DRIVE,DLF FARMS	72	Other Outage	Planned Outage	12-12-2025	10:41	12-12-2025	14:50	4:09	0.001660	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
142	13-12-2025	Part of : ANSAL VILLAS SAT BARI	19	Other Outage	Planned Outage	13-12-2025	12:39	13-12-2025	13:29	0:50	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
143	13-12-2025	Part of : FATEHPUR BERI	29	Other Outage	Planned Outage	13-12-2025	11:58	13-12-2025	13:47	1:49	0.000000	1PH DB REPLACEMENT,3PH DB REPLACEMENT,3PH DB REVAMPING,INSTALLATION OF PHASE SEPERATOR PER SPAN
144	13-12-2025	Part of : BHATI KALAN	1090	Other Outage	Planned Outage	13-12-2025	12:18	13-12-2025	13:28	1:10	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
145	13-12-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR	2	Other Outage	Planned Outage	13-12-2025	11:58	13-12-2025	13:46	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
146	13-12-2025	Part of : AMBEDKAR COLONY MANDI	511	Other Outage	Planned Outage	13-12-2025	11:30	13-12-2025	12:31	1:01	0.000407	1PH DB REPLACEMENT,3PH DB REVAMPING,LT AB SAGGING PER SPAN
147	13-12-2025	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR	1183	Other Outage	Planned Outage	13-12-2025	12:02	13-12-2025	14:24	2:22	0.000394	TIGHTENEING OF NUT BOLT
148	13-12-2025	Part of : POCKET A & B DR AMBEDKAR COLONY CHHATARPUR,DR AMBEDKAR COLONY CHHATARPUR	147	Other Outage	Planned Outage	13-12-2025	10:22	13-12-2025	14:19	3:57	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
149	15-12-2025	Part of : ASOLA	2	Other Outage	Planned Outage	15-12-2025	14:30	15-12-2025	14:48	0:18	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE
150	15-12-2025	Part of : DERA VILLAGE	6	Other Outage	Planned Outage	15-12-2025	11:09	15-12-2025	11:41	0:32	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
151	15-12-2025	Part of : DERA VILLAGE	7	Other Outage	Planned Outage	15-12-2025	11:42	15-12-2025	12:27	0:45	0.000000	1PH DB REPLACEMENT
152	15-12-2025	Part of : DERA VILLAGE	313	Other Outage	Planned Outage	15-12-2025	15:06	15-12-2025	16:10	1:04	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
153	15-12-2025	Part of : BLOCK C CHHATARPUR EXTENSION,BLOCK A1 CHHATARPUR VILLAGE ,ANSAL VILLAS SAT BARI	881	Other Outage	Planned Outage	15-12-2025	15:01	15-12-2025	16:42	1:41	0.000000	REPLACEMET OF FAULTY END BOX
154	15-12-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,RAJPUR KHURD VILLAGE CHHATARPUR	925	Other Outage	Planned Outage	15-12-2025	12:22	15-12-2025	14:26	2:04	0.000000	REPLACEMET OF HT BUSHING ROD
155	15-12-2025	Part of : PHASE 1 CHHATARPUR ENCLAVE	997	Other Outage	Planned Outage	15-12-2025	12:35	15-12-2025	15:21	2:46	0.000461	REPLACEMET OF HT BUSHING ROD
156	15-12-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	160	Other Outage	Planned Outage	15-12-2025	10:20	15-12-2025	13:55	3:35	0.001194	REPLACEMENT OF LT BUSHING ROD
157	15-12-2025	Part of : BHATI KALAN	2	Other Outage	Planned Outage	15-12-2025	11:16	15-12-2025	14:22	3:06	0.000000	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER
158	15-12-2025	Part of : SULTANPUR	385	Other Outage	Planned Outage	15-12-2025	10:40	15-12-2025	12:57	2:17	0.000533	1PH DB REPLACEMENT,3PH DB REVAMPING,LT AB SAGGING PER SPAN
159	15-12-2025	Part of : AMBEDKAR COLONY AYA NAGAR	271	Other Outage	Planned Outage	15-12-2025	11:21	15-12-2025	13:59	2:38	0.000000	3PH DB REPLACEMENT
160	16-12-2025	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION AYA NAGAR,	1138	Other Outage	Planned Outage	16-12-2025	12:03	16-12-2025	12:32	0:29	0.000081	MAINTENANCE OF TRANSFORMER
161	16-12-2025	Part of : AYA NAGAR PHASE 1 AYA NAGAR,	318	Other Outage	Planned Outage	16-12-2025	11:02	16-12-2025	12:10	1:08	0.000000	MAINTENANCE OF LT CIRCUIT
162	16-12-2025	Part of : ANSAL VILLAS SAT BARI,	1	Other Outage	Planned Outage	16-12-2025	11:52	16-12-2025	13:34	1:42	0.000000	MAINTENANCE OF HT CIRCUIT
163	16-12-2025	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION AYA NAGAR,	64	Other Outage	Planned Outage	16-12-2025	10:34	16-12-2025	12:08	1:34	0.000261	MAINTENANCE OF TRANSFORMER
164	16-12-2025	Part of : RADHEY MOHAN DRIVE,	3	Other Outage	Planned Outage	16-12-2025	11:52	16-12-2025	13:36	1:44	0.000000	MAINTENANCE OF HT CIRCUIT
165	16-12-2025	Part of : DERA VILLAGE,	4	Other Outage	Planned Outage	16-12-2025	11:54	16-12-2025	13:31	1:37	0.000000	MAINTENANCE OF HT CIRCUIT
166	16-12-2025	Part of : CHHATARPUR,	21	Other Outage	Planned Outage	16-12-2025	12:28	16-12-2025	15:26	2:58	0.000000	MAINTENANCE OF TRANSFORMER
167	16-12-2025	Part of : CHHATARPUR ENCLAVE CHHATARPUR,	573	Other Outage	Planned Outage	16-12-2025	11:52	16-12-2025	15:26	3:34	0.000000	MAINTENANCE OF TRANSFORMER
168	16-12-2025	Part of : BLOCK A1 CHHATARPUR VILLAGE CHHATARPUR,	842	Other Outage	Planned Outage	16-12-2025	10:39	16-12-2025	14:18	3:39	0.000000	MAINTENANCE OF RMU
169	16-12-2025	Part of : ASOLA WILD LIFE SANCTUARY ASOLA,	1	Other Outage	Planned Outage	16-12-2025	10:27	16-12-2025	13:39	3:12	0.000000	MAINTENANCE OF HT CIRCUIT
170	17-12-2025	Part of : DERA VILLAGE	49	Other Outage	Planned Outage	17-12-2025	15:32	17-12-2025	15:55	0:23	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION
171	17-12-2025	Part of : DERA VILLAGE	1	Other Outage	Planned Outage	17-12-2025	14:37	17-12-2025	15:33	0:56	0.000000	FEEDER PILLAR CLEANING
172	17-12-2025	Part of : MAIDAN GARHI VILLAGE CHHATARPUR	2	Other Outage	Planned Outage	17-12-2025	11:01	17-12-2025	11:55	0:54	0.000000	DB REPLACEMENT,DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,JUMPER REPLACEMENT PER POLE
173	17-12-2025	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR	828	Other Outage	Planned Outage	17-12-2025	14:54	17-12-2025	16:05	1:11	0.000197	TIGHTENEING OF NUT BOLT
174	17-12-2025	Part of : MANDI VILLAGE	271	Other Outage	Planned Outage	17-12-2025	14:21	17-12-2025	15:33	1:12	0.000280	DB REPLACEMENT,DB REVAMPING,LT AB SAGGING PER SPAN
175	17-12-2025	Part of : ANSAL VILLAS SAT BARI	38	Other Outage	Planned Outage	17-12-2025	11:56	17-12-2025	13:13	1:17	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION
176	17-12-2025	Part of : ASOLA	2	Other Outage	Planned Outage	17-12-2025	13:15	17-12-2025	14:37	1:22	0.000000	DB REPLACEMENT,DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,LT AB SAGGING PER SPAN
177	17-12-2025	Part of : RADHEY MOHAN DRIVE,JAUNAPUR VILLAGE JAUNAPUR,DLF FARMS,FATEHPUR BERI,CHANDAN HOLA,ANSAL VILLAS SAT BARI,BLOCK C CHHATARPUR EXTENSION	801	Other Outage	Planned Outage	17-12-2025	13:17	17-12-2025	16:26	3:09	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
178	17-12-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,ANSAL VILLAS SAT BARI	2233	Other Outage	Planned Outage	17-12-2025	11:18	17-12-2025	14:33	3:15	0.000000	HT AB CABLE REPLACEMENT PER SPAN
179	17-12-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	158	Other Outage	Planned Outage	17-12-2025	10:28	17-12-2025	14:19	3:51	0.001604	REPLACEMENT OF HT BUSHING ROD
180	18-12-2025	Part of : DERA VILLAGE	1	Other Outage	Planned Outage	18-12-2025	13:43	18-12-2025	14:32	0:49	0.000000	HT FEEDER PILLAR CLEANING
181	18-12-2025	Part of : RADHEY MOHAN DRIVE,JAUNAPUR VILLAGE,DLF FARMS,FATEHPUR BERI,CHANDAN HOLA,ANSAL VILLAS SAT BARI,C-BLOCK CHHATARPUR EXTENSION	801	Other Outage	Planned Outage	18-12-2025	13:42	18-12-2025	14:31	0:49	0.000000	HT FEEDER PILLAR CLEANING
182	18-12-2025	Part of : SAT BARI	10	Other Outage	Planned Outage	18-12-2025	12:47	18-12-2025	13:47	1:00	0.000000	HT FEEDER PILLAR CLEANING
183	18-12-2025	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR,	258	Other Outage	Planned Outage	18-12-2025	11:37	18-12-2025	12:35	0:58	0.000161	TIGHTENEING OF NUT BOLT
184	18-12-2025	Part of : GADPUR FARM DLF FARMS	17	Other Outage	Planned Outage	18-12-2025	11:18	18-12-2025	12:02	0:44	0.000122	TIGHTENEING OF NUT BOLT
185	18-12-2025	Part of : SAT BARI	241	Other Outage	Planned Outage	18-12-2025	12:03	18-12-2025	13:47	1:44	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
186	18-12-2025	Part of : FATEHPUR BERI	687	Other Outage	Planned Outage	18-12-2025	12:44	18-12-2025	14:29	1:45	0.000000	CHECKING OF EARTHING VALUE USING ONLINE TESTER,CONDUCTOR REPLACEMENT,CONNECTING OF NEW EARTHING PER EARTHING
187	18-12-2025	Part of : SAT BARI	3	Other Outage	Planned Outage	18-12-2025	12:06	18-12-2025	13:46	1:40	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION
188	18-12-2025	Part of : SULTANPUR	6	Other Outage	Planned Outage	18-12-2025	10:23	18-12-2025	11:42	1:19	0.000219	TIGHTENEING OF NUT BOLT
189	18-12-2025	Part of : MITTAL GARDEN SAINIK FARM,DR AMBEDKAR COLONY CHHATARPUR	218	Other Outage	Planned Outage	18-12-2025	10:14	18-12-2025	13:48	3:34	0.000000	3PH HT AB CABLE REPLACEMENT
190	18-12-2025	Part of : MANDI VILLAGE	795	Other Outage	Planned Outage	18-12-2025	11:11	18-12-2025	14:48	3:37	0.000000	LT CIRCUIT MAINTENANCE
191	18-12-2025	Part of : AYA NAGAR PHASE-1	954	Other Outage	Planned Outage	18-12-2025	10:30	18-12-2025	14:49	4:19	0.000000	LT CIRCUIT MAINTENANCE
192	19-12-2025	Part of : IGNOU CAMPUS (HTC)	1	Other Outage	Unplanned Outage	19-12-2025	17:38	19-12-2025	18:36	0:58	0.000000	HT SYSTEM FAULT
193	19-12-2025	Part of : SAT BARI	380	Other Outage	Planned Outage	19-12-2025	12:51	19-12-2025	14:19	1:28	0.000000	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER
194	19-12-2025	Part of : DERA VILLAGE	18	Other Outage	Planned Outage	19-12-2025	12:42	19-12-2025	14:28	1:46	0.000000	FEEDER PILLAR CLEANING
195	19-12-2025	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR	681	Other Outage	Planned Outage	19-12-2025	10:57	19-12-2025	12:07	1:10	0.000194	TIGHTENEING OF NUT BOLT
196	19-12-2025	Part of : BLOCK G AYA NAGAR EXTENSION	958	Other Outage	Planned Outage	19-12-2025	10:57	19-12-2025	13:05	2:08	0.000178	TIGHTENEING OF NUT BOLT
197	19-12-2025	Part of : JAUNAPUR VILLAGE	27	Other Outage	Planned Outage	19-12-2025	11:43	19-12-2025	14:27	2:44	0.000000	FEEDER PILLAR CLEANING
198	19-12-2025	Part of : DLF FARMS	15	Other Outage	Planned Outage	19-12-2025	10:37	19-12-2025	14:22	3:45	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
199	19-12-2025	Part of : DERA VILLAGE	16	Other Outage	Planned Outage	19-12-2025	11:45	19-12-2025	14:23	2:38	0.000000	FEEDER PILLAR CLEANING
200	19-12-2025	Part of : PHASE-V AYA NAGAR EXTENSION	828	Other Outage	Planned Outage	19-12-2025	11:21	19-12-2025	14:59	3:38	0.000000	3PH DB REVAMPING
201	20-12-2025	Part of : FATEHPUR BERI,	52	Other Outage	Planned Outage	20-12-2025	14:02	20-12-2025	14:54	0:52	0.000000	MAINTENANCE OF O/H HT CIRCUIT
202	20-12-2025	Part of : DERA VILLAGE,	1	Other Outage	Planned Outage	20-12-2025	14:03	20-12-2025	15:04	1:01	0.000000	MAINTENANCE OF O/H HT CIRCUIT
203	20-12-2025	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR,	936	Other Outage	Planned Outage	20-12-2025	10:43	20-12-2025	15:22	4:39	0.000000	MAINTENANCE OF LT CIRCUIT
204	20-12-2025	Part of : DLF FARMS,BLOCK C CHHATARPUR EXTENSION CHHATARPUR,	376	Other Outage	Planned Outage	20-12-2025	11:33	20-12-2025	14:11	2:38	0.000000	MAINTENANCE OF O/H HT CIRCUIT
205	20-12-2025	Part of : BHIM BASTI JUANAPUR,	2	Other Outage	Planned Outage	20-12-2025	10:21	20-12-2025	12:22	2:01	0.000000	MAINTENANCE OF LT CIRCUIT
206	22-12-2025	Part of : MANGLAPURI VILLAGE SULTANPUR	530	Other Outage	Planned Outage	22-12-2025	13:37	22-12-2025	14:21	0:44	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS
207	22-12-2025	Part of : CHANDAN HOLA,SAT BARI	1557	Other Outage	Planned Outage	22-12-2025	12:20	22-12-2025	14:46	2:26	0.000000	FEEDER PILLAR CLEANING
208	22-12-2025	Part of : FATEHPUR BERI	827	Other Outage	Planned Outage	22-12-2025	12:22	22-12-2025	14:47	2:25	0.000000	FEEDER PILLAR CLEANING
209	22-12-2025	Part of : GADPUR FARM DLF FARMS	205	Other Outage	Planned Outage	22-12-2025	10:37	22-12-2025	13:29	2:52	0.000669	3PH DB REPLACEMENT,3PH DB REVAMPING
210	22-12-2025	Part of : POCKET A & B DR AMBEDKAR COLONY CHHATARPUR	147	Other Outage	Planned Outage	22-12-2025	10:17	22-12-2025	14:30	4:13	0.000000	3PH HT AB CABLE REPLACEMENT
211	22-12-2025	Part of : AYA NAGAR EXTENSION PHASE-V	1251	Other Outage	Planned Outage	22-12-2025	10:44	22-12-2025	13:35	2:51	0.000000	LT CIRCUIT MAINTENANCE WORK
212	23-12-2025	Part of : AYA NAGAR PHASE 1	1	Other Outage	Planned Outage	23-12-2025	12:33	23-12-2025	12:49	0:16	0.000044	TIGHTENEING OF NUT BOLT
213	23-12-2025	Part of : AYA NAGAR PHASE 1	2	Other Outage	Planned Outage	23-12-2025	12:33	23-12-2025	12:49	0:16	0.000044	TIGHTENEING OF NUT BOLT
214	23-12-2025	Part of : DERA VILLAGE	21	Other Outage	Planned Outage	23-12-2025	13:37	23-12-2025	17:24	3:47	0.000000	FEEDER PILLAR CLEANING
215	23-12-2025	Part of : DR AMBEDKAR COLONY CHHATARPUR,MITTAL GARDEN SAINIK FARM,BUTTERFLY PARK QILA RAI PITHORA SAINIK FARM	3113	Other Outage	Planned Outage	23-12-2025	10:23	23-12-2025	14:20	3:57	0.000000	GUARD WIRES SAGGING PER SPAN
216	23-12-2025	Part of : DERA VILLAGE	106	Other Outage	Planned Outage	23-12-2025	11:09	23-12-2025	14:10	3:01	0.000000	FEEDER PILLAR CLEANING
217	23-12-2025	Part of : PHASE-V AYA NAGAR EXTENSION	183	Other Outage	Planned Outage	23-12-2025	10:55	23-12-2025	15:57	5:02	0.000000	3PH DB REVAMPING
218	24-12-2025	Part of : MANGLAPURI VILLAGE SULTANPUR,	630	Other Outage	Planned Outage	24-12-2025	12:39	24-12-2025	14:04	1:25	0.000000	MAINTENANCE OF LT CIRCUIT
219	24-12-2025	Part of : PHASE 2 CHHATARPUR ENCLAVE CHHATARPUR,CHHATARPUR ENCLAVE CHHATARPUR,	972	Other Outage	Planned Outage	24-12-2025	14:13	24-12-2025	16:33	2:20	0.000000	MAINTENANCE OF HT O/H CIRCUIT
220	24-12-2025	Part of : RAJPUR KHURD VILLAGE CHHATARPUR,	322	Other Outage	Planned Outage	24-12-2025	10:26	24-12-2025	14:03	3:37	0.001206	MAINTENANCE OF TRANSFORMER
221	24-12-2025	Part of : BLOCK E AYA NAGAR EXTENSION AYA NAGAR,	590	Other Outage	Planned Outage	24-12-2025	11:23	24-12-2025	15:04	3:41	0.000000	MAINTENANCE OF LT CIRCUIT
222	26-12-2025	Part of : DERA VILLAGE	137	Other Outage	Planned Outage	26-12-2025	10:52	26-12-2025	13:43	2:51	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION
223	26-12-2025	Part of : BLOCK A1,C,D,G&F CHHATARPUR VILLAGE CHHATARPUR	4578	Other Outage	Planned Outage	26-12-2025	10:49	26-12-2025	14:20	3:31	0.000000	3PH HT AB END TERMINATION REPLACEMENT
224	26-12-2025	Part of : DERA VILLAGE	571	Other Outage	Planned Outage	26-12-2025	10:52	26-12-2025	13:41	2:49	0.000000	REPLACEMENT OF HT BUSHING ROD
225	26-12-2025	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION	1481	Other Outage	Planned Outage	26-12-2025	11:06	26-12-2025	15:52	4:46	0.000874	3PH DB REVAMPING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
226	26-12-2025	Part of : SULTANPUR	42	Other Outage	Planned Outage	26-12-2025	10:52	26-12-2025	13:28	2:36	0.000000	LT CIRCUIT MAINTENANCE
227	27-12-2025	Part of : SULTANPUR	47	Other Outage	Planned Outage	27-12-2025	11:19	27-12-2025	11:58	0:39	0.000217	REPLACEMET OF HT BUSHING ROD
228	27-12-2025	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	575	Other Outage	Planned Outage	27-12-2025	11:19	27-12-2025	12:00	0:41	0.000569	REPLACEMENT OF LT BUSHING ROD
229	27-12-2025	Part of : BHATI KALAN	606	Other Outage	Planned Outage	27-12-2025	12:05	27-12-2025	13:54	1:49	0.000000	FEEDER COVER /SERVICE PILLAR COVER INSTALLTION
230	27-12-2025	Part of : GADPUR FARM DLF FARMS	21	Other Outage	Planned Outage	27-12-2025	10:50	27-12-2025	15:06	4:16	0.000000	3PH DB REPLACEMENT,3PH DB REVAMPING,JUMPER REPLACEMENT PER POLE
231	27-12-2025	Part of : BLOCK E AYA NAGAR EXTENSION	909	Other Outage	Planned Outage	27-12-2025	10:41	27-12-2025	15:08	4:27	0.000000	3PH DB REPLACEMENT
232	29-12-2025	Part of : ASOLA,ANSAL VILLAS SAT BARI,SAT BARI	811	Other Outage	Unplanned Outage	29-12-2025	04:10	29-12-2025	04:14	0:04	0.000018	HT SYSTEM FAULT
233	29-12-2025	Part of : GAWALPAHARI VILLAGE,NEW GAWALPAHARI VILLAGE,DERA VILLAGE	148	Other Outage	Unplanned Outage	29-12-2025	12:34	29-12-2025	12:57	0:23	0.000064	REPAIRING OF RMU
234	29-12-2025	Part of : CHANDAN HOLA	1	Other Outage	Planned Outage	29-12-2025	12:10	29-12-2025	13:44	1:34	0.000000	FEEDER PILLAR CLEANING
235	29-12-2025	Part of : SAT BARI	262	Other Outage	Planned Outage	29-12-2025	11:05	29-12-2025	13:41	2:36	0.000087	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
236	29-12-2025	Part of : BLOCK D CHHATARPUR VILLAGE CHHATARPUR,BLOCK C CHHATARPUR EXTENSION CHHATARPUR,CHHATARPUR,BLOCK G CHHATARPUR VILLAGE	4632	Other Outage	Planned Outage	29-12-2025	11:27	29-12-2025	13:41	2:14	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
237	29-12-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR	126	Other Outage	Planned Outage	29-12-2025	11:04	29-12-2025	13:52	2:48	0.000000	3PH DB REPLACEMENT,3PH DB REVAMPING,JUMPER REPLACEMENT PER POLE
238	29-12-2025	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION	279	Other Outage	Planned Outage	29-12-2025	10:43	29-12-2025	14:19	3:36	0.000000	3PH DB REPLACEMENT
239	30-12-2025	Part of : AYA NAGAR VILLAGE	1279	Other Outage	Planned Outage	30-12-2025	10:43	30-12-2025	12:08	1:25	0.001299	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER
240	30-12-2025	Part of : CHHATARPUR	21	Other Outage	Planned Outage	30-12-2025	12:47	30-12-2025	16:00	3:13	0.000536	REPLACEMENT OF HT BUSHING ROD
241	30-12-2025	Part of : DLF FARMS,CHHATARPUR,SULTANPUR	159	Other Outage	Planned Outage	30-12-2025	10:40	30-12-2025	14:25	3:45	0.000000	GUARD WIRES SAGGING
242	30-12-2025	Part of : G-BLOCK AYA NAGAR EXTENSION	373	Other Outage	Planned Outage	30-12-2025	10:43	30-12-2025	15:49	5:06	0.000000	LT CIRCUIT MAINTENANCE WORK
243	31-12-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	221	Other Outage	Planned Outage	31-12-2025	11:23	31-12-2025	13:10	1:47	0.000000	3PH HT AB END TERMINATION REPLACEMENT
244	31-12-2025	Part of : SAT BARI	241	Other Outage	Planned Outage	31-12-2025	11:37	31-12-2025	13:31	1:54	0.000000	FEEDER PILLAR CLEANING
245	01-12-2025	Part of : AYUR VIGYAN NAGAR SADIQ NAGAR	168	Other Outage	Planned Outage	01-12-2025	12:28	01-12-2025	13:15	0:47	0.000131	RELAY REPLACEMENT/VPI/FPI
246	01-12-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	520	Other Outage	Planned Outage	01-12-2025	11:38	01-12-2025	14:22	2:44	0.000911	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
247	01-12-2025	Part of : BLOCK C QUTAB INSTITUTIONAL AREA	57	Other Outage	Planned Outage	01-12-2025	11:16	01-12-2025	13:52	2:36	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
248	01-12-2025	Part of : SIRI FORT INSTITUTIONAL AREA SIRI FORT	16	Other Outage	Planned Outage	01-12-2025	10:43	01-12-2025	13:47	3:04	0.000051	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
249	01-12-2025	Part of : BLOCK B 6 HUMAYUNPUR SAFDARJUNG ENCLAVE	1442	Other Outage	Planned Outage	01-12-2025	11:19	01-12-2025	13:40	2:21	0.001175	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
250	02-12-2025	Part of : QUTAB HOTEL (HT CONSUMER)	1	Other Outage	Planned Outage	02-12-2025	11:34	02-12-2025	13:21	1:47	0.000149	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
251	02-12-2025	Part of : MASJID MOTH VILLAGE SOUTH EXTENSION II	1275	Other Outage	Planned Outage	02-12-2025	10:38	02-12-2025	13:12	2:34	0.000428	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
252	02-12-2025	Part of : BLOCK A SOAMI NAGAR	319	Other Outage	Planned Outage	02-12-2025	11:44	02-12-2025	15:10	3:26	0.000801	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
253	02-12-2025	Part of : MAYFAIR GARDEN HAUZ KHAS	304	Other Outage	Planned Outage	02-12-2025	12:53	02-12-2025	15:19	2:26	0.000203	ACB REPLACEMENT
254	03-12-2025	Part of : INDIAN INSTITUTE OF TECHNOLOGY DELHI HAUZ KHAS	262	Other Outage	Planned Outage	03-12-2025	12:25	03-12-2025	14:10	1:45	0.000233	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
255	03-12-2025	Part of : BLOCK C 4 SAFDARJUNG DEVELOPMENT AREA HAUZ KHAS	511	Other Outage	Planned Outage	03-12-2025	11:02	03-12-2025	12:39	1:37	0.000269	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
256	03-12-2025	Part of : BLOCK D SOAMI NAGAR SOUTH	507	Other Outage	Planned Outage	03-12-2025	12:13	03-12-2025	15:26	3:13	0.000965	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
257	04-12-2025	Part of : BLOCK A HAUZ KHAS	546	Other Outage	Planned Outage	04-12-2025	13:42	04-12-2025	15:47	2:05	0.000243	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
258	05-12-2025	Part of : DEER PARK HAUZ KHAS	373	Other Outage	Planned Outage	05-12-2025	11:05	05-12-2025	13:02	1:57	0.000812	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
259	05-12-2025	Part of : AYUR VIGYAN NAGAR SADIQ NAGAR	167	Other Outage	Planned Outage	05-12-2025	12:19	05-12-2025	13:55	1:36	0.000267	RELAY REPLACEMET/VPI/FPI

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
260	05-12-2025	Part of : POCKET A KATWARIA SARAI	128	Other Outage	Planned Outage	05-12-2025	11:23	05-12-2025	14:28	3:05	0.000514	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
261	06-12-2025	Part of : NISDOC (HT CONSUMER)	1	Other Outage	Planned Outage	06-12-2025	15:57	06-12-2025	16:27	0:30	0.000083	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
262	06-12-2025	Part of : M/S DIR OF WORKS MINE OF D,C-7 QLA (HT CONSUMER)	1	Other Outage	Planned Outage	06-12-2025	11:31	06-12-2025	13:31	2:00	0.000333	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
263	06-12-2025	Part of : KENDRIYA VIDYALAYA (HT CONSUMER)	1	Other Outage	Planned Outage	06-12-2025	11:30	06-12-2025	13:31	2:01	0.000336	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
264	06-12-2025	Part of : A-BLOCK SOUTH EXTENSION-2	1140	Other Outage	Planned Outage	06-12-2025	10:53	06-12-2025	14:07	3:14	0.001186	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
265	06-12-2025	Part of : INSTITUTE OF HOME ECONOMICS F-4 HAUZ KHAS (HT CONSUMER)	1	Other Outage	Planned Outage	06-12-2025	11:14	06-12-2025	13:29	2:15	0.000188	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
266	08-12-2025	Part of : HTC:QUTAB HOTEL	1	Other Outage	Planned Outage	08-12-2025	12:10	08-12-2025	13:36	1:26	0.000119	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,RELAY REPLACEMET/VPI/FPI
267	08-12-2025	Part of : BLOCK A 1 NAUROIJI NAGAR SAFDARJUNG ENCLAVE,	436	Other Outage	Planned Outage	08-12-2025	11:14	08-12-2025	13:12	1:58	0.000656	APPLY OF INSULATION TAPE HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
268	08-12-2025	Part of : BLOCK E KATWARIA SARAI,	93	Other Outage	Planned Outage	08-12-2025	11:40	08-12-2025	14:44	3:04	0.000256	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
269	08-12-2025	Part of : ASIAN GAMES VILLAGE COMPLEX SIRI FORT,	351	Other Outage	Planned Outage	08-12-2025	11:38	08-12-2025	15:18	3:40	0.000489	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
270	09-12-2025	Part of : SIRI FORT INSTITUTIONAL AREA SIRI FORT	3	Other Outage	Planned Outage	09-12-2025	10:36	09-12-2025	12:58	2:22	0.000197	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
271	10-12-2025	Part of : A 2-BLOCK NAUROI NAGAR SAFDARJUNG ENCLAVE	175	Other Outage	Planned Outage	10-12-2025	11:21	10-12-2025	13:21	2:00	0.000500	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
272	10-12-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	1132	Other Outage	Planned Outage	10-12-2025	11:20	10-12-2025	13:50	2:30	0.000417	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
273	10-12-2025	Part of : JIA SARAI HAUZ KHAS	1089	Other Outage	Planned Outage	10-12-2025	11:21	10-12-2025	14:36	3:15	0.000542	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
274	11-12-2025	Part of : SECTOR 1 SADIQ NAGAR	66	Other Outage	Unplanned Outage	11-12-2025	11:42	11-12-2025	12:34	0:52	0.000000	CHECK RMU PROTECTION CIRCUIT
275	11-12-2025	Part of : INDIAN INSTITUTE OF TECHNOLOGY DELHI HAUZ KHAS	331	Other Outage	Planned Outage	11-12-2025	14:22	11-12-2025	15:08	0:46	0.000038	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
276	11-12-2025	Part of : PANCHSHILA PARK NORTH	394	Other Outage	Planned Outage	11-12-2025	11:11	11-12-2025	14:59	3:48	0.000887	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
277	12-12-2025	Part of : YUSUF SARAI	551	Other Outage	Unplanned Outage	12-12-2025	15:14	12-12-2025	15:24	0:10	0.000000	HT SYSTEM FAULT
278	12-12-2025	Part of : BEER SARAI,	253	Other Outage	Planned Outage	12-12-2025	11:53	12-12-2025	13:07	1:14	0.000206	REPLACEMET OF FAULTY END BOX
279	12-12-2025	Part of : BLOCK B 3 SAFDARJUNG ENCLAVE,	214	Other Outage	Planned Outage	12-12-2025	11:17	12-12-2025	13:36	2:19	0.000579	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
280	12-12-2025	Part of : YUSUF SARAI,	543	Other Outage	Planned Outage	12-12-2025	10:57	12-12-2025	14:05	3:08	0.000261	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
281	13-12-2025	Part of : BLOCK A 1 NAUROI NAGAR SAFDARJUNG ENCLAVE	190	Other Outage	Unplanned Outage	13-12-2025	14:28	13-12-2025	16:22	1:54	0.000317	ATTENDING WEAK POINTS/HOT SPOT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
282	13-12-2025	Part of : NIFT (HTC)	1	Other Outage	Planned Outage	13-12-2025	11:38	13-12-2025	13:03	1:25	0.000236	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
283	13-12-2025	Part of : KARAMPA INTERNATIONAL, B19 & 20 (HTC)	1	Other Outage	Planned Outage	13-12-2025	12:25	13-12-2025	14:55	2:30	0.000417	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
284	15-12-2025	Part of : BLOCK N PANCHSHILA PARK NORTH PANCHSHILA PARK	164	Other Outage	Planned Outage	15-12-2025	14:39	15-12-2025	16:21	1:42	0.000085	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
285	16-12-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT,	734	Other Outage	Planned Outage	16-12-2025	14:00	16-12-2025	15:45	1:45	0.000233	MAINTENANCE OF TRANSFORMER
286	17-12-2025	Part of : AYUR VIGYAN NAGAR SADIQ NAGAR,ANDREWS GANJ EXTENSION ANDREWS GANJ	274	Other Outage	Unplanned Outage	17-12-2025	05:20	17-12-2025	06:23	1:03	0.000298	CABLE FAULT
287	17-12-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	1104	Other Outage	Planned Outage	17-12-2025	13:58	17-12-2025	15:48	1:50	0.000306	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
288	17-12-2025	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE	1757	Other Outage	Planned Outage	17-12-2025	11:22	17-12-2025	13:24	2:02	0.000678	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
289	18-12-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	521	Other Outage	Planned Outage	18-12-2025	13:21	18-12-2025	14:25	1:04	0.000036	LT ACB MAINTENANCE
290	19-12-2025	Part of : MAYFAIR GARDEN HAUZ KHAS	24	Other Outage	Planned Outage	19-12-2025	14:18	19-12-2025	17:19	3:01	0.000151	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
291	19-12-2025	Part of : POCKET B KATWARIA SARAI	1309	Other Outage	Planned Outage	19-12-2025	11:32	19-12-2025	15:17	3:45	0.000438	INSTALLATION OF BUS BAR
292	20-12-2025	Part of : BLOCK E HAUZ KHAS,	845	Other Outage	Planned Outage	20-12-2025	12:01	20-12-2025	14:57	2:56	0.000391	MAINTENANCE OF TRANSFORMER
293	20-12-2025	Part of : HTC:KALINDI BHAWAN QUTUB IND. AREA	1	Other Outage	Planned Outage	20-12-2025	12:22	20-12-2025	14:51	2:29	0.000124	MAINTENANCE OF RMU
294	21-12-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	421	Other Outage	Planned Outage	21-12-2025	13:35	21-12-2025	16:41	3:06	0.000362	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,END TERMINATION COVER REPLACEMENT,REPLACEMENT OF FAULTY END BOX
295	22-12-2025	Part of : DEER PARK HAUZ KHAS	626	Other Outage	Planned Outage	22-12-2025	11:22	22-12-2025	14:04	2:42	0.001125	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
296	22-12-2025	Part of : B 7-BLOCK ARJUN NAGAR SAFDARJUNG ENCLAVE	524	Other Outage	Planned Outage	22-12-2025	11:14	22-12-2025	14:12	2:58	0.001236	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
297	23-12-2025	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE	714	Other Outage	Planned Outage	23-12-2025	11:43	23-12-2025	14:41	2:58	0.001483	REPLACEMENT OF LT BUSHING ROD
298	23-12-2025	Part of : SECTOR 3 SADIQ NAGAR	523	Other Outage	Planned Outage	23-12-2025	11:12	23-12-2025	13:36	2:24	0.000360	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
299	23-12-2025	Part of : BLOCK Y HAUZ KHAS	346	Other Outage	Planned Outage	23-12-2025	11:51	23-12-2025	15:23	3:32	0.000353	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
300	24-12-2025	Part of : RBF STAFF QUARTERS MAYFAIR GARDEN HAUZ KHAS,	90	Other Outage	Planned Outage	24-12-2025	12:11	24-12-2025	14:22	2:11	0.000000	MAINTENANCE OF TRANSFORMER
301	24-12-2025	Part of : BLOCK D GULMOHAR PARK,	757	Other Outage	Planned Outage	24-12-2025	11:02	24-12-2025	13:52	2:50	0.001417	MAINTENANCE OF TRANSFORMER
302	24-12-2025	Part of : DEER PARK HAUZ KHAS,	190	Other Outage	Planned Outage	24-12-2025	11:28	24-12-2025	13:56	2:28	0.000411	MAINTENANCE OF TRANSFORMER
303	26-12-2025	Part of : MAYFAIR GARDEN HAUZ KHAS	294	Other Outage	Planned Outage	26-12-2025	12:10	26-12-2025	14:13	2:03	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
304	26-12-2025	Part of : SECTOR 1 SADIQ NAGAR	66	Other Outage	Planned Outage	26-12-2025	10:28	26-12-2025	13:11	2:43	0.000272	RELAY REPLACEMENT/VP/FP/
305	26-12-2025	Part of : JIA SARAI HAUZ KHAS	863	Other Outage	Planned Outage	26-12-2025	11:17	26-12-2025	15:01	3:44	0.000622	LT CIRCUIT MAINTENANCE
306	27-12-2025	Part of : ISI KATWARIA SARAI (HTC)	1	Other Outage	Planned Outage	27-12-2025	14:22	27-12-2025	15:21	0:59	0.000082	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
307	27-12-2025	Part of : AMERICAN EMBASSEY (HTC)	1	Other Outage	Planned Outage	27-12-2025	14:22	27-12-2025	15:22	1:00	0.000050	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
308	27-12-2025	Part of : MOFPI KHEL GAON SRIFORT COMPLEX (HTC)	1	Other Outage	Planned Outage	27-12-2025	11:30	27-12-2025	13:21	1:51	0.000093	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
309	27-12-2025	Part of : BLOCK A HAUZ KHAS	261	Other Outage	Planned Outage	27-12-2025	12:18	27-12-2025	15:45	3:27	0.000690	CONDUCTOR REPLACEMENT PER SPAN
310	27-12-2025	Part of : MASJID MOTH VILLAGE SOUTH EXTENSION II	1284	Other Outage	Planned Outage	27-12-2025	10:30	27-12-2025	14:39	4:09	0.001383	ACB REPLACEMENT PER ACB
311	29-12-2025	Part of : BLOCK S PANCHSHILA PARK SOUTH PANCHSHILA PARK	308	Other Outage	Planned Outage	29-12-2025	14:55	29-12-2025	16:24	1:29	0.000346	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
312	29-12-2025	Part of : PANCHSHILA PARK NORTH PANCHSHILA PARK	202	Other Outage	Planned Outage	29-12-2025	12:54	29-12-2025	16:59	4:05	0.000476	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
313	29-12-2025	Part of : IIFT (HTC)	1	Other Outage	Planned Outage	29-12-2025	11:56	29-12-2025	14:23	2:27	0.000123	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
314	29-12-2025	Part of : BLOCK C 3 SAFDARJUNG DEVELOPMENT AREA HAUZ KHAS	335	Other Outage	Planned Outage	29-12-2025	11:16	29-12-2025	13:31	2:15	0.000938	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE
315	30-12-2025	Part of : B 4-BLOCK SAFDARJUNG ENCLAVE	1784	Other Outage	Planned Outage	30-12-2025	12:40	30-12-2025	13:15	0:35	0.000097	TAPPING OF JUMPERS
316	30-12-2025	Part of : SECTOR 1 SADIQ NAGAR	1410	Other Outage	Planned Outage	30-12-2025	12:11	30-12-2025	14:20	2:09	0.000502	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
317	30-12-2025	Part of : FORE SCHOOL OF MANAGEMENT	1	Other Outage	Planned Outage	30-12-2025	11:16	30-12-2025	14:10	2:54	0.000242	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
318	30-12-2025	Part of : X-BLOCK HAUZ KHAS	154	Other Outage	Planned Outage	30-12-2025	11:29	30-12-2025	14:50	3:21	0.000614	LT CIRCUIT MAINTENANCE WORK
319	31-12-2025	Part of : GAUTAM NAGAR	418	Other Outage	Planned Outage	31-12-2025	15:15	31-12-2025	16:15	1:00	0.000000	LT AB SAGGING PER SPAN
320	31-12-2025	Part of : PANCHSHILA PARK NORTH PANCHSHILA PARK	310	Other Outage	Planned Outage	31-12-2025	11:18	31-12-2025	15:14	3:56	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
321	31-12-2025	Part of : BLOCK C 2 BHIM NAGAR HAUZ KHAS	210	Other Outage	Planned Outage	31-12-2025	11:08	31-12-2025	13:19	2:11	0.000364	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
322	01-12-2025	Part of : BLOCK B DEVL I SANGAM VIHAR	1184	Other Outage	Planned Outage	01-12-2025	11:05	01-12-2025	12:16	1:11	0.000217	REPLACEMENT OF HT BUSHING ROD
323	01-12-2025	Part of : BLOCK A PULPEHLADPUR	1	Other Outage	Planned Outage	01-12-2025	12:04	01-12-2025	15:07	3:03	0.000559	REPLACEMENT OF HT BUSHING ROD
324	01-12-2025	Part of : KHANPUR EXTENSION SANGAM VIHAR,KHANPUR VILLAGE KHANPUR,POCKET A DUGGAL COLONY KHANPUR,BLOCK G SECTOR 5 DAKSHINPURI,JAWAHAR PARK SANGAM VIHAR	1248	Other Outage	Planned Outage	01-12-2025	11:09	01-12-2025	13:44	2:35	0.000474	3PH HT AB CABLE REPLACEMENT PER SPAN
325	01-12-2025	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	566	Other Outage	Planned Outage	01-12-2025	11:07	01-12-2025	14:16	3:09	0.000578	REPLACEMENT OF LT BUSHING ROD
326	02-12-2025	Part of : BLOCK A PULPEHLADPUR	2	Other Outage	Planned Outage	02-12-2025	13:37	02-12-2025	14:10	0:33	0.000101	REPLACEMET OF HT BUSHING ROD
327	02-12-2025	Part of : BLOCK E SANGAM VIHAR	1659	Other Outage	Planned Outage	02-12-2025	10:59	02-12-2025	12:09	1:10	0.000214	REPLACEMENT OF LT BUSHING ROD
328	02-12-2025	Part of : MADANGIR VILLAGE	15	Other Outage	Planned Outage	02-12-2025	11:06	02-12-2025	13:48	2:42	0.000495	REPLACEMENT OF HT BUSHING ROD
329	02-12-2025	Part of : BLOCK B & HR PULPEHLADPUR	1	Other Outage	Planned Outage	02-12-2025	11:28	02-12-2025	14:09	2:41	0.000492	3PH HT AB CABLE REPLACEMENT
330	02-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	3748	Other Outage	Planned Outage	02-12-2025	10:02	02-12-2025	13:08	3:06	0.000568	3PH HT AB CABLE REPLACEMENT
331	03-12-2025	Part of : BLOCK B,C & L DEVL I SANGAM VIHAR	1	Other Outage	Planned Outage	03-12-2025	11:29	03-12-2025	14:04	2:35	0.000474	3PH HT AB CABLE REPLACEMENT PER SPAN
332	03-12-2025	Part of : BLOCK J DEVL I SANGAM VIHAR	1029	Other Outage	Planned Outage	03-12-2025	11:00	03-12-2025	14:21	3:21	0.000614	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
333	03-12-2025	Part of : BLOCK A PULPEHLADPUR	67	Other Outage	Planned Outage	03-12-2025	11:07	03-12-2025	13:57	2:50	0.000519	REPLACEMENT OF LT BUSHING ROD
334	03-12-2025	Part of : BLOCK L DEVL I SANGAM VIHAR,BLOCK J DEVL I SANGAM VIHAR	1408	Other Outage	Planned Outage	03-12-2025	10:13	03-12-2025	13:34	3:21	0.000614	3PH HT AB CABLE REPLACEMENT PER SPAN
335	04-12-2025	Part of : HAMDARD NAGAR,TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD,TALIMABAD SANGAM VIHAR	566	Other Outage	Unplanned Outage	04-12-2025	20:31	04-12-2025	21:12	0:41	0.000194	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
336	04-12-2025	Part of : POCKET B DUGGAL COLONY KHANPUR,TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD,JAWAHAR PARK SANGAM VIHAR	1683	Other Outage	Unplanned Outage	04-12-2025	17:28	04-12-2025	18:32	1:04	0.001867	HVDS FAULT
337	04-12-2025	Part of : BLOCK B DEVL I SANGAM VIHAR,BLOCK A TIGRI EXTENSION SANGAM VIHAR	1792	Other Outage	Planned Outage	04-12-2025	11:06	04-12-2025	12:08	1:02	0.000189	3PH HT AB CABLE REPLACEMENT PER SPAN
338	04-12-2025	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	2341	Other Outage	Planned Outage	04-12-2025	11:05	04-12-2025	13:50	2:45	0.000504	CONDUCTOR REPLACEMENT PER SPAN
339	04-12-2025	Part of : MADANGIR VILLAGE MADANGIR	2117	Other Outage	Planned Outage	04-12-2025	11:04	04-12-2025	13:51	2:47	0.000510	REPLACEMENT OF HT BUSHING ROD
340	04-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	3449	Other Outage	Planned Outage	04-12-2025	10:22	04-12-2025	13:20	2:58	0.000544	3PH HT AB CABLE REPLACEMENT PER SPAN
341	05-12-2025	Part of : VISHWAKARMA COLONY PULPEHLADPUR,DDA PARK LAL KUAN	1525	Other Outage	Planned Outage	05-12-2025	12:22	05-12-2025	14:53	2:31	0.000461	REPLACEMET OF HT BUSHING ROD
342	05-12-2025	Part of : BLOCK C PULPEHLADPUR	830	Other Outage	Planned Outage	05-12-2025	11:36	05-12-2025	14:07	2:31	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
343	05-12-2025	Part of : BLOCK B DEVL I SANGAM VIHAR	2329	Other Outage	Planned Outage	05-12-2025	11:17	05-12-2025	14:00	2:43	0.000498	3PH HT AB CABLE REPLACEMENT PER SPAN
344	05-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	3748	Other Outage	Planned Outage	05-12-2025	10:01	05-12-2025	12:57	2:56	0.000538	3PH HT AB CABLE REPLACEMENT PER SPAN
345	06-12-2025	Part of : RPS COLONY MADANGIR,POCKET A DUGGAL COLONY,KHANPUR EXTENSION,KHANPUR VILLAGE,G-BLOCK SECTOR 5 DAKSHINPURI,JAWAHAR PARK	1571	Other Outage	Unplanned Outage	06-12-2025	07:19	06-12-2025	08:11	0:52	0.000794	HVDS FAULT
346	06-12-2025	Part of : D-BLOCK JJ COLONY KHANPUR	550	Other Outage	Planned Outage	06-12-2025	13:12	06-12-2025	14:54	1:42	0.000312	3PH DB REPLACEMENT
347	06-12-2025	Part of : A,C,R & HR -BLOCK PULPEHLADPUR	850	Other Outage	Planned Outage	06-12-2025	12:06	06-12-2025	15:39	3:33	0.000651	3PH HT AB CABLE REPLACEMENT
348	06-12-2025	Part of : TALIMABAD SANGAM VIHAR	1375	Other Outage	Planned Outage	06-12-2025	11:06	06-12-2025	14:00	2:54	0.000532	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
349	06-12-2025	Part of : SHIV PARK DUGGAL COLONY,F-BLOCK KHANPUR COLONY,KHANPUR VILLAGE	16	Other Outage	Planned Outage	06-12-2025	11:15	06-12-2025	14:38	3:23	0.000620	3PH HT AB CABLE REPLACEMENT
350	06-12-2025	Part of : TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD	10	Other Outage	Planned Outage	06-12-2025	11:01	06-12-2025	14:02	3:01	0.000553	REPLACEMENT OF HT BUSHING ROD
351	06-12-2025	Part of : L,L 2 & J-BLOCK DEVL I SANGAM VIHAR	1408	Other Outage	Planned Outage	06-12-2025	10:01	06-12-2025	12:25	2:24	0.000440	3PH HT AB END TERMINATION REPLACEMENT
352	08-12-2025	Part of : RPS COLONY MADANGIR,	813	Other Outage	Planned Outage	08-12-2025	12:47	08-12-2025	17:55	5:08	0.000941	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
353	08-12-2025	Part of : BLOCK B VISHWAKARMA COLONY PULPEHLADPUR,BLOCK A VISHWAKARMA COLONY PULPEHLADPUR,BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,BLOCK C VISHWAKARMA COLONY PULPEHLADPUR,BLOCK C LAL KUAN,BLOCK F VISHWAKARMA COLONY PULPEHLADPUR.	1866	Other Outage	Planned Outage	08-12-2025	12:10	08-12-2025	15:09	2:59	0.000547	3PH HT AB CABLE REPLACEMENT PER SPAN
354	08-12-2025	Part of : BLOCK D SANGAM VIHAR,	993	Other Outage	Planned Outage	08-12-2025	11:22	08-12-2025	15:17	3:55	0.000718	DT REPLACEMENT
355	08-12-2025	Part of : BLOCK 4 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,	1655	Other Outage	Planned Outage	08-12-2025	11:06	08-12-2025	14:21	3:15	0.000596	ACB REPLACEMENT PER ACB
356	08-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,	3449	Other Outage	Planned Outage	08-12-2025	09:45	08-12-2025	13:15	3:30	0.000642	3PH HT AB CABLE REPLACEMENT PER SPAN
357	09-12-2025	Part of : BLOCK N SOUTH SAINIK FARM SAINIK FARM,DURGA VIHAR DEVL I SANGAM VIHAR,BLOCK L 2 DEVL I SANGAM VIHAR	2571	Other Outage	Unplanned Outage	09-12-2025	15:40	09-12-2025	16:05	0:25	0.000222	CABLE FAULT
358	09-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,BLOCK L DEVL I SANGAM VIHAR	6655	Other Outage	Unplanned Outage	09-12-2025	15:07	09-12-2025	15:59	0:52	0.000823	TREE BRANCH FALLEN ON HT O/H LINE
359	09-12-2025	Part of : BLOCK B SECTOR 5 DAKSHINPURI	969	Other Outage	Planned Outage	09-12-2025	13:24	09-12-2025	15:19	1:55	0.000351	DT REPLACEMENT
360	09-12-2025	Part of : BLOCK B DEVL I SANGAM VIHAR	1401	Other Outage	Planned Outage	09-12-2025	10:58	09-12-2025	12:06	1:08	0.000208	REPLACEMENT OF LT BUSHING ROD
361	09-12-2025	Part of : BLOCK A PULPEHLADPUR	780	Other Outage	Planned Outage	09-12-2025	11:57	09-12-2025	15:17	3:20	0.000611	REPLACEMENT OF HT BUSHING ROD
362	09-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	3749	Other Outage	Planned Outage	09-12-2025	11:08	09-12-2025	13:59	2:51	0.000523	3PH HT AB CABLE REPLACEMENT PER SPAN
363	09-12-2025	Part of : POCKET C RAJU PARK SANGAM VIHAR	172	Other Outage	Planned Outage	09-12-2025	11:00	09-12-2025	13:39	2:39	0.000486	REPLACEMENT OF HT BUSHING ROD
364	10-12-2025	Part of : A & B-BLOCK SECTOR 5 DAKSHINPURI	2672	Other Outage	Unplanned Outage	10-12-2025	14:19	10-12-2025	14:29	0:10	0.000000	CABLE FAULT
365	10-12-2025	Part of : A & B-BLOCK SECTOR 5 DAKSHINPURI	2672	Other Outage	Unplanned Outage	10-12-2025	12:46	10-12-2025	13:29	0:43	0.000824	CABLE FAULT
366	10-12-2025	Part of : TALIMABAD SANGAM VIHAR	6276	Other Outage	Unplanned Outage	10-12-2025	12:41	10-12-2025	13:33	0:52	0.000592	HT SYSTEM FAULT
367	10-12-2025	Part of : L & L 2-BLOCK L 2 DEVL I SANGAM VIHAR,HARIJAN BASTI	6656	Other Outage	Unplanned Outage	10-12-2025	07:37	10-12-2025	08:45	1:08	0.001870	HYVDS FAULT
368	10-12-2025	Part of : LAL KUAN	13	Other Outage	Planned Outage	10-12-2025	11:32	10-12-2025	13:32	2:00	0.000367	REPLACEMENT OF HT BUSHING ROD
369	10-12-2025	Part of : B-BLOCK PULPEHLADPUR	609	Other Outage	Planned Outage	10-12-2025	12:20	10-12-2025	14:52	2:32	0.000464	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
370	10-12-2025	Part of : A,C & D-BLOCK VISHWAKARMA COLONY PULPEHLADPUR	1976	Other Outage	Planned Outage	10-12-2025	11:21	10-12-2025	14:17	2:56	0.000538	3PH HT AB CABLE REPLACEMENT
371	10-12-2025	Part of : BLOCK 7 DAKSHINPURI EXTENSION,SECTOR 6 DAKSHINPURI	1774	Other Outage	Planned Outage	10-12-2025	11:03	10-12-2025	13:50	2:47	0.000510	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
372	10-12-2025	Part of : L & J-BLOCK DEVLİ SANGAM VIHAR	1408	Other Outage	Planned Outage	10-12-2025	10:08	10-12-2025	13:38	3:30	0.000642	3PH HT AB CABLE REPLACEMENT
373	10-12-2025	Part of : G 2 & H-BLOCK G 2 SANGAM VIHAR	207	Other Outage	Planned Outage	10-12-2025	10:45	10-12-2025	13:49	3:04	0.000562	3PH HT AB CABLE REPLACEMENT
374	11-12-2025	Part of : BLOCK F 2 SANGAM VIHAR	1481	Other Outage	Unplanned Outage	11-12-2025	13:40	11-12-2025	14:23	0:43	0.000000	REPAIR OF RMU
375	11-12-2025	Part of : BLOCK F 2 SANGAM VIHAR	1470	Other Outage	Planned Outage	11-12-2025	13:49	11-12-2025	17:03	3:14	0.000593	REPLACEMENT OF CROSS-ARMS AND POLES
376	11-12-2025	Part of : BLOCK C & D VISHWAKARMA COLONY PULPEHLADPUR	1934	Other Outage	Planned Outage	11-12-2025	11:08	11-12-2025	14:13	3:05	0.000565	3PH HT AB CABLE REPLACEMENT PER SPAN
377	11-12-2025	Part of : POCKET C RAJU PARK SANGAM VIHAR	2093	Other Outage	Planned Outage	11-12-2025	11:06	11-12-2025	14:55	3:49	0.000700	REPLACEMET OF HT BUSHING ROD
378	11-12-2025	Part of : BLOCK J & L DEVLİ SANGAM VIHAR	3671	Other Outage	Planned Outage	11-12-2025	10:06	11-12-2025	13:48	3:42	0.000678	3PH HT AB CABLE REPLACEMENT PER SPAN
379	11-12-2025	Part of : BLOCK H SANGAM VIHAR,TALIMABAD SANGAM VIHAR	2415	Other Outage	Planned Outage	11-12-2025	10:41	11-12-2025	15:00	4:19	0.000791	3PH HT AB CABLE REPLACEMENT PER SPAN
380	12-12-2025	Part of : HR-BLOCK PULPEHLADPUR,	360	Other Outage	Planned Outage	12-12-2025	12:15	12-12-2025	14:02	1:47	0.000327	REPLACEMET OF HT BUSHING ROD
381	12-12-2025	Part of : DURGA VIHAR DEVLİ SANGAM VIHAR,	937	Other Outage	Planned Outage	12-12-2025	10:54	12-12-2025	14:13	3:19	0.000608	REPLACEMENT OF GAS KIT AND OIL SEAL
382	12-12-2025	Part of : BLOCK 14 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,	368	Other Outage	Planned Outage	12-12-2025	10:58	12-12-2025	13:37	2:39	0.000486	REPLACEMET OF HT BUSHING ROD
383	12-12-2025	Part of : BLOCK D SANGAM VIHAR,	997	Other Outage	Planned Outage	12-12-2025	11:42	12-12-2025	14:47	3:05	0.000565	CONDUCTOR REPLACEMENT PER SPAN
384	12-12-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR,	2799	Other Outage	Planned Outage	12-12-2025	09:58	12-12-2025	12:57	2:59	0.000547	3PH HT AB CABLE REPLACEMENT PER SPAN
385	13-12-2025	Part of : BLOCK C DEVLİ SANGAM VIHAR	1101	Other Outage	Planned Outage	13-12-2025	12:48	13-12-2025	15:11	2:23	0.000437	REPLACEMENT OF HT BUSHING ROD
386	13-12-2025	Part of : BLOCK F DR AMBEDKAR NAGAR MADANGIR	1201	Other Outage	Planned Outage	13-12-2025	11:26	13-12-2025	14:15	2:49	0.000516	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
387	13-12-2025	Part of : BLOCK G JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1858	Other Outage	Planned Outage	13-12-2025	11:03	13-12-2025	14:10	3:07	0.000571	REPLACEMENT OF LT BUSHING ROD
388	13-12-2025	Part of : BLOCK B DEVLİ SANGAM VIHAR	716	Other Outage	Planned Outage	13-12-2025	10:46	13-12-2025	14:58	4:12	0.000770	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
389	13-12-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR	3749	Other Outage	Planned Outage	13-12-2025	10:45	13-12-2025	13:34	2:49	0.000516	3PH HT AB CABLE REPLACEMENT PER SPAN
390	14-12-2025	Part of : KARNI SINGH SHOOTING RANGE	0	Other Outage	Unplanned Outage	14-12-2025	01:52	14-12-2025	02:19	0:27	0.000068	HT SYSTEM FAULT
391	14-12-2025	Part of : TEMP AFCONS 1 TUGLAKABAD (HT CONSUMER)	0	Other Outage	Unplanned Outage	14-12-2025	01:52	14-12-2025	02:33	0:41	0.000068	FAULT IN CONSUMER PANEL (AFCONS DMRC)
392	15-12-2025	Part of : F-2 BLOCK SANGAMVIHAR KHANPUR	0	Other Outage	Unplanned Outage	15-12-2025	10:10	15-12-2025	10:56	0:46	0.001367	HT SYSTEM FAULT
393	15-12-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR	1565	Other Outage	Planned Outage	15-12-2025	14:01	15-12-2025	16:06	2:05	0.000382	3PH HT AB CABLE REPLACEMENT PER SPAN
394	15-12-2025	Part of : BLOCK 2 DAKSHINPURI EXTENSION SECTOR	966	Other Outage	Planned Outage	15-12-2025	11:12	15-12-2025	14:18	3:06	0.000568	REPLACEMENT OF LT BUSHING ROD
395	15-12-2025	Part of : MADANGIR VILLAGE	893	Other Outage	Planned Outage	15-12-2025	12:55	15-12-2025	16:04	3:09	0.000578	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
396	15-12-2025	Part of : BLOCK 4 DAKSHINPURI EXTENSION SECTOR 6	985	Other Outage	Planned Outage	15-12-2025	11:27	15-12-2025	16:02	4:35	0.000840	ACB REPLACEMENT PER ACB
397	15-12-2025	Part of : BLOCK J DEVLİ SANGAM VIHAR,BLOCK L & L 2 DEVLİ SANGAM VIHAR	1408	Other Outage	Planned Outage	15-12-2025	10:09	15-12-2025	13:02	2:53	0.000529	3PH HT AB CABLE REPLACEMENT PER SPAN
398	15-12-2025	Part of : BLOCK A,C & RZ PULPEHLADPUR	2561	Other Outage	Planned Outage	15-12-2025	10:25	15-12-2025	12:57	2:32	0.000464	3PH HT AB CABLE REPLACEMENT PER SPAN
399	16-12-2025	Part of : BLOCK A VISHWAKARMA COLONY PULPEHLADPUR,BLOCK D VISHWAKARMA COLONY PULPEHLADPUR,	1934	Other Outage	Planned Outage	16-12-2025	10:30	16-12-2025	11:45	1:15	0.000229	MAINTENANCE OF HVDS CIRCUIT
400	16-12-2025	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	2348	Other Outage	Planned Outage	16-12-2025	11:31	16-12-2025	15:51	4:20	0.000794	MAINTENANCE OF HT CIRCUIT
401	16-12-2025	Part of : TALIMABAD SANGAM VIHAR,	702	Other Outage	Planned Outage	16-12-2025	11:25	16-12-2025	13:29	2:04	0.000379	MAINTENANCE OF TRANSFORMER
402	16-12-2025	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	1039	Other Outage	Planned Outage	16-12-2025	11:27	16-12-2025	15:49	4:22	0.000801	MAINTENANCE OF RMU
403	16-12-2025	Part of : BLOCK J DEVLİ SANGAM VIHAR,BLOCK L DEVLİ SANGAM VIHAR,	3670	Other Outage	Planned Outage	16-12-2025	10:04	16-12-2025	13:58	3:54	0.000715	MAINTENANCE OF HVDS CIRCUIT
404	17-12-2025	Part of : BLOCK J 1 DEVLİ SANGAM VIHAR,BLOCK J 2 DEVLİ SANGAM VIHAR,ASOLA WILD LIFE SANCTUARY ASOLA	5071	Other Outage	Unplanned Outage	17-12-2025	04:31	17-12-2025	05:09	0:38	0.000042	CABLE FAULT
405	17-12-2025	Part of : LAL KUAN	525	Other Outage	Planned Outage	17-12-2025	10:57	17-12-2025	12:47	1:50	0.000336	HT AB CABLE REPLACEMENT PER SPAN
406	17-12-2025	Part of : HR-BLOCK PULPEHLADPUR,DDA LIG FLATS PULPEHLADPUR	2253	Other Outage	Planned Outage	17-12-2025	10:58	17-12-2025	12:45	1:47	0.000327	HT AB CABLE REPLACEMENT PER SPAN
407	17-12-2025	Part of : BLOCK J 2 DEVLİ SANGAM VIHAR,BLOCK J 1 DEVLİ SANGAM VIHAR	2202	Other Outage	Planned Outage	17-12-2025	11:18	17-12-2025	15:50	4:32	0.000831	HT AB CABLE REPLACEMENT PER SPAN
408	17-12-2025	Part of : BLOCK I JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1317	Other Outage	Planned Outage	17-12-2025	13:05	17-12-2025	15:40	2:35	0.000474	DT REPLACEMENT
409	17-12-2025	Part of : POCKET B JAWAHAR PARK KHANPUR	824	Other Outage	Planned Outage	17-12-2025	11:06	17-12-2025	14:11	3:05	0.000565	REPLACEMENT OF HT BUSHING ROD
410	17-12-2025	Part of : BLOCK L DEVLİ SANGAM VIHAR,BLOCK L 2 DEVLİ SANGAM VIHAR	5713	Other Outage	Planned Outage	17-12-2025	09:58	17-12-2025	13:27	3:29	0.000639	HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
411	18-12-2025	Part of : D-BLOCK JJ COLONY KHANPUR	553	Other Outage	Planned Outage	18-12-2025	11:43	18-12-2025	15:18	3:35	0.000657	HT CONDUCTOR REPLACEMENT
412	18-12-2025	Part of : BLOCK 18 DAKSHINPURI EXTENSION,SECTOR 6 DAKSHINPURI	1973	Other Outage	Planned Outage	18-12-2025	11:27	18-12-2025	14:59	3:32	0.000648	REPLACEMENT OF HT BUSHING ROD
413	18-12-2025	Part of : B-BLOCK PULPEHLADPUR	594	Other Outage	Planned Outage	18-12-2025	11:46	18-12-2025	14:23	2:37	0.000480	REPLACEMENT OF HT BUSHING ROD
414	18-12-2025	Part of : DDA PARK LAL KUAN,A,C & D-BLOCK VISHWAKARMA COLONY	1291	Other Outage	Planned Outage	18-12-2025	10:45	18-12-2025	12:49	2:04	0.000379	3PH HT AB CABLE REPLACEMENT
415	18-12-2025	Part of : J, L & L 2-BLOCK DEVL I SANGAM VIHAR	1027	Other Outage	Planned Outage	18-12-2025	09:53	18-12-2025	14:53	5:00	0.000917	3PH HT AB CABLE REPLACEMENT
416	19-12-2025	Part of : BLOCK 1 DAKSHINPURI EXTENSION SECTOR 6	2902	Other Outage	Planned Outage	19-12-2025	15:09	19-12-2025	15:56	0:47	0.000144	CONDUCTOR REPLACEMENT PER SPAN
417	19-12-2025	Part of : BLOCK F DR AMBEDKAR NAGAR MADANGIR	1203	Other Outage	Planned Outage	19-12-2025	11:17	19-12-2025	15:49	4:32	0.000831	DT REPLACEMENT
418	19-12-2025	Part of : HR-BLOCK PULPEHLADPUR,BLOCK C PULPEHLADPUR	2253	Other Outage	Planned Outage	19-12-2025	10:56	19-12-2025	13:59	3:03	0.000559	3PH HT AB CABLE REPLACEMENT PER SPAN
419	19-12-2025	Part of : BLOCK B CHUNGI NO 1 KOTLA MAHINGIRAN LAL KUAN	607	Other Outage	Planned Outage	19-12-2025	10:57	19-12-2025	13:58	3:01	0.000553	REPLACEMENT OF LT BUSHING ROD
420	19-12-2025	Part of : POCKET A & D JAWAHAR PARK KHANPUR,BLOCK F KHANPUR COLONY KHANPUR	3212	Other Outage	Planned Outage	19-12-2025	11:10	19-12-2025	14:24	3:14	0.000593	REPLACEMET OF HT BUSHING ROD
421	19-12-2025	Part of : BLOCK F KHANPUR COLONY KHANPUR,POCKET A, B & D JAWAHAR PARK KHANPUR,POCKET C JAWAHAR PARK KHANPUR	1377	Other Outage	Planned Outage	19-12-2025	11:07	19-12-2025	14:44	3:37	0.000663	3PH HT AB CABLE REPLACEMENT PER SPAN
422	19-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,BLOCK L DEVL I SANGAM VIHAR	1964	Other Outage	Planned Outage	19-12-2025	10:02	19-12-2025	12:39	2:37	0.000480	3PH HT AB CABLE REPLACEMENT PER SPAN
423	20-12-2025	Part of : DDA PARK LAL KUAN,BLOCK A VISHWAKARMA COLONY PULPEHLADPUR,LAL KUAN,CHUNGI NO 2 KOTLA MAHINGIRAN LAL KUAN,BLOCK D VISHWAKARMA COLONY PULPEHLADPUR,BLOCK C VISHWAKARMA COLONY PULPEHLADPUR	4166	Other Outage	Unplanned Outage	20-12-2025	10:55	20-12-2025	11:37	0:42	0.000560	TREE TOUCHING
424	20-12-2025	Part of : BLOCK A PULPEHLADPUR,HR-BLOCK PULPEHLADPUR,	1102	Other Outage	Planned Outage	20-12-2025	10:52	20-12-2025	14:03	3:11	0.000584	MAINTENANCE OF HVDS CIRCUIT
425	20-12-2025	Part of : AIRFORCE STATION TUGHLAKABAD,	4	Other Outage	Planned Outage	20-12-2025	11:48	20-12-2025	14:20	2:32	0.000464	MAINTENANCE OF TRANSFORMER
426	20-12-2025	Part of : BLOCK H SECTOR 5 DAKSHINPURI,	2443	Other Outage	Planned Outage	20-12-2025	11:19	20-12-2025	14:40	3:21	0.000614	MAINTENANCE OF TRANSFORMER
427	20-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,	3749	Other Outage	Planned Outage	20-12-2025	10:12	20-12-2025	14:50	4:38	0.000849	MAINTENANCE OF HVDS CIRCUIT
428	22-12-2025	Part of : F-BLOCK VISHWAKARMA COLONY PULPEHLADPUR	279	Other Outage	Planned Outage	22-12-2025	11:58	22-12-2025	13:43	1:45	0.000321	REPLACEMENT OF HT BUSHING ROD
429	22-12-2025	Part of : A-BLOCK SECTOR 5 DAKSHINPURI	1272	Other Outage	Planned Outage	22-12-2025	11:06	22-12-2025	13:43	2:37	0.000480	REPLACEMENT OF HT BUSHING ROD
430	22-12-2025	Part of : B-BLOCK DEVL I SANGAM VIHAR	717	Other Outage	Planned Outage	22-12-2025	11:27	22-12-2025	14:28	3:01	0.000553	DT REPLACEMENT
431	22-12-2025	Part of : J,L & L 2-BLOCK DEVL I SANGAM VIHAR	1408	Other Outage	Planned Outage	22-12-2025	10:00	22-12-2025	13:11	3:11	0.000584	3PH HT AB CABLE REPLACEMENT
432	22-12-2025	Part of : J 2-BLOCK DEVL I SANGAM VIHAR	4104	Other Outage	Planned Outage	22-12-2025	11:24	22-12-2025	14:45	3:21	0.000614	3PH HT AB CABLE REPLACEMENT
433	23-12-2025	Part of : MADANGIR VILLAGE	893	Other Outage	Planned Outage	23-12-2025	11:41	23-12-2025	13:36	1:55	0.000351	3PH DB REPLACEMENT
434	23-12-2025	Part of : BLOCK L & L2 DEVL I SANGAM VIHAR	1964	Other Outage	Planned Outage	23-12-2025	10:05	23-12-2025	12:58	2:53	0.000529	3PH HT AB CABLE REPLACEMENT PER SPAN
435	24-12-2025	Part of : DURGA VIHAR DEVL I SANGAM VIHAR,BLOCK B DEVL I SANGAM VIHAR,BLOCK L 2 DEVL I SANGAM VIHAR	4804	Other Outage	Unplanned Outage	24-12-2025	20:58	24-12-2025	21:04	0:06	0.000065	HVDS FAULT
436	24-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,BLOCK L DEVL I SANGAM VIHAR	2897	Other Outage	Unplanned Outage	24-12-2025	09:19	24-12-2025	10:42	1:23	0.001453	HVDS FAULT
437	24-12-2025	Part of : BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,	1	Other Outage	Planned Outage	24-12-2025	11:13	24-12-2025	13:12	1:59	0.000364	MAINTENANCE OF TRANSFORMER
438	24-12-2025	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	2348	Other Outage	Planned Outage	24-12-2025	12:46	24-12-2025	14:54	2:08	0.000391	MAINTENANCE OF TRANSFORMER
439	24-12-2025	Part of : SHIV PARK DUGGAL COLONY KHANPUR,JJ COLONY DUGGAL COLONY KHANPUR	1289	Other Outage	Planned Outage	24-12-2025	11:07	24-12-2025	13:40	2:33	0.000468	MAINTENANCE OF TRANSFORMER
440	24-12-2025	Part of : BLOCK K SANGAM VIHAR,BLOCK I 1 SANGAM VIHAR,	3616	Other Outage	Planned Outage	24-12-2025	11:20	24-12-2025	13:56	2:36	0.000477	MAINTENANCE OF HVDS
441	24-12-2025	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,	3749	Other Outage	Planned Outage	24-12-2025	10:19	24-12-2025	14:44	4:25	0.000810	MAINTENANCE OF HVDS
442	24-12-2025	Part of : HR-BLOCK PULPEHLADPUR,DDA LIG FLATS PULPEHLADPUR,BLOCK C PULPEHLADPUR,	2253	Other Outage	Planned Outage	24-12-2025	10:30	24-12-2025	13:09	2:39	0.000486	MAINTENANCE OF HVDS
443	25-12-2025	Part of : Railway Colony Tughlakabad,Block G Vishwakarma Colony Pulpehladpur,HR-Block Pulpehladpur,Block B Pulpehladpur,DDA LIG Flats Pulpehladpur,Block C Pulpehladpur,Block A Pulpehladpur	5020	Other Outage	Unplanned Outage	25-12-2025	02:37	25-12-2025	02:55	0:18	0.000150	CABLE FAULT

Sr. No.	Date	Area Affected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
444	25-12-2025	Part of : Block L 2 Devli Sangam Vihar,Block L Devli Sangam Vihar	2897	Other Outage	Unplanned Outage	25-12-2025	16:28	25-12-2025	17:11	0:43	0.000131	BIRDAGE
445	26-12-2025	Part of : BSF TIGRI	1	Other Outage	Planned Outage	26-12-2025	12:28	26-12-2025	13:15	0:47	0.000144	REPLACEMENT OF HT BUSHING ROD
446	26-12-2025	Part of : BLOCK L,L-2 & J DEVLi SANGAM VIHAR	1408	Other Outage	Planned Outage	26-12-2025	10:13	26-12-2025	12:02	1:49	0.000333	3PH HT AB CABLE REPLACEMENT
447	26-12-2025	Part of : MADANGIR VILLAGE	893	Other Outage	Planned Outage	26-12-2025	12:58	26-12-2025	15:39	2:41	0.000492	DT REPLACEMENT
448	26-12-2025	Part of : BLOCK B DEVLi SANGAM VIHAR	724	Other Outage	Planned Outage	26-12-2025	11:01	26-12-2025	13:02	2:01	0.000370	3PH DB REPLACEMENT
449	26-12-2025	Part of : BLOCK F DR AMBEDKAR NAGAR MADANGIR	1205	Other Outage	Planned Outage	26-12-2025	11:47	26-12-2025	15:42	3:55	0.000718	3PH DB REPLACEMENT
450	26-12-2025	Part of : BLOCK 3 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	1081	Other Outage	Planned Outage	26-12-2025	11:01	26-12-2025	14:19	3:18	0.000605	REPLACEMENT OF HT BUSHING ROD
451	27-12-2025	Part of : DR. KARNI SINGH SHOOTING RANGE (HTC)	0	Other Outage	Unplanned Outage	27-12-2025	13:10	27-12-2025	13:55	0:45	0.000238	CABLE DAMAGED BY OUTSIDE AGENCY (MCD)
452	27-12-2025	Part of : BLOCK J 1 DEVLi SANGAM VIHAR	5	Other Outage	Planned Outage	27-12-2025	11:07	27-12-2025	11:58	0:51	0.000156	REPLACEMENT OF LT BUSHING ROD
453	27-12-2025	Part of : BLOCK A & C PULPEHLADPUR,BLOCK RZ H PULPEHLADPUR,BLOCK R ZTO F PULPEHLADPUR	2561	Other Outage	Planned Outage	27-12-2025	11:04	27-12-2025	13:46	2:42	0.000495	3PH HT AB CABLE REPLACEMENT PER SPAN
454	27-12-2025	Part of : BLOCK L DEVLi SANGAM VIHAR,BLOCK J DEVLi SANGAM VIHAR	3671	Other Outage	Planned Outage	27-12-2025	10:04	27-12-2025	13:53	3:49	0.000700	3PH HT AB CABLE REPLACEMENT PER SPAN
455	29-12-2025	Part of : RPS COLONY MADANGIR,POCKET A DUGGAL COLONY KHANPUR,KHANPUR EXTENSION SANGAM VIHAR,KHANPUR VILLAGE KHANPUR,BLOCK G SECTOR 5 DAKSHINPURI,JAWAHAR PARK SANGAM VIHAR	1609	Other Outage	Unplanned Outage	29-12-2025	00:01	29-12-2025	00:35	0:34	0.000283	HVDS FAULT
456	29-12-2025	Part of : BLOCK 1 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	2902	Other Outage	Planned Outage	29-12-2025	13:51	29-12-2025	17:12	3:21	0.000614	3PH DB REVAMPING
457	29-12-2025	Part of : BLOCK F DR AMBEDKAR NAGAR MADANGIR	1205	Other Outage	Planned Outage	29-12-2025	12:37	29-12-2025	17:36	4:59	0.000914	3PH DB REPLACEMENT
458	29-12-2025	Part of : BLOCK J 2 DEVLi SANGAM VIHAR	4125	Other Outage	Planned Outage	29-12-2025	10:43	29-12-2025	14:01	3:18	0.000605	3PH HT AB CABLE REPLACEMENT PER SPAN
459	29-12-2025	Part of : BLOCK 4 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	3653	Other Outage	Planned Outage	29-12-2025	11:54	29-12-2025	16:35	4:41	0.000859	DT REPLACEMENT
460	29-12-2025	Part of : TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD	5	Other Outage	Planned Outage	29-12-2025	11:11	29-12-2025	14:24	3:13	0.000590	3PH DB REPLACEMENT
461	29-12-2025	Part of : BLOCK C DR AMBEDKAR NAGAR MADANGIR	2278	Other Outage	Planned Outage	29-12-2025	11:05	29-12-2025	14:13	3:08	0.000574	REPLACEMENT OF HT BUSHING ROD
462	29-12-2025	Part of : BLOCK L 2 DEVLi SANGAM VIHAR,BLOCK L DEVLi SANGAM VIHAR	1964	Other Outage	Planned Outage	29-12-2025	10:01	29-12-2025	13:25	3:24	0.000623	3PH HT AB CABLE REPLACEMENT PER SPAN
463	29-12-2025	Part of : BLOCK B PULPEHLADPUR,BLOCK A PULPEHLADPUR,HR-BLOCK PULPEHLADPUR	501	Other Outage	Planned Outage	29-12-2025	10:36	29-12-2025	12:52	2:16	0.000416	3PH HT AB CABLE REPLACEMENT PER SPAN
464	30-12-2025	Part of : B,C & F-BLOCK DEVLi SANGAM VIHAR	3759	Other Outage	Unplanned Outage	30-12-2025	13:13	30-12-2025	13:41	0:28	0.000537	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
465	30-12-2025	Part of : TALIMABAD SANGAM VIHAR	1310	Other Outage	Planned Outage	30-12-2025	10:52	30-12-2025	12:48	1:56	0.000354	REPLACEMENT OF HT BUSHING ROD
466	30-12-2025	Part of : A & D-BLOCK VISHWAKARMA COLONY PULPEHLADPUR	1976	Other Outage	Planned Outage	30-12-2025	10:22	30-12-2025	12:03	1:41	0.000309	3PH HT AB CABLE REPLACEMENT
467	30-12-2025	Part of : J-BLOCK SECTOR 5 DAKSHINPURI	942	Other Outage	Planned Outage	30-12-2025	11:42	30-12-2025	14:48	3:06	0.000517	DT REPLACEMENT,MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
468	30-12-2025	Part of : A & B-BLOCK SECTOR 5 DAKSHINPURI	2680	Other Outage	Planned Outage	30-12-2025	10:53	30-12-2025	15:37	4:44	0.000868	3PH DB REPLACEMENT
469	30-12-2025	Part of : G-BLOCK VISHWAKARMA COLONY PULPEHLADPUR	1	Other Outage	Planned Outage	30-12-2025	11:10	30-12-2025	13:25	2:15	0.000413	REPLACEMENT OF HT BUSHING ROD
470	30-12-2025	Part of : BLOCK 1 DAKSHINPURI EXTENSION,SECTOR 6 DAKSHINPURI	1277	Other Outage	Planned Outage	30-12-2025	11:03	30-12-2025	14:43	3:40	0.000672	REPLACEMENT OF HT BUSHING ROD
471	30-12-2025	Part of : L 2-BLOCK DEVLi SANGAM VIHAR	3749	Other Outage	Planned Outage	30-12-2025	09:56	30-12-2025	14:04	4:08	0.000758	3PH HT AB CABLE REPLACEMENT
472	31-12-2025	Part of : SHIV PARK DUGGAL COLONY KHANPUR,POCKET B DUGGAL COLONY KHANPUR,KHANPUR VILLAGE	4695	Other Outage	Unplanned Outage	31-12-2025	14:56	31-12-2025	16:18	1:22	0.000000	RMU RELAY CHANGE
473	31-12-2025	Part of : BLOCK A SECTOR 5 DAKSHINPURI	1711	Other Outage	Unplanned Outage	31-12-2025	14:25	31-12-2025	17:27	3:02	0.001011	CONNECTION OF NEW LT CABLE
474	31-12-2025	Part of : BLOCK K SANGAM VIHAR,BLOCK G 2 SANGAM VIHAR	3616	Other Outage	Planned Outage	31-12-2025	11:46	31-12-2025	14:52	3:06	0.000568	3PH HT AB END TERMINATION REPLACEMENT
475	31-12-2025	Part of : BLOCK A VISHWAKARMA COLONY PULPEHLADPUR	951	Other Outage	Planned Outage	31-12-2025	11:07	31-12-2025	14:24	3:17	0.000602	REPLACEMET OF HT BUSHING ROD
476	31-12-2025	Part of : BLOCK L DEVLi SANGAM VIHAR,BLOCK J DEVLi SANGAM VIHAR,BLOCK L 2 DEVLi SANGAM VIHAR	1408	Other Outage	Planned Outage	31-12-2025	10:43	31-12-2025	13:46	3:03	0.000559	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
477	01-12-2025	Part of : BLOCK C JOGA BAI EXTENSION OKHLA	863	Other Outage	Planned Outage	01-12-2025	13:04	01-12-2025	16:06	3:02	0.003033	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
478	01-12-2025	Part of : BLOCK H MAHARANI BAGH NEW FRIENDS COLONY	239	Other Outage	Planned Outage	01-12-2025	11:04	01-12-2025	14:51	3:47	0.001892	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
479	02-12-2025	Part of : VILLAGE JASOLA VIHAR	349	Other Outage	Planned Outage	02-12-2025	10:26	02-12-2025	12:17	1:51	0.000925	REPLACEMET OF HT BUSHING ROD
480	02-12-2025	Part of : BHARAT NAGAR NEW FRIENDS COLONY	672	Other Outage	Planned Outage	02-12-2025	10:59	02-12-2025	14:54	3:55	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD
481	03-12-2025	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR	28	Other Outage	Planned Outage	03-12-2025	11:01	03-12-2025	12:19	1:18	0.000238	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
482	03-12-2025	Part of : JOGA BAI OKHLA	296	Other Outage	Planned Outage	03-12-2025	12:56	03-12-2025	15:42	2:46	0.002306	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
483	03-12-2025	Part of : BLOCK C KALINDI COLONY NEW FRIENDS COLONY	40	Other Outage	Planned Outage	03-12-2025	11:00	03-12-2025	13:23	2:23	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
484	04-12-2025	Part of : NOOR NAGAR OKHLA	833	Other Outage	Planned Outage	04-12-2025	13:51	04-12-2025	15:57	2:06	0.002100	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER
485	04-12-2025	Part of : MASIHGARH OKHLA	45	Other Outage	Planned Outage	04-12-2025	11:09	04-12-2025	13:46	2:37	0.002617	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
486	04-12-2025	Part of : BLOCK A SHAHEEN BAGH JASOLA VIHAR	711	Other Outage	Planned Outage	04-12-2025	10:20	04-12-2025	12:51	2:31	0.001258	REPLACEMENT OF LT BUSHING ROD
487	05-12-2025	Part of : BLOCK H SRINIVAS PURI	214	Other Outage	Planned Outage	05-12-2025	11:11	05-12-2025	13:47	2:36	0.002600	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
488	06-12-2025	Part of : B-BLOCK JOGA BAI EXTENSION BATLA HOUSE OKHLA	3382	Other Outage	Unplanned Outage	06-12-2025	17:19	06-12-2025	17:57	0:38	0.000032	CABLE FAULT
489	06-12-2025	Part of : A-BLOCK OKHLA VIHAR JAMIA NAGAR OKHLA	1398	Other Outage	Planned Outage	06-12-2025	13:06	06-12-2025	16:01	2:55	0.002917	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
490	06-12-2025	Part of : G-BLOCK SRINIVAS PURI	657	Other Outage	Planned Outage	06-12-2025	11:03	06-12-2025	15:06	4:03	0.003375	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
491	08-12-2025	Part of : BLOCK C JOGA BAI EXTENSION OKHLA	3953	Other Outage	Unplanned Outage	08-12-2025	03:34	08-12-2025	03:43	0:09	0.000053	CABLE FAULT
492	08-12-2025	Part of : VILLAGE JASOLA JASOLA VIHAR,	440	Other Outage	Planned Outage	08-12-2025	10:25	08-12-2025	12:23	1:58	0.001311	REPLACEMENT OF LT BUSHING ROD
493	08-12-2025	Part of : NOOR NAGAR OKHLA,	270	Other Outage	Planned Outage	08-12-2025	12:57	08-12-2025	15:51	2:54	0.002900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
494	08-12-2025	Part of : BLOCK C KALINDI COLONY NEW FRIENDS COLONY,	276	Other Outage	Planned Outage	08-12-2025	11:12	08-12-2025	14:02	2:50	0.002361	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
495	09-12-2025	Part of : BLOCK H SRINIVAS PURI	214	Other Outage	Planned Outage	09-12-2025	11:02	09-12-2025	12:05	1:03	0.000000	REPLACEMENT OF LT BUSHING ROD
496	10-12-2025	Part of : JAMIA NAGAR OKHLA	259	Other Outage	Planned Outage	10-12-2025	13:10	10-12-2025	16:09	2:59	0.002983	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER
497	10-12-2025	Part of : VILLAGE JASOLA & JASOLA VIHAR	1097	Other Outage	Planned Outage	10-12-2025	10:31	10-12-2025	12:52	2:21	0.001567	REPLACEMENT OF HT BUSHING ROD
498	10-12-2025	Part of : VILLAGE JASOLA & JASOLA VIHAR	233	Other Outage	Planned Outage	10-12-2025	10:30	10-12-2025	12:51	2:21	0.001371	REPLACEMENT OF HT BUSHING ROD
499	11-12-2025	Part of : JOGA BAI OKHLA	2834	Other Outage	Planned Outage	11-12-2025	10:59	11-12-2025	12:33	1:34	0.001567	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
500	11-12-2025	Part of : NOOR NAGAR OKHLA	831	Other Outage	Planned Outage	11-12-2025	13:25	11-12-2025	15:52	2:27	0.002450	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING INSULATOR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
501	11-12-2025	Part of : BLOCK D NEW FRIENDS COLONY EAST	780	Other Outage	Planned Outage	11-12-2025	11:10	11-12-2025	13:55	2:45	0.002750	REPLACEMENT OF LT BUSHING ROD
502	12-12-2025	Part of : JOGA BAI OKHLA,	305	Other Outage	Planned Outage	12-12-2025	11:18	12-12-2025	12:24	1:06	0.001100	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS
503	13-12-2025	Part of : NOOR NAGAR OKHLA	272	Other Outage	Planned Outage	13-12-2025	11:22	13-12-2025	12:31	1:09	0.001150	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
504	13-12-2025	Part of : CANAL COLONY OKHLA	71	Other Outage	Planned Outage	13-12-2025	13:01	13-12-2025	15:47	2:46	0.002767	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
505	13-12-2025	Part of : BLOCK G SRINIVAS PURI	31	Other Outage	Planned Outage	13-12-2025	11:23	13-12-2025	13:45	2:22	0.002367	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
506	14-12-2025	Part of : VILLAGE JASOLA JASOLA VIHAR	5187	Other Outage	Unplanned Outage	14-12-2025	07:55	14-12-2025	08:24	0:29	0.000403	CABLE FAULT
507	15-12-2025	Part of : GAFOOR NAGAR OKHLA	68	Other Outage	Planned Outage	15-12-2025	12:57	15-12-2025	15:43	2:46	0.002767	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
508	15-12-2025	Part of : NEW FRIENDS COLONY	1	Other Outage	Planned Outage	15-12-2025	11:06	15-12-2025	13:34	2:28	0.001644	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
509	16-12-2025	Part of : VILLAGE JASOLA JASOLA VIHAR,	292	Other Outage	Planned Outage	16-12-2025	10:17	16-12-2025	12:30	2:13	0.001847	MAINTENANCE OF TRANSFORMER
510	17-12-2025	Part of : KHIZARABAD BHAGOL VILLAGE NEW FRIENDS COLONY	220	Other Outage	Planned Outage	17-12-2025	11:02	17-12-2025	13:37	2:35	0.002153	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
511	17-12-2025	Part of : BLOCK E SHAHEEN BAGH JASOLA VIHAR	1145	Other Outage	Planned Outage	17-12-2025	10:32	17-12-2025	13:04	2:32	0.001689	REPLACEMENT OF HT BUSHING ROD
512	18-12-2025	Part of : AZIM DAIRY OKHLA	1161	Other Outage	Planned Outage	18-12-2025	13:04	18-12-2025	14:16	1:12	0.001200	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
513	19-12-2025	Part of : CANAL COLONY OKHLA	72	Other Outage	Planned Outage	19-12-2025	11:16	19-12-2025	12:14	0:58	0.000967	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
514	20-12-2025	Part of : BLOCK J PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA,	960	Other Outage	Planned Outage	20-12-2025	12:52	20-12-2025	13:30	0:38	0.000454	MAINTENANCE OF O/H HT CIRCUIT
515	20-12-2025	Part of : JAMIA NAGAR OKHLA,	258	Other Outage	Planned Outage	20-12-2025	11:00	20-12-2025	12:15	1:15	0.001250	MAINTENANCE OF TRANSFORMER
516	20-12-2025	Part of : BLOCK H SHAHEEN BAGH JASOLA VIHAR,	49	Other Outage	Planned Outage	20-12-2025	10:58	20-12-2025	12:25	1:27	0.000967	MAINTENANCE OF TRANSFORMER
517	20-12-2025	Part of : MUJEEB BAGH JAMIA NAGAR OKHLA,	472	Other Outage	Planned Outage	20-12-2025	13:36	20-12-2025	16:03	2:27	0.002450	MAINTENANCE OF TRANSFORMER
518	20-12-2025	Part of : BLOCK A NEW FRIENDS COLONY WEST NEW FRIENDS COLONY,	94	Other Outage	Planned Outage	20-12-2025	11:00	20-12-2025	14:22	3:22	0.002806	MAINTENANCE OF O/H HT CIRCUIT
519	21-12-2025	Part of : GHAFAR MANZIL COLONY JAMIA NAGAR OKHLA,NOOR NAGAR OKHLA	4054	Other Outage	Unplanned Outage	21-12-2025	09:49	21-12-2025	10:09	0:20	0.000328	CABLE FAULT
520	22-12-2025	Part of : POCKET 11 JASOLA VIHAR	897	Other Outage	Planned Outage	22-12-2025	11:02	22-12-2025	12:43	1:41	0.001178	REPLACEMENT OF HT BUSHING ROD
521	22-12-2025	Part of : A-BLOCK NEW FRIENDS COLONY EAST	81	Other Outage	Planned Outage	22-12-2025	11:16	22-12-2025	14:05	2:49	0.002817	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES
522	24-12-2025	Part of : BLOCK J PRIVATE COLONY SRINIVAS PURI,	1521	Other Outage	Planned Outage	24-12-2025	13:31	24-12-2025	14:19	0:48	0.000800	MAINTENANCE OF HT O/H CIRCUIT
523	24-12-2025	Part of : BLOCK B JOGA BAI EXTENSION JOGA BAI OKHLA,	934	Other Outage	Planned Outage	24-12-2025	13:31	24-12-2025	14:19	0:48	0.000800	MAINTENANCE OF TRANSFORMER
524	24-12-2025	Part of : JAMIA NAGAR OKHLA,	9	Other Outage	Planned Outage	24-12-2025	13:30	24-12-2025	14:20	0:50	0.000833	MAINTENANCE OF TRANSFORMER
525	24-12-2025	Part of : BLOCK E SHAHEEN BAGH JASOLA VIHAR,	750	Other Outage	Planned Outage	24-12-2025	10:28	24-12-2025	13:02	2:34	0.001283	MAINTENANCE OF TRANSFORMER
526	26-12-2025	Part of : BLOCK A & C NEW FRIENDS COLONY EAST	534	Other Outage	Planned Outage	26-12-2025	10:57	26-12-2025	13:35	2:38	0.001317	OIL TOP UP IN TRANSFORMER
527	26-12-2025	Part of : BLOCK A NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	41	Other Outage	Planned Outage	26-12-2025	10:57	26-12-2025	13:37	2:40	0.001333	OIL TOP UP IN TRANSFORMER
528	26-12-2025	Part of : MASIHGARH OKHLA	45	Other Outage	Planned Outage	26-12-2025	10:56	26-12-2025	13:38	2:42	0.001350	OIL TOP UP IN TRANSFORMER
529	27-12-2025	Part of : POCKET 1 JASOLA VIHAR	211	Other Outage	Unplanned Outage	27-12-2025	13:21	27-12-2025	14:10	0:49	0.000299	REPAIR OF RMU
530	27-12-2025	Part of : BLOCK E PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	1132	Other Outage	Planned Outage	27-12-2025	10:34	27-12-2025	12:29	1:55	0.001278	REPLACEMET OF HT BUSHING ROD
531	27-12-2025	Part of : GHAFAR MANZIL COLONY JAMIA NAGAR OKHLA	1019	Other Outage	Planned Outage	27-12-2025	13:02	27-12-2025	15:45	2:43	0.002717	APPLY OF INSULATION TAPE HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE,OIL TOP UP IN TRANSFORMER
532	27-12-2025	Part of : BLOCK S PRIVATE COLONY SRINIVAS PURI	321	Other Outage	Planned Outage	27-12-2025	11:21	27-12-2025	13:47	2:26	0.002433	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
533	28-12-2025	Part of : NOOR NAGAR OKHLA,	184	Other Outage	Planned Outage	28-12-2025	13:33	28-12-2025	14:50	1:17	0.001283	SUB STATION CLEANING
534	29-12-2025	Part of : BLOCK D NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	331	Other Outage	Planned Outage	29-12-2025	11:09	29-12-2025	13:35	2:26	0.002433	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
535	30-12-2025	Part of : JAMIA NAGAR OKHLA	11	Other Outage	Planned Outage	30-12-2025	13:01	30-12-2025	15:28	2:27	0.002450	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
536	30-12-2025	Part of : A-BLOCK NEW FRIENDS COLONY EAST	135	Other Outage	Planned Outage	30-12-2025	11:14	30-12-2025	14:09	2:55	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
537	01-12-2025	Part of : SIRI FORT,BLOCK W GREATER KAILASH I GREATER KAILASH	915	Other Outage	Unplanned Outage	01-12-2025	10:22	01-12-2025	11:07	0:45	0.001638	TREE BRANCH FALLEN
538	01-12-2025	Part of : SANT NAGAR EAST OF KAILASH	605	Other Outage	Planned Outage	01-12-2025	15:00	01-12-2025	15:59	0:59	0.000852	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
539	01-12-2025	Part of : BLOCK B DAYANAND COLONY LAJPAT NAGAR	642	Other Outage	Planned Outage	01-12-2025	10:14	01-12-2025	11:09	0:55	0.000840	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
540	01-12-2025	Part of : BLOCK G KAILASH COLONY GREATER KAILASH	107	Other Outage	Planned Outage	01-12-2025	11:47	01-12-2025	13:57	2:10	0.001878	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
541	02-12-2025	Part of : SANT NAGAR EAST OF KAILASH	223	Other Outage	Planned Outage	02-12-2025	14:58	02-12-2025	15:51	0:53	0.000766	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
542	02-12-2025	Part of : BLOCK E EAST OF KAILASH	161	Other Outage	Planned Outage	02-12-2025	09:58	02-12-2025	12:45	2:47	0.002551	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
543	03-12-2025	Part of : SANT NAGAR EAST OF KAILASH	394	Other Outage	Planned Outage	03-12-2025	15:08	03-12-2025	16:01	0:53	0.000766	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
544	03-12-2025	Part of : BLOCK C GREATER KAILASH I	272	Other Outage	Planned Outage	03-12-2025	11:33	03-12-2025	14:01	2:28	0.002138	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
545	03-12-2025	Part of : BLOCK C DAYANAND COLONY LAJPAT NAGAR	602	Other Outage	Planned Outage	03-12-2025	10:00	03-12-2025	12:46	2:46	0.002398	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
546	04-12-2025	Part of : BLOCK A OKHLA PHASE II OKHLA INDUSTRIAL AREA	17	Other Outage	Unplanned Outage	04-12-2025	11:23	04-12-2025	13:45	2:22	0.001578	CONNECTION/DISCONNECTION OF HT/LT CABLES
547	04-12-2025	Part of : BLOCK A KAILASH COLONY GREATER KAILASH	148	Other Outage	Planned Outage	04-12-2025	12:53	04-12-2025	15:44	2:51	0.002470	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
548	05-12-2025	Part of : Q BLOCK LAJPAT NAGAR IV	951	Other Outage	Unplanned Outage	05-12-2025	13:26	05-12-2025	15:12	1:46	0.000589	REPAIRING OF HT O/H CIRCUIT
549	05-12-2025	Part of : GARHI EAST OF KAILASH	593	Other Outage	Planned Outage	05-12-2025	10:01	05-12-2025	12:46	2:45	0.002521	SUB STATION CLEANING
550	06-12-2025	Part of : PUMPING STATION GK-1 (HT CONSUMER)	0	Other Outage	Unplanned Outage	06-12-2025	00:37	06-12-2025	01:24	0:47	0.001541	FAULT IN HT CONSUMER PANEL (PUMP HOUSE G.K-1)
551	06-12-2025	Part of : G-BLOCK KAILASH COLONY GREATER KAILASH	107	Other Outage	Planned Outage	06-12-2025	11:29	06-12-2025	13:52	2:23	0.002066	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
552	07-12-2025	Part of : POCKET Y SANJAY COLONY II OKHLA PHASE II OKHLA INDUSTRIAL AREA	717	Other Outage	Planned Outage	07-12-2025	10:57	07-12-2025	14:13	3:16	0.002450	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF LT BUSHING ROD
553	08-12-2025	Part of : KAILASH COLONY GREATER KAILASH,	75	Other Outage	Planned Outage	08-12-2025	11:03	08-12-2025	13:56	2:53	0.002499	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
554	09-12-2025	Part of : BLOCK H KAILASH COLONY GREATER KAILASH	48	Other Outage	Planned Outage	09-12-2025	11:15	09-12-2025	13:53	2:38	0.002282	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
555	09-12-2025	Part of : BLOCK D EAST OF KAILASH	43	Other Outage	Planned Outage	09-12-2025	10:02	09-12-2025	12:52	2:50	0.002597	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
556	10-12-2025	Part of : NEHRU PLACE	57	Other Outage	Unplanned Outage	10-12-2025	14:57	10-12-2025	15:43	0:46	0.000664	GAS REFILLING/ REPAIRING OF RMU
557	10-12-2025	Part of : A-BLOCK KAILASH COLONY GREATER KAILASH	256	Other Outage	Planned Outage	10-12-2025	11:05	10-12-2025	14:12	3:07	0.002701	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
558	10-12-2025	Part of : MOUNT KAILASH APARTMENT EAST OF KAILASH	101	Other Outage	Planned Outage	10-12-2025	09:59	10-12-2025	12:46	2:47	0.002551	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
559	11-12-2025	Part of : KAILASH COLONY GREATER KAILASH	39	Other Outage	Planned Outage	11-12-2025	11:08	11-12-2025	13:56	2:48	0.002427	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
560	11-12-2025	Part of : BLOCK B AMRITPURI GARHI EAST OF KAILASH	1062	Other Outage	Planned Outage	11-12-2025	10:04	11-12-2025	13:00	2:56	0.002689	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
561	12-12-2025	Part of : BLOCK D EAST OF KAILASH,BLOCK E AMAR COLONY LAJPAT NAGAR,GARHI JHARIA MARIA EAST OF KAILASH	1197	Other Outage	Unplanned Outage	12-12-2025	11:28	12-12-2025	12:14	0:46	0.000601	TRANSIENT FAULT
562	12-12-2025	Part of : BLOCK W GREATER KAILASH I GREATER KAILASH,	54	Other Outage	Planned Outage	12-12-2025	12:14	12-12-2025	12:32	0:18	0.000260	REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
563	13-12-2025	Part of : BLOCK B PAMPOSH ENCLAVE GREATER KAILASH	273	Other Outage	Planned Outage	13-12-2025	11:04	13-12-2025	14:17	3:13	0.002788	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
564	14-12-2025	Part of : POCKET W OKHLA INDUSTRIAL AREA PHASE-2	61	Other Outage	Planned Outage	14-12-2025	11:13	14-12-2025	14:15	3:02	0.001517	DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
565	15-12-2025	Part of : KRISHI VIHAR GREATER KAILASH,SIRI FORT,MASJID MOTH PHASE I GREATER KAILASH,MASJID MOTH PHASE 2	998	Other Outage	Unplanned Outage	15-12-2025	22:58	15-12-2025	23:25	0:27	0.000015	HT SYSTEM FAULT
566	15-12-2025	Part of : BLOCK D & E EAST OF KAILASH, BLOCK E AMAR COLONY LAJPAT NAGAR, GARHI JHARIA MARIA EAST OF KAILASH, NATIONAL HEART INSTITUTE (HTC)	1197	Other Outage	Unplanned Outage	15-12-2025	13:10	15-12-2025	14:01	0:51	0.000553	HT SYSTEM FAULT
567	15-12-2025	Part of : KAILASH COLONY GREATER KAILASH	18	Other Outage	Planned Outage	15-12-2025	11:16	15-12-2025	13:50	2:34	0.002224	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,TIGHTENEING OF NUT BOLT
568	15-12-2025	Part of : BLOCK D EAST OF KAILASH	64	Other Outage	Planned Outage	15-12-2025	10:00	15-12-2025	12:50	2:50	0.002597	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
569	16-12-2025	Part of : BLOCK A GREATER KAILASH I GREATER KAILASH,	164	Other Outage	Planned Outage	16-12-2025	10:56	16-12-2025	13:56	3:00	0.002600	MAINTENANCE OF TRANSFORMER
570	16-12-2025	Part of : SHERA MOHALLA GARHI EAST OF KAILASH,	1118	Other Outage	Planned Outage	16-12-2025	10:00	16-12-2025	13:00	3:00	0.002750	MAINTENANCE OF TRANSFORMER
571	17-12-2025	Part of : KRISHI VIHAR GREATER KAILASH,SIRI FORT,MASJID MOTH PHASE I GREATER KAILASH,MASJID MOTH PHASE 2 GREATER KAILASH	998	Other Outage	Unplanned Outage	17-12-2025	22:04	17-12-2025	22:47	0:43	0.000119	FAULT IN HT CONSUMER PANEL (DTL)
572	17-12-2025	Part of : KALASH ENCLAVE GREATER KAILASH	395	Other Outage	Planned Outage	17-12-2025	11:10	17-12-2025	14:42	3:32	0.003062	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
573	17-12-2025	Part of : GARI EXTENSION AMRITPURI EAST OF KAILASH	467	Other Outage	Planned Outage	17-12-2025	09:58	17-12-2025	12:51	2:53	0.002643	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
574	18-12-2025	Part of : A-BLOCK GREATER KAILASH-1	36	Other Outage	Planned Outage	18-12-2025	11:44	18-12-2025	14:01	2:17	0.001979	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
575	18-12-2025	Part of : E-BLOCK AMAR COLONY LAJPAT NAGAR	367	Other Outage	Planned Outage	18-12-2025	09:58	18-12-2025	12:42	2:44	0.002506	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
576	19-12-2025	Part of : POCKET D OKHLA PHASE II OKHLA INDUSTRIAL AREA	133	Other Outage	Unplanned Outage	19-12-2025	12:45	19-12-2025	14:36	1:51	0.002158	MOBILE TRANSFORMER REPLACEMENT
577	19-12-2025	Part of : HEMKUNT COLONY GREATER KAILASH	176	Other Outage	Planned Outage	19-12-2025	14:06	19-12-2025	16:17	2:11	0.001892	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING
578	19-12-2025	Part of : SANT NAGAR EAST OF KAILASH	618	Other Outage	Planned Outage	19-12-2025	10:26	19-12-2025	15:47	5:21	0.004904	REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS
579	20-12-2025	Part of : BLOCK A CHIRAG ENCLAVE GREATER KAILASH,	263	Other Outage	Planned Outage	20-12-2025	11:37	20-12-2025	13:51	2:14	0.001936	MAINTENANCE OF TRANSFORMER
580	21-12-2025	Part of : PUMPING STATION, GK-1 (HTC)	0	Other Outage	Unplanned Outage	21-12-2025	11:40	21-12-2025	12:36	0:56	0.001416	FAULT IN HT CONSUMER PANEL (PUMP STATION)
581	21-12-2025	Part of : POCKET A SANJAY COLONY II OKHLA PHASE II OKHLA INDUSTRIAL AREA	149	Other Outage	Planned Outage	21-12-2025	11:18	21-12-2025	14:18	3:00	0.001500	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
582	22-12-2025	Part of : KALASH ENCLAVE GREATER KAILASH	163	Other Outage	Planned Outage	22-12-2025	12:16	22-12-2025	14:00	1:44	0.001444	CT REPLACEMENT
583	22-12-2025	Part of : KRISHI VIHAR GREATER KAILASH	97	Other Outage	Planned Outage	22-12-2025	10:55	22-12-2025	14:03	3:08	0.002716	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
584	22-12-2025	Part of : NATIONAL PARK LAJPAT NAGAR	329	Other Outage	Planned Outage	22-12-2025	09:59	22-12-2025	12:52	2:53	0.002643	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
585	23-12-2025	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA, SHYAM NAGAR OKHLA INDUSTRIAL AREA	654	Other Outage	Unplanned Outage	23-12-2025	05:01	23-12-2025	05:15	0:14	0.000039	CABLE FAULT
586	23-12-2025	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA	57	Other Outage	Unplanned Outage	23-12-2025	11:04	23-12-2025	11:54	0:50	0.000472	FAULT IN HT CONSUMER PANEL (PLOT NO.-227 OKHLA PH-III)
587	23-12-2025	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA, SHYAM NAGAR OKHLA INDUSTRIAL AREA	654	Other Outage	Unplanned Outage	23-12-2025	04:07	23-12-2025	04:40	0:33	0.000092	HT SYSTEM FAULT
588	23-12-2025	Part of : HARKESH NAGAR OKHLA INDUSTRIAL AREA	477	Other Outage	Unplanned Outage	23-12-2025	00:46	23-12-2025	01:30	0:44	0.000318	BIRDAGE
589	23-12-2025	Part of : KAILASH COLONY GREATER KAILASH	148	Other Outage	Planned Outage	23-12-2025	11:14	23-12-2025	13:38	2:24	0.002080	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
590	24-12-2025	Part of : BLOCK A KAILASH COLONY GREATER KAILASH,BLOCK E EAST OF KAILASH,BLOCK N GREATER KAILASH I GREATER KAILASH	2201	Other Outage	Unplanned Outage	24-12-2025	12:16	24-12-2025	13:00	0:44	0.000037	HT SYSTEM FAULT
591	24-12-2025	Part of : POCKET D OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA,	722	Other Outage	Unplanned Outage	24-12-2025	15:00	24-12-2025	16:08	1:08	0.000000	REFILLING OIL IN TRANSFORMER
592	24-12-2025	Part of : POCKET D OKHLA PHASE II OKHLA INDUSTRIAL AREA,	148	Other Outage	Unplanned Outage	24-12-2025	14:23	24-12-2025	16:07	1:44	0.000000	REFILLING OIL IN TRANSFORMER
593	24-12-2025	Part of : BLOCK B EAST OF KAILASH,	307	Other Outage	Planned Outage	24-12-2025	10:39	24-12-2025	11:11	0:32	0.000489	MAINTENANCE OF TRANSFORMER
594	26-12-2025	Part of : BLOCK B PAMPOSH ENCLAVE GREATER KAILASH	260	Other Outage	Planned Outage	26-12-2025	11:04	26-12-2025	14:39	3:35	0.003106	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
595	26-12-2025	Part of : VIKRAM VIHAR LAJPAT NAGAR IV	50	Other Outage	Planned Outage	26-12-2025	09:58	26-12-2025	12:11	2:13	0.002032	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
596	27-12-2025	Part of : MASJID MOTH PHASE I GREATER KAILASH	90	Other Outage	Unplanned Outage	27-12-2025	13:14	27-12-2025	13:58	0:44	0.000636	CHECK RMU PROTECTION
597	27-12-2025	Part of : BLOCK A CHIRAG ENCLAVE GREATER KAILASH	263	Other Outage	Planned Outage	27-12-2025	11:40	27-12-2025	14:01	2:21	0.002037	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
598	27-12-2025	Part of : NATIONAL PARK LAJPAT NAGAR	8	Other Outage	Planned Outage	27-12-2025	10:00	27-12-2025	12:33	2:33	0.002338	REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,TIGHTENEING OF NUT BOLT
599	29-12-2025	Part of : NATIONAL PARK LAJPAT NAGAR	282	Other Outage	Planned Outage	29-12-2025	09:59	29-12-2025	11:07	1:08	0.001039	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
600	29-12-2025	Part of : KAILASH COLONY GREATER KAILASH	31	Other Outage	Planned Outage	29-12-2025	11:11	29-12-2025	13:54	2:43	0.002354	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
601	30-12-2025	Part of : KRISHI VIHAR GREATER KAILASH	119	Other Outage	Planned Outage	30-12-2025	11:57	30-12-2025	14:16	2:19	0.002008	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
602	30-12-2025	Part of : E-BLOCK EAST OF KAILASH	380	Other Outage	Planned Outage	30-12-2025	09:58	30-12-2025	12:48	2:50	0.002597	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
603	31-12-2025	Part of : BLOCK G KAILASH COLONY GREATER KAILASH	170	Other Outage	Planned Outage	31-12-2025	12:32	31-12-2025	13:15	0:43	0.000621	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
604	31-12-2025	Part of : BLOCK E EAST OF KAILASH	114	Other Outage	Planned Outage	31-12-2025	10:00	31-12-2025	12:44	2:44	0.002506	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
605	01-12-2025	Part of : BLOCK F LAJPAT NAGAR I LAJPAT NAGAR,BLOCK H LAJPAT NAGAR I LAJPAT NAGAR,BLOCK G LAJPAT NAGAR I LAJPAT NAGAR	1678	Other Outage	Unplanned Outage	01-12-2025	14:43	01-12-2025	15:23	0:40	0.000000	FAULT IN HT CONSUMER PANEL (JAL SADHAN)
606	01-12-2025	Part of : BLOCK B SEWA NAGAR	1353	Other Outage	Planned Outage	01-12-2025	11:10	01-12-2025	14:23	3:13	0.001716	REPLACEMENT OF HT BUSHING ROD
607	01-12-2025	Part of : BLOCK K JANGUPURA EXTENSION JANGPURA	318	Other Outage	Planned Outage	01-12-2025	11:03	01-12-2025	14:21	3:18	0.001100	REPLACEMENT OF HT BUSHING ROD
608	01-12-2025	Part of : BLOCK A LAJPAT NAGAR III LAJPAT NAGAR	604	Other Outage	Planned Outage	01-12-2025	11:29	01-12-2025	14:22	2:53	0.000961	REPLACEMENT OF HT BUSHING ROD
609	01-12-2025	Part of : BLOCK A LAJPAT NAGAR II LAJPAT NAGAR	499	Other Outage	Planned Outage	01-12-2025	10:12	01-12-2025	12:59	2:47	0.001856	REPLACEMENT OF HT BUSHING ROD
610	02-12-2025	Part of : CGO COMPLEX PRAGATI VIHAR	9	Other Outage	Unplanned Outage	02-12-2025	21:55	02-12-2025	22:39	0:44	0.000000	FAULT IN HT CONSUMER PANEL (CGO COMPLEX)
611	02-12-2025	Part of : CGO COMPLEX PRAGATI VIHAR	9	Other Outage	Unplanned Outage	02-12-2025	20:22	02-12-2025	21:16	0:54	0.000000	FAULT IN HT CONSUMER PANEL (CGO COMPLEX)
612	02-12-2025	Part of : NCRTC JUNGPUA	0	Other Outage	Unplanned Outage	02-12-2025	06:19	02-12-2025	07:05	0:46	0.000115	CABLE FAULT
613	02-12-2025	Part of : MAHAVEER NAGAR BHOLA NAGAR SOUTH EXTENSION PART 1	524	Other Outage	Planned Outage	02-12-2025	12:07	02-12-2025	15:27	3:20	0.001000	REPLACEMET OF HT BUSHING ROD
614	02-12-2025	Part of : BLOCK 12 NEHRU NAGAR LAJPAT NAGAR	1183	Other Outage	Planned Outage	02-12-2025	11:36	02-12-2025	15:26	3:50	0.000958	REPLACEMET OF HT BUSHING ROD
615	03-12-2025	Part of : RISHI NAGAR SOUTH EXTENSION PART 1,PREM NAGAR BK DUTT COLONY	2123	Other Outage	Unplanned Outage	03-12-2025	13:34	03-12-2025	15:44	2:10	0.001083	RMU GAS REFILLING
616	03-12-2025	Part of : POCKET C SIDDHARTHA NAGAR	996	Other Outage	Planned Outage	03-12-2025	11:20	03-12-2025	14:37	3:17	0.002463	INSTALLATION OF BUS BAR
617	04-12-2025	Part of : GAS TURBINE POWER STATION IP ESTATE,SANT NAGAR SUNDAR NAGAR,BLOCK A GANGA VIHAR SARAI KALE KHAN,PRAGATI MAIDAN	944	Other Outage	Unplanned Outage	04-12-2025	14:58	04-12-2025	15:32	0:34	0.000746	CABLE FAULT
618	04-12-2025	Part of : BLOCK 10 LODI COLONY	154	Other Outage	Planned Outage	04-12-2025	11:01	04-12-2025	14:10	3:09	0.000630	REPLACEMENT OF HT BUSHING ROD
619	04-12-2025	Part of : BLOCK E LAJPAT NAGAR III LAJPAT NAGAR	643	Other Outage	Planned Outage	04-12-2025	11:37	04-12-2025	14:11	2:34	0.001283	REPLACEMENT OF HT BUSHING ROD
620	04-12-2025	Part of : BLOCK D DEFENCE COLONY	490	Other Outage	Planned Outage	04-12-2025	11:04	04-12-2025	14:12	3:08	0.001462	REPLACEMENT OF HT BUSHING ROD
621	05-12-2025	Part of : C BLOCK JUNGPUA B JANGPURA,BLOCK B JUNGPUA B JANGPURA,BLOCK A NIZAMUDDIN WEST	2508	Other Outage	Unplanned Outage	05-12-2025	10:33	05-12-2025	11:25	0:52	0.001156	FAULT IN HT CONSUMER PANEL (SUNDER NURSURY)
622	05-12-2025	Part of : BLOCK C DEFENCE COLONY	251	Other Outage	Planned Outage	05-12-2025	10:59	05-12-2025	14:48	3:49	0.000763	REPLACEMET OF HT BUSHING ROD
623	06-12-2025	Part of : SUNDAR NAGAR,NATIONAL ZOOLOGICAL PARK	428	Other Outage	Unplanned Outage	06-12-2025	11:51	06-12-2025	12:48	0:57	0.000317	REPAIRING OF RMU
624	06-12-2025	Part of : BLOCK C DEFENCE COLONY,	190	Other Outage	Planned Outage	06-12-2025	10:50	06-12-2025	13:48	2:58	0.000593	REPLACEMENT OF HT BUSHING ROD
625	08-12-2025	Part of : BEHLOLPUR BANGAR SARAI KALE KHAN,NIZAMUDDIN EAST,BLOCK B SARAI KALE KHAN,BLOCK A SARAI KALE KHAN	3513	Other Outage	Unplanned Outage	08-12-2025	16:04	08-12-2025	16:56	0:52	0.000000	CABLE DAMAGE BY OUTSIDE AGENCY (IGL)
626	08-12-2025	Part of : POCKET A SIDDHARTHA NAGAR,	5	Other Outage	Planned Outage	08-12-2025	11:34	08-12-2025	15:10	3:36	0.000900	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
627	08-12-2025	Part of : BLOCK D DEFENCE COLONY,	121	Other Outage	Planned Outage	08-12-2025	11:27	08-12-2025	15:11	3:44	0.001680	REPLACEMET OF HT BUSHING ROD
628	09-12-2025	Part of : BLOCK H LAJPAT NAGAR I LAJPAT NAGAR	655	Other Outage	Planned Outage	09-12-2025	11:26	09-12-2025	14:48	3:22	0.001122	REPLACEMENT OF HT BUSHING ROD
629	09-12-2025	Part of : KILOKARI PHASE 1 SUNLIGHT COLONY	1039	Other Outage	Planned Outage	09-12-2025	11:33	09-12-2025	14:49	3:16	0.004846	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF GAS KIT AND OIL SEAL
630	10-12-2025	Part of : H & L-BLOCK H LAJPAT NAGAR-2	784	Other Outage	Planned Outage	10-12-2025	11:47	10-12-2025	16:11	4:24	0.001833	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
631	10-12-2025	Part of : C-BLOCK DEFENCE COLONY	327	Other Outage	Planned Outage	10-12-2025	10:54	10-12-2025	14:43	3:49	0.001654	REPLACEMENT OF HT BUSHING ROD
632	10-12-2025	Part of : BLOCK 18 INSTITUTIONAL AREA LODI COLONY	116	Other Outage	Planned Outage	10-12-2025	10:58	10-12-2025	14:40	3:42	0.000925	REPLACEMENT OF HT BUSHING ROD
633	11-12-2025	Part of : BLOCK D DEFENCE COLONY	217	Other Outage	Planned Outage	11-12-2025	11:39	11-12-2025	14:34	2:55	0.000729	REPLACEMET OF HT BUSHING ROD
634	11-12-2025	Part of : BLOCK 7 LODI COLONY	116	Other Outage	Planned Outage	11-12-2025	11:16	11-12-2025	15:57	4:41	0.001561	REPLACEMET OF HT BUSHING ROD
635	11-12-2025	Part of : BLOCK F LAJPAT NAGAR III	316	Other Outage	Planned Outage	11-12-2025	11:16	11-12-2025	15:56	4:40	0.002256	REPLACEMET OF HT BUSHING ROD
636	12-12-2025	Part of : HTC:TYAGRAJ STADIUM	0	Other Outage	Unplanned Outage	12-12-2025	13:55	12-12-2025	14:43	0:48	0.000000	CABLE DAMAGE BY OUTSIDE AGENCY (ITDC-CPWD)
637	12-12-2025	Part of : APPU GHAR PRAGATI MAIDAN,	2	Other Outage	Planned Outage	12-12-2025	11:43	12-12-2025	14:43	3:00	0.001500	REPLACEMET OF HT BUSHING ROD
638	13-12-2025	Part of : PRAGATI VIHAR	17	Other Outage	Unplanned Outage	13-12-2025	04:01	13-12-2025	04:55	0:54	0.000000	CABLE FAULT
639	13-12-2025	Part of : BLOCK C JANGUPURA EXTENSION JANGPURA	657	Other Outage	Planned Outage	13-12-2025	11:00	13-12-2025	14:53	3:53	0.001294	REPLACEMENT OF HT BUSHING ROD
640	13-12-2025	Part of : BLOCK A DEFENCE COLONY	444	Other Outage	Planned Outage	13-12-2025	10:39	13-12-2025	14:20	3:41	0.000921	REPLACEMENT OF HT BUSHING ROD
641	14-12-2025	Part of : RISHI NAGAR SOUTH EXTENSION PART 1,PREM NAGAR BK DUTT COLONY	2130	Other Outage	Unplanned Outage	14-12-2025	22:07	14-12-2025	22:57	0:50	0.000333	HT SYSTEM FAULT
642	15-12-2025	Part of : AVIATION COLONY INA COLONY	516	Other Outage	Planned Outage	15-12-2025	12:23	15-12-2025	16:22	3:59	0.001859	REPLACEMET OF HT BUSHING ROD
643	15-12-2025	Part of : BLOCK D DEFENCE COLONY	143	Other Outage	Planned Outage	15-12-2025	10:43	15-12-2025	13:44	3:01	0.000754	REPLACEMENT OF HT BUSHING ROD
644	16-12-2025	Part of : BLOCK C NIZAMUDDIN EAST,	388	Other Outage	Planned Outage	16-12-2025	14:42	16-12-2025	16:33	1:51	0.001233	MAINTENANCE OF RMU
645	16-12-2025	Part of : LODHI ROAD QUARTERS LODI COLONY,	229	Other Outage	Planned Outage	16-12-2025	11:36	16-12-2025	14:33	2:57	0.000885	MAINTENANCE OF TRANSFORMER
646	16-12-2025	Part of : BLOCK C DEFENCE COLONY,	158	Other Outage	Planned Outage	16-12-2025	11:07	16-12-2025	14:53	3:46	0.001256	MAINTENANCE OF TRANSFORMER
647	16-12-2025	Part of : JANGUPURA EXTENSION JANGPURA,	1703	Other Outage	Planned Outage	16-12-2025	11:18	16-12-2025	14:37	3:19	0.002488	MAINTENANCE OF TRANSFORMER
648	16-12-2025	Part of : POCKET C SIDDHARTHA NAGAR,	2269	Other Outage	Planned Outage	16-12-2025	11:21	16-12-2025	14:35	3:14	0.004958	MAINTENANCE OF TRANSFORMER
649	18-12-2025	Part of : B & C-BLOCK JUNGUPURA,A-BLOCK NIZAMUDDIN WEST	2513	Other Outage	Unplanned Outage	18-12-2025	10:39	18-12-2025	11:05	0:26	0.000607	CABALE DAMAGE BY OUTSIDE AGENCY (ASI)
650	18-12-2025	Part of : A-BLOCK NIZAMUDDIN WEST	772	Other Outage	Planned Outage	18-12-2025	11:34	18-12-2025	15:58	4:24	0.001100	REPLACEMENT OF HT BUSHING ROD
651	19-12-2025	Part of : LODHI COLONEY NEAR COMP CENTER	109	Other Outage	Planned Outage	19-12-2025	10:59	19-12-2025	15:08	4:09	0.000830	REPLACEMET OF HT BUSHING ROD
652	19-12-2025	Part of : SUNDAR NAGAR	18	Other Outage	Planned Outage	19-12-2025	10:59	19-12-2025	14:09	3:10	0.001583	REPLACEMET OF HT BUSHING ROD
653	20-12-2025	Part of : POCKET B SIDDHARTHA NAGAR,POCKET C SIDDHARTHA NAGAR,	468	Other Outage	Planned Outage	20-12-2025	10:56	20-12-2025	14:18	3:22	0.006733	MAINTENANCE OF TRANSFORMER
654	22-12-2025	Part of : SHIV NAGAR KOTLA MUBARAKPUR SOUTH EXTENSION PART 1	866	Other Outage	Planned Outage	22-12-2025	12:19	22-12-2025	15:29	3:10	0.001319	REPLACEMENT OF HT BUSHING ROD
655	22-12-2025	Part of : L-BLOCK LAJPAT NAGAR-2	510	Other Outage	Planned Outage	22-12-2025	11:21	22-12-2025	14:19	2:58	0.001731	REPLACEMENT OF HT BUSHING ROD
656	23-12-2025	Part of : DEFENCE COLONY, JAWAHARLAL NEHRU STADIUM PRAGATI VIHAR	4	Other Outage	Unplanned Outage	23-12-2025	22:35	23-12-2025	23:19	0:44	0.000098	HT SYSTEM FAULT
657	23-12-2025	Part of : BLOCK C NIZAMUDDIN EAST	156	Other Outage	Planned Outage	23-12-2025	11:44	23-12-2025	16:14	4:30	0.001350	REPLACEMET OF HT BUSHING ROD
658	23-12-2025	Part of : NEHRU NAGAR LAJPAT NAGAR	551	Other Outage	Planned Outage	23-12-2025	11:29	23-12-2025	16:12	4:43	0.002751	REPLACEMET OF HT BUSHING ROD
659	24-12-2025	Part of : JAWAHARLAL NEHRU STADIUM PRAGATI VIHAR	4	Other Outage	Unplanned Outage	24-12-2025	08:41	24-12-2025	09:16	0:35	0.000039	HT SYSTEM FAULT
660	24-12-2025	Part of : BLOCK I LAJPAT NAGAR I LAJPAT NAGAR,	790	Other Outage	Planned Outage	24-12-2025	11:39	24-12-2025	15:40	4:01	0.002678	MAINTENANCE OF TRANSFORMER
661	26-12-2025	Part of : VIDYUT VIHAR PHASE 1 SUNLIGHT COLONY	242	Other Outage	Planned Outage	26-12-2025	11:24	26-12-2025	14:35	3:11	0.002653	REPLACEMENT OF GAS KIT AND OIL SEAL
662	27-12-2025	Part of : CGO COMPLEX PRAGATI VIHAR	14	Other Outage	Planned Outage	27-12-2025	11:24	27-12-2025	14:25	3:01	0.000251	REPLACEMET OF HT BUSHING ROD
663	27-12-2025	Part of : ARAB KI SARAI NIZAMUDDIN EAST	287	Other Outage	Planned Outage	27-12-2025	11:24	27-12-2025	14:26	3:02	0.000506	REPLACEMET OF HT BUSHING ROD
664	29-12-2025	Part of : BLOCK H LAJPAT NAGAR II LAJPAT NAGAR,BLOCK L LAJPAT NAGAR II LAJPAT NAGAR	787	Other Outage	Planned Outage	29-12-2025	11:55	29-12-2025	16:20	4:25	0.001104	REPLACEMENT OF LT BUSHING ROD
665	30-12-2025	Part of : BEHLOLPUR BANGAR SARAI KALE KHAN	1038	Other Outage	Planned Outage	30-12-2025	11:15	30-12-2025	14:17	3:02	0.002022	REPLACEMENT OF HT BUSHING ROD
666	30-12-2025	Part of : H-BLOCK LAJPAT NAGAR-2	787	Other Outage	Planned Outage	30-12-2025	11:15	30-12-2025	14:34	3:19	0.002211	REPLACEMENT OF HT BUSHING ROD
667	31-12-2025	Part of : DEFENCE COLONY BHOGAL JANGPURA	952	Other Outage	Planned Outage	31-12-2025	12:22	31-12-2025	15:27	3:05	0.000514	REPLACEMET OF HT BUSHING ROD
668	01-12-2025	Part of : SECTOR 8 RAMAKRISHNA PURAM	915	Other Outage	Planned Outage	01-12-2025	11:03	01-12-2025	15:21	4:18	0.002150	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
669	01-12-2025	Part of : SATYA NIKETAN MOTI BAGH SOUTH	799	Other Outage	Planned Outage	01-12-2025	10:06	01-12-2025	13:43	3:37	0.000723	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF HT BUSHING ROD
670	02-12-2025	Part of : SECTOR 1 RAMAKRISHNA PURAM	1360	Other Outage	Unplanned Outage	02-12-2025	14:53	02-12-2025	16:20	1:27	0.000604	PREVENTIVE MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
671	02-12-2025	Part of : DHAULA KUAN ENCLAVE	3	Other Outage	Planned Outage	02-12-2025	13:37	02-12-2025	17:27	3:50	0.000639	CLEANING OF HT BUSHING PER WAY,RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
672	02-12-2025	Part of : JAWAHAR LAL NEHRU UNIVERSITY OLD JNU CAMPUS MUNIRKA	99	Other Outage	Planned Outage	02-12-2025	10:32	02-12-2025	14:36	4:04	0.000407	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMET OF HT BUSHING ROD
673	03-12-2025	Part of : JAWAHAR LAL NEHRU UNIVERSITY OLD JNU CAMPUS MUNIRKA, FSI MUNIRAKA (HTC), NTRO OLD JNU CAMPUS (HTC)	99	Other Outage	Unplanned Outage	03-12-2025	15:07	03-12-2025	15:44	0:37	0.000154	FAULT IN HT CONSUMER PANEL (FSI MUNIRKA)
674	03-12-2025	Part of : SECTOR 8 RAMAKRISHNA PURAM	286	Other Outage	Planned Outage	03-12-2025	11:11	03-12-2025	14:15	3:04	0.000767	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING
675	03-12-2025	Part of : BLOCK C WEST END	155	Other Outage	Planned Outage	03-12-2025	10:05	03-12-2025	13:38	3:33	0.000769	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
676	04-12-2025	Part of : SECTOR 8 RAMAKRISHNA PURAM	281	Other Outage	Planned Outage	04-12-2025	11:11	04-12-2025	14:23	3:12	0.000800	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
677	04-12-2025	Part of : MAHIPALPUR	1	Other Outage	Planned Outage	04-12-2025	10:44	04-12-2025	14:47	4:03	0.000473	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
678	05-12-2025	Part of : NAGALAND HOUSE, PLOT NO.4,SEC-12,RKPURAM	1	Other Outage	Planned Outage	05-12-2025	11:01	05-12-2025	12:47	1:46	0.000294	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
679	05-12-2025	Part of : WEST BLOCK RAMAKRISHNA PURAM	2	Other Outage	Planned Outage	05-12-2025	13:36	05-12-2025	15:41	2:05	0.000278	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING
680	05-12-2025	Part of : BLOCK F NANAKPURA MOTI BAGH SOUTH	292	Other Outage	Planned Outage	05-12-2025	10:22	05-12-2025	13:36	3:14	0.000539	INSTALLATION OF HT BOOTS,REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
681	06-12-2025	Part of : IGL, SECTOR-9 R.K.PURAM (HT CONSUMER)	1	Other Outage	Planned Outage	06-12-2025	14:13	06-12-2025	14:52	0:39	0.000163	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
682	06-12-2025	Part of : MUNIRKA ENCLAVE	88	Other Outage	Planned Outage	06-12-2025	12:25	06-12-2025	14:51	2:26	0.000284	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
683	06-12-2025	Part of : SECTOR 9 RAMAKRISHNA PURAM	609	Other Outage	Planned Outage	06-12-2025	11:06	06-12-2025	14:06	3:00	0.001000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
684	06-12-2025	Part of : SATYA NIKETAN MOTI BAGH SOUTH	570	Other Outage	Planned Outage	06-12-2025	10:13	06-12-2025	13:23	3:10	0.000686	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING ROD
685	08-12-2025	Part of : BLOCK H NANAKPURA MOTI BAGH SOUTH,	136	Other Outage	Planned Outage	08-12-2025	13:28	08-12-2025	15:42	2:14	0.000298	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACMET,SUB STATION CLEANING
686	08-12-2025	Part of : SECTOR 10 RAMAKRISHNA PURAM,	165	Other Outage	Planned Outage	08-12-2025	11:06	08-12-2025	13:49	2:43	0.000906	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
687	08-12-2025	Part of : SECTOR 9 RAMAKRISHNA PURAM,	455	Other Outage	Planned Outage	08-12-2025	11:38	08-12-2025	16:16	4:38	0.000000	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,LT AB SAGGING PER SPAN
688	09-12-2025	Part of : D.P.S. SECTOR-12, R.K.PURAM (HTC)	1	Other Outage	Planned Outage	09-12-2025	11:10	09-12-2025	12:33	1:23	0.000277	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF LT BUSHING ROD
689	09-12-2025	Part of : MUNIRKA VIHAR MUNIRKA	574	Other Outage	Planned Outage	09-12-2025	15:26	09-12-2025	17:30	2:04	0.000620	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
690	09-12-2025	Part of : SATYA NIKETAN MOTI BAGH SOUTH	512	Other Outage	Planned Outage	09-12-2025	10:11	09-12-2025	14:16	4:05	0.000408	INSTALLATION OF HT BOOTS,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
691	09-12-2025	Part of : BASANT GAON VASANT VIHAR	5	Other Outage	Planned Outage	09-12-2025	10:33	09-12-2025	13:41	3:08	0.000261	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
692	10-12-2025	Part of : C-BLOCK WEST END COLONY	128	Other Outage	Planned Outage	10-12-2025	10:04	10-12-2025	13:07	3:03	0.000559	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD
693	11-12-2025	Part of : SECTOR 4 SHANTI NIKETAN	235	Other Outage	Planned Outage	11-12-2025	10:16	11-12-2025	11:01	0:45	0.000150	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
694	11-12-2025	Part of : D.P.S. HOSTEL SECTOR-12 R.K.PURAM (HTC)	1	Other Outage	Planned Outage	11-12-2025	11:22	11-12-2025	13:15	1:53	0.000377	REPLACEMET OF HT BUSHING ROD
695	11-12-2025	Part of : BLOCK F VASANT VIHAR	301	Other Outage	Planned Outage	11-12-2025	12:11	11-12-2025	17:46	5:35	0.005583	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
696	11-12-2025	Part of : VASANT ENCLAVE VASANT VIHAR	1	Other Outage	Planned Outage	11-12-2025	10:50	11-12-2025	14:03	3:13	0.000643	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
697	12-12-2025	Part of : SECTOR 9 RAMAKRISHNA PURAM,	456	Other Outage	Planned Outage	12-12-2025	12:16	12-12-2025	13:57	1:41	0.000000	1PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN
698	12-12-2025	Part of : NIVEDITA KUNJ SECTOR 10 RAMAKRISHNA PURAM,	93	Other Outage	Planned Outage	12-12-2025	11:19	12-12-2025	13:43	2:24	0.000600	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
699	12-12-2025	Part of : BLOCK H NANAKPURA MOTI BAGH SOUTH,	467	Other Outage	Planned Outage	12-12-2025	10:02	12-12-2025	13:39	3:37	0.000603	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD
700	13-12-2025	Part of : CGHC COLONY VASANT VIHAR	40	Other Outage	Planned Outage	13-12-2025	11:25	13-12-2025	14:27	3:02	0.001011	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
701	14-12-2025	Part of : BHIKAJI CAMA PLACE RAMAKRISHNA PURAM	19	Other Outage	Unplanned Outage	14-12-2025	11:28	14-12-2025	15:20	3:52	0.000644	REPLACEMENT OF RMU
702	15-12-2025	Part of : MUNIRKA VIHAR MUNIRKA	574	Other Outage	Planned Outage	15-12-2025	11:26	15-12-2025	12:44	1:18	0.001517	REPLACEMET OF HT BUSHING ROD
703	15-12-2025	Part of : WEST BLOCK RAMAKRISHNA PURAM	225	Other Outage	Planned Outage	15-12-2025	13:19	15-12-2025	15:47	2:28	0.000411	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
704	16-12-2025	Part of : HTC:D.P.S. INTERNATIONAL, R.K.PURAM	1	Other Outage	Planned Outage	16-12-2025	13:47	16-12-2025	15:05	1:18	0.000108	MAINTENANCE OF TRANSFORMER
705	18-12-2025	Part of : BASANT GAON VASANT VIHAR,POCKET 2 SECTOR 2 DWARKA	752	Other Outage	Unplanned Outage	18-12-2025	08:24	18-12-2025	08:50	0:26	0.000152	BIRDAGE
706	18-12-2025	Part of : WEST BLOCK RAMAKRISHNA PURAM	1436	Other Outage	Unplanned Outage	18-12-2025	10:58	18-12-2025	12:50	1:52	0.000000	REPAIRING OF RMU/FAULT IN RMU
707	18-12-2025	Part of : SUBROTO PARK	4	Other Outage	Planned Outage	18-12-2025	10:55	18-12-2025	14:12	3:17	0.000219	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
708	18-12-2025	Part of : MOTILAL NEHRU CAMP OLD JNU CAMPUS MUNIRKA	903	Other Outage	Planned Outage	18-12-2025	10:41	18-12-2025	13:35	2:54	0.001208	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
709	20-12-2025	Part of : SONIA GANDHI CAMP SECTOR 6 RAMAKRISHNA PURAM,	300	Other Outage	Unplanned Outage	20-12-2025	11:34	20-12-2025	12:48	1:14	0.000000	REPAIRING OF RMU
710	20-12-2025	Part of : BLOCK H NANAKPURA MOTI BAGH SOUTH,	136	Other Outage	Planned Outage	20-12-2025	11:54	20-12-2025	16:55	5:01	0.000753	MAINTENANCE OF TRANSFORMER
711	20-12-2025	Part of : SECTOR 9 RAMAKRISHNA PURAM,	49	Other Outage	Planned Outage	20-12-2025	10:51	20-12-2025	13:06	2:15	0.000300	MAINTENANCE OF TRANSFORMER
712	20-12-2025	Part of : INDIAN AIR LINES AND AIR INDIA ESTATE VASANT VIHAR,	2	Other Outage	Planned Outage	20-12-2025	11:02	20-12-2025	13:09	2:07	0.000176	MAINTENANCE OF TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
713	22-12-2025	Part of : SECTOR 7 RAMAKRISHNA PURAM	651	Other Outage	Unplanned Outage	22-12-2025	16:22	22-12-2025	17:09	0:47	0.000000	HT SYSTEM FAULT
714	22-12-2025	Part of : SECTOR 5 RAMAKRISHNA PURAM	261	Other Outage	Planned Outage	22-12-2025	11:03	22-12-2025	12:32	1:29	0.000494	INSTALLATION OF BUS BAR,REPLACEMENT OF HT BUSHING ROD
715	23-12-2025	Part of : BASANT LOK VASANT VIHAR, INDIAN AIR LINES AND AIR INDIA ESTATE VASANT VIHAR, CGHC COLONY VASANT VIHAR, A- BLOCK PARK KUSUMPUR PAHARI, JHARKHAND HOUSE (HTC)	4815	Other Outage	Unplanned Outage	23-12-2025	20:57	23-12-2025	21:44	0:47	0.000287	FAULT IN HT CONSUMER PANEL (JHARKHAND HOUSE)
716	23-12-2025	Part of : SECTOR 7 RAMAKRISHNA PURAM	418	Other Outage	Planned Outage	23-12-2025	14:27	23-12-2025	17:04	2:37	0.000436	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
717	23-12-2025	Part of : GAIL PLOT NO.-16 B.C.PLACE (HTC)	1	Other Outage	Planned Outage	23-12-2025	11:15	23-12-2025	13:25	2:10	0.000794	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMENT OF INSULATION RESISTANCE,SUB STATION CLEANING
718	24-12-2025	Part of : BLOCK E MOTI BAGH SOUTH,	1107	Other Outage	Planned Outage	24-12-2025	10:44	24-12-2025	12:25	1:41	0.000393	MAINTENANCE OF TRANSFORMER
719	25-12-2025	Part of : CPWD WEST BLOCK, R.K.PURAM (HTC)	1	Other Outage	Planned Outage	25-12-2025	12:05	25-12-2025	13:41	1:36	0.000400	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
720	25-12-2025	Part of : CWC, CPWD WEST BLOCK, R.K.PURAM (HTC)	1	Other Outage	Planned Outage	25-12-2025	11:42	25-12-2025	13:40	1:58	0.000656	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
721	26-12-2025	Part of : POCKET 2 SECTOR 2 DWARKA	6	Other Outage	Planned Outage	26-12-2025	11:51	26-12-2025	15:12	3:21	0.000223	REPLACEMENT OF HT BUSHING ROD
722	26-12-2025	Part of : BLOCK C VASANT VIHAR	307	Other Outage	Planned Outage	26-12-2025	10:23	26-12-2025	14:15	3:52	0.003867	REPLACEMENT OF HT BUSHING ROD
723	27-12-2025	Part of : POCKET 2 SECTOR 2 DWARKA	6	Other Outage	Planned Outage	27-12-2025	12:37	27-12-2025	14:18	1:41	0.000056	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
724	27-12-2025	Part of : NIVEDITA KUNJ SECTOR 10 RAMAKRISHNA PURAM	83	Other Outage	Planned Outage	27-12-2025	11:19	27-12-2025	14:16	2:57	0.001721	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
725	27-12-2025	Part of : BLOCK E VASANT VIHAR	370	Other Outage	Planned Outage	27-12-2025	10:46	27-12-2025	13:22	2:36	0.002817	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
726	27-12-2025	Part of : BHIKAJI CAMA PLACE RAMAKRISHNA PURAM	10	Other Outage	Planned Outage	27-12-2025	11:19	27-12-2025	14:30	3:11	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
727	29-12-2025	Part of : SUBROTO PARK	2	Other Outage	Planned Outage	29-12-2025	11:33	29-12-2025	15:40	4:07	0.000274	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
728	29-12-2025	Part of : SUBROTO PARK	2	Other Outage	Planned Outage	29-12-2025	11:32	29-12-2025	15:39	4:07	0.000274	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
729	29-12-2025	Part of : POLICE COLONY SECTOR 12 RAMAKRISHNA PURAM	72	Other Outage	Planned Outage	29-12-2025	11:08	29-12-2025	14:07	2:59	0.000398	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
730	29-12-2025	Part of : BLOCK D VASANT VIHAR	286	Other Outage	Planned Outage	29-12-2025	10:36	29-12-2025	14:47	4:11	0.003486	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
731	30-12-2025	Part of : WEST BLOCK & SECTOR 5 RAMAKRISHNA PURAM	363	Other Outage	Unplanned Outage	30-12-2025	22:07	30-12-2025	22:47	0:40	0.000144	CABLE FAULT
732	30-12-2025	Part of : SATYA NIKETAN MOTI BAGH SOUTH	340	Other Outage	Planned Outage	30-12-2025	10:16	30-12-2025	11:49	1:33	0.000233	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
733	30-12-2025	Part of : INDIAN AIR LINES AND AIR INDIA ESTATE VASANT VIHAR	232	Other Outage	Planned Outage	30-12-2025	10:53	30-12-2025	14:39	3:46	0.003767	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
734	31-12-2025	Part of : BHIKAJI CAMA PLACE RAMAKRISHNA PURAM	10	Other Outage	Planned Outage	31-12-2025	12:18	31-12-2025	13:56	1:38	0.000000	CONDUCTOR REPLACEMENT PER SPAN,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
735	31-12-2025	Part of : BASANT GAON VASANT VIHAR	746	Other Outage	Planned Outage	31-12-2025	10:52	31-12-2025	13:40	2:48	0.002100	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
736	01-12-2025	Part of : CHIRAG DELHI	229	Other Outage	Planned Outage	01-12-2025	11:57	01-12-2025	14:40	2:43	0.000000	REPLACEMENT OF HT BUSHING ROD
737	01-12-2025	Part of : BLOCK C SHIVALIK MALVIYA NAGAR,BHAVISHYANIDHI ENCLAVE MALVIYA NAGAR	1129	Other Outage	Planned Outage	01-12-2025	11:40	01-12-2025	14:56	3:16	0.000544	REPLACEMENT OF HT BUSHING ROD
738	01-12-2025	Part of : SECTOR 1 PUSHPA VIHAR	418	Other Outage	Planned Outage	01-12-2025	10:57	01-12-2025	13:48	2:51	0.006175	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
739	01-12-2025	Part of : KALU SARAI	264	Other Outage	Planned Outage	01-12-2025	10:34	01-12-2025	13:25	2:51	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
740	02-12-2025	Part of : SECTOR 3 PUSHPA VIHAR	269	Other Outage	Planned Outage	02-12-2025	14:44	02-12-2025	17:19	2:35	0.004306	REPLACEMET OF FAULTY END BOX
741	02-12-2025	Part of : SECTOR 3 PUSHPA VIHAR	352	Other Outage	Planned Outage	02-12-2025	11:08	02-12-2025	13:58	2:50	0.006139	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
742	02-12-2025	Part of : SARVODYA ENCLAVE	341	Other Outage	Planned Outage	02-12-2025	10:12	02-12-2025	13:05	2:53	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF HT BOOTS,REPLACEMENT OF SILICAGEL IN BREATHER
743	02-12-2025	Part of : BLOCK A MALVIYA NAGAR	258	Other Outage	Planned Outage	02-12-2025	09:41	02-12-2025	14:21	4:40	0.000000	REPLACEMET OF HT BUSHING ROD
744	03-12-2025	Part of : KHIRKI EXT. JC-43 PKG	1	Other Outage	Planned Outage	03-12-2025	12:26	03-12-2025	13:32	1:06	0.000000	REPLACEMET OF HT BUSHING ROD
745	03-12-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	1496	Other Outage	Planned Outage	03-12-2025	11:04	03-12-2025	14:49	3:45	0.006250	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,ST.TH JOINT ON 3PH HT AB
746	03-12-2025	Part of : KALU SARAI	264	Other Outage	Planned Outage	03-12-2025	10:45	03-12-2025	13:19	2:34	0.000642	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
747	03-12-2025	Part of : PANCHSHEEL EXTENSION MALVIYA NAGAR	1	Other Outage	Planned Outage	03-12-2025	10:57	03-12-2025	14:30	3:33	0.000000	REPLACEMET OF HT BUSHING ROD
748	04-12-2025	Part of : BUTTERFLY PARK QILA RAI PITHORA SAINIK FARM	364	Other Outage	Planned Outage	04-12-2025	15:21	04-12-2025	16:35	1:14	0.002056	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
749	04-12-2025	Part of : SAHEED BHAGAT SINGH CLG (HTC)	1	Other Outage	Planned Outage	04-12-2025	12:09	04-12-2025	13:21	1:12	0.000000	REPLACEMENT OF HT BUSHING ROD
750	04-12-2025	Part of : SECTOR 1 PUSHPA VIHAR	510	Other Outage	Planned Outage	04-12-2025	11:00	04-12-2025	13:46	2:46	0.005994	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
751	04-12-2025	Part of : BLOCK B NAVJIVAN VIHAR MALVIYA NAGAR	134	Other Outage	Planned Outage	04-12-2025	10:03	04-12-2025	12:52	2:49	0.000657	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
752	05-12-2025	Part of : ASHOK VIHAR PRESS ENCLAVE SAKET,BLOCK F SAKET	214	Other Outage	Unplanned Outage	05-12-2025	11:11	05-12-2025	12:02	0:51	0.003584	HT SYSTEM FAULT
753	05-12-2025	Part of : FREEDOM FIGHTER VIHAR SAINIK FARM,PARYAVARAN COMPLEX SAINIK FARM	2457	Other Outage	Planned Outage	05-12-2025	12:54	05-12-2025	13:43	0:49	0.001361	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT,LT BUSHING REPLACEMENT
754	05-12-2025	Part of : BLOCK H 5 MALVIYA NAGAR	1116	Other Outage	Planned Outage	05-12-2025	10:24	05-12-2025	14:11	3:47	0.000000	REPLACEMET OF HT BUSHING ROD
755	05-12-2025	Part of : BLOCK A GITANJALI ENCLAVE MALVIYA NAGAR	147	Other Outage	Planned Outage	05-12-2025	10:13	05-12-2025	12:53	2:40	0.000756	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
756	06-12-2025	Part of : FREEDOM FIGHTER VIHAR,A,C,D & E-BLOCK PARYAVARAN COMPLEX,SAIYAD UL AJAIB VILLAGE	5003	Other Outage	Planned Outage	06-12-2025	11:15	06-12-2025	14:06	2:51	0.004750	GUARD WIRES SAGGING PER,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS,TAPPING OF JUMPERS
757	06-12-2025	Part of : KALU SARAI	543	Other Outage	Planned Outage	06-12-2025	10:13	06-12-2025	12:55	2:42	0.000000	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
758	06-12-2025	Part of : BEGUMPUR	1174	Other Outage	Planned Outage	06-12-2025	10:10	06-12-2025	12:53	2:43	0.000000	CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
759	08-12-2025	Part of : SECTOR 1 PUSHPA VIHAR,	414	Other Outage	Planned Outage	08-12-2025	13:07	08-12-2025	15:16	2:09	0.003583	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING
760	08-12-2025	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI,	631	Other Outage	Planned Outage	08-12-2025	10:36	08-12-2025	13:20	2:44	0.000000	TIGHTENING OF NUT BOLT
761	08-12-2025	Part of : MALVIYA NAGAR,	563	Other Outage	Planned Outage	08-12-2025	10:44	08-12-2025	14:01	3:17	0.000000	CONDUCTOR REPLACEMENT PER SPAN
762	08-12-2025	Part of : VIJAY MANDAL ENCLAVE KALU SARAI,	350	Other Outage	Planned Outage	08-12-2025	10:21	08-12-2025	13:13	2:52	0.000382	REPLACMET OF HT BUSHING ROD
763	09-12-2025	Part of : BLOCK F SAKET	500	Other Outage	Planned Outage	09-12-2025	11:11	09-12-2025	13:53	2:42	0.002025	REPLACEMENT OF LT BUSHING ROD,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
764	09-12-2025	Part of : JAGDAMBA CAMP SHEIKH SARAI	1579	Other Outage	Planned Outage	09-12-2025	10:10	09-12-2025	13:54	3:44	0.000000	REPLACEMENT OF HT BUSHING ROD
765	09-12-2025	Part of : SARVODYA ENCLAVE	342	Other Outage	Planned Outage	09-12-2025	10:13	09-12-2025	12:37	2:24	0.000600	REPLACEMENT OF HT BUSHING ROD
766	10-12-2025	Part of : H-BLOCK PANCHSHEEL VIHAR SHEIKH SARAI VILLAGE	2027	Other Outage	Planned Outage	10-12-2025	10:44	10-12-2025	14:42	3:58	0.000000	REPLACEMENT OF LT BUSHING ROD
767	10-12-2025	Part of : N-BLOCK SAKET	463	Other Outage	Planned Outage	10-12-2025	11:29	10-12-2025	14:42	3:13	0.002413	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
768	10-12-2025	Part of : B-BLOCK NAVJIVAN VIHAR MALVIYA NAGAR	134	Other Outage	Planned Outage	10-12-2025	09:54	10-12-2025	12:41	2:47	0.000464	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF HT BUSHING ROD
769	11-12-2025	Part of : BLOCK H PANCHSHEEL VIHAR SHEIKH SARAI VILLAGE	867	Other Outage	Planned Outage	11-12-2025	11:30	11-12-2025	12:06	0:36	0.000100	REPLACMET OF HT BUSHING ROD
770	11-12-2025	Part of : CHIRAG DELHI	2760	Other Outage	Planned Outage	11-12-2025	11:23	11-12-2025	13:10	1:47	0.000000	REPLACEMENT OF HT BUSHING ROD
771	11-12-2025	Part of : BLOCK B NAVJIVAN VIHAR MALVIYA NAGAR	288	Other Outage	Planned Outage	11-12-2025	11:16	11-12-2025	14:17	3:01	0.000000	REPLACEMENT OF LT BUSHING ROD
772	11-12-2025	Part of : BLOCK J SAKET	504	Other Outage	Planned Outage	11-12-2025	11:19	11-12-2025	13:50	2:31	0.001888	REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
773	11-12-2025	Part of : BEGUMPUR	364	Other Outage	Planned Outage	11-12-2025	10:01	11-12-2025	12:47	2:46	0.000415	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD
774	12-12-2025	Part of : BLOCK D SAKET,BLOCK G DDA FLATS SAKET,ASHOK VIHAR PRESS ENCLAVE SAKET	1087	Other Outage	Unplanned Outage	12-12-2025	17:46	12-12-2025	18:33	0:47	0.000000	CABLE FAULT
775	12-12-2025	Part of : BLOCK L SAKET,	561	Other Outage	Planned Outage	12-12-2025	11:13	12-12-2025	14:02	2:49	0.002113	REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
776	12-12-2025	Part of : PHASE II SHEIKH SARAI,	2483	Other Outage	Planned Outage	12-12-2025	10:33	12-12-2025	14:46	4:13	0.000000	REPLACEMENT OF HT BUSHING ROD
777	12-12-2025	Part of : MMTC COLONY SARVODYA ENCLAVE,	73	Other Outage	Planned Outage	12-12-2025	09:59	12-12-2025	12:50	2:51	0.000380	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
778	13-12-2025	Part of : BLOCK B SARVODYA ENCLAVE	192	Other Outage	Planned Outage	13-12-2025	13:58	13-12-2025	16:51	2:53	0.000096	REPLACEMENT OF HT BUSHING ROD
779	13-12-2025	Part of : SECTOR 7 PUSHPA VIHAR	99	Other Outage	Planned Outage	13-12-2025	11:17	13-12-2025	14:15	2:58	0.002225	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
780	13-12-2025	Part of : PANCHSHEEL EXTENSION MALVIYA NAGAR	1801	Other Outage	Planned Outage	13-12-2025	10:09	13-12-2025	13:13	3:04	0.000000	REPLACEMENT OF HT BUSHING ROD
781	14-12-2025	Part of : MMTC COLONY SARVODYA ENCLAVE	1	Other Outage	Planned Outage	14-12-2025	10:35	14-12-2025	12:58	2:23	0.000000	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
782	15-12-2025	Part of : BLOCK G 6 MALVIYA NAGAR	562	Other Outage	Planned Outage	15-12-2025	11:07	15-12-2025	12:56	1:49	0.000000	REPLACEMENT OF HT BUSHING ROD
783	15-12-2025	Part of : BLOCK B SARVODYA ENCLAVE	1	Other Outage	Planned Outage	15-12-2025	13:59	15-12-2025	16:54	2:55	0.000389	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
784	15-12-2025	Part of : BLOCK H 5 MALVIYA NAGAR	1114	Other Outage	Planned Outage	15-12-2025	11:15	15-12-2025	14:13	2:58	0.000000	REPLACEMENT OF HT BUSHING ROD
785	15-12-2025	Part of : BLOCK G SAKET	373	Other Outage	Planned Outage	15-12-2025	11:01	15-12-2025	13:59	2:58	0.002225	REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
786	15-12-2025	Part of : JAGDAMBA CAMP SHEIKH SARAI	1487	Other Outage	Planned Outage	15-12-2025	10:51	15-12-2025	14:02	3:11	0.000000	REPLACEMENT OF HT BUSHING ROD
787	16-12-2025	Part of : BLOCK C MALVIYA NAGAR,	761	Other Outage	Planned Outage	16-12-2025	12:13	16-12-2025	15:01	2:48	0.000467	MAINTENANCE OF TRANSFORMER
788	16-12-2025	Part of : SECTOR 7 PUSHPA VIHAR,	127	Other Outage	Planned Outage	16-12-2025	11:18	16-12-2025	14:23	3:05	0.002313	MAINTENANCE OF TRANSFORMER

Sr. No.	Date	Area Affected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
789	16-12-2025	Part of : SECTOR 3 PUSHPA VIHAR,	268	Other Outage	Planned Outage	16-12-2025	12:33	16-12-2025	14:39	2:06	0.003500	MAINTENANCE OF TRANSFORMER
790	16-12-2025	Part of : BLOCK F GITANJALI ENCLAVE MALVIYA NAGAR,	170	Other Outage	Planned Outage	16-12-2025	10:06	16-12-2025	12:51	2:45	0.000413	MAINTENANCE OF TRANSFORMER
791	17-12-2025	Part of : SAIKH SARAI PHASE	1	Other Outage	Planned Outage	17-12-2025	10:44	17-12-2025	12:49	2:05	0.000000	REPLACEMENT OF HT BUSHING ROD
792	17-12-2025	Part of : MMTC COLONY SARVODYA ENCLAVE	7	Other Outage	Planned Outage	17-12-2025	09:58	17-12-2025	12:52	2:54	0.000435	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
793	18-12-2025	Part of : G 6-BLOCK MALVIYA NAGAR	562	Other Outage	Planned Outage	18-12-2025	12:05	18-12-2025	12:58	0:53	0.000147	REPLACEMENT OF HT BUSHING ROD
794	18-12-2025	Part of : G 11-BLOCK MALVIYA NAGAR	1287	Other Outage	Planned Outage	18-12-2025	10:40	18-12-2025	14:00	3:20	0.000000	REPLACEMENT OF HT BUSHING ROD
795	18-12-2025	Part of : SECTOR 3 PUSHPA VIHAR	78	Other Outage	Planned Outage	18-12-2025	11:20	18-12-2025	13:57	2:37	0.001963	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
796	18-12-2025	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE	237	Other Outage	Planned Outage	18-12-2025	10:08	18-12-2025	12:29	2:21	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
797	19-12-2025	Part of : BLOCK H 5 MALVIYA NAGAR	1114	Other Outage	Planned Outage	19-12-2025	12:17	19-12-2025	15:12	2:55	0.000000	CONDUCTOR REPLACEMENT PER SPAN
798	19-12-2025	Part of : PANCHSHEEL EXTENSION MALVIYA NAGAR	774	Other Outage	Planned Outage	19-12-2025	10:28	19-12-2025	14:13	3:45	0.000000	REPLACEMET OF HT BUSHING ROD
799	19-12-2025	Part of : SECTOR 3 PUSHPA VIHAR	84	Other Outage	Planned Outage	19-12-2025	11:10	19-12-2025	13:52	2:42	0.002025	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
800	19-12-2025	Part of : NEAR ORTHO NOVA HOSPITAL	1	Other Outage	Planned Outage	19-12-2025	10:27	19-12-2025	13:01	2:34	0.000385	CLEANING OF HT BUSHING PER WAY,DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
801	20-12-2025	Part of : SECTOR 1 PUSHPA VIHAR,	257	Other Outage	Planned Outage	20-12-2025	11:10	20-12-2025	14:08	2:58	0.002225	MAINTENANCE OF TRANSFORMER
802	20-12-2025	Part of : BLOCK A SHIVALIK MALVIYA NAGAR,	783	Other Outage	Planned Outage	20-12-2025	10:32	20-12-2025	13:00	2:28	0.000000	MAINTENANCE OF TRANSFORMER
803	21-12-2025	Part of : SECTOR 7 PUSHPA VIHAR	155	Other Outage	Planned Outage	21-12-2025	11:12	21-12-2025	13:19	2:07	0.001588	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
804	22-12-2025	Part of : SECTOR 1 PUSHPA VIHAR,H,N,G,L & J-BLOCK SAKET,ASHOK VIHAR PRESS ENCLAVE	1983	Other Outage	Unplanned Outage	22-12-2025	02:55	22-12-2025	04:08	1:13	0.000973	CABLE DAMAGE BY OUTSIDE AGENCY (MCD)
805	22-12-2025	Part of : SAIYAD UL AJAIB EXTENSION SAINIK FARM	1360	Other Outage	Planned Outage	22-12-2025	11:52	22-12-2025	17:07	5:15	0.008750	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
806	22-12-2025	Part of : SECTOR 1 PUSHPA VIHAR	170	Other Outage	Planned Outage	22-12-2025	11:03	22-12-2025	14:20	3:17	0.002463	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
807	22-12-2025	Part of : H 5-BLOCK MALVIYA NAGAR	1114	Other Outage	Planned Outage	22-12-2025	10:43	22-12-2025	13:09	2:26	0.000000	REPLACEMENT OF HT BUSHING ROD
808	22-12-2025	Part of : CHIRAG DELHI	429	Other Outage	Planned Outage	22-12-2025	11:13	22-12-2025	14:14	3:01	0.000000	REPLACEMENT OF HT BUSHING ROD
809	22-12-2025	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	5	Other Outage	Planned Outage	22-12-2025	10:15	22-12-2025	12:35	2:20	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
810	23-12-2025	Part of : BLOCK H PANCHSHEEL VIHAR SHEIKH SARAI VILLAGE	1968	Other Outage	Planned Outage	23-12-2025	11:10	23-12-2025	14:11	3:01	0.000000	REPLACEMET OF HT BUSHING ROD
811	23-12-2025	Part of : SECTOR 1 PUSHPA VIHAR	553	Other Outage	Planned Outage	23-12-2025	11:02	23-12-2025	14:12	3:10	0.002375	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
812	23-12-2025	Part of : MADHUKAR HOSPITAL MALVIYA NAGAR (HTC)	1	Other Outage	Planned Outage	23-12-2025	10:15	23-12-2025	12:23	2:08	0.000320	CLEANING OF HT BUSHING PER WAY,DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
813	24-12-2025	Part of : BLOCK J SAINIK FARM,	38	Other Outage	Planned Outage	24-12-2025	13:00	24-12-2025	14:50	1:50	0.003056	MAINTENANCE OF TRANSFORMER
814	24-12-2025	Part of : FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK A PARYAVARAN COMPLEX SAINIK FARM	961	Other Outage	Planned Outage	24-12-2025	12:53	24-12-2025	15:51	2:58	0.004944	MAINTENANCE OF HVDS
815	24-12-2025	Part of : BLOCK B KHIDKI EXTENSION MALVIYA NAGAR,	1091	Other Outage	Planned Outage	24-12-2025	10:12	24-12-2025	13:24	3:12	0.000000	MAINTENANCE OF TRANSFORMER
816	24-12-2025	Part of : GITANJALI ENCLAVE MALVIYA NAGAR,	184	Other Outage	Planned Outage	24-12-2025	10:08	24-12-2025	12:55	2:47	0.000093	MAINTENANCE OF TRANSFORMER
817	25-12-2025	Part of : BLOCK J SAINIK FARM	71	Other Outage	Planned Outage	25-12-2025	12:09	25-12-2025	13:44	1:35	0.002639	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
818	25-12-2025	Part of : FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK A PARYAVARAN COMPLEX SAINIK FARM,BLOCK C, D & E PARYAVARAN COMPLEX SAINIK FARM	2450	Other Outage	Planned Outage	25-12-2025	13:11	25-12-2025	15:41	2:30	0.004167	HT AB CABLE REPLACEMENT PER SPAN,HT AB END TERMINATION REPLACEMENT,HT AB CABLE REPLACEMENT PER SPAN,HT AB END TERMINATION REPLACEMENT
819	26-12-2025	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	317	Other Outage	Planned Outage	26-12-2025	12:34	26-12-2025	14:59	2:25	0.000081	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
820	26-12-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	1558	Other Outage	Planned Outage	26-12-2025	11:54	26-12-2025	15:02	3:08	0.005222	REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT,ST.TH JOINT ON 1PH HT AB
821	26-12-2025	Part of : BLOCK N SOUTH SAINIK FARM	64	Other Outage	Planned Outage	26-12-2025	11:22	26-12-2025	13:54	2:32	0.004222	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
822	26-12-2025	Part of : SAIYAD UL AJAIB EXTENSION SAINIK FARM,BUTTERFLY PARK QILA RAI PITHORA	1725	Other Outage	Planned Outage	26-12-2025	11:16	26-12-2025	15:02	3:46	0.001883	REPLACEMENT OF HT BUSHING INULATOR
823	26-12-2025	Part of : PANCHSHEEL EXTENSION MALVIYA NAGAR	1796	Other Outage	Planned Outage	26-12-2025	10:38	26-12-2025	13:46	3:08	0.000000	REPLACEMENT OF HT BUSHING ROD
824	27-12-2025	Part of : PTS COLONY SAKET	1	Other Outage	Planned Outage	27-12-2025	10:04	27-12-2025	11:52	1:48	0.000270	CLEANING OF HT BUSHING PER WAY,DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
825	27-12-2025	Part of : SECTOR 6 PUSHPA VIHAR	14	Other Outage	Planned Outage	27-12-2025	10:52	27-12-2025	14:08	3:16	0.005444	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,TIGHTENEING OF NUT BOLT
826	27-12-2025	Part of : BLOCK L MALVIYA NAGAR	2252	Other Outage	Planned Outage	27-12-2025	10:16	27-12-2025	13:01	2:45	0.000000	REPLACEMET OF HT BUSHING ROD
827	28-12-2025	Part of : SECTOR 3 PUSHPA VIHAR,BLOCK H SAKET,SECTOR 1 PUSHPA VIHAR,KUTUB GOLF COURSE LADO SARAI,BLOCK D SAKET	1625	Other Outage	Unplanned Outage	28-12-2025	11:07	28-12-2025	12:00	0:53	0.001089	CABLE DAMAGE BY OUTSIDE AGENCY (DMRC)
828	29-12-2025	Part of : BLOCK F 4 MALVIYA NAGAR,HAUZ RANI MALVIYA NAGAR	2226	Other Outage	Unplanned Outage	29-12-2025	04:49	29-12-2025	05:40	0:51	0.000496	CABLE FAULT
829	29-12-2025	Part of : BLOCK D SAKET	36	Other Outage	Planned Outage	29-12-2025	11:31	29-12-2025	13:12	1:41	0.002806	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
830	29-12-2025	Part of : BLOCK H 5 MALVIYA NAGAR	1114	Other Outage	Planned Outage	29-12-2025	11:45	29-12-2025	15:17	3:32	0.000000	REPLACEMENT OF HT BUSHING ROD
831	29-12-2025	Part of : SAINIK FARMS COLONY SAINIK FARM	90	Other Outage	Planned Outage	29-12-2025	11:14	29-12-2025	13:54	2:40	0.004444	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
832	29-12-2025	Part of : BLOCK B NAVJIVAN VIHAR MALVIYA NAGAR	141	Other Outage	Planned Outage	29-12-2025	10:21	29-12-2025	12:49	2:28	0.000082	REPLACEMENT OF HT BUSHING ROD
833	29-12-2025	Part of : BLOCK A MALVIYA NAGAR	424	Other Outage	Planned Outage	29-12-2025	10:09	29-12-2025	13:01	2:52	0.000000	REPLACEMENT OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
834	30-12-2025	Part of : MMTC COLONY SARVODYA ENCLAVE	96	Other Outage	Planned Outage	30-12-2025	10:12	30-12-2025	10:47	0:35	0.000019	REPLACEMENT OF HT BUSHING ROD
835	30-12-2025	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE	239	Other Outage	Planned Outage	30-12-2025	09:59	30-12-2025	11:12	1:13	0.000000	REPLACEMENT OF FAULTY END BOX,SF6 GAS FILLING
836	30-12-2025	Part of : F-BLOCK KHANPUR COLONY	43	Other Outage	Planned Outage	30-12-2025	11:23	30-12-2025	14:20	2:57	0.004917	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
837	30-12-2025	Part of : ASHOK VIHAR PRESS ENCLAVE SAKET	402	Other Outage	Planned Outage	30-12-2025	10:42	30-12-2025	14:18	3:36	0.006000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
838	30-12-2025	Part of : D-BLOCK DDA FLATE MALVIYA NAGAR	828	Other Outage	Planned Outage	30-12-2025	10:29	30-12-2025	13:43	3:14	0.000000	REPLACEMENT OF HT BUSHING ROD
839	31-12-2025	Part of : BLOCK F 2 MALVIYA NAGAR	1337	Other Outage	Planned Outage	31-12-2025	10:42	31-12-2025	12:52	2:10	0.000000	REPLACEMET OF HT BUSHING ROD
840	31-12-2025	Part of : BLOCK E SAINIK FARM	36	Other Outage	Planned Outage	31-12-2025	11:05	31-12-2025	14:07	3:02	0.005056	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
841	31-12-2025	Part of : BLOCK E SAINIK FARM	31	Other Outage	Planned Outage	31-12-2025	11:19	31-12-2025	14:05	2:46	0.004611	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE
842	31-12-2025	Part of : BHAVISHYANIDHI ENCLAVE MALVIYA NAGAR	63	Other Outage	Planned Outage	31-12-2025	10:02	31-12-2025	12:42	2:40	0.000089	REPLACEMENT OF LT BUSHING ROD
843	01-12-2025	Part of : MITHAPUR	2029	Other Outage	Planned Outage	01-12-2025	11:04	01-12-2025	13:24	2:20	0.003500	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
844	02-12-2025	Part of : B-BLOCK MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	1	Other Outage	Unplanned Outage	02-12-2025	02:40	02-12-2025	03:13	0:33	0.000128	CABLE FAULT
845	02-12-2025	Part of : MOLARBAND	1095	Other Outage	Planned Outage	02-12-2025	12:16	02-12-2025	15:36	3:20	0.000556	SUB STATION CLEANING
846	02-12-2025	Part of : MADANPUR KHADAR VILLAGE	693	Other Outage	Planned Outage	02-12-2025	11:02	02-12-2025	14:00	2:58	0.006675	REPLACEMENT OF GAS KIT AND OIL SEAL
847	02-12-2025	Part of : BADARPUR EXTENSION,TAJPUR	978	Other Outage	Planned Outage	02-12-2025	11:23	02-12-2025	14:12	2:49	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
848	04-12-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1383	Other Outage	Planned Outage	04-12-2025	10:55	04-12-2025	15:22	4:27	0.002225	3PH HT AB CABLE REPLACEMENT PER SPAN
849	04-12-2025	Part of : POCKET M SARITA VIHAR	1086	Other Outage	Planned Outage	04-12-2025	10:55	04-12-2025	15:23	4:28	0.002978	REPLACEMENT OF LT BUSHING ROD
850	05-12-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1364	Other Outage	Unplanned Outage	05-12-2025	10:57	05-12-2025	11:52	0:55	0.000458	REPAIRING OF TRANSFORMER
851	05-12-2025	Part of : POCKET L SARITA VIHAR	331	Other Outage	Planned Outage	05-12-2025	10:59	05-12-2025	13:31	2:32	0.003251	INSTALLATION OF BUS BAR
852	05-12-2025	Part of : BLOCK E 1 MOLARBAND EXTENSION BADARPUR,BLOCK C MOLARBAND EXTENSION BADARPUR,BLOCK E 2 MOLARBAND EXTENSION BADARPUR	1923	Other Outage	Planned Outage	05-12-2025	11:05	05-12-2025	13:43	2:38	0.000658	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,HT BUSHING ROD REPLACEMENT,INSULATOR REPLACEMENT,LT BUSHING REPLACEMENT,LT JUMPER REPLACEMENT
853	06-12-2025	Part of : C-BLOCK MOLARBAND EXTENSION BADARPUR	17	Other Outage	Planned Outage	06-12-2025	11:35	06-12-2025	14:21	2:46	0.001383	3PH HT AB CABLE REPLACEMENT
854	06-12-2025	Part of : RAJ NAGAR MADANPUR KHADAR	434	Other Outage	Planned Outage	06-12-2025	11:13	06-12-2025	13:48	2:35	0.001464	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING ROD
855	06-12-2025	Part of : MADANPUR KHADAR VILLAGE	13	Other Outage	Planned Outage	06-12-2025	11:14	06-12-2025	14:24	3:10	0.003167	REPLACEMENT OF HT BUSHING ROD
856	07-12-2025	Part of : KHADDA COLONY JAIPUR	1685	Other Outage	Unplanned Outage	07-12-2025	01:13	07-12-2025	01:43	0:30	0.000433	CABLE FAULT
857	08-12-2025	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR,ALI VILLAGE ALI,ALI EXTENSION ALI	1332	Other Outage	Unplanned Outage	08-12-2025	07:22	08-12-2025	07:52	0:30	0.000558	HVDS FAULT
858	08-12-2025	Part of : JAIPUR EXTN G-BLOCK,JAIPUR EXTN E-1& E-BLOCK,JAIPUR EXTN H-BLOCK,JAIPUR EXTN F-BLOCK,EKTA VIHAR B-BLOCK,	1717	Other Outage	Planned Outage	08-12-2025	11:04	08-12-2025	13:50	2:46	0.000461	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT,ST.TH JOINT ON 1PH HT AB
859	08-12-2025	Part of : POCKET L SARITA VIHAR,	335	Other Outage	Planned Outage	08-12-2025	11:22	08-12-2025	13:48	2:26	0.001217	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
860	09-12-2025	Part of : M-BLOCK SAURABH VIHAR,K-BLOCK SAURABH VIHAR,L-BLOCK SAURABH VIHAR,JAIPUR,H BLOCK SAURABH VIHAR	2035	Other Outage	Planned Outage	09-12-2025	11:08	09-12-2025	13:40	2:32	0.000422	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT,ST.TH JOINT ON 1PH HT AB
861	10-12-2025	Part of : D,J & K-BLOCK SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND	1380	Other Outage	Planned Outage	10-12-2025	12:06	10-12-2025	14:55	2:49	0.000469	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
862	10-12-2025	Part of : POCKET M SARITA VIHAR	1095	Other Outage	Planned Outage	10-12-2025	11:04	10-12-2025	13:39	2:35	0.004736	REPLACEMENT OF GAS KIT AND OIL SEAL
863	10-12-2025	Part of : GAYATRI KUNJ	1414	Other Outage	Planned Outage	10-12-2025	11:04	10-12-2025	13:37	2:33	0.001275	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
864	11-12-2025	Part of : BLOCK B,D & J SAURABH VIHAR, VASIST FARM HARI NAGAR, E-BLOCK HARI NAGAR EXT PART-2	1620	Other Outage	Unplanned Outage	11-12-2025	11:01	11-12-2025	11:36	0:35	0.000661	CABLE FAULT
865	11-12-2025	Part of : KHADDA COLONY JAIPUR	295	Other Outage	Planned Outage	11-12-2025	11:14	11-12-2025	13:34	2:20	0.001944	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
866	12-12-2025	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR,BLOCK D MOLARBAND EXTENSION BADARPUR,	882	Other Outage	Unplanned Outage	12-12-2025	10:48	12-12-2025	11:08	0:20	0.000056	REPLACEMENT OF RMU
867	12-12-2025	Part of : RAJ NAGAR MADANPUR KHADAR,	1430	Other Outage	Planned Outage	12-12-2025	11:05	12-12-2025	13:36	2:31	0.002097	3PH HT AB END TERMINATION REPLACEMENT
868	12-12-2025	Part of : ABC BLOCK HARI NAGAR MOLARBAND,	613	Other Outage	Planned Outage	12-12-2025	11:00	12-12-2025	13:29	2:29	0.000414	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN,GUARD WIRES SAGGING PER SPAN
869	13-12-2025	Part of : D2-BLOCK HARI NAGAR EXTN-III	2489	Other Outage	Planned Outage	13-12-2025	12:34	13-12-2025	14:30	1:56	0.000516	SUB STATION CLEANING
870	13-12-2025	Part of : KHADDA COLONY JAIPUR	160	Other Outage	Planned Outage	13-12-2025	11:03	13-12-2025	13:52	2:49	0.001408	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
871	13-12-2025	Part of : ALI VILLAGE ALI	1218	Other Outage	Planned Outage	13-12-2025	10:52	13-12-2025	13:53	3:01	0.000000	CONDUCTOR REPLACEMENT PER SPAN
872	15-12-2025	Part of : KHADDA COLONY JAIPUR	260	Other Outage	Planned Outage	15-12-2025	10:58	15-12-2025	12:30	1:32	0.000000	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
873	15-12-2025	Part of : BLOCK-E,F,G JAIPUR EXTN, -B EKTA VIHAR	1717	Other Outage	Planned Outage	15-12-2025	11:06	15-12-2025	13:44	2:38	0.000439	DB REVAMPING,LT BUSHING REPLACEMENT,ST.TH JOINT ON 1PH HT AB
874	15-12-2025	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR	1062	Other Outage	Planned Outage	15-12-2025	10:58	15-12-2025	13:29	2:31	0.002936	REPLACEMENT OF GAS KIT AND OIL SEAL
875	16-12-2025	Part of : M-BLOCK SAURABH VIHAR,K-BLOCK SAURABH VIHAR,L-BLOCK SAURABH VIHAR	2035	Other Outage	Planned Outage	16-12-2025	11:12	16-12-2025	13:28	2:16	0.000378	MAINTENANCE OF HVDS CIRCUIT
876	17-12-2025	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND,GAGAN VIHAR MITHAPUR EXTENSION MITHAPUR	3598	Other Outage	Unplanned Outage	17-12-2025	21:42	17-12-2025	22:37	0:55	0.000275	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
877	17-12-2025	Part of : J BLOCK SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND,K-BLOCK SAURABH VIHAR,D-BLOCK SAURABH	1380	Other Outage	Planned Outage	17-12-2025	11:10	17-12-2025	13:56	2:46	0.000461	HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
878	17-12-2025	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR	1782	Other Outage	Planned Outage	17-12-2025	11:12	17-12-2025	13:35	2:23	0.002781	INSTALLATION OF BUS BAR
879	18-12-2025	Part of : KHADDA COLONY JAIPUR	1667	Other Outage	Planned Outage	18-12-2025	11:06	18-12-2025	13:29	2:23	0.002383	3PH HT AB END TERMINATION REPLACEMENT
880	19-12-2025	Part of : BLOCK F,K,H & L SAURABH VIHAR,JAIPUR	2075	Other Outage	Unplanned Outage	19-12-2025	03:46	19-12-2025	04:19	0:33	0.000000	HVDS CABLE FAULT
881	19-12-2025	Part of : MITHAPUR	1675	Other Outage	Planned Outage	19-12-2025	11:36	19-12-2025	12:55	1:19	0.000878	REPLACEMET OF FAULTY END BOX
882	19-12-2025	Part of : POCKET K SARITA VIHAR	170	Other Outage	Planned Outage	19-12-2025	11:09	19-12-2025	13:31	2:22	0.000789	REPLACEMET OF FAULTY END BOX
883	19-12-2025	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR	21	Other Outage	Planned Outage	19-12-2025	10:52	19-12-2025	13:55	3:03	0.001017	3PH HT AB CABLE REPLACEMENT PER SPAN
884	19-12-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1903	Other Outage	Planned Outage	19-12-2025	11:08	19-12-2025	13:15	2:07	0.001764	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
885	20-12-2025	Part of : MADANPUR KHADAR,	840	Other Outage	Planned Outage	20-12-2025	11:59	20-12-2025	13:59	2:00	0.001667	MAINTENANCE OF TRANSFORMER
886	20-12-2025	Part of : BLOCK E 1 MOLARBAND EXTENSION BADARPUR,BLOCK C MOLARBAND EXTENSION BADARPUR	1923	Other Outage	Planned Outage	20-12-2025	11:21	20-12-2025	13:57	2:36	0.000433	MAINTENANCE OF HVDS CIRCUIT
887	21-12-2025	Part of : POCKET A SARITA VIHAR	10	Other Outage	Unplanned Outage	21-12-2025	11:42	21-12-2025	13:43	2:01	0.001681	REPAIRING OF RMU
888	21-12-2025	Part of : MADANPUR KHADAR VILLAGE	10	Other Outage	Planned Outage	21-12-2025	10:53	21-12-2025	12:52	1:59	0.001322	REPLACEMENT OF FAULTY END BOX
889	22-12-2025	Part of : POCKET B SARITA VIHAR	3	Other Outage	Unplanned Outage	22-12-2025	11:08	22-12-2025	13:04	1:56	0.000967	REPAIRING OF RMU
890	22-12-2025	Part of : KHADDA COLONY JAIPUR	299	Other Outage	Planned Outage	22-12-2025	10:54	22-12-2025	13:54	3:00	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
891	22-12-2025	Part of : H,E-1& E-BLOCK JAIPUR EXTN.,B-BLOCKEKTA VIHAR	1717	Other Outage	Planned Outage	22-12-2025	11:01	22-12-2025	13:57	2:56	0.000489	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
892	22-12-2025	Part of : ALI VIHAR,PRIYANKA CAMP,ALI EXTENSION	1031	Other Outage	Planned Outage	22-12-2025	10:52	22-12-2025	13:53	3:01	0.002514	HVDS MAINTENANCE
893	23-12-2025	Part of : POCKET F SARITA VIHAR	340	Other Outage	Planned Outage	23-12-2025	10:57	23-12-2025	13:15	2:18	0.002300	MEASUREMET OF INSULATION RESISTANCE
894	23-12-2025	Part of : BLOCK H,K,L & M SAURABH VIHAR, JAIPUR	2035	Other Outage	Planned Outage	23-12-2025	11:03	23-12-2025	13:45	2:42	0.000450	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING
895	24-12-2025	Part of : J BLOCK SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND,K-BLOCK SAURABH VIHAR,D-BLOCK SAURABH	1380	Other Outage	Planned Outage	24-12-2025	11:19	24-12-2025	12:44	1:25	0.000236	MAINTENANCE OF HVDS
896	25-12-2025	Part of : POCKET K & L SARITA VIHAR	558	Other Outage	Unplanned Outage	25-12-2025	12:56	25-12-2025	14:35	1:39	0.001375	REPAIRING OF RMU
897	25-12-2025	Part of : KHADDA COLONY JAIPUR	258	Other Outage	Planned Outage	25-12-2025	12:44	25-12-2025	13:40	0:56	0.001556	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
898	26-12-2025	Part of : F-BLOCK SAURABH VIHAR	19	Other Outage	Unplanned Outage	26-12-2025	11:33	26-12-2025	12:58	1:25	0.001889	REPAIR/REPLACEMENT OF CONDUCTOR
899	26-12-2025	Part of : NTPC WATER TREATMENT PLANT BADARPUR	3	Other Outage	Unplanned Outage	26-12-2025	11:29	26-12-2025	12:54	1:25	0.001181	MAKING OF END TERMINATION
900	26-12-2025	Part of : POCKET B SARITA VIHAR	11	Other Outage	Unplanned Outage	26-12-2025	11:06	26-12-2025	13:04	1:58	0.002294	REPAIRING OF RMU
901	26-12-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1903	Other Outage	Planned Outage	26-12-2025	11:03	26-12-2025	14:01	2:58	0.002967	3PH HT AB END TERMINATION REPLACEMENT
902	26-12-2025	Part of : BLOCK A & C MOLARBAND EXTENSION BADARPUR,MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR	374	Other Outage	Planned Outage	26-12-2025	11:00	26-12-2025	13:49	2:49	0.000939	3PH HT AB CABLE REPLACEMENT
903	27-12-2025	Part of : ALI EXTENSION, BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	25	Other Outage	Unplanned Outage	27-12-2025	17:01	27-12-2025	17:36	0:35	0.000000	HT SYSTEM FAULT
904	27-12-2025	Part of : BLOCK C,D & E1 MOLARBAND EXTENSION BADARPUR,MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR	1337	Other Outage	Planned Outage	27-12-2025	11:32	27-12-2025	15:21	3:49	0.001272	3PH HT AB CABLE REPLACEMENT PER SPAN
905	27-12-2025	Part of : KHADDA COLONY JAIPUR	1667	Other Outage	Planned Outage	27-12-2025	10:57	27-12-2025	13:29	2:32	0.002533	3PH HT AB END TERMINATION REPLACEMENT
906	28-12-2025	Part of : MOHAN BABA NAGAR	0	Other Outage	Unplanned Outage	28-12-2025	10:49	28-12-2025	11:34	0:45	0.000013	CABLE FAULT
907	29-12-2025	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR	704	Other Outage	Unplanned Outage	29-12-2025	14:11	29-12-2025	16:01	1:50	0.000917	REPAIRING OF RMU
908	29-12-2025	Part of : GAYATRI KUNJ ALI	496	Other Outage	Unplanned Outage	29-12-2025	08:55	29-12-2025	10:54	1:59	0.002975	REPAIRING OF TRANSFORMER
909	29-12-2025	Part of : ALI VILLAGE ALI	1213	Other Outage	Planned Outage	29-12-2025	11:00	29-12-2025	13:52	2:52	0.003344	INSTALLATION OF BUS BAR
910	29-12-2025	Part of : JAIPUR EXTN G-BLOCK,JAIPUR EXTN E-1& E-BLOCK,JAIPUR EXTN H-BLOCK,JAIPUR EXTN F-BLOCK,EKTA VIHAR B-BLOCK	1717	Other Outage	Planned Outage	29-12-2025	11:13	29-12-2025	13:44	2:31	0.000419	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
911	29-12-2025	Part of : POCKET M SARITA VIHAR	638	Other Outage	Planned Outage	29-12-2025	10:59	29-12-2025	13:51	2:52	0.001911	REPLACEMENT OF FAULTY END BOX

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
912	30-12-2025	Part of : E 2-BLOCK MOLARBAND EXTENSION BADARPUR	1496	Other Outage	Planned Outage	30-12-2025	12:05	30-12-2025	13:52	1:47	0.003269	REPLACEMENT OF FAULTY END BOX
913	30-12-2025	Part of : H,L,K & M-BLOCK SAURABH VIHAR	2035	Other Outage	Planned Outage	30-12-2025	12:34	30-12-2025	14:56	2:22	0.000394	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
914	30-12-2025	Part of : ALI VIHAR,LALU COLONY	1623	Other Outage	Planned Outage	30-12-2025	10:59	30-12-2025	13:35	2:36	0.002600	REPLACEMENT OF HT BUSHING ROD
915	31-12-2025	Part of : SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND,-BLOCK -J & K SAURABH VIHAR	1380	Other Outage	Planned Outage	31-12-2025	11:02	31-12-2025	12:49	1:47	0.000297	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
916	31-12-2025	Part of : ALI VIHAR,PRIYANKA CAMP ALI,ALI EXTENSION	1035	Other Outage	Planned Outage	31-12-2025	11:05	31-12-2025	13:09	2:04	0.002411	REPLACEMENT OF GAS KIT AND OIL SEAL
917	01-12-2025	Part of : MES, MARRIED ACOMODATION, RANGPURI (HTC)	0	Other Outage	Unplanned Outage	01-12-2025	11:22	01-12-2025	12:04	0:42	0.000093	CABLE FAULT
918	01-12-2025	Part of : GHITORNI VILLAGE GHITORNI	832	Other Outage	Planned Outage	01-12-2025	11:13	01-12-2025	13:13	2:00	0.003000	3PH DB REVAMPING,INSULATOR REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER
919	01-12-2025	Part of : SETH SARAI MEHRAULI	2	Other Outage	Planned Outage	01-12-2025	10:53	01-12-2025	13:45	2:52	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
920	01-12-2025	Part of : POCKET 5 SECTOR D VASANT KUNJ	204	Other Outage	Planned Outage	01-12-2025	10:49	01-12-2025	13:45	2:56	0.000489	DT OIL SAMPLING TO CHECK BDV VALUE,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
921	02-12-2025	Part of : POCKET 9 SECTOR C VASANT KUNJ	463	Other Outage	Unplanned Outage	02-12-2025	09:52	02-12-2025	10:40	0:48	0.000093	HT SYSTEM FAULT
922	02-12-2025	Part of : ANAND GRAM,GHITORNI VILLAGE	2205	Other Outage	Unplanned Outage	02-12-2025	01:04	02-12-2025	01:39	0:35	0.000301	CABLE FAULT
923	02-12-2025	Part of : MEHRAULI VILLAGE	1024	Other Outage	Planned Outage	02-12-2025	10:29	02-12-2025	12:26	1:57	0.000000	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER
924	02-12-2025	Part of : POCKET 1 SECTOR C VASANT KUNJ	325	Other Outage	Planned Outage	02-12-2025	10:17	02-12-2025	13:15	2:58	0.001978	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
925	02-12-2025	Part of : GHITORNI VILLAGE	1217	Other Outage	Planned Outage	02-12-2025	10:52	02-12-2025	13:33	2:41	0.004025	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,JUMPER REPLACEMENT PER POLE
926	02-12-2025	Part of : NAYAK PURA BIJWASAN	57	Other Outage	Planned Outage	02-12-2025	10:21	02-12-2025	13:52	3:31	0.000000	REPLACEMET OF HT BUSHING ROD
927	03-12-2025	Part of : SETH SARAI MEHRAULI	15	Other Outage	Planned Outage	03-12-2025	11:37	03-12-2025	12:34	0:57	0.000000	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER
928	03-12-2025	Part of : POCKET 5 AND 6 SECTOR B VASANT KUNJ	332	Other Outage	Planned Outage	03-12-2025	10:31	03-12-2025	12:04	1:33	0.000000	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
929	03-12-2025	Part of : VASANT KUNJ PHASE II	12	Other Outage	Planned Outage	03-12-2025	10:31	03-12-2025	13:33	3:02	0.000506	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
930	04-12-2025	Part of : KHANDSA COLONY MEHRAULI	782	Other Outage	Planned Outage	04-12-2025	11:43	04-12-2025	14:07	2:24	0.000800	INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS
931	04-12-2025	Part of : GHITORNI VILLAGE GHITORNI	857	Other Outage	Planned Outage	04-12-2025	11:09	04-12-2025	13:43	2:34	0.000642	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
932	04-12-2025	Part of : POCKET 5 SECTOR D VASANT KUNJ	187	Other Outage	Planned Outage	04-12-2025	10:33	04-12-2025	13:28	2:55	0.000486	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
933	04-12-2025	Part of : PALAM FARMS	243	Other Outage	Planned Outage	04-12-2025	11:09	04-12-2025	13:19	2:10	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,MEASUREMENT OF INSULATION RESISTANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
934	04-12-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA	635	Other Outage	Planned Outage	04-12-2025	10:49	04-12-2025	13:29	2:40	0.000000	CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
935	05-12-2025	Part of : INDIRA GANDHI INTERNATIONAL AIRPORT	1087	Other Outage	Planned Outage	05-12-2025	12:08	05-12-2025	14:07	1:59	0.000661	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
936	05-12-2025	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS	3427	Other Outage	Planned Outage	05-12-2025	10:32	05-12-2025	12:01	1:29	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
937	05-12-2025	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ	332	Other Outage	Planned Outage	05-12-2025	10:59	05-12-2025	13:48	2:49	0.000939	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF LUGS,SUB STATION CLEANING
938	05-12-2025	Part of : RANGPURI	1317	Other Outage	Planned Outage	05-12-2025	10:59	05-12-2025	14:08	3:09	0.002363	REPLACEMENT OF LT BUSHING ROD
939	05-12-2025	Part of : SECTOR D VASANT KUNJ	53	Other Outage	Planned Outage	05-12-2025	10:41	05-12-2025	13:39	2:58	0.000494	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
940	06-12-2025	Part of : INDIRA GANDHI INTERNATIONAL AIRPORT	2	Other Outage	Planned Outage	06-12-2025	13:02	06-12-2025	14:02	1:00	0.000367	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
941	06-12-2025	Part of : POCKET 1 SECTOR D VASANT KUNJ	285	Other Outage	Planned Outage	06-12-2025	10:31	06-12-2025	12:31	2:00	0.001667	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
942	06-12-2025	Part of : POCKET A SECTOR A VASANT KUNJ	916	Other Outage	Planned Outage	06-12-2025	13:39	06-12-2025	16:11	2:32	0.001267	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
943	06-12-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ	40	Other Outage	Planned Outage	06-12-2025	10:30	06-12-2025	13:25	2:55	0.000486	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
944	06-12-2025	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ	120	Other Outage	Planned Outage	06-12-2025	10:55	06-12-2025	13:45	2:50	0.001889	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
945	07-12-2025	Part of : DEVELOPMENT COMMISONER HANDICRAFT (HT CONSUMER) VASANT ENCLAVE	0	Other Outage	Unplanned Outage	07-12-2025	16:37	07-12-2025	17:31	0:54	0.001215	CABLE FAULT
946	08-12-2025	Part of : HTC:WAVE HOSPITALITY,ASSET-12,AEROCITY,, HTC:OAK INFRASTR,ASSET NO-08, AEROCITY	2	Other Outage	Planned Outage	08-12-2025	12:27	08-12-2025	13:04	0:37	0.000391	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
947	08-12-2025	Part of : PALAM FARMS,	102	Other Outage	Planned Outage	08-12-2025	13:51	08-12-2025	15:19	1:28	0.000000	INSTALLATION OF BUS BAR
948	08-12-2025	Part of : SAMALKA,	218	Other Outage	Planned Outage	08-12-2025	10:59	08-12-2025	13:55	2:56	0.001222	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
949	08-12-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ,	69	Other Outage	Planned Outage	08-12-2025	11:42	08-12-2025	14:42	3:00	0.000500	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
950	08-12-2025	Part of : KHANDSA COLONY MEHRAULI,	1037	Other Outage	Planned Outage	08-12-2025	10:54	08-12-2025	14:30	3:36	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
951	09-12-2025	Part of : POCKET 5 AND 6 SECTOR B VASANT KUNJ	83	Other Outage	Planned Outage	09-12-2025	10:27	09-12-2025	12:10	1:43	0.001288	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR
952	09-12-2025	Part of : NAYAK PURA BIJWASAN	570	Other Outage	Planned Outage	09-12-2025	10:02	09-12-2025	11:03	1:01	0.000000	REPLACEMENT OF HT BUSHING ROD
953	09-12-2025	Part of : MAHIPALPUR EXTENSION MAHIPALPUR	1277	Other Outage	Planned Outage	09-12-2025	10:40	09-12-2025	13:55	3:15	0.002438	REPLACEMENT OF LT BUSHING ROD
954	09-12-2025	Part of : SECTOR D VASANT KUNJ	117	Other Outage	Planned Outage	09-12-2025	10:34	09-12-2025	13:29	2:55	0.000486	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
955	09-12-2025	Part of : LAKHI NATH KUTI MEHRAULI	1355	Other Outage	Planned Outage	09-12-2025	10:28	09-12-2025	13:19	2:51	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
956	10-12-2025	Part of : MES MARRIED ACOMODATION RANG PURI (HT CONSUMER)	0	Other Outage	Unplanned Outage	10-12-2025	23:40	11-12-2025	00:16	0:36	0.000110	CABLE FAULT
957	10-12-2025	Part of : INDIRA GANDHI INTERNATIONAL AIRPORT,AHLUWALIA AEROCITY & GTEWAY ARCITY (HT CONSUMER)	1	Other Outage	Unplanned Outage	10-12-2025	09:58	10-12-2025	10:31	0:33	0.000458	CABLE FAULT
958	10-12-2025	Part of : ROOPAM WALA KUNWA MEHRAULI	965	Other Outage	Planned Outage	10-12-2025	12:01	10-12-2025	14:03	2:02	0.000000	CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF BUS BAR,REPLACEMENT OF HT BUSHING ROD
959	10-12-2025	Part of : PUSHPANJALI FARMS	280	Other Outage	Planned Outage	10-12-2025	11:03	10-12-2025	15:21	4:18	0.000000	BIRD SPIKES INSTALLATION PER POLE,TAPPING OF JUMPERS
960	10-12-2025	Part of : KAPAS HERA EXTENSION	243	Other Outage	Planned Outage	10-12-2025	10:26	10-12-2025	17:36	7:10	0.006928	REPLACEMENT OF HT BUSHING ROD
961	10-12-2025	Part of : ANAND GRAM GHITORNI	28	Other Outage	Planned Outage	10-12-2025	10:55	10-12-2025	13:09	2:14	0.000335	SUB STATION CLEANING
962	10-12-2025	Part of : RUCHI VIHAR VASANT KUNJ	679	Other Outage	Planned Outage	10-12-2025	10:47	10-12-2025	13:41	2:54	0.000483	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL
963	11-12-2025	Part of : GHITORNI VILLAGE	60	Other Outage	Planned Outage	11-12-2025	11:55	11-12-2025	14:00	2:05	0.000347	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
964	11-12-2025	Part of : POCKET 5 SECTOR D VASANT KUNJ	229	Other Outage	Planned Outage	11-12-2025	11:18	11-12-2025	14:14	2:56	0.000489	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
965	11-12-2025	Part of : MAHIPALPUR VILLAGE	316	Other Outage	Planned Outage	11-12-2025	11:10	11-12-2025	14:06	2:56	0.000489	REPLACEMENT OF LT BUSHING ROD
966	11-12-2025	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ	674	Other Outage	Planned Outage	11-12-2025	10:22	11-12-2025	14:04	3:42	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMET OF LUGS
967	11-12-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	1134	Other Outage	Planned Outage	11-12-2025	10:57	11-12-2025	12:57	2:00	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
968	12-12-2025	Part of : GHITORNI VILLAGE GHITORNI,	64	Other Outage	Planned Outage	12-12-2025	15:19	12-12-2025	15:49	0:30	0.000067	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
969	12-12-2025	Part of : ARJUN GARH AYA NAGAR,	47	Other Outage	Planned Outage	12-12-2025	14:09	12-12-2025	14:50	0:41	0.001253	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR
970	12-12-2025	Part of : PALAM FARMS,DALMIA VIHAR BIJWASAN,	457	Other Outage	Planned Outage	12-12-2025	10:39	12-12-2025	16:00	5:21	0.000000	TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
971	12-12-2025	Part of : ISLAM COLONY MEHRAULI,	584	Other Outage	Planned Outage	12-12-2025	10:59	12-12-2025	13:54	2:55	0.000000	DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF HT BOOTS,REPLACEMENT OF SILICAGEL IN BREATHER
972	12-12-2025	Part of : ANAND GRAM GHITORNI,	278	Other Outage	Planned Outage	12-12-2025	10:54	12-12-2025	13:00	2:06	0.003850	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
973	12-12-2025	Part of : INSTITUTIONAL AREA VASANT KUNJ,	6	Other Outage	Planned Outage	12-12-2025	10:27	12-12-2025	13:12	2:45	0.000458	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
974	13-12-2025	Part of : GHITORNI VILLAGE GHITORNI	55	Other Outage	Planned Outage	13-12-2025	14:57	13-12-2025	16:16	1:19	0.000154	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
975	13-12-2025	Part of : ANAND GRAM GHITORNI	50	Other Outage	Planned Outage	13-12-2025	15:04	13-12-2025	16:15	1:11	0.002169	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
976	13-12-2025	Part of : ANAND GRAM GHITORNI	21	Other Outage	Planned Outage	13-12-2025	11:02	13-12-2025	12:59	1:57	0.003575	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
977	13-12-2025	Part of : BLOCK RZ MAHIPALPUR VILLAGE	118	Other Outage	Planned Outage	13-12-2025	10:54	13-12-2025	13:55	3:01	0.001508	REPLACEMENT OF LT BUSHING ROD
978	13-12-2025	Part of : POCKET 5 SECTOR D VASANT KUNJ	205	Other Outage	Planned Outage	13-12-2025	10:40	13-12-2025	13:31	2:51	0.000475	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
979	13-12-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA	341	Other Outage	Planned Outage	13-12-2025	10:47	13-12-2025	13:31	2:44	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
980	14-12-2025	Part of : TEMP JKUMAR AEROCITY (HT CONSUMER)	0	Other Outage	Unplanned Outage	14-12-2025	12:07	14-12-2025	12:53	0:46	0.000000	CABLE FAULT
981	15-12-2025	Part of : TEACHER COLONY MEHRAULI, KISHANGARH VILLAGE SECTOR A VASANT KUNJ	3275	Other Outage	Unplanned Outage	15-12-2025	05:19	15-12-2025	06:10	0:51	0.000354	HT SYSTEM FAULT
982	15-12-2025	Part of : DALMIA VIHAR BIJWASAN	322	Other Outage	Planned Outage	15-12-2025	10:06	15-12-2025	10:58	0:52	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
983	15-12-2025	Part of : ANAND GRAM GHITORNI	175	Other Outage	Planned Outage	15-12-2025	11:42	15-12-2025	13:24	1:42	0.003117	GUARD WIRES SAGGING PER SPAN,TAPPING OF JUMPERS
984	15-12-2025	Part of : BLOCK L MAHIPALPUR VILLAGE	945	Other Outage	Planned Outage	15-12-2025	11:00	15-12-2025	13:44	2:44	0.001367	REPLACEMENT OF LT BUSHING ROD
985	15-12-2025	Part of : POCKET 3 SECTOR C VASANT KUNJ	268	Other Outage	Planned Outage	15-12-2025	11:36	15-12-2025	14:31	2:55	0.000486	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
986	15-12-2025	Part of : KHANDSA COLONY MEHRAULI	776	Other Outage	Planned Outage	15-12-2025	10:50	15-12-2025	14:32	3:42	0.000000	OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
987	16-12-2025	Part of : RUCHI VIHAR VASANT KUNJ,BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ,SECTOR D VASANT KUNJ,IAA COLONY SECTOR D VASANT KUNJ	3038	Other Outage	Unplanned Outage	16-12-2025	06:13	16-12-2025	07:04	0:51	0.000000	TREE BRANCH FALLEN ON O/H LINE
988	16-12-2025	Part of : ANAND GRAM GHITORNI,	3	Other Outage	Planned Outage	16-12-2025	13:49	16-12-2025	15:42	1:53	0.000157	MAINTENANCE OF TRANSFORMER
989	16-12-2025	Part of : SECTOR D VASANT KUNJ,	179	Other Outage	Planned Outage	16-12-2025	11:44	16-12-2025	13:34	1:50	0.003361	MAINTENANCE OF TRANSFORMER
990	16-12-2025	Part of : LAKHI NATH KUTI MEHRAULI,ROOPAM WALA KUNWA MEHRAULI,	2918	Other Outage	Planned Outage	16-12-2025	10:03	16-12-2025	11:36	1:33	0.000000	MAINTENANCE OF HT CIRCUIT
991	16-12-2025	Part of : ROOPAM WALA KUNWA MEHRAULI,LAKHI NATH KUTI MEHRAULI,	1676	Other Outage	Planned Outage	16-12-2025	10:04	16-12-2025	11:37	1:33	0.000000	MAINTENANCE OF HT CIRCUIT
992	16-12-2025	Part of : SECTOR D VASANT KUNJ,	135	Other Outage	Planned Outage	16-12-2025	11:16	16-12-2025	14:12	2:56	0.000489	MAINTENANCE OF TRANSFORMER
993	17-12-2025	Part of : MAHIPAL PUR ASSET NO 13	0	Other Outage	Unplanned Outage	17-12-2025	13:22	17-12-2025	14:06	0:44	0.000024	HT SYSTEM FAULT
994	17-12-2025	Part of : ISLAM COLONY MEHRAULI	882	Other Outage	Planned Outage	17-12-2025	10:49	17-12-2025	12:44	1:55	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
995	17-12-2025	Part of : PALAM FARMS	1	Other Outage	Planned Outage	17-12-2025	09:48	17-12-2025	11:39	1:51	0.000000	INSTALLATION OF BUS BAR
996	17-12-2025	Part of : SECTOR D VASANT KUNJ	215	Other Outage	Planned Outage	17-12-2025	10:27	17-12-2025	14:00	3:33	0.000710	INSTALLATION OF BUS BAR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
997	17-12-2025	Part of : MEHRAM NAGAR WEST MEHRAM NAGAR	797	Other Outage	Planned Outage	17-12-2025	11:39	17-12-2025	13:55	2:16	0.001700	REPLACEMENT OF LT BUSHING ROD
998	17-12-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	46	Other Outage	Planned Outage	17-12-2025	10:37	17-12-2025	13:34	2:57	0.000492	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
999	18-12-2025	Part of : MAHIPALPUR VILLAGE	574	Other Outage	Unplanned Outage	18-12-2025	19:10	18-12-2025	19:43	0:33	0.000073	CABLE FAULT
1000	18-12-2025	Part of : KAPAS HERA ESTATE	429	Other Outage	Planned Outage	18-12-2025	12:04	18-12-2025	12:45	0:41	0.000285	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1001	18-12-2025	Part of : HARIJAN BASTI RAJOKRI	564	Other Outage	Planned Outage	18-12-2025	11:14	18-12-2025	12:07	0:53	0.000353	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1002	18-12-2025	Part of : NAYAK PURA BIJWASAN	329	Other Outage	Planned Outage	18-12-2025	10:44	18-12-2025	12:22	1:38	0.000000	INSTALLATION OF BUS BAR
1003	18-12-2025	Part of : GHITORNI VILLAGE	861	Other Outage	Planned Outage	18-12-2025	11:46	18-12-2025	14:39	2:53	0.000577	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1004	18-12-2025	Part of : ROOPAM WALA KUNWA MEHRAULI	966	Other Outage	Planned Outage	18-12-2025	10:47	18-12-2025	14:18	3:31	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
1005	18-12-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ	168	Other Outage	Planned Outage	18-12-2025	11:09	18-12-2025	14:03	2:54	0.000483	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1006	19-12-2025	Part of : AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	472	Other Outage	Planned Outage	19-12-2025	14:22	19-12-2025	14:46	0:24	0.000100	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1007	19-12-2025	Part of : GHITORNI VILLAGE	219	Other Outage	Planned Outage	19-12-2025	12:30	19-12-2025	14:11	1:41	0.000421	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1008	19-12-2025	Part of : GHITORNI VILLAGE	340	Other Outage	Planned Outage	19-12-2025	12:02	19-12-2025	14:17	2:15	0.000450	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS
1009	19-12-2025	Part of : SECTOR D VASANT KUNJ	97	Other Outage	Planned Outage	19-12-2025	10:42	19-12-2025	13:37	2:55	0.000486	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1010	19-12-2025	Part of : KHANDSA COLONY MEHRAULI	943	Other Outage	Planned Outage	19-12-2025	10:48	19-12-2025	14:11	3:23	0.000000	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF SILICAGEL IN BREATHER
1011	19-12-2025	Part of : MAHIPALPUR VILLAGE	1052	Other Outage	Planned Outage	19-12-2025	10:58	19-12-2025	13:51	2:53	0.002163	REPLACEMENT OF LT BUSHING ROD
1012	19-12-2025	Part of : SLASH PUR VILLAGE PALAM FARMS	1564	Other Outage	Planned Outage	19-12-2025	10:28	19-12-2025	12:31	2:03	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1013	20-12-2025	Part of : KAPAS HERA ESTATE,	423	Other Outage	Planned Outage	20-12-2025	11:19	20-12-2025	11:30	0:11	0.000000	MAINTENANCE OF TRANSFORMER
1014	20-12-2025	Part of : MEHRAULI VILLAGE MEHRAULI,	669	Other Outage	Planned Outage	20-12-2025	11:51	20-12-2025	14:06	2:15	0.000000	MAINTENANCE OF TRANSFORMER
1015	20-12-2025	Part of : GHITORNI VILLAGE GHITORNI,	161	Other Outage	Planned Outage	20-12-2025	11:21	20-12-2025	13:24	2:03	0.003758	MAINTENANCE OF O/H HT CIRCUIT
1016	20-12-2025	Part of : SECTOR D VASANT KUNJ,	89	Other Outage	Planned Outage	20-12-2025	10:31	20-12-2025	13:25	2:54	0.000483	MAINTENANCE OF TRANSFORMER
1017	22-12-2025	Part of : KAPAS HERA EXTENSION	645	Other Outage	Planned Outage	22-12-2025	10:59	22-12-2025	11:49	0:50	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1018	22-12-2025	Part of : SAMALKA	50	Other Outage	Planned Outage	22-12-2025	10:38	22-12-2025	12:40	2:02	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1019	22-12-2025	Part of : LAKHI NATH KUTI MEHRAULI	1356	Other Outage	Planned Outage	22-12-2025	10:31	22-12-2025	14:32	4:01	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1020	22-12-2025	Part of : MAHIPALPUR VILLAGE	752	Other Outage	Planned Outage	22-12-2025	10:49	22-12-2025	13:52	3:03	0.002288	REPLACEMENT OF HT BUSHING ROD
1021	22-12-2025	Part of : SECTOR D VASANT KUNJ	135	Other Outage	Planned Outage	22-12-2025	10:30	22-12-2025	13:28	2:58	0.000494	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1022	22-12-2025	Part of : GHITORNI VILLAGE	194	Other Outage	Planned Outage	22-12-2025	10:40	22-12-2025	13:22	2:42	0.004950	GUARD WIRES SAGGING,JUMPER REPLACEMENT PER POLE
1023	22-12-2025	Part of : NAYAK PURA BIJWASAN	1614	Other Outage	Planned Outage	22-12-2025	10:08	22-12-2025	12:11	2:03	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LUGS,SUB STATION CLEANING
1024	23-12-2025	Part of : ANAND GRAM GHITORNI,GHITORNI VILLAGE	2191	Other Outage	Planned Outage	23-12-2025	15:01	23-12-2025	15:58	0:57	0.001742	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY
1025	23-12-2025	Part of : DESU COLONY VASANT KUNJ,GANDHI COLONY MEHRAULI,KHANDSA COLONY MEHRAULI	3558	Other Outage	Planned Outage	23-12-2025	11:32	23-12-2025	12:44	1:12	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,GUARD WIRES SAGGING PER SPAN
1026	23-12-2025	Part of : DESU COLONY VASANT KUNJ,KHANDSA COLONY MEHRAULI,BRIJBASI COLONY MEHRAULI	1747	Other Outage	Planned Outage	23-12-2025	11:31	23-12-2025	12:43	1:12	0.000000	REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1027	23-12-2025	Part of : NAYAK PURA BIJWASAN	579	Other Outage	Planned Outage	23-12-2025	09:50	23-12-2025	11:34	1:44	0.000000	REPLACEMET OF HT BUSHING ROD
1028	23-12-2025	Part of : SECTOR D VASANT KUNJ	71	Other Outage	Planned Outage	23-12-2025	10:30	23-12-2025	13:26	2:56	0.000489	MEASUREMET OF INSULATION RESISTANCE
1029	23-12-2025	Part of : ANAND GRAM GHITORNI	8	Other Outage	Planned Outage	23-12-2025	11:21	23-12-2025	13:32	2:11	0.000437	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE
1030	23-12-2025	Part of : RAJOKRI VILLAGE	336	Other Outage	Planned Outage	23-12-2025	10:46	23-12-2025	13:46	3:00	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1031	24-12-2025	Part of : RAJOKRI VILLAGE RAJOKRI,	49	Other Outage	Planned Outage	24-12-2025	11:03	24-12-2025	12:54	1:51	0.000000	MAINTENANCE OF TRANSFORMER
1032	24-12-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA,	1064	Other Outage	Planned Outage	24-12-2025	10:32	24-12-2025	12:00	1:28	0.000000	MAINTENANCE OF TRANSFORMER
1033	24-12-2025	Part of : MEHRAULI VILLAGE MEHRAULI,	271	Other Outage	Planned Outage	24-12-2025	10:35	24-12-2025	14:25	3:50	0.000000	MAINTENANCE OF TRANSFORMER
1034	24-12-2025	Part of : POCKET 3 SECTOR B VASANT KUNJ,	816	Other Outage	Planned Outage	24-12-2025	10:58	24-12-2025	13:17	2:19	0.000386	MAINTENANCE OF TRANSFORMER
1035	24-12-2025	Part of : RUCHI VIHAR VASANT KUNJ,	308	Other Outage	Planned Outage	24-12-2025	11:35	24-12-2025	14:31	2:56	0.000489	MAINTENANCE OF LT CIRCUIT
1036	24-12-2025	Part of : RANGPURI PAHARI RANGPURI,	18	Other Outage	Planned Outage	24-12-2025	10:57	24-12-2025	13:36	2:39	0.001988	MAINTENANCE OF TRANSFORMER
1037	24-12-2025	Part of : SECTOR D VASANT KUNJ,	25	Other Outage	Planned Outage	24-12-2025	11:01	24-12-2025	13:56	2:55	0.000486	MAINTENANCE OF HT O/H CIRCUIT
1038	25-12-2025	Part of : Ahinsha Enclave Mehrauli,Mehrauli Village Mehrauli,Ladha Sarai Village Mehrauli	3479	Other Outage	Unplanned Outage	25-12-2025	09:04	25-12-2025	09:47	0:43	0.000239	CABLE FAULT BY OUTSIDE AGENCY (MCD)
1039	26-12-2025	Part of : RANGPURI,E,R & L-BLOCK L MAHIPALPUR VILLAGE	4015	Other Outage	Unplanned Outage	26-12-2025	23:52	27-12-2025	00:27	0:35	0.000000	CABLE FAULT
1040	26-12-2025	Part of : RANGPURI PAHARI	245	Other Outage	Planned Outage	26-12-2025	14:20	26-12-2025	15:01	0:41	0.000171	SUB STATION CLEANING
1041	26-12-2025	Part of : GHITORNI VILLAGE	839	Other Outage	Planned Outage	26-12-2025	12:05	26-12-2025	13:16	1:11	0.000296	SUB STATION CLEANING
1042	26-12-2025	Part of : SEC 7 J J COLONY S	3	Other Outage	Planned Outage	26-12-2025	12:05	26-12-2025	13:17	1:12	0.000180	SUB STATION CLEANING
1043	26-12-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA,PUSHPANJALI FARMS,PALAM FARMS	1872	Other Outage	Planned Outage	26-12-2025	11:08	26-12-2025	13:37	2:29	0.000000	TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
1044	26-12-2025	Part of : RAJOKRI VILLAGE	57	Other Outage	Planned Outage	26-12-2025	10:57	26-12-2025	13:38	2:41	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1045	26-12-2025	Part of : SECTOR D VASANT KUNJ	157	Other Outage	Planned Outage	26-12-2025	10:31	26-12-2025	13:27	2:56	0.000489	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1046	26-12-2025	Part of : GHITORNI VILLAGE	896	Other Outage	Planned Outage	26-12-2025	11:03	26-12-2025	13:40	2:37	0.000654	REPLACEMENT OF HT BUSHING INSULATOR
1047	26-12-2025	Part of : MEHRAULI VILLAGE	1394	Other Outage	Planned Outage	26-12-2025	10:42	26-12-2025	13:58	3:16	0.001633	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR
1048	26-12-2025	Part of : RANGPURI NALLAPAR	438	Other Outage	Planned Outage	26-12-2025	10:23	26-12-2025	13:59	3:36	0.002700	REPLACEMENT OF HT BUSHING ROD
1049	27-12-2025	Part of : POCKET 3 SECTOR D VASANT KUNJ	55	Other Outage	Planned Outage	27-12-2025	13:27	27-12-2025	14:18	0:51	0.000213	REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1050	27-12-2025	Part of : RANGPURI	1489	Other Outage	Planned Outage	27-12-2025	10:47	27-12-2025	12:41	1:54	0.001425	REPLACEMENT OF LT BUSHING ROD
1051	27-12-2025	Part of : AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	1	Other Outage	Planned Outage	27-12-2025	10:59	27-12-2025	12:31	1:32	0.000000	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1052	27-12-2025	Part of : GHITORNI VILLAGE	144	Other Outage	Planned Outage	27-12-2025	11:33	27-12-2025	12:57	1:24	0.000350	REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
1053	27-12-2025	Part of : SECTOR D VASANT KUNJ	78	Other Outage	Planned Outage	27-12-2025	10:35	27-12-2025	13:36	3:01	0.000503	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1054	27-12-2025	Part of : ROOPAM WALA KUNWA MEHRAULI	1597	Other Outage	Planned Outage	27-12-2025	10:37	27-12-2025	13:53	3:16	0.001361	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1055	28-12-2025	Part of : GANDHI COLONY MEHRAULI,KHANDSA COLONY MEHRAULI,DESU COLONY VASANT KUNJ	3638	Other Outage	Unplanned Outage	28-12-2025	09:49	28-12-2025	10:21	0:32	0.000844	CABLE FAULT
1056	29-12-2025	Part of : SETH SARAI MEHRAULI,CHRISTIAN COLONY MEHRAULI,MEHRAULI VILLAGE MEHRAULI,LADHA SARAI VILLAGE MEHRAULI	1351	Other Outage	Unplanned Outage	29-12-2025	06:34	29-12-2025	07:28	0:54	0.001290	CABLE FAULT
1057	29-12-2025	Part of : AVENUE BOUGANVILLEA RANGPURI	8	Other Outage	Planned Outage	29-12-2025	10:52	29-12-2025	12:46	1:54	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
1058	29-12-2025	Part of : ANAND GRAM GHITORNI,GHITORNI VILLAGE GHITORNI,ANDHERIA MOR VILLAGE VASANT KUNJ,ARJUN GARH AYA NAGAR	687	Other Outage	Planned Outage	29-12-2025	10:42	29-12-2025	13:46	3:04	0.001278	CONDUCTOR REPLACEMENT PER SPAN,GUARD WIRES SAGGING PER SPAN,HT SLEEVE INSTALLATION PER SPAN
1059	29-12-2025	Part of : SECTOR D VASANT KUNJ	193	Other Outage	Planned Outage	29-12-2025	10:46	29-12-2025	13:44	2:58	0.000494	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1060	29-12-2025	Part of : RANGPURI NALLAPAR RANGPURI	402	Other Outage	Planned Outage	29-12-2025	10:27	29-12-2025	13:58	3:31	0.002638	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1061	29-12-2025	Part of : BADIWALA KUA MEHRAULI	1042	Other Outage	Planned Outage	29-12-2025	10:43	29-12-2025	13:52	3:09	0.000000	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
1062	30-12-2025	Part of : NAYAK PURA,HARIJAN BASTI,AMBEDKAR BASTI,GREWAL COLONY BIJWASAN	2706	Other Outage	Unplanned Outage	30-12-2025	14:28	30-12-2025	14:45	0:17	0.000165	BIRDAGE
1063	30-12-2025	Part of : PALAM FARMS	101	Other Outage	Planned Outage	30-12-2025	11:06	30-12-2025	11:56	0:50	0.000000	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF HT/LT CLEATS
1064	30-12-2025	Part of : WEST END GREENS RANGPURI	1	Other Outage	Planned Outage	30-12-2025	10:50	30-12-2025	12:39	1:49	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1065	30-12-2025	Part of : GHITORNI VILLAGE	21	Other Outage	Planned Outage	30-12-2025	10:50	30-12-2025	12:47	1:57	0.000390	INSTALLATION OF BUS BAR,SUB STATION CLEANING
1066	30-12-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ	46	Other Outage	Planned Outage	30-12-2025	11:07	30-12-2025	14:03	2:56	0.000489	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1067	30-12-2025	Part of : T.B HOSPITAL	1	Other Outage	Planned Outage	30-12-2025	10:55	30-12-2025	12:56	2:01	0.000504	1PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1068	30-12-2025	Part of : MAHIPALPUR EXTENSION	909	Other Outage	Planned Outage	30-12-2025	10:45	30-12-2025	13:57	3:12	0.000800	REPLACEMENT OF HT BUSHING ROD
1069	31-12-2025	Part of : GHITORNI VILLAGE	1	Other Outage	Planned Outage	31-12-2025	11:10	31-12-2025	13:05	1:55	0.000383	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1070	31-12-2025	Part of : KALKA DASS MEHRAULI	1258	Other Outage	Planned Outage	31-12-2025	11:19	31-12-2025	12:33	1:14	0.000000	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1071	31-12-2025	Part of : PALAM FARMS	47	Other Outage	Planned Outage	31-12-2025	10:02	31-12-2025	11:51	1:49	0.000000	REPLACEMET OF LUGS,SUB STATION CLEANING
1072	31-12-2025	Part of : SECTOR D VASANT KUNJ	25	Other Outage	Planned Outage	31-12-2025	11:04	31-12-2025	13:59	2:55	0.000486	HT SLEEVE INSTALLATION PER SPAN
1073	31-12-2025	Part of : ANDHERIA MOR VILLAGE VASANT KUNJ	43	Other Outage	Planned Outage	31-12-2025	10:59	31-12-2025	13:04	2:05	0.000417	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,SUB STATION CLEANING
1074	31-12-2025	Part of : BLOCK RZ MAHIPALPUR VILLAGE	101	Other Outage	Planned Outage	31-12-2025	10:28	31-12-2025	13:56	3:28	0.001733	REPLACEMENT OF LT BUSHING ROD
1075	01-12-2025	Part of : HARI VIHAR SECTOR 15 DWARKA	69	Other Outage	Planned Outage	01-12-2025	15:50	01-12-2025	16:47	0:57	0.000000	ACB REPLACEMENT PER ACB
1076	02-12-2025	Part of : POCKET 1 SECTOR 14 DWARKA,BHARAT VIHAR DWARKA	727	Other Outage	Unplanned Outage	02-12-2025	09:22	02-12-2025	10:13	0:51	0.000723	CABLE FAULT
1077	03-12-2025	Part of : JAIN COLONY MATIALA,G AND S BLOCK VISHWAS PARK, SECTOR 3 DWARKA,RAJAPURI MATIALA	2368	Other Outage	Unplanned Outage	03-12-2025	03:46	03-12-2025	05:00	1:14	0.000226	CABLE FAULT
1078	05-12-2025	Part of : POCKET 3,6,7 SECTOR 12 DWARKA,POCKET 2&5 SECTOR 12 DWARKA,BLOCK B POCKET 8 SECTOR 12 DWARKA	1504	Other Outage	Unplanned Outage	05-12-2025	15:46	05-12-2025	16:26	0:40	0.000789	CABLE FAULT
1079	05-12-2025	Part of : HARI VIHAR SECTOR 15 DWARKA	427	Other Outage	Planned Outage	05-12-2025	14:31	05-12-2025	15:58	1:27	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1080	08-12-2025	Part of : SECTOR 3 DWARKA	1811	Other Outage	Unplanned Outage	08-12-2025	16:19	08-12-2025	17:10	0:51	0.000000	CABLE FAULT
1081	08-12-2025	Part of : HAR NAGAR SECTOR 16 DWARKA,	1259	Other Outage	Planned Outage	08-12-2025	14:58	08-12-2025	17:11	2:13	0.000000	REPLACEMET OF HT BUSHING ROD
1082	09-12-2025	Part of : SECTOR 11 DWARKA,POCKET 1 SECTOR-5 MARKET SECTOR 5 DWARKA,SECTOR 5 DWARKA,POCKET 1 SECTOR 11 DWARKA	1851	Other Outage	Planned Outage	09-12-2025	15:19	09-12-2025	16:35	1:16	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1083	09-12-2025	Part of : BLOCK D UTTAM VIHAR BINDAPUR,BLOCK A BHARAT NAGAR MADHU VIHAR,BLOCK A3 UTTAM VIHAR BINDAPUR	1634	Other Outage	Planned Outage	09-12-2025	11:23	09-12-2025	13:52	2:29	0.000000	REPLACEMENT OF HT BUSHING ROD
1084	10-12-2025	Part of : RZ-BLOCK MADHU VIHAR,A 3-BLOCK UTTAM VIHAR BINDAPUR	743	Other Outage	Planned Outage	10-12-2025	11:16	10-12-2025	13:37	2:21	0.000000	REPLACEMENT OF HT BUSHING ROD
1085	11-12-2025	Part of : POCKET 1 SECTOR 19 DWARKA	73	Other Outage	Planned Outage	11-12-2025	14:12	11-12-2025	16:25	2:13	0.000000	REPLACEMET OF HT BUSHING ROD
1086	12-12-2025	Part of : JAIN COLONY MATIALA,BLOCK G JAIN COLONY MATIALA,	4502	Other Outage	Planned Outage	12-12-2025	11:12	12-12-2025	13:57	2:45	0.000000	REPLACEMET OF HT BUSHING ROD
1087	13-12-2025	Part of : SECTOR 5 DWARKA,SECTOR 4 DWARKA	680	Other Outage	Planned Outage	13-12-2025	10:31	13-12-2025	12:57	2:26	0.000000	REPLACEMENT OF HT BUSHING INULATOR
1088	15-12-2025	Part of : RAJU ENCLAVE SECTOR 15 DWARKA,HARI VIHAR SECTOR 15 DWARKA	1063	Other Outage	Planned Outage	15-12-2025	12:32	15-12-2025	14:58	2:26	0.000000	REPLACEMET OF HT BUSHING ROD
1089	16-12-2025	Part of : TRANSIT CAMP DWARKA,VIKAS NAGAR SECTOR 15 DWARKA,RAJU PARAK EXTENSION DWARKA	2334	Other Outage	Planned Outage	16-12-2025	12:29	16-12-2025	14:39	2:10	0.000000	MAINTENANCE OF TRANSFORMER
1090	17-12-2025	Part of : BHARAT VIHAR DWARKA,TRANSIT CAMP DWARKA	2070	Other Outage	Planned Outage	17-12-2025	11:07	17-12-2025	13:27	2:20	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1091	18-12-2025	Part of : BHARAT VIHAR & RAJU PARAK EXTENSION DWARKA	2506	Other Outage	Planned Outage	18-12-2025	10:55	18-12-2025	13:08	2:13	0.000000	REPLACEMENT OF HT BUSHING ROD
1092	19-12-2025	Part of : SEC-12 & 13 DWARKA, PARK PLAZA HOTEL SECTOR-13 DWARKA (HTC)	0	Other Outage	Unplanned Outage	19-12-2025	00:22	19-12-2025	01:59	1:37	0.000000	CABLE FAULT
1093	19-12-2025	Part of : BHAGWATI VIHAR BINDAPUR	3121	Other Outage	Unplanned Outage	19-12-2025	15:47	19-12-2025	17:34	1:47	0.000000	CONNECTION/DISCONNECTION OF LT CABLE
1094	21-12-2025	Part of : POCKET 2 SECTOR 2 DWARKA,POCKET 1 SECTOR 2 DWARKA,ADARSH APARTMENT MADHU VIHAR	1540	Other Outage	Unplanned Outage	21-12-2025	14:16	21-12-2025	14:53	0:37	0.000000	FAULT IN HT CONSUMER PANEL (BHASKARACHARYA COLLEGE)
1095	22-12-2025	Part of : SECTOR 6 DWARKA	31	Other Outage	Planned Outage	22-12-2025	16:03	22-12-2025	17:55	1:52	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1096	22-12-2025	Part of : NAND VIHAR,HARI VIHAR,HAR NAGAR SECTOR 16 DWARKA,KAKRAULA VILLAGE	3371	Other Outage	Planned Outage	22-12-2025	11:58	22-12-2025	13:36	1:38	0.000000	REPLACEMENT OF HT BUSHING ROD
1097	23-12-2025	Part of : NISHAT PARK SECTOR 15 DWARKA	490	Other Outage	Planned Outage	23-12-2025	11:28	23-12-2025	13:58	2:30	0.000000	REPLACEMET OF HT BUSHING ROD
1098	26-12-2025	Part of : HAR NAGAR SECTOR 16 DWARKA	1259	Other Outage	Planned Outage	26-12-2025	12:59	26-12-2025	15:04	2:05	0.000000	REPLACEMENT OF HT BUSHING ROD
1099	29-12-2025	Part of : POCKET 3 SECTOR 11 DWARKA,SECTOR 12 DWARKA,POCKET 4 SECTOR 11 DWARKA,POCKET 2 SECTOR 11 DWARKA	1497	Other Outage	Unplanned Outage	29-12-2025	11:28	29-12-2025	12:18	0:50	0.000917	TREE TOUCHING
1100	29-12-2025	Part of : TRANSIT CAMP DWARKA,VIKAS NAGAR SECTOR 15 DWARKA,RAJU PARAK EXTENSION DWARKA,TARA NAGAR DWARKA,BHARAT VIHAR DWARKA,BLOCK A BHARAT VIHAR DWARKA	2376	Other Outage	Planned Outage	29-12-2025	11:47	29-12-2025	14:01	2:14	0.000000	REPLACEMENT OF HT BUSHING ROD
1101	30-12-2025	Part of : NISHAT PARK SECTOR 15 DWARKA	490	Other Outage	Planned Outage	30-12-2025	10:26	30-12-2025	12:46	2:20	0.000000	REPLACEMENT OF HT BUSHING ROD
1102	31-12-2025	Part of : TRANSIT CAMP DWARKA,VIKAS NAGAR SECTOR 15 DWARKA,TARA NAGAR DWARKA,BLOCK A BHARAT VIHAR DWARKA	1814	Other Outage	Planned Outage	31-12-2025	10:54	31-12-2025	13:34	2:40	0.000000	REPLACEMET OF HT BUSHING ROD
1103	01-12-2025	Part of : SUREHRA VILLAGE	466	Other Outage	Planned Outage	01-12-2025	14:53	01-12-2025	16:46	1:53	0.001569	REPLACEMENT OF HT BUSHING ROD
1104	01-12-2025	Part of : BADHOSRA	315	Other Outage	Planned Outage	01-12-2025	14:54	01-12-2025	16:56	2:02	0.001694	REPLACEMENT OF HT BUSHING ROD
1105	01-12-2025	Part of : KHARKHARI JATMAL VILLAGE	1	Other Outage	Planned Outage	01-12-2025	14:38	01-12-2025	16:45	2:07	0.001764	REPLACEMENT OF HT BUSHING ROD
1106	01-12-2025	Part of : SUREHRA VILLAGE	77	Other Outage	Planned Outage	01-12-2025	14:38	01-12-2025	16:45	2:07	0.001764	REPLACEMENT OF HT BUSHING ROD
1107	01-12-2025	Part of : KHERA HOSPITAL (HTC), GHUMNHERA CAMP CTR (HTC),POWER G CORP (HTC), GHUMANHER	1	Other Outage	Planned Outage	01-12-2025	12:01	01-12-2025	14:42	2:41	0.002236	GUARD WIRES SAGGING PER SPAN
1108	01-12-2025	Part of : SAMAZPUR KHALSA	361	Other Outage	Planned Outage	01-12-2025	11:09	01-12-2025	13:55	2:46	0.002306	REPLACEMENT OF HT BUSHING ROD
1109	01-12-2025	Part of : MANDHELA KALAN VILLAGE	8	Other Outage	Planned Outage	01-12-2025	10:59	01-12-2025	13:19	2:20	0.001944	REPLACEMENT OF HT BUSHING ROD
1110	01-12-2025	Part of : MANDHELA KALAN VILLAGE	518	Other Outage	Planned Outage	01-12-2025	11:01	01-12-2025	13:19	2:18	0.001533	REPLACEMENT OF HT BUSHING ROD
1111	02-12-2025	Part of : KHERA DABAS VILLAGE	158	Other Outage	Planned Outage	02-12-2025	15:17	02-12-2025	16:40	1:23	0.000922	REPLACEMET OF HT BUSHING ROD
1112	02-12-2025	Part of : MITRAON VILLAGE NAJAFGARH	243	Other Outage	Planned Outage	02-12-2025	14:06	02-12-2025	16:40	2:34	0.001711	REPLACEMET OF HT BUSHING ROD
1113	02-12-2025	Part of : ISSAPUR VILLAGE	267	Other Outage	Planned Outage	02-12-2025	14:00	02-12-2025	16:14	2:14	0.001489	REPLACEMET OF HT BUSHING ROD
1114	02-12-2025	Part of : MITRAON VILLAGE NAJAFGARH	1	Other Outage	Planned Outage	02-12-2025	14:08	02-12-2025	16:39	2:31	0.001678	REPLACEMET OF HT BUSHING ROD
1115	03-12-2025	Part of : BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN	650	Other Outage	Planned Outage	03-12-2025	15:29	03-12-2025	16:58	1:29	0.000247	REPLACEMET OF HT BUSHING ROD
1116	03-12-2025	Part of : JAFARPUR KALAN VILLAGE	249	Other Outage	Planned Outage	03-12-2025	15:01	03-12-2025	16:33	1:32	0.001022	REPLACEMET OF HT BUSHING ROD
1117	03-12-2025	Part of : SUREHRA VILLAGE	213	Other Outage	Planned Outage	03-12-2025	13:44	03-12-2025	15:53	2:09	0.001433	REPLACEMET OF HT BUSHING ROD
1118	03-12-2025	Part of : JANTA VIHAR HAIBUTPUR	260	Other Outage	Planned Outage	03-12-2025	13:08	03-12-2025	16:00	2:52	0.000478	REPLACEMET OF HT BUSHING ROD
1119	03-12-2025	Part of : GHUMAN HERA JAINPUR VILLAGE	28	Other Outage	Planned Outage	03-12-2025	11:04	03-12-2025	13:44	2:40	0.001778	REPLACEMET OF HT BUSHING ROD
1120	04-12-2025	Part of : SURAKHPUR	3	Other Outage	Planned Outage	04-12-2025	15:01	04-12-2025	16:45	1:44	0.001733	REPLACEMENT OF LT BUSHING ROD
1121	04-12-2025	Part of : MANDHELA KALAN VILLAGE	4	Other Outage	Planned Outage	04-12-2025	12:06	04-12-2025	13:54	1:48	0.000300	REPLACEMENT OF LT BUSHING ROD
1122	04-12-2025	Part of : SRI HANS NAGAR	510	Other Outage	Planned Outage	04-12-2025	12:56	04-12-2025	15:02	2:06	0.000700	REPLACEMENT OF LT BUSHING ROD
1123	04-12-2025	Part of : BADHOSRA	190	Other Outage	Planned Outage	04-12-2025	11:21	04-12-2025	13:54	2:33	0.000425	REPLACEMENT OF HT BUSHING ROD
1124	04-12-2025	Part of : SAMAZPUR KHALSA	294	Other Outage	Planned Outage	04-12-2025	10:03	04-12-2025	12:44	2:41	0.000447	REPLACEMENT OF LT BUSHING ROD
1125	05-12-2025	Part of : RAWTA VILLAGE	14	Other Outage	Planned Outage	05-12-2025	14:41	05-12-2025	16:05	1:24	0.000233	REPLACEMET OF HT BUSHING ROD
1126	05-12-2025	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	691	Other Outage	Planned Outage	05-12-2025	14:46	05-12-2025	16:23	1:37	0.000269	REPLACEMENT OF LT BUSHING ROD
1127	05-12-2025	Part of : JAFARPUR KALAN VILLAGE	270	Other Outage	Planned Outage	05-12-2025	13:59	05-12-2025	15:13	1:14	0.001028	REPLACEMET OF HT BUSHING ROD
1128	05-12-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	994	Other Outage	Planned Outage	05-12-2025	13:58	05-12-2025	15:11	1:13	0.000203	REPLACEMENT OF LT BUSHING ROD
1129	05-12-2025	Part of : JANTA VIHAR HAIBUTPUR	260	Other Outage	Planned Outage	05-12-2025	11:32	05-12-2025	14:03	2:31	0.002097	REPLACEMENT OF HT BUSHING ROD
1130	05-12-2025	Part of : DHANSA VILLAGE	258	Other Outage	Planned Outage	05-12-2025	11:08	05-12-2025	13:36	2:28	0.000411	REPLACEMENT OF LT BUSHING ROD
1131	05-12-2025	Part of : MANDHELA KALAN VILLAGE	8	Other Outage	Planned Outage	05-12-2025	11:00	05-12-2025	13:51	2:51	0.000475	REPLACEMENT OF LT BUSHING ROD
1132	05-12-2025	Part of : KAIR VILLAGE	495	Other Outage	Planned Outage	05-12-2025	11:27	05-12-2025	14:03	2:36	0.002167	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1133	06-12-2025	Part of : JAFARPUR KALAN VILLAGE	466	Other Outage	Planned Outage	06-12-2025	15:49	06-12-2025	16:38	0:49	0.000681	REPLACEMENT OF HT BUSHING ROD
1134	06-12-2025	Part of : HOCKEY STADIUM GHUMMANHERA (HT CONSUMER)	1	Other Outage	Planned Outage	06-12-2025	14:42	06-12-2025	16:32	1:50	0.001528	REPLACEMENT OF HT BUSHING ROD
1135	06-12-2025	Part of : BAQAR GARH VILLAGE	302	Other Outage	Planned Outage	06-12-2025	11:43	06-12-2025	13:49	2:06	0.001750	REPLACEMENT OF HT BUSHING ROD
1136	06-12-2025	Part of : SURAKHPUR	4	Other Outage	Planned Outage	06-12-2025	11:06	06-12-2025	13:49	2:43	0.002264	REPLACEMENT OF HT BUSHING ROD
1137	08-12-2025	Part of : SAMAZPUR KHALSA,	190	Other Outage	Planned Outage	08-12-2025	14:27	08-12-2025	15:57	1:30	0.001250	REPLACEMET OF HT BUSHING ROD
1138	08-12-2025	Part of : SUREHRA VILLAGE,	466	Other Outage	Planned Outage	08-12-2025	13:56	08-12-2025	16:31	2:35	0.002153	REPLACEMET OF HT BUSHING ROD
1139	08-12-2025	Part of : KHERA DABAS VILLAGE,	7	Other Outage	Planned Outage	08-12-2025	13:56	08-12-2025	16:32	2:36	0.002167	REPLACEMET OF HT BUSHING ROD
1140	08-12-2025	Part of : SHYAM ENCAVE NAJAFGARH,	310	Other Outage	Planned Outage	08-12-2025	12:59	08-12-2025	15:57	2:58	0.002472	REPLACEMENT OF HT BUSHING ROD
1141	08-12-2025	Part of : ISSAPUR VILLAGE,	452	Other Outage	Planned Outage	08-12-2025	11:03	08-12-2025	13:29	2:26	0.002028	REPLACEMET OF HT BUSHING ROD
1142	08-12-2025	Part of : GHALLBPUR VILLAGE,	1	Other Outage	Planned Outage	08-12-2025	10:44	08-12-2025	12:57	2:13	0.001847	REPLACEMET OF HT BUSHING ROD
1143	09-12-2025	Part of : QAZIPUR VILLAGE	273	Other Outage	Planned Outage	09-12-2025	11:56	09-12-2025	13:32	1:36	0.001067	REPLACEMENT OF HT BUSHING ROD
1144	09-12-2025	Part of : GOPAL EXTENSION II NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	5	Other Outage	Planned Outage	09-12-2025	13:19	09-12-2025	15:49	2:30	0.002083	REPLACEMENT OF LT BUSHING ROD
1145	09-12-2025	Part of : KAIR VILLAGE	489	Other Outage	Planned Outage	09-12-2025	13:18	09-12-2025	15:50	2:32	0.001689	REPLACEMENT OF HT BUSHING ROD
1146	09-12-2025	Part of : SUREHRA VILLAGE	10	Other Outage	Planned Outage	09-12-2025	12:05	09-12-2025	15:09	3:04	0.002556	REPLACEMENT OF HT BUSHING ROD
1147	09-12-2025	Part of : MITRAON VILLAGE NAJAFGARH	364	Other Outage	Planned Outage	09-12-2025	12:05	09-12-2025	15:08	3:03	0.002033	REPLACEMENT OF HT BUSHING ROD
1148	09-12-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	990	Other Outage	Planned Outage	09-12-2025	11:06	09-12-2025	13:56	2:50	0.001889	REPLACEMENT OF HT BUSHING ROD
1149	10-12-2025	Part of : SUREHRA VILLAGE	213	Other Outage	Planned Outage	10-12-2025	11:45	10-12-2025	13:41	1:56	0.001289	REPLACEMENT OF HT BUSHING ROD
1150	10-12-2025	Part of : DHANSA VILLAGE	383	Other Outage	Planned Outage	10-12-2025	12:08	10-12-2025	13:59	1:51	0.001233	REPLACEMENT OF HT BUSHING ROD
1151	10-12-2025	Part of : A 1-BLOCK VINOBHA ENCLAVE, CRPF COLONY JHARODA KALAN	651	Other Outage	Planned Outage	10-12-2025	13:44	10-12-2025	15:56	2:12	0.000367	REPLACEMENT OF HT BUSHING ROD
1152	10-12-2025	Part of : SRI HANS NAGAR	510	Other Outage	Planned Outage	10-12-2025	13:32	10-12-2025	15:56	2:24	0.002000	REPLACEMENT OF HT BUSHING ROD
1153	10-12-2025	Part of : MANDHELA KALAN VILLAGE	281	Other Outage	Planned Outage	10-12-2025	11:46	10-12-2025	14:59	3:13	0.000536	REPLACEMENT OF HT BUSHING ROD
1154	10-12-2025	Part of : GHUMAN HERA JAINPUR VILLAGE	1	Other Outage	Planned Outage	10-12-2025	12:08	10-12-2025	14:58	2:50	0.001889	REPLACEMENT OF HT BUSHING ROD
1155	10-12-2025	Part of : KHERA DABAS VILLAGE	158	Other Outage	Planned Outage	10-12-2025	11:05	10-12-2025	13:28	2:23	0.001589	REPLACEMENT OF HT BUSHING ROD
1156	10-12-2025	Part of : KHERA DABAS VILLAGE	252	Other Outage	Planned Outage	10-12-2025	10:22	10-12-2025	12:42	2:20	0.001944	REPLACEMENT OF HT BUSHING ROD
1157	11-12-2025	Part of : SAMAZPUR KHALSA	171	Other Outage	Planned Outage	11-12-2025	15:05	11-12-2025	16:40	1:35	0.000264	REPLACEMENT OF LT BUSHING ROD
1158	11-12-2025	Part of : SUREHRA VILLAGE	1	Other Outage	Planned Outage	11-12-2025	14:31	11-12-2025	16:40	2:09	0.001792	REPLACEMET OF HT BUSHING ROD
1159	11-12-2025	Part of : KAIR VILLAGE	489	Other Outage	Planned Outage	11-12-2025	11:01	11-12-2025	13:24	2:23	0.001589	REPLACEMET OF HT BUSHING ROD
1160	11-12-2025	Part of : BAQAR GARH VILLAGE	1	Other Outage	Planned Outage	11-12-2025	10:59	11-12-2025	13:41	2:42	0.000450	REPLACEMENT OF LT BUSHING ROD
1161	11-12-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	1052	Other Outage	Planned Outage	11-12-2025	11:13	11-12-2025	13:41	2:28	0.000411	REPLACEMENT OF LT BUSHING ROD
1162	12-12-2025	Part of : DAURALA VILLAGE,	12	Other Outage	Planned Outage	12-12-2025	14:08	12-12-2025	16:11	2:03	0.000342	REPLACEMET OF HT BUSHING ROD
1163	12-12-2025	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	691	Other Outage	Planned Outage	12-12-2025	13:51	12-12-2025	16:19	2:28	0.000411	REPLACEMET OF HT BUSHING ROD
1164	12-12-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,	1404	Other Outage	Planned Outage	12-12-2025	12:04	12-12-2025	14:45	2:41	0.002236	REPLACEMET OF HT BUSHING ROD
1165	12-12-2025	Part of : BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN,	651	Other Outage	Planned Outage	12-12-2025	12:25	12-12-2025	14:45	2:20	0.000389	REPLACEMET OF HT BUSHING ROD
1166	12-12-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE,	994	Other Outage	Planned Outage	12-12-2025	11:14	12-12-2025	13:51	2:37	0.000436	REPLACEMENT OF LT BUSHING ROD
1167	12-12-2025	Part of : MANDHELA KALAN VILLAGE,	281	Other Outage	Planned Outage	12-12-2025	11:21	12-12-2025	13:52	2:31	0.000419	REPLACEMET OF HT BUSHING ROD
1168	12-12-2025	Part of : DHANSA VILLAGE,	11	Other Outage	Planned Outage	12-12-2025	11:32	12-12-2025	13:49	2:17	0.000381	REPLACEMENT OF LT BUSHING ROD
1169	13-12-2025	Part of : JANTA VIHAR HAIBUTPUR	266	Other Outage	Planned Outage	13-12-2025	15:01	13-12-2025	16:20	1:19	0.001097	REPLACEMENT OF HT BUSHING ROD
1170	13-12-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	1052	Other Outage	Planned Outage	13-12-2025	13:58	13-12-2025	15:57	1:59	0.001653	REPLACEMENT OF HT BUSHING ROD
1171	13-12-2025	Part of : GHUMAN HERA JAINPUR VILLAGE	66	Other Outage	Planned Outage	13-12-2025	12:06	13-12-2025	14:45	2:39	0.002208	REPLACEMENT OF HT BUSHING ROD
1172	13-12-2025	Part of : JANTA VIHAR HAIBUTPUR	260	Other Outage	Planned Outage	13-12-2025	12:08	13-12-2025	14:57	2:49	0.002347	REPLACEMENT OF HT BUSHING ROD
1173	13-12-2025	Part of : SARANGPUR VILLAGE	1	Other Outage	Planned Outage	13-12-2025	10:58	13-12-2025	13:49	2:51	0.002375	REPLACEMENT OF HT BUSHING ROD
1174	15-12-2025	Part of : MITRAON VILLAGE NAJAFGARH, KAIR VILLAGE	1526	Other Outage	Unplanned Outage	15-12-2025	03:01	15-12-2025	03:09	0:08	0.000040	HT SYSTEM FAULT
1175	15-12-2025	Part of : BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN	650	Other Outage	Planned Outage	15-12-2025	14:33	15-12-2025	15:00	0:27	0.000375	REPLACEMET OF HT BUSHING ROD
1176	15-12-2025	Part of : MALIKPUR ZER VILLAGE	336	Other Outage	Planned Outage	15-12-2025	15:30	15-12-2025	16:35	1:05	0.000903	REPLACEMET OF HT BUSHING ROD
1177	15-12-2025	Part of : SARANGPUR VILLAGE	14	Other Outage	Planned Outage	15-12-2025	14:23	15-12-2025	15:45	1:22	0.001139	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1178	15-12-2025	Part of : BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	549	Other Outage	Planned Outage	15-12-2025	14:15	15-12-2025	16:29	2:14	0.001861	REPLACEMET OF HT BUSHING ROD
1179	15-12-2025	Part of : MANDHELA KHURD VILLAGE	4	Other Outage	Planned Outage	15-12-2025	12:31	15-12-2025	14:58	2:27	0.000000	SUB STATION CLEANING
1180	15-12-2025	Part of : ISSAPUR VILLAGE	313	Other Outage	Planned Outage	15-12-2025	12:04	15-12-2025	15:00	2:56	0.002444	REPLACEMET OF HT BUSHING ROD
1181	15-12-2025	Part of : NAJAFGARH VILLAGE,SHIV VIHAR COLONY GOPAL NAGAR NAJAFGARH	691	Other Outage	Planned Outage	15-12-2025	12:16	15-12-2025	14:59	2:43	0.002264	REPLACEMET OF HT BUSHING ROD
1182	16-12-2025	Part of : GHUMANHERA,	9	Other Outage	Planned Outage	16-12-2025	15:28	16-12-2025	17:01	1:33	0.001292	MAINTENANCE OF TRANSFORMER
1183	16-12-2025	Part of : UJWA VILLAGE,	527	Other Outage	Planned Outage	16-12-2025	15:49	16-12-2025	17:02	1:13	0.001014	MAINTENANCE OF TRANSFORMER
1184	16-12-2025	Part of : MITRAON VILLAGE NAJAFGARH,	243	Other Outage	Planned Outage	16-12-2025	15:27	16-12-2025	17:01	1:34	0.001044	MAINTENANCE OF TRANSFORMER
1185	16-12-2025	Part of : SHERPUR DERI,	13	Other Outage	Planned Outage	16-12-2025	14:18	16-12-2025	15:29	1:11	0.000789	MAINTENANCE OF TRANSFORMER
1186	16-12-2025	Part of : SHYAM ENCAVE NAJAFGARH,	313	Other Outage	Planned Outage	16-12-2025	13:32	16-12-2025	15:12	1:40	0.001389	MAINTENANCE OF TRANSFORMER
1187	16-12-2025	Part of : MANDHELA KHURD VILLAGE,	2	Other Outage	Planned Outage	16-12-2025	11:03	16-12-2025	12:53	1:50	0.001222	MAINTENANCE OF TRANSFORMER
1188	16-12-2025	Part of : BADHOSRA,	190	Other Outage	Planned Outage	16-12-2025	10:59	16-12-2025	14:00	3:01	0.002011	MAINTENANCE OF TRANSFORMER
1189	16-12-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE,	990	Other Outage	Planned Outage	16-12-2025	11:02	16-12-2025	14:00	2:58	0.001978	MAINTENANCE OF TRANSFORMER
1190	17-12-2025	Part of : UJWA VILLAGE	465	Other Outage	Planned Outage	17-12-2025	15:48	17-12-2025	16:43	0:55	0.000611	REPLACEMENT OF HT BUSHING ROD
1191	17-12-2025	Part of : ISSAPUR VILLAGE	246	Other Outage	Planned Outage	17-12-2025	11:02	17-12-2025	12:52	1:50	0.001222	REPLACEMENT OF HT BUSHING ROD
1192	17-12-2025	Part of : SUREHRA VILLAGE	213	Other Outage	Planned Outage	17-12-2025	12:35	17-12-2025	14:42	2:07	0.001411	REPLACEMENT OF HT BUSHING ROD
1193	17-12-2025	Part of : MANDHELA KALAN VILLAGE	13	Other Outage	Planned Outage	17-12-2025	11:00	17-12-2025	13:55	2:55	0.001944	REPLACEMENT OF HT BUSHING ROD
1194	18-12-2025	Part of : KHERA DABAS VILLAGE	159	Other Outage	Planned Outage	18-12-2025	11:53	18-12-2025	13:51	1:58	0.000328	REPLACEMENT OF HT BUSHING ROD
1195	18-12-2025	Part of : DHANSA VILLAGE	146	Other Outage	Planned Outage	18-12-2025	11:01	18-12-2025	12:41	1:40	0.000278	REPLACEMENT OF HT BUSHING ROD
1196	18-12-2025	Part of : JANTA VIHAR HAIBUTPUR	8	Other Outage	Planned Outage	18-12-2025	14:27	18-12-2025	16:46	2:19	0.000386	REPLACEMENT OF HT BUSHING ROD
1197	18-12-2025	Part of : KHERA DABAS VILLAGE	252	Other Outage	Planned Outage	18-12-2025	12:26	18-12-2025	14:54	2:28	0.000411	REPLACEMENT OF HT BUSHING ROD
1198	18-12-2025	Part of : DAURALA VILLAGE	11	Other Outage	Planned Outage	18-12-2025	11:18	18-12-2025	13:50	2:32	0.000422	REPLACEMENT OF HT BUSHING ROD
1199	18-12-2025	Part of : MANDHELA KALAN VILLAGE	4	Other Outage	Planned Outage	18-12-2025	11:30	18-12-2025	13:51	2:21	0.000392	REPLACEMENT OF HT BUSHING ROD
1200	19-12-2025	Part of : MANDHELA KHURD VILLAGE	1	Other Outage	Planned Outage	19-12-2025	15:02	19-12-2025	16:49	1:47	0.000297	REPLACEMET OF HT BUSHING ROD
1201	19-12-2025	Part of : MALIKPUR ZER VILLAGE	285	Other Outage	Planned Outage	19-12-2025	15:46	19-12-2025	16:50	1:04	0.000178	REPLACEMET OF HT BUSHING ROD
1202	19-12-2025	Part of : NANU RAM PARK NAJAFGARH	28	Other Outage	Planned Outage	19-12-2025	14:05	19-12-2025	16:07	2:02	0.000339	REPLACEMENT OF LT BUSHING ROD
1203	19-12-2025	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	691	Other Outage	Planned Outage	19-12-2025	12:37	19-12-2025	15:02	2:25	0.000403	REPLACEMENT OF LT BUSHING ROD
1204	19-12-2025	Part of : BADHOSRA	840	Other Outage	Planned Outage	19-12-2025	11:26	19-12-2025	13:39	2:13	0.000369	REPLACEMET OF HT BUSHING ROD
1205	20-12-2025	Part of : SRI HANS NAGAR	8	Other Outage	Unplanned Outage	20-12-2025	05:49	20-12-2025	06:07	0:18	0.000000	TRANSIENT FAULT
1206	20-12-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE,	717	Other Outage	Planned Outage	20-12-2025	13:33	20-12-2025	15:13	1:40	0.001389	MAINTENANCE OF TRANSFORMER
1207	20-12-2025	Part of : DHANSA VILLAGE,	355	Other Outage	Planned Outage	20-12-2025	11:23	20-12-2025	13:08	1:45	0.001458	MAINTENANCE OF TRANSFORMER
1208	20-12-2025	Part of : GHALLBPUR VILLAGE,	147	Other Outage	Planned Outage	20-12-2025	13:01	20-12-2025	16:02	3:01	0.002514	MAINTENANCE OF TRANSFORMER
1209	20-12-2025	Part of : MANDHELA KHURD VILLAGE,	2	Other Outage	Planned Outage	20-12-2025	13:15	20-12-2025	15:16	2:01	0.001681	MAINTENANCE OF TRANSFORMER
1210	20-12-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	321	Other Outage	Planned Outage	20-12-2025	11:18	20-12-2025	14:12	2:54	0.002417	MAINTENANCE OF TRANSFORMER
1211	20-12-2025	Part of : SHYAM ENCAVE NAJAFGARH,KRISHAN VIHAR NAJAFGARH,BASCO COLONY ARYA NAGAR NAJAFGARH	1864	Other Outage	Planned Outage	20-12-2025	11:09	20-12-2025	13:14	2:05	0.001736	MAINTENANCE OF TRANSFORMER
1212	22-12-2025	Part of : JAFARPUR KALAN VILLAGE	249	Other Outage	Planned Outage	22-12-2025	15:09	22-12-2025	17:01	1:52	0.001556	REPLACEMENT OF HT BUSHING ROD
1213	22-12-2025	Part of : SUREHRA VILLAGE	466	Other Outage	Planned Outage	22-12-2025	14:32	22-12-2025	16:25	1:53	0.001569	REPLACEMENT OF HT BUSHING ROD
1214	22-12-2025	Part of : BADHOSRA	315	Other Outage	Planned Outage	22-12-2025	11:15	22-12-2025	12:58	1:43	0.001431	REPLACEMENT OF HT BUSHING ROD
1215	22-12-2025	Part of : SHIV VIHAR COLONY GOPAL NAGAR NAJAFGARH	671	Other Outage	Planned Outage	22-12-2025	12:23	22-12-2025	14:30	2:07	0.001764	REPLACEMENT OF HT BUSHING ROD
1216	22-12-2025	Part of : SARANGPUR VILLAGE	181	Other Outage	Planned Outage	22-12-2025	11:23	22-12-2025	14:00	2:37	0.002181	REPLACEMENT OF HT BUSHING ROD
1217	23-12-2025	Part of : MALIKPUR ZER VILLAGE	214	Other Outage	Planned Outage	23-12-2025	15:39	23-12-2025	16:44	1:05	0.000722	REPLACEMET OF HT BUSHING ROD
1218	23-12-2025	Part of : MANDHELA KALAN VILLAGE	4	Other Outage	Planned Outage	23-12-2025	11:34	23-12-2025	13:52	2:18	0.001533	REPLACEMET OF HT BUSHING ROD
1219	23-12-2025	Part of : JAIN PUR VILLAGE	5	Other Outage	Planned Outage	23-12-2025	11:37	23-12-2025	13:53	2:16	0.001511	REPLACEMET OF HT BUSHING ROD
1220	23-12-2025	Part of : NEHA COLONY NEW GOPAL NAGAR,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	321	Other Outage	Planned Outage	23-12-2025	11:33	23-12-2025	13:53	2:20	0.001556	REPLACEMET OF HT BUSHING ROD
1221	23-12-2025	Part of : SHYAM ENCAVE NAJAFGARH	314	Other Outage	Planned Outage	23-12-2025	10:31	23-12-2025	13:06	2:35	0.002153	REPLACEMENT OF LT BUSHING ROD
1222	24-12-2025	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE	1897	Other Outage	Unplanned Outage	24-12-2025	06:07	24-12-2025	06:51	0:44	0.000428	CABLE FAULT
1223	24-12-2025	Part of : ISSAPUR VILLAGE,	267	Other Outage	Planned Outage	24-12-2025	15:21	24-12-2025	16:44	1:23	0.000922	MAINTENANCE OF TRANSFORMER
1224	24-12-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE,	993	Other Outage	Planned Outage	24-12-2025	12:01	24-12-2025	14:30	2:29	0.001656	MAINTENANCE OF TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1225	24-12-2025	Part of : SUREHRA VILLAGE,	13	Other Outage	Planned Outage	24-12-2025	11:02	24-12-2025	14:00	2:58	0.001978	MAINTENANCE OF TRANSFORMER
1226	24-12-2025	Part of : GOPAL NAGAR WEST PART 1	445	Other Outage	Planned Outage	24-12-2025	11:30	24-12-2025	13:59	2:29	0.001656	MAINTENANCE OF TRANSFORMER
1227	26-12-2025	Part of : KHARKHARI JATMAL VILLAGE	313	Other Outage	Planned Outage	26-12-2025	16:04	26-12-2025	17:07	1:03	0.000175	REPLACEMENT OF HT BUSHING ROD
1228	26-12-2025	Part of : BADHOSRA	6	Other Outage	Planned Outage	26-12-2025	16:02	26-12-2025	17:07	1:05	0.000181	REPLACEMENT OF HT BUSHING ROD
1229	26-12-2025	Part of : UJWA VILLAGE	466	Other Outage	Planned Outage	26-12-2025	14:18	26-12-2025	16:05	1:47	0.000297	REPLACEMENT OF HT BUSHING ROD
1230	26-12-2025	Part of : MANDHELA KHURD VILLAGE	4	Other Outage	Planned Outage	26-12-2025	13:00	26-12-2025	14:59	1:59	0.000331	REPLACEMENT OF HT BUSHING ROD
1231	26-12-2025	Part of : JANTA VIHAR HAIBUTPUR	268	Other Outage	Planned Outage	26-12-2025	12:29	26-12-2025	14:57	2:28	0.002056	REPLACEMENT OF HT BUSHING ROD
1232	27-12-2025	Part of : UJWA VILLAGE	526	Other Outage	Planned Outage	27-12-2025	15:23	27-12-2025	17:01	1:38	0.001361	REPLACEMET OF HT BUSHING ROD
1233	27-12-2025	Part of : PREM NAGAR GOPAL NAGAR,SHIV VIHAR COLONY,NAJAFGARH VILLAGE	446	Other Outage	Planned Outage	27-12-2025	14:08	27-12-2025	16:00	1:52	0.001556	REPLACEMET OF HT BUSHING ROD
1234	27-12-2025	Part of : GHALLBPUR VILLAGE	7	Other Outage	Planned Outage	27-12-2025	13:09	27-12-2025	16:05	2:56	0.002444	REPLACEMET OF HT BUSHING ROD
1235	29-12-2025	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE	1898	Other Outage	Unplanned Outage	29-12-2025	03:22	29-12-2025	03:57	0:35	0.000185	HT SYSTEM FAULT
1236	29-12-2025	Part of : ISSAPUR VILLAGE	267	Other Outage	Planned Outage	29-12-2025	15:25	29-12-2025	16:31	1:06	0.000917	REPLACEMENT OF LT BUSHING ROD
1237	29-12-2025	Part of : MALIKPUR ZER VILLAGE	401	Other Outage	Planned Outage	29-12-2025	15:26	29-12-2025	16:32	1:06	0.000917	REPLACEMENT OF LT BUSHING ROD
1238	29-12-2025	Part of : JHULIHULI VILLAGE	24	Other Outage	Planned Outage	29-12-2025	14:08	29-12-2025	15:57	1:49	0.001514	REPLACEMENT OF HT BUSHING ROD
1239	29-12-2025	Part of : GOPAL NAGAR	1	Other Outage	Planned Outage	29-12-2025	14:41	29-12-2025	16:20	1:39	0.001375	REPLACEMENT OF HT BUSHING ROD
1240	29-12-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	1053	Other Outage	Planned Outage	29-12-2025	13:48	29-12-2025	15:49	2:01	0.001681	REPLACEMENT OF HT BUSHING ROD
1241	29-12-2025	Part of : SHYAM ENCAVE NAJAFGARH	314	Other Outage	Planned Outage	29-12-2025	12:12	29-12-2025	14:44	2:32	0.002111	REPLACEMENT OF HT BUSHING ROD
1242	30-12-2025	Part of : SWG AT AIR FORCE STATION DHANSA	0	Other Outage	Unplanned Outage	30-12-2025	05:31	30-12-2025	06:19	0:48	0.000107	CABLE FAULT
1243	30-12-2025	Part of : KHARKHARI JATMAL VILLAGE	252	Other Outage	Planned Outage	30-12-2025	16:03	30-12-2025	16:53	0:50	0.000556	REPLACEMENT OF HT BUSHING ROD
1244	30-12-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	716	Other Outage	Planned Outage	30-12-2025	16:05	30-12-2025	16:54	0:49	0.000544	REPLACEMENT OF HT BUSHING ROD
1245	30-12-2025	Part of : JAIN PUR VILLAGE	2	Other Outage	Planned Outage	30-12-2025	14:00	30-12-2025	16:25	2:25	0.001611	REPLACEMENT OF HT BUSHING ROD
1246	30-12-2025	Part of : BADHOSRA	315	Other Outage	Planned Outage	30-12-2025	13:35	30-12-2025	16:03	2:28	0.001644	REPLACEMENT OF HT BUSHING ROD
1247	30-12-2025	Part of : MANDHELA KALAN VILLAGE	481	Other Outage	Planned Outage	30-12-2025	13:24	30-12-2025	16:02	2:38	0.001756	REPLACEMENT OF HT BUSHING ROD
1248	31-12-2025	Part of : PREM NAGAR GOPAL NAGAR,SHIV VIHAR COLONY GOPAL NAGAR,NAJAFGARH VILLAGE	445	Other Outage	Planned Outage	31-12-2025	15:28	31-12-2025	16:25	0:57	0.000633	REPLACEMET OF HT BUSHING ROD
1249	31-12-2025	Part of : BADHOSRA	23	Other Outage	Planned Outage	31-12-2025	15:27	31-12-2025	16:24	0:57	0.000633	REPLACEMET OF HT BUSHING ROD
1250	31-12-2025	Part of : JAFARPUR KALAN VILLAGE	466	Other Outage	Planned Outage	31-12-2025	11:15	31-12-2025	12:47	1:32	0.001022	REPLACEMET OF HT BUSHING ROD
1251	31-12-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	2346	Other Outage	Planned Outage	31-12-2025	12:05	31-12-2025	14:48	2:43	0.001811	REPLACEMET OF HT BUSHING ROD
1252	01-12-2025	Part of : BLOCK 5 SUBHASH NAGAR	622	Other Outage	Planned Outage	01-12-2025	11:21	01-12-2025	15:19	3:58	0.001983	DT REPLACEMENT
1253	01-12-2025	Part of : BLOCK C1 JANAK PURI	272	Other Outage	Planned Outage	01-12-2025	11:41	01-12-2025	14:09	2:28	0.000822	CONDUCTOR REPLACEMENT PER SPAN,GUARD WIRE LACS INSTALLTION PER SPAN
1254	01-12-2025	Part of : BLOCK WZ RC BASTI NANGAL RAYA JANAK PURI	845	Other Outage	Planned Outage	01-12-2025	11:54	01-12-2025	14:13	2:19	0.000772	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1255	01-12-2025	Part of : PRESS COLONY MAYAPURI	40	Other Outage	Planned Outage	01-12-2025	11:19	01-12-2025	13:47	2:28	0.000822	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1256	01-12-2025	Part of : BLOCK V RAJOURI GARDEN	243	Other Outage	Planned Outage	01-12-2025	10:58	01-12-2025	15:00	4:02	0.001344	3PH DB REVAMPING,CONDUCTOR REPLACEMENT PER SPAN
1257	01-12-2025	Part of : BLOCK S RAJOURI GARDEN	421	Other Outage	Planned Outage	01-12-2025	11:28	01-12-2025	13:56	2:28	0.000822	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1258	01-12-2025	Part of : BLOCK A-1 JANAK PURI	276	Other Outage	Planned Outage	01-12-2025	11:52	01-12-2025	14:20	2:28	0.000822	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1259	02-12-2025	Part of : BLOCK C2 JANAK PURI	331	Other Outage	Planned Outage	02-12-2025	14:53	02-12-2025	16:00	1:07	0.000000	LT CIRCUIT MAINTENANCE
1260	02-12-2025	Part of : BLOCK A-1/ A PART B JANAK PURI	196	Other Outage	Planned Outage	02-12-2025	13:15	02-12-2025	15:06	1:51	0.000000	LT CIRCUIT MAINTENANCE
1261	02-12-2025	Part of : BLOCK 40 ASHOK NAGAR	1542	Other Outage	Planned Outage	02-12-2025	11:01	02-12-2025	15:58	4:57	0.002888	DT REPLACEMENT
1262	02-12-2025	Part of : BLOCK C1 JANAK PURI	400	Other Outage	Planned Outage	02-12-2025	11:16	02-12-2025	14:11	2:55	0.000000	LT CIRCUIT MAINTENANCE
1263	02-12-2025	Part of : BLOCK C3 RAJOURI GARDEN	173	Other Outage	Planned Outage	02-12-2025	10:56	02-12-2025	14:28	3:32	0.000000	LT CIRCUIT MAINTENANCE
1264	02-12-2025	Part of : POCKET D 1 JANAK PURI	535	Other Outage	Planned Outage	02-12-2025	11:16	02-12-2025	14:29	3:13	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1265	02-12-2025	Part of : PRESS COLONY MAYAPURI	1	Other Outage	Planned Outage	02-12-2025	11:03	02-12-2025	13:58	2:55	0.000000	LT CIRCUIT MAINTENANCE
1266	03-12-2025	Part of : BLOCK EC MAYA ENCLAVE HARI NAGAR	460	Other Outage	Planned Outage	03-12-2025	12:03	03-12-2025	16:11	4:08	0.002067	DT REPLACEMENT
1267	03-12-2025	Part of : BLOCK C 2C JANAK PURI	123	Other Outage	Planned Outage	03-12-2025	12:46	03-12-2025	15:09	2:23	0.001788	REPLACEMENT OF LT BUSHING ROD
1268	03-12-2025	Part of : BLOCK G RAJOURI GARDEN	216	Other Outage	Planned Outage	03-12-2025	10:56	03-12-2025	13:45	2:49	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1269	03-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE I	64	Other Outage	Planned Outage	03-12-2025	11:35	03-12-2025	14:06	2:31	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1270	03-12-2025	Part of : POCKET D 1C LAJWANTI GARDEN JANAK PURI	380	Other Outage	Planned Outage	03-12-2025	11:36	03-12-2025	14:25	2:49	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1271	03-12-2025	Part of : BLOCK A-1 JANAK PURI	271	Other Outage	Planned Outage	03-12-2025	12:01	03-12-2025	14:50	2:49	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1272	04-12-2025	Part of : BLOCK 50 ASHOK NAGAR	583	Other Outage	Planned Outage	04-12-2025	12:31	04-12-2025	14:17	1:46	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1273	04-12-2025	Part of : BLOCK C2 JANAK PURI	169	Other Outage	Planned Outage	04-12-2025	11:41	04-12-2025	14:14	2:33	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1274	04-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	39	Other Outage	Planned Outage	04-12-2025	11:37	04-12-2025	14:20	2:43	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1275	04-12-2025	Part of : BLOCK A 2B ASALATPUR VILLAGE JANAK PURI	575	Other Outage	Planned Outage	04-12-2025	11:56	04-12-2025	14:16	2:20	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1276	04-12-2025	Part of : BLOCK A KARAN MARKET NANGAL RAYA JANAK PURI	205	Other Outage	Planned Outage	04-12-2025	11:40	04-12-2025	14:21	2:41	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1277	05-12-2025	Part of : POSSANGIPUR VILLAGE JANAK PURI	404	Other Outage	Planned Outage	05-12-2025	12:26	05-12-2025	16:15	3:49	0.001908	DT REPLACEMENT
1278	05-12-2025	Part of : BLOCK B PATEL BLOCK RAGHU NAGAR DABRI	959	Other Outage	Planned Outage	05-12-2025	12:07	05-12-2025	14:36	2:29	0.000828	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1279	05-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	31	Other Outage	Planned Outage	05-12-2025	12:06	05-12-2025	14:16	2:10	0.000722	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1280	05-12-2025	Part of : BLOCK C 1A JANAK PURI	197	Other Outage	Planned Outage	05-12-2025	11:33	05-12-2025	14:02	2:29	0.000828	REPLACEMENT OF GAS KIT AND OIL SEAL
1281	05-12-2025	Part of : BLOCK 5 SUBHASH NAGAR	549	Other Outage	Planned Outage	05-12-2025	11:18	05-12-2025	13:49	2:31	0.000839	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1282	06-12-2025	Part of : D-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-2	211	Other Outage	Planned Outage	06-12-2025	13:14	06-12-2025	14:13	0:59	0.000000	LT CIRCUIT MAINTENANCE WORK
1283	06-12-2025	Part of : B-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-1	44	Other Outage	Planned Outage	06-12-2025	11:27	06-12-2025	14:36	3:09	0.000000	LT CIRCUIT MAINTENANCE WORK
1284	06-12-2025	Part of : BLOCK 4 SUBHASH NAGAR	549	Other Outage	Planned Outage	06-12-2025	10:54	06-12-2025	14:08	3:14	0.000000	LT CIRCUIT MAINTENANCE WORK
1285	06-12-2025	Part of : A 2B-BLOCK ASALATPUR VILLAGE JANAK PURI	551	Other Outage	Planned Outage	06-12-2025	11:52	06-12-2025	14:07	2:15	0.000000	LT CIRCUIT MAINTENANCE WORK
1286	07-12-2025	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE II	46	Other Outage	Planned Outage	07-12-2025	12:05	07-12-2025	17:27	5:22	0.002683	DT REPLACEMENT
1287	08-12-2025	Part of : BLOCK B FATEH NAGAR JANAK PURI,	246	Other Outage	Planned Outage	08-12-2025	12:43	08-12-2025	14:14	1:31	0.000758	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1288	08-12-2025	Part of : BLOCK WZ LAJWANTI GARDEN JANAK PURI,	558	Other Outage	Planned Outage	08-12-2025	12:18	08-12-2025	13:30	1:12	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1289	08-12-2025	Part of : MEENAKSHI GARDEN ASHOK NAGAR,	392	Other Outage	Planned Outage	08-12-2025	11:05	08-12-2025	13:53	2:48	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1290	08-12-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI,	52	Other Outage	Planned Outage	08-12-2025	11:27	08-12-2025	14:16	2:49	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1291	08-12-2025	Part of : NARANG COLONY CHANDAR NAGAR JANAK PURI,	175	Other Outage	Planned Outage	08-12-2025	11:55	08-12-2025	14:42	2:47	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1292	08-12-2025	Part of : BLOCK C2 JANAK PURI,	330	Other Outage	Planned Outage	08-12-2025	11:20	08-12-2025	13:53	2:33	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1293	09-12-2025	Part of : DISTRICT CENTRE JANAK PURI	879	Other Outage	Unplanned Outage	09-12-2025	17:25	09-12-2025	18:51	1:26	0.000908	HT SYSTEM FAULT
1294	09-12-2025	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	758	Other Outage	Unplanned Outage	09-12-2025	01:10	09-12-2025	02:13	1:03	0.000630	CABLE FAULT
1295	09-12-2025	Part of : BLOCK 5 SUBHASH NAGAR	622	Other Outage	Planned Outage	09-12-2025	12:25	09-12-2025	15:51	3:26	0.001717	DT REPLACEMENT
1296	09-12-2025	Part of : BLOCK 4 SUBHASH NAGAR	714	Other Outage	Planned Outage	09-12-2025	10:58	09-12-2025	14:09	3:11	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1297	09-12-2025	Part of : NARANG COLONY CHANDAR NAGAR JANAK PURI	274	Other Outage	Planned Outage	09-12-2025	11:31	09-12-2025	14:27	2:56	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1298	09-12-2025	Part of : BLOCK C 2B JANAK PURI	380	Other Outage	Planned Outage	09-12-2025	11:24	09-12-2025	13:57	2:33	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1299	09-12-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	300	Other Outage	Planned Outage	09-12-2025	11:39	09-12-2025	14:35	2:56	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
1300	09-12-2025	Part of : BLOCK WZ LAJWANTI GARDEN JANAK PURI	723	Other Outage	Planned Outage	09-12-2025	11:31	09-12-2025	14:35	3:04	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1301	10-12-2025	Part of : POCKET D2A NANGAL RAYA JANAK PURI	447	Other Outage	Planned Outage	10-12-2025	11:03	10-12-2025	13:31	2:28	0.000822	LT CIRCUIT MAINTENANCE
1302	10-12-2025	Part of : J-BLOCK RAJOURI GARDEN	317	Other Outage	Planned Outage	10-12-2025	11:00	10-12-2025	13:28	2:28	0.000822	LT CIRCUIT MAINTENANCE
1303	10-12-2025	Part of : B-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-1	128	Other Outage	Planned Outage	10-12-2025	11:34	10-12-2025	14:03	2:29	0.000828	LT CIRCUIT MAINTENANCE
1304	11-12-2025	Part of : BLOCK A & E MAYAPURI INDUSTRIAL AREA PHASE II	253	Other Outage	Unplanned Outage	11-12-2025	23:10	11-12-2025	23:52	0:42	0.000012	CABLE FAULT
1305	11-12-2025	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI	556	Other Outage	Planned Outage	11-12-2025	11:20	11-12-2025	13:56	2:36	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1306	11-12-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I	103	Other Outage	Planned Outage	11-12-2025	11:13	11-12-2025	13:37	2:24	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1307	11-12-2025	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN	1062	Other Outage	Planned Outage	11-12-2025	11:41	11-12-2025	14:57	3:16	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1308	11-12-2025	Part of : BLOCK V RAJOURI GARDEN	243	Other Outage	Planned Outage	11-12-2025	11:24	11-12-2025	14:37	3:13	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1309	11-12-2025	Part of : BLOCK B1 JANAK PURI	194	Other Outage	Planned Outage	11-12-2025	11:57	11-12-2025	14:33	2:36	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1310	12-12-2025	Part of : POCKET D 1A JANAK PURI,BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	776	Other Outage	Unplanned Outage	12-12-2025	22:43	12-12-2025	23:36	0:53	0.000780	CABLE FAULT

Sr. No.	Date	Area Affected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1311	12-12-2025	Part of : MANAK VIHAR TIHAR VILLAGE,BLOCK J BERI WALA BAGH HARI NAGAR,	2381	Other Outage	Planned Outage	12-12-2025	15:01	12-12-2025	15:47	0:46	0.000128	REPLACEMET OF FAULTY END BOX
1312	12-12-2025	Part of : BLOCK WZ NANGAL RAYA JANAK PURI,	782	Other Outage	Planned Outage	12-12-2025	14:35	12-12-2025	16:52	2:17	0.000000	3PH DB REPLACEMENT
1313	12-12-2025	Part of : BLOCK WZ PADAM BASTI NANGAL RAYA JANAK PURI,	508	Other Outage	Planned Outage	12-12-2025	11:43	12-12-2025	14:13	2:30	0.000000	1PH DB REVAMPING,3PH DB REVAMPING
1314	12-12-2025	Part of : BLOCK E RAJOURI GARDEN,	239	Other Outage	Planned Outage	12-12-2025	11:12	12-12-2025	14:05	2:53	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1315	12-12-2025	Part of : BLOCK C 2D JANAK PURI,	731	Other Outage	Planned Outage	12-12-2025	11:42	12-12-2025	14:05	2:23	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1316	12-12-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI,	185	Other Outage	Planned Outage	12-12-2025	11:14	12-12-2025	14:12	2:58	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER
1317	12-12-2025	Part of : BLOCK B 1A JANAK PURI,	305	Other Outage	Planned Outage	12-12-2025	11:10	12-12-2025	14:11	3:01	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1318	13-12-2025	Part of : CHHOTI SUBJI MANDI JANAK PURI	417	Other Outage	Unplanned Outage	13-12-2025	15:10	13-12-2025	17:21	2:11	0.000364	REPAIR OF DAMAGED WIRE ON POLES
1319	13-12-2025	Part of : TRANSPORT DEPTT HARINAGAR, PRATAP NAGAR	1	Other Outage	Planned Outage	13-12-2025	16:12	13-12-2025	17:22	1:10	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1320	13-12-2025	Part of : TIHAR CENTRAL JAIL JANAK PURI	67	Other Outage	Planned Outage	13-12-2025	12:44	13-12-2025	14:31	1:47	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1321	13-12-2025	Part of : BLOCK C 5B JANAK PURI	494	Other Outage	Planned Outage	13-12-2025	13:27	13-12-2025	16:15	2:48	0.001400	REPLACEMENT OF LT BUSHING ROD
1322	13-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	85	Other Outage	Planned Outage	13-12-2025	11:57	13-12-2025	14:32	2:35	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1323	14-12-2025	Part of : BLOCK C1 JANAK PURI	541	Other Outage	Unplanned Outage	14-12-2025	11:25	14-12-2025	12:08	0:43	0.000693	TREE TOUCHING
1324	14-12-2025	Part of : J-BLOCK BERI WALA BAGH HARI NAGAR	784	Other Outage	Planned Outage	14-12-2025	14:50	14-12-2025	16:54	2:04	0.001033	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1325	15-12-2025	Part of : RAJOURI GARDEN, JANAK PURI	0	Other Outage	Unplanned Outage	15-12-2025	13:03	15-12-2025	13:59	0:56	0.000000	CABLE FAULT
1326	15-12-2025	Part of : BLOCK J BERI WALA BAGH HARI NAGAR	784	Other Outage	Planned Outage	15-12-2025	13:15	15-12-2025	16:06	2:51	0.001425	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1327	15-12-2025	Part of : BLOCK C4B JANAK PURI	535	Other Outage	Planned Outage	15-12-2025	12:06	15-12-2025	14:15	2:09	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1328	15-12-2025	Part of : ADITI APARTMENTS JANAK PURI	349	Other Outage	Planned Outage	15-12-2025	11:46	15-12-2025	14:35	2:49	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1329	15-12-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I	107	Other Outage	Planned Outage	15-12-2025	11:14	15-12-2025	14:01	2:47	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1330	15-12-2025	Part of : BLOCK A-1 & A PART B JANAK PURI	196	Other Outage	Planned Outage	15-12-2025	11:52	15-12-2025	14:13	2:21	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1331	15-12-2025	Part of : BLOCK G RAJOURI GARDEN	247	Other Outage	Planned Outage	15-12-2025	11:05	15-12-2025	13:54	2:49	0.000000	REPLACEMENT OF LT BUSHING ROD
1332	16-12-2025	Part of : MEENAKSHI GARDEN ASHOK NAGAR,BLOCK 1 SUBHASH NAGAR,BLOCK 1 ASHOK NAGAR	2771	Other Outage	Planned Outage	16-12-2025	15:45	16-12-2025	16:10	0:25	0.000069	MAINTENANCE OF RMU
1333	16-12-2025	Part of : TIHAR CENTRAL JAIL JANAK PURI,	12	Other Outage	Planned Outage	16-12-2025	11:36	16-12-2025	12:26	0:50	0.000000	MAINTENANCE OF LT CIRCUIT
1334	16-12-2025	Part of : C-4 BLOCK JANAK PURI,	311	Other Outage	Planned Outage	16-12-2025	15:00	16-12-2025	16:11	1:11	0.000000	MAINTENANCE OF LT TRANSFORMER
1335	16-12-2025	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN SAGARPUR,	665	Other Outage	Planned Outage	16-12-2025	13:40	16-12-2025	15:04	1:24	0.000000	MAINTENANCE OF LT CIRCUIT
1336	16-12-2025	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI,	1209	Other Outage	Planned Outage	16-12-2025	12:46	16-12-2025	15:45	2:59	0.003232	MAINTENANCE OF TRANSFORMER
1337	16-12-2025	Part of : BLOCK Z RAJOURI GARDEN EXTENSION RAJOURI GARDEN,	187	Other Outage	Planned Outage	16-12-2025	11:12	16-12-2025	13:58	2:46	0.000000	MAINTENANCE OF LT CIRCUIT
1338	16-12-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI,	34	Other Outage	Planned Outage	16-12-2025	12:22	16-12-2025	14:24	2:02	0.000000	MAINTENANCE OF LT TRANSFORMER
1339	17-12-2025	Part of : BLOCK A 2B ASALATPUR VILLAGE JANAK PURI	575	Other Outage	Planned Outage	17-12-2025	14:38	17-12-2025	16:20	1:42	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1340	17-12-2025	Part of : BLOCK RZ VASHISHT PARK SAGARPUR	857	Other Outage	Planned Outage	17-12-2025	11:41	17-12-2025	15:11	3:30	0.000000	DB REVAMPING,DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1341	17-12-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	5	Other Outage	Planned Outage	17-12-2025	11:39	17-12-2025	14:34	2:55	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
1342	17-12-2025	Part of : BLOCK C1 RAJOURI GARDEN	133	Other Outage	Planned Outage	17-12-2025	11:40	17-12-2025	15:12	3:32	0.000000	DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1343	17-12-2025	Part of : BLOCK C 4D JANAK PURI	322	Other Outage	Planned Outage	17-12-2025	11:41	17-12-2025	14:35	2:54	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1344	18-12-2025	Part of : POCKET J-C HARI ENCLAVE HARI NAGAR	1244	Other Outage	Unplanned Outage	18-12-2025	11:53	18-12-2025	12:12	0:19	0.000106	REPAIRING OF RMU/FAULT IN RMU
1345	18-12-2025	Part of : C 4F-BLOCK JANAK PURI	641	Other Outage	Planned Outage	18-12-2025	12:40	18-12-2025	14:19	1:39	0.000275	REPLACEMENT OF GAS KIT AND OIL SEAL
1346	18-12-2025	Part of : POSSANGIPUR VILLAGE JANAK PURI	409	Other Outage	Planned Outage	18-12-2025	11:43	18-12-2025	15:33	3:50	0.001917	DT REPLACEMENT
1347	18-12-2025	Part of : J-BLOCK RAJOURI GARDEN EXTENSION	421	Other Outage	Planned Outage	18-12-2025	11:06	18-12-2025	13:40	2:34	0.000856	LT CIRCUIT MAINTENANCE
1348	18-12-2025	Part of : A 3-BLOCK ASALATPUR VILLAGE JANAK PURI	422	Other Outage	Planned Outage	18-12-2025	11:44	18-12-2025	14:37	2:53	0.000961	LT CIRCUIT MAINTENANCE
1349	18-12-2025	Part of : POCKET D 1A JANAK PURI	6	Other Outage	Planned Outage	18-12-2025	11:11	18-12-2025	13:23	2:12	0.000733	LT CIRCUIT MAINTENANCE
1350	18-12-2025	Part of : A-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-2	80	Other Outage	Planned Outage	18-12-2025	11:07	18-12-2025	13:44	2:37	0.000872	LT CIRCUIT MAINTENANCE
1351	19-12-2025	Part of : POCKET D 1A JANAK PURI	25	Other Outage	Planned Outage	19-12-2025	11:39	19-12-2025	12:36	0:57	0.000317	3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1352	19-12-2025	Part of : BLOCK C4F JANAK PURI	527	Other Outage	Planned Outage	19-12-2025	11:38	19-12-2025	13:32	1:54	0.000633	REPLACEMENT OF GAS KIT AND OIL SEAL
1353	19-12-2025	Part of : BLOCK A 3 ASALATPUR VILLAGE JANAK PURI	160	Other Outage	Planned Outage	19-12-2025	11:41	19-12-2025	14:54	3:13	0.001876	DT REPLACEMENT
1354	19-12-2025	Part of : BLOCK C NANAK PURA HARI NAGAR	573	Other Outage	Planned Outage	19-12-2025	11:33	19-12-2025	14:24	2:51	0.000950	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1355	19-12-2025	Part of : BLOCK D RAJOURI GARDEN	290	Other Outage	Planned Outage	19-12-2025	11:09	19-12-2025	13:39	2:30	0.000833	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1356	19-12-2025	Part of : BLOCK A 2B ASALATPUR VILLAGE JANAK PURI	551	Other Outage	Planned Outage	19-12-2025	11:08	19-12-2025	13:37	2:29	0.000828	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1357	19-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II	83	Other Outage	Planned Outage	19-12-2025	11:35	19-12-2025	14:06	2:31	0.000839	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
1358	20-12-2025	Part of : BLOCK 5 SUBHASH NAGAR,	620	Other Outage	Planned Outage	20-12-2025	13:21	20-12-2025	16:12	2:51	0.001425	MAINTENANCE OF TRANSFORMER
1359	20-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	549	Other Outage	Planned Outage	20-12-2025	13:37	20-12-2025	15:56	2:19	0.000000	MAINTENANCE OF LT CIRCUIT
1360	20-12-2025	Part of : POCKET D 1A JANAK PURI,	4	Other Outage	Planned Outage	20-12-2025	11:32	20-12-2025	13:40	2:08	0.000000	MAINTENANCE OF LT CIRCUIT
1361	20-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	120	Other Outage	Planned Outage	20-12-2025	11:04	20-12-2025	13:39	2:35	0.000000	MAINTENANCE OF LT TRANSFORMER
1362	20-12-2025	Part of : NARANG COLONY CHANDAR NAGAR JANAK PURI,	175	Other Outage	Planned Outage	20-12-2025	12:11	20-12-2025	14:51	2:40	0.000000	MAINTENANCE OF LT TRANSFORMER
1363	20-12-2025	Part of : BLOCK J 13 RAJOURI GARDEN,	185	Other Outage	Planned Outage	20-12-2025	11:14	20-12-2025	14:06	2:52	0.000000	MAINTENANCE OF LT CIRCUIT
1364	21-12-2025	Part of : BLOCK C NANAK PURA HARI NAGAR	573	Other Outage	Planned Outage	21-12-2025	15:00	21-12-2025	16:40	1:40	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1365	21-12-2025	Part of : BLOCK 40 ASHOK NAGAR	1567	Other Outage	Planned Outage	21-12-2025	12:02	21-12-2025	16:40	4:38	0.002317	DT REPLACEMENT
1366	22-12-2025	Part of : NARANG COLONY CHANDAR NAGAR JANAK PURI	274	Other Outage	Planned Outage	22-12-2025	11:37	22-12-2025	13:53	2:16	0.000756	LT CIRCUIT MAINTENANCE WORK
1367	22-12-2025	Part of : C 4H-BLOCK JANAK PURI	227	Other Outage	Planned Outage	22-12-2025	11:34	22-12-2025	14:05	2:31	0.000839	LT CIRCUIT MAINTENANCE WORK
1368	22-12-2025	Part of : J 13-BLOCK RAJOURI GARDEN	282	Other Outage	Planned Outage	22-12-2025	11:18	22-12-2025	13:49	2:31	0.000839	LT CIRCUIT MAINTENANCE WORK
1369	22-12-2025	Part of : F C-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-2	54	Other Outage	Planned Outage	22-12-2025	11:20	22-12-2025	13:51	2:31	0.000839	LT CIRCUIT MAINTENANCE WORK
1370	22-12-2025	Part of : NANGAL VILLAGE DELHI CANTONMENT	630	Other Outage	Planned Outage	22-12-2025	11:52	22-12-2025	14:24	2:32	0.000844	LT CIRCUIT MAINTENANCE WORK
1371	23-12-2025	Part of : NARANG COLONY JANAK PURI, BLOCK A 3 ASALATPUR VILLAGE, BLOCK A 4C P AND T COLONY JANAK PURI, DJB SPS JANAK PURI (HTC)	758	Other Outage	Unplanned Outage	23-12-2025	23:01	24-12-2025	00:50	1:49	0.000515	FAULT IN HT CONSUMER PANEL (DJB BPS)
1372	23-12-2025	Part of : BLOCK C2 JANAK PURI	168	Other Outage	Planned Outage	23-12-2025	12:04	23-12-2025	13:22	1:18	0.000433	REPLACEMET OF HT/LT CLEATS
1373	23-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II	8	Other Outage	Planned Outage	23-12-2025	12:21	23-12-2025	14:19	1:58	0.000000	MEASUREMET OF INSULATION RESISTANCE,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1374	23-12-2025	Part of : BLOCK RZ SAGARPUR	261	Other Outage	Planned Outage	23-12-2025	12:02	23-12-2025	14:53	2:51	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1375	24-12-2025	Part of : BLOCK C3 JANAK PURI,	169	Other Outage	Planned Outage	24-12-2025	12:00	24-12-2025	13:48	1:48	0.000000	MAINTENANCE OF LT TRANSFORMER
1376	24-12-2025	Part of : BLOCK F MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	525	Other Outage	Planned Outage	24-12-2025	11:14	24-12-2025	13:39	2:25	0.000000	MAINTENANCE OF LT TRANSFORMER
1377	24-12-2025	Part of : BLOCK B1 JANAK PURI,	194	Other Outage	Planned Outage	24-12-2025	10:58	24-12-2025	13:19	2:21	0.000000	MAINTENANCE OF LT TRANSFORMER
1378	24-12-2025	Part of : BLOCK E RAGHU NAGAR DABRI,	673	Other Outage	Planned Outage	24-12-2025	12:23	24-12-2025	14:58	2:35	0.000000	MAINTENANCE OF LT CIRCUIT
1379	25-12-2025	Part of : Block C1 Janak Puri	541	Other Outage	Unplanned Outage	25-12-2025	00:01	25-12-2025	01:21	1:20	0.001378	CABLE FAULT
1380	26-12-2025	Part of : BLOCK J RAJOURI GARDEN	123	Other Outage	Planned Outage	26-12-2025	15:27	26-12-2025	16:25	0:58	0.000322	LT CIRCUIT MAINTENANCE
1381	26-12-2025	Part of : BLOCK A 3 ASALATPUR VILLAGE JANAK PURI	229	Other Outage	Planned Outage	26-12-2025	13:32	26-12-2025	16:53	3:21	0.001954	DT REPLACEMENT
1382	26-12-2025	Part of : BLOCK B 1A JANAK PURI	305	Other Outage	Planned Outage	26-12-2025	12:23	26-12-2025	14:25	2:02	0.000678	LT CIRCUIT MAINTENANCE
1383	26-12-2025	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE-2	113	Other Outage	Planned Outage	26-12-2025	11:17	26-12-2025	13:48	2:31	0.000839	LT CIRCUIT MAINTENANCE
1384	26-12-2025	Part of : BLOCK J RAJOURI GARDEN EXTENSION	269	Other Outage	Planned Outage	26-12-2025	11:07	26-12-2025	13:36	2:29	0.000828	LT CIRCUIT MAINTENANCE
1385	26-12-2025	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST	449	Other Outage	Planned Outage	26-12-2025	11:23	26-12-2025	14:01	2:38	0.000878	LT CIRCUIT MAINTENANCE
1386	26-12-2025	Part of : BLOCK C 6A JANAK PURI	169	Other Outage	Planned Outage	26-12-2025	11:58	26-12-2025	14:00	2:02	0.000678	LT CIRCUIT MAINTENANCE
1387	26-12-2025	Part of : BLOCK J 8 RAJOURI GARDEN EXTENSION	200	Other Outage	Planned Outage	26-12-2025	10:46	26-12-2025	13:28	2:42	0.000900	LT CIRCUIT MAINTENANCE
1388	27-12-2025	Part of : POSSANGIPUR VILLAGE JANAK PURI	409	Other Outage	Unplanned Outage	27-12-2025	12:05	27-12-2025	14:07	2:02	0.000339	TRANSFORMER REPLACEMENT
1389	27-12-2025	Part of : BLOCK A KARAN MARKET NANGAL RAYA JANAK PURI	928	Other Outage	Planned Outage	27-12-2025	12:58	27-12-2025	14:24	1:26	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1390	27-12-2025	Part of : BLOCK C2 JANAK PURI	223	Other Outage	Planned Outage	27-12-2025	12:09	27-12-2025	14:03	1:54	0.000000	REPLACEMENT OF LT BUSHING ROD
1391	27-12-2025	Part of : BLOCK A-1 JANAK PURI	276	Other Outage	Planned Outage	27-12-2025	12:15	27-12-2025	14:55	2:40	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1392	27-12-2025	Part of : BLOCK S MEENAKSHI GARDEN ASHOK NAGAR	198	Other Outage	Planned Outage	27-12-2025	11:09	27-12-2025	13:25	2:16	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1393	27-12-2025	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE II	129	Other Outage	Planned Outage	27-12-2025	11:13	27-12-2025	13:37	2:24	0.000000	MEASUREMET OF INSULATION RESISTANCE,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1394	27-12-2025	Part of : BLOCK J RAJOURI GARDEN	221	Other Outage	Planned Outage	27-12-2025	11:12	27-12-2025	13:24	2:12	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1395	28-12-2025	Part of : A 2B BLOCK ASALATPUR VILLAGE JANAK PURI,DISTRICT CENTRE JANAK PURI,BLOCK A-1 JANAK PURI	2057	Other Outage	Unplanned Outage	28-12-2025	07:52	28-12-2025	09:46	1:54	0.002280	CABLE FAULT
1396	29-12-2025	Part of : BLOCK 5 SUBHASH NAGAR	620	Other Outage	Planned Outage	29-12-2025	11:24	29-12-2025	14:54	3:30	0.001750	DT REPLACEMENT
1397	29-12-2025	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI,BLOCK C 5D JANAK PURI,BLOCK C 6A JANAK PURI	1681	Other Outage	Planned Outage	29-12-2025	11:24	29-12-2025	13:53	2:29	0.000828	REPLACEMENT OF GAS KIT AND OIL SEAL
1398	29-12-2025	Part of : ADITI APARTMENTS JANAK PURI	38	Other Outage	Planned Outage	29-12-2025	14:25	29-12-2025	16:25	2:00	0.000667	HRC FUSE/HRC BASE REPLACEMENT
1399	29-12-2025	Part of : BLOCK 4 SUBHASH NAGAR	599	Other Outage	Planned Outage	29-12-2025	11:07	29-12-2025	13:36	2:29	0.000828	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1400	29-12-2025	Part of : BLOCK A-1/ A PART B JANAK PURI	196	Other Outage	Planned Outage	29-12-2025	11:37	29-12-2025	13:58	2:21	0.000783	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
1401	29-12-2025	Part of : ADITI APARTMENTS JANAK PURI	425	Other Outage	Planned Outage	29-12-2025	11:10	29-12-2025	13:39	2:29	0.000828	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1402	29-12-2025	Part of : POCKET W MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	320	Other Outage	Planned Outage	29-12-2025	11:08	29-12-2025	13:37	2:29	0.000828	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1403	30-12-2025	Part of : A 1-BLOCK JANAK PURI	271	Other Outage	Planned Outage	30-12-2025	11:34	30-12-2025	13:19	1:45	0.000000	LT CIRCUIT MAINTENANCE WORK
1404	30-12-2025	Part of : NANGAL RAYA JANAK PURI	880	Other Outage	Planned Outage	30-12-2025	11:40	30-12-2025	15:27	3:47	0.000000	LT CIRCUIT MAINTENANCE WORK

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1405	30-12-2025	Part of : POCKET WS1 MAYAPURI INDUSTRIAL AREA PHASE-2	113	Other Outage	Planned Outage	30-12-2025	11:30	30-12-2025	14:50	3:20	0.000000	LT CIRCUIT MAINTENANCE WORK
1406	30-12-2025	Part of : J 13-BLOCK RAJOURI GARDEN	289	Other Outage	Planned Outage	30-12-2025	10:58	30-12-2025	14:27	3:29	0.000000	LT CIRCUIT MAINTENANCE WORK
1407	30-12-2025	Part of : TIHAR CENTRAL JAIL JANAK PURI	145	Other Outage	Planned Outage	30-12-2025	11:35	30-12-2025	14:01	2:26	0.000000	LT CIRCUIT MAINTENANCE WORK
1408	31-12-2025	Part of : BLOCK C 5D JANAK PURI	56	Other Outage	Planned Outage	31-12-2025	11:24	31-12-2025	13:46	2:22	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1409	31-12-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II	45	Other Outage	Planned Outage	31-12-2025	11:14	31-12-2025	13:40	2:26	0.000000	OIL TOP UP IN TRANSFORMER , REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1410	31-12-2025	Part of : BLOCK Z RAJOURI GARDEN EXTENSION RAJOURI GARDEN	4	Other Outage	Planned Outage	31-12-2025	11:23	31-12-2025	13:39	2:16	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1411	31-12-2025	Part of : BLOCK A 2B ASALATPUR VILLAGE JANAK PURI	575	Other Outage	Planned Outage	31-12-2025	11:49	31-12-2025	14:40	2:51	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
1412	31-12-2025	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN	663	Other Outage	Planned Outage	31-12-2025	11:31	31-12-2025	14:15	2:44	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1413	02-12-2025	Part of : LAXMI PARK COLONY & D-BLOCK KUNWAR SINGH NAGAR KAMARUDDIN NAGAR	3962	Other Outage	Unplanned Outage	02-12-2025	06:46	02-12-2025	07:37	0:51	0.000538	CABLE FAULT
1414	02-12-2025	Part of : RANHOLLA	621	Other Outage	Planned Outage	02-12-2025	11:13	02-12-2025	13:43	2:30	0.000833	REPLACEMET OF HT BUSHING ROD
1415	03-12-2025	Part of : JAI VIHAR KAMARUDDIN NAGAR	322	Other Outage	Planned Outage	03-12-2025	14:51	03-12-2025	16:46	1:55	0.000958	REPLACEMENT OF LT BUSHING ROD
1416	03-12-2025	Part of : BAKKARWALA VILLAGE,JJ COLONY BAKARWALA,MUNDKA INDUSTRIAL AREA	6194	Other Outage	Planned Outage	03-12-2025	13:19	03-12-2025	16:00	2:41	0.001342	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1417	03-12-2025	Part of : RAJENDRA PARK EXTENSION NANGLOI EXTENSION	962	Other Outage	Planned Outage	03-12-2025	11:11	03-12-2025	13:22	2:11	0.000728	REPLACEMENT OF LT BUSHING ROD
1418	04-12-2025	Part of : RAM NAGAR KAMARUDDIN NAGAR	568	Other Outage	Planned Outage	04-12-2025	11:00	04-12-2025	12:45	1:45	0.000583	REPLACEMENT OF LT BUSHING ROD
1419	04-12-2025	Part of : POCKET A LOKNAYAK PURAM BAKARWALA,MUNDKA INDUSTRIAL AREA MUNDKA	109	Other Outage	Planned Outage	04-12-2025	13:40	04-12-2025	16:05	2:25	0.002014	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1420	04-12-2025	Part of : TIKRI KALAN,NEELWAL VILLAGE	1414	Other Outage	Planned Outage	04-12-2025	12:42	04-12-2025	15:37	2:55	0.001944	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1421	04-12-2025	Part of : JOHAR VILLAGE NANGLOI EXTENSION NANGLOI	390	Other Outage	Planned Outage	04-12-2025	12:41	04-12-2025	14:51	2:10	0.001083	REPLACEMENT OF LT BUSHING ROD
1422	05-12-2025	Part of : TIKRI KALAN	341	Other Outage	Planned Outage	05-12-2025	11:36	05-12-2025	12:27	0:51	0.000283	CONDUCTOR REPLACEMENT PER SPAN
1423	05-12-2025	Part of : POCKET Y JJ COLONY 3 NANGLOI	770	Other Outage	Planned Outage	05-12-2025	12:05	05-12-2025	14:04	1:59	0.001322	REPLACEMET OF HT BUSHING ROD
1424	05-12-2025	Part of : TIKRI KALAN	1080	Other Outage	Planned Outage	05-12-2025	10:35	05-12-2025	12:48	2:13	0.000739	REPLACEMET OF HT BUSHING ROD
1425	05-12-2025	Part of : AMAR COLONY NANGLOI EXTENSION NANGLOI	718	Other Outage	Planned Outage	05-12-2025	11:02	05-12-2025	13:32	2:30	0.000833	REPLACEMENT OF LT BUSHING ROD
1426	06-12-2025	Part of : MUNDKA INDUSTRIAL AREA	8	Other Outage	Planned Outage	06-12-2025	11:03	06-12-2025	11:49	0:46	0.000256	REPLACEMENT OF GAS KIT AND OIL SEAL
1427	06-12-2025	Part of : TIKRI KALAN	881	Other Outage	Planned Outage	06-12-2025	13:01	06-12-2025	14:57	1:56	0.001128	REPLACEMENT OF GAS KIT AND OIL SEAL
1428	06-12-2025	Part of : MUNDKA INDUSTRIAL AREA	8	Other Outage	Planned Outage	06-12-2025	11:46	06-12-2025	13:05	1:19	0.000439	REPLACEMENT OF GAS KIT AND OIL SEAL
1429	06-12-2025	Part of : MUNDKA EXTENSION	9	Other Outage	Planned Outage	06-12-2025	12:00	06-12-2025	15:34	3:34	0.000892	REPLACEMENT OF HT BUSHING ROD
1430	07-12-2025	Part of : VEENA ENCLAVE MUNDKA,BLOCK C MUNDKA	189	Other Outage	Unplanned Outage	07-12-2025	10:57	07-12-2025	11:14	0:17	0.000000	REPLACEMENT OF RMU
1431	07-12-2025	Part of : WEST CABIN BLOCK MUNDKA	15	Other Outage	Planned Outage	07-12-2025	12:45	07-12-2025	16:17	3:32	0.001178	REPLACEMENT OF LT BUSHING ROD
1432	07-12-2025	Part of : MUNDKA INDUSTRIAL AREA	24	Other Outage	Planned Outage	07-12-2025	12:47	07-12-2025	16:16	3:29	0.001161	CONDUCTOR REPLACEMENT PER SPAN
1433	07-12-2025	Part of : WEST CABIN BLOCK MUNDKA	14	Other Outage	Planned Outage	07-12-2025	11:05	07-12-2025	13:56	2:51	0.004750	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1434	07-12-2025	Part of : BLOCK C TYAGI VIHAR MUNDKA,VEENA ENCLAVE,MUNDKA INDUSTRIAL AREA	3013	Other Outage	Planned Outage	07-12-2025	10:00	07-12-2025	12:50	2:50	0.002361	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1435	08-12-2025	Part of : BLOCK A JJ COLONY 2 NANGLOI,	732	Other Outage	Planned Outage	08-12-2025	11:58	08-12-2025	14:10	2:12	0.001100	REPLACEMENT OF GAS KIT AND OIL SEAL
1436	08-12-2025	Part of : SAVITA VIHAR MUNDKA,	479	Other Outage	Planned Outage	08-12-2025	12:01	08-12-2025	15:28	3:27	0.001725	REPLACEMENT OF GAS KIT AND OIL SEAL
1437	08-12-2025	Part of : TIKRI KALAN,	341	Other Outage	Planned Outage	08-12-2025	12:25	08-12-2025	15:30	3:05	0.000514	CONDUCTOR REPLACEMENT PER SPAN
1438	08-12-2025	Part of : BABA HARIDAS NAGAR TIKRI KALAN,	347	Other Outage	Planned Outage	08-12-2025	11:07	08-12-2025	13:53	2:46	0.000922	REPLACEMENT OF LT BUSHING ROD
1439	08-12-2025	Part of : BABA HARIDAS NAGAR TIKRI KALAN,	256	Other Outage	Planned Outage	08-12-2025	11:08	08-12-2025	13:47	2:39	0.000883	REPLACEMENT OF LT BUSHING ROD
1440	09-12-2025	Part of : RANHOLLA	241	Other Outage	Planned Outage	09-12-2025	14:14	09-12-2025	16:10	1:56	0.000644	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1441	09-12-2025	Part of : HIRAN KUDNA	110	Other Outage	Planned Outage	09-12-2025	11:55	09-12-2025	13:25	1:30	0.000750	REPLACEMENT OF GAS KIT AND OIL SEAL
1442	10-12-2025	Part of : TIKRI KALAN	1211	Other Outage	Planned Outage	10-12-2025	13:48	10-12-2025	15:30	1:42	0.000850	REPLACEMENT OF GAS KIT AND OIL SEAL
1443	10-12-2025	Part of : RATAN BAGH NANGLOI	1213	Other Outage	Planned Outage	10-12-2025	15:10	10-12-2025	17:28	2:18	0.001533	REPLACEMENT OF GAS KIT AND OIL SEAL
1444	10-12-2025	Part of : BANI AIR FORCE CAMP JAI VIHAR BAPROLA	747	Other Outage	Planned Outage	10-12-2025	11:14	10-12-2025	14:20	3:06	0.002067	REPLACEMENT OF HT BUSHING ROD
1445	11-12-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	1676	Other Outage	Planned Outage	11-12-2025	11:42	11-12-2025	12:49	1:07	0.000372	REPLACEMENT OF GAS KIT AND OIL SEAL
1446	11-12-2025	Part of : TILANGPUR KOTLA	1329	Other Outage	Planned Outage	11-12-2025	12:47	11-12-2025	14:34	1:47	0.000743	REPLACEMET OF HT BUSHING ROD
1447	11-12-2025	Part of : MUNDKA INDUSTRIAL AREA	7	Other Outage	Planned Outage	11-12-2025	15:08	11-12-2025	17:14	2:06	0.000700	REPLACEMENT OF GAS KIT AND OIL SEAL
1448	11-12-2025	Part of : NEELWAL VILLAGE	607	Other Outage	Planned Outage	11-12-2025	11:52	11-12-2025	14:21	2:29	0.000828	REPLACEMET OF HT BUSHING ROD
1449	11-12-2025	Part of : TIKRI KALAN,NEELWAL VILLAGE,NEW PVC MARKET TIKRI KALAN	2206	Other Outage	Planned Outage	11-12-2025	12:19	11-12-2025	14:54	2:35	0.002583	CONDUCTOR REPLACEMENT PER SPAN
1450	12-12-2025	Part of : JOHAR VILLAGE NANGLOI EXTENSION NANGLOI,	248	Other Outage	Planned Outage	12-12-2025	15:01	12-12-2025	16:22	1:21	0.000000	REPLACEMENT OF LT BUSHING ROD
1451	12-12-2025	Part of : BLOCK A NANGLOI EXTENSION NANGLOI,	936	Other Outage	Planned Outage	12-12-2025	13:40	12-12-2025	15:04	1:24	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1452	12-12-2025	Part of : TIKRI KALAN,	646	Other Outage	Planned Outage	12-12-2025	10:36	12-12-2025	13:20	2:44	0.000911	REPLACEMENT OF LT BUSHING ROD
1453	13-12-2025	Part of : NETAJI SUBHASH VIHAR MUNDKA,HIRAN KUDNA,MUNDKA INDUSTRIAL AREA MUNDKA,NEELWAL VILLAGE	1670	Other Outage	Unplanned Outage	13-12-2025	14:30	13-12-2025	16:05	1:35	0.000000	ATTENDING WEAK POINTS/HOT SPOT
1454	13-12-2025	Part of : TIKRI KALAN	340	Other Outage	Planned Outage	13-12-2025	12:10	13-12-2025	13:40	1:30	0.000250	LT AB SAGGING PER SPAN
1455	13-12-2025	Part of : HIRAN KUDNA	503	Other Outage	Planned Outage	13-12-2025	11:23	13-12-2025	14:00	2:37	0.001526	REPLACEMENT OF HT BUSHING ROD
1456	14-12-2025	Part of : MUNDKA EXTENSION	341	Other Outage	Planned Outage	14-12-2025	14:32	14-12-2025	16:49	2:17	0.000761	HT CONDUCTOR REPLACEMENT
1457	14-12-2025	Part of : VEENA ENCLAVE MUNDKA	222	Other Outage	Planned Outage	14-12-2025	12:40	14-12-2025	16:00	3:20	0.000556	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1458	14-12-2025	Part of : WEST CABIN BLOCK MUNDKA	561	Other Outage	Planned Outage	14-12-2025	11:49	14-12-2025	14:57	3:08	0.001044	REPLACEMENT OF HT BUSHING ROD
1459	14-12-2025	Part of : NETAJI SUBHASH VIHAR,HIRAN KUDNA,MUNDKA INDUSTRIAL AREA,NEELWAL VILLAGE	1695	Other Outage	Planned Outage	14-12-2025	10:31	14-12-2025	13:10	2:39	0.002208	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
1460	14-12-2025	Part of : MUNDKA INDUSTRIAL AREA,NETAJI SUBHASH VIHAR,HIRAN KUDNA	339	Other Outage	Planned Outage	14-12-2025	10:34	14-12-2025	13:11	2:37	0.004361	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL
1461	14-12-2025	Part of : C-BLOCK TYAGI VIHAR MUNDKA	15	Other Outage	Planned Outage	14-12-2025	10:40	14-12-2025	13:53	3:13	0.000536	LT CIRCUIT MAINTENANCE
1462	15-12-2025	Part of : MUNDKA EXTENSION,SAVITA VIHAR MUNDKA,SWARN PARK MUNDKA	1623	Other Outage	Unplanned Outage	15-12-2025	03:46	15-12-2025	04:38	0:52	0.000636	HVDS FAULT
1463	15-12-2025	Part of : MUNDKA INDUSTRIAL AREA	87	Other Outage	Planned Outage	15-12-2025	12:48	15-12-2025	13:55	1:07	0.000372	REPLACEMENT OF GAS KIT AND OIL SEAL
1464	15-12-2025	Part of : SAVITA VIHAR MUNDKA	481	Other Outage	Planned Outage	15-12-2025	12:07	15-12-2025	14:30	2:23	0.000794	REPLACEMENT OF GAS KIT AND OIL SEAL
1465	15-12-2025	Part of : TIKRI KALAN	340	Other Outage	Planned Outage	15-12-2025	12:11	15-12-2025	15:05	2:54	0.000967	SUB STATION CLEANING
1466	15-12-2025	Part of : POCKET C LOKNAYAK PURAM BAKARWALA	207	Other Outage	Planned Outage	15-12-2025	12:07	15-12-2025	14:33	2:26	0.001622	REPLACEMET OF HT BUSHING ROD
1467	15-12-2025	Part of : AAKASH VIHAR	858	Other Outage	Planned Outage	15-12-2025	11:19	15-12-2025	13:53	2:34	0.001283	REPLACEMET OF HT BUSHING ROD
1468	16-12-2025	Part of : NETAJI SUBHASH VIHAR MUNDKA,	44	Other Outage	Planned Outage	16-12-2025	10:20	16-12-2025	13:02	2:42	0.000450	MAINTENANCE OF TRANSFORMER
1469	16-12-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	10	Other Outage	Planned Outage	16-12-2025	11:32	16-12-2025	14:11	2:39	0.000883	MAINTENANCE OF TRANSFORMER
1470	16-12-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	11	Other Outage	Planned Outage	16-12-2025	11:32	16-12-2025	14:12	2:40	0.000889	MAINTENANCE OF TRANSFORMER
1471	17-12-2025	Part of : NETAJI SUBHASH VIHAR MUNDKA,HIRAN KUDNA,MUNDKA INDUSTRIAL AREA MUNDKA,NEELWAL VILLAGE	1670	Other Outage	Unplanned Outage	17-12-2025	13:17	17-12-2025	13:21	0:04	0.000061	TREE TRIMMING
1472	17-12-2025	Part of : TILANGPUR KOTLA	1070	Other Outage	Planned Outage	17-12-2025	11:29	17-12-2025	13:03	1:34	0.000522	REPLACEMENT OF HT BUSHING ROD
1473	17-12-2025	Part of : NETAJI SUBHASH VIHAR MUNDKA	346	Other Outage	Planned Outage	17-12-2025	10:39	17-12-2025	12:43	2:04	0.000689	REPLACEMENT OF GAS KIT AND OIL SEAL
1474	18-12-2025	Part of : MUNDKA INDUSTRIAL AREA	1	Other Outage	Planned Outage	18-12-2025	14:49	18-12-2025	16:18	1:29	0.000247	REPLACEMENT OF HT BUSHING ROD
1475	18-12-2025	Part of : TIKRI KALAN	3	Other Outage	Planned Outage	18-12-2025	14:29	18-12-2025	16:50	2:21	0.000783	REPLACEMENT OF GAS KIT AND OIL SEAL
1476	18-12-2025	Part of : POCKET A LOKNAYAK PURAM BAKARWALA	7	Other Outage	Planned Outage	18-12-2025	11:25	18-12-2025	13:57	2:32	0.000844	REPLACEMENT OF HT BUSHING ROD
1477	18-12-2025	Part of : A-BLOCK NANGLOI EXTENSION	936	Other Outage	Planned Outage	18-12-2025	10:49	18-12-2025	13:40	2:51	0.001425	HT CONDUCTOR REPLACEMENT
1478	18-12-2025	Part of : RANHOLLA	356	Other Outage	Planned Outage	18-12-2025	11:10	18-12-2025	13:46	2:36	0.001517	REPLACEMENT OF HT BUSHING ROD
1479	19-12-2025	Part of : DHANKA COLONY KAMARUDDIN NAGAR,JAI VIHAR KAMARUDDIN NAGAR,KAMARUDDIN NAGAR EXTENSION,YADAV PARK KAMARUDDIN NAGAR	4298	Other Outage	Unplanned Outage	19-12-2025	07:49	19-12-2025	08:25	0:36	0.000220	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1480	19-12-2025	Part of : HIRAN KUDNA	474	Other Outage	Planned Outage	19-12-2025	14:07	19-12-2025	15:38	1:31	0.000506	REPLACEMET OF HT BUSHING ROD
1481	19-12-2025	Part of : MUNDKA EXTENSION	88	Other Outage	Planned Outage	19-12-2025	12:55	19-12-2025	15:08	2:13	0.000369	REPLACEMET OF HT BUSHING ROD
1482	20-12-2025	Part of : TIKRI KALAN,	340	Other Outage	Planned Outage	20-12-2025	16:44	20-12-2025	17:38	0:54	0.000015	MAINTENANCE OF O/H HT CIRCUIT
1483	20-12-2025	Part of : BLOCK A NANGLOI EXTENSION NANGLOI,	936	Other Outage	Planned Outage	20-12-2025	16:29	20-12-2025	17:36	1:07	0.000372	MAINTENANCE OF O/H HT CIRCUIT
1484	20-12-2025	Part of : TIKRI KALAN,	212	Other Outage	Planned Outage	20-12-2025	12:06	20-12-2025	14:13	2:07	0.001058	MAINTENANCE OF TRANSFORMER
1485	21-12-2025	Part of : SAVITA VIHAR MUNDKA,MUNDKA EXTENSION MUNDKA	526	Other Outage	Planned Outage	21-12-2025	12:34	21-12-2025	14:23	1:49	0.003633	CONDUCTOR REPLACEMENT PER SPAN
1486	21-12-2025	Part of : MUNDKA EXTENSION MUNDKA,BLOCK C MUNDKA	182	Other Outage	Planned Outage	21-12-2025	12:30	21-12-2025	14:20	1:50	0.003361	CONDUCTOR REPLACEMENT PER SPAN
1487	21-12-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,NETAJI SUBHASH VIHAR MUNDKA	99	Other Outage	Planned Outage	21-12-2025	10:46	21-12-2025	12:18	1:32	0.002300	CONNECTING OF NEW EARTHING PER EARTHING,GUARD WIRE LACS INSTALLTION PER SPAN
1488	21-12-2025	Part of : MUNDKA VILLAGE MUNDKA	46	Other Outage	Planned Outage	21-12-2025	13:40	21-12-2025	15:58	2:18	0.000767	REPLACEMENT OF HT BUSHING ROD
1489	21-12-2025	Part of : GULSHAN PARK WEST CABIN BLOCK MUNDKA	21	Other Outage	Planned Outage	21-12-2025	12:31	21-12-2025	15:20	2:49	0.004694	CONDUCTOR REPLACEMENT PER SPAN
1490	21-12-2025	Part of : BLOCK C MUNDKA	53	Other Outage	Planned Outage	21-12-2025	12:31	21-12-2025	14:51	2:20	0.001944	CONDUCTOR REPLACEMENT PER SPAN
1491	21-12-2025	Part of : VEENA ENCLAVE MUNDKA	224	Other Outage	Planned Outage	21-12-2025	10:36	21-12-2025	13:19	2:43	0.000906	REPLACEMENT OF HT BUSHING ROD
1492	21-12-2025	Part of : GULSHAN PARK WEST CABIN BLOCK MUNDKA	110	Other Outage	Planned Outage	21-12-2025	10:35	21-12-2025	13:18	2:43	0.002717	REPLACEMENT OF HT BUSHING ROD
1493	21-12-2025	Part of : VEENA ENCLAVE WEST CABIN BLOCK MUNDKA	15	Other Outage	Planned Outage	21-12-2025	10:35	21-12-2025	13:36	3:01	0.000503	INSTALLATION OF BUS BAR
1494	21-12-2025	Part of : WEST CABIN BLOCK MUNDKA	664	Other Outage	Planned Outage	21-12-2025	10:34	21-12-2025	13:21	2:47	0.002319	CONDUCTOR REPLACEMENT PER SPAN
1495	21-12-2025	Part of : TIKRI KALAN	53	Other Outage	Planned Outage	21-12-2025	10:45	21-12-2025	13:22	2:37	0.002181	ACB REPLACEMENT PER ACB
1496	22-12-2025	Part of : VEENA ENCLAVE MUNDKA	224	Other Outage	Planned Outage	22-12-2025	15:00	22-12-2025	16:50	1:50	0.000306	REPLACEMENT OF HT BUSHING ROD
1497	22-12-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	662	Other Outage	Planned Outage	22-12-2025	12:55	22-12-2025	16:04	3:09	0.000525	REPLACEMENT OF HT BUSHING ROD
1498	22-12-2025	Part of : TILANGPUR KOTLA	833	Other Outage	Planned Outage	22-12-2025	13:02	22-12-2025	16:03	3:01	0.002011	REPLACEMENT OF HT BUSHING ROD
1499	22-12-2025	Part of : MUNDKA INDUSTRIAL AREA	26	Other Outage	Planned Outage	22-12-2025	11:18	22-12-2025	14:03	2:45	0.000458	REPLACEMENT OF GAS KIT AND OIL SEAL
1500	23-12-2025	Part of : TIKRI KALAN	519	Other Outage	Planned Outage	23-12-2025	15:49	23-12-2025	16:35	0:46	0.000511	REPLACEMENT OF LT BUSHING ROD
1501	23-12-2025	Part of : TILANGPUR KOTLA	815	Other Outage	Planned Outage	23-12-2025	11:40	23-12-2025	12:25	0:45	0.000375	REPLACEMENT OF HT BUSHING INULATOR
1502	23-12-2025	Part of : YADAV PARK KAMARUDDIN NAGAR	374	Other Outage	Planned Outage	23-12-2025	11:39	23-12-2025	13:00	1:21	0.000675	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF LUGS
1503	24-12-2025	Part of : NIRMAL VIHAR BAPROLA,BANI AIR FORCE CAMP JAI VIHAR BAPROLA,TILANGPUR KOTLA	6189	Other Outage	Unplanned Outage	24-12-2025	03:58	24-12-2025	04:40	0:42	0.000152	HVDS FAULT
1504	25-12-2025	Part of : MUNDKA INDUSTRIAL AREA	25	Other Outage	Planned Outage	25-12-2025	13:12	25-12-2025	15:28	2:16	0.000756	REPLACEMENT OF HT BUSHING ROD
1505	25-12-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,NETAJI SUBHASH VIHAR MUNDKA	209	Other Outage	Planned Outage	25-12-2025	10:41	25-12-2025	13:28	2:47	0.006958	GUARD WIRES SAGGING PER SPAN,TAPPING OF JUMPERS
1506	25-12-2025	Part of : TILANGPUR KOTLA	1329	Other Outage	Planned Outage	25-12-2025	11:24	25-12-2025	13:59	2:35	0.000861	REPLACEMENT OF HT BUSHING ROD
1507	25-12-2025	Part of : TIKRI KALAN	37	Other Outage	Planned Outage	25-12-2025	11:40	25-12-2025	14:28	2:48	0.000233	1C 630 SQ MM CABLE REPLACEMENT PER PHASE
1508	26-12-2025	Part of : POCKET C LOKNAYAK PURAM BAKARWALA	224	Other Outage	Planned Outage	26-12-2025	13:34	26-12-2025	16:11	2:37	0.001744	REPLACEMENT OF HT BUSHING ROD
1509	26-12-2025	Part of : RANHOLLA	387	Other Outage	Planned Outage	26-12-2025	11:39	26-12-2025	14:40	3:01	0.000503	REPLACEMENT OF FAULTY END BOX
1510	26-12-2025	Part of : RANHOLLA	462	Other Outage	Planned Outage	26-12-2025	11:29	26-12-2025	14:22	2:53	0.001922	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1511	27-12-2025	Part of : BLOCK A JJ COLONY 2 NANGLOI	1078	Other Outage	Planned Outage	27-12-2025	13:47	27-12-2025	15:16	1:29	0.000494	REPLACEMENT OF GAS KIT AND OIL SEAL
1512	27-12-2025	Part of : MUNDKA INDUSTRIAL AREA	37	Other Outage	Planned Outage	27-12-2025	13:44	27-12-2025	15:10	1:26	0.000478	REPLACEMET OF HT BUSHING ROD
1513	27-12-2025	Part of : BLOCK B TYAGI VIHAR MUNDKA	1	Other Outage	Planned Outage	27-12-2025	14:22	27-12-2025	15:48	1:26	0.000478	REPLACEMENT OF LT BUSHING ROD
1514	27-12-2025	Part of : TIKRI KALAN	340	Other Outage	Planned Outage	27-12-2025	12:29	27-12-2025	15:11	2:42	0.000900	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1515	28-12-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	66	Other Outage	Planned Outage	28-12-2025	11:04	28-12-2025	13:35	2:31	0.002936	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1516	28-12-2025	Part of : WEST CABIN BLOCK MUNDKA,	565	Other Outage	Planned Outage	28-12-2025	12:04	28-12-2025	14:15	2:11	0.000728	REPLACEMET OF FAULTY END BOX
1517	29-12-2025	Part of : BLOCK A TYAGI VIHAR MUNDKA	13	Other Outage	Planned Outage	29-12-2025	14:53	29-12-2025	15:50	0:57	0.000317	REPLACEMENT OF HT BUSHING ROD
1518	29-12-2025	Part of : BLOCK A TYAGI VIHAR MUNDKA	14	Other Outage	Planned Outage	29-12-2025	14:12	29-12-2025	15:13	1:01	0.000847	REPLACEMENT OF HT BUSHING ROD
1519	29-12-2025	Part of : BLOCK D JJ COLONY 2 NANGLOI	854	Other Outage	Planned Outage	29-12-2025	14:10	29-12-2025	16:28	2:18	0.001150	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1520	29-12-2025	Part of : RANHOLLA,LAXMI PARK COLONY KAMARUDDIN NAGAR	1981	Other Outage	Planned Outage	29-12-2025	14:09	29-12-2025	16:34	2:25	0.002819	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1521	29-12-2025	Part of : TILANGPUR KOTLA	835	Other Outage	Planned Outage	29-12-2025	13:49	29-12-2025	16:26	2:37	0.000785	LT AB SAGGING PER SPAN
1522	29-12-2025	Part of : RANHOLLA,TILANGPUR KOTLA	1568	Other Outage	Planned Outage	29-12-2025	11:03	29-12-2025	13:51	2:48	0.004667	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1523	29-12-2025	Part of : RANHOLLA	387	Other Outage	Planned Outage	29-12-2025	11:26	29-12-2025	14:17	2:51	0.003325	REPLACEMENT OF FAULTY END BOX
1524	30-12-2025	Part of : MUNDKA INDUSTRIAL AREA,NETAJI SUBHASH VIHAR,HIRAN KUDNA	334	Other Outage	Unplanned Outage	30-12-2025	21:22	30-12-2025	22:14	0:52	0.000000	CABLE FAULT
1525	31-12-2025	Part of : BLOCK A JJ COLONY 2 NANGLOI	1511	Other Outage	Planned Outage	31-12-2025	13:09	31-12-2025	15:03	1:54	0.000792	REPLACEMET OF HT BUSHING ROD
1526	01-12-2025	Part of : SAINIK ENCLAVE VIPIN GARDEN NAWADA,VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA,LAXMI VIHAR NAWADA	7599	Other Outage	Unplanned Outage	01-12-2025	23:43	02-12-2025	01:22	1:39	0.000550	HT POLE DAMAGED BY UNKNOWN VEHICLE
1527	01-12-2025	Part of : PHASE 1 OM VIHAR NAWADA	763	Other Outage	Planned Outage	01-12-2025	16:01	01-12-2025	16:33	0:32	0.000178	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
1528	01-12-2025	Part of : BLOCK D BHAGWATI GARDEN NAWADA	1784	Other Outage	Planned Outage	01-12-2025	14:40	01-12-2025	16:32	1:52	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1529	01-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD,BLOCK W MOHAN GARDEN RAZAPUR KHURD	4263	Other Outage	Planned Outage	01-12-2025	12:09	01-12-2025	14:44	2:35	0.000431	3PH HT AB CABLE REPLACEMENT PER SPAN
1530	01-12-2025	Part of : PHASE 1 OM VIHAR NAWADA	1016	Other Outage	Planned Outage	01-12-2025	11:05	01-12-2025	14:00	2:55	0.000972	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
1531	01-12-2025	Part of : LAXMI VIHAR NAWADA	790	Other Outage	Planned Outage	01-12-2025	11:26	01-12-2025	13:45	2:19	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1532	02-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,R,RK,W & WE-BLOCK MOHAN GARDEN,RAZAPUR KHURD	5703	Other Outage	Unplanned Outage	02-12-2025	10:52	02-12-2025	11:37	0:45	0.000938	CABLE FAULT
1533	02-12-2025	Part of : BLOCK M & F ZAILDAR ENCLAVE HASTSAL	1407	Other Outage	Planned Outage	02-12-2025	15:18	02-12-2025	16:42	1:24	0.000467	ST.TH JOINT ON 1PH HT AB
1534	02-12-2025	Part of : BLOCK K 7 & K 5 ZAILDAR ENCLAVE HASTSAL	1585	Other Outage	Planned Outage	02-12-2025	12:10	02-12-2025	13:39	1:29	0.000494	DT REPLACEMET PER DT
1535	02-12-2025	Part of : BHAGWATI GARDEN NAWADA	128	Other Outage	Planned Outage	02-12-2025	13:56	02-12-2025	16:41	2:45	0.000000	REPLACEMET OF HT BUSHING ROD
1536	02-12-2025	Part of : BLOCK C & R 5 VIPIN GARDEN NAWADA	3651	Other Outage	Planned Outage	02-12-2025	13:57	02-12-2025	16:42	2:45	0.000000	GUARD WIRES SAGGING
1537	02-12-2025	Part of : BLOCK P 2 & P MOHAN GARDEN RAZAPUR KHURD	1365	Other Outage	Planned Outage	02-12-2025	14:30	02-12-2025	16:40	2:10	0.000361	3PH HT AB CABLE REPLACEMENT PER SPAN
1538	02-12-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD	385	Other Outage	Planned Outage	02-12-2025	12:14	02-12-2025	14:28	2:14	0.000000	LT CIRCUIT MAINTENANCE
1539	03-12-2025	Part of : BLOCK RK & WE MOHAN GARDEN RAZAPUR KHURD	819	Other Outage	Planned Outage	03-12-2025	15:21	03-12-2025	16:29	1:08	0.000189	3PH HT AB CABLE REPLACEMENT PER SPAN
1540	03-12-2025	Part of : BLOCK D,E,L & H BHAGWATI GARDEN NAWADA	2635	Other Outage	Planned Outage	03-12-2025	11:38	03-12-2025	13:23	1:45	0.000000	GUARD WIRES SAGGING PER SPAN
1541	03-12-2025	Part of : BLOCK A,B & C SEWAK PARK DWARKA,BLOCK B1 SEWAK PARK DWARKA,SHANTI PARK DWARKA	3398	Other Outage	Planned Outage	03-12-2025	11:42	03-12-2025	13:25	1:43	0.000000	GUARD WIRES SAGGING PER SPAN
1542	03-12-2025	Part of : BLOCK P2 & R5 MOHAN GARDEN RAZAPUR KHURD,BLOCK H BHAGWATI GARDEN NAWADA	1169	Other Outage	Planned Outage	03-12-2025	11:58	03-12-2025	14:36	2:38	0.000439	3PH HT AB CABLE REPLACEMENT PER SPAN
1543	03-12-2025	Part of : PHASE 2 OM VIHAR NAWADA	1197	Other Outage	Planned Outage	03-12-2025	11:06	03-12-2025	13:27	2:21	0.000000	REPLACEMENT OF LT BUSHING ROD
1544	04-12-2025	Part of : BHAGWATI GARDEN NAWADA	128	Other Outage	Planned Outage	04-12-2025	12:09	04-12-2025	13:42	1:33	0.000000	REPLACEMENT OF LT BUSHING ROD
1545	04-12-2025	Part of : NAWADA EXTENSION NAWADA	648	Other Outage	Planned Outage	04-12-2025	12:14	04-12-2025	13:41	1:27	0.000000	REPLACEMENT OF LT BUSHING ROD
1546	04-12-2025	Part of : BLOCK C VIPIN GARDEN NAWADA	71	Other Outage	Planned Outage	04-12-2025	12:07	04-12-2025	14:51	2:44	0.000000	3PH DB REVAMPING
1547	04-12-2025	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,RAZAPUR KHURD	1781	Other Outage	Planned Outage	04-12-2025	11:31	04-12-2025	13:41	2:10	0.000361	3PH HT AB CABLE REPLACEMENT PER SPAN
1548	04-12-2025	Part of : PHASE 2 OM VIHAR NAWADA	1197	Other Outage	Planned Outage	04-12-2025	11:30	04-12-2025	13:37	2:07	0.000000	JUMPER REPLACEMENT PER POLE
1549	05-12-2025	Part of : PHASE 1 OM VIHAR NAWADA	763	Other Outage	Planned Outage	05-12-2025	15:48	05-12-2025	16:09	0:21	0.000117	3PH HT AB CABLE REPLACEMENT PER SPAN
1550	05-12-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	2569	Other Outage	Planned Outage	05-12-2025	15:04	05-12-2025	16:08	1:04	0.000178	3PH HT AB CABLE REPLACEMENT PER SPAN
1551	05-12-2025	Part of : PHASE 2 OM VIHAR NAWADA	740	Other Outage	Planned Outage	05-12-2025	14:50	05-12-2025	16:10	1:20	0.000000	REPLACEMENT OF LT BUSHING ROD
1552	05-12-2025	Part of : BHAGWATI GARDEN EXTENSION NAWADA	2209	Other Outage	Planned Outage	05-12-2025	11:37	05-12-2025	13:47	2:10	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1553	05-12-2025	Part of : PHASE 1 OM VIHAR NAWADA	1016	Other Outage	Planned Outage	05-12-2025	11:10	05-12-2025	13:46	2:36	0.000867	HT BUSHING ROD REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1554	05-12-2025	Part of : SAINIK ENCLAVE VIPIN GARDEN NAWADA,VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA,LAXMI VIHAR NAWADA,	6534	Other Outage	Planned Outage	05-12-2025	11:28	05-12-2025	13:44	2:16	0.000000	GUARD WIRES SAGGING PER SPAN
1555	05-12-2025	Part of : BLOCK RK MOHAN GARDEN RAZAPUR KHURD,	1029	Other Outage	Planned Outage	05-12-2025	11:08	05-12-2025	13:43	2:35	0.000861	3PH HT AB CABLE REPLACEMENT PER SPAN
1556	06-12-2025	Part of : A-BLOCK MAHAVIR ENCLAVE NAWADA	386	Other Outage	Unplanned Outage	06-12-2025	11:48	06-12-2025	13:33	1:45	0.001458	LAYING OF NEW LTAB
1557	06-12-2025	Part of : K 4,K 5 & K 7-BLOCK ZAILDAR ENCLAVE HASTSAL,A,B&C-BLOCK MAHARANI ENCLAVE	1585	Other Outage	Planned Outage	06-12-2025	15:20	06-12-2025	17:02	1:42	0.000567	1PH HT AB END TERMINATION REPLACEMENT
1558	06-12-2025	Part of : R 1-BLOCK MOHAN GARDEN RAZAPUR KHURD	129	Other Outage	Planned Outage	06-12-2025	12:43	06-12-2025	14:53	2:10	0.000000	REPLACEMENT OF HT BUSHING ROD
1559	06-12-2025	Part of : M & F-BLOCK ZAILDAR ENCLAVE HASTSAL	1408	Other Outage	Planned Outage	06-12-2025	11:19	06-12-2025	13:55	2:36	0.000867	1PH HT AB END TERMINATION REPLACEMENT
1560	06-12-2025	Part of : B-BLOCK SEWAK PARK DWARKA	1332	Other Outage	Planned Outage	06-12-2025	12:45	06-12-2025	14:54	2:09	0.000000	LT CIRCUIT MAINTENANCE WORK
1561	06-12-2025	Part of : NAWADA EXTENSION	440	Other Outage	Planned Outage	06-12-2025	12:33	06-12-2025	14:55	2:22	0.000000	LT CIRCUIT MAINTENANCE WORK
1562	06-12-2025	Part of : F-BLOCK ZAILDAR ENCLAVE NAWADA	705	Other Outage	Planned Outage	06-12-2025	11:42	06-12-2025	13:50	2:08	0.000000	LT CIRCUIT MAINTENANCE WORK
1563	06-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	257	Other Outage	Planned Outage	06-12-2025	11:06	06-12-2025	13:47	2:41	0.000000	LT CIRCUIT MAINTENANCE WORK
1564	07-12-2025	Part of : NAWADA EXTENSION,BLOCK A & B MAHAVIR ENCLAVE NAWADA,BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA	4240	Other Outage	Unplanned Outage	07-12-2025	14:31	07-12-2025	15:16	0:45	0.000400	BIRDAGE
1565	08-12-2025	Part of : NAWADA EXTENSION NAWADA,	632	Other Outage	Planned Outage	08-12-2025	15:14	08-12-2025	16:39	1:25	0.000472	CONDUCTOR REPLACEMENT PER SPAN
1566	08-12-2025	Part of : BLOCK RK MOHAN GARDEN RAZAPUR KHURD,BLOCK R MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,	564	Other Outage	Planned Outage	08-12-2025	15:17	08-12-2025	16:26	1:09	0.000383	1PH HT AB END TERMINATION REPLACEMENT
1567	08-12-2025	Part of : PHASE 1 OM VIHAR NAWADA,	3027	Other Outage	Planned Outage	08-12-2025	15:16	08-12-2025	16:38	1:22	0.000456	1PH HT AB END TERMINATION REPLACEMENT
1568	08-12-2025	Part of : PHASE 2 OM VIHAR NAWADA,	1197	Other Outage	Planned Outage	08-12-2025	14:16	08-12-2025	16:37	2:21	0.000000	REPLACEMENT OF LT BUSHING ROD
1569	08-12-2025	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK N 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,	2915	Other Outage	Planned Outage	08-12-2025	14:08	08-12-2025	16:36	2:28	0.000411	3PH HT AB CABLE REPLACEMENT PER SPAN
1570	08-12-2025	Part of : BLOCK L BHAGWATI GARDEN NAWADA,	2639	Other Outage	Planned Outage	08-12-2025	12:15	08-12-2025	15:09	2:54	0.000000	DB REVAMPING
1571	08-12-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	424	Other Outage	Planned Outage	08-12-2025	11:37	08-12-2025	13:44	2:07	0.000000	DT REPLACEMENT
1572	08-12-2025	Part of : PHASE 1 OM VIHAR NAWADA,	1016	Other Outage	Planned Outage	08-12-2025	11:03	08-12-2025	13:51	2:48	0.000933	1PH HT AB CABLE REPLACEMENT PER SPAN
1573	09-12-2025	Part of : BLOCK RK MOHAN GARDEN RAZAPUR KHURD,BLOCK R MOHAN GARDEN RAZAPUR KHURD	1041	Other Outage	Unplanned Outage	09-12-2025	11:21	09-12-2025	13:26	2:05	0.000347	REPAIRING OF HVDS CIRCUIT
1574	09-12-2025	Part of : BLOCK K 7 ZAILDAR ENCLAVE HASTSAL,BLOCK K 5 ZAILDAR ENCLAVE HASTSAL,BLOCK K 4 ZAILDAR ENCLAVE HASTSAL,A,B&C-BLOCK MAHARANI ENCLAVE	1586	Other Outage	Planned Outage	09-12-2025	15:42	09-12-2025	16:28	0:46	0.000256	1PH HT AB END TERMINATION REPLACEMENT
1575	09-12-2025	Part of : BHAGWATI GARDEN NAWADA	1252	Other Outage	Planned Outage	09-12-2025	11:50	09-12-2025	14:54	3:04	0.001022	REPLACEMENT OF HT BUSHING ROD
1576	09-12-2025	Part of : NAWADA EXTENSION NAWADA	632	Other Outage	Planned Outage	09-12-2025	11:51	09-12-2025	14:55	3:04	0.001022	CONDUCTOR REPLACEMENT PER SPAN
1577	09-12-2025	Part of : BLOCK A, B & D BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA	2259	Other Outage	Planned Outage	09-12-2025	11:34	09-12-2025	13:54	2:20	0.000000	REPLACEMENT OF HT BUSHING ROD
1578	09-12-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK F ZAILDAR ENCLAVE NAWADA	1408	Other Outage	Planned Outage	09-12-2025	11:33	09-12-2025	13:52	2:19	0.000772	1PH HT AB END TERMINATION REPLACEMENT
1579	09-12-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	424	Other Outage	Planned Outage	09-12-2025	13:28	09-12-2025	15:32	2:04	0.000000	3PH DB REPLACEMENT
1580	09-12-2025	Part of : BLOCK F ZAILDAR ENCLAVE NAWADA	705	Other Outage	Planned Outage	09-12-2025	11:51	09-12-2025	14:52	3:01	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1581	10-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	278	Other Outage	Planned Outage	10-12-2025	14:43	10-12-2025	16:22	1:39	0.000275	3PH HT AB CABLE REPLACEMENT
1582	10-12-2025	Part of : H-BLOCK BHAGWATI GARDEN & LAXMI VIHAR NAWADA	1476	Other Outage	Planned Outage	10-12-2025	11:17	10-12-2025	12:39	1:22	0.000000	REPLACEMENT OF HT BUSHING ROD
1583	10-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,WE-BLOCK MOHAN GARDEN RAZAPUR KHURD	1475	Other Outage	Planned Outage	10-12-2025	11:02	10-12-2025	13:51	2:49	0.000469	3PH HT AB CABLE REPLACEMENT
1584	10-12-2025	Part of : K 6-BLOCK ZAILDAR ENCLAVE HASTSAL	2206	Other Outage	Planned Outage	10-12-2025	11:24	10-12-2025	13:45	2:21	0.000000	LT CIRCUIT MAINTENANCE
1585	11-12-2025	Part of : BLOCK R,R1 & S MOHAN GARDEN RAZAPUR KHURD, RAZAPUR KHURD	2090	Other Outage	Unplanned Outage	11-12-2025	13:58	11-12-2025	15:47	1:49	0.001514	REPAIRING OF HVDS CIRCUIT
1586	11-12-2025	Part of : PHASE 5 OM VIHAR HASTSAL	748	Other Outage	Unplanned Outage	11-12-2025	11:59	11-12-2025	13:32	1:33	0.000517	REPAIR/REPLACEMENT OF LT AB

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1587	11-12-2025	Part of : BLOCK F ZAILDAR ENCLAVE NAWADA	714	Other Outage	Planned Outage	11-12-2025	14:48	11-12-2025	16:29	1:41	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1588	11-12-2025	Part of : NAWADA EXTENSION	1528	Other Outage	Planned Outage	11-12-2025	14:49	11-12-2025	16:28	1:39	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1589	11-12-2025	Part of : BLOCK H BHAGWATI GARDEN NAWADA	8	Other Outage	Planned Outage	11-12-2025	12:34	11-12-2025	14:29	1:55	0.000000	HT BUSHING ROD REPLACEMENT
1590	11-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	449	Other Outage	Planned Outage	11-12-2025	11:11	11-12-2025	13:36	2:25	0.000403	3PH DB REPLACEMENT
1591	11-12-2025	Part of : PHASE 2 OM VIHAR NAWADA	793	Other Outage	Planned Outage	11-12-2025	11:25	11-12-2025	13:35	2:10	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1592	12-12-2025	Part of : NAWADA EXTENSION NAWADA,BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK A MAHAVIR ENCLAVE NAWADA,BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK B BHAGWATI GARDEN NAWADA	4252	Other Outage	Unplanned Outage	12-12-2025	08:22	12-12-2025	09:12	0:50	0.000639	BIRDAGE
1593	12-12-2025	Part of : PHASE 1 OM VIHAR NAWADA,	763	Other Outage	Planned Outage	12-12-2025	15:06	12-12-2025	16:46	1:40	0.000556	1PH HT AB END TERMINATION REPLACEMENT
1594	12-12-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	426	Other Outage	Planned Outage	12-12-2025	14:11	12-12-2025	16:46	2:35	0.000000	REPLACEMENT OF LT BUSHING ROD
1595	12-12-2025	Part of : BHAGWATI GARDEN NAWADA,	1260	Other Outage	Planned Outage	12-12-2025	12:29	12-12-2025	14:59	2:30	0.000000	REPLACEMENT OF LT BUSHING ROD
1596	12-12-2025	Part of : BLOCK C VIPIN GARDEN NAWADA,	2025	Other Outage	Planned Outage	12-12-2025	11:13	12-12-2025	13:48	2:35	0.001722	REPLACEMET OF HT BUSHING ROD
1597	12-12-2025	Part of : PHASE 1 OM VIHAR NAWADA,	1016	Other Outage	Planned Outage	12-12-2025	11:29	12-12-2025	13:39	2:10	0.000722	1PH HT AB END TERMINATION REPLACEMENT
1598	12-12-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD	564	Other Outage	Planned Outage	12-12-2025	11:03	12-12-2025	13:47	2:44	0.000456	3PH HT AB CABLE REPLACEMENT PER SPAN
1599	13-12-2025	Part of : BLOCK K 7 ZAILDAR ENCLAVE HASTSAL,BLOCK K 5 ZAILDAR ENCLAVE HASTSAL,BLOCK K 4 ZAILDAR ENCLAVE HASTSAL,A,B&C-BLOCK MAHARANI ENCLAVE	1586	Other Outage	Planned Outage	13-12-2025	15:16	13-12-2025	17:13	1:57	0.000650	1PH HT AB END TERMINATION REPLACEMENT
1600	13-12-2025	Part of : BLOCK S MOHAN GARDEN RAZAPUR KHURD	111	Other Outage	Planned Outage	13-12-2025	13:59	13-12-2025	15:45	1:46	0.000000	3PH DB REPLACEMENT
1601	13-12-2025	Part of : PHASE 2 OM VIHAR NAWADA	793	Other Outage	Planned Outage	13-12-2025	13:11	13-12-2025	15:25	2:14	0.000000	REPLACEMENT OF LT BUSHING ROD
1602	13-12-2025	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA	1718	Other Outage	Planned Outage	13-12-2025	11:18	13-12-2025	14:02	2:44	0.000000	REPLACEMENT OF HT BUSHING ROD
1603	13-12-2025	Part of : NAWADA EXTENSION NAWADA	888	Other Outage	Planned Outage	13-12-2025	11:16	13-12-2025	14:07	2:51	0.000000	3PH DB REPLACEMENT
1604	13-12-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK F ZAILDAR ENCLAVE NAWADA	1408	Other Outage	Planned Outage	13-12-2025	10:48	13-12-2025	14:08	3:20	0.001111	1PH HT AB END TERMINATION REPLACEMENT
1605	13-12-2025	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,RAZAPUR KHURD	1781	Other Outage	Planned Outage	13-12-2025	11:06	13-12-2025	13:40	2:34	0.000428	3PH HT AB CABLE REPLACEMENT PER SPAN
1606	13-12-2025	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD	129	Other Outage	Planned Outage	13-12-2025	13:13	13-12-2025	15:26	2:13	0.000000	3PH DB REVAMPING
1607	15-12-2025	Part of : BLOCK P2,R,R1 & R5 MOHAN GARDEN RAZAPUR KHURD,BLOCK N1 & N2 MOHAN GARDEN RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL	5115	Other Outage	Unplanned Outage	15-12-2025	05:34	15-12-2025	06:00	0:26	0.000022	CABLE FAULT
1608	15-12-2025	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD	129	Other Outage	Planned Outage	15-12-2025	15:25	15-12-2025	16:27	1:02	0.000344	CONDUCTOR REPLACEMENT PER SPAN
1609	15-12-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD	734	Other Outage	Planned Outage	15-12-2025	12:46	15-12-2025	14:35	1:49	0.000000	3PH DB REVAMPING
1610	15-12-2025	Part of : BLOCK RK & W MOHAN GARDEN RAZAPUR KHURD	1910	Other Outage	Planned Outage	15-12-2025	14:10	15-12-2025	16:24	2:14	0.000372	3PH HT AB CABLE REPLACEMENT PER SPAN
1611	15-12-2025	Part of : PHASE 1 OM VIHAR NAWADA	3027	Other Outage	Planned Outage	15-12-2025	12:03	15-12-2025	14:48	2:45	0.000917	1PH HT AB CABLE REPLACEMENT PER SPAN
1612	15-12-2025	Part of : BLOCK L BHAGWATI GARDEN NAWADA	2655	Other Outage	Planned Outage	15-12-2025	11:57	15-12-2025	14:47	2:50	0.000000	HT BUSHING ROD REPLACEMENT
1613	15-12-2025	Part of : PHASE 2 OM VIHAR NAWADA	793	Other Outage	Planned Outage	15-12-2025	12:13	15-12-2025	14:47	2:34	0.000856	DT REPLACEMENT
1614	16-12-2025	Part of : BLOCK C VIPIN GARDEN NAWADA,SAINIK ENCLAVE VIPIN GARDEN NAWADA,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	4172	Other Outage	Unplanned Outage	16-12-2025	17:37	16-12-2025	18:08	0:31	0.000000	CABLE FAULT
1615	16-12-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD,	1044	Other Outage	Unplanned Outage	16-12-2025	11:22	16-12-2025	13:11	1:49	0.000606	REPLACEMENT OF HVDS CABLE
1616	16-12-2025	Part of : PHASE 5 OM VIHAR HASTSAL,	3783	Other Outage	Planned Outage	16-12-2025	15:21	16-12-2025	16:29	1:08	0.000378	MAINTENANCE OF RMU
1617	16-12-2025	Part of : BLOCK K 5 ZAILDAR ENCLAVE HASTSAL,	1586	Other Outage	Planned Outage	16-12-2025	15:23	16-12-2025	16:30	1:07	0.000372	MAINTENANCE OF HVDS CIRCUIT
1618	16-12-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,	726	Other Outage	Planned Outage	16-12-2025	13:14	16-12-2025	15:02	1:48	0.000000	MAINTENANCE OF LT CIRCUIT
1619	16-12-2025	Part of : BLOCK F ZAILDAR ENCLAVE NAWADA,	715	Other Outage	Planned Outage	16-12-2025	13:42	16-12-2025	16:28	2:46	0.000922	MAINTENANCE OF HT CIRCUIT
1620	16-12-2025	Part of : BHAGWATI GARDEN NAWADA,	1260	Other Outage	Planned Outage	16-12-2025	12:19	16-12-2025	14:28	2:09	0.000717	MAINTENANCE OF TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1621	16-12-2025	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA	2259	Other Outage	Planned Outage	16-12-2025	11:03	16-12-2025	13:26	2:23	0.000000	MAINTENANCE OF TRANSFORMER
1622	16-12-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,	1408	Other Outage	Planned Outage	16-12-2025	11:21	16-12-2025	13:25	2:04	0.000689	MAINTENANCE OF HVDS CIRCUIT
1623	17-12-2025	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK P MOHAN GARDEN RAZAPUR KHURD	1370	Other Outage	Unplanned Outage	17-12-2025	16:51	17-12-2025	17:52	1:01	0.000169	REPAIRING OF HVDS CIRCUIT
1624	17-12-2025	Part of : PHASE 5 OM VIHAR HASTSAL	732	Other Outage	Planned Outage	17-12-2025	15:31	17-12-2025	16:12	0:41	0.000000	DT REPLACEMENT
1625	17-12-2025	Part of : BLOCK H BHAGWATI GARDEN NAWADA,LAXMI VIHAR NAWADA	1478	Other Outage	Planned Outage	17-12-2025	12:49	17-12-2025	16:14	3:25	0.000000	REPLACEMENT OF HT BUSHING ROD
1626	17-12-2025	Part of : NAWADA EXTENSION NAWADA	1528	Other Outage	Planned Outage	17-12-2025	12:01	17-12-2025	14:51	2:50	0.000944	CONDUCTOR REPLACEMENT PER SPAN
1627	17-12-2025	Part of : PHASE 2 OM VIHAR NAWADA	793	Other Outage	Planned Outage	17-12-2025	12:13	17-12-2025	14:50	2:37	0.000872	DT REPLACEMENT
1628	17-12-2025	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD	819	Other Outage	Planned Outage	17-12-2025	11:13	17-12-2025	13:31	2:18	0.000383	HT AB CABLE REPLACEMENT PER SPAN
1629	18-12-2025	Part of : F-BLOCK ZAILDAR ENCLAVE NAWADA	715	Other Outage	Unplanned Outage	18-12-2025	14:18	18-12-2025	15:47	1:29	0.000494	FOR TAKING LOAD ON REPAIRED CABLE
1630	18-12-2025	Part of : OM VIHAR PHASE 5 HASTSAL	748	Other Outage	Unplanned Outage	18-12-2025	13:12	18-12-2025	15:02	1:50	0.000611	HT BUSHING REPLACEMENT
1631	18-12-2025	Part of : BHAGWATI GARDEN NAWADA	1260	Other Outage	Unplanned Outage	18-12-2025	11:39	18-12-2025	14:02	2:23	0.001986	REPAIRING OF LT AB CABLE
1632	18-12-2025	Part of : R & RK-BLOCK RK MOHAN GARDEN RAZAPUR KHURD	1031	Other Outage	Planned Outage	18-12-2025	12:36	18-12-2025	15:13	2:37	0.000436	3PH HT AB CABLE REPLACEMENT
1633	18-12-2025	Part of : H-BLOCK BHAGWATI GARDEN NAWADA,R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	8	Other Outage	Planned Outage	18-12-2025	11:23	18-12-2025	13:59	2:36	0.001733	DT REPLACEMENT PER DT
1634	18-12-2025	Part of : A-BLOCK MAHAVIR ENCLAVE NAWADA	1136	Other Outage	Planned Outage	18-12-2025	11:38	18-12-2025	13:58	2:20	0.000000	LT CIRCUIT MAINTENANCE
1635	19-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	1270	Other Outage	Unplanned Outage	19-12-2025	15:34	19-12-2025	16:45	1:11	0.000197	REPAIRING OF HVDS CIRCUIT
1636	19-12-2025	Part of : PHASE 1 OM VIHAR NAWADA	763	Other Outage	Planned Outage	19-12-2025	15:37	19-12-2025	16:50	1:13	0.000406	3PH HT AB CABLE REPLACEMENT PER SPAN
1637	19-12-2025	Part of : NAWADA EXTENSION	1528	Other Outage	Planned Outage	19-12-2025	14:13	19-12-2025	16:48	2:35	0.000861	CONDUCTOR REPLACEMENT PER SPAN
1638	19-12-2025	Part of : PHASE 2 OM VIHAR NAWADA	793	Other Outage	Planned Outage	19-12-2025	12:02	19-12-2025	15:17	3:15	0.001083	DT REPLACEMENT
1639	19-12-2025	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK P MOHAN GARDEN RAZAPUR KHURD	1366	Other Outage	Planned Outage	19-12-2025	12:14	19-12-2025	15:06	2:52	0.000478	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
1640	19-12-2025	Part of : BLOCK C VIPIN GARDEN NAWADA	2012	Other Outage	Planned Outage	19-12-2025	11:37	19-12-2025	14:04	2:27	0.002042	3PH HT AB CABLE REPLACEMENT PER SPAN
1641	20-12-2025	Part of : BLOCK K 5 ZAILDAR ENCLAVE HASTSAL,	1586	Other Outage	Planned Outage	20-12-2025	15:39	20-12-2025	16:48	1:09	0.000383	MAINTENANCE OF HVDS CIRCUIT
1642	20-12-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD	760	Other Outage	Planned Outage	20-12-2025	15:12	20-12-2025	16:49	1:37	0.000269	MAINTENANCE OF HVDS CIRCUIT
1643	20-12-2025	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,	129	Other Outage	Planned Outage	20-12-2025	13:58	20-12-2025	16:47	2:49	0.000939	MAINTENANCE OF O/H HT CIRCUIT
1644	20-12-2025	Part of : PHASE 5 OM VIHAR HASTSAL,	3783	Other Outage	Planned Outage	20-12-2025	14:02	20-12-2025	16:46	2:44	0.000911	MAINTENANCE OF RMU
1645	20-12-2025	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA,	1693	Other Outage	Planned Outage	20-12-2025	11:50	20-12-2025	13:59	2:09	0.001792	MAINTENANCE OF HVDS CIRCUIT
1646	20-12-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,	1408	Other Outage	Planned Outage	20-12-2025	11:31	20-12-2025	13:55	2:24	0.000800	MAINTENANCE OF HVDS CIRCUIT
1647	20-12-2025	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	1169	Other Outage	Planned Outage	20-12-2025	11:44	20-12-2025	13:53	2:09	0.000358	MAINTENANCE OF HVDS CIRCUIT
1648	22-12-2025	Part of : R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	1035	Other Outage	Unplanned Outage	22-12-2025	13:27	22-12-2025	14:57	1:30	0.000500	REPAIRING OF HVDS CIRCUIT
1649	22-12-2025	Part of : R1, R5 & WE-BLOCK MOHAN GARDEN RAZAPUR KHURD	2046	Other Outage	Planned Outage	22-12-2025	15:02	22-12-2025	16:23	1:21	0.000450	HT CONDUCTOR REPLACEMENT
1650	22-12-2025	Part of : OM VIHAR PHASE 1 NAWADA	763	Other Outage	Planned Outage	22-12-2025	15:09	22-12-2025	16:22	1:13	0.000406	3PH HT AB CABLE REPLACEMENT
1651	22-12-2025	Part of : OM VIHAR PHASE 1 NAWADA	1016	Other Outage	Planned Outage	22-12-2025	11:36	22-12-2025	13:41	2:05	0.000694	3PH HT AB CABLE REPLACEMENT
1652	22-12-2025	Part of : D,E,H & L-BLOCK BHAGWATI GARDEN NAWADA	2659	Other Outage	Planned Outage	22-12-2025	12:37	22-12-2025	14:48	2:11	0.000728	REPLACEMENT OF CROSS-ARMS AND POLES
1653	22-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	1268	Other Outage	Planned Outage	22-12-2025	11:27	22-12-2025	13:39	2:12	0.000367	3PH HT AB CABLE REPLACEMENT
1654	22-12-2025	Part of : NAWADA EXTENSION	1528	Other Outage	Planned Outage	22-12-2025	13:12	22-12-2025	15:35	2:23	0.000794	HT CONDUCTOR REPLACEMENT
1655	22-12-2025	Part of : F-BLOCK ZAILDAR ENCLAVE NAWADA	715	Other Outage	Planned Outage	22-12-2025	12:12	22-12-2025	14:47	2:35	0.000861	HT CONDUCTOR REPLACEMENT
1656	22-12-2025	Part of : H-BLOCK BHAGWATI GARDEN NAWADA,R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	8	Other Outage	Planned Outage	22-12-2025	13:44	22-12-2025	16:21	2:37	0.000872	HT CONDUCTOR REPLACEMENT
1657	22-12-2025	Part of : BHAGWATI GARDEN NAWADA	1260	Other Outage	Planned Outage	22-12-2025	12:54	22-12-2025	15:32	2:38	0.000878	DT REPLACEMENT
1658	23-12-2025	Part of : BLOCK R1,R5 & WE MOHAN GARDEN RAZAPUR KHURD	2045	Other Outage	Planned Outage	23-12-2025	12:31	23-12-2025	14:30	1:59	0.000331	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1659	23-12-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	424	Other Outage	Planned Outage	23-12-2025	15:08	23-12-2025	16:52	1:44	0.000000	3PH DB REPLACEMENT
1660	23-12-2025	Part of : BLOCK K 5 ZAILDAR ENCLAVE HASTSAL	1586	Other Outage	Planned Outage	23-12-2025	14:49	23-12-2025	17:01	2:12	0.000733	3PH HT AB CABLE REPLACEMENT PER SPAN
1661	23-12-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK F ZAILDAR ENCLAVE NAWADA	1408	Other Outage	Planned Outage	23-12-2025	11:25	23-12-2025	13:49	2:24	0.000800	3PH HT AB CABLE REPLACEMENT PER SPAN
1662	23-12-2025	Part of : BLOCK B1 SEWAK PARK DWARKA	555	Other Outage	Planned Outage	23-12-2025	11:06	23-12-2025	13:54	2:48	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1663	24-12-2025	Part of : BLOCK B1 SEWAK PARK DWARKA,NAWADA EXTENSION NAWADA,BLOCK B SEWAK PARK DWARKA,	2552	Other Outage	Unplanned Outage	24-12-2025	12:57	24-12-2025	14:37	1:40	0.002778	REPLACEMENT OF HVDS TRANSFORMER
1664	24-12-2025	Part of : PHASE 2 OM VIHAR NAWADA,	760	Other Outage	Unplanned Outage	24-12-2025	12:34	24-12-2025	14:04	1:30	0.002500	REPLACEMENT OF HVDS TRANSFORMER
1665	24-12-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA	6148	Other Outage	Planned Outage	24-12-2025	11:53	24-12-2025	13:37	1:44	0.000000	MAINTENANCE OF HVDS
1666	24-12-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	880	Other Outage	Planned Outage	24-12-2025	11:35	24-12-2025	13:36	2:01	0.000000	MAINTENANCE OF LT CIRCUIT
1667	25-12-2025	Part of : Phase 5 Om Vihar Hastal,Phase 1 Om Vihar Nawada	6022	Other Outage	Unplanned Outage	25-12-2025	11:32	25-12-2025	12:28	0:56	0.000731	CABLE FAULT
1668	25-12-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA	135	Other Outage	Planned Outage	25-12-2025	12:20	25-12-2025	14:17	1:57	0.000000	DT REPLACEMENT
1669	26-12-2025	Part of : BHAGWATI GARDEN NAWADA	1260	Other Outage	Unplanned Outage	26-12-2025	12:41	26-12-2025	14:53	2:12	0.001833	REPAIRING OF RMU
1670	26-12-2025	Part of : BLOCK R,S & R 1 MOHAN GARDEN RAZAPUR KHURD	2045	Other Outage	Planned Outage	26-12-2025	14:05	26-12-2025	16:05	2:00	0.000333	3PH HT AB CABLE REPLACEMENT
1671	26-12-2025	Part of : OM VIHAR PHASE 1 NAWADA	763	Other Outage	Planned Outage	26-12-2025	14:50	26-12-2025	16:06	1:16	0.000422	3PH HT AB CABLE REPLACEMENT
1672	26-12-2025	Part of : OM VIHAR PHASE 1 NAWADA	1016	Other Outage	Planned Outage	26-12-2025	11:13	26-12-2025	13:33	2:20	0.000778	3PH HT AB CABLE REPLACEMENT
1673	27-12-2025	Part of : ANAND VIHAR, OM VIHAR PHASE-2, PHASE 1 OM VIHAR NAWADA	3924	Other Outage	Unplanned Outage	27-12-2025	16:34	27-12-2025	17:15	0:41	0.000729	HVDS FAULT
1674	27-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,RAZAPUR KHURD	1092	Other Outage	Planned Outage	27-12-2025	11:08	27-12-2025	13:01	1:53	0.000314	3PH HT AB CABLE REPLACEMENT PER SPAN
1675	27-12-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL	1408	Other Outage	Planned Outage	27-12-2025	12:02	27-12-2025	14:31	2:29	0.000828	3PH HT AB CABLE REPLACEMENT PER SPAN
1676	29-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	1272	Other Outage	Unplanned Outage	29-12-2025	14:38	29-12-2025	16:18	1:40	0.000556	REPAIRING OF HVDS CIRCUIT
1677	29-12-2025	Part of : BHAGWATI GARDEN NAWADA	1260	Other Outage	Unplanned Outage	29-12-2025	12:39	29-12-2025	14:06	1:27	0.001208	REPAIRING OF LT CIRCUIT
1678	29-12-2025	Part of : LAXMI VIHAR NAWADA	555	Other Outage	Planned Outage	29-12-2025	15:31	29-12-2025	17:11	1:40	0.000000	REPLACEMENT OF HT BUSHING ROD
1679	29-12-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,BLOCK WE MOHAN GARDEN RAZAPUR KHURD	1475	Other Outage	Planned Outage	29-12-2025	12:15	29-12-2025	14:34	2:19	0.000386	3PH HT AB CABLE REPLACEMENT PER SPAN
1680	29-12-2025	Part of : BLOCK C VIPIN GARDEN NAWADA	84	Other Outage	Planned Outage	29-12-2025	11:36	29-12-2025	13:51	2:15	0.000000	REPLACEMENT OF HT BUSHING ROD
1681	30-12-2025	Part of : NAWADA EXTENSION	1111	Other Outage	Unplanned Outage	30-12-2025	13:30	30-12-2025	14:53	1:23	0.000461	REPAIRING OF RMU
1682	30-12-2025	Part of : R, RK & WE-BLOCK RK MOHAN GARDEN RAZAPUR KHURD	1031	Other Outage	Planned Outage	30-12-2025	11:59	30-12-2025	14:59	3:00	0.000500	3PH HT AB CABLE REPLACEMENT
1683	30-12-2025	Part of : NAWADA EXTENSION	20	Other Outage	Planned Outage	30-12-2025	11:32	30-12-2025	13:35	2:03	0.000683	3PH HT AB CABLE REPLACEMENT
1684	30-12-2025	Part of : D-BLOCK BHAGWATI GARDEN NAWADA	1795	Other Outage	Planned Outage	30-12-2025	11:06	30-12-2025	13:34	2:28	0.000000	REPLACEMENT OF HT BUSHING ROD
1685	31-12-2025	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD	818	Other Outage	Unplanned Outage	31-12-2025	14:03	31-12-2025	15:52	1:49	0.000303	REPAIRING OF HVDS CIRCUIT
1686	31-12-2025	Part of : BLOCK D, E & H BHAGWATI GARDEN NAWADA	2660	Other Outage	Planned Outage	31-12-2025	15:12	31-12-2025	16:47	1:35	0.000528	CONDUCTOR REPLACEMENT PER SPAN
1687	31-12-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	1	Other Outage	Planned Outage	31-12-2025	11:17	31-12-2025	13:48	2:31	0.000419	3PH DB REPLACEMENT
1688	31-12-2025	Part of : BLOCK C VIPIN GARDEN NAWADA	210	Other Outage	Planned Outage	31-12-2025	11:20	31-12-2025	13:50	2:30	0.000000	REPLACEMENT OF LT BUSHING ROD
1689	01-12-2025	Part of : SHIV VIHAR NANGLOI,BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI,NANGLOI JAT NANGLOI	2992	Other Outage	Unplanned Outage	01-12-2025	15:28	01-12-2025	16:12	0:44	0.000098	CABLE FAULT
1690	01-12-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI,DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	6642	Other Outage	Planned Outage	01-12-2025	11:06	01-12-2025	14:32	3:26	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1691	01-12-2025	Part of : SHRI RAM COLONY,SHIV VIHAR A, B BLOCK,TEK CHAND COLONY,CHANDER VIHAR,SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	1799	Other Outage	Planned Outage	01-12-2025	10:56	01-12-2025	14:23	3:27	0.000000	REPLACEMENT OF FAULTY END BOX
1692	01-12-2025	Part of : NANGLI VIHAR	1058	Other Outage	Planned Outage	01-12-2025	10:54	01-12-2025	14:22	3:28	0.000000	REPLACEMENT OF LT BUSHING ROD
1693	01-12-2025	Part of : BLOCK A 3 MIYANWALI NAGAR PASCHIM VIHAR	204	Other Outage	Planned Outage	01-12-2025	10:55	01-12-2025	14:23	3:28	0.000000	REPLACEMENT OF HT BUSHING ROD
1694	01-12-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	360	Other Outage	Planned Outage	01-12-2025	10:33	01-12-2025	14:21	3:48	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1695	02-12-2025	Part of : UDYOG NAGAR MANGOLPURI	119	Other Outage	Unplanned Outage	02-12-2025	18:44	02-12-2025	19:21	0:37	0.000514	HT SYSTEM FAULT
1696	02-12-2025	Part of : TILANGPUR KOTLA VILLAGE	1460	Other Outage	Planned Outage	02-12-2025	14:37	02-12-2025	16:14	1:37	0.001078	LT CIRCUIT MAINTENANCE
1697	02-12-2025	Part of : BLOCK A MIRA BAGH PASCHIM VIHAR	1276	Other Outage	Planned Outage	02-12-2025	10:59	02-12-2025	13:07	2:08	0.000711	REPLACEMENT OF CROSS-ARMS AND POLES
1698	02-12-2025	Part of : UDAI VIHAR,RANJEET VIHAR	1719	Other Outage	Planned Outage	02-12-2025	11:40	02-12-2025	14:08	2:28	0.000617	3PH HT AB CABLE REPLACEMENT
1699	02-12-2025	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,SH ISHWAR VATIKA ADHYAPAK NAGAR	2217	Other Outage	Planned Outage	02-12-2025	11:07	02-12-2025	14:06	2:59	0.000746	REPLACEMENT OF CROSS-ARMS AND POLES
1700	02-12-2025	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR	156	Other Outage	Planned Outage	02-12-2025	14:32	02-12-2025	16:56	2:24	0.000800	LT CIRCUIT MAINTENANCE
1701	02-12-2025	Part of : CAMP 5 JAWALAPURI PASCHIM VIHAR	680	Other Outage	Planned Outage	02-12-2025	11:35	02-12-2025	14:07	2:32	0.000211	LT CIRCUIT MAINTENANCE
1702	02-12-2025	Part of : DASS GARDEN	488	Other Outage	Planned Outage	02-12-2025	11:00	02-12-2025	14:07	3:07	0.001818	LT CIRCUIT MAINTENANCE
1703	03-12-2025	Part of : CHANDER VIHAR	1309	Other Outage	Planned Outage	03-12-2025	14:28	03-12-2025	16:54	2:26	0.000000	REPLACEMENT OF HT BUSHING ROD
1704	03-12-2025	Part of : GH 6 WHITE APPARTMENTS PASCHIM VIHAR	321	Other Outage	Planned Outage	03-12-2025	12:01	03-12-2025	15:07	3:06	0.000000	REPLACEMENT OF LT BUSHING ROD
1705	03-12-2025	Part of : BLOCK G UDAY VIHAR 2 ADHYAPAK NAGAR NANGLOI	1233	Other Outage	Planned Outage	03-12-2025	10:55	03-12-2025	14:28	3:33	0.001183	REPLACEMENT OF LT BUSHING ROD
1706	03-12-2025	Part of : SUNDER VIHAR PASCHIM VIHAR	1	Other Outage	Planned Outage	03-12-2025	10:58	03-12-2025	13:30	2:32	0.000000	REPLACEMENT OF LT BUSHING ROD
1707	03-12-2025	Part of : NANGLI VIHAR	1036	Other Outage	Planned Outage	03-12-2025	11:01	03-12-2025	14:27	3:26	0.000000	REPLACEMENT OF HT BUSHING ROD
1708	04-12-2025	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR	323	Other Outage	Planned Outage	04-12-2025	14:34	04-12-2025	16:31	1:57	0.000813	REPLACEMENT OF LT BUSHING ROD
1709	04-12-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1075	Other Outage	Planned Outage	04-12-2025	11:06	04-12-2025	14:10	3:04	0.001533	AUXILARY SUPPLY FOR RELAYS
1710	04-12-2025	Part of : RANHOLLA	156	Other Outage	Planned Outage	04-12-2025	11:07	04-12-2025	14:05	2:58	0.000742	REPLACEMENT OF HT BUSHING ROD
1711	04-12-2025	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR	212	Other Outage	Planned Outage	04-12-2025	10:56	04-12-2025	14:07	3:11	0.003183	REPLACEMENT OF LT BUSHING ROD
1712	04-12-2025	Part of : NANGLI VIHAR	1512	Other Outage	Planned Outage	04-12-2025	10:59	04-12-2025	14:06	3:07	0.002078	REPLACEMENT OF HT BUSHING ROD
1713	04-12-2025	Part of : UDYOG NAGAR MANGOLPURI	391	Other Outage	Planned Outage	04-12-2025	11:14	04-12-2025	14:06	2:52	0.000239	REPLACEMENT OF HT BUSHING ROD
1714	05-12-2025	Part of : SHIV VIHAR NANGLOI	1381	Other Outage	Planned Outage	05-12-2025	11:53	05-12-2025	14:55	3:02	0.001011	REPLACEMENT OF HT BUSHING ROD
1715	05-12-2025	Part of : VIRAT APARTMENT PASCHIM VIHAR	40	Other Outage	Planned Outage	05-12-2025	11:21	05-12-2025	13:50	2:29	0.000000	REPLACEMENT OF LT BUSHING ROD
1716	05-12-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	360	Other Outage	Planned Outage	05-12-2025	11:22	05-12-2025	13:51	2:29	0.000000	REPLACEMENT OF LT BUSHING ROD
1717	05-12-2025	Part of : NANGLI VIHAR	550	Other Outage	Planned Outage	05-12-2025	11:00	05-12-2025	14:54	3:54	0.000650	REPLACEMENT OF HT BUSHING ROD
1718	06-12-2025	Part of : RANJEET VIHAR,UDAI VIHAR	2544	Other Outage	Planned Outage	06-12-2025	12:14	06-12-2025	13:34	1:20	0.000222	REPLACEMENT OF HT BUSHING ROD
1719	06-12-2025	Part of : A-BLOCK MIRA BAGH PASCHIM VIHAR	74	Other Outage	Planned Outage	06-12-2025	12:07	06-12-2025	13:32	1:25	0.000236	LT CIRCUIT MAINTENANCE WORK
1720	06-12-2025	Part of : G-BLOCK UDAY VIHAR 2 ADHYAPAK NAGAR NANGLOI	139	Other Outage	Planned Outage	06-12-2025	10:58	06-12-2025	13:33	2:35	0.000431	REPLACEMENT OF HT BUSHING ROD
1721	06-12-2025	Part of : RAIL NEER PLANT NANGLOI	1418	Other Outage	Planned Outage	06-12-2025	11:27	06-12-2025	13:35	2:08	0.000356	REPLACEMENT OF FAULTY END BOX
1722	06-12-2025	Part of : CHANDER VIHAR	1242	Other Outage	Planned Outage	06-12-2025	11:00	06-12-2025	13:32	2:32	0.000422	LT CIRCUIT MAINTENANCE WORK
1723	07-12-2025	Part of : POCKET A NARESH PARK NANGLOI	70	Other Outage	Planned Outage	07-12-2025	11:06	07-12-2025	14:00	2:54	0.000000	REPLACEMENT OF LT BUSHING ROD
1724	07-12-2025	Part of : BLOCK G DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	28	Other Outage	Planned Outage	07-12-2025	11:13	07-12-2025	14:05	2:52	0.000000	REPLACEMENT OF HT BUSHING ROD
1725	08-12-2025	Part of : BLOCK A MIRA BAGH PASCHIM VIHAR,	188	Other Outage	Planned Outage	08-12-2025	11:10	08-12-2025	14:43	3:33	0.000000	REPLACEMENT OF LT BUSHING ROD
1726	08-12-2025	Part of : JAI VIHAR PH-1, PH-3,	651	Other Outage	Planned Outage	08-12-2025	11:05	08-12-2025	14:46	3:41	0.000000	REPLACEMENT OF LT BUSHING ROD
1727	08-12-2025	Part of : SHRI RAM COLONY,SHIV VIHAR A, B BLOCK,TEK CHAND COLONY,CHANDER VIHAR,SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,	1799	Other Outage	Planned Outage	08-12-2025	10:32	08-12-2025	14:41	4:09	0.001729	REPLACEMENT OF FAULTY END BOX
1728	08-12-2025	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR,	1716	Other Outage	Planned Outage	08-12-2025	11:05	08-12-2025	14:45	3:40	0.000000	REPLACEMENT OF HT BUSHING ROD
1729	09-12-2025	Part of : BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,BLOCK A, B & I NARESH PARK EXTENSION NANGLOI,BLOCK D KUNWAR SINGH NAGAR KAMARUDDIN NAGAR	270	Other Outage	Planned Outage	09-12-2025	10:42	09-12-2025	14:59	4:17	0.002499	GUARD WIRE LACS INSTALLTION PER SPAN
1730	09-12-2025	Part of : UDAI VIHAR	1340	Other Outage	Planned Outage	09-12-2025	11:56	09-12-2025	15:45	3:49	0.000000	REPLACEMENT OF HT BUSHING ROD
1731	09-12-2025	Part of : ADHYAPAK NAGAR NANGLOI	1033	Other Outage	Planned Outage	09-12-2025	10:48	09-12-2025	15:03	4:15	0.001771	REPLACEMENT OF HT BUSHING ROD
1732	09-12-2025	Part of : GURUNANAK VIHAR	402	Other Outage	Planned Outage	09-12-2025	10:59	09-12-2025	15:02	4:03	0.000675	REPLACEMENT OF LT BUSHING ROD
1733	09-12-2025	Part of : BLOCK A JAWALAPURI PASCHIM VIHAR	974	Other Outage	Planned Outage	09-12-2025	11:42	09-12-2025	14:18	2:36	0.000433	REPLACEMENT OF HT BUSHING ROD
1734	09-12-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	292	Other Outage	Planned Outage	09-12-2025	10:57	09-12-2025	14:20	3:23	0.000564	REPLACEMENT OF HT BUSHING ROD
1735	10-12-2025	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR,TILANGPUR KOTLA VILLAGE,RISHAL GARDEN,TILANGPUR KOTLA,RANHOLLA	8727	Other Outage	Planned Outage	10-12-2025	10:59	10-12-2025	13:20	2:21	0.001175	GUARD WIRE LACS INSTALLTION
1736	10-12-2025	Part of : RANJEET VIHAR & UDAI VIHAR	2581	Other Outage	Planned Outage	10-12-2025	11:38	10-12-2025	14:21	2:43	0.000679	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1737	10-12-2025	Part of : JAI VIHAR PH-1 & 3,RANHOLLA,TILANGPUR KOTLA VILLAGE,PRATAP VIHAR	2674	Other Outage	Planned Outage	10-12-2025	11:00	10-12-2025	13:32	2:32	0.001478	GUARD WIRE LACS INSTALLTION
1738	10-12-2025	Part of : E-BLOCK VANDANA VIHAR NANGLOI	1646	Other Outage	Planned Outage	10-12-2025	10:43	10-12-2025	14:21	3:38	0.001514	LT CIRCUIT MAINTENANCE
1739	10-12-2025	Part of : B-BLOCK JAWALAPURI PASCHIM VIHAR	712	Other Outage	Planned Outage	10-12-2025	11:29	10-12-2025	14:20	2:51	0.000475	LT CIRCUIT MAINTENANCE
1740	11-12-2025	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI	683	Other Outage	Planned Outage	11-12-2025	12:06	11-12-2025	13:44	1:38	0.000000	REPLACEMET OF FAULTY END BOX
1741	11-12-2025	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	758	Other Outage	Planned Outage	11-12-2025	11:59	11-12-2025	13:21	1:22	0.000342	REPLACEMET OF HT BUSHING ROD
1742	11-12-2025	Part of : UDAI VIHAR	1340	Other Outage	Planned Outage	11-12-2025	10:56	11-12-2025	13:43	2:47	0.000000	REPLACEMET OF HT BUSHING ROD
1743	11-12-2025	Part of : JAI VIHAR BAPROLA,JAI VIHAR PH-1, BAPROLA VILLAGE,RAJIV RATAN AWAS FLATS	6889	Other Outage	Planned Outage	11-12-2025	10:57	11-12-2025	13:42	2:45	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1744	11-12-2025	Part of : RANHOLLA	162	Other Outage	Planned Outage	11-12-2025	11:00	11-12-2025	13:24	2:24	0.000600	REPLACEMET OF HT BUSHING ROD
1745	11-12-2025	Part of : BLOCK GH 14 PASCHIM VIHAR	109	Other Outage	Planned Outage	11-12-2025	10:58	11-12-2025	13:26	2:28	0.000411	REPLACEMENT OF LT BUSHING ROD
1746	12-12-2025	Part of : SHIV VIHAR NANGLOI,VANDANA VIHAR NANGLOI,BLOCK D VANDANA VIHAR NANGLOI,BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI,RAO VIHAR NANGLOI,HANUMAN ENCLAVE NANGLOI	6590	Other Outage	Unplanned Outage	12-12-2025	14:50	12-12-2025	15:34	0:44	0.000770	CABLE FAULT
1747	12-12-2025	Part of : BLOCK 13 SUNDER VIHAR PASCHIM VIHAR,	434	Other Outage	Unplanned Outage	12-12-2025	14:24	12-12-2025	15:33	1:09	0.000000	LT MOBILE TRANSFORMER REPLACEMENT
1748	12-12-2025	Part of : VANDANA VIHAR NANGLOI,	1936	Other Outage	Planned Outage	12-12-2025	12:03	12-12-2025	14:42	2:39	0.000883	3PH HT AB CABLE REPLACEMENT PER SPAN
1749	12-12-2025	Part of : PRADHAN ENCLAVE,	78	Other Outage	Planned Outage	12-12-2025	10:45	12-12-2025	14:44	3:59	0.000000	REPLACEMENT OF LT BUSHING ROD
1750	13-12-2025	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,BHERA ENCLAVE PASCHIM VIHAR,NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	1027	Other Outage	Planned Outage	13-12-2025	13:57	13-12-2025	16:14	2:17	0.000000	GUARD WIRES SAGGING PER SPAN
1751	13-12-2025	Part of : BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI	615	Other Outage	Planned Outage	13-12-2025	12:11	13-12-2025	15:35	3:24	0.000000	REPLACEMENT OF FAULTY END BOX
1752	13-12-2025	Part of : RANJEET VIHAR,UDAI VIHAR	2581	Other Outage	Planned Outage	13-12-2025	11:08	13-12-2025	15:00	3:52	0.000000	LT AB SAGGING PER SPAN
1753	13-12-2025	Part of : POCKET B NARESH PARK NANGLOI,BLOCK B NARESH PARK EXTENSION NANGLOI,NARESH PARK NANGLOI,BLOCK A NARESH PARK EXTENSION NANGLOI	665	Other Outage	Planned Outage	13-12-2025	10:52	13-12-2025	14:59	4:07	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1754	13-12-2025	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR	433	Other Outage	Planned Outage	13-12-2025	10:56	13-12-2025	13:58	3:02	0.000000	SUB STATION CLEANING
1755	13-12-2025	Part of : JAI VIHAR BAPROLA	1287	Other Outage	Planned Outage	13-12-2025	11:01	13-12-2025	14:57	3:56	0.000000	REPLACEMENT OF LT BUSHING ROD
1756	14-12-2025	Part of : UDAI VIHAR & RANJEET VIHAR	1662	Other Outage	Planned Outage	14-12-2025	12:10	14-12-2025	15:18	3:08	0.000783	REPLACEMENT OF HT BUSHING ROD
1757	14-12-2025	Part of : NANGLOI JAT NANGLOI	597	Other Outage	Planned Outage	14-12-2025	12:54	14-12-2025	16:23	3:29	0.000581	LT CIRCUIT MAINTENANCE
1758	14-12-2025	Part of : A-BLOCK DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	4	Other Outage	Planned Outage	14-12-2025	10:54	14-12-2025	14:06	3:12	0.000533	LT CIRCUIT MAINTENANCE
1759	15-12-2025	Part of : JAI VIHAR PH-1, RANHOLLA, AKASH VIHAR, TILANGPUR KOTLA VILLAGE, PRATAP VIHAR	2677	Other Outage	Unplanned Outage	15-12-2025	05:15	15-12-2025	05:57	0:42	0.000000	TRANSFORMER FAULTY
1760	15-12-2025	Part of : JAI VIHAR PH-1, RANHOLLA, AKASH VIHAR, TILANGPUR KOTLA VILLAGE, PRATAP VIHAR	2675	Other Outage	Unplanned Outage	15-12-2025	03:29	15-12-2025	04:17	0:48	0.000640	TRANSFORMER FAULTY
1761	15-12-2025	Part of : UDYOG NAGAR MANGOLPURI, BLOCK G DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	213	Other Outage	Unplanned Outage	15-12-2025	01:03	15-12-2025	01:49	0:46	0.000511	FAULT IN HT CONSUMER PANEL (GREEN LOUNG)
1762	15-12-2025	Part of : BLOCK RR MIYANWALI NAGAR PASCHIM VIHAR	194	Other Outage	Planned Outage	15-12-2025	15:47	15-12-2025	17:00	1:13	0.000406	REPLACEMET OF HT BUSHING ROD
1763	15-12-2025	Part of : TILANGPUR KOTLA VILLAGE	294	Other Outage	Planned Outage	15-12-2025	11:48	15-12-2025	13:19	1:31	0.000506	REPLACEMET OF HT BUSHING ROD
1764	15-12-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1816	Other Outage	Planned Outage	15-12-2025	11:34	15-12-2025	14:26	2:52	0.001194	REPLACEMET OF FAULTY END BOX,SF6 GAS FILLING
1765	15-12-2025	Part of : BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI	1622	Other Outage	Planned Outage	15-12-2025	11:36	15-12-2025	14:24	2:48	0.001167	REPLACEMET OF FAULTY END BOX
1766	15-12-2025	Part of : BLOCK GH 8 PASCHIM VIHAR	228	Other Outage	Planned Outage	15-12-2025	13:59	15-12-2025	16:26	2:27	0.000817	REPLACEMET OF HT BUSHING ROD
1767	15-12-2025	Part of : VIRAT APARTMENT PASCHIM VIHAR	34	Other Outage	Planned Outage	15-12-2025	11:02	15-12-2025	13:17	2:15	0.000563	REPLACEMET OF HT BUSHING ROD
1768	15-12-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	292	Other Outage	Planned Outage	15-12-2025	10:39	15-12-2025	13:15	2:36	0.000433	REPLACEMET OF HT BUSHING ROD
1769	16-12-2025	Part of : BLOCK A MIRA BAGH PASCHIM VIHAR,	318	Other Outage	Planned Outage	16-12-2025	12:23	16-12-2025	15:33	3:10	0.000528	MAINTENANCE OF LT CIRCUIT
1770	16-12-2025	Part of : RANHOLLA,	162	Other Outage	Planned Outage	16-12-2025	11:21	16-12-2025	14:01	2:40	0.000444	MAINTENANCE OF LT TRANSFORMER
1771	16-12-2025	Part of : SATYAM VIHAR,	327	Other Outage	Planned Outage	16-12-2025	11:20	16-12-2025	13:59	2:39	0.000442	MAINTENANCE OF LT TRANSFORMER
1772	16-12-2025	Part of : UDYOG NAGAR MANGOLPURI,	391	Other Outage	Planned Outage	16-12-2025	11:34	16-12-2025	13:58	2:24	0.000400	MAINTENANCE OF LT TRANSFORMER
1773	16-12-2025	Part of : NANGLOI JAT NANGLOI,	1474	Other Outage	Planned Outage	16-12-2025	11:02	16-12-2025	14:00	2:58	0.000742	MAINTENANCE OF RMU

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1774	17-12-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	715	Other Outage	Planned Outage	17-12-2025	11:10	17-12-2025	14:28	3:18	0.000000	REPLACEMENT OF FAULTY END BOX
1775	17-12-2025	Part of : CHANDER VIHAR	797	Other Outage	Planned Outage	17-12-2025	14:04	17-12-2025	16:55	2:51	0.000000	LT AB SAGGING PER SPAN
1776	17-12-2025	Part of : NILOTHI VILLAGE	272	Other Outage	Planned Outage	17-12-2025	11:07	17-12-2025	14:07	3:00	0.000000	REPLACEMENT OF HT BUSHING ROD
1777	17-12-2025	Part of : RAIL NEER PLANT NANGLOI	295	Other Outage	Planned Outage	17-12-2025	11:09	17-12-2025	14:27	3:18	0.000000	REPLACEMENT OF HT BUSHING ROD
1778	17-12-2025	Part of : RANHOLLA	131	Other Outage	Planned Outage	17-12-2025	11:13	17-12-2025	14:08	2:55	0.000000	REPLACEMENT OF LT BUSHING ROD
1779	17-12-2025	Part of : EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR	428	Other Outage	Planned Outage	17-12-2025	11:02	17-12-2025	14:25	3:23	0.000000	REPLACEMENT OF HT BUSHING ROD
1780	18-12-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1817	Other Outage	Planned Outage	18-12-2025	10:59	18-12-2025	14:20	3:21	0.001117	RELAY REPLACEMENT/VPI/FPI,REPLACEMENT OF FAULTY END BOX
1781	18-12-2025	Part of : JAI VIHAR BAPROLA	989	Other Outage	Planned Outage	18-12-2025	10:53	18-12-2025	13:55	3:02	0.000506	LT CIRCUIT MAINTENANCE
1782	18-12-2025	Part of : UDYOG NAGAR MANGOLPURI	213	Other Outage	Planned Outage	18-12-2025	11:01	18-12-2025	13:54	2:53	0.000481	LT CIRCUIT MAINTENANCE
1783	18-12-2025	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI	1108	Other Outage	Planned Outage	18-12-2025	10:59	18-12-2025	13:52	2:53	0.000481	LT CIRCUIT MAINTENANCE
1784	19-12-2025	Part of : UDAI VIHAR	1340	Other Outage	Planned Outage	19-12-2025	12:40	19-12-2025	13:18	0:38	0.000000	REPLACEMET OF HT BUSHING ROD
1785	19-12-2025	Part of : VIRAT APARTMENT PASCHIM VIHAR,BLOCK C JAWALAPURI PASCHIM VIHAR	2661	Other Outage	Planned Outage	19-12-2025	11:59	19-12-2025	13:17	1:18	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1786	19-12-2025	Part of : BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI	917	Other Outage	Planned Outage	19-12-2025	10:51	19-12-2025	13:14	2:23	0.000794	REPLACEMENT OF LT BUSHING ROD
1787	19-12-2025	Part of : DASS GARDEN	676	Other Outage	Planned Outage	19-12-2025	11:04	19-12-2025	13:14	2:10	0.000722	REPLACEMET OF HT BUSHING ROD
1788	19-12-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	293	Other Outage	Planned Outage	19-12-2025	10:26	19-12-2025	13:15	2:49	0.000704	REPLACEMET OF HT BUSHING ROD
1789	19-12-2025	Part of : BLOCK 1 SUNDER VIHAR PASCHIM VIHAR	150	Other Outage	Planned Outage	19-12-2025	11:01	19-12-2025	13:16	2:15	0.000563	REPLACEMET OF HT BUSHING ROD
1790	20-12-2025	Part of : BLOCK 2C NANGLOI EXTENSION NANGLOI,NANGLOI JAT NANGLOI	2339	Other Outage	Unplanned Outage	20-12-2025	05:34	20-12-2025	05:51	0:17	0.000595	CABLE FAULT
1791	20-12-2025	Part of : BLOCK D VANDANA VIHAR NANGLOI,VANDANA VIHAR NANGLOI,BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI	5525	Other Outage	Unplanned Outage	20-12-2025	04:34	20-12-2025	05:12	0:38	0.000274	HVDS FAULT
1792	20-12-2025	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR	1124	Other Outage	Planned Outage	20-12-2025	10:47	20-12-2025	12:32	1:45	0.000292	MAINTENANCE OF O/H HT CIRCUIT
1793	20-12-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,	2195	Other Outage	Planned Outage	20-12-2025	12:26	20-12-2025	15:38	3:12	0.000533	MAINTENANCE OF RMU
1794	20-12-2025	Part of : GURUNANAK VIHAR,	416	Other Outage	Planned Outage	20-12-2025	11:46	20-12-2025	14:19	2:33	0.000213	MAINTENANCE OF TRANSFORMER
1795	20-12-2025	Part of : TILANGPUR KOTLA VILLAGE,	1119	Other Outage	Planned Outage	20-12-2025	11:00	20-12-2025	14:19	3:19	0.000553	MAINTENANCE OF LT TRANSFORMER
1796	20-12-2025	Part of : BLOCK GH5 PASCHIM VIHAR,	615	Other Outage	Planned Outage	20-12-2025	11:21	20-12-2025	14:18	2:57	0.000492	MAINTENANCE OF LT TRANSFORMER
1797	21-12-2025	Part of : BLOCK RR MIYANWALI NAGAR PASCHIM VIHAR	416	Other Outage	Unplanned Outage	21-12-2025	14:06	21-12-2025	14:55	0:49	0.000000	REPAIRING OF HVDS CIRCUIT
1798	21-12-2025	Part of : NARESH PARK NANGLOI	526	Other Outage	Planned Outage	21-12-2025	14:08	21-12-2025	15:42	1:34	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1799	21-12-2025	Part of : UDAI VIHAR	1340	Other Outage	Planned Outage	21-12-2025	14:01	21-12-2025	16:45	2:44	0.000000	REPLACEMENT OF HT BUSHING ROD
1800	22-12-2025	Part of : A & H-BLOCK DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI, A 3,C & NS-BLOCK MIYANWALI NAGAR PASCHIM VIHAR	1913	Other Outage	Unplanned Outage	22-12-2025	16:25	22-12-2025	16:40	0:15	0.000000	REPAIRING OF LT AB CABLE
1801	22-12-2025	Part of : SIHV RAM PARK,DDA PARK NIHAL VIHAR,ADHYAPAK NAGAR,G-BLOCK UDAY VIHAR-2	5341	Other Outage	Planned Outage	22-12-2025	14:32	22-12-2025	17:26	2:54	0.001208	REPLACEMENT OF FAULTY END BOX
1802	22-12-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1532	Other Outage	Planned Outage	22-12-2025	11:16	22-12-2025	14:11	2:55	0.000729	REPLACEMENT OF HT BUSHING ROD
1803	22-12-2025	Part of : GH 12-BLOCK PASCHIM VIHAR	303	Other Outage	Planned Outage	22-12-2025	11:06	22-12-2025	14:09	3:03	0.000508	LT CIRCUIT MAINTENANCE WORK
1804	22-12-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	293	Other Outage	Planned Outage	22-12-2025	10:33	22-12-2025	14:10	3:37	0.000603	LT CIRCUIT MAINTENANCE WORK
1805	22-12-2025	Part of : BHERA ENCLAVE PASCHIM VIHAR	344	Other Outage	Planned Outage	22-12-2025	11:05	22-12-2025	14:10	3:05	0.000514	LT CIRCUIT MAINTENANCE WORK
1806	22-12-2025	Part of : TILANGPUR KOTLA VILLAGE	657	Other Outage	Planned Outage	22-12-2025	11:03	22-12-2025	14:01	2:58	0.000494	LT CIRCUIT MAINTENANCE WORK
1807	23-12-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1452	Other Outage	Planned Outage	23-12-2025	15:23	23-12-2025	16:55	1:32	0.000511	REPLACEMET OF HT BUSHING ROD
1808	23-12-2025	Part of : JAI VIHAR PH-1,RANHOLLA,TILANGPUR KOTLA VILLAGE,PRATAP VIHAR	2679	Other Outage	Planned Outage	23-12-2025	14:01	23-12-2025	17:16	3:15	0.000000	CONDUCTOR REPLACEMET PER SPAN
1809	23-12-2025	Part of : RAJIV RATAN AWAS FLATS	145	Other Outage	Planned Outage	23-12-2025	11:07	23-12-2025	13:42	2:35	0.000000	REPLACEMET OF HT BUSHING ROD
1810	23-12-2025	Part of : CAMP 5 JAWALAPURI PASCHIM VIHAR	680	Other Outage	Planned Outage	23-12-2025	10:55	23-12-2025	13:39	2:44	0.000911	REPLACEMET OF HT BUSHING ROD
1811	24-12-2025	Part of : BLOCK A NARESH PARK EXTENSION NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI	4320	Other Outage	Planned Outage	24-12-2025	14:52	24-12-2025	16:24	1:32	0.000000	MAINTENANCE OF HT O/H CIRCUIT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1812	24-12-2025	Part of : RAJIV RATAN AWAS FLATS,	186	Other Outage	Planned Outage	24-12-2025	11:44	24-12-2025	14:25	2:41	0.000671	MAINTENANCE OF LT TRANSFORMER
1813	24-12-2025	Part of : RANJEET VIHAR,UDAI VIHAR,	2581	Other Outage	Planned Outage	24-12-2025	11:12	24-12-2025	14:26	3:14	0.001347	MAINTENANCE OF TRANSFORMER
1814	26-12-2025	Part of : HANUMAN ENCLAVE,SHIV VIHAR,BLOCK A & B JAWALAPURI PASCHIM VIHAR,RAO VIHAR NANGLOI	6581	Other Outage	Planned Outage	26-12-2025	12:06	26-12-2025	15:00	2:54	0.000242	GUARD WIRE LACS INSTALLTION
1815	26-12-2025	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI	1	Other Outage	Planned Outage	26-12-2025	11:05	26-12-2025	14:00	2:55	0.001069	3PH HT AB CABLE REPLACEMENT
1816	26-12-2025	Part of : BHERA ENCLAVE PASCHIM VIHAR	350	Other Outage	Planned Outage	26-12-2025	14:59	26-12-2025	17:49	2:50	0.000944	LT CIRCUIT MAINTENANCE
1817	26-12-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1580	Other Outage	Planned Outage	26-12-2025	11:29	26-12-2025	14:07	2:38	0.000483	LT CIRCUIT MAINTENANCE
1818	26-12-2025	Part of : RISALA GARDEN NILOTHI	320	Other Outage	Planned Outage	26-12-2025	11:10	26-12-2025	14:04	2:54	0.002417	LT CIRCUIT MAINTENANCE
1819	26-12-2025	Part of : BLOCK GH 9 PASCHIM VIHAR	40	Other Outage	Planned Outage	26-12-2025	11:46	26-12-2025	13:59	2:13	0.000296	LT CIRCUIT MAINTENANCE
1820	27-12-2025	Part of : SHANKAR GARDEN, PIRA GARHI PASCHIM VIHAR, EKTA ENCLAVE, RICHMOND SCHOOL (HTC)	1137	Other Outage	Unplanned Outage	27-12-2025	12:37	27-12-2025	13:10	0:33	0.003053	HT SYSTEM FAULT
1821	27-12-2025	Part of : NATIONAL MARKET PIRA GARHI, BHERA ENCLAVE PASCHIM VIHAR, PIRA GARHI VILLAGE PASCHIM VIHAR	1021	Other Outage	Unplanned Outage	27-12-2025	11:49	27-12-2025	12:23	0:34	0.002116	CABLE FAULT
1822	27-12-2025	Part of : UDAI VIHAR,RANJEET VIHAR	1665	Other Outage	Planned Outage	27-12-2025	12:25	27-12-2025	13:51	1:26	0.000000	REPLACEMET OF FAULTY END BOX
1823	27-12-2025	Part of : RANJEET VIHAR	366	Other Outage	Planned Outage	27-12-2025	11:01	27-12-2025	12:27	1:26	0.000358	REPLACEMET OF HT BUSHING ROD
1824	27-12-2025	Part of : BLOCK 13 SUNDER VIHAR PASCHIM VIHAR	404	Other Outage	Planned Outage	27-12-2025	11:06	27-12-2025	13:50	2:44	0.000000	GUARD WIRES SAGGING PER SPAN
1825	27-12-2025	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	1094	Other Outage	Planned Outage	27-12-2025	10:48	27-12-2025	13:39	2:51	0.000950	REPLACEMENT OF LT BUSHING ROD
1826	28-12-2025	Part of : BLOCK G DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI,	28	Other Outage	Planned Outage	28-12-2025	11:38	28-12-2025	15:44	4:06	0.000683	REPLACEMENT OF LT BUSHING ROD
1827	28-12-2025	Part of : UDAI VIHAR,	1341	Other Outage	Planned Outage	28-12-2025	11:32	28-12-2025	15:42	4:10	0.000694	REPLACEMENT OF LT BUSHING ROD
1828	28-12-2025	Part of : NARESH PARK NANGLOI,	93	Other Outage	Planned Outage	28-12-2025	11:37	28-12-2025	15:43	4:06	0.000683	REPLACEMET OF LT BUSHING ROD
1829	29-12-2025	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	429	Other Outage	Planned Outage	29-12-2025	10:58	29-12-2025	14:06	3:08	0.002089	REPLACEMENT OF HT BUSHING INULATOR
1830	29-12-2025	Part of : DASS GARDEN	595	Other Outage	Planned Outage	29-12-2025	11:06	29-12-2025	14:31	3:25	0.000000	REPLACEMENT OF LT BUSHING ROD
1831	29-12-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	210	Other Outage	Planned Outage	29-12-2025	11:05	29-12-2025	14:17	3:12	0.000000	REPLACEMENT OF HT BUSHING ROD
1832	29-12-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1940	Other Outage	Planned Outage	29-12-2025	11:05	29-12-2025	14:48	3:43	0.000000	REPLACEMENT OF HT BUSHING ROD
1833	29-12-2025	Part of : BLOCK GH 9 PASCHIM VIHAR	118	Other Outage	Planned Outage	29-12-2025	11:00	29-12-2025	14:30	3:30	0.001750	REPLACEMENT OF HT BUSHING ROD
1834	30-12-2025	Part of : RISALA GARDEN NILOTHI	167	Other Outage	Planned Outage	30-12-2025	11:09	30-12-2025	13:54	2:45	0.001833	LT CIRCUIT MAINTENANCE WORK
1835	30-12-2025	Part of : RAO VIHAR NANGLOI	1413	Other Outage	Planned Outage	30-12-2025	10:56	30-12-2025	14:14	3:18	0.001375	LT CIRCUIT MAINTENANCE WORK
1836	30-12-2025	Part of : B-BLOCK JAWALAPURI PASCHIM VIHAR	339	Other Outage	Planned Outage	30-12-2025	11:07	30-12-2025	14:13	3:06	0.000258	LT CIRCUIT MAINTENANCE WORK
1837	30-12-2025	Part of : GH 8-BLOCK PASCHIM VIHAR	197	Other Outage	Planned Outage	30-12-2025	11:09	30-12-2025	14:10	3:01	0.000754	LT CIRCUIT MAINTENANCE WORK
1838	31-12-2025	Part of : BLOCK GH 9 & 14 PASCHIM VIHAR,AMBIKA VIHAR PASCHIM VIHAR, LAKE VIEW APPARTMENT	1233	Other Outage	Unplanned Outage	31-12-2025	07:10	31-12-2025	07:55	0:45	0.000013	HT SYSTEM FAULT
1839	31-12-2025	Part of : BLOCK GH 8 PASCHIM VIHAR,NANGLOI SAIYED VILLAGE PASCHIM VIHAR	1623	Other Outage	Planned Outage	31-12-2025	12:29	31-12-2025	14:48	2:19	0.000000	GUARD WIRES SAGGING PER SPAN
1840	31-12-2025	Part of : BLOCK G UDAY VIHAR 2 ADHYAPAK NAGAR NANGLOI	139	Other Outage	Planned Outage	31-12-2025	10:52	31-12-2025	13:52	3:00	0.001000	REPLACEMET OF HT BUSHING ROD
1841	31-12-2025	Part of : NANGLI VIHAR	1063	Other Outage	Planned Outage	31-12-2025	10:59	31-12-2025	13:51	2:52	0.000956	CONDUCTOR REPLACEMENT PER SPAN,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE
1842	01-12-2025	Part of : AGARWAL COLONY HAIBUTPUR	32	Other Outage	Planned Outage	01-12-2025	15:32	01-12-2025	16:01	0:29	0.000000	REPLACEMENT OF LT BUSHING ROD
1843	01-12-2025	Part of : PREM NAGAR PAPRAWAT VILLAGE	196	Other Outage	Planned Outage	01-12-2025	11:40	01-12-2025	14:45	3:05	0.001542	REPLACEMENT OF LT BUSHING ROD
1844	01-12-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH EXTENSION NAJAFGARH	842	Other Outage	Planned Outage	01-12-2025	11:48	01-12-2025	14:51	3:03	0.003050	REPLACEMENT OF HT BUSHING ROD
1845	01-12-2025	Part of : SAMTA ENCLAVE QUTUB VIHAR	957	Other Outage	Planned Outage	01-12-2025	11:17	01-12-2025	14:27	3:10	0.003167	3PH HT AB CABLE REPLACEMENT PER SPAN
1846	02-12-2025	Part of : SHYAM ENCLAVE,BLOCK E SHYAM VIHAR I NAJAFGARH	773	Other Outage	Planned Outage	02-12-2025	14:24	02-12-2025	16:35	2:11	0.000000	3PH HT AB CABLE REPLACEMENT
1847	02-12-2025	Part of : PIND WALA KHURD VILLAGE	198	Other Outage	Planned Outage	02-12-2025	10:43	02-12-2025	13:24	2:41	0.001342	REPLACEMET OF HT BUSHING ROD
1848	03-12-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	534	Other Outage	Planned Outage	03-12-2025	13:15	03-12-2025	16:05	2:50	0.001417	REPLACEMENT OF LT BUSHING ROD
1849	03-12-2025	Part of : DHARAMPURA NAJAFGARH	835	Other Outage	Planned Outage	03-12-2025	13:13	03-12-2025	16:04	2:51	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1850	03-12-2025	Part of : BADUSARAI	395	Other Outage	Planned Outage	03-12-2025	10:20	03-12-2025	14:03	3:43	0.001549	INSTALLATION OF PHASE SEPERATOR PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1851	03-12-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH,BLOCK Q NEW ROSHAN PURA NAJAFGARH	912	Other Outage	Planned Outage	03-12-2025	10:10	03-12-2025	13:03	2:53	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1852	04-12-2025	Part of : NAJAFGARH VILLAGE,TODARMAL COLONY NAJAFGARH,BLOCK A2 ROSHAN GARDEN MASUDABAD NAJAFGARH,ROSHAN PURA NAJAFGARH,ROSHAN VIHAR NAJAFGARH,PREM NAGAR NAJAFGARH	2922	Other Outage	Unplanned Outage	04-12-2025	14:47	04-12-2025	15:12	0:25	0.000000	REPAIRING OF RMU
1853	04-12-2025	Part of : SANGAM VIHAR DHARAMPURA NAJAFGARH,DHARAMPURA NAJAFGARH	1005	Other Outage	Unplanned Outage	04-12-2025	12:22	04-12-2025	12:57	0:35	0.000243	REFILLING OIL IN TRANSFORMER
1854	04-12-2025	Part of : BLOCK E SHYAM VIHAR I NAJAFGARH,DINARPUR EXTENSION NAJAFGARH,DURGA PARK NAJAFGARH	1498	Other Outage	Planned Outage	04-12-2025	16:27	04-12-2025	17:28	1:01	0.000000	REPLACEMENT OF LT BUSHING ROD
1855	04-12-2025	Part of : NAJAFGARH VILLAGE	1244	Other Outage	Planned Outage	04-12-2025	14:14	04-12-2025	17:02	2:48	0.000000	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER
1856	04-12-2025	Part of : GOYLA KHURD	517	Other Outage	Planned Outage	04-12-2025	12:48	04-12-2025	15:05	2:17	0.000000	1PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1857	04-12-2025	Part of : SOMESH VIHAR CHAWLA	432	Other Outage	Planned Outage	04-12-2025	10:18	04-12-2025	13:24	3:06	0.000258	3PH HT AB CABLE REPLACEMENT PER SPAN
1858	04-12-2025	Part of : ASALATPUR KHAWAD	19	Other Outage	Planned Outage	04-12-2025	11:25	04-12-2025	14:15	2:50	0.001417	REPLACEMENT OF LT BUSHING ROD
1859	04-12-2025	Part of : SAMTA ENCLAVE QUTUB VIHAR	1179	Other Outage	Planned Outage	04-12-2025	11:45	04-12-2025	15:06	3:21	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1860	05-12-2025	Part of : SHIV NAGAR DICHAON KALAN	227	Other Outage	Planned Outage	05-12-2025	14:21	05-12-2025	16:17	1:56	0.000000	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER
1861	05-12-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	524	Other Outage	Planned Outage	05-12-2025	13:13	05-12-2025	15:10	1:57	0.000000	FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1862	05-12-2025	Part of : JHARODA KALAN	13	Other Outage	Planned Outage	05-12-2025	14:23	05-12-2025	16:55	2:32	0.001267	REPLACEMENT OF LT BUSHING ROD
1863	05-12-2025	Part of : CHAWLA	185	Other Outage	Planned Outage	05-12-2025	12:29	05-12-2025	15:09	2:40	0.000000	3PH DB REPLACEMENT,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1864	05-12-2025	Part of : GOYALA DAIRY QUTUB VIHAR,GOYLA KHURD,BLOCK A GOYLA VIHAR GOYLA KHURD,BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR	1	Other Outage	Planned Outage	05-12-2025	12:33	05-12-2025	15:01	2:28	0.002261	3PH HT AB CABLE REPLACEMENT PER SPAN
1865	05-12-2025	Part of : ROSHANPURA COLONY NAJAFGARH	813	Other Outage	Planned Outage	05-12-2025	10:14	05-12-2025	12:51	2:37	0.000000	REPLACEMENT OF LT BUSHING ROD
1866	06-12-2025	Part of : DURGA VIHAR 1 & 2,TODARMAL COLONY,DURGA VIHAR,DATA RAM PARK DINPUR,SHANTI VIHAR,MUNIRKA KUNJ,ROSHAN VIHA,NAJAFGARH VILLAGE	3783	Other Outage	Unplanned Outage	06-12-2025	19:04	06-12-2025	19:29	0:25	0.000000	BIRDAGE
1867	06-12-2025	Part of : A-BLOCK POCHANPUR DWARKA	1110	Other Outage	Planned Outage	06-12-2025	11:07	06-12-2025	12:10	1:03	0.000035	REPLACEMENT OF HT BUSHING ROD
1868	06-12-2025	Part of : B-BLOCK & POCKET 1 SECTOR 19 DWARKA,POCKET 1 BEES SUTRI COLONY	1096	Other Outage	Planned Outage	06-12-2025	12:44	06-12-2025	15:37	2:53	0.001442	REPLACEMENT OF HT BUSHING ROD
1869	06-12-2025	Part of : QUTUB VIHAR PHASE 2	615	Other Outage	Planned Outage	06-12-2025	10:23	06-12-2025	13:19	2:56	0.003667	REPLACEMENT OF HT BUSHING ROD
1870	06-12-2025	Part of : PREM VIHAR COLONY GHASIPURA	847	Other Outage	Planned Outage	06-12-2025	10:53	06-12-2025	13:30	2:37	0.000000	REPLACEMENT OF HT BUSHING ROD
1871	07-12-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI	27	Other Outage	Planned Outage	07-12-2025	11:44	07-12-2025	13:33	1:49	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1872	07-12-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	64	Other Outage	Planned Outage	07-12-2025	11:58	07-12-2025	14:37	2:39	0.000000	REPLACEMENT OF HT BUSHING ROD
1873	08-12-2025	Part of : DHULSIRAS VILLAGE DWARKA,	664	Other Outage	Planned Outage	08-12-2025	13:47	08-12-2025	15:14	1:27	0.000483	REPLACEMENT OF LT BUSHING ROD
1874	08-12-2025	Part of : GANDHI PARK DINPUR,SHYAM VIHAR - II DINPUR,SHIV PURI II DINPUR,	2149	Other Outage	Planned Outage	08-12-2025	12:53	08-12-2025	15:16	2:23	0.000794	REPLACEMET OF HT BUSHING ROD
1875	08-12-2025	Part of : SURYA VIHAR DINPUR,SHIV PURI II DINPUR,GANDHI PARK DINPUR,	513	Other Outage	Planned Outage	08-12-2025	11:00	08-12-2025	13:35	2:35	0.002928	REPLACEMET OF HT BUSHING ROD
1876	08-12-2025	Part of : PREM NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,	171	Other Outage	Planned Outage	08-12-2025	10:10	08-12-2025	13:06	2:56	0.002933	REPLACEMET OF HT BUSHING ROD
1877	08-12-2025	Part of : ASALETPUR KHAWAD VILLAGE,	534	Other Outage	Planned Outage	08-12-2025	11:26	08-12-2025	14:00	2:34	0.000000	REPLACEMENT OF LT BUSHING ROD
1878	08-12-2025	Part of : DHARAMPURA NAJAFGARH,	1359	Other Outage	Planned Outage	08-12-2025	10:23	08-12-2025	12:53	2:30	0.001250	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1879	08-12-2025	Part of : NAJAFGARH VILLAGE,	925	Other Outage	Planned Outage	08-12-2025	11:05	08-12-2025	13:44	2:39	0.000000	REPLACEMENT OF LT BUSHING ROD
1880	09-12-2025	Part of : NIRMAL VIHAR DICHAN KALAN	68	Other Outage	Planned Outage	09-12-2025	10:07	09-12-2025	12:42	2:35	0.000861	REPLACEMENT OF LT BUSHING ROD
1881	09-12-2025	Part of : BADUSARAI,JHATIKARA	610	Other Outage	Planned Outage	09-12-2025	11:54	09-12-2025	14:28	2:34	0.001711	REPLACEMENT OF HT BUSHING ROD
1882	09-12-2025	Part of : DATA RAM PARK DINPUR	372	Other Outage	Planned Outage	09-12-2025	10:36	09-12-2025	12:54	2:18	0.002300	3PH HT AB CABLE REPLACEMENT PER SPAN
1883	09-12-2025	Part of : NAJAFGARH VILLAGE	883	Other Outage	Planned Outage	09-12-2025	10:38	09-12-2025	13:30	2:52	0.000000	REPLACEMENT OF HT BUSHING ROD
1884	09-12-2025	Part of : BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR	1282	Other Outage	Planned Outage	09-12-2025	11:20	09-12-2025	13:53	2:33	0.003400	REPLACEMENT OF HT BUSHING ROD
1885	10-12-2025	Part of : JHARODA KALAN	2	Other Outage	Planned Outage	10-12-2025	13:36	10-12-2025	15:13	1:37	0.000539	REPLACEMENT OF HT BUSHING ROD
1886	10-12-2025	Part of : SECTOR 27 DWARKA	359	Other Outage	Planned Outage	10-12-2025	10:16	10-12-2025	11:46	1:30	0.000500	REPLACEMENT OF HT BUSHING ROD
1887	10-12-2025	Part of : A-BLOCK QUTUB VIHAR PHASE 1	445	Other Outage	Planned Outage	10-12-2025	13:59	10-12-2025	16:04	2:05	0.002778	REPLACEMENT OF HT BUSHING ROD
1888	10-12-2025	Part of : DHARAMPURA NAJAFGARH	342	Other Outage	Planned Outage	10-12-2025	11:06	10-12-2025	13:31	2:25	0.001007	REPLACEMENT OF HT BUSHING ROD
1889	10-12-2025	Part of : B-BLOCK NAVEEN PALACE & SARASWATI KUNJ JHARODA KALAN	1280	Other Outage	Planned Outage	10-12-2025	11:27	10-12-2025	14:32	3:05	0.001285	REPLACEMENT OF HT BUSHING ROD
1890	10-12-2025	Part of : DURGA VIHAR 1 & 2 DINPUR,DATA RAM PARK,MUNIRKA KUNJ,SHANTI VIHAR	997	Other Outage	Planned Outage	10-12-2025	10:14	10-12-2025	12:28	2:14	0.002233	3PH HT AB CABLE REPLACEMENT
1891	10-12-2025	Part of : RANAJI ENCLAVE MASUDABAD NAJAFGARH	2307	Other Outage	Planned Outage	10-12-2025	10:19	10-12-2025	12:52	2:33	0.000850	REPLACEMENT OF HT BUSHING ROD
1892	10-12-2025	Part of : NAJAFGARH EXTENSION	425	Other Outage	Planned Outage	10-12-2025	09:17	10-12-2025	11:49	2:32	0.000000	REPLACEMENT OF HT BUSHING ROD
1893	11-12-2025	Part of : DICHAN ENCLAVE DICHAN KALAN	240	Other Outage	Planned Outage	11-12-2025	12:51	11-12-2025	14:44	1:53	0.000785	REPLACEMENT OF LT BUSHING ROD
1894	11-12-2025	Part of : QUTUB VIHAR PHASE 2	615	Other Outage	Planned Outage	11-12-2025	13:35	11-12-2025	16:24	2:49	0.003380	REPLACEMET OF HT BUSHING ROD
1895	11-12-2025	Part of : KHAIRA VILLAGE	10	Other Outage	Planned Outage	11-12-2025	12:02	11-12-2025	14:43	2:41	0.003578	REPLACEMENT OF LT BUSHING ROD
1896	11-12-2025	Part of : DURGA VIHAR I DINPUR	807	Other Outage	Planned Outage	11-12-2025	10:37	11-12-2025	13:16	2:39	0.003975	3PH HT AB CABLE REPLACEMENT PER SPAN
1897	11-12-2025	Part of : SECTOR 27 DWARKA	268	Other Outage	Planned Outage	11-12-2025	10:34	11-12-2025	12:57	2:23	0.000794	REPLACEMENT OF LT BUSHING ROD
1898	11-12-2025	Part of : PREM VIHAR COLONY GHASIPURA	948	Other Outage	Planned Outage	11-12-2025	11:15	11-12-2025	13:51	2:36	0.000000	REPLACEMENT OF LT BUSHING ROD
1899	12-12-2025	Part of : SULTAN GARDEN,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,SAINIK ENCLAVE,LOKESH PARK NAJAFGARH,NIRMAL VIHAR DICHAN KALAN,MAHESH GARDEN NANU RAM PARK NAJAFGARH,VIRENDRA MARKET,AGARWAL COLONY HAIBUTPUR,NEW HIRA NAGAR DICHAN KALAN,BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH VILLAGE,NAJAFGARH VILLAGE NAJAFGARH SHIV ENCLAVE NAJAFGARH	7715	Other Outage	Unplanned Outage	12-12-2025	10:52	12-12-2025	11:07	0:15	0.000292	REPAIRING OF HT O/H CIRCUIT
1900	12-12-2025	Part of : DAULATPUR VILLAGE,JHATIKARA,	16	Other Outage	Planned Outage	12-12-2025	14:06	12-12-2025	14:17	0:11	0.000092	REPLACEMET OF HT BUSHING ROD
1901	12-12-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI,	90	Other Outage	Planned Outage	12-12-2025	14:08	12-12-2025	16:49	2:41	0.001342	REPLACEMENT OF LT BUSHING ROD
1902	12-12-2025	Part of : KANGANHERI VILLAGE,	408	Other Outage	Planned Outage	12-12-2025	13:40	12-12-2025	16:00	2:20	0.002333	REPLACEMET OF HT BUSHING ROD
1903	12-12-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH,	301	Other Outage	Planned Outage	12-12-2025	13:56	12-12-2025	16:47	2:51	0.001188	DT REPLACEMET PER DT
1904	12-12-2025	Part of : SECTOR 28 DWARKA,	67	Other Outage	Planned Outage	12-12-2025	13:38	12-12-2025	15:59	2:21	0.000783	REPLACEMET OF HT BUSHING ROD
1905	12-12-2025	Part of : TODARMAL COLONY NAJAFGARH,ROSHAN VIHAR NAJAFGARH,	344	Other Outage	Planned Outage	12-12-2025	11:35	12-12-2025	13:59	2:24	0.003600	3PH HT AB CABLE REPLACEMENT PER SPAN
1906	12-12-2025	Part of : GOYALA DAIRY QUTUB VIHAR,	656	Other Outage	Planned Outage	12-12-2025	10:09	12-12-2025	13:09	3:00	0.001000	REPLACEMET OF HT BUSHING ROD
1907	13-12-2025	Part of : PREM NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	525	Other Outage	Planned Outage	13-12-2025	11:47	13-12-2025	14:02	2:15	0.003000	3PH HT AB CABLE REPLACEMENT PER SPAN
1908	13-12-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI	27	Other Outage	Planned Outage	13-12-2025	10:45	13-12-2025	13:49	3:04	0.001022	REPLACEMENT OF LT BUSHING ROD
1909	13-12-2025	Part of : DHULSIRAS VILLAGE DWARKA	232	Other Outage	Planned Outage	13-12-2025	10:51	13-12-2025	13:58	3:07	0.001039	REPLACEMENT OF LT BUSHING ROD
1910	13-12-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	645	Other Outage	Planned Outage	13-12-2025	10:50	13-12-2025	13:51	3:01	0.003017	REPLACEMENT OF HT BUSHING ROD
1911	13-12-2025	Part of : DURGA VIHAR II DINPUR	429	Other Outage	Planned Outage	13-12-2025	10:49	13-12-2025	13:50	3:01	0.004022	REPLACEMENT OF LT BUSHING ROD
1912	13-12-2025	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR,ROSHAN VIHAR NAJAFGARH,DATA RAM PARK DINPUR,SHYAM ENCLAVE DINPUR	942	Other Outage	Planned Outage	13-12-2025	10:43	13-12-2025	13:56	3:13	0.003753	REPLACEMENT OF LT BUSHING ROD
1913	13-12-2025	Part of : ROSHANPURA COLONY NAJAFGARH	818	Other Outage	Planned Outage	13-12-2025	10:26	13-12-2025	12:59	2:33	0.000510	REPLACEMENT OF GAS KIT AND OIL SEAL
1914	14-12-2025	Part of : NEW HIRA NAGAR DICHAN KALAN	4	Other Outage	Unplanned Outage	14-12-2025	19:43	14-12-2025	20:25	0:42	0.000058	CABLE FAULT
1915	14-12-2025	Part of : NEW HIRA NAGAR DICHAN KALAN	4	Other Outage	Unplanned Outage	14-12-2025	12:10	14-12-2025	12:52	0:42	0.000058	CABLE FAULT
1916	14-12-2025	Part of : D-BLOCK LAXMI VIHAR COLONY NANGLI SAKRAWATI	27	Other Outage	Planned Outage	14-12-2025	14:13	14-12-2025	16:09	1:56	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1917	14-12-2025	Part of : NANGLI SANKRANTI & NANGLI SAKRAWATI	67	Other Outage	Planned Outage	14-12-2025	14:13	14-12-2025	16:08	1:55	0.000000	3PH DB REPLACEMENT,HT CONDUCTOR REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1918	15-12-2025	Part of : BLOCK A POCHANPUR DWARKA	693	Other Outage	Planned Outage	15-12-2025	11:47	15-12-2025	12:12	0:25	0.000208	REPLACEMENT OF LT BUSHING ROD
1919	15-12-2025	Part of : SURYA VIHAR DINPUR,SHIV PURI II DINPUR,GANDHI PARK DINPUR	525	Other Outage	Planned Outage	15-12-2025	12:44	15-12-2025	14:38	1:54	0.001710	3PH HT AB CABLE REPLACEMENT PER SPAN
1920	15-12-2025	Part of : TAJPUR KHURD	282	Other Outage	Planned Outage	15-12-2025	14:42	15-12-2025	16:46	2:04	0.001929	REPLACEMENT OF LT BUSHING ROD
1921	15-12-2025	Part of : QUTUB VIHAR PHASE 2 ,SAMTA ENCLAVE QUTUB VIHAR	2250	Other Outage	Planned Outage	15-12-2025	13:05	15-12-2025	15:33	2:28	0.001233	REPLACEMENT OF LT BUSHING ROD
1922	15-12-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	534	Other Outage	Planned Outage	15-12-2025	11:47	15-12-2025	13:48	2:01	0.000672	REPLACEMET OF HT BUSHING ROD
1923	16-12-2025	Part of : GANDHI PARK DINPUR,SHYAM VIHAR - II DINPUR,SHIV PURI II DINPUR,	2149	Other Outage	Planned Outage	16-12-2025	15:30	16-12-2025	17:09	1:39	0.002475	MAINTENANCE OF HVDS CIRCUIT
1924	16-12-2025	Part of : DHARAMPURA NAJAFGARH,	352	Other Outage	Planned Outage	16-12-2025	12:57	16-12-2025	15:41	2:44	0.001367	MAINTENANCE OF TRANSFORMER
1925	16-12-2025	Part of : PIND WALA KALAN VILLAGE,	2	Other Outage	Planned Outage	16-12-2025	11:58	16-12-2025	14:48	2:50	0.001417	MAINTENANCE OF TRANSFORMER
1926	16-12-2025	Part of : BLOCK B NAVEEN PALACE JHARODA KALAN,SARASWATI KUNJ JHARODA KALAN,	1280	Other Outage	Planned Outage	16-12-2025	11:07	16-12-2025	14:27	3:20	0.000000	MAINTENANCE OF HVDS CIRCUIT
1927	16-12-2025	Part of : SECTOR 28 DWARKA,	912	Other Outage	Planned Outage	16-12-2025	10:39	16-12-2025	14:35	3:56	0.001967	MAINTENANCE OF TRANSFORMER
1928	16-12-2025	Part of : ROSHAN PURA NAJAFGARH,PREM NAGAR NAJAFGARH,	843	Other Outage	Planned Outage	16-12-2025	11:09	16-12-2025	14:24	3:15	0.003250	MAINTENANCE OF HVDS CIRCUIT
1929	16-12-2025	Part of : REWLA KHANPUR VILLAGE,	231	Other Outage	Planned Outage	16-12-2025	09:50	16-12-2025	12:34	2:44	0.003189	MAINTENANCE OF TRANSFORMER
1930	17-12-2025	Part of : TAJPUR KHURD	303	Other Outage	Planned Outage	17-12-2025	13:24	17-12-2025	16:11	2:47	0.003711	REPLACEMENT OF LT BUSHING ROD
1931	17-12-2025	Part of : BHARTHAL VILLAGE DWARKA	304	Other Outage	Planned Outage	17-12-2025	12:44	17-12-2025	15:44	3:00	0.004500	REPLACEMENT OF LT BUSHING ROD
1932	17-12-2025	Part of : BLOCK A POCHANPUR DWARKA,BLOCK B POCHANPUR DWARKA	708	Other Outage	Planned Outage	17-12-2025	11:16	17-12-2025	13:22	2:06	0.000700	REPLACEMENT OF LT BUSHING ROD
1933	17-12-2025	Part of : DAULATPUR VILLAGE	16	Other Outage	Planned Outage	17-12-2025	12:38	17-12-2025	15:26	2:48	0.001167	REPLACEMENT OF HT BUSHING ROD
1934	17-12-2025	Part of : SARIKA VIHAR DINPUR,MUNIRKA KUNJ DINPUR,DINPUR LAL DORA EXTN DINPUR	665	Other Outage	Planned Outage	17-12-2025	11:20	17-12-2025	13:58	2:38	0.003950	HT AB CABLE REPLACEMENT PER SPAN
1935	17-12-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	645	Other Outage	Planned Outage	17-12-2025	11:50	17-12-2025	14:25	2:35	0.003875	REPLACEMENT OF LT BUSHING ROD
1936	18-12-2025	Part of : DINPUR LAL DORA EXTN DINPUR,SHANTI VIHAR	377	Other Outage	Unplanned Outage	18-12-2025	16:43	18-12-2025	17:15	0:32	0.000356	REPLACEMENT OF ACB
1937	18-12-2025	Part of : SHYAM KUNJ DINPUR	1342	Other Outage	Planned Outage	18-12-2025	14:12	18-12-2025	16:36	2:24	0.003600	3PH HT AB CABLE REPLACEMENT
1938	18-12-2025	Part of : DAULATPUR VILLAGE	279	Other Outage	Planned Outage	18-12-2025	11:54	18-12-2025	14:35	2:41	0.001342	REPLACEMENT OF HT BUSHING ROD
1939	18-12-2025	Part of : SHYAM VIHAR-1 NAJAFGARH & SHYAM KUNJ DINPUR	1614	Other Outage	Planned Outage	18-12-2025	11:28	18-12-2025	14:11	2:43	0.004075	3PH HT AB CABLE REPLACEMENT
1940	18-12-2025	Part of : BADUSARAI	395	Other Outage	Planned Outage	18-12-2025	11:05	18-12-2025	14:05	3:00	0.003400	REPLACEMENT OF HT BUSHING ROD
1941	18-12-2025	Part of : TODARMAL COLONY NAJAFGARH	160	Other Outage	Planned Outage	18-12-2025	11:08	18-12-2025	14:05	2:57	0.004425	3PH HT AB CABLE REPLACEMENT
1942	18-12-2025	Part of : SECTOR 29 DWARKA	236	Other Outage	Planned Outage	18-12-2025	10:44	18-12-2025	13:32	2:48	0.000933	REPLACEMENT OF HT BUSHING ROD
1943	19-12-2025	Part of : ROSHAN GARDEN, RATHI COLONY, OLD DHARAMPURA MASUDABAD NAJAFGARH, DHARAMPURA NAJAFGARH	4505	Other Outage	Unplanned Outage	19-12-2025	03:46	19-12-2025	04:29	0:43	0.000096	CABLE FAULT
1944	19-12-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	245	Other Outage	Planned Outage	19-12-2025	15:36	19-12-2025	16:56	1:20	0.001333	REPLACEMENT OF LT BUSHING ROD
1945	19-12-2025	Part of : GOPAL EXTENSION II NAJAFGARH,ROSHAN PURA NAJAFGARH,KHAIRA VILLAGE	2464	Other Outage	Planned Outage	19-12-2025	14:28	19-12-2025	16:59	2:31	0.001258	REPLACEMENT OF LT BUSHING ROD
1946	19-12-2025	Part of : GOYLA KHURD	516	Other Outage	Planned Outage	19-12-2025	13:18	19-12-2025	16:17	2:59	0.001492	REPLACEMENT OF LT BUSHING ROD
1947	19-12-2025	Part of : LOKESH PARK EXTN NAJAFGARH,LOKESH PARK NAJAFGARH,INDRA MARKET	685	Other Outage	Planned Outage	19-12-2025	13:41	19-12-2025	16:20	2:39	0.000000	REPLACEMENT OF LT BUSHING ROD
1948	19-12-2025	Part of : KANGANHERI VILLAGE,DAULATPUR VILLAGE	44	Other Outage	Planned Outage	19-12-2025	11:11	19-12-2025	13:44	2:33	0.001275	REPLACEMENT OF LT BUSHING ROD
1949	19-12-2025	Part of : ROSHAN PURA NAJAFGARH,TODARMAL COLONY NAJAFGARH,ROSHAN VIHAR NAJAFGARH,PREM NAGAR NAJAFGARH	581	Other Outage	Planned Outage	19-12-2025	11:10	19-12-2025	13:46	2:36	0.004160	3PH HT AB CABLE REPLACEMENT PER SPAN
1950	20-12-2025	Part of : POCHANPUR DWARKA,	126	Other Outage	Planned Outage	20-12-2025	14:22	20-12-2025	16:02	1:40	0.000556	MAINTENANCE OF TRANSFORMER
1951	20-12-2025	Part of : NATHU RAM PARK MASUDABAD NAJAFGARH,	349	Other Outage	Planned Outage	20-12-2025	11:02	20-12-2025	13:46	2:44	0.001139	MAINTENANCE OF TRANSFORMER
1952	20-12-2025	Part of : SAMTA ENCLAVE QUTUB VIHAR,GOYALA DAIRY QUTUB VIHAR,	657	Other Outage	Planned Outage	20-12-2025	11:09	20-12-2025	13:49	2:40	0.003111	MAINTENANCE OF TRANSFORMER
1953	20-12-2025	Part of : KANGANHERI VILLAGE,DAULATPUR VILLAGE,	44	Other Outage	Planned Outage	20-12-2025	11:06	20-12-2025	13:45	2:39	0.001325	MAINTENANCE OF TRANSFORMER
1954	20-12-2025	Part of : SHIV NAGAR NAJAFGARH,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET	1282	Other Outage	Planned Outage	20-12-2025	12:31	20-12-2025	14:50	2:19	0.000000	MAINTENANCE OF TRANSFORMER
1955	20-12-2025	Part of : ROSHAN PURA NAJAFGARH,ROSHAN VIHAR 1 NAJAFGARH,	1235	Other Outage	Planned Outage	20-12-2025	11:06	20-12-2025	13:47	2:41	0.004025	MAINTENANCE OF HVDS CIRCUIT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1956	20-12-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH,	175	Other Outage	Planned Outage	20-12-2025	10:24	20-12-2025	13:28	3:04	0.001533	MAINTENANCE OF TRANSFORMER
1957	21-12-2025	Part of : SECTOR 24 DWARKA,QUTUB VIHAR PHASE 2 QUTUB VIHAR,SAMTA ENCLAVE QUTUB VIHAR,SECTOR 16D DWARKA	5001	Other Outage	Unplanned Outage	21-12-2025	14:01	21-12-2025	14:26	0:25	0.000479	CABLE FAULT
1958	21-12-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	67	Other Outage	Planned Outage	21-12-2025	12:59	21-12-2025	15:47	2:48	0.001400	REPLACEMENT OF HT BUSHING ROD
1959	21-12-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI	27	Other Outage	Planned Outage	21-12-2025	12:59	21-12-2025	15:47	2:48	0.000933	REPLACEMENT OF HT BUSHING ROD
1960	22-12-2025	Part of : DURGA VIHAR-1 & 2 DINPUR,TODARMAL COLONY,DATA RAM PARK,SHANTI VIHAR,DINPUR,MUNIRKA KUNJ,ROSHAN VIHAR,NAJAFGARH VILLAGE	3788	Other Outage	Unplanned Outage	22-12-2025	16:02	22-12-2025	16:54	0:52	0.000000	HT SYSTEM FAULT
1961	22-12-2025	Part of : DHARAMPURA,E-BLOCK NEW ROshan PURA NAJAFGARH	3798	Other Outage	Planned Outage	22-12-2025	16:37	22-12-2025	17:18	0:41	0.000513	REPLACEMENT OF GAS KIT AND OIL SEAL
1962	22-12-2025	Part of : E & Q-BLOCK NEW ROshan PURA,DURGA PARK NAJAFGARH	1119	Other Outage	Planned Outage	22-12-2025	11:11	22-12-2025	13:09	1:58	0.002950	3PH HT AB CABLE REPLACEMENT
1963	22-12-2025	Part of : KANGANHERI VILLAGE,DAULATPUR VILLAGE	44	Other Outage	Planned Outage	22-12-2025	11:13	22-12-2025	13:36	2:23	0.001192	REPLACEMENT OF HT BUSHING ROD
1964	22-12-2025	Part of : ROshan PURA & PREM NAGAR NAJAFGARH	205	Other Outage	Planned Outage	22-12-2025	10:51	22-12-2025	13:20	2:29	0.002483	3PH HT AB CABLE REPLACEMENT
1965	22-12-2025	Part of : A-BLOCK QUTUB VIHAR PHASE-1,QUTUB VIHAR PHASE-2	1706	Other Outage	Planned Outage	22-12-2025	12:45	22-12-2025	15:15	2:30	0.003500	REPLACEMENT OF HT BUSHING ROD
1966	22-12-2025	Part of : ASALETPUR KHAWAD VILLAGE	3	Other Outage	Planned Outage	22-12-2025	13:30	22-12-2025	16:01	2:31	0.001258	REPLACEMENT OF HT BUSHING ROD
1967	22-12-2025	Part of : DHULSIRAS VILLAGE DWARKA	238	Other Outage	Planned Outage	22-12-2025	12:11	22-12-2025	14:46	2:35	0.001076	REPLACEMENT OF HT BUSHING ROD
1968	23-12-2025	Part of : DURGA VIHAR, NEHRU GARDEN, ROshan VIHAR NAJAFGARH, VILLAGE ROshanPURA	2966	Other Outage	Unplanned Outage	23-12-2025	01:31	23-12-2025	02:07	0:36	0.000160	CABLE FAULT
1969	23-12-2025	Part of : EKTA VIHAR & RAJIV VIHAR	426	Other Outage	Planned Outage	23-12-2025	11:58	23-12-2025	13:57	1:59	0.000000	REPLACEMENT OF LT BUSHING ROD
1970	23-12-2025	Part of : PIND WALA KHURD VILLAGE	7	Other Outage	Planned Outage	23-12-2025	14:09	23-12-2025	16:20	2:11	0.001092	REPLACEMENT OF LT BUSHING ROD
1971	23-12-2025	Part of : BHARTHAL VILLAGE DWARKA	304	Other Outage	Planned Outage	23-12-2025	13:19	23-12-2025	16:07	2:48	0.001400	REPLACEMENT OF LT BUSHING ROD
1972	23-12-2025	Part of : CLUSTER BUS DEPOT DWARKA SEC-22 DWARKA (HTC)	1	Other Outage	Planned Outage	23-12-2025	13:39	23-12-2025	16:13	2:34	0.001283	REPLACEMENT OF HT BUSHING ROD
1973	23-12-2025	Part of : REWLA KHANPUR VILLAGE	507	Other Outage	Planned Outage	23-12-2025	11:18	23-12-2025	14:13	2:55	0.003111	REPLACEMENT OF LT BUSHING ROD
1974	23-12-2025	Part of : KANGANHERI VILLAGE,DAULATPUR VILLAGE	44	Other Outage	Planned Outage	23-12-2025	11:19	23-12-2025	14:09	2:50	0.001417	REPLACEMENT OF HT BUSHING ROD
1975	23-12-2025	Part of : SECTOR 27 DWARKA	25	Other Outage	Planned Outage	23-12-2025	10:49	23-12-2025	13:08	2:19	0.000772	REPLACEMENT OF LT BUSHING ROD
1976	23-12-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	314	Other Outage	Planned Outage	23-12-2025	11:17	23-12-2025	14:12	2:55	0.001458	REPLACEMENT OF LT BUSHING ROD
1977	23-12-2025	Part of : ROshan VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR,DURGA PARK NAJAFGARH	673	Other Outage	Planned Outage	23-12-2025	10:58	23-12-2025	13:56	2:58	0.002967	3PH HT AB CABLE REPLACEMENT PER SPAN
1978	23-12-2025	Part of : DHARAMPURA NAJAFGARH	475	Other Outage	Planned Outage	23-12-2025	10:46	23-12-2025	13:22	2:36	0.003467	REPLACEMENT OF LT BUSHING ROD
1979	24-12-2025	Part of : ROshan VIHAR 1 NAJAFGARH,	1107	Other Outage	Planned Outage	24-12-2025	12:33	24-12-2025	13:48	1:15	0.001875	MAINTENANCE OF HVDS
1980	24-12-2025	Part of : SECTOR 29 DWARKA,SECTOR 19 DWARKA,SECTOR 24 DWARKA	1833	Other Outage	Planned Outage	24-12-2025	13:10	24-12-2025	15:39	2:29	0.001863	MAINTENANCE OF TRANSFORMER
1981	24-12-2025	Part of : KANGANHERI VILLAGE,DAULATPUR VILLAGE,	44	Other Outage	Planned Outage	24-12-2025	13:11	24-12-2025	15:41	2:30	0.001250	MAINTENANCE OF TRANSFORMER
1982	24-12-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,	14	Other Outage	Planned Outage	24-12-2025	14:28	24-12-2025	16:49	2:21	0.000783	MAINTENANCE OF TRANSFORMER
1983	24-12-2025	Part of : JHATIKARA,	1	Other Outage	Planned Outage	24-12-2025	12:19	24-12-2025	14:53	2:34	0.001283	MAINTENANCE OF TRANSFORMER
1984	24-12-2025	Part of : BLOCK B POCHANPUR DWARKA,	58	Other Outage	Planned Outage	24-12-2025	10:38	24-12-2025	13:09	2:31	0.000839	MAINTENANCE OF TRANSFORMER
1985	24-12-2025	Part of : SULTAN GARDEN,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,SAINIK ENCLAVE,LOKESH PARK NAJAFGARH	5112	Other Outage	Planned Outage	24-12-2025	11:36	24-12-2025	13:51	2:15	0.000000	MAINTENANCE OF HT O/H CIRCUIT
1986	26-12-2025	Part of : SAI BABA ENCLAVE MASUDABAD NAJAFGARH	5	Other Outage	Planned Outage	26-12-2025	16:05	26-12-2025	17:14	1:09	0.000479	REPLACEMENT OF HT BUSHING ROD
1987	26-12-2025	Part of : BLOCK E SHYAM VIHAR-1,DINARPUR EXTENSION NAJAFGARH	461	Other Outage	Planned Outage	26-12-2025	13:54	26-12-2025	16:25	2:31	0.001258	REPLACEMENT OF HT BUSHING ROD
1988	26-12-2025	Part of : CHAWLA	465	Other Outage	Planned Outage	26-12-2025	13:24	26-12-2025	15:47	2:23	0.002224	REPLACEMENT OF HT BUSHING ROD
1989	26-12-2025	Part of : BLOCK E NEW ROshan PURA NAJAFGARH	534	Other Outage	Planned Outage	26-12-2025	14:01	26-12-2025	16:37	2:36	0.001300	REPLACEMENT OF HT BUSHING ROD
1990	26-12-2025	Part of : NEW HEERA PARK,SHIV NAGAR,SULTAN GARDEN,SHIV ENCLAVE,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET	1518	Other Outage	Planned Outage	26-12-2025	11:55	26-12-2025	14:26	2:31	0.000000	REPLACEMENT OF HT BUSHING ROD
1991	26-12-2025	Part of : BLOCK E NEW ROshan PURA NAJAFGARH	405	Other Outage	Planned Outage	26-12-2025	11:31	26-12-2025	13:58	2:27	0.000817	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1992	26-12-2025	Part of : KANGANHERI VILLAGE,DAULATPUR VILLAGE	44	Other Outage	Planned Outage	26-12-2025	11:34	26-12-2025	14:02	2:28	0.001233	REPLACEMENT OF HT BUSHING ROD
1993	26-12-2025	Part of : ROSHAN PURA NAJAFGARH	291	Other Outage	Planned Outage	26-12-2025	10:42	26-12-2025	13:21	2:39	0.003975	3PH HT AB CABLE REPLACEMENT
1994	27-12-2025	Part of : KANGANHERI VILLAGE	637	Other Outage	Planned Outage	27-12-2025	12:13	27-12-2025	14:43	2:30	0.003125	REPLACEMET OF HT BUSHING ROD
1995	27-12-2025	Part of : BLOCK A & B POCHANPUR DWARKA	722	Other Outage	Planned Outage	27-12-2025	11:03	27-12-2025	13:38	2:35	0.000861	REPLACEMENT OF LT BUSHING ROD
1996	27-12-2025	Part of : REWLA KHANPUR VILLAGE,PREM NAGAR PAPRAWAT VILLAGE	18	Other Outage	Planned Outage	27-12-2025	11:39	27-12-2025	13:51	2:12	0.001100	REPLACEMET OF HT BUSHING ROD
1997	27-12-2025	Part of : SHYAM KUNJ DINPUR,BLOCK E SHYAM VIHAR I NAJAFGARH	1621	Other Outage	Planned Outage	27-12-2025	10:34	27-12-2025	13:33	2:59	0.003978	3PH HT AB CABLE REPLACEMENT PER SPAN
1998	28-12-2025	Part of : SECTOR 24 DWARKA,QUTUB VIHAR PHASE 2 QUTUB VIHAR,SAMTA ENCLAVE QUTUB VIHAR,SECTOR 16D DWARKA	5016	Other Outage	Unplanned Outage	28-12-2025	14:28	28-12-2025	14:44	0:16	0.000284	TREE TOUCHING
1999	28-12-2025	Part of : SULTAN GARDEN,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,SAINIK ENCLAVE,LOKESH PARK NAJAFGARH,NIRMAL VIHAR DICHAN KALAN,MAHESH GARDEN NANU RAM PARK NAJAFGARH,VIRENDRA MARKET,AGARWAL COLONY HAIBUTPUR,NEW HIRA NAGAR DICHAN KALAN,BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH VILLAGE,NAJAFGARH VILLAGE NAJAFGARH,SHIV ENCLAVE NAJAFGARH	7718	Other Outage	Unplanned Outage	28-12-2025	08:18	28-12-2025	08:44	0:26	0.000722	HT SYSTEM FAULT
2000	28-12-2025	Part of : POCHANPUR DWARKA,BHARTHAL VILLAGE DWARKA	3002	Other Outage	Unplanned Outage	28-12-2025	15:22	28-12-2025	15:59	0:37	0.000709	BIRDAGE
2001	29-12-2025	Part of : SHYAM KUNJ DINPUR	516	Other Outage	Planned Outage	29-12-2025	12:15	29-12-2025	13:35	1:20	0.002000	REPLACEMENT OF LT BUSHING ROD
2002	29-12-2025	Part of : PREM NAGAR NAJAFGARH	178	Other Outage	Planned Outage	29-12-2025	10:52	29-12-2025	13:25	2:33	0.002550	3PH HT AB CABLE REPLACEMENT PER SPAN
2003	29-12-2025	Part of : SECTOR 29 DWARKA,SECTOR 19 DWARKA,SECTOR 24 DWARKA,SOMESH VIHAR CHAWLA,CHAWLA	1833	Other Outage	Planned Outage	29-12-2025	12:45	29-12-2025	15:21	2:36	0.002427	REPLACEMENT OF LT BUSHING ROD
2004	29-12-2025	Part of : AGARWAL COLONY HAIBUTPUR	36	Other Outage	Planned Outage	29-12-2025	12:40	29-12-2025	15:20	2:40	0.000000	REPLACEMENT OF LT BUSHING ROD
2005	29-12-2025	Part of : SECTOR 29 DWARKA	10	Other Outage	Planned Outage	29-12-2025	11:35	29-12-2025	14:21	2:46	0.000922	REPLACEMENT OF HT BUSHING ROD
2006	30-12-2025	Part of : X-BLOCK NEW ROSHAN PURA NAJAFGARH,DWARKA VIHAR KAKROLA ROAD	416	Other Outage	Unplanned Outage	30-12-2025	02:37	30-12-2025	02:58	0:21	0.000251	CABLE FAULT
2007	30-12-2025	Part of : TODARMAL COLONY NAJAFGARH	409	Other Outage	Planned Outage	30-12-2025	11:57	30-12-2025	13:30	1:33	0.002325	3PH HT AB CABLE REPLACEMENT
2008	30-12-2025	Part of : REWLA KHANPUR VILLAGE	177	Other Outage	Planned Outage	30-12-2025	13:30	30-12-2025	16:09	2:39	0.003313	REPLACEMENT OF HT BUSHING ROD
2009	30-12-2025	Part of : B-BLOCK POCHANPUR DWARKA	999	Other Outage	Planned Outage	30-12-2025	10:52	30-12-2025	13:04	2:12	0.000733	1PH HT AB END TERMINATION REPLACEMENT,ST.TH JOINT ON 1PH HT AB
2010	31-12-2025	Part of : QUTUB VIHAR PHASE 2 QUTUB VIHAR,SAMTA ENCLAVE QUTUB VIHAR	1055	Other Outage	Planned Outage	31-12-2025	11:23	31-12-2025	13:56	2:33	0.003188	REPLACEMET OF HT BUSHING ROD
2011	31-12-2025	Part of : ROSHAN PURA NAJAFGARH,ROSHAN VIHAR NAJAFGARH	578	Other Outage	Planned Outage	31-12-2025	11:12	31-12-2025	17:10	5:58	0.005967	3PH HT AB CABLE REPLACEMENT PER SPAN
2012	31-12-2025	Part of : PIND WALA KHURD VILLAGE	15	Other Outage	Planned Outage	31-12-2025	11:14	31-12-2025	13:31	2:17	0.001142	REPLACEMENT OF LT BUSHING ROD
2013	01-12-2025	Part of : BLOCK GH 4 STATE BANK COLONY PASCHIM VIHAR	77	Other Outage	Planned Outage	01-12-2025	12:12	01-12-2025	13:49	1:37	0.000269	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2014	01-12-2025	Part of : BLOCK GH 4 STATE BANK COLONY PASCHIM VIHAR	72	Other Outage	Planned Outage	01-12-2025	10:43	01-12-2025	12:13	1:30	0.000250	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2015	01-12-2025	Part of : SWAYAMSIDHA COLONY PUNJABI BAGH	136	Other Outage	Planned Outage	01-12-2025	10:42	01-12-2025	13:48	3:06	0.001033	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2016	02-12-2025	Part of : BLOCK B STATE BANK COLONY PASCHIM VIHAR	249	Other Outage	Planned Outage	02-12-2025	13:35	02-12-2025	14:45	1:10	0.000194	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
2017	02-12-2025	Part of : BLOCK B NEW MOTI NAGAR	845	Other Outage	Planned Outage	02-12-2025	10:16	02-12-2025	12:10	1:54	0.000950	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2018	02-12-2025	Part of : BLOCK B STATE BANK COLONY PASCHIM VIHAR	213	Other Outage	Planned Outage	02-12-2025	10:42	02-12-2025	12:41	1:59	0.000331	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
2019	03-12-2025	Part of : BLOCK D SURYA ENCLAVE SHAKURBASTI	2	Other Outage	Planned Outage	03-12-2025	10:47	03-12-2025	12:42	1:55	0.000319	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2020	03-12-2025	Part of : PUNJABI BAGH EXTENSION	122	Other Outage	Planned Outage	03-12-2025	10:19	03-12-2025	12:16	1:57	0.000650	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2021	04-12-2025	Part of : ANKUR ENCLAVE PASCHIM VIHAR	302	Other Outage	Planned Outage	04-12-2025	13:09	04-12-2025	14:33	1:24	0.000233	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2022	04-12-2025	Part of : ANKUR ENCLAVE PASCHIM VIHAR	232	Other Outage	Planned Outage	04-12-2025	10:30	04-12-2025	13:11	2:41	0.000447	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2023	05-12-2025	Part of : BLOCK A 3 CA APARTMENTS PASCHIM VIHAR	91	Other Outage	Planned Outage	05-12-2025	10:53	05-12-2025	12:19	1:26	0.000239	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2024	05-12-2025	Part of : BLOCK A 3 CA APARTMENTS PASCHIM VIHAR	47	Other Outage	Planned Outage	05-12-2025	12:17	05-12-2025	14:33	2:16	0.000378	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2025	05-12-2025	Part of : PUNJABI BAGH EXTENSION PUNJABI BAGH	588	Other Outage	Planned Outage	05-12-2025	11:36	05-12-2025	14:36	3:00	0.001000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2026	05-12-2025	Part of : PUNJABI BAGH COOPERATIVE HOUSING SOCEITY PUNJABI BAGH EAST PUNJABI BAGH	327	Other Outage	Planned Outage	05-12-2025	10:31	05-12-2025	13:22	2:51	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2027	07-12-2025	Part of : BLOCK C SHIVAJI PARK PUNJABI BAGH,RAILWAY COLONY NORTH SHAKURBASTI,WEST PUNJABI BAGH	1306	Other Outage	Unplanned Outage	07-12-2025	13:40	07-12-2025	14:21	0:41	0.000683	CABLE FAULT
2028	08-12-2025	Part of : RBI ENCLAVE PASCHIM VIHAR,	123	Other Outage	Planned Outage	08-12-2025	11:22	08-12-2025	13:18	1:56	0.000322	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2029	08-12-2025	Part of : BLOCK GH 4 STATE BANK COLONY PASCHIM VIHAR,	149	Other Outage	Planned Outage	08-12-2025	11:33	08-12-2025	13:21	1:48	0.001200	SF6 GAS FILLING
2030	08-12-2025	Part of : RBI ENCLAVE PASCHIM VIHAR,	116	Other Outage	Planned Outage	08-12-2025	13:18	08-12-2025	15:18	2:00	0.000333	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2031	08-12-2025	Part of : ARIHANT NAGAR PUNJABI BAGH,	386	Other Outage	Planned Outage	08-12-2025	11:15	08-12-2025	14:16	3:01	0.001760	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2032	08-12-2025	Part of : BLOCK H KARAMPURA WEST KARAMPURA,	1201	Other Outage	Planned Outage	08-12-2025	10:11	08-12-2025	14:15	4:04	0.002711	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2033	09-12-2025	Part of : BLOCK B 2 PASCHIM VIHAR	306	Other Outage	Unplanned Outage	09-12-2025	12:33	09-12-2025	14:45	2:12	0.000367	MOBILE TRANSFORMER REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2034	09-12-2025	Part of : BLOCK A 2 PASCHIM VIHAR	377	Other Outage	Planned Outage	09-12-2025	12:58	09-12-2025	14:46	1:48	0.000600	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2035	09-12-2025	Part of : BLOCK A 2 PASCHIM VIHAR	185	Other Outage	Planned Outage	09-12-2025	10:27	09-12-2025	12:24	1:57	0.000975	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2036	09-12-2025	Part of : BLOCK C KARAMPURA MARKET KARAMPURA	796	Other Outage	Planned Outage	09-12-2025	10:10	09-12-2025	15:09	4:59	0.003322	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2037	10-12-2025	Part of : A 2B-BLOCK PASCHIM VIHAR	63	Other Outage	Planned Outage	10-12-2025	13:28	10-12-2025	14:37	1:09	0.000288	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
2038	10-12-2025	Part of : SWAYAMSIDHA COLONY PUNJABI BAGH	252	Other Outage	Planned Outage	10-12-2025	10:53	10-12-2025	14:06	3:13	0.001072	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2039	10-12-2025	Part of : A 2B-BLOCK PASCHIM VIHAR	137	Other Outage	Planned Outage	10-12-2025	10:53	10-12-2025	13:30	2:37	0.000872	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF HT BUSHING ROD
2040	10-12-2025	Part of : I-BLOCK KARAMPURA WEST	960	Other Outage	Planned Outage	10-12-2025	10:06	10-12-2025	13:37	3:31	0.001172	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
2041	11-12-2025	Part of : STATE BANK COLONY PASCHIM VIHAR	146	Other Outage	Planned Outage	11-12-2025	10:25	11-12-2025	13:27	3:02	0.000758	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2042	12-12-2025	Part of : WEST PUNJABI BAGH PUNJABI BAGH,	292	Other Outage	Planned Outage	12-12-2025	14:34	12-12-2025	16:34	2:00	0.000833	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD
2043	12-12-2025	Part of : BLOCK B 1 PASCHIM VIHAR,	310	Other Outage	Planned Outage	12-12-2025	11:00	12-12-2025	12:52	1:52	0.000778	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
2044	12-12-2025	Part of : PUNJABI BAGH COOPERATIVE HOUSING SOCEITY PUNJABI BAGH EAST PUNJABI BAGH,	288	Other Outage	Planned Outage	12-12-2025	10:04	12-12-2025	12:52	2:48	0.000933	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
2045	13-12-2025	Part of : PUNJABI BAGH EXTENSION PUNJABI BAGH,ARIHANT NAGAR PUNJABI BAGH,WEST PUNJABI BAGH PUNJABI BAGH	1424	Other Outage	Unplanned Outage	13-12-2025	02:46	13-12-2025	03:35	0:49	0.000368	FAULT IN HT CONSUMER PANEL (PJB BOOSTER PUMP)
2046	13-12-2025	Part of : POCKET 3 PASCHIM PURI PASCHIM VIHAR	1782	Other Outage	Planned Outage	13-12-2025	10:27	13-12-2025	13:00	2:33	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
2047	15-12-2025	Part of : BLOCK A & B PASCHIM PURI PASCHIM VIHAR,WEST PUNJABI BAGH,POCKET 1 PASCHIM PURI PASCHIM VIHAR	3141	Other Outage	Unplanned Outage	15-12-2025	03:58	15-12-2025	04:49	0:51	0.000227	CABLE FAULT
2048	15-12-2025	Part of : BLOCK A 2 PASCHIM VIHAR	577	Other Outage	Unplanned Outage	15-12-2025	12:37	15-12-2025	15:47	3:10	0.000792	MOBILE TRANSFORMER REPLACEMENT
2049	15-12-2025	Part of : BLOCK BG 7 PASCHIM VIHAR	354	Other Outage	Planned Outage	15-12-2025	13:37	15-12-2025	14:37	1:00	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
2050	15-12-2025	Part of : BLOCK BG 7 PASCHIM VIHAR	396	Other Outage	Planned Outage	15-12-2025	10:45	15-12-2025	12:04	1:19	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
2051	15-12-2025	Part of : BLOCK E KARAMPURA	1791	Other Outage	Planned Outage	15-12-2025	10:01	15-12-2025	13:28	3:27	0.002300	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD
2052	15-12-2025	Part of : WEST PUNJABI BAGH	304	Other Outage	Planned Outage	15-12-2025	10:42	15-12-2025	14:36	3:54	0.002275	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD
2053	16-12-2025	Part of : BLOCK BG 3 PASCHIM VIHAR,BLOCK BG 6 PASCHIM VIHAR	1009	Other Outage	Unplanned Outage	16-12-2025	00:03	16-12-2025	00:27	0:24	0.000000	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2054	16-12-2025	Part of : BLOCK H KARAMPURA WEST KARAMPURA,BLOCK I KARAMPURA WEST KARAMPURA,PUNJABI BAGH COOPERATIVE HOUSING SOCEITY PUNJABI BAGH EAST PUNJABI BAGH,	2884	Other Outage	Unplanned Outage	16-12-2025	11:41	16-12-2025	15:55	4:14	0.002469	RMU REPLACEMENT
2055	16-12-2025	Part of : PUNJABI BAGH EXTENSION PUNJABI BAGH,	260	Other Outage	Planned Outage	16-12-2025	10:27	16-12-2025	12:23	1:56	0.000000	MAINTENANCE OF TRANSFORMER
2056	16-12-2025	Part of : STATE BANK COLONY PASCHIM VIHAR,	91	Other Outage	Planned Outage	16-12-2025	10:29	16-12-2025	12:22	1:53	0.000785	MAINTENANCE OF TRANSFORMER
2057	17-12-2025	Part of : SWAYAMSIDHA COLONY PUNJABI BAGH	465	Other Outage	Planned Outage	17-12-2025	12:42	17-12-2025	16:04	3:22	0.001122	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2058	17-12-2025	Part of : SWAYAMSIDHA COLONY PUNJABI BAGH	516	Other Outage	Planned Outage	17-12-2025	10:25	17-12-2025	12:44	2:19	0.000772	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2059	17-12-2025	Part of : BLOCK C NEW MULTAN NAGAR SHAKURBASTI	1147	Other Outage	Planned Outage	17-12-2025	10:45	17-12-2025	13:15	2:30	0.000833	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2060	18-12-2025	Part of : RBI ENCLAVE PASCHIM VIHAR	11	Other Outage	Unplanned Outage	18-12-2025	11:54	18-12-2025	16:28	4:34	0.000000	REPAIRING OF RMU/FAULT IN RMU
2061	18-12-2025	Part of : B 5-BLOCK PASCHIM VIHAR	373	Other Outage	Planned Outage	18-12-2025	11:17	18-12-2025	13:23	2:06	0.000700	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2062	18-12-2025	Part of : INDIRA COLONY TRI NAGAR	503	Other Outage	Planned Outage	18-12-2025	10:00	18-12-2025	13:21	3:21	0.001954	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2063	19-12-2025	Part of : PUNJABI BAGH EXTENSION, ADARSH BHAWAN PUNJABI BAGH EXTN.	625	Other Outage	Unplanned Outage	19-12-2025	14:37	19-12-2025	15:25	0:48	0.000240	CABLE FAULT
2064	19-12-2025	Part of : BLOCK A 3 CA APARTMENTS PASCHIM VIHAR	75	Other Outage	Planned Outage	19-12-2025	13:47	19-12-2025	15:34	1:47	0.000446	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
2065	19-12-2025	Part of : JANTA COLONY PASCHIM VIHAR	621	Other Outage	Planned Outage	19-12-2025	10:31	19-12-2025	12:31	2:00	0.000667	DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER
2066	19-12-2025	Part of : BLOCK A 3 CA APARTMENTS PASCHIM VIHAR	66	Other Outage	Planned Outage	19-12-2025	10:32	19-12-2025	12:32	2:00	0.000500	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
2067	20-12-2025	Part of : BLOCK A 3 CA APARTMENTS PASCHIM VIHAR,BLOCK A 3 PASCHIM VIHAR	1310	Other Outage	Unplanned Outage	20-12-2025	07:13	20-12-2025	08:01	0:48	0.000373	HT SYSTEM FAULT
2068	20-12-2025	Part of : RBI ENCLAVE PASCHIM VIHAR,	163	Other Outage	Unplanned Outage	20-12-2025	11:53	20-12-2025	17:17	5:24	0.002250	REPAIRING OF RMU
2069	22-12-2025	Part of : RBI ENCLAVE PASCHIM VIHAR	81	Other Outage	Planned Outage	22-12-2025	13:20	22-12-2025	15:26	2:06	0.000525	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2070	22-12-2025	Part of : RBI ENCLAVE PASCHIM VIHAR	112	Other Outage	Planned Outage	22-12-2025	10:52	22-12-2025	13:20	2:28	0.000617	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
2071	22-12-2025	Part of : JANTA COLONY PASCHIM VIHAR	3	Other Outage	Planned Outage	22-12-2025	11:05	22-12-2025	14:39	3:34	0.000892	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
2072	23-12-2025	Part of : WEST PUNJABI BAGH,1212 JANTA QUATERS PASCHIM PURI, BLOCK A JANTA COLONY PASCHIM VIHAR, PKT-2 PASCHIM PURI	3660	Other Outage	Unplanned Outage	23-12-2025	03:46	23-12-2025	04:39	0:53	0.000265	CABLE FAULT
2073	23-12-2025	Part of : BLOCK B 3 PASCHIM VIHAR	283	Other Outage	Planned Outage	23-12-2025	12:11	23-12-2025	14:09	1:58	0.000492	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
2074	23-12-2025	Part of : BLOCK D MANOHAR PARK PUNJABI BAGH EAST	619	Other Outage	Planned Outage	23-12-2025	10:11	23-12-2025	14:08	3:57	0.000658	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
2075	24-12-2025	Part of : BLOCK B 2 PASCHIM VIHAR,	488	Other Outage	Planned Outage	24-12-2025	11:03	24-12-2025	12:31	1:28	0.000489	MAINTENANCE OF TRANSFORMER
2076	24-12-2025	Part of : BLOCK B PASCHIM PURI PASCHIM VIHAR,	1213	Other Outage	Planned Outage	24-12-2025	11:04	24-12-2025	14:04	3:00	0.001250	MAINTENANCE OF TRANSFORMER
2077	26-12-2025	Part of : PUNJABI BAGH APARTMENT	226	Other Outage	Planned Outage	26-12-2025	10:49	26-12-2025	14:13	3:24	0.001700	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2078	28-12-2025	Part of : A BLOCK MANOHAR PARK PUNJABI BAGH EAST	1692	Other Outage	Unplanned Outage	28-12-2025	23:41	29-12-2025	00:48	1:07	0.000744	CABLE FAULT
2079	29-12-2025	Part of : BLOCK B BHAGWAN DAS COLONY PUNJABI BAGH EAST PUNJABI BAGH,PUNJABI BAGH COOPERATIVE HOUSING SOCEITY PUNJABI BAGH EAST PUNJABI BAGH	2444	Other Outage	Unplanned Outage	29-12-2025	01:58	29-12-2025	02:09	0:11	0.000684	HT SYSTEM FAULT
2080	29-12-2025	Part of : MADHUBAN ENCLAVE PUNJABI BAGH	501	Other Outage	Planned Outage	29-12-2025	11:24	29-12-2025	13:20	1:56	0.000644	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2081	30-12-2025	Part of : B-BLOCK BHAGWAN DAS COLONY PUNJABI BAGH EAST	484	Other Outage	Planned Outage	30-12-2025	15:05	30-12-2025	16:59	1:54	0.001108	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
2082	30-12-2025	Part of : PUNJABI BAGH COOPERATIVE HOUSING SOCEITY PUNJABI BAGH EAST	225	Other Outage	Planned Outage	30-12-2025	10:15	30-12-2025	13:42	3:27	0.001150	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2083	30-12-2025	Part of : PASCHIM VIHAR EXTENSION	1759	Other Outage	Planned Outage	30-12-2025	10:39	30-12-2025	15:28	4:49	0.001606	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
2084	01-12-2025	Part of : SECTOR 22 DWARKA	11	Other Outage	Planned Outage	01-12-2025	13:13	01-12-2025	15:06	1:53	0.000628	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
2085	01-12-2025	Part of : BLOCK H SITAPURI PART 2 SITAPURI	1728	Other Outage	Planned Outage	01-12-2025	12:06	01-12-2025	13:34	1:28	0.000244	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
2086	01-12-2025	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM	689	Other Outage	Planned Outage	01-12-2025	11:01	01-12-2025	12:58	1:57	0.000325	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2087	01-12-2025	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM,POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,KAILASHPURI MAIN PALAM	3527	Other Outage	Planned Outage	01-12-2025	10:18	01-12-2025	13:11	2:53	0.000961	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2088	01-12-2025	Part of : BLOCK J RAJ NAGAR 2 RAJ NAGAR	1635	Other Outage	Planned Outage	01-12-2025	12:03	01-12-2025	15:55	3:52	0.001289	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
2089	01-12-2025	Part of : BLOCK B DASRATHPURI	911	Other Outage	Planned Outage	01-12-2025	11:40	01-12-2025	15:28	3:48	0.001267	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2090	01-12-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1	1483	Other Outage	Planned Outage	01-12-2025	11:12	01-12-2025	14:07	2:55	0.000972	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2091	02-12-2025	Part of : POCKET 1 SECTOR 23 DWARKA	162	Other Outage	Planned Outage	02-12-2025	14:53	02-12-2025	16:43	1:50	0.000306	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
2092	02-12-2025	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM	332	Other Outage	Planned Outage	02-12-2025	10:37	02-12-2025	11:57	1:20	0.000222	LT CIRCUIT MAINTENANCE
2093	02-12-2025	Part of : BLOCK RZ GEETANJALI PARK SAGARPUR WEST	1779	Other Outage	Planned Outage	02-12-2025	10:42	02-12-2025	11:58	1:16	0.000211	LT CIRCUIT MAINTENANCE
2094	02-12-2025	Part of : KAILASHPURI WEST,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI	2061	Other Outage	Planned Outage	02-12-2025	10:42	02-12-2025	13:33	2:51	0.000950	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
2095	02-12-2025	Part of : BLOCK A SITAPURI PART 1 SITAPURI	968	Other Outage	Planned Outage	02-12-2025	12:03	02-12-2025	15:32	3:29	0.001161	LT CIRCUIT MAINTENANCE
2096	02-12-2025	Part of : BLOCK WZ RAJ NAGAR 2	987	Other Outage	Planned Outage	02-12-2025	11:54	02-12-2025	15:45	3:51	0.001283	LT CIRCUIT MAINTENANCE
2097	02-12-2025	Part of : BLOCK B 3 MAHAVIR ENCLAVE PART 1	1319	Other Outage	Planned Outage	02-12-2025	11:30	02-12-2025	14:24	2:54	0.000967	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2098	03-12-2025	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN,POCKET B KAILASHPURI EAST, KAMAL PARK, HARIJAN BASTI SAGARPUR	2065	Other Outage	Unplanned Outage	03-12-2025	13:01	03-12-2025	13:37	0:36	0.000310	HT SYSTEM FAULT
2099	03-12-2025	Part of : KAILASHPURI WEST PALAM	169	Other Outage	Planned Outage	03-12-2025	11:34	03-12-2025	12:29	0:55	0.000306	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2100	03-12-2025	Part of : TAMILAR ENCLAVE VIJAY ENCLAVE MAHAVIR ENCLAVE	355	Other Outage	Planned Outage	03-12-2025	13:31	03-12-2025	14:52	1:21	0.000450	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2101	03-12-2025	Part of : VEER NAGAR SAGARPUR WEST	1269	Other Outage	Planned Outage	03-12-2025	10:58	03-12-2025	12:57	1:59	0.000661	LT AB SAGGING PER SPAN
2102	03-12-2025	Part of : BLOCK A DABRI EXTENSION EAST	593	Other Outage	Planned Outage	03-12-2025	11:11	03-12-2025	12:27	1:16	0.000422	LT AB SAGGING PER SPAN
2103	03-12-2025	Part of : DABRI VILLAGE,BLOCK B DASRATHPURI,BLOCK A MAHAVIR ENCLAVE,VAISHALI EXTENSION DASRATHPURI	2117	Other Outage	Planned Outage	03-12-2025	11:20	03-12-2025	14:59	3:39	0.001217	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2104	03-12-2025	Part of : BLOCK RZ PALAM	306	Other Outage	Planned Outage	03-12-2025	11:16	03-12-2025	13:54	2:38	0.000878	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2105	03-12-2025	Part of : BLOCK F RAJ NAGAR EXTENSION	1294	Other Outage	Planned Outage	03-12-2025	11:12	03-12-2025	14:56	3:44	0.001244	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2106	03-12-2025	Part of : BLOCK A RAJ NAGAR 1	968	Other Outage	Planned Outage	03-12-2025	11:03	03-12-2025	14:37	3:34	0.001189	LT AB SAGGING PER SPAN
2107	04-12-2025	Part of : BLOCK B DASRATHPURI	812	Other Outage	Planned Outage	04-12-2025	15:04	04-12-2025	16:31	1:27	0.000483	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2108	04-12-2025	Part of : SANT MOHALLA SAGARPUR MAIN SAGARPUR	1647	Other Outage	Planned Outage	04-12-2025	11:29	04-12-2025	12:52	1:23	0.000231	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2109	04-12-2025	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,PALAM COLONY MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE	1759	Other Outage	Planned Outage	04-12-2025	11:15	04-12-2025	14:06	2:51	0.000950	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,ST. TH JOINT ON 1PH HT AB
2110	04-12-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR	1192	Other Outage	Planned Outage	04-12-2025	14:18	04-12-2025	16:46	2:28	0.000822	LT AB SAGGING PER SPAN
2111	04-12-2025	Part of : MANGALPURI I PALAM	1083	Other Outage	Planned Outage	04-12-2025	11:27	04-12-2025	13:52	2:25	0.000806	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
2112	04-12-2025	Part of : BAGDAULA VILLAGE SECTOR 8 DWARKA	479	Other Outage	Planned Outage	04-12-2025	11:16	04-12-2025	15:05	3:49	0.001272	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
2113	04-12-2025	Part of : BLOCK G VIJAY ENCLAVE MAHAVIR ENCLAVE	1052	Other Outage	Planned Outage	04-12-2025	11:26	04-12-2025	15:07	3:41	0.001228	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
2114	05-12-2025	Part of : HARIJAN BASTI PALAM EXTENSION PALAM	835	Other Outage	Unplanned Outage	05-12-2025	23:10	05-12-2025	23:44	0:34	0.000000	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2115	05-12-2025	Part of : POCKET 13 MANGALPURI II PALAM	578	Other Outage	Planned Outage	05-12-2025	10:52	05-12-2025	12:21	1:29	0.000494	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2116	05-12-2025	Part of : BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR,SECTOR 8 DWARKA	1007	Other Outage	Planned Outage	05-12-2025	11:50	05-12-2025	14:43	2:53	0.000961	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2117	05-12-2025	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM	2061	Other Outage	Planned Outage	05-12-2025	10:52	05-12-2025	13:30	2:38	0.000878	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2118	05-12-2025	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM	332	Other Outage	Planned Outage	05-12-2025	11:59	05-12-2025	15:46	3:47	0.001261	LT AB SAGGING PER SPAN
2119	05-12-2025	Part of : BLOCK J PALAM	1460	Other Outage	Planned Outage	05-12-2025	10:53	05-12-2025	13:32	2:39	0.000883	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2120	05-12-2025	Part of : VAISHALI EXTENSION DASRATHPURI	605	Other Outage	Planned Outage	05-12-2025	11:16	05-12-2025	14:58	3:42	0.001233	LT AB SAGGING PER SPAN
2121	05-12-2025	Part of : BLOCK E SITAPURI PART 1 SITAPURI	1108	Other Outage	Planned Outage	05-12-2025	11:57	05-12-2025	15:24	3:27	0.001150	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2122	06-12-2025	Part of : D-BLOCK PALAM EXTENSION	24	Other Outage	Planned Outage	06-12-2025	13:01	06-12-2025	14:19	1:18	0.000433	LT CIRCUIT MAINTENANCE WORK
2123	06-12-2025	Part of : T-BLOCK GANDHI MARKET SAGARPUR	750	Other Outage	Planned Outage	06-12-2025	11:06	06-12-2025	12:30	1:24	0.000233	LT CIRCUIT MAINTENANCE WORK
2124	06-12-2025	Part of : MTNL DWARKA PURI (HT CONSUMER)	1	Other Outage	Planned Outage	06-12-2025	12:58	06-12-2025	16:50	3:52	0.001289	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2125	06-12-2025	Part of : B 2 & C-BLOCK DASRATHPURI,DURGA PARK COLONY,B-BLOCK DABRI EXTENSION EAST	871	Other Outage	Planned Outage	06-12-2025	11:07	06-12-2025	14:47	3:40	0.001222	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2126	06-12-2025	Part of : KAILASHPURI MAIN PALAM,R-BLOCK INDRA PARK,POCKET B KAILASHPURI EAST	3527	Other Outage	Planned Outage	06-12-2025	10:45	06-12-2025	13:28	2:43	0.000906	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2127	06-12-2025	Part of : SECTOR 23 DWARKA	220	Other Outage	Planned Outage	06-12-2025	13:01	06-12-2025	16:32	3:31	0.001172	LT AB SAGGING PER SPAN
2128	06-12-2025	Part of : A-BLOCK RAJ NAGAR 1	1062	Other Outage	Planned Outage	06-12-2025	11:06	06-12-2025	14:47	3:41	0.001228	LT CIRCUIT MAINTENANCE WORK
2129	06-12-2025	Part of : PALAM EXTENSION	192	Other Outage	Planned Outage	06-12-2025	11:13	06-12-2025	13:46	2:33	0.000850	LT CIRCUIT MAINTENANCE WORK
2130	08-12-2025	Part of : BLOCK B MANGALPURI II PALAM	557	Other Outage	Unplanned Outage	08-12-2025	08:13	08-12-2025	08:59	0:46	0.000831	TRANSIENT FAULT
2131	08-12-2025	Part of : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE,	483	Other Outage	Planned Outage	08-12-2025	12:33	08-12-2025	13:30	0:57	0.000317	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2132	08-12-2025	Part of : BLOCK RZ PALAM,	172	Other Outage	Planned Outage	08-12-2025	12:10	08-12-2025	13:12	1:02	0.000172	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2133	08-12-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	555	Other Outage	Planned Outage	08-12-2025	12:10	08-12-2025	13:14	1:04	0.000178	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2134	08-12-2025	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,	976	Other Outage	Planned Outage	08-12-2025	10:54	08-12-2025	12:10	1:16	0.000422	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2135	08-12-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,BLOCK J RAJ NAGAR 2 RAJ NAGAR,	371	Other Outage	Planned Outage	08-12-2025	10:59	08-12-2025	14:39	3:40	0.001222	GUARD WIRE LACS INSTALLTION PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2136	08-12-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	2595	Other Outage	Planned Outage	08-12-2025	11:00	08-12-2025	14:40	3:40	0.001222	GUARD WIRES SAGGING PER SPAN
2137	08-12-2025	Part of : BLOCK A 1 VIJAY ENCLAVE MAHAVIR ENCLAVE,	810	Other Outage	Planned Outage	08-12-2025	11:13	08-12-2025	15:02	3:49	0.001272	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2138	08-12-2025	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,	1080	Other Outage	Planned Outage	08-12-2025	10:53	08-12-2025	14:37	3:44	0.001244	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2139	08-12-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM,	1388	Other Outage	Planned Outage	08-12-2025	10:58	08-12-2025	14:41	3:43	0.001239	LT AB SAGGING PER SPAN
2140	08-12-2025	Part of : BLOCK H SITAPURI PART 2 SITAPURI,	3102	Other Outage	Planned Outage	08-12-2025	10:52	08-12-2025	14:38	3:46	0.001569	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
2141	09-12-2025	Part of : POCKET 13 MANGALPURI II PALAM,BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR,PALAM COLONY MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE	4174	Other Outage	Planned Outage	09-12-2025	10:43	09-12-2025	12:16	1:33	0.000258	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,SUB STATION CLEANING
2142	09-12-2025	Part of : SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR	56	Other Outage	Planned Outage	09-12-2025	11:53	09-12-2025	15:44	3:51	0.001283	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2143	09-12-2025	Part of : POCKET 1 SECTOR 23 DWARKA	173	Other Outage	Planned Outage	09-12-2025	10:43	09-12-2025	14:02	3:19	0.001106	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
2144	09-12-2025	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM	2061	Other Outage	Planned Outage	09-12-2025	10:42	09-12-2025	13:31	2:49	0.000939	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2145	09-12-2025	Part of : DABRI EXTENSION EAST DABRI	1282	Other Outage	Planned Outage	09-12-2025	12:03	09-12-2025	15:46	3:43	0.001239	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
2146	09-12-2025	Part of : BLOCK J PALAM	463	Other Outage	Planned Outage	09-12-2025	11:20	09-12-2025	14:00	2:40	0.000889	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE
2147	09-12-2025	Part of : MANGALPURI I PALAM	1093	Other Outage	Planned Outage	09-12-2025	11:51	09-12-2025	14:50	2:59	0.000994	LT AB SAGGING PER SPAN
2148	09-12-2025	Part of : BLOCK D RAJ NAGAR 1 RAJ NAGAR	869	Other Outage	Planned Outage	09-12-2025	11:19	09-12-2025	14:05	2:46	0.000922	LT AB SAGGING PER SPAN
2149	10-12-2025	Part of : SPG COMPLEX SECT-21 DWK ESS NO. 6	0	Other Outage	Unplanned Outage	10-12-2025	18:10	10-12-2025	18:54	0:44	0.000000	CABLE DAMAGE BY OUTSIDE AGENCY (DDA)
2150	10-12-2025	Part of : SECTOR 8 & 21 DWARKA	2996	Other Outage	Unplanned Outage	10-12-2025	17:50	10-12-2025	18:27	0:37	0.000627	CABLE DAMAGE BY OUTSIDE AGENCY (DDA)
2151	10-12-2025	Part of : POCKET 4 SECTOR 1 DWARKA	395	Other Outage	Planned Outage	10-12-2025	11:18	10-12-2025	12:41	1:23	0.000231	LT CIRCUIT MAINTENANCE
2152	10-12-2025	Part of : POCKET B KAILASHPURI EAST & MAIN PALAM	967	Other Outage	Planned Outage	10-12-2025	10:34	10-12-2025	12:12	1:38	0.000272	LT CIRCUIT MAINTENANCE
2153	10-12-2025	Part of : G & J-BLOCK SAGARPUR WEST	646	Other Outage	Planned Outage	10-12-2025	11:26	10-12-2025	15:01	3:35	0.001194	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2154	10-12-2025	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY	1759	Other Outage	Planned Outage	10-12-2025	10:33	10-12-2025	14:26	3:53	0.001294	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2155	10-12-2025	Part of : PALAM COLONY SADH NAGAR-1	1387	Other Outage	Planned Outage	10-12-2025	11:17	10-12-2025	15:01	3:44	0.001244	LT CIRCUIT MAINTENANCE
2156	10-12-2025	Part of : RZ-BLOCK PALAM	492	Other Outage	Planned Outage	10-12-2025	10:49	10-12-2025	14:38	3:49	0.001272	LT CIRCUIT MAINTENANCE
2157	10-12-2025	Part of : SECTOR 21 DWARKA	331	Other Outage	Planned Outage	10-12-2025	10:54	10-12-2025	14:47	3:53	0.001294	LT CIRCUIT MAINTENANCE
2158	10-12-2025	Part of : A-BLOCK RAJ NAGAR-1	967	Other Outage	Planned Outage	10-12-2025	10:37	10-12-2025	14:27	3:50	0.001278	LT CIRCUIT MAINTENANCE
2159	11-12-2025	Part of : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE	485	Other Outage	Planned Outage	11-12-2025	15:20	11-12-2025	16:04	0:44	0.000000	LT AB SAGGING PER SPAN
2160	11-12-2025	Part of : BLOCK A & B3 MAHAVIR ENCLAVE PART 1,TAMILAR ENCLAVE VIJAY ENCLAVE,BLOCK A1 & B VIJAY ENCLAVE MAHAVIR ENCLAVE	2735	Other Outage	Planned Outage	11-12-2025	13:01	11-12-2025	14:57	1:56	0.000000	AUXILARY SUPPLY FOR RELAYS
2161	11-12-2025	Part of : BAGDAULA VILLAGE SECTOR 8 DWARKA	477	Other Outage	Planned Outage	11-12-2025	10:59	11-12-2025	12:50	1:51	0.000000	LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2162	11-12-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM	313	Other Outage	Planned Outage	11-12-2025	12:50	11-12-2025	14:54	2:04	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2163	11-12-2025	Part of : BLOCK H RAGHU NAGAR DABRI	1272	Other Outage	Planned Outage	11-12-2025	12:03	11-12-2025	14:45	2:42	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2164	11-12-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM	1407	Other Outage	Planned Outage	11-12-2025	10:58	11-12-2025	13:53	2:55	0.000000	LT AB SAGGING PER SPAN
2165	11-12-2025	Part of : PALAM EXTENSION	36	Other Outage	Planned Outage	11-12-2025	11:02	11-12-2025	13:48	2:46	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2166	11-12-2025	Part of : BLOCK F RAJ NAGAR EXTENSION	1207	Other Outage	Planned Outage	11-12-2025	10:13	11-12-2025	13:42	3:29	0.000000	LT AB SAGGING PER SPAN
2167	11-12-2025	Part of : BLOCK A SECTOR 8 DWARKA	211	Other Outage	Planned Outage	11-12-2025	11:01	11-12-2025	13:46	2:45	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
2168	11-12-2025	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY MAHAVIR ENCLAVE PART 2	5352	Other Outage	Planned Outage	11-12-2025	10:56	11-12-2025	13:07	2:11	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,SUB STATION CLEANING
2169	12-12-2025	Part of : BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR,	641	Other Outage	Planned Outage	12-12-2025	10:29	12-12-2025	12:09	1:40	0.000278	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,SUB STATION CLEANING
2170	12-12-2025	Part of : VAISHALI COLONY DASRATHPURI,	260	Other Outage	Planned Outage	12-12-2025	12:41	12-12-2025	16:27	3:46	0.001256	GUARD WIRES SAGGING PER SPAN
2171	12-12-2025	Part of : DURGA PARK COLONY DASRATHPURI,BLOCK B 2 DASRATHPURI,POCKET 10 SECTOR I DASRATHPURI	585	Other Outage	Planned Outage	12-12-2025	12:20	12-12-2025	14:49	2:29	0.000828	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2172	12-12-2025	Part of : BAGDAULA VILLAGE SECTOR 8 DWARKA,	229	Other Outage	Planned Outage	12-12-2025	11:19	12-12-2025	15:06	3:47	0.001261	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
2173	12-12-2025	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	175	Other Outage	Planned Outage	12-12-2025	11:20	12-12-2025	14:04	2:44	0.000911	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
2174	12-12-2025	Part of : KAILASHPURI MAIN PALAM,BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM	3527	Other Outage	Planned Outage	12-12-2025	10:28	12-12-2025	14:07	3:39	0.001217	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2175	13-12-2025	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE	976	Other Outage	Planned Outage	13-12-2025	11:48	13-12-2025	13:12	1:24	0.000467	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
2176	13-12-2025	Part of : SECTOR 23 DWARKA	220	Other Outage	Planned Outage	13-12-2025	11:38	13-12-2025	13:13	1:35	0.000264	LT AB SAGGING PER SPAN
2177	13-12-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,BLOCK J RAJ NAGAR 2 RAJ NAGAR	365	Other Outage	Planned Outage	13-12-2025	13:08	13-12-2025	16:22	3:14	0.001078	GUARD WIRES SAGGING PER SPAN
2178	13-12-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR	2577	Other Outage	Planned Outage	13-12-2025	13:09	13-12-2025	16:19	3:10	0.001056	GUARD WIRES SAGGING PER SPAN
2179	13-12-2025	Part of : BLOCK A RAJ NAGAR 1 RAJ NAGAR	1062	Other Outage	Planned Outage	13-12-2025	12:13	13-12-2025	15:52	3:39	0.001217	LT AB SAGGING PER SPAN
2180	13-12-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE	1463	Other Outage	Planned Outage	13-12-2025	11:38	13-12-2025	14:36	2:58	0.000989	LT AB SAGGING PER SPAN
2181	13-12-2025	Part of : BLOCK I MAHAVIR ENCLAVE PART 1	427	Other Outage	Planned Outage	13-12-2025	11:18	13-12-2025	13:40	2:22	0.000789	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
2182	13-12-2025	Part of : BLOCK WZ RAJ NAGAR 2 RAJ NAGAR	308	Other Outage	Planned Outage	13-12-2025	11:37	13-12-2025	15:02	3:25	0.001139	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
2183	15-12-2025	Part of : PALAM VILLAGE PALAM	488	Other Outage	Planned Outage	15-12-2025	11:13	15-12-2025	12:57	1:44	0.000578	LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2184	15-12-2025	Part of : PALAM EXTENSION PALAM	83	Other Outage	Planned Outage	15-12-2025	11:58	15-12-2025	13:16	1:18	0.000217	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
2185	15-12-2025	Part of : NAVEEN KUNJ SOCIETY NARSIRPUR	161	Other Outage	Planned Outage	15-12-2025	10:50	15-12-2025	12:16	1:26	0.000239	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2186	15-12-2025	Part of : DURGA PARK COLONY DASRATHPURI,BLOCK A POKKET 9 PINK APARTMENTS NARSIRPUR,DURGA PURI SAGARPUR WEST SAGARPUR	1548	Other Outage	Planned Outage	15-12-2025	12:13	15-12-2025	15:02	2:49	0.000939	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2187	15-12-2025	Part of : KAILASHPURI WEST PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM	2061	Other Outage	Planned Outage	15-12-2025	10:50	15-12-2025	13:15	2:25	0.000806	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2188	15-12-2025	Part of : JAGDAMBA VIHAR SAGARPUR WEST	1278	Other Outage	Planned Outage	15-12-2025	13:02	15-12-2025	15:46	2:44	0.000911	LT AB SAGGING PER SPAN
2189	15-12-2025	Part of : MANGALPURI I PALAM	1084	Other Outage	Planned Outage	15-12-2025	12:54	15-12-2025	15:45	2:51	0.000950	LT AB SAGGING PER SPAN
2190	15-12-2025	Part of : BLOCK H PALAM EXTENSION	728	Other Outage	Planned Outage	15-12-2025	12:01	15-12-2025	14:20	2:19	0.000772	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
2191	16-12-2025	Part of : SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR	2791	Other Outage	Unplanned Outage	16-12-2025	09:00	16-12-2025	09:20	0:20	0.000483	FAULT IN HT CONSUMER PANEL (B.R.AMBEDKAR INSTT.)
2192	16-12-2025	Part of : POKKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,BLOCK RZ KAMAL PARK KAILASHPURI MAIN PALAM	1801	Other Outage	Planned Outage	16-12-2025	12:56	16-12-2025	14:29	1:33	0.000517	MAINTENANCE OF HVDS CIRCUIT
2193	16-12-2025	Part of : BLOCK D RAJ NAGAR 1 RAJ NAGAR,	877	Other Outage	Planned Outage	16-12-2025	11:45	16-12-2025	13:36	1:51	0.000617	MAINTENANCE OF LT CIRCUIT
2194	16-12-2025	Part of : VAISHALI EXTENSION DASRATHPURI,	607	Other Outage	Planned Outage	16-12-2025	13:21	16-12-2025	16:15	2:54	0.000967	MAINTENANCE OF LT CIRCUIT
2195	16-12-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM,	386	Other Outage	Planned Outage	16-12-2025	13:34	16-12-2025	16:26	2:52	0.000956	MAINTENANCE OF LT CIRCUIT
2196	16-12-2025	Part of : BLOCK F MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	953	Other Outage	Planned Outage	16-12-2025	11:13	16-12-2025	13:20	2:07	0.000706	MAINTENANCE OF LT TRANSFORMER
2197	16-12-2025	Part of : BLOCK A DABRI EXTENSION EAST DABRI,	592	Other Outage	Planned Outage	16-12-2025	11:35	16-12-2025	14:28	2:53	0.000961	MAINTENANCE OF LT TRANSFORMER
2198	16-12-2025	Part of : BLOCK C SECTOR 8 DWARKA,	573	Other Outage	Planned Outage	16-12-2025	11:04	16-12-2025	13:29	2:25	0.000806	MAINTENANCE OF LT TRANSFORMER
2199	17-12-2025	Part of : VAISHALI COLONY DASRATHPURI	260	Other Outage	Planned Outage	17-12-2025	12:56	17-12-2025	14:39	1:43	0.000572	REPLACEMENT OF HT BUSHING ROD
2200	17-12-2025	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,PALAM COLONY MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE	5352	Other Outage	Planned Outage	17-12-2025	10:58	17-12-2025	12:53	1:55	0.000639	HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2201	17-12-2025	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI	1665	Other Outage	Planned Outage	17-12-2025	12:46	17-12-2025	15:43	2:57	0.000983	LT AB SAGGING PER SPAN
2202	17-12-2025	Part of : BLOCK F PALAM EXTENSION PALAM	292	Other Outage	Planned Outage	17-12-2025	12:06	17-12-2025	14:40	2:34	0.000856	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
2203	17-12-2025	Part of : SECTOR 23 DWARKA	220	Other Outage	Planned Outage	17-12-2025	11:26	17-12-2025	14:20	2:54	0.000967	LT AB SAGGING PER SPAN
2204	17-12-2025	Part of : DABRI VILLAGE DABRI	677	Other Outage	Planned Outage	17-12-2025	11:23	17-12-2025	13:51	2:28	0.000822	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
2205	17-12-2025	Part of : BLOCK D SECTOR 8 DWARKA	118	Other Outage	Planned Outage	17-12-2025	11:02	17-12-2025	13:48	2:46	0.000922	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
2206	17-12-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM	1407	Other Outage	Planned Outage	17-12-2025	11:47	17-12-2025	14:38	2:51	0.000950	LT AB SAGGING PER SPAN
2207	18-12-2025	Part of : A-BLOCK SITAPURI PART 1	542	Other Outage	Planned Outage	18-12-2025	11:47	18-12-2025	13:24	1:37	0.000269	CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
2208	18-12-2025	Part of : INDRA PARK PALEM,R-BLOCK INDRA PARK,POCKET B KAILASHPURI EAST,KAILASHPURI MAIN	2901	Other Outage	Planned Outage	18-12-2025	13:25	18-12-2025	16:21	2:56	0.000978	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
2209	18-12-2025	Part of : MIRZAPUR MAHAVIR ENCLAVE	341	Other Outage	Planned Outage	18-12-2025	11:23	18-12-2025	14:22	2:59	0.000994	LT CIRCUIT MAINTENANCE
2210	18-12-2025	Part of : D-BLOCK SECTOR 8 DWARKA	201	Other Outage	Planned Outage	18-12-2025	10:56	18-12-2025	13:49	2:53	0.000961	LT CIRCUIT MAINTENANCE
2211	18-12-2025	Part of : B-BLOCK PATEL BLOCK RAGHU NAGAR DABRI	1011	Other Outage	Planned Outage	18-12-2025	11:45	18-12-2025	14:38	2:53	0.000961	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2212	19-12-2025	Part of : DURGA PARK COLONY DASRATHPURI	212	Other Outage	Planned Outage	19-12-2025	13:07	19-12-2025	14:44	1:37	0.000269	CHECKING OF EARTHING VALUE OF BODY EARTHING,REPLACEMENT OF SILICAGEL IN BREATHER
2213	19-12-2025	Part of : BLOCK F DASRATHPURI	966	Other Outage	Planned Outage	19-12-2025	12:49	19-12-2025	14:42	1:53	0.000314	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
2214	19-12-2025	Part of : MAHAVIR ENCLAVE PART 2,BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR,NAVEEN KUNJ SOCIETY NARSIRPUR	3963	Other Outage	Planned Outage	19-12-2025	13:30	19-12-2025	15:40	2:10	0.000722	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2215	19-12-2025	Part of : SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR	1183	Other Outage	Planned Outage	19-12-2025	11:03	19-12-2025	13:56	2:53	0.000961	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2216	19-12-2025	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	775	Other Outage	Planned Outage	19-12-2025	11:59	19-12-2025	14:51	2:52	0.000956	LT AB SAGGING PER SPAN
2217	19-12-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM	1869	Other Outage	Planned Outage	19-12-2025	12:19	19-12-2025	14:41	2:22	0.000789	LT AB SAGGING PER SPAN
2218	19-12-2025	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1	449	Other Outage	Planned Outage	19-12-2025	11:08	19-12-2025	13:41	2:33	0.000850	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
2219	19-12-2025	Part of : MIRZAPUR MAHAVIR ENCLAVE	1291	Other Outage	Planned Outage	19-12-2025	11:08	19-12-2025	14:00	2:52	0.000956	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
2220	20-12-2025	Part of : SANT MOHALLA SAGARPUR MAIN SAGARPUR,BLOCK RZ GANDHI MARKET SAGARPUR MAIN SAGARPUR	3751	Other Outage	Unplanned Outage	20-12-2025	16:13	20-12-2025	16:53	0:40	0.000189	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
2221	20-12-2025	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI,	644	Other Outage	Planned Outage	20-12-2025	13:47	20-12-2025	15:15	1:28	0.000489	MAINTENANCE OF LT CIRCUIT
2222	20-12-2025	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM	2061	Other Outage	Planned Outage	20-12-2025	10:55	20-12-2025	12:38	1:43	0.000572	MAINTENANCE OF HVDS CIRCUIT
2223	20-12-2025	Part of : VAISHALI COLONY DASRATHPURI,	259	Other Outage	Planned Outage	20-12-2025	12:35	20-12-2025	15:24	2:49	0.000939	MAINTENANCE OF TRANSFORMER
2224	20-12-2025	Part of : MANGALPURI I PALAM,	1065	Other Outage	Planned Outage	20-12-2025	12:35	20-12-2025	15:15	2:40	0.000889	MAINTENANCE OF LT CIRCUIT
2225	20-12-2025	Part of : SECTOR 1 DWARKA,	596	Other Outage	Planned Outage	20-12-2025	11:25	20-12-2025	14:15	2:50	0.000944	MAINTENANCE OF LT TRANSFORMER
2226	20-12-2025	Part of : BLOCK G SAGARPUR WEST SAGARPUR,BLOCK J SAGARPUR WEST SAGARPUR,	647	Other Outage	Planned Outage	20-12-2025	11:09	20-12-2025	14:06	2:57	0.000983	MAINTENANCE OF HVDS CIRCUIT
2227	22-12-2025	Part of : POCKET B KAILASHPURI EAST,KAILASHPURI MAIN,INDIRA PARK EXTENSION	1801	Other Outage	Planned Outage	22-12-2025	10:33	22-12-2025	13:17	2:44	0.000911	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
2228	22-12-2025	Part of : DURGA PARK COLONY,B 2-BLOCK DASRATHPURI,POCKET 10 SECTOR I DASRATHPURI	585	Other Outage	Planned Outage	22-12-2025	11:23	22-12-2025	14:16	2:53	0.000961	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2229	22-12-2025	Part of : HARIJAN BASTI PALAM EXTENSION	250	Other Outage	Planned Outage	22-12-2025	11:33	22-12-2025	13:57	2:24	0.000800	LT CIRCUIT MAINTENANCE WORK
2230	23-12-2025	Part of : MANGALPURI PHASE-II PALAM	557	Other Outage	Unplanned Outage	23-12-2025	08:19	23-12-2025	09:08	0:49	0.000939	BIRDAGE
2231	23-12-2025	Part of : BLOCK J PALAM	379	Other Outage	Planned Outage	23-12-2025	11:24	23-12-2025	13:23	1:59	0.000661	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
2232	23-12-2025	Part of : SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION	56	Other Outage	Planned Outage	23-12-2025	11:32	23-12-2025	14:24	2:52	0.000956	1PH HT AB END TERMINATION REPLACEMENT,LT BUSHING REPLACEMENT
2233	23-12-2025	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY MAHAVIR ENCLAVE PART 2	1759	Other Outage	Planned Outage	23-12-2025	10:28	23-12-2025	13:19	2:51	0.000950	1PH HT AB END TERMINATION REPLACEMENT,HT BUSHING ROD REPLACEMENT
2234	23-12-2025	Part of : SECTOR 23 DWARKA	221	Other Outage	Planned Outage	23-12-2025	12:58	23-12-2025	15:50	2:52	0.000956	LT AB SAGGING PER SPAN
2235	23-12-2025	Part of : BLOCK RZ PALAM	304	Other Outage	Planned Outage	23-12-2025	12:59	23-12-2025	15:49	2:50	0.000944	LT AB SAGGING PER SPAN
2236	23-12-2025	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	774	Other Outage	Planned Outage	23-12-2025	12:10	23-12-2025	15:00	2:50	0.000944	LT AB SAGGING PER SPAN
2237	23-12-2025	Part of : BLOCK J SAGARPUR WEST	817	Other Outage	Planned Outage	23-12-2025	11:25	23-12-2025	14:17	2:52	0.000956	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS
2238	23-12-2025	Part of : PALAM VILLAGE	490	Other Outage	Planned Outage	23-12-2025	11:25	23-12-2025	14:16	2:51	0.000950	LT AB SAGGING PER SPAN
2239	24-12-2025	Part of : BAGDAULA VILLAGE SECTOR 8 DWARKA,	478	Other Outage	Planned Outage	24-12-2025	14:55	24-12-2025	17:08	2:13	0.000739	MAINTENANCE OF LT CIRCUIT
2240	24-12-2025	Part of : SECTOR 9 DWARKA,	4	Other Outage	Planned Outage	24-12-2025	14:54	24-12-2025	16:59	2:05	0.000694	MAINTENANCE OF LT CIRCUIT
2241	24-12-2025	Part of : BLOCK G RAJ NAGAR 2 RAJ NAGAR,	720	Other Outage	Planned Outage	24-12-2025	13:23	24-12-2025	15:50	2:27	0.000817	MAINTENANCE OF LT CIRCUIT
2242	24-12-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	532	Other Outage	Planned Outage	24-12-2025	12:26	24-12-2025	14:56	2:30	0.000833	MAINTENANCE OF LT CIRCUIT
2243	24-12-2025	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM	2061	Other Outage	Planned Outage	24-12-2025	11:17	24-12-2025	14:09	2:52	0.000956	MAINTENANCE OF HVDS

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2244	24-12-2025	Part of : BLOCK J PALAM,	463	Other Outage	Planned Outage	24-12-2025	11:08	24-12-2025	13:59	2:51	0.000950	MAINTENANCE OF LT TRANSFORMER
2245	24-12-2025	Part of : BLOCK G RAJ NAGAR 2 RAJ NAGAR,	931	Other Outage	Planned Outage	24-12-2025	11:29	24-12-2025	14:22	2:53	0.000961	MAINTENANCE OF LT TRANSFORMER
2246	24-12-2025	Part of : BLOCK B 2 DASRATHPURI,	532	Other Outage	Planned Outage	24-12-2025	11:26	24-12-2025	14:17	2:51	0.000950	MAINTENANCE OF LT TRANSFORMER
2247	25-12-2025	Part of : Mahavir Enclave Part 2 Mahavir Enclave	978	Other Outage	Unplanned Outage	25-12-2025	03:42	25-12-2025	04:12	0:30	0.000100	CABLE FAULT
2248	26-12-2025	Part of : SECTOR 9 DWARKA	15	Other Outage	Planned Outage	26-12-2025	12:40	26-12-2025	13:36	0:56	0.000311	LT CIRCUIT MAINTENANCE
2249	26-12-2025	Part of : PLOT-18 B CROWN RESIDENCY APPT	1	Other Outage	Planned Outage	26-12-2025	11:58	26-12-2025	15:45	3:47	0.001261	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2250	26-12-2025	Part of : BLOCK RZ PALAM	797	Other Outage	Planned Outage	26-12-2025	12:31	26-12-2025	15:50	3:19	0.001106	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2251	26-12-2025	Part of : BLOCK B RAJ NAGAR 2	1490	Other Outage	Planned Outage	26-12-2025	13:31	26-12-2025	16:20	2:49	0.000939	LT CIRCUIT MAINTENANCE
2252	26-12-2025	Part of : BLOCK B 2 DASRATHPURI	804	Other Outage	Planned Outage	26-12-2025	13:35	26-12-2025	16:21	2:46	0.000922	LT CIRCUIT MAINTENANCE
2253	26-12-2025	Part of : MANGALPURI I PALAM	1065	Other Outage	Planned Outage	26-12-2025	13:12	26-12-2025	15:51	2:39	0.000883	LT CIRCUIT MAINTENANCE
2254	26-12-2025	Part of : VAISHALI EXTENSION DASRATHPURI	607	Other Outage	Planned Outage	26-12-2025	13:00	26-12-2025	15:46	2:46	0.000922	LT CIRCUIT MAINTENANCE
2255	26-12-2025	Part of : BLOCK R RAGHU NAGAR DABRI	681	Other Outage	Planned Outage	26-12-2025	10:58	26-12-2025	13:49	2:51	0.000950	LT CIRCUIT MAINTENANCE
2256	26-12-2025	Part of : BLOCK B SECTOR 8 DWARKA	110	Other Outage	Planned Outage	26-12-2025	11:15	26-12-2025	13:35	2:20	0.000778	LT CIRCUIT MAINTENANCE
2257	26-12-2025	Part of : MIRZAPUR MAHAVIR ENCLAVE	1343	Other Outage	Planned Outage	26-12-2025	11:16	26-12-2025	13:42	2:26	0.000811	LT CIRCUIT MAINTENANCE
2258	27-12-2025	Part of : PALAM VIHAR SADH NAGAR 1 PALAM	2734	Other Outage	Planned Outage	27-12-2025	11:08	27-12-2025	13:06	1:58	0.000328	GUARD WIRES SAGGING PER SPAN
2259	27-12-2025	Part of : SECTOR 23 DWARKA	221	Other Outage	Planned Outage	27-12-2025	13:05	27-12-2025	14:37	1:32	0.000511	LT AB SAGGING PER SPAN
2260	27-12-2025	Part of : PALAM VILLAGE PALAM	490	Other Outage	Planned Outage	27-12-2025	11:07	27-12-2025	13:05	1:58	0.000328	LT AB SAGGING PER SPAN
2261	27-12-2025	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY MAHAVIR ENCLAVE PART 2	1759	Other Outage	Planned Outage	27-12-2025	11:16	27-12-2025	14:02	2:46	0.000922	1PH HT AB END TERMINATION REPLACEMENT,LT BUSHING REPLACEMENT
2262	27-12-2025	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1	460	Other Outage	Planned Outage	27-12-2025	11:25	27-12-2025	13:58	2:33	0.000850	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
2263	27-12-2025	Part of : BLOCK A MAHAVIR ENCLAVE	417	Other Outage	Planned Outage	27-12-2025	11:06	27-12-2025	14:00	2:54	0.000967	LT AB SAGGING PER SPAN
2264	27-12-2025	Part of : BLOCK A SECTOR 8 DWARKA	171	Other Outage	Planned Outage	27-12-2025	11:44	27-12-2025	14:35	2:51	0.000950	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR
2265	29-12-2025	Part of : BLOCK B 2 DASRATHPURI	709	Other Outage	Planned Outage	29-12-2025	12:13	29-12-2025	15:54	3:41	0.001228	DT REPLACEMENT
2266	29-12-2025	Part of : NAVEEN KUNJ SOCIETY NARSIRPUR	221	Other Outage	Planned Outage	29-12-2025	11:58	29-12-2025	15:45	3:47	0.001261	REPLACEMENT OF CROSS-ARMS AND POLES
2267	29-12-2025	Part of : DABRI VILLAGE DABRI,BLOCK B DASRATHPURI,VAISHALI EXTENSION DASRATHPURI	246	Other Outage	Planned Outage	29-12-2025	11:12	29-12-2025	14:00	2:48	0.000933	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2268	29-12-2025	Part of : KAILASHPURI MAIN PALAM,BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM,POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM	3527	Other Outage	Planned Outage	29-12-2025	10:32	29-12-2025	13:10	2:38	0.000878	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2269	29-12-2025	Part of : BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR	872	Other Outage	Planned Outage	29-12-2025	11:28	29-12-2025	14:23	2:55	0.000972	LT AB SAGGING PER SPAN
2270	29-12-2025	Part of : VAISHALI EXTENSION DASRATHPURI	607	Other Outage	Planned Outage	29-12-2025	11:27	29-12-2025	14:24	2:57	0.000983	LT AB SAGGING PER SPAN
2271	30-12-2025	Part of : A-BLOCK MAHAVIR ENCLAVE PART 1	774	Other Outage	Planned Outage	30-12-2025	14:40	30-12-2025	16:09	1:29	0.000494	LT CIRCUIT MAINTENANCE WORK
2272	30-12-2025	Part of : P-BLOCK RAJ NAGAR EXTENSION,SECTOR 8 DWARKA	1007	Other Outage	Planned Outage	30-12-2025	11:28	30-12-2025	14:17	2:49	0.000939	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
2273	30-12-2025	Part of : SPG COMPLEX DWARKA SEC-21	1	Other Outage	Planned Outage	30-12-2025	11:42	30-12-2025	15:32	3:50	0.000639	REPLACEMENT OF CROSS-ARMS AND POLES
2274	30-12-2025	Part of : B 2 & C-BLOCK DASRATHPURI,DURGA PARK COLONY,B-BLOCK DABRI EXTENSION EAST	871	Other Outage	Planned Outage	30-12-2025	11:43	30-12-2025	14:31	2:48	0.000933	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2275	30-12-2025	Part of : KAILASHPURI MAIN,KAILASHPURI WEST,INDIRA PARK EXTENSION	2061	Other Outage	Planned Outage	30-12-2025	10:44	30-12-2025	13:25	2:41	0.000894	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
2276	30-12-2025	Part of : MANGALPURI-1 PALAM	1065	Other Outage	Planned Outage	30-12-2025	13:03	30-12-2025	15:51	2:48	0.000933	LT CIRCUIT MAINTENANCE WORK
2277	30-12-2025	Part of : SECTOR 23 DWARKA	221	Other Outage	Planned Outage	30-12-2025	12:16	30-12-2025	15:04	2:48	0.000933	LT CIRCUIT MAINTENANCE WORK
2278	30-12-2025	Part of : A-BLOCK MAHAVIR ENCLAVE PART-1	774	Other Outage	Planned Outage	30-12-2025	11:52	30-12-2025	14:42	2:50	0.000944	LT CIRCUIT MAINTENANCE WORK
2279	31-12-2025	Part of : SECTOR 23 DWARKA,SECTOR 22 DWARKA	1102	Other Outage	Unplanned Outage	31-12-2025	10:53	31-12-2025	11:30	0:37	0.000617	TREE TOUCHING
2280	31-12-2025	Part of : POCKET 6 SECTOR 1 NARSIRPUR	445	Other Outage	Planned Outage	31-12-2025	12:07	31-12-2025	15:55	3:48	0.001267	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2281	31-12-2025	Part of : SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION	56	Other Outage	Planned Outage	31-12-2025	11:00	31-12-2025	13:57	2:57	0.000983	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2282	31-12-2025	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,BLOCK RZ KAMAL PARK KAILASHPURI MAIN PALAM	2610	Other Outage	Planned Outage	31-12-2025	10:57	31-12-2025	13:20	2:23	0.000794	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
2283	31-12-2025	Part of : BLOCK A SITAPURI PART 1	97	Other Outage	Planned Outage	31-12-2025	11:11	31-12-2025	13:58	2:47	0.000928	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
2284	31-12-2025	Part of : BLOCK RZ PALAM	493	Other Outage	Planned Outage	31-12-2025	11:45	31-12-2025	14:32	2:47	0.000928	LT AB SAGGING PER SPAN
2285	01-12-2025	Part of : CHAUKHANDI VISHNU GARDEN	3000	Other Outage	Unplanned Outage	01-12-2025	13:34	01-12-2025	14:21	0:47	0.000131	CABLE FAULT
2286	01-12-2025	Part of : BLOCK I KHAYALA VILLAGE KHAYALA VISHNU GARDEN	503	Other Outage	Unplanned Outage	01-12-2025	18:35	01-12-2025	20:33	1:58	0.000328	ATTENDING WEAK POINTS/HOT SPOT
2287	01-12-2025	Part of : BLOCK C KHAYALA VISHNU GARDEN	149	Other Outage	Planned Outage	01-12-2025	10:53	01-12-2025	14:12	3:19	0.000553	REPLACEMENT OF HT BUSHING ROD
2288	01-12-2025	Part of : POCKET A RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	2150	Other Outage	Planned Outage	01-12-2025	11:19	01-12-2025	14:20	3:01	0.000503	REPLACEMENT OF HT BUSHING ROD
2289	02-12-2025	Part of : A-BLOCK NURSIGH GARDEN,I-BLOCK KHAYALA VILLAGE KHAYALA VISHNU GARDEN	768	Other Outage	Unplanned Outage	02-12-2025	17:08	02-12-2025	18:02	0:54	0.000960	HT SYSTEM FAULT
2290	02-12-2025	Part of : BLOCK C HARJAN COLONY TILAK NAGAR	203	Other Outage	Planned Outage	02-12-2025	10:41	02-12-2025	13:43	3:02	0.000506	REPLACEMET OF HT BUSHING ROD
2291	02-12-2025	Part of : BLOCK FD JANTA COLONY TAGORE GARDEN EXTENSION	735	Other Outage	Planned Outage	02-12-2025	10:15	02-12-2025	13:14	2:59	0.000497	REPLACEMET OF HT BUSHING ROD
2292	03-12-2025	Part of : BLOCK A VISHAL ENCLAVE TAGORE GARDEN EXTENSION,TAGORE GARDEN EXTENSION,KUKREJA HOSPITAL (HTC)	2190	Other Outage	Unplanned Outage	03-12-2025	16:07	03-12-2025	16:59	0:52	0.000751	HT SYSTEM FAULT
2293	03-12-2025	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN	485	Other Outage	Planned Outage	03-12-2025	11:20	03-12-2025	14:02	2:42	0.000450	REPLACEMET OF HT BUSHING ROD
2294	03-12-2025	Part of : BLOCK EC VISHAL ENCLAVE TAGORE GARDEN EXTENSION	312	Other Outage	Planned Outage	03-12-2025	10:54	03-12-2025	13:39	2:45	0.000458	REPLACEMET OF HT BUSHING ROD
2295	03-12-2025	Part of : BLOCK K MAHAVIR NAGAR NEW TILAK NAGAR	441	Other Outage	Planned Outage	03-12-2025	10:39	03-12-2025	13:37	2:58	0.000494	REPLACEMET OF HT BUSHING ROD
2296	03-12-2025	Part of : BLOCK N SHAM NAGAR VISHNU GARDEN	222	Other Outage	Planned Outage	03-12-2025	12:38	03-12-2025	15:45	3:07	0.000000	INSULATOR REPLACEMENT PER POLE,LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
2297	04-12-2025	Part of : BLOCK D TAGORE GARDEN TAGORE GARDEN EXTENSION	1075	Other Outage	Planned Outage	04-12-2025	13:53	04-12-2025	15:22	1:29	0.000247	REPLACEMENT OF HT BUSHING ROD
2298	04-12-2025	Part of : BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION	424	Other Outage	Planned Outage	04-12-2025	10:59	04-12-2025	14:12	3:13	0.000536	REPLACEMENT OF HT BUSHING ROD
2299	04-12-2025	Part of : BLOCK T KHAYALA VISHNU GARDEN	2655	Other Outage	Planned Outage	04-12-2025	11:03	04-12-2025	14:13	3:10	0.000528	REPLACEMENT OF HT BUSHING ROD
2300	04-12-2025	Part of : BLOCK A MAHAVIR NAGAR NEW TILAK NAGAR	838	Other Outage	Planned Outage	04-12-2025	10:42	04-12-2025	14:14	3:32	0.001472	REPLACEMENT OF HT BUSHING ROD
2301	05-12-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	847	Other Outage	Planned Outage	05-12-2025	10:55	05-12-2025	14:00	3:05	0.000514	CONDUCTOR REPLACEMENT PER SPAN
2302	05-12-2025	Part of : BLOCK S4 MAHAVIR NAGAR NEW TILAK NAGAR,BLOCK A MAHAVIR NAGAR NEW TILAK NAGAR	1389	Other Outage	Planned Outage	05-12-2025	10:45	05-12-2025	13:55	3:10	0.001056	REPLACEMET OF HT BUSHING ROD
2303	05-12-2025	Part of : BLOCK FD JANTA COLONY TAGORE GARDEN EXTENSION	734	Other Outage	Planned Outage	05-12-2025	11:53	05-12-2025	14:03	2:10	0.000722	REPLACEMET OF HT BUSHING ROD
2304	05-12-2025	Part of : BLOCK D KHAYALA VISHNU GARDEN	490	Other Outage	Planned Outage	05-12-2025	10:32	05-12-2025	13:52	3:20	0.000000	CONDUCTOR REPLACEMENT PER SPAN,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
2305	06-12-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	2225	Other Outage	Planned Outage	06-12-2025	10:32	06-12-2025	13:12	2:40	0.000444	HT CONDUCTOR REPLACEMENT
2306	06-12-2025	Part of : S-BLOCK KHAYALA VISHNU GARDEN	1411	Other Outage	Planned Outage	06-12-2025	11:41	06-12-2025	14:56	3:15	0.000542	HT CONDUCTOR REPLACEMENT
2307	08-12-2025	Part of : BLOCK A VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	168	Other Outage	Planned Outage	08-12-2025	10:27	08-12-2025	13:35	3:08	0.000522	REPLACEMET OF HT BUSHING ROD
2308	08-12-2025	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN,	675	Other Outage	Planned Outage	08-12-2025	11:36	08-12-2025	14:42	3:06	0.000517	REPLACEMET OF HT BUSHING ROD
2309	08-12-2025	Part of : BLOCK E OLD MAHAVIR NAGAR TILAK NAGAR,BLOCK F OLD MAHAVIR NAGAR TILAK NAGAR,	1136	Other Outage	Planned Outage	08-12-2025	10:33	08-12-2025	13:36	3:03	0.000763	REPLACEMET OF HT BUSHING ROD
2310	08-12-2025	Part of : POCKET A RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	2150	Other Outage	Planned Outage	08-12-2025	11:14	08-12-2025	14:32	3:18	0.000550	REPLACEMET OF HT BUSHING ROD
2311	09-12-2025	Part of : BLOCK A VISHAL ENCLAVE TAGORE GARDEN EXTENSION	208	Other Outage	Planned Outage	09-12-2025	11:09	09-12-2025	14:33	3:24	0.000567	REPLACEMENT OF HT BUSHING ROD
2312	09-12-2025	Part of : BLOCK M SHAM NAGAR VISHNU GARDEN	875	Other Outage	Planned Outage	09-12-2025	11:08	09-12-2025	14:33	3:25	0.000569	REPLACEMENT OF HT BUSHING ROD
2313	10-12-2025	Part of : POCKET E SHAM NAGAR VISHNU GARDEN	1340	Other Outage	Planned Outage	10-12-2025	11:56	10-12-2025	13:58	2:02	0.000339	REPLACEMENT OF HT BUSHING ROD
2314	10-12-2025	Part of : S 2-BLOCK OLD MAHAVIR NAGAR TILAK NAGAR	883	Other Outage	Planned Outage	10-12-2025	11:12	10-12-2025	14:22	3:10	0.000528	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2315	10-12-2025	Part of : BLOCK 6 TILAK NAGAR	527	Other Outage	Planned Outage	10-12-2025	11:16	10-12-2025	14:18	3:02	0.000506	REPLACEMENT OF HT BUSHING ROD
2316	10-12-2025	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	284	Other Outage	Planned Outage	10-12-2025	10:28	10-12-2025	13:55	3:27	0.000575	REPLACEMENT OF HT BUSHING ROD
2317	10-12-2025	Part of : A-BLOCK NURSIGH GARDEN KHAYALA VISHNU GARDEN	304	Other Outage	Planned Outage	10-12-2025	11:15	10-12-2025	14:16	3:01	0.000000	LT CIRCUIT MAINTENANCE
2318	11-12-2025	Part of : SHIVAJI PALACE VISHAL ENCLAVE TAGORE GARDEN EXTENSION	57	Other Outage	Planned Outage	11-12-2025	11:06	11-12-2025	14:21	3:15	0.000813	REPLACEMET OF HT BUSHING ROD
2319	11-12-2025	Part of : BLOCK N SHAM NAGAR VISHNU GARDEN	1195	Other Outage	Planned Outage	11-12-2025	10:45	11-12-2025	14:23	3:38	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
2320	12-12-2025	Part of : BLOCK C VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	1164	Other Outage	Planned Outage	12-12-2025	10:49	12-12-2025	13:19	2:30	0.000417	REPLACEMET OF HT BUSHING ROD
2321	12-12-2025	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION,	1	Other Outage	Planned Outage	12-12-2025	10:57	12-12-2025	14:28	3:31	0.000586	REPLACEMET OF HT BUSHING ROD
2322	12-12-2025	Part of : RAVI NAGAR VISHNU GARDEN,	2332	Other Outage	Planned Outage	12-12-2025	12:03	12-12-2025	15:08	3:05	0.000514	REPLACEMET OF HT BUSHING ROD
2323	12-12-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN,	2223	Other Outage	Planned Outage	12-12-2025	12:12	12-12-2025	15:10	2:58	0.000742	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
2324	12-12-2025	Part of : SANT NAGAR CHAUKHANDI VISHNU GARDEN,BLOCK WZ SHAHPURA CHAUKHANDI VISHNU GARDEN	983	Other Outage	Planned Outage	12-12-2025	10:40	12-12-2025	13:31	2:51	0.000475	REPLACEMET OF HT BUSHING ROD
2325	13-12-2025	Part of : BLOCK I KHAYALA VILLAGE KHAYALA VISHNU GARDEN	488	Other Outage	Planned Outage	13-12-2025	11:52	13-12-2025	14:27	2:35	0.000431	REPLACEMENT OF HT BUSHING ROD
2326	13-12-2025	Part of : BLOCK D KHAYALA VISHNU GARDEN	545	Other Outage	Planned Outage	13-12-2025	11:16	13-12-2025	13:33	2:17	0.000381	REPLACEMENT OF HT BUSHING ROD
2327	15-12-2025	Part of : SHIVAJI PALACE VISHAL ENCLAVE TAGORE GARDEN EXTENSION, GGS HOSPITAL (HTC)	0	Other Outage	Unplanned Outage	15-12-2025	04:28	15-12-2025	05:22	0:54	0.000315	CABLE FAULT
2328	15-12-2025	Part of : BLOCK I KHAYALA VILLAGE KHAYALA VISHNU GARDEN	503	Other Outage	Planned Outage	15-12-2025	10:59	15-12-2025	14:17	3:18	0.000550	REPLACEMET OF HT BUSHING ROD
2329	15-12-2025	Part of : BLOCK K RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	1306	Other Outage	Planned Outage	15-12-2025	11:00	15-12-2025	14:16	3:16	0.000544	REPLACEMET OF HT BUSHING ROD
2330	15-12-2025	Part of : BLOCK S KHAYALA VISHNU GARDEN	387	Other Outage	Planned Outage	15-12-2025	11:21	15-12-2025	14:18	2:57	0.000492	REPLACEMET OF HT BUSHING ROD
2331	15-12-2025	Part of : BLOCK D TAGORE GARDEN TAGORE GARDEN EXTENSION	417	Other Outage	Planned Outage	15-12-2025	11:00	15-12-2025	14:15	3:15	0.000542	REPLACEMET OF HT BUSHING ROD
2332	16-12-2025	Part of : SANT NAGAR CHAUKHANDI VISHNU GARDEN,	545	Other Outage	Planned Outage	16-12-2025	10:58	16-12-2025	13:20	2:22	0.002761	MAINTENANCE OF TRANSFORMER
2333	16-12-2025	Part of : BLOCK C MAHAVIR NAGAR NEW TILAK NAGAR,	250	Other Outage	Planned Outage	16-12-2025	10:57	16-12-2025	14:28	3:31	0.000586	MAINTENANCE OF TRANSFORMER
2334	16-12-2025	Part of : BLOCK NA KHAYALA VISHNU GARDEN,	2189	Other Outage	Planned Outage	16-12-2025	10:59	16-12-2025	14:30	3:31	0.000586	MAINTENANCE OF TRANSFORMER
2335	16-12-2025	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION,	118	Other Outage	Planned Outage	16-12-2025	10:58	16-12-2025	13:44	2:46	0.000461	MAINTENANCE OF TRANSFORMER
2336	16-12-2025	Part of : TAGORE GARDEN TAGORE GARDEN EXTENSION,	999	Other Outage	Planned Outage	16-12-2025	10:59	16-12-2025	13:44	2:45	0.000458	MAINTENANCE OF TRANSFORMER
2337	16-12-2025	Part of : NEW CHAUKHANDI VISHNU GARDEN,	140	Other Outage	Planned Outage	16-12-2025	11:00	16-12-2025	13:19	2:19	0.002703	MAINTENANCE OF TRANSFORMER
2338	17-12-2025	Part of : BLOCK D KHAYALA VISHNU GARDEN	490	Other Outage	Planned Outage	17-12-2025	11:52	17-12-2025	13:43	1:51	0.000000	CONDUCTOR REPLACEMENT PER SPAN
2339	17-12-2025	Part of : POCKET A RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	35	Other Outage	Planned Outage	17-12-2025	10:51	17-12-2025	13:43	2:52	0.000478	REPLACEMENT OF HT BUSHING ROD
2340	17-12-2025	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	564	Other Outage	Planned Outage	17-12-2025	10:51	17-12-2025	14:07	3:16	0.002722	REPLACEMENT OF GAS KIT AND OIL SEAL
2341	17-12-2025	Part of : BLOCK WZ KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	90	Other Outage	Planned Outage	17-12-2025	10:52	17-12-2025	14:10	3:18	0.000550	REPLACEMENT OF HT BUSHING ROD
2342	18-12-2025	Part of : SHIVAJI PALACE VISHAL ENCLAVE TAGORE GARDEN EXTENSION	0	Other Outage	Unplanned Outage	18-12-2025	04:37	18-12-2025	05:33	0:56	0.000233	HT SYSTEM FAULT
2343	18-12-2025	Part of : SHIVAJI PALACE VISHAL ENCLAVE TAGORE GARDEN EXTENSION	0	Other Outage	Unplanned Outage	18-12-2025	06:34	18-12-2025	07:35	1:01	0.000271	HT SYSTEM FAULT
2344	18-12-2025	Part of : RG-BLOCK RAGHUBIR NAGAR EXTENSION	422	Other Outage	Planned Outage	18-12-2025	11:36	18-12-2025	14:33	2:57	0.000492	REPLACEMENT OF HT BUSHING ROD
2345	18-12-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	1029	Other Outage	Planned Outage	18-12-2025	10:41	18-12-2025	14:35	3:54	0.000000	LT CIRCUIT MAINTENANCE
2346	19-12-2025	Part of : KRISHNA PARK EXTENSION TILAK NAGAR	1421	Other Outage	Planned Outage	19-12-2025	11:03	19-12-2025	14:13	3:10	0.001056	REPLACEMET OF HT BUSHING ROD
2347	19-12-2025	Part of : BLOCK WZ KHAYALA VISHNU GARDEN	812	Other Outage	Planned Outage	19-12-2025	10:50	19-12-2025	14:09	3:19	0.000553	REPLACEMET OF HT BUSHING ROD
2348	19-12-2025	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	5	Other Outage	Planned Outage	19-12-2025	10:49	19-12-2025	13:59	3:10	0.000528	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Affected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2349	20-12-2025	Part of : BLOCK B PRITHVI PARK TILAK NAGAR,BLOCK WZ KRISHNA NAGAR CHAUKHANDI VISHNU GARDEN,SANT NAGAR CHAUKHANDI VISHNU GARDEN,BLOCK WZ SHAHPURA CHAUKHANDI VISHNU GARDEN	4194	Other Outage	Unplanned Outage	20-12-2025	09:25	20-12-2025	10:20	0:55	0.000810	HT SYSTEM FAULT
2350	20-12-2025	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN,	505	Other Outage	Planned Outage	20-12-2025	11:45	20-12-2025	13:42	1:57	0.000325	MAINTENANCE OF TRANSFORMER
2351	20-12-2025	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION,	801	Other Outage	Planned Outage	20-12-2025	13:06	20-12-2025	15:52	2:46	0.000000	MAINTENANCE OF LT CIRCUIT
2352	20-12-2025	Part of : BLOCK AE TAGORE GARDEN TAGORE GARDEN EXTENSION,	276	Other Outage	Planned Outage	20-12-2025	11:18	20-12-2025	13:27	2:09	0.000358	MAINTENANCE OF TRANSFORMER
2353	20-12-2025	Part of : BLOCK WZ MAJ BHUPENDRA SINGH NAGAR CHAUKHANDI VISHNU GARDEN,	427	Other Outage	Planned Outage	20-12-2025	10:53	20-12-2025	13:49	2:56	0.000489	MAINTENANCE OF TRANSFORMER
2354	22-12-2025	Part of : RAVI NAGAR VISHNU GARDEN	1241	Other Outage	Planned Outage	22-12-2025	11:53	22-12-2025	15:20	3:27	0.004025	REPLACEMENT OF GAS KIT AND OIL SEAL
2355	22-12-2025	Part of : K-BLOCK RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	1306	Other Outage	Planned Outage	22-12-2025	11:04	22-12-2025	14:38	3:34	0.000594	REPLACEMENT OF HT BUSHING ROD
2356	22-12-2025	Part of : S 1-BLOCK POCKET A KRISHNA PURI TILAK NAGAR	1175	Other Outage	Planned Outage	22-12-2025	11:03	22-12-2025	14:13	3:10	0.000528	REPLACEMENT OF HT BUSHING ROD
2357	23-12-2025	Part of : BLOCK WZ MBS NAGAR CHAUKHANDI, BLOCK C HARJAN COLONY TILAK NAGAR, KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	571	Other Outage	Unplanned Outage	23-12-2025	08:52	23-12-2025	09:49	0:57	0.001251	HT SYSTEM FAULT
2358	23-12-2025	Part of : BLOCK C GANESH NAGAR TILAK NAGAR	837	Other Outage	Planned Outage	23-12-2025	11:00	23-12-2025	14:09	3:09	0.000525	REPLACEMET OF HT BUSHING ROD
2359	23-12-2025	Part of : BLOCK A VISHAL ENCLAVE TAGORE GARDEN EXTENSION	184	Other Outage	Planned Outage	23-12-2025	11:03	23-12-2025	14:17	3:14	0.000539	REPLACEMET OF HT BUSHING ROD
2360	23-12-2025	Part of : BLOCK G JANTA COLONY TAGORE GARDEN EXTENSION	908	Other Outage	Planned Outage	23-12-2025	11:04	23-12-2025	14:21	3:17	0.000547	LT AB SAGGING PER SPAN
2361	23-12-2025	Part of : MUKHERJI PARK CHAUKHANDI VISHNU GARDEN	421	Other Outage	Planned Outage	23-12-2025	11:04	23-12-2025	14:11	3:07	0.000519	REPLACEMET OF HT BUSHING ROD
2362	24-12-2025	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN	968	Other Outage	Unplanned Outage	24-12-2025	11:22	24-12-2025	12:17	0:55	0.000993	HT SYSTEM FAULT
2363	24-12-2025	Part of : NEW CHAUKHANDI VISHNU GARDEN,	205	Other Outage	Planned Outage	24-12-2025	11:00	24-12-2025	14:14	3:14	0.003233	MAINTENANCE OF TRANSFORMER
2364	24-12-2025	Part of : BLOCK 21 TILAK NAGAR,	1102	Other Outage	Planned Outage	24-12-2025	11:09	24-12-2025	14:25	3:16	0.000544	MAINTENANCE OF TRANSFORMER
2365	24-12-2025	Part of : BLOCK F TAGORE GARDEN TAGORE GARDEN EXTENSION,	902	Other Outage	Planned Outage	24-12-2025	10:58	24-12-2025	14:11	3:13	0.000536	MAINTENANCE OF TRANSFORMER
2366	25-12-2025	Part of : KHAYALA VISHNU GARDEN	363	Other Outage	Planned Outage	25-12-2025	10:14	25-12-2025	13:25	3:11	0.000000	LT AB SAGGING PER SPAN
2367	26-12-2025	Part of : BLOCK C KHAYALA VISHNU GARDEN	140	Other Outage	Planned Outage	26-12-2025	11:54	26-12-2025	14:22	2:28	0.002878	REPLACEMENT OF GAS KIT AND OIL SEAL
2368	26-12-2025	Part of : BLOCK M RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	655	Other Outage	Planned Outage	26-12-2025	11:23	26-12-2025	14:25	3:02	0.000506	REPLACEMENT OF HT BUSHING ROD
2369	26-12-2025	Part of : BLOCK 16 TILAK NAGAR,	250	Other Outage	Planned Outage	26-12-2025	10:23	26-12-2025	13:23	3:00	0.000500	REPLACEMENT OF HT BUSHING ROD
2370	26-12-2025	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	189	Other Outage	Planned Outage	26-12-2025	11:28	26-12-2025	14:20	2:52	0.000000	LT ACB MAINTENANCE
2371	26-12-2025	Part of : BLOCK N SHAM NAGAR VISHNU GARDEN	1197	Other Outage	Planned Outage	26-12-2025	10:01	26-12-2025	13:17	3:16	0.000000	LT ACB MAINTENANCE
2372	27-12-2025	Part of : BLOCK H KHAYALA VISHNU GARDEN	2937	Other Outage	Planned Outage	27-12-2025	11:39	27-12-2025	14:36	2:57	0.000492	REPLACEMET OF HT BUSHING ROD
2373	27-12-2025	Part of : SHIVAJI PALACE VISHAL ENCLAVE TAGORE GARDEN EXTENSION	5	Other Outage	Planned Outage	27-12-2025	10:58	27-12-2025	13:44	2:46	0.000461	REPLACEMET OF HT BUSHING ROD
2374	27-12-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	1041	Other Outage	Planned Outage	27-12-2025	10:19	27-12-2025	13:36	3:17	0.000000	ACB REPLACEMENT PER ACB
2375	28-12-2025	Part of : BLOCK S KHAYALA VISHNU GARDEN,	480	Other Outage	Planned Outage	28-12-2025	15:56	28-12-2025	17:55	1:59	0.000000	PUNCHING LT AB TO LT AB PER FEEDER
2376	29-12-2025	Part of : BLOCK M RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	1313	Other Outage	Planned Outage	29-12-2025	10:56	29-12-2025	14:04	3:08	0.000522	REPLACEMENT OF HT BUSHING ROD
2377	29-12-2025	Part of : BLOCK NA KHAYALA VISHNU GARDEN	2172	Other Outage	Planned Outage	29-12-2025	10:57	29-12-2025	14:01	3:04	0.000511	REPLACEMENT OF HT BUSHING ROD
2378	29-12-2025	Part of : KRISHNA PARK EXTENSION TILAK NAGAR,BLOCK WZ MAHAVIR NAGAR NEW TILAK NAGAR	2655	Other Outage	Planned Outage	29-12-2025	10:58	29-12-2025	14:02	3:04	0.000511	REPLACEMENT OF HT BUSHING ROD
2379	30-12-2025	Part of : POCKET A RAGHUBIR NAGAR,F-BLOCK TAGORE GARDEN EXTENSION	3049	Other Outage	Unplanned Outage	30-12-2025	07:34	30-12-2025	08:20	0:46	0.000294	CABLE FAULT
2380	30-12-2025	Part of : G-BLOCK TILAK NAGAR	1177	Other Outage	Planned Outage	30-12-2025	10:29	30-12-2025	13:37	3:08	0.000522	REPLACEMENT OF HT BUSHING ROD
2381	30-12-2025	Part of : G-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	623	Other Outage	Planned Outage	30-12-2025	10:57	30-12-2025	13:55	2:58	0.000494	REPLACEMENT OF HT BUSHING ROD
2382	30-12-2025	Part of : A-BLOCK NURSIGH GARDEN KHAYALA VISHNU GARDEN	485	Other Outage	Planned Outage	30-12-2025	10:57	30-12-2025	13:39	2:42	0.000450	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2383	31-12-2025	Part of : BLOCK M RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	1313	Other Outage	Planned Outage	31-12-2025	10:57	31-12-2025	13:51	2:54	0.000483	REPLACEMET OF HT BUSHING ROD
2384	01-12-2025	Part of : MAHINDRA PARK BINDAPUR	1473	Other Outage	Planned Outage	01-12-2025	12:43	01-12-2025	13:44	1:01	0.000000	REPLACEMENT OF HT BUSHING ROD
2385	01-12-2025	Part of : BLOCK E PARAM PURI UTTAM NAGAR	203	Other Outage	Planned Outage	01-12-2025	12:48	01-12-2025	16:04	3:16	0.000000	DT REPLACEMENT
2386	02-12-2025	Part of : BLOCK F UTTAM VIHAR BINDAPUR	1156	Other Outage	Planned Outage	02-12-2025	14:42	02-12-2025	16:40	1:58	0.000000	REPLACEMET OF HT BUSHING ROD
2387	02-12-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR	564	Other Outage	Planned Outage	02-12-2025	11:25	02-12-2025	13:39	2:14	0.000000	REPLACEMET OF HT BUSHING ROD
2388	02-12-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	866	Other Outage	Planned Outage	02-12-2025	10:58	02-12-2025	13:37	2:39	0.000000	REPLACEMET OF HT BUSHING ROD
2389	02-12-2025	Part of : BLOCK A RAM DATT ENCLAVE UTTAM NAGAR	1199	Other Outage	Planned Outage	02-12-2025	11:13	02-12-2025	13:35	2:22	0.000000	LT CIRCUIT MAINTENANCE
2390	03-12-2025	Part of : BLOCK B UTTAM NAGAR	231	Other Outage	Planned Outage	03-12-2025	11:25	03-12-2025	13:24	1:59	0.000000	DT REPLACEMENT
2391	03-12-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	1231	Other Outage	Planned Outage	03-12-2025	11:39	03-12-2025	13:26	1:47	0.000000	REPLACEMENT OF LT BUSHING ROD
2392	03-12-2025	Part of : BLOCK C CHANAKYA PLACE I SITAPURI	1566	Other Outage	Planned Outage	03-12-2025	11:15	03-12-2025	13:26	2:11	0.000000	REPLACEMENT OF LT BUSHING ROD
2393	04-12-2025	Part of : INDIRA PARK BINDAPUR	1159	Other Outage	Unplanned Outage	04-12-2025	12:29	04-12-2025	13:43	1:14	0.000617	REFILLING OIL IN TRANSFORMER
2394	04-12-2025	Part of : MAHINDRA PARK BINDAPUR	1472	Other Outage	Unplanned Outage	04-12-2025	14:16	04-12-2025	16:02	1:46	0.000883	REPLACEMENT OF LT CIRCUIT
2395	04-12-2025	Part of : MAHAVIR ENCLAVE PART 3 MAHAVIR ENCLAVE	1207	Other Outage	Planned Outage	04-12-2025	11:55	04-12-2025	13:40	1:45	0.000000	REPLACEMENT OF LT BUSHING ROD
2396	04-12-2025	Part of : BLOCK E UTTAM VIHAR BINDAPUR	332	Other Outage	Planned Outage	04-12-2025	11:23	04-12-2025	13:33	2:10	0.000000	REPLACEMENT OF HT BUSHING ROD
2397	05-12-2025	Part of : C BLOCK CHANAKYA PLACE I SITAPURI	787	Other Outage	Unplanned Outage	05-12-2025	11:37	05-12-2025	12:52	1:15	0.000417	REPAIRING OF TRANSFORMER
2398	05-12-2025	Part of : BLOCK D 2 MAHINDRA PARK BINDAPUR,BLOCK C MAHINDRA PARK BINDAPUR	2428	Other Outage	Planned Outage	05-12-2025	10:42	05-12-2025	13:44	3:02	0.000000	REPLACEMENT OF LT BUSHING ROD
2399	06-12-2025	Part of : INDIRA PARK BINDAPUR	962	Other Outage	Planned Outage	06-12-2025	11:06	06-12-2025	13:54	2:48	0.000000	REPLACEMENT OF HT BUSHING ROD
2400	06-12-2025	Part of : GULABHI BAGH OM VIHAR UTTAM NAGAR	861	Other Outage	Planned Outage	06-12-2025	11:26	06-12-2025	13:48	2:22	0.000000	LT CIRCUIT MAINTENANCE WORK
2401	08-12-2025	Part of : BLOCK D JJ COLONY UTTAM NAGAR,BLOCK G UTTAM NAGAR,BLOCK C MILAP NAGAR UTTAM NAGAR	5218	Other Outage	Unplanned Outage	08-12-2025	13:49	08-12-2025	14:26	0:37	0.000349	CABLE FAULT
2402	08-12-2025	Part of : BLOCK F UTTAM VIHAR BINDAPUR,	1157	Other Outage	Planned Outage	08-12-2025	12:28	08-12-2025	14:50	2:22	0.000000	3PH DB REPLACEMENT
2403	08-12-2025	Part of : SANTOSH PARK UTTAM NAGAR,	1495	Other Outage	Planned Outage	08-12-2025	11:12	08-12-2025	13:45	2:33	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2404	08-12-2025	Part of : BHAGWATI VIHAR BINDAPUR,	1857	Other Outage	Planned Outage	08-12-2025	11:12	08-12-2025	13:49	2:37	0.000000	REPLACEMENT OF LT BUSHING ROD
2405	08-12-2025	Part of : BLOCK A SITAPURI PART 2 SITAPURI,	1	Other Outage	Planned Outage	08-12-2025	10:56	08-12-2025	13:50	2:54	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2406	09-12-2025	Part of : PARAM PURI UTTAM NAGAR	986	Other Outage	Planned Outage	09-12-2025	11:42	09-12-2025	13:51	2:09	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2407	09-12-2025	Part of : BLOCK A SITAPURI PART 2 SITAPURI	691	Other Outage	Planned Outage	09-12-2025	11:06	09-12-2025	13:51	2:45	0.000000	REPLACEMENT OF LT BUSHING ROD
2408	09-12-2025	Part of : BLOCK A3 UTTAM VIHAR BINDAPUR	159	Other Outage	Planned Outage	09-12-2025	10:50	09-12-2025	13:50	3:00	0.000000	REPLACEMENT OF LT BUSHING ROD
2409	10-12-2025	Part of : PARJAPAT COLONY BINDAPUR,NAND RAM PARK NEW UTTAM NAGAR	679	Other Outage	Planned Outage	10-12-2025	12:24	10-12-2025	13:49	1:25	0.000000	3PH HT AB CABLE REPLACEMENT
2410	10-12-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	1231	Other Outage	Planned Outage	10-12-2025	13:53	10-12-2025	16:21	2:28	0.000000	REPLACEMENT OF FAULTY END BOX
2411	10-12-2025	Part of : C-BLOCK CHANAKYA PLACE I SITAPURI	788	Other Outage	Planned Outage	10-12-2025	11:06	10-12-2025	13:49	2:43	0.001811	REPLACEMENT OF CROSS-ARMS AND POLES
2412	10-12-2025	Part of : D-BLOCK MILAP NAGAR UTTAM NAGAR	217	Other Outage	Planned Outage	10-12-2025	11:04	10-12-2025	13:46	2:42	0.000000	LT CIRCUIT MAINTENANCE
2413	11-12-2025	Part of : BLOCK B UTTAM VIHAR BINDAPUR	477	Other Outage	Planned Outage	11-12-2025	11:36	11-12-2025	13:34	1:58	0.000000	REPLACEMENT OF LT BUSHING ROD
2414	11-12-2025	Part of : BHAGAT ENCLAVE BINDAPUR	1004	Other Outage	Planned Outage	11-12-2025	14:25	11-12-2025	15:53	1:28	0.000000	REPLACEMENT OF HT BUSHING ROD
2415	11-12-2025	Part of : OLD JANKI PURI BINDAPUR	416	Other Outage	Planned Outage	11-12-2025	11:07	11-12-2025	13:35	2:28	0.001644	REPLACEMENT OF CROSS-ARMS AND POLES
2416	11-12-2025	Part of : BLOCK E PARAM PURI UTTAM NAGAR	740	Other Outage	Planned Outage	11-12-2025	11:28	11-12-2025	13:33	2:05	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2417	12-12-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,	156	Other Outage	Planned Outage	12-12-2025	12:24	12-12-2025	15:02	2:38	0.000000	REPLACEMET OF HT BUSHING ROD
2418	12-12-2025	Part of : OLD JANKI PURI BINDAPUR,	1336	Other Outage	Planned Outage	12-12-2025	11:07	12-12-2025	13:50	2:43	0.001811	REPLACEMENT OF CROSS-ARMS AND POLES
2419	12-12-2025	Part of : MANAS KUNJ NEW UTTAM NAGAR UTTAM NAGAR,	1129	Other Outage	Planned Outage	12-12-2025	11:29	12-12-2025	13:47	2:18	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2420	13-12-2025	Part of : BLOCK A3 UTTAM VIHAR BINDAPUR	439	Other Outage	Planned Outage	13-12-2025	14:44	13-12-2025	16:21	1:37	0.000000	REPLACEMENT OF LT BUSHING ROD
2421	13-12-2025	Part of : POCKET 4 CHANAKYA PLACE I SITAPURI	338	Other Outage	Planned Outage	13-12-2025	11:15	13-12-2025	13:52	2:37	0.001744	REPLACEMENT OF CROSS-ARMS AND POLES
2422	13-12-2025	Part of : PARJAPAT COLONY BINDAPUR	461	Other Outage	Planned Outage	13-12-2025	11:12	13-12-2025	14:09	2:57	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2423	15-12-2025	Part of : BLOCK F JEEVAN PARK BINDAPUR	626	Other Outage	Unplanned Outage	15-12-2025	15:06	15-12-2025	16:20	1:14	0.000617	FAULTY TRANSFORMER REPLACEMENT
2424	15-12-2025	Part of : BLOCK E SITAPURI PART 2 SITAPURI	390	Other Outage	Planned Outage	15-12-2025	13:28	15-12-2025	14:46	1:18	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF LUGS,SUB STATION CLEANING
2425	15-12-2025	Part of : SANTOSH PARK UTTAM NAGAR	433	Other Outage	Planned Outage	15-12-2025	14:08	15-12-2025	16:23	2:15	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2426	15-12-2025	Part of : BHAGAT ENCLAVE BINDAPUR	1004	Other Outage	Planned Outage	15-12-2025	12:19	15-12-2025	14:45	2:26	0.000000	3PH DB REPLACEMENT
2427	15-12-2025	Part of : UTTAM VIHAR BINDAPUR	1006	Other Outage	Planned Outage	15-12-2025	11:08	15-12-2025	13:58	2:50	0.000000	REPLACEMENT OF HT BUSHING ROD
2428	15-12-2025	Part of : BLOCK B SITAPURI PART 2	997	Other Outage	Planned Outage	15-12-2025	11:41	15-12-2025	13:58	2:17	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2429	16-12-2025	Part of : BLOCK F UTTAM VIHAR BINDAPUR,	1691	Other Outage	Planned Outage	16-12-2025	14:53	16-12-2025	16:27	1:34	0.000914	MAINTENANCE OF LT CIRCUIT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2430	16-12-2025	Part of : NANHEY PARK OM VIHAR UTTAM NAGAR,	901	Other Outage	Planned Outage	16-12-2025	13:30	16-12-2025	15:30	2:00	0.000000	MAINTENANCE OF LT CIRCUIT
2431	16-12-2025	Part of : BLOCK C MAHINDRA PARK BINDAPUR,	804	Other Outage	Planned Outage	16-12-2025	11:00	16-12-2025	13:24	2:24	0.000000	MAINTENANCE OF LT TRANSFORMER
2432	16-12-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR,	1598	Other Outage	Planned Outage	16-12-2025	11:17	16-12-2025	13:23	2:06	0.000000	MAINTENANCE OF LT TRANSFORMER
2433	17-12-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	1004	Other Outage	Planned Outage	17-12-2025	11:59	17-12-2025	13:29	1:30	0.000000	REPLACEMENT OF HT BUSHING ROD
2434	17-12-2025	Part of : BLOCK F JEEVAN PARK BINDAPUR	1410	Other Outage	Planned Outage	17-12-2025	11:17	17-12-2025	13:24	2:07	0.001411	REPLACEMENT OF CROSS-ARMS AND POLES
2435	17-12-2025	Part of : BLOCK O UTTAM NAGAR	786	Other Outage	Planned Outage	17-12-2025	13:23	17-12-2025	16:12	2:49	0.000000	HT AB CABLE REPLACEMENT PER SPAN
2436	18-12-2025	Part of : OLD JANKI PURI BINDAPUR	657	Other Outage	Planned Outage	18-12-2025	11:08	18-12-2025	13:59	2:51	0.001188	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
2437	18-12-2025	Part of : F-BLOCK JEEVAN PARK BINDAPUR	505	Other Outage	Planned Outage	18-12-2025	11:04	18-12-2025	13:58	2:54	0.000000	REPLACEMENT OF HT BUSHING ROD
2438	18-12-2025	Part of : E-BLOCK PARAM PURI UTTAM NAGAR	352	Other Outage	Planned Outage	18-12-2025	14:11	18-12-2025	16:46	2:35	0.000000	LT ACB MAINTENANCE
2439	19-12-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,MAHAVIR ENCLAVE PART 3,BINDAPUR POCKET-4,CHANAKYA PLACE	3288	Other Outage	Unplanned Outage	19-12-2025	09:22	19-12-2025	09:50	0:28	0.000552	HT SYSTEM FAULT
2440	19-12-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	749	Other Outage	Planned Outage	19-12-2025	13:02	19-12-2025	16:48	3:46	0.000000	REPLACEMET OF HT BUSHING ROD
2441	20-12-2025	Part of : BLOCK A UTTAM VIHAR BINDAPUR,	23	Other Outage	Planned Outage	20-12-2025	13:58	20-12-2025	15:44	1:46	0.000000	MAINTENANCE OF LT CIRCUIT
2442	20-12-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,	1242	Other Outage	Planned Outage	20-12-2025	13:59	20-12-2025	15:43	1:44	0.000867	MAINTENANCE OF LT CIRCUIT
2443	20-12-2025	Part of : BLOCK A 3 HARJAN COLONY SITAPURI PART 1 SITAPURI,	518	Other Outage	Planned Outage	20-12-2025	10:57	20-12-2025	13:56	2:59	0.000000	MAINTENANCE OF TRANSFORMER
2444	21-12-2025	Part of : JAIN COLONY MATIALA,PARAM PURI UTTAM NAGAR,SANTOSH PARK UTTAM NAGAR,BHAGWATI VIHAR BINDAPUR,BLOCK C UTTAM VIHAR BINDAPUR	4134	Other Outage	Unplanned Outage	21-12-2025	03:43	21-12-2025	04:25	0:42	0.000163	FAULT IN HT CONSUMER PANEL (CGL DDA COMMUNITY HALL)
2445	22-12-2025	Part of : A-BLOCK KIRAN GARDENS UTTAM NAGAR	460	Other Outage	Planned Outage	22-12-2025	14:34	22-12-2025	15:34	1:00	0.000000	LT CIRCUIT MAINTENANCE WORK
2446	22-12-2025	Part of : MAHINDRA PARK BINDAPUR	1472	Other Outage	Planned Outage	22-12-2025	11:33	22-12-2025	13:35	2:02	0.000000	LT CIRCUIT MAINTENANCE WORK
2447	22-12-2025	Part of : PARAM PURI UTTAM NAGAR	827	Other Outage	Planned Outage	22-12-2025	12:22	22-12-2025	15:24	3:02	0.000000	LT CIRCUIT MAINTENANCE WORK
2448	23-12-2025	Part of : BHAGWATI VIHAR BINDAPUR	1976	Other Outage	Planned Outage	23-12-2025	11:27	23-12-2025	13:51	2:24	0.000000	REPLACEMENT OF HT BUSHING ROD
2449	23-12-2025	Part of : BLOCK F JEEVAN PARK BINDAPUR	505	Other Outage	Planned Outage	23-12-2025	11:02	23-12-2025	13:53	2:51	0.000000	REPLACEMENT OF LT BUSHING ROD
2450	24-12-2025	Part of : OLD JANKI PURI BINDAPUR,	500	Other Outage	Planned Outage	24-12-2025	11:10	24-12-2025	13:39	2:29	0.000000	MAINTENANCE OF TRANSFORMER
2451	26-12-2025	Part of : BLOCK A UTTAM VIHAR BINDAPUR	23	Other Outage	Planned Outage	26-12-2025	12:33	26-12-2025	15:15	2:42	0.000000	REPLACEMENT OF HT BUSHING ROD
2452	26-12-2025	Part of : OLD JANKI PURI BINDAPUR	555	Other Outage	Planned Outage	26-12-2025	11:11	26-12-2025	13:32	2:21	0.000000	REPLACEMENT OF HT BUSHING ROD
2453	29-12-2025	Part of : MANAS KUNJ NEW UTTAM NAGAR UTTAM NAGAR	1151	Other Outage	Planned Outage	29-12-2025	11:13	29-12-2025	13:50	2:37	0.000000	DT REPLACEMENT
2454	29-12-2025	Part of : BLOCK B UTTAM VIHAR BINDAPUR	604	Other Outage	Planned Outage	29-12-2025	11:38	29-12-2025	13:50	2:12	0.000000	REPLACEMENT OF HT BUSHING ROD
2455	30-12-2025	Part of : D-BLOCK JJ COLONY UTTAM NAGAR	988	Other Outage	Planned Outage	30-12-2025	11:44	30-12-2025	15:03	3:19	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2456	30-12-2025	Part of : C-BLOCK MAHINDRA PARK BINDAPUR	1034	Other Outage	Planned Outage	30-12-2025	11:02	30-12-2025	13:28	2:26	0.000000	LT CIRCUIT MAINTENANCE WORK
2457	31-12-2025	Part of : OLD JANKI PURI BINDAPUR	657	Other Outage	Unplanned Outage	31-12-2025	14:50	31-12-2025	16:48	1:58	0.000983	LAYING OF NEW LTAB
2458	31-12-2025	Part of : INDIRA PARK BINDAPUR	962	Other Outage	Planned Outage	31-12-2025	11:15	31-12-2025	13:49	2:34	0.000000	REPLACEMENT OF LT BUSHING ROD
2459	01-12-2025	Part of : BLOCK A 2 UTTAM NAGAR,KRISHNA COLONY HASTSAL VILLAGE HASTSAL,HOSTAL VIHAR OM VIHAR HASTSAL,PHASE 2 OM VIHAR HASTSAL	3148	Other Outage	Unplanned Outage	01-12-2025	09:07	01-12-2025	09:40	0:33	0.000394	HT SYSTEM FAULT
2460	01-12-2025	Part of : KESHOPUR VIKAS PURI	328	Other Outage	Planned Outage	01-12-2025	15:17	01-12-2025	16:29	1:12	0.000000	REPLACEMENT OF LT BUSHING ROD
2461	01-12-2025	Part of : PHASE 1 OM VIHAR NAWADA	1084	Other Outage	Planned Outage	01-12-2025	12:45	01-12-2025	15:41	2:56	0.000000	REPLACEMENT OF LT BUSHING ROD
2462	01-12-2025	Part of : B-BLOCK VIKAS VIHAR	1737	Other Outage	Planned Outage	01-12-2025	11:03	01-12-2025	13:43	2:40	0.000000	REPLACEMENT OF LT BUSHING ROD
2463	02-12-2025	Part of : BLOCK H3 VIKAS PURI	7	Other Outage	Planned Outage	02-12-2025	10:41	02-12-2025	12:39	1:58	0.000000	LT CIRCUIT MAINTENANCE
2464	02-12-2025	Part of : A-BLOCK SHIV VIHAR JJ COLONY	173	Other Outage	Planned Outage	02-12-2025	11:22	02-12-2025	13:36	2:14	0.000000	LT CIRCUIT MAINTENANCE
2465	03-12-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE	185	Other Outage	Planned Outage	03-12-2025	14:30	03-12-2025	16:36	2:06	0.000000	REPLACEMENT OF LT BUSHING ROD
2466	03-12-2025	Part of : BLOCK N 3 MOHAN GARDEN RAZAPUR KHURD	1056	Other Outage	Planned Outage	03-12-2025	11:43	03-12-2025	14:36	2:53	0.000000	REPLACEMENT OF LT BUSHING ROD
2467	03-12-2025	Part of : BLOCK AG 1 VIKAS PURI	277	Other Outage	Planned Outage	03-12-2025	10:23	03-12-2025	12:41	2:18	0.000000	REPLACEMENT OF LT BUSHING ROD
2468	04-12-2025	Part of : SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE	3061	Other Outage	Planned Outage	04-12-2025	12:21	04-12-2025	14:37	2:16	0.000000	REPLACEMENT OF LT BUSHING ROD
2469	05-12-2025	Part of : C BLOCK VIKAS PURI,BLOCK A SHANKER GARDEN VIKAS PURI,BLOCK M VIKAS PURI	1804	Other Outage	Unplanned Outage	05-12-2025	13:46	05-12-2025	14:30	0:44	0.000159	HT SYSTEM FAULT
2470	05-12-2025	Part of : A&B BLOCK VIKAS VIHAR AND SAI ENCLAVCE	1524	Other Outage	Planned Outage	05-12-2025	10:55	05-12-2025	13:45	2:50	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2471	05-12-2025	Part of : PHASE 3 OM VIHAR HASTSAL	1284	Other Outage	Planned Outage	05-12-2025	10:51	05-12-2025	13:41	2:50	0.000000	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2472	05-12-2025	Part of : PHASE 1 VIKAS PURI	143	Other Outage	Planned Outage	05-12-2025	10:32	05-12-2025	12:54	2:22	0.000000	REPLACEMENT OF LT BUSHING ROD
2473	06-12-2025	Part of : DEEPAK VIHAR EXTN., L & L1A BLOCK-MOHAN GARDEN	2747	Other Outage	Unplanned Outage	06-12-2025	12:28	06-12-2025	13:16	0:48	0.000960	CABLE FAULT
2474	06-12-2025	Part of : SHIV VIHAR HASTSAL	1581	Other Outage	Planned Outage	06-12-2025	11:53	06-12-2025	14:57	3:04	0.000000	REPLACEMENT OF HT BUSHING ROD
2475	06-12-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE	16	Other Outage	Planned Outage	06-12-2025	11:37	06-12-2025	13:51	2:14	0.000000	LT CIRCUIT MAINTENANCE WORK
2476	06-12-2025	Part of : JG 3-BLOCK VIKAS PURI	857	Other Outage	Planned Outage	06-12-2025	10:05	06-12-2025	13:04	2:59	0.000000	LT CIRCUIT MAINTENANCE WORK
2477	08-12-2025	Part of : JJ COLONY UTTAM NAGAR,BLOCK C JJ COLONY UTTAM NAGAR,BLOCK A 1 UTTAM NAGAR,BLOCK B JJ COLONY UTTAM NAGAR	3832	Other Outage	Unplanned Outage	08-12-2025	13:43	08-12-2025	14:26	0:43	0.000741	CABLE FAULT
2478	08-12-2025	Part of : SAINIK ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,SURKAKHA ENCLAVE AND M-BLOCK COMMANDER CHOWK,PRESS ENCLAVE,	1540	Other Outage	Planned Outage	08-12-2025	11:53	08-12-2025	15:08	3:15	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2479	08-12-2025	Part of : BLOCK JG 2 VIKAS PURI,	460	Other Outage	Planned Outage	08-12-2025	10:25	08-12-2025	12:40	2:15	0.000000	REPLACEMENT OF LT BUSHING ROD
2480	08-12-2025	Part of : DDA LG FLATS HASTSAL,	328	Other Outage	Planned Outage	08-12-2025	10:27	08-12-2025	12:37	2:10	0.000000	REPLACEMENT OF HT BUSHING ROD
2481	09-12-2025	Part of : A,B&C-BLOCK MAHARANI ENCLAVE	1968	Other Outage	Planned Outage	09-12-2025	11:22	09-12-2025	13:53	2:31	0.000000	REPLACEMENT OF HT BUSHING ROD
2482	09-12-2025	Part of : PHASE 3 OM VIHAR HASTSAL,PHASE 5 OM VIHAR HASTSAL	1273	Other Outage	Planned Outage	09-12-2025	10:27	09-12-2025	12:35	2:08	0.000000	REPLACEMENT OF HT BUSHING ROD
2483	10-12-2025	Part of : C-BLOCK JJ COLONY UTTAM NAGAR	2002	Other Outage	Planned Outage	10-12-2025	11:22	10-12-2025	13:40	2:18	0.000000	REPLACEMENT OF HT BUSHING ROD
2484	10-12-2025	Part of : SHIV VIHAR HASTSAL	957	Other Outage	Planned Outage	10-12-2025	11:37	10-12-2025	13:50	2:13	0.000000	REPLACEMENT OF HT BUSHING ROD
2485	10-12-2025	Part of : AK MARKET VIKAS PURI	1648	Other Outage	Planned Outage	10-12-2025	10:21	10-12-2025	12:41	2:20	0.000000	REPLACEMENT OF HT BUSHING ROD
2486	11-12-2025	Part of : YADAV ENCLAVE AND VIKAS VIHAR,SAI ENCLAVE,SURKAKHA ENCLAVE AND M- BLOCK COMMANDER CHOWK	1524	Other Outage	Planned Outage	11-12-2025	11:20	11-12-2025	13:41	2:21	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2487	12-12-2025	Part of : HOSTAL VIHAR OM VIHAR HASTSAL,PHASE 2 OM VIHAR HASTSAL,	664	Other Outage	Planned Outage	12-12-2025	11:15	12-12-2025	13:46	2:31	0.000000	REPLACEMENT OF HT BUSHING ROD
2488	12-12-2025	Part of : AK MARKET VIKAS PURI,	164	Other Outage	Planned Outage	12-12-2025	10:16	12-12-2025	12:27	2:11	0.000000	REPLACEMENT OF LT BUSHING ROD
2489	12-12-2025	Part of : AB&C-BLOCK L-2 MOHAN GARDEN,RAJAN VIHAR AND D-BLOCK VIJAY NAGAR	2051	Other Outage	Planned Outage	12-12-2025	11:19	12-12-2025	13:49	2:30	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2490	13-12-2025	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMANDER CHOWK,VIKAS NAGAR EXTN.,M-BLOCK VIKAS VIHAR COMMANDER CHOWK	1820	Other Outage	Planned Outage	13-12-2025	10:40	13-12-2025	13:49	3:09	0.000000	DT REPLACEMENT PER DT
2491	13-12-2025	Part of : PHASE 1 OM VIHAR NAWADA,PHASE 3 OM VIHAR HASTSAL,PHASE 4 OM VIHAR HASTSAL,PHASE 2 OM VIHAR HASTSAL,HOSTAL VIHAR	1301	Other Outage	Planned Outage	13-12-2025	10:49	13-12-2025	13:46	2:57	0.000000	REPLACEMENT OF HT BUSHING ROD
2492	13-12-2025	Part of : BLOCK M VIKAS PURI	103	Other Outage	Planned Outage	13-12-2025	10:38	13-12-2025	14:08	3:30	0.000000	REPLACEMENT OF LT BUSHING ROD
2493	13-12-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL	16	Other Outage	Planned Outage	13-12-2025	10:50	13-12-2025	12:55	2:05	0.000000	3PH DB REVAMPING
2494	15-12-2025	Part of : DEEPAK VIHAR EXTN.	866	Other Outage	Planned Outage	15-12-2025	10:54	15-12-2025	13:57	3:03	0.000000	REPLACEMENT OF HT BUSHING ROD
2495	15-12-2025	Part of : BLOCK M VIKAS PURI	417	Other Outage	Planned Outage	15-12-2025	10:20	15-12-2025	13:02	2:42	0.000000	REPLACEMENT OF LT BUSHING ROD
2496	16-12-2025	Part of : SHIV VIHAR WEST,	996	Other Outage	Planned Outage	16-12-2025	11:05	16-12-2025	13:24	2:19	0.000000	MAINTENANCE OF TRANSFORMER
2497	17-12-2025	Part of : AK MARKET VIKAS PURI	276	Other Outage	Planned Outage	17-12-2025	12:45	17-12-2025	16:15	3:30	0.000000	REPLACEMENT OF FAULTY END BOX
2498	17-12-2025	Part of : BLOCK G VIKAS PURI	380	Other Outage	Planned Outage	17-12-2025	13:24	17-12-2025	16:16	2:52	0.000000	REPLACEMENT OF LT BUSHING ROD
2499	17-12-2025	Part of : K5 & K6 AND DEFENCE ENCLAVE PART-1 MOHAN GARDEN,K-5 EXTN. AND DEEPAK VIHAR,PRESS ENCLAVE,BLOCK N 3 MOHAN GARDEN RAZAPUR KHURD	1056	Other Outage	Planned Outage	17-12-2025	10:54	17-12-2025	13:22	2:28	0.000000	HT AB CABLE REPLACEMENT PER SPAN
2500	17-12-2025	Part of : BLOCK A 2 UTTAM NAGAR,KRISHNA COLONY HASTSAL VILLAGE HASTSAL,PHASE 2 OM VIHAR HASTSAL	1457	Other Outage	Planned Outage	17-12-2025	11:06	17-12-2025	13:28	2:22	0.000000	REPLACEMENT OF HT BUSHING ROD
2501	18-12-2025	Part of : SAINIK ENCLAVE,PANCHSHEEL ENCLAVE,VIKRANT VIHAR,A&B BLOCK VIKAS VIHAR,SAI ENCLAVE	3061	Other Outage	Planned Outage	18-12-2025	10:28	18-12-2025	12:43	2:15	0.000000	3PH HT AB CABLE REPLACEMENT
2502	19-12-2025	Part of : LIG MIG FLATS POCKET B HASTSAL	1105	Other Outage	Planned Outage	19-12-2025	11:27	19-12-2025	14:02	2:35	0.000000	REPLACEMENT OF LT BUSHING ROD
2503	19-12-2025	Part of : BLOCK GG1 VIKAS PURI	466	Other Outage	Planned Outage	19-12-2025	12:00	19-12-2025	15:17	3:17	0.000000	REPLACEMENT OF LT BUSHING ROD
2504	19-12-2025	Part of : A&B BLOCK VIKAS VIHAR AND SAI ENCLAVE	1421	Other Outage	Planned Outage	19-12-2025	11:29	19-12-2025	14:01	2:32	0.000000	REPLACEMENT OF HT BUSHING ROD
2505	20-12-2025	Part of : PHASE 3 OM VIHAR HASTSAL,PHASE 5 OM VIHAR HASTSAL,	1273	Other Outage	Planned Outage	20-12-2025	11:02	20-12-2025	13:41	2:39	0.000000	MAINTENANCE OF TRANSFORMER
2506	20-12-2025	Part of : A,B&C-BLOCK MAHARANI ENCLAVE,	1405	Other Outage	Planned Outage	20-12-2025	11:02	20-12-2025	13:57	2:55	0.000000	MAINTENANCE OF TRANSFORMER

Sr. No.	Date	Area Affected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2507	20-12-2025	Part of : PHASE 1 OM VIHAR NAWADA,PHASE 3 OM VIHAR HASTSAL,PHASE 5 OM VIHAR HASTSAL	2521	Other Outage	Planned Outage	20-12-2025	11:02	20-12-2025	13:30	2:28	0.000000	MAINTENANCE OF RMU
2508	22-12-2025	Part of : HOSTAL VIHAR,OM VIHAR PHASE 2 HASTSAL	664	Other Outage	Planned Outage	22-12-2025	11:12	22-12-2025	13:40	2:28	0.000000	3PH HT AB CABLE REPLACEMENT
2509	22-12-2025	Part of : AB&C-BLOCK MOHAN GARDEN,RAJAN VIHA,D-BLOCK VIJAY NAGAR,A&B-BLOCK SHAKTI VIHAR	2054	Other Outage	Planned Outage	22-12-2025	12:12	22-12-2025	14:49	2:37	0.000000	3PH HT AB CABLE REPLACEMENT
2510	22-12-2025	Part of : KG 2-BLOCK VIKAS PURI	196	Other Outage	Planned Outage	22-12-2025	12:09	22-12-2025	14:58	2:49	0.000000	LT CIRCUIT MAINTENANCE WORK
2511	23-12-2025	Part of : SURKAKHA ENCLAVE,VIKAS NAGAR EXTN.,M-BLOCK VIKAS VIHAR COMMANDER CHOWK,SAINIK ENCLAVE	1822	Other Outage	Planned Outage	23-12-2025	11:21	23-12-2025	13:50	2:29	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2512	23-12-2025	Part of : PHASE 1 OM VIHAR NAWADA,PHASE 3 OM VIHAR HASTSAL,HASTAL VIHAR OM VIHAR	1301	Other Outage	Planned Outage	23-12-2025	11:26	23-12-2025	13:48	2:22	0.000000	REPLACEMENT OF LT BUSHING ROD
2513	24-12-2025	Part of : BLOCK E PROMISE APARTMENT VIKAS PURI,	86	Other Outage	Planned Outage	24-12-2025	12:06	24-12-2025	14:45	2:39	0.000000	MAINTENANCE OF TRANSFORMER
2514	24-12-2025	Part of : K5 & K6 AND DEFENCE ENCLAVE PART-1 MOHAN GARDEN,K-5 EXTN. AND DEEPAK VIHAR,PRESS ENCLAVE	1057	Other Outage	Planned Outage	24-12-2025	11:24	24-12-2025	13:39	2:15	0.000000	MAINTENANCE OF HVDS
2515	26-12-2025	Part of : BLOCK A 2 UTTAM NAGAR,OM VIHAR PHASE 2,HOSTAL VIHAR OM VIHAR HASTSAL	2303	Other Outage	Planned Outage	26-12-2025	11:59	26-12-2025	15:15	3:16	0.000000	GUARD WIRES SAGGING
2516	26-12-2025	Part of : YADAV ENCLAVE AND VIKAS VIHAR,A&B BLOCK VIKAS VIHAR AND SAI ENCLAVCE,SURKAKHA ENCLAVE,SAINIK ENCLAVE,PANCHSHEEL ENCLAVE	1524	Other Outage	Planned Outage	26-12-2025	11:18	26-12-2025	13:31	2:13	0.000000	3PH HT AB CABLE REPLACEMENT
2517	26-12-2025	Part of : BLOCK FG1 VIKAS PURI	576	Other Outage	Planned Outage	26-12-2025	10:01	26-12-2025	12:35	2:34	0.000000	LT CIRCUIT MAINTENANCE
2518	27-12-2025	Part of : RAJ HANS VIHAR, SHIV VIHAR HASTSAL	1518	Other Outage	Unplanned Outage	27-12-2025	04:09	27-12-2025	04:18	0:09	0.000000	HVDS FAULT
2519	27-12-2025	Part of : BLOCK A 3 UTTAM NAGAR	978	Other Outage	Unplanned Outage	27-12-2025	14:59	27-12-2025	16:06	1:07	0.000000	ATTEND WEAK POINT/HOT SPOT
2520	27-12-2025	Part of : BLOCK H KESHOPUR INDUSTRIAL AREA VIKAS PURI	51	Other Outage	Planned Outage	27-12-2025	10:30	27-12-2025	12:59	2:29	0.000000	REPLACEMENT OF LT BUSHING ROD
2521	27-12-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE	16	Other Outage	Planned Outage	27-12-2025	10:42	27-12-2025	12:58	2:16	0.000000	3PH DB REVAMPING
2522	27-12-2025	Part of : LIONS ENCLAVE	675	Other Outage	Planned Outage	27-12-2025	10:37	27-12-2025	12:57	2:20	0.000000	REPLACEMENT OF LT BUSHING ROD
2523	29-12-2025	Part of : PHASE 1 OM VIHAR NAWADA,PHASE 3 OM VIHAR HASTSAL,PHASE 4 OM VIHAR HASTSAL,PHASE 2 OM VIHAR HASTSAL,HOSTAL VIHAR OM VIHAR HASTSAL	1301	Other Outage	Planned Outage	29-12-2025	11:02	29-12-2025	13:52	2:50	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2524	29-12-2025	Part of : SAINIK ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,SURKAKHA ENCLAVE AND M-BLOCK COMMONDER CHOWK,PRESS ENCLAVE	1540	Other Outage	Planned Outage	29-12-2025	10:30	29-12-2025	12:42	2:12	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2525	29-12-2025	Part of : BLOCK A 3 UTTAM NAGAR	1063	Other Outage	Planned Outage	29-12-2025	11:04	29-12-2025	13:49	2:45	0.000000	CONDUCTOR REPLACEMENT PER SPAN
2526	30-12-2025	Part of : AB&C-BLOCK MOHAN GARDEN,RAJAN VIHAR,D-BLOCK VIJAY NAGAR,A&B-BLOCK SHAKTI VIHAR	2054	Other Outage	Planned Outage	30-12-2025	11:26	30-12-2025	13:30	2:04	0.000000	3PH HT AB CABLE REPLACEMENT
2527	30-12-2025	Part of : C-BLOCK VIKAS PURI	325	Other Outage	Planned Outage	30-12-2025	10:26	30-12-2025	13:29	3:03	0.000000	HT CONDUCTOR REPLACEMENT
2528	30-12-2025	Part of : M-BLOCK VIKAS PURI	404	Other Outage	Planned Outage	30-12-2025	10:19	30-12-2025	13:14	2:55	0.000000	LT CIRCUIT MAINTENANCE WORK
2529	31-12-2025	Part of : VIKAS KUNJ AND VIKAS KUNJ EXTN., VIKAS PURI EXTN.	2273	Other Outage	Unplanned Outage	31-12-2025	00:07	31-12-2025	00:44	0:37	0.000041	CABLE FAULT
2530	31-12-2025	Part of : PHASE 3 OM VIHAR HASTSAL,PHASE 5 OM VIHAR HASTSAL	1290	Other Outage	Planned Outage	31-12-2025	11:11	31-12-2025	13:44	2:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN