

Name of Distribution Licensee: BSES Rajdhani Power Limited												
Period of Outage: FEBRUARY 2026												
Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1	01-02-2026	Part of : F-BLOCK OKHLA PHASE-1	325	Other Outage	Planned Outage	01-02-2026	10:59	01-02-2026	13:52	2:53	0.001201	REPLACEMET OF HT BUSHING ROD
2	02-02-2026	Part of : H-BLOCK CR PARK,	388	Other Outage	Planned Outage	02-02-2026	11:22	02-02-2026	13:57	2:35	0.000646	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
3	02-02-2026	Part of : A14-BLOCK KALKA JI EXTN_G BLOCK KALKAJI,	432	Other Outage	Planned Outage	02-02-2026	11:07	02-02-2026	14:05	2:58	0.000000	REPLACEMENT OF LT BUSHING ROD
4	03-02-2026	Part of : GANGOTRI ENCLAVE	236	Other Outage	Unplanned Outage	03-02-2026	14:27	03-02-2026	16:13	1:46	0.001531	REPAIRING OF RMU
5	03-02-2026	Part of : A14 & G-BLOCK KALKA JI	347	Other Outage	Planned Outage	03-02-2026	11:02	03-02-2026	14:06	3:04	0.000000	REPLACEMENT OF HT BUSHING ROD
6	04-02-2026	Part of : GOVINDPURI	915	Other Outage	Planned Outage	04-02-2026	11:10	04-02-2026	13:50	2:40	0.000000	LT CIRCUIT MAINTENANCE
7	04-02-2026	Part of : W-BLOCK GK-2	127	Other Outage	Planned Outage	04-02-2026	11:10	04-02-2026	13:51	2:41	0.000671	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD
8	04-02-2026	Part of : A14-BLOCK KALKA JI EXTN,DDA FLATS KALKAJI	108	Other Outage	Planned Outage	04-02-2026	11:09	04-02-2026	13:51	2:42	0.000000	REPLACEMET OF HT BUSHING ROD
9	06-02-2026	Part of : A14-BLOCK KALKA JI EXTN_DDA FLATS KALKAJI,	316	Other Outage	Planned Outage	06-02-2026	11:13	06-02-2026	13:52	2:39	0.000000	REPLACEMENT OF LT BUSHING ROD
10	06-02-2026	Part of : H-BLOCK CR PARK,	330	Other Outage	Planned Outage	06-02-2026	11:27	06-02-2026	13:50	2:23	0.000794	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
11	08-02-2026	Part of : C-BLOCK OKHLA PHASE-1,	27	Other Outage	Planned Outage	08-02-2026	11:01	08-02-2026	14:37	3:36	0.000600	DT REPLACEMENT
12	08-02-2026	Part of : D-BLOCK OKHLA PHASE-1	379	Other Outage	Planned Outage	08-02-2026	11:01	08-02-2026	13:56	2:55	0.001458	REPLACEMENT OF HT BUSHING ROD
13	09-02-2026	Part of : J2-BLOCK DDA FLAT KALKA JI, ALAKNANDA SHOPPING COMPLEX, BLOCK J3 GOVINDPURI KALKAJI	4617	Other Outage	Unplanned Outage	09-02-2026	11:55	09-02-2026	12:39	0:44	0.000521	CABLE FAULT
14	09-02-2026	Part of : GOVINDPURI	905	Other Outage	Planned Outage	09-02-2026	11:05	09-02-2026	13:28	2:23	0.003575	END TERMINATION COVER REPLACEMENT,REPLACEMENT OF FAULTY END BOX
15	09-02-2026	Part of : TUGHLAKABAD EXTN	720	Other Outage	Planned Outage	09-02-2026	11:01	09-02-2026	13:04	2:03	0.000000	3PH DB REPLACEMENT,CONDUCTOR REPLACEMENT PER SPAN
16	09-02-2026	Part of : E-BLOCK MASJID MOTH	238	Other Outage	Planned Outage	09-02-2026	11:49	09-02-2026	13:50	2:01	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
17	10-02-2026	Part of : TUGHLAKABAD EXTN	5384	Other Outage	Unplanned Outage	10-02-2026	22:52	10-02-2026	23:46	0:54	0.000788	CABLE FAULT
18	10-02-2026	Part of : GANGOTRI ENCLAVE,	199	Other Outage	Unplanned Outage	10-02-2026	11:13	10-02-2026	13:26	2:13	0.001182	MAINTENANCE/REPAIR OF RMU
19	11-02-2026	Part of : GOVINDPURI	1765	Other Outage	Planned Outage	11-02-2026	13:58	11-02-2026	15:52	1:54	0.003483	INSTALLATION OF HT BOOTS,REPLACEMENT OF HT BUSHING ROD
20	11-02-2026	Part of : GOVINDPURI	703	Other Outage	Planned Outage	11-02-2026	11:35	11-02-2026	13:57	2:22	0.004339	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF LT BUSHING ROD
21	11-02-2026	Part of : BLOCK A CHITTARANJAN PARK	191	Other Outage	Planned Outage	11-02-2026	11:35	11-02-2026	13:55	2:20	0.000000	LT CIRCUIT MAINTENANCE
22	12-02-2026	Part of : NEHRU ENCLAVE KALKA JI	255	Other Outage	Unplanned Outage	12-02-2026	10:56	12-02-2026	11:39	0:43	0.000000	MAKING OF END TERMINATION/ END TERMINATION DAMAGE
23	12-02-2026	Part of : NEHRU ENCLAVE KALKA JI	318	Other Outage	Planned Outage	12-02-2026	11:35	12-02-2026	13:49	2:14	0.002978	REPLACEMENT OF FAULTY END BOX
24	13-02-2026	Part of : S-BLOCK GK-2	259	Other Outage	Planned Outage	13-02-2026	11:19	13-02-2026	13:45	2:26	0.000000	CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE
25	14-02-2026	Part of : TILAK KHAND GIRI NAGAR,	483	Other Outage	Planned Outage	14-02-2026	12:08	14-02-2026	13:51	1:43	0.002289	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
26	15-02-2026	Part of : F-BLOCK OKHLA PHASE-1	829	Other Outage	Planned Outage	15-02-2026	10:57	15-02-2026	14:01	3:04	0.000767	REPLACEMENT OF CROSS-ARMS AND POLES
27	16-02-2026	Part of : S-BLOCK GK-2	225	Other Outage	Planned Outage	16-02-2026	11:53	16-02-2026	13:52	1:59	0.000000	LT CIRCUIT MAINTENANCE
28	17-02-2026	Part of : TUGHLAKABAD EXTN	5390	Other Outage	Unplanned Outage	17-02-2026	07:43	17-02-2026	08:33	0:50	0.001183	HT SYSTEM FAULT
29	17-02-2026	Part of : TUGHLAKABAD EXTN	1321	Other Outage	Planned Outage	17-02-2026	11:01	17-02-2026	12:59	1:58	0.000000	3PH DB REVAMPING
30	17-02-2026	Part of : J-BLOCK KALKA JI	388	Other Outage	Planned Outage	17-02-2026	14:33	17-02-2026	16:50	2:17	0.003044	3PH DB REPLACEMENT
31	17-02-2026	Part of : J-BLOCK KALKA JI	798	Other Outage	Planned Outage	17-02-2026	11:01	17-02-2026	13:55	2:54	0.003867	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
32	18-02-2026	Part of : E-BLOCK MASJID MOTH,	319	Other Outage	Planned Outage	18-02-2026	11:16	18-02-2026	13:50	2:34	0.000000	3PH DB REPLACEMENT,CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
33	19-02-2026	Part of : Part of : LSC-59 KALKAJI	285	Other Outage	Planned Outage	19-02-2026	13:26	19-02-2026	14:19	0:53	0.001472	CT REPLACEMENT,END TERMINATION COVER REPLACEMENT,REPLACEMENT OF FAULTY END BOX
34	20-02-2026	Part of : M-BLOCK GK-2	224	Other Outage	Planned Outage	20-02-2026	11:26	20-02-2026	13:45	2:19	0.000579	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD
35	21-02-2026	Part of : F-BLOCK OKHLA PHASE-1	832	Other Outage	Unplanned Outage	21-02-2026	14:01	21-02-2026	15:05	1:04	0.000000	ATTEND WEAK POINT/HOT SPOT
36	22-02-2026	Part of : HINDUSTAN STEEL YARD,D-BLOCK OKHLA PHASE-1,B-BLOCK OKHLA PHASE-1,TEHKHAND TELEPHONE EXCHANGE	573	Other Outage	Unplanned Outage	22-02-2026	00:54	22-02-2026	01:38	0:44	0.000403	CABLE FAULT
37	22-02-2026	Part of : DDA SHED OKHLA PHASE-1,	108	Other Outage	Planned Outage	22-02-2026	10:57	22-02-2026	13:54	2:57	0.000492	REPLACEMENT OF HT BUSHING ROD
38	22-02-2026	Part of : B-BLOCK OKHLA PHASE-1,	152	Other Outage	Planned Outage	22-02-2026	10:57	22-02-2026	13:54	2:57	0.001229	REPLACEMENT OF HT BUSHING ROD
39	23-02-2026	Part of : BLOCK A CHITTARANJAN PARK	148	Other Outage	Planned Outage	23-02-2026	12:28	23-02-2026	13:50	1:22	0.000000	LT CIRCUIT MAINTENANCE
40	24-02-2026	Part of : E-BLOCK MASJID MOTH,W-BLOCK GK-2	1392	Other Outage	Unplanned Outage	24-02-2026	16:47	24-02-2026	17:26	0:39	0.000553	CABLE FAULT
41	24-02-2026	Part of : TILAK KHAND GIRI NAGAR	303	Other Outage	Planned Outage	24-02-2026	11:33	24-02-2026	12:11	0:38	0.000844	REPLACEMENT OF FAULTY END BOX
42	25-02-2026	Part of : L-BLOCK KALKA JI	622	Other Outage	Planned Outage	25-02-2026	14:05	25-02-2026	16:39	2:34	0.003850	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS
43	25-02-2026	Part of : L-BLOCK KALKA JI	226	Other Outage	Planned Outage	25-02-2026	11:08	25-02-2026	13:50	2:42	0.004050	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF HT BUSHING ROD
44	25-02-2026	Part of : E-BLOCK MASJID MOTH	227	Other Outage	Planned Outage	25-02-2026	11:09	25-02-2026	13:49	2:40	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
45	26-02-2026	Part of : GANGA APARTMENT,	199	Other Outage	Planned Outage	26-02-2026	11:14	26-02-2026	13:53	2:39	0.000000	REPLACEMENT OF HT BUSHING ROD
46	27-02-2026	Part of : TUGHLAKABAD	5	Other Outage	Planned Outage	27-02-2026	10:05	27-02-2026	12:11	2:06	0.000070	REPLACEMENT OF CROSS-ARMS AND POLES
47	27-02-2026	Part of : S-BLOCK GK-2	204	Other Outage	Planned Outage	27-02-2026	11:37	27-02-2026	13:47	2:10	0.000000	LT CIRCUIT MAINTENANCE
48	28-02-2026	Part of : TUGHLAKABAD EXTN	1117	Other Outage	Planned Outage	28-02-2026	14:50	28-02-2026	16:25	1:35	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
49	02-02-2026	Part of : SULTANPUR,JAUNAPUR VILLAGE JAUNAPUR,RADHEY MOHAN DRIVE,DLF FARMS,GADAIPUR JAUNAPUR,	70	Other Outage	Planned Outage	02-02-2026	11:17	02-02-2026	12:30	1:13	0.000284	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
50	02-02-2026	Part of : DR AMBEDKAR COLONY CHHATARPUR,	116	Other Outage	Planned Outage	02-02-2026	10:48	02-02-2026	14:41	3:53	0.000000	REPLACEMENT OF HT BUSHING ROD
51	03-02-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,ANSAL VILLAS SAT BARI	2168	Other Outage	Planned Outage	03-02-2026	11:39	03-02-2026	14:56	3:17	0.000000	3PH HT AB END TERMINATION REPLACEMENT
52	03-02-2026	Part of : BLOCK C CHHATARPUR EXTENSION,CHHATARPUR DLF FARMS	50	Other Outage	Planned Outage	03-02-2026	12:19	03-02-2026	14:55	2:36	0.000000	REPLACEMENT OF HT BUSHING ROD
53	03-02-2026	Part of : WESTEND DLF CHATTARPUR FARMS,JAUNAPUR VILLAGE,BHIM BASTI,AMBEDKAR COLONY MANDI,MANDI VILLAGE,SULTANPUR	4030	Other Outage	Planned Outage	03-02-2026	10:47	03-02-2026	14:59	4:12	0.000980	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
54	04-02-2026	Part of : ASOLA	57	Other Outage	Unplanned Outage	04-02-2026	16:47	04-02-2026	17:34	0:47	0.000000	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
55	04-02-2026	Part of : A 1-BLOCK CHHATARPUR VILLAGE	812	Other Outage	Planned Outage	04-02-2026	10:35	04-02-2026	14:08	3:33	0.000000	REPLACEMENT OF HT BUSHING ROD
56	05-02-2026	Part of : ASOLA	436	Other Outage	Unplanned Outage	05-02-2026	14:59	05-02-2026	16:29	1:30	0.000000	SHIFTING OF CABLE
57	05-02-2026	Part of : RADHEY MOHAN DRIVE	1	Other Outage	Planned Outage	05-02-2026	14:16	05-02-2026	16:44	2:28	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF BUS BAR
58	05-02-2026	Part of : DLF FARMS,SULTANPUR,CHHATARPUR	160	Other Outage	Planned Outage	05-02-2026	11:11	05-02-2026	15:22	4:11	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
59	05-02-2026	Part of : SULTANPUR,JAUNAPUR VILLAGE,RADHEY MOHAN DRIVE,DLF FARMS	70	Other Outage	Planned Outage	05-02-2026	10:41	05-02-2026	15:40	4:59	0.001163	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
60	06-02-2026	Part of : POCKET B DR AMBEDKAR COLONY CHHATARPUR,DR AMBEDKAR COLONY CHHATARPUR,POCKET A DR AMBEDKAR COLONY CHHATARPUR,	147	Other Outage	Planned Outage	06-02-2026	10:59	06-02-2026	14:08	3:09	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
61	06-02-2026	Part of : GADPUR FARM DLF FARMS,GADAIPUR DLF FARMS,GADAIPUR JAUNAPUR,SULTANPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,	1483	Other Outage	Planned Outage	06-02-2026	10:50	06-02-2026	14:10	3:20	0.000778	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,TIGHTENING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
62	07-02-2026	Part of : MAIDAN GARHI VILLAGE,ANSAL VILLAS SAT BARI,ASOLA WILD LIFE SANCTUARY,RAJPUR KHURD EXTENSION,CHHATARPUR DLF FARMS,BLOCK C CHHATARPUR EXTENSION	322	Other Outage	Planned Outage	07-02-2026	12:23	07-02-2026	13:13	0:50	0.000000	INSTALLATION OF BUS BAR
63	07-02-2026	Part of : SULTANPUR	252	Other Outage	Planned Outage	07-02-2026	11:46	07-02-2026	12:39	0:53	0.000206	1PH DB REVAMPING,3PH DB REPLACEMENT,LT AB SAGGING
64	07-02-2026	Part of : RAJPUR KHURD VILLAGE,CHHATARPURPHASE-1 & 2,CHHATARPUR ENCLAVE,MITTAL GARDEN SAINIK FARM	4129	Other Outage	Planned Outage	07-02-2026	11:29	07-02-2026	14:01	2:32	0.000000	3PH HT AB END TERMINATION REPLACEMENT
65	07-02-2026	Part of : BLOCK G AYA NAGAR EXTENSION	586	Other Outage	Planned Outage	07-02-2026	12:13	07-02-2026	15:56	3:43	0.000000	LT CIRCUIT MAINTENANCE
66	09-02-2026	Part of : SAT BARI	244	Other Outage	Planned Outage	09-02-2026	11:02	09-02-2026	12:08	1:06	0.000000	CHECKING OF EARTHING VALUE USING ONLINE TESTER
67	09-02-2026	Part of : CHHATARPUR	766	Other Outage	Planned Outage	09-02-2026	11:58	09-02-2026	16:04	4:06	0.000957	REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
68	09-02-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE,GHITORNI VILLAGE	3227	Other Outage	Planned Outage	09-02-2026	10:39	09-02-2026	13:58	3:19	0.000553	REPLACEMENT OF HT BUSHING ROD
69	09-02-2026	Part of : SULTANPUR	164	Other Outage	Planned Outage	09-02-2026	11:11	09-02-2026	14:55	3:44	0.000871	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT/LT CLEATS
70	09-02-2026	Part of : MANGLAPURI VILLAGE SULTANPUR	526	Other Outage	Planned Outage	09-02-2026	12:01	09-02-2026	15:46	3:45	0.000000	JUMPER REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER
71	09-02-2026	Part of : PHASE-V AYA NAGAR EXTENSION	955	Other Outage	Planned Outage	09-02-2026	11:12	09-02-2026	14:54	3:42	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS
72	10-02-2026	Part of : PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR,	997	Other Outage	Planned Outage	10-02-2026	10:52	10-02-2026	12:28	1:36	0.000267	REPLACEMET OF HT BUSHING ROD
73	10-02-2026	Part of : RADHEY MOHAN DRIVE,JAUNAPUR VILLAGE JAUNAPUR,DLF FARMS,FATEHPUR BERI,CHANDAN HOLA,ANSAL VILLAS SAT BARI,BLOCK C CHHATARPUR EXTENSION CHHATARPUR,	813	Other Outage	Planned Outage	10-02-2026	10:39	10-02-2026	13:29	2:50	0.000000	CLEANING OF INSULATORS PER POLE
74	10-02-2026	Part of : NEW GAWALPAHARI VILLAGE,DERA VILLAGE,GAWALPAHARI VILLAGE,	251	Other Outage	Planned Outage	10-02-2026	10:57	10-02-2026	13:36	2:39	0.001060	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
75	10-02-2026	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR,	955	Other Outage	Planned Outage	10-02-2026	10:44	10-02-2026	16:08	5:24	0.000000	JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
76	11-02-2026	Part of : ASOLA,ASOLA WILD LIFE SANCTUARY ASOLA	1663	Other Outage	Unplanned Outage	11-02-2026	09:07	11-02-2026	09:24	0:17	0.000367	BIRDAGE
77	11-02-2026	Part of : CHHATARPUR ENCLAVE	604	Other Outage	Planned Outage	11-02-2026	12:49	11-02-2026	13:27	0:38	0.000000	REPLACEMENT OF HT BUSHING ROD
78	11-02-2026	Part of : AYA NAGAR EXTENSION PHASE-V	851	Other Outage	Planned Outage	11-02-2026	12:28	11-02-2026	14:07	1:39	0.000000	LT CIRCUIT MAINTENANCE
79	12-02-2026	Part of : AYA NAGAR VILLAGE	2289	Other Outage	Unplanned Outage	12-02-2026	11:46	12-02-2026	12:18	0:32	0.000560	HT SYSTEM FAULT
80	12-02-2026	Part of : JAUNAPUR VILLAGE,DERA VILLAGE,FATEHPUR BERI,NEW GAWALPAHARI VILLAGE,ASOLA	532	Other Outage	Planned Outage	12-02-2026	12:21	12-02-2026	13:53	1:32	0.000000	CHECKING OF EARTHING VALUE USING ONLINE TESTER
81	12-02-2026	Part of : SULTANPUR,JAUNAPUR VILLAGE,RADHEY MOHAN DRIVE,DLF FARMS,GADAIPUR JAUNAPUR	70	Other Outage	Planned Outage	12-02-2026	10:57	12-02-2026	12:19	1:22	0.000683	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING ROD
82	12-02-2026	Part of : AYA NAGAR EXTENSION PHASE-V	851	Other Outage	Planned Outage	12-02-2026	13:56	12-02-2026	15:39	1:43	0.000000	LT CIRCUIT MAINTENANCE
83	12-02-2026	Part of : POCKET D DR AMBEDKAR COLONY CHHATARPUR	907	Other Outage	Planned Outage	12-02-2026	10:26	12-02-2026	13:59	3:33	0.000000	REPLACEMENT OF HT BUSHING ROD
84	13-02-2026	Part of : AYA NAGAR PHASE-I, ADARSH ENCLAVE AYA NAGAR EXTENSION, AYA NAGAR VILLAGE	3517	Other Outage	Unplanned Outage	13-02-2026	14:45	13-02-2026	15:23	0:38	0.000488	CABLE FAULT
85	13-02-2026	Part of : PHASE-V AYA NAGAR EXTENSION	851	Other Outage	Planned Outage	13-02-2026	13:18	13-02-2026	13:47	0:29	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
86	13-02-2026	Part of : MANDI VILLAGE	441	Other Outage	Planned Outage	13-02-2026	11:21	13-02-2026	12:09	0:48	0.000000	3PH DB REPLACEMENT,LT AB SAGGING PER SPAN
87	14-02-2026	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR,	1276	Other Outage	Planned Outage	14-02-2026	12:38	14-02-2026	12:48	0:10	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
88	14-02-2026	Part of : GADAIPUR JAUNAPUR,	45	Other Outage	Planned Outage	14-02-2026	11:56	14-02-2026	12:12	0:16	0.000000	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
89	14-02-2026	Part of : CHHATARPUR,	774	Other Outage	Planned Outage	14-02-2026	12:22	14-02-2026	13:16	0:54	0.000000	INSTALLATION OF PHASE SEPERATOR PER SPAN,LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
90	14-02-2026	Part of : MAIDAN GARHI VILLAGE CHHATARPUR,ANSAL VILLAS SAT BARI,ASOLA WILD LIFE SANCTUARY ASOLA,RAJPUR KHURD EXTENSION CHHATARPUR,DLF FARMS,BLOCK C CHHATARPUR EXTENSION CHHATARPUR,	322	Other Outage	Planned Outage	14-02-2026	13:15	14-02-2026	15:20	2:05	0.000000	REPLACEMET OF HT/LT CLEATS
91	14-02-2026	Part of : PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR,	1006	Other Outage	Planned Outage	14-02-2026	10:39	14-02-2026	13:27	2:48	0.000467	REPLACEMET OF HT BUSHING ROD
92	15-02-2026	Part of : ASOLA,ANSAL VILLAS SAT BARI,SAT BARI	828	Other Outage	Unplanned Outage	15-02-2026	09:13	15-02-2026	09:25	0:12	0.000340	BIRDAGE
93	15-02-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	715	Other Outage	Unplanned Outage	15-02-2026	16:19	15-02-2026	16:57	0:38	0.000876	HT SYSTEM FAULT
94	16-02-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	630	Other Outage	Unplanned Outage	16-02-2026	11:30	16-02-2026	12:40	1:10	0.001089	CABLE FAULT
95	16-02-2026	Part of : SULTANPUR,JAUNAPUR VILLAGE,RADHEY MOHAN DRIVE,DLF FARMS,GADAIPUR JAUNAPUR	71	Other Outage	Planned Outage	16-02-2026	13:36	16-02-2026	14:48	1:12	0.000200	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
96	16-02-2026	Part of : AYA NAGAR VILLAGE	3587	Other Outage	Planned Outage	16-02-2026	12:35	16-02-2026	14:36	2:01	0.000336	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
97	16-02-2026	Part of : FATEHPUR BERI	685	Other Outage	Planned Outage	16-02-2026	11:25	16-02-2026	12:49	1:24	0.000000	REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
98	16-02-2026	Part of : SULTANPUR	201	Other Outage	Planned Outage	16-02-2026	11:01	16-02-2026	13:27	2:26	0.000568	3PH DB REVAMPING,LT AB SAGGING
99	16-02-2026	Part of : A 1-BLOCK CHHATARPUR VILLAGE,GHITORNI VILLAGE	3227	Other Outage	Planned Outage	16-02-2026	10:54	16-02-2026	13:49	2:55	0.000486	REPLACEMENT OF HT BUSHING ROD
100	16-02-2026	Part of : SAT BARI	247	Other Outage	Planned Outage	16-02-2026	11:27	16-02-2026	13:34	2:07	0.000000	REPLACEMENT OF LUGS,SUB STATION CLEANING
101	16-02-2026	Part of : ANSAL VILLAS SAT BARI	36	Other Outage	Planned Outage	16-02-2026	11:26	16-02-2026	13:35	2:09	0.000000	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
102	16-02-2026	Part of : AYA NAGAR EXTENSION PHASE-V	1276	Other Outage	Planned Outage	16-02-2026	12:06	16-02-2026	14:10	2:04	0.000000	LT CIRCUIT MAINTENANCE
103	17-02-2026	Part of : BHATI KALAN, DERA VILLAGE, FATEHPUR BERI	2972	Other Outage	Unplanned Outage	17-02-2026	17:36	17-02-2026	17:57	0:21	0.000435	BIRDAGE
104	17-02-2026	Part of : FATEHPUR BERI	826	Other Outage	Unplanned Outage	17-02-2026	09:00	17-02-2026	09:03	0:03	0.000038	BIRDAGE
105	17-02-2026	Part of : DERA VILLAGE,JAUNAPUR VILLAGE,FATEHPUR BERI	543	Other Outage	Planned Outage	17-02-2026	12:04	17-02-2026	13:32	1:28	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMET PER SPAN
106	17-02-2026	Part of : PHASE-V AYA NAGAR EXTENSION	1276	Other Outage	Planned Outage	17-02-2026	10:59	17-02-2026	12:18	1:19	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS
107	17-02-2026	Part of : WESTEND DLF CHATTARPUR FARMS DLF FARMS,BHIM BASTI JUANAPUR,AMBEDKAR COLONY MANDI	4030	Other Outage	Planned Outage	17-02-2026	10:58	17-02-2026	12:30	1:32	0.000613	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
108	17-02-2026	Part of : MANDI VILLAGE	281	Other Outage	Planned Outage	17-02-2026	13:15	17-02-2026	15:20	2:05	0.000486	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
109	17-02-2026	Part of : CHHATARPUR	25	Other Outage	Planned Outage	17-02-2026	10:44	17-02-2026	13:37	2:53	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
110	18-02-2026	Part of : ASOLA	436	Other Outage	Unplanned Outage	18-02-2026	10:09	18-02-2026	10:32	0:23	0.000229	HT SYSTEM FAULT
111	18-02-2026	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR,	183	Other Outage	Planned Outage	18-02-2026	13:03	18-02-2026	15:10	2:07	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING
112	18-02-2026	Part of : SULTANPUR,	2562	Other Outage	Planned Outage	18-02-2026	13:05	18-02-2026	15:11	2:06	0.000490	3PH DB REPLACEMENT,LT AB SAGGING PER SPAN
113	18-02-2026	Part of : CHHATARPUR,	96	Other Outage	Planned Outage	18-02-2026	11:22	18-02-2026	14:04	2:42	0.000000	REPLACEMENT OF LT BUSHING ROD
114	19-02-2026	Part of : AYA NAGAR VILLAGE AYA NAGAR	3598	Other Outage	Unplanned Outage	19-02-2026	13:45	19-02-2026	14:45	1:00	0.000333	REPAIRING OF RMU
115	19-02-2026	Part of : Part of : DR AMBEDKAR COLONY CHHATARPUR	493	Other Outage	Planned Outage	19-02-2026	15:59	19-02-2026	16:12	0:13	0.000000	REPLACEMENT OF HT BUSHING ROD
116	19-02-2026	Part of : Part of : SULTANPUR	356	Other Outage	Planned Outage	19-02-2026	14:42	19-02-2026	15:23	0:41	0.000000	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
117	19-02-2026	Part of : Part of : G-BLOCK AYA NAGAR EXTENSION	381	Other Outage	Planned Outage	19-02-2026	14:23	19-02-2026	15:26	1:03	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
118	19-02-2026	Part of : Part of : JAUNAPUR VILLAGE	567	Other Outage	Planned Outage	19-02-2026	12:02	19-02-2026	13:12	1:10	0.000000	LT CIRCUIT MAINTENANCE
119	20-02-2026	Part of : CHHATARPUR ENCLAVE	604	Other Outage	Planned Outage	20-02-2026	15:18	20-02-2026	16:08	0:50	0.000000	REPLACEMET OF HT BUSHING ROD
120	20-02-2026	Part of : BHIM BASTI JUANAPUR	816	Other Outage	Planned Outage	20-02-2026	11:05	20-02-2026	12:43	1:38	0.000000	LT CIRCUIT MAINTENANCE
121	20-02-2026	Part of : AYA NAGAR PHASE 1	319	Other Outage	Planned Outage	20-02-2026	11:26	20-02-2026	12:44	1:18	0.000000	LT CIRCUIT MAINTENANCE
122	20-02-2026	Part of : MITTAL GARDEN SAINIK FARM,DR AMBEDKAR COLONY CHHATARPUR	218	Other Outage	Planned Outage	20-02-2026	10:55	20-02-2026	15:19	4:24	0.000000	3PH HT AB CABLE REPLACEMENT
123	21-02-2026	Part of : ASOLA, NEAR DELHI JAL BOARD ASOLA BANDH	436	Other Outage	Unplanned Outage	21-02-2026	13:54	21-02-2026	14:35	0:41	0.000122	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
124	21-02-2026	Part of : SULTANPUR	356	Other Outage	Planned Outage	21-02-2026	10:50	21-02-2026	11:50	1:00	0.000000	JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
125	21-02-2026	Part of : DR AMBEDKAR COLONY CHHATARPUR	493	Other Outage	Planned Outage	21-02-2026	13:05	21-02-2026	15:35	2:30	0.000000	REPLACEMENT OF LT BUSHING ROD
126	21-02-2026	Part of : FATEHPUR BERI	378	Other Outage	Planned Outage	21-02-2026	10:21	21-02-2026	13:26	3:05	0.000000	CLEANING OF INSULATORS PER POLE
127	23-02-2026	Part of : CHANDANHULA	0	Other Outage	Unplanned Outage	23-02-2026	04:00	23-02-2026	04:10	0:10	0.000114	BIRDAGE
128	23-02-2026	Part of : MAIDAN GARHI VILLAGE,ANSAL VILLAS SAT BARI,ASOLA WILD LIFE SANCTUARY ASOLA,RAJPUR KHURD EXTENSION,DLF FARMS	327	Other Outage	Planned Outage	23-02-2026	14:25	23-02-2026	15:58	1:33	0.000000	REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
129	23-02-2026	Part of : SULTANPUR	974	Other Outage	Planned Outage	23-02-2026	14:55	23-02-2026	16:20	1:25	0.000331	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
130	23-02-2026	Part of : AYA NAGAR VILLAGE	182	Other Outage	Planned Outage	23-02-2026	13:27	23-02-2026	14:30	1:03	0.000000	LT CIRCUIT MAINTENANCE
131	23-02-2026	Part of : SULTANPUR	42	Other Outage	Planned Outage	23-02-2026	12:20	23-02-2026	14:32	2:12	0.000513	3PH DB REPLACEMENT
132	23-02-2026	Part of : SAT BARI	215	Other Outage	Planned Outage	23-02-2026	11:05	23-02-2026	13:44	2:39	0.000000	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
133	23-02-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE,GHITORNI VILLAGE	3227	Other Outage	Planned Outage	23-02-2026	10:46	23-02-2026	13:56	3:10	0.000528	REPLACEMET OF HT BUSHING ROD
134	23-02-2026	Part of : AMBEDKAR COLONY MANDI	82	Other Outage	Planned Outage	23-02-2026	13:14	23-02-2026	15:32	2:18	0.000000	LT CIRCUIT MAINTENANCE
135	24-02-2026	Part of : AYA NAGAR VILLAGE	1300	Other Outage	Planned Outage	24-02-2026	11:05	24-02-2026	12:09	1:04	0.000978	REPLACEMENT OF HT BUSHING INULATOR
136	24-02-2026	Part of : FATEHPUR BERI	850	Other Outage	Planned Outage	24-02-2026	14:46	24-02-2026	16:01	1:15	0.000000	LT CIRCUIT MAINTENANCE
137	24-02-2026	Part of : SULTANPUR	60	Other Outage	Planned Outage	24-02-2026	11:07	24-02-2026	12:09	1:02	0.000000	LT CIRCUIT MAINTENANCE
138	24-02-2026	Part of : AYA NAGAR VILLAGE	1274	Other Outage	Planned Outage	24-02-2026	12:07	24-02-2026	13:11	1:04	0.000000	LT CIRCUIT MAINTENANCE
139	24-02-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	630	Other Outage	Planned Outage	24-02-2026	10:57	24-02-2026	13:59	3:02	0.000000	3PH HT AB CABLE REPLACEMENT
140	25-02-2026	Part of : CHHATARPUR VILLAGE,GHITORNI VILLAGE	3273	Other Outage	Unplanned Outage	25-02-2026	19:51	25-02-2026	20:32	0:41	0.000011	CABLE FAULT
141	25-02-2026	Part of : SULTANPUR	974	Other Outage	Planned Outage	25-02-2026	11:32	25-02-2026	13:23	1:51	0.000432	REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
142	25-02-2026	Part of : SULTANPUR	36	Other Outage	Planned Outage	25-02-2026	13:47	25-02-2026	14:54	1:07	0.000000	CONDUCTOR REPLACEMENT PER SPAN,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
143	25-02-2026	Part of : AMBEDKAR COLONY MANDI	82	Other Outage	Planned Outage	25-02-2026	11:58	25-02-2026	13:52	1:54	0.000000	3PH DB REVAMPING,LT AB SAGGING PER SPAN
144	25-02-2026	Part of : PHASE 1 CHHATARPUR ENCLAVE	993	Other Outage	Planned Outage	25-02-2026	11:01	25-02-2026	14:20	3:19	0.002764	REPLACEMENT OF LT BUSHING ROD
145	25-02-2026	Part of : BLOCK G AYA NAGAR EXTENSION	586	Other Outage	Planned Outage	25-02-2026	11:20	25-02-2026	13:21	2:01	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
146	26-02-2026	Part of : ASOLA,ASOLA WILD LIFE SANCTUARY ASOLA	1672	Other Outage	Unplanned Outage	26-02-2026	14:01	26-02-2026	14:58	0:57	0.000439	ELECTROCUATION OF MONKEY
147	26-02-2026	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR,	586	Other Outage	Planned Outage	26-02-2026	14:03	26-02-2026	15:34	1:31	0.000000	INSTALLATION OF PHASE SEPERATOR PER SPAN,LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
148	26-02-2026	Part of : FATEHPUR BERI,	850	Other Outage	Planned Outage	26-02-2026	13:41	26-02-2026	15:05	1:24	0.000000	REPLACEMENT OF LUGS,SUB STATION CLEANING
149	26-02-2026	Part of : MANDI VILLAGE,	645	Other Outage	Planned Outage	26-02-2026	11:29	26-02-2026	12:57	1:28	0.000587	3PH DB REVAMPING,CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE
150	26-02-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR,	1151	Other Outage	Planned Outage	26-02-2026	11:13	26-02-2026	13:59	2:46	0.001383	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
151	27-02-2026	Part of : Chhatarpur,Sultanpur	4488	Other Outage	Unplanned Outage	27-02-2026	01:00	27-02-2026	01:45	0:45	0.000301	CABLE FAULT
152	27-02-2026	Part of : F & G-BLOCK AYA NAGAR EXTENSION,AYA NAGAR,GADPUR FARM DLF FARMS	3690	Other Outage	Planned Outage	27-02-2026	12:06	27-02-2026	12:25	0:19	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING
153	27-02-2026	Part of : SULTANPUR	974	Other Outage	Planned Outage	27-02-2026	14:02	27-02-2026	16:01	1:59	0.000463	1PH DB REVAMPING,LT AB SAGGING
154	27-02-2026	Part of : BHATI KALAN	980	Other Outage	Planned Outage	27-02-2026	11:50	27-02-2026	12:54	1:04	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
155	27-02-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	630	Other Outage	Planned Outage	27-02-2026	11:19	27-02-2026	13:18	1:59	0.000000	3PH HT AB CABLE REPLACEMENT
156	27-02-2026	Part of : BHATI KALAN	923	Other Outage	Planned Outage	27-02-2026	11:19	27-02-2026	12:22	1:03	0.000000	JUMPER REPLACEMENT PER POLE,TAPPING OF JUMPERS
157	27-02-2026	Part of : NEW GAWALPAHARI VILLAGE,DERA VILLAGE,GAWALPAHARI VILLAGE	251	Other Outage	Planned Outage	27-02-2026	11:24	27-02-2026	12:26	1:02	0.000413	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
158	27-02-2026	Part of : AMBEDKAR COLONY AYA NAGAR	10	Other Outage	Planned Outage	27-02-2026	10:56	27-02-2026	14:07	3:11	0.000000	LT CIRCUIT MAINTENANCE
159	27-02-2026	Part of : AMBEDKAR COLONY MANDI	82	Other Outage	Planned Outage	27-02-2026	11:52	27-02-2026	14:06	2:14	0.000000	LT CIRCUIT MAINTENANCE
160	28-02-2026	Part of : ADARSH ENCLAVE,AYA NAGAR EXTENSION PHASE-V	4770	Other Outage	Unplanned Outage	28-02-2026	22:52	28-02-2026	23:10	0:18	0.000035	TREE TOUCHING
161	28-02-2026	Part of : A 1-BLOCK CHHATARPUR VILLAGE	1587	Other Outage	Unplanned Outage	28-02-2026	09:12	28-02-2026	09:42	0:30	0.000841	BIRDAGE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
162	28-02-2026	Part of : F-BLOCK AYA NAGAR EXTENSION	336	Other Outage	Planned Outage	28-02-2026	12:25	28-02-2026	12:51	0:26	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING
163	28-02-2026	Part of : BHIM BASTI JUANAPUR	816	Other Outage	Planned Outage	28-02-2026	12:23	28-02-2026	12:46	0:23	0.000000	LT CIRCUIT MAINTENANCE
164	28-02-2026	Part of : BHATI KALAN	1100	Other Outage	Planned Outage	28-02-2026	11:23	28-02-2026	12:15	0:52	0.000000	BIRD SPIKES INSTALLATION PER POLE, GUARD WIRE LACS INSTALLTION
165	28-02-2026	Part of : AMBEDKAR COLONY MANDI	793	Other Outage	Planned Outage	28-02-2026	12:45	28-02-2026	13:35	0:50	0.000000	LT CIRCUIT MAINTENANCE
166	28-02-2026	Part of : DR AMBEDKAR COLONY CHHATARPUR	172	Other Outage	Planned Outage	28-02-2026	13:11	28-02-2026	15:30	2:19	0.000000	REPLACEMENT OF HT BUSHING ROD
167	28-02-2026	Part of : MANDI VILLAGE	282	Other Outage	Planned Outage	28-02-2026	11:19	28-02-2026	13:34	2:15	0.000000	LT CIRCUIT MAINTENANCE
168	02-02-2026	Part of : BEER SARAI,	451	Other Outage	Planned Outage	02-02-2026	11:24	02-02-2026	13:20	1:56	0.000097	3PH DB REVAMPING
169	02-02-2026	Part of : BLOCK C 3 SAFDARJUNG DEVELOPMENT AREA HAUZ KHAS,	323	Other Outage	Planned Outage	02-02-2026	11:05	02-02-2026	12:59	1:54	0.000475	REPLACEMENT OF GAS KIT AND OIL SEAL
170	03-02-2026	Part of : SECTOR 1 SADIQ NAGAR	1413	Other Outage	Planned Outage	03-02-2026	11:24	03-02-2026	12:42	1:18	0.000325	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
171	03-02-2026	Part of : BLOCK A GREEN PARK EXTENSION	221	Other Outage	Planned Outage	03-02-2026	11:02	03-02-2026	12:59	1:57	0.000163	LT CIRCUIT MAINTENANCE
172	03-02-2026	Part of : YUSUF SARAI	940	Other Outage	Planned Outage	03-02-2026	11:29	03-02-2026	14:16	2:47	0.001484	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
173	03-02-2026	Part of : BLOCK D PANCHSHEEL ENCLAVE	148	Other Outage	Planned Outage	03-02-2026	11:42	03-02-2026	13:42	2:00	0.000233	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
174	04-02-2026	Part of : E-BLOCK HAUZ KHAS	270	Other Outage	Planned Outage	04-02-2026	11:08	04-02-2026	14:55	3:47	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF LT BUSHING INSULATOR
175	04-02-2026	Part of : B 3-BLOCK SAFDARJUNG ENCLAVE	745	Other Outage	Planned Outage	04-02-2026	11:14	04-02-2026	13:51	2:37	0.000654	REPLACEMENT OF GAS KIT AND OIL SEAL
176	04-02-2026	Part of : NCERT CAMPUS KATWARIA SARAI	237	Other Outage	Planned Outage	04-02-2026	12:22	04-02-2026	14:56	2:34	0.000000	LT CIRCUIT MAINTENANCE
177	04-02-2026	Part of : IIT NO.3 (HT CONSUMER)	2	Other Outage	Planned Outage	04-02-2026	11:32	04-02-2026	14:04	2:32	0.000844	RELAY REPLACEMENT/VPI/FPI
178	05-02-2026	Part of : BLOCK X HAUZ KHAS	150	Other Outage	Planned Outage	05-02-2026	11:17	05-02-2026	13:52	2:35	0.000646	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
179	06-02-2026	Part of : GULMOHAR ENCLAVE GULMOHAR PARK,	1229	Other Outage	Planned Outage	06-02-2026	13:15	06-02-2026	16:00	2:45	0.001375	RELAY REPLACEMENT/VPI/FPI
180	06-02-2026	Part of : HTC:PANCHSHEEL CLUB OPP PANCHSHEELFLYOVER	1	Other Outage	Planned Outage	06-02-2026	12:15	06-02-2026	14:41	2:26	0.000000	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
181	06-02-2026	Part of : BLOCK M SOUTH EXTENSION II,	2	Other Outage	Planned Outage	06-02-2026	09:51	06-02-2026	12:37	2:46	0.000922	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
182	07-02-2026	Part of : NATIONAL CHEST INSTITUTE GAUTAM NGR (HT CONSUMER)	1	Other Outage	Planned Outage	07-02-2026	12:08	07-02-2026	13:04	0:56	0.000124	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
183	07-02-2026	Part of : ADMIN BLDG. CULTURAL CENTRE (HT CONSUMER)	3	Other Outage	Planned Outage	07-02-2026	11:20	07-02-2026	13:14	1:54	0.000222	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
184	07-02-2026	Part of : GAUTAM NAGAR	825	Other Outage	Planned Outage	07-02-2026	10:55	07-02-2026	13:18	2:23	0.001192	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
185	09-02-2026	Part of : DEER PARK HAUZ KHAS	636	Other Outage	Planned Outage	09-02-2026	11:05	09-02-2026	14:09	3:04	0.000767	REPLACEMENT OF GAS KIT AND OIL SEAL
186	10-02-2026	Part of : BLOCK J HAUZ KHAS ENCLAVE HAUZ KHAS,	131	Other Outage	Planned Outage	10-02-2026	13:06	10-02-2026	13:45	0:39	0.000108	RELAY REPLACEMENT/VPI/FPI,REPLACEMENT OF FAULTY END BOX
187	10-02-2026	Part of : BLOCK A HAUZ KHAS,	262	Other Outage	Planned Outage	10-02-2026	12:42	10-02-2026	16:03	3:21	0.000670	DT REPLACEMENT
188	10-02-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE,	912	Other Outage	Planned Outage	10-02-2026	11:33	10-02-2026	14:58	3:25	0.001139	DT REPLACEMENT
189	10-02-2026	Part of : GAUTAM NAGAR,	1069	Other Outage	Planned Outage	10-02-2026	10:46	10-02-2026	13:28	2:42	0.000720	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
190	11-02-2026	Part of : BLOCK S PANCHSHILA PARK SOUTH	300	Other Outage	Planned Outage	11-02-2026	13:35	11-02-2026	14:12	0:37	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
191	13-02-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE	250	Other Outage	Planned Outage	13-02-2026	13:00	13-02-2026	13:49	0:49	0.000150	3PH DB REPLACEMENT
192	13-02-2026	Part of : BLOCK B KATWARIA SARAI	436	Other Outage	Planned Outage	13-02-2026	11:06	13-02-2026	13:17	2:11	0.000364	3PH DB REVAMPING
193	13-02-2026	Part of : PANCHSHILA PARK NORTH	400	Other Outage	Planned Outage	13-02-2026	11:00	13-02-2026	16:17	5:17	0.000881	DT REPLACEMENT
194	13-02-2026	Part of : SHAHPUR JAT VILLAGE SIRI FORT	421	Other Outage	Planned Outage	13-02-2026	11:15	13-02-2026	14:27	3:12	0.000533	INSTALLATION OF PHASE SEPARATOR PER SPAN,PRC REPLACEMET PER FEEDER
195	14-02-2026	Part of : HTC:PHD HOUSE	1	Other Outage	Planned Outage	14-02-2026	11:05	14-02-2026	11:41	0:36	0.000010	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
196	14-02-2026	Part of : HTC:SEETA RAM	1	Other Outage	Planned Outage	14-02-2026	11:49	14-02-2026	13:19	1:30	0.000175	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
197	14-02-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE,	912	Other Outage	Planned Outage	14-02-2026	11:06	14-02-2026	14:59	3:53	0.000971	DT REPLACEMENT
198	16-02-2026	Part of : A 1-BLOCK NAUROJI NAGAR SAFDARJUNG ENCLAVE	524	Other Outage	Planned Outage	16-02-2026	11:02	16-02-2026	12:58	1:56	0.000483	REPLACEMENT OF GAS KIT AND OIL SEAL
199	16-02-2026	Part of : POCKET A KATWARIA SARAI	63	Other Outage	Planned Outage	16-02-2026	11:25	16-02-2026	12:33	1:08	0.000000	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
200	17-02-2026	Part of : GAUTAM NAGAR	279	Other Outage	Planned Outage	17-02-2026	10:49	17-02-2026	14:41	3:52	0.000644	OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
201	17-02-2026	Part of : BLOCK Q GREEN PARK EXTENSION	398	Other Outage	Planned Outage	17-02-2026	11:02	17-02-2026	13:04	2:02	0.000508	3PH DB REPLACEMENT
202	18-02-2026	Part of : DEER PARK HAUZ KHAS	125	Other Outage	Unplanned Outage	18-02-2026	16:34	18-02-2026	16:57	0:23	0.000000	HT SYSTEM FAULT
203	18-02-2026	Part of : BLOCK Y HAUZ KHAS,	117	Other Outage	Planned Outage	18-02-2026	11:02	18-02-2026	11:47	0:45	0.000050	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
204	18-02-2026	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE,	1520	Other Outage	Planned Outage	18-02-2026	11:14	18-02-2026	13:00	1:46	0.000442	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
205	18-02-2026	Part of : PANCHSHILA PARK NORTH PANCHSHILA PARK,	400	Other Outage	Planned Outage	18-02-2026	11:35	18-02-2026	14:38	3:03	0.000254	DT REPLACEMENT
206	19-02-2026	Part of : Part of : SHAHPUR JAT VILLAGE SIRI FORT	907	Other Outage	Planned Outage	19-02-2026	11:14	19-02-2026	12:47	1:33	0.000181	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER
207	19-02-2026	Part of : Part of : INDIAN INSTITUTE OF TECHNOLOGY DELHI HAUZ KHAS	260	Other Outage	Planned Outage	19-02-2026	10:57	19-02-2026	12:36	1:39	0.000220	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
208	19-02-2026	Part of : Part of : A 1-BLOCK NAUROJI NAGAR SAFDARJUNG ENCLAVE	315	Other Outage	Planned Outage	19-02-2026	11:08	19-02-2026	12:50	1:42	0.000142	LT CIRCUIT MAINTENANCE
209	20-02-2026	Part of : AYUR VIGYAN NAGAR SADIQ NAGAR	195	Other Outage	Planned Outage	20-02-2026	12:58	20-02-2026	13:42	0:44	0.000122	JUMPER REPLACEMENT PER POLE
210	20-02-2026	Part of : BLOCK A HAUZ KHAS	263	Other Outage	Planned Outage	20-02-2026	11:26	20-02-2026	15:16	3:50	0.000511	DT REPLACEMENT
211	20-02-2026	Part of : NEETI BAGH	226	Other Outage	Planned Outage	20-02-2026	10:29	20-02-2026	13:50	3:21	0.000112	LT CIRCUIT MAINTENANCE
212	21-02-2026	Part of : BEER SARAI, JAWAHAR LAL NEHRU UNIVERSITY, IIT MINI CAMPUS (HTC), INST. OF RUSSIAN STUDIES (HTC)	92	Other Outage	Unplanned Outage	21-02-2026	17:45	21-02-2026	18:30	0:45	0.000273	FAULT IN HT CONSUMER PANEL (IIT MINI CAMPUS)
213	21-02-2026	Part of : BEER SARAI, JAWAHAR LAL NEHRU UNIVERSITY, IIT MINI CAMPUS (HTC), INST. OF RUSSIAN STUDIES (HTC), BHARTI SCHOOL (HTC)	92	Other Outage	Unplanned Outage	21-02-2026	11:33	21-02-2026	12:16	0:43	0.001086	FAULT IN HT CONSUMER PANEL (BHARTI SCHOOL)
214	21-02-2026	Part of : BLOCK C QUTAB INSTITUTIONAL AREA	57	Other Outage	Planned Outage	21-02-2026	11:08	21-02-2026	12:50	1:42	0.000227	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER
215	21-02-2026	Part of : NDCD HAUZ KHAS (HTC)	1	Other Outage	Planned Outage	21-02-2026	11:11	21-02-2026	12:32	1:21	0.000158	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
216	21-02-2026	Part of : GAUTAM NAGAR	1150	Other Outage	Planned Outage	21-02-2026	11:57	21-02-2026	13:59	2:02	0.000474	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
217	22-02-2026	Part of : BLOCK B QUTAB INSTITUTIONAL AREA,BLOCK C QUTAB INSTITUTIONAL AREA	178	Other Outage	Unplanned Outage	22-02-2026	13:24	22-02-2026	14:13	0:49	0.000289	CABLE DAMAGE BY OUTSIDE AGENCY (POWER GRID TELESERVICES LTD)
218	23-02-2026	Part of : BLOCK S & N PANCHSHILA PARK SOUTH,ASIAN GAMES VILLAGE COMPLEX SIRI FORT	1205	Other Outage	Planned Outage	23-02-2026	14:24	23-02-2026	15:09	0:45	0.000050	INSTALLATION OF BUS BAR
219	23-02-2026	Part of : BLOCK A HAUZ KHAS	295	Other Outage	Planned Outage	23-02-2026	11:52	23-02-2026	12:52	1:00	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
220	23-02-2026	Part of : BLOCK E HAUZ KHAS	511	Other Outage	Planned Outage	23-02-2026	11:23	23-02-2026	12:33	1:10	0.000097	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
221	23-02-2026	Part of : PANCHSHILA PARK NORTH	400	Other Outage	Planned Outage	23-02-2026	12:08	23-02-2026	15:00	2:52	0.000239	DT REPLACEMENT
222	23-02-2026	Part of : BLOCK C GREEN PARK EXTENSION	135	Other Outage	Planned Outage	23-02-2026	12:43	23-02-2026	14:58	2:15	0.000563	DT REPLACEMENT
223	24-02-2026	Part of : PANCHSHILA PARK NORTH,SHAHPUR JAT VILLAGE SIRI FORT	1645	Other Outage	Unplanned Outage	24-02-2026	22:47	24-02-2026	23:09	0:22	0.000208	CABLE FAULT
224	24-02-2026	Part of : BLOCK B 7 ARJUN NAGAR SAFDARJUNG ENCLAVE	316	Other Outage	Planned Outage	24-02-2026	11:24	24-02-2026	12:50	1:26	0.000239	LT CIRCUIT MAINTENANCE
225	25-02-2026	Part of : BLOCK D PANCHSHEEL ENCLAVE	149	Other Outage	Unplanned Outage	25-02-2026	15:40	25-02-2026	16:13	0:33	0.000000	CONNECTION/DISCONNECTION OF HT/LT CABLES
226	25-02-2026	Part of : PANCHSHILA PARK NORTH	224	Other Outage	Planned Outage	25-02-2026	11:24	25-02-2026	11:55	0:31	0.000000	FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,JUMPER REPLACEMENT PER POLE
227	26-02-2026	Part of : BLOCK A 2 NAUROJI NAGAR SAFDARJUNG ENCLAVE,	182	Other Outage	Unplanned Outage	26-02-2026	15:16	26-02-2026	15:57	0:41	0.000000	TREE TRIMMING
228	26-02-2026	Part of : BLOCK A GREEN PARK EXTENSION GREEN PARK,	300	Other Outage	Unplanned Outage	26-02-2026	13:15	26-02-2026	14:10	0:55	0.000000	REPAIR/REPLACEMENT OF DB AND SERVICE LINE
229	26-02-2026	Part of : BLOCK A 2 NAUROJI NAGAR SAFDARJUNG ENCLAVE,	249	Other Outage	Unplanned Outage	26-02-2026	11:13	26-02-2026	13:13	2:00	0.000000	TREE TRIMMING
230	26-02-2026	Part of : BLOCK C GREEN PARK EXTENSION GREEN PARK,	135	Other Outage	Planned Outage	26-02-2026	10:57	26-02-2026	12:49	1:52	0.000311	DT REPLACEMENT
231	26-02-2026	Part of : BLOCK E SOAMI NAGAR NORTH SOAMI NAGAR,	213	Other Outage	Planned Outage	26-02-2026	11:35	26-02-2026	13:49	2:14	0.000112	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN
232	26-02-2026	Part of : BEER SARAI,	451	Other Outage	Planned Outage	26-02-2026	11:10	26-02-2026	14:02	2:52	0.000334	3PH DB REVAMPING
233	27-02-2026	Part of : BLOCK A 1 NAUROJI NAGAR SAFDARJUNG ENCLAVE	236	Other Outage	Unplanned Outage	27-02-2026	15:47	27-02-2026	16:48	1:01	0.000000	TREE TRIMMING
234	27-02-2026	Part of : A-BLOCK HAUZ KHAS	295	Other Outage	Planned Outage	27-02-2026	11:09	27-02-2026	13:41	2:32	0.000127	LT CIRCUIT MAINTENANCE
235	27-02-2026	Part of : JIA SARAI HAUZ KHAS	228	Other Outage	Planned Outage	27-02-2026	10:53	27-02-2026	14:52	3:59	0.001129	LT CIRCUIT MAINTENANCE
236	28-02-2026	Part of : C 3-BLOCK SAFDARJUNG DEVELOPMENT AREA HAUZ KHAS	241	Other Outage	Unplanned Outage	28-02-2026	13:20	28-02-2026	13:43	0:23	0.000000	REPAIRING OF LT CIRCUIT
237	28-02-2026	Part of : INSTITUTIONAL AREA HAUZ KHAS	4	Other Outage	Planned Outage	28-02-2026	14:59	28-02-2026	15:20	0:21	0.000029	LT CIRCUIT MAINTENANCE
238	28-02-2026	Part of : A-BLOCK QUTAB INSTITUTIONAL AREA	54	Other Outage	Planned Outage	28-02-2026	11:03	28-02-2026	13:07	2:04	0.000241	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS,REPLACEMENT OF FAULTY END BOX
239	28-02-2026	Part of : POCKET B KATWARIA SARAI	847	Other Outage	Planned Outage	28-02-2026	11:02	28-02-2026	13:04	2:02	0.000508	OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
240	01-02-2026	Part of : MITAL COLONY, BLOCK A & C PULPEHLADPUR,BLOCK R ZTO F PULPEHLADPUR, STORM WATER BADARPUR (HTC)	6080	Other Outage	Unplanned Outage	01-02-2026	20:38	01-02-2026	20:52	0:14	0.000132	FAULT IN HT CONSUMER PANEL (SS-2 PULPEHLADPUR)
241	01-02-2026	Part of : RAJU PARK SANGAM VIHAR	3425	Other Outage	Unplanned Outage	01-02-2026	12:46	01-02-2026	13:26	0:40	0.001148	CABLE FAULT
242	02-02-2026	Part of : BLOCK J 2 DEVLJI SANGAM VIHAR,	2493	Other Outage	Planned Outage	02-02-2026	11:56	02-02-2026	15:12	3:16	0.000599	3PH HT AB CABLE REPLACEMENT PER SPAN
243	02-02-2026	Part of : POCKET C RAJU PARK SANGAM VIHAR,	2135	Other Outage	Planned Outage	02-02-2026	12:14	02-02-2026	15:08	2:54	0.000532	3PH DB REVAMPING
244	02-02-2026	Part of : KHANPUR VILLAGE KHANPUR,BLOCK F KHANPUR COLONY KHANPUR,SHIV PARK DUGGAL COLONY KHANPUR,	16	Other Outage	Planned Outage	02-02-2026	11:37	02-02-2026	14:13	2:36	0.000477	3PH HT AB CABLE REPLACEMENT PER SPAN
245	02-02-2026	Part of : BLOCK L DEVLJI SANGAM VIHAR,BLOCK G DEVLJI SANGAM VIHAR,	3261	Other Outage	Planned Outage	02-02-2026	10:08	02-02-2026	15:07	4:59	0.000914	3PH HT AB CABLE REPLACEMENT PER SPAN
246	03-02-2026	Part of : MADANGIR VILLAGE,BLOCK C,E & F DR AMBEDKAR NAGAR MADANGIR	4879	Other Outage	Unplanned Outage	03-02-2026	03:28	03-02-2026	04:01	0:33	0.000108	CABLE DAMAGE BY OUT SIDE AGENCY (DMRC)
247	03-02-2026	Part of : BLOCK G 1 TALIMABAD SANGAM VIHAR,BLOCK H & G 2-SANGAM VIHAR	2440	Other Outage	Planned Outage	03-02-2026	14:43	03-02-2026	16:00	1:17	0.000235	REPLACEMENT OF FAULTY END BOX
248	03-02-2026	Part of : BLOCK J 1 & J 2 DEVLJI SANGAM VIHAR	9425	Other Outage	Planned Outage	03-02-2026	14:34	03-02-2026	16:02	1:28	0.000269	3PH HT AB CABLE REPLACEMENT
249	03-02-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	1148	Other Outage	Planned Outage	03-02-2026	11:26	03-02-2026	13:04	1:38	0.000299	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
250	03-02-2026	Part of : DR AMBEDKAR NAGAR MADANGIR	1807	Other Outage	Planned Outage	03-02-2026	12:38	03-02-2026	14:53	2:15	0.000413	3PH DB REPLACEMENT
251	03-02-2026	Part of : VAYUSENA VIHAR VAYUSENABAD	2895	Other Outage	Planned Outage	03-02-2026	11:07	03-02-2026	13:41	2:34	0.000471	3PH DB REPLACEMENT
252	03-02-2026	Part of : BLOCK L & J DEVLJI SANGAM VIHAR	3669	Other Outage	Planned Outage	03-02-2026	10:01	03-02-2026	12:58	2:57	0.000541	3PH HT AB CABLE REPLACEMENT
253	04-02-2026	Part of : POCKET B DUGGAL COLONY KHANPUR,TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD,JAWAHAR PARK SANGAM VIHAR	1684	Other Outage	Unplanned Outage	04-02-2026	12:55	04-02-2026	13:42	0:47	0.000896	HVDS FAULT
254	04-02-2026	Part of : MADANGIRI PH-2,RPS FLATS KHANPUR,KHANPUR COMPLAIN CENTRE	2762	Other Outage	Unplanned Outage	04-02-2026	23:58	05-02-2026	00:31	0:33	0.000424	CABLE DAMAGE BY OUTSIDE AGENCY (DMRC)
255	04-02-2026	Part of : C-BLOCK DEVLJI SANGAM VIHAR	3	Other Outage	Planned Outage	04-02-2026	11:45	04-02-2026	14:49	3:04	0.000562	3PH HT AB CABLE REPLACEMENT
256	04-02-2026	Part of : F-BLOCK KHANPUR COLONY,POCKET A JAWAHAR PARK	1379	Other Outage	Planned Outage	04-02-2026	11:36	04-02-2026	13:50	2:14	0.000409	3PH HT AB CABLE REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
257	04-02-2026	Part of : L & L 2-BLOCK L 2 DEVL SANGAM VIHAR	1983	Other Outage	Planned Outage	04-02-2026	10:37	04-02-2026	12:54	2:17	0.000419	3PH HT AB CABLE REPLACEMENT
258	04-02-2026	Part of : BLOCK 19 DAKSHINPURI EXTENSION,SECTOR 6 DAKSHINPURI	1790	Other Outage	Planned Outage	04-02-2026	11:18	04-02-2026	13:49	2:31	0.000461	REPLACEMET OF HT BUSHING ROD
259	05-02-2026	Part of : TALIMABAD SANGAM VIHAR, GALI NO- 8,9 & 12 G-BLOCK SANGAM VIAHAR	6311	Other Outage	Unplanned Outage	05-02-2026	16:19	05-02-2026	17:00	0:41	0.000000	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
260	05-02-2026	Part of : SECTOR 7 PUSHPA VIHAR,MADANGIR VILLAGE,DR AMBEDKAR NAGAR MADANGIR	3502	Other Outage	Planned Outage	05-02-2026	12:16	05-02-2026	14:42	2:26	0.000446	3PH DB REPLACEMENT
261	05-02-2026	Part of : BLOCK J 2 DEVL SANGAM VIHAR	4116	Other Outage	Planned Outage	05-02-2026	11:14	05-02-2026	13:32	2:18	0.000422	3PH HT AB CABLE REPLACEMENT PER SPAN
262	05-02-2026	Part of : BLOCK C,G & L DEVL SANGAM VIHAR	3261	Other Outage	Planned Outage	05-02-2026	10:02	05-02-2026	12:54	2:52	0.000526	3PH HT AB CABLE REPLACEMENT PER SPAN
263	06-02-2026	Part of : O/G F-2 BLOCK H NO. 720	0	Other Outage	Unplanned Outage	06-02-2026	11:46	06-02-2026	12:29	0:43	0.000235	ELECTROCUTION OF MONKEY
264	06-02-2026	Part of : TALIMABAD SANGAM VIHAR,BLOCK G 1 TALIMABAD SANGAM VIHAR,BLOCK H SANGAM VIHAR	2937	Other Outage	Unplanned Outage	06-02-2026	07:58	06-02-2026	08:37	0:39	0.000524	CABLE FAULT
265	06-02-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,	1150	Other Outage	Planned Outage	06-02-2026	10:58	06-02-2026	12:45	1:47	0.000327	3PH DB REPLACEMENT
266	06-02-2026	Part of : JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	1450	Other Outage	Planned Outage	06-02-2026	10:59	06-02-2026	13:50	2:51	0.000523	DT REPLACEMENT
267	06-02-2026	Part of : BLOCK J 1 DEVL SANGAM VIHAR,	2231	Other Outage	Planned Outage	06-02-2026	10:54	06-02-2026	14:25	3:31	0.000645	3PH HT AB CABLE REPLACEMENT PER SPAN
268	06-02-2026	Part of : JAHANPANA CITY FOREST,	1384	Other Outage	Planned Outage	06-02-2026	11:10	06-02-2026	13:49	2:39	0.000486	REPLACEMENT OF LT BUSHING ROD
269	06-02-2026	Part of : BLOCK L DEVL SANGAM VIHAR,BLOCK J DEVL SANGAM VIHAR,	3669	Other Outage	Planned Outage	06-02-2026	09:57	06-02-2026	12:41	2:44	0.000501	3PH HT AB CABLE REPLACEMENT PER SPAN
270	07-02-2026	Part of : RPS COLONY MADANGIR,KHANPUR EXTENSION SANGAM VIHAR,POCKET A DUGGAL COLONY KHANPUR,KHANPUR VILLAGE KHANPUR	3623	Other Outage	Unplanned Outage	07-02-2026	15:37	07-02-2026	16:22	0:45	0.000000	SHIFTING OF CABLE
271	07-02-2026	Part of : BLOCK 19 DAKSHINPURI EXTENSION,SECTOR 6 DAKSHINPURI	1790	Other Outage	Planned Outage	07-02-2026	11:56	07-02-2026	14:31	2:35	0.000474	3PH DB REPLACEMENT
272	07-02-2026	Part of : BLOCK R ZTO F PULPEHLADPUR	2097	Other Outage	Planned Outage	07-02-2026	11:01	07-02-2026	13:26	2:25	0.000443	3PH HT AB CABLE REPLACEMENT
273	07-02-2026	Part of : POCKET A,B,C,D & E JAWAHAR PARK KHANPUR	1379	Other Outage	Planned Outage	07-02-2026	10:25	07-02-2026	14:04	3:39	0.000669	3PH HT AB CABLE REPLACEMENT
274	07-02-2026	Part of : BLOCK L & L 2-DEVL SANGAM VIHAR	1983	Other Outage	Planned Outage	07-02-2026	09:58	07-02-2026	13:01	3:03	0.000559	3PH HT AB CABLE REPLACEMENT
275	08-02-2026	Part of : DEVL SANGAM VIHAR	0	Other Outage	Unplanned Outage	08-02-2026	12:07	08-02-2026	12:38	0:31	0.000365	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
276	09-02-2026	Part of : BLOCK L DEVL SANGAM VIHAR,BLOCK C DEVL SANGAM VIHAR	3261	Other Outage	Planned Outage	09-02-2026	11:05	09-02-2026	12:48	1:43	0.000315	3PH HT AB CABLE REPLACEMENT PER SPAN
277	09-02-2026	Part of : JJ COLONY DUGGAL COLONY KHANPUR,BLOCK F KHANPUR COLONY,KHANPUR VILLAGE	1363	Other Outage	Planned Outage	09-02-2026	11:00	09-02-2026	12:10	1:10	0.000214	3PH HT AB CABLE REPLACEMENT PER SPAN
278	09-02-2026	Part of : BLOCK F 2 SANGAM VIHAR,BLOCK G 2 SANGAM VIHAR	1301	Other Outage	Planned Outage	09-02-2026	11:07	09-02-2026	13:37	2:30	0.000458	3PH HT AB CABLE REPLACEMENT PER SPAN
279	09-02-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	1150	Other Outage	Planned Outage	09-02-2026	11:01	09-02-2026	14:47	3:46	0.000691	DT REPLACEMENT
280	10-02-2026	Part of : BLOCK K SANGAM VIHAR,BLOCK I 1 SANGAM VIHAR,BLOCK G 2 SANGAM VIHAR,ASOLA WILD LIFE SANCTUARY, TUGHLAKABAD,BLOCK F 2 SANGAM VIHAR	7893	Other Outage	Unplanned Outage	10-02-2026	16:18	10-02-2026	16:57	0:39	0.000390	CABLE DAMAGE BY OUTSIDE AGENCY (FLOOD DEPARTMENT)
281	10-02-2026	Part of : BLOCK F 2 SANGAM VIHAR,BLOCK F SANGAM VIHAR	4436	Other Outage	Unplanned Outage	10-02-2026	15:10	10-02-2026	15:53	0:43	0.001459	CABLE DAMAGE BY OUTSIDE AGENCY (FLOOD DEPARTMENT)
282	10-02-2026	Part of : BLOCK 19 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,	1790	Other Outage	Planned Outage	10-02-2026	12:00	10-02-2026	14:48	2:48	0.000513	3PH DB REVAMPING
283	10-02-2026	Part of : BLOCK C DR AMBEDKAR NAGAR MADANGIR,	667	Other Outage	Planned Outage	10-02-2026	11:27	10-02-2026	13:45	2:18	0.000422	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
284	10-02-2026	Part of : HR-BLOCK PULPEHLADPUR,	2279	Other Outage	Planned Outage	10-02-2026	11:02	10-02-2026	13:30	2:28	0.000452	3PH HT AB CABLE REPLACEMENT PER SPAN
285	10-02-2026	Part of : BLOCK L DEVL SANGAM VIHAR,BLOCK J DEVL SANGAM VIHAR,	3669	Other Outage	Planned Outage	10-02-2026	09:57	10-02-2026	12:46	2:49	0.000516	3PH HT AB CABLE REPLACEMENT PER SPAN
286	11-02-2026	Part of : BLOCK G JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1871	Other Outage	Planned Outage	11-02-2026	12:54	11-02-2026	15:12	2:18	0.000422	3PH DB REPLACEMENT
287	11-02-2026	Part of : BLOCK G 2 SANGAM VIHAR	215	Other Outage	Planned Outage	11-02-2026	11:17	11-02-2026	13:50	2:33	0.000468	3PH HT AB CABLE REPLACEMENT
288	11-02-2026	Part of : POCKET A,B,C & D JAWAHAR PARK,BLOCK F KHANPUR COLONY	1379	Other Outage	Planned Outage	11-02-2026	10:28	11-02-2026	13:04	2:36	0.000477	3PH HT AB CABLE REPLACEMENT
289	11-02-2026	Part of : BLOCK L & L 2 DEVL SANGAM VIHAR	1983	Other Outage	Planned Outage	11-02-2026	09:54	11-02-2026	12:49	2:55	0.000535	3PH HT AB CABLE REPLACEMENT
290	12-02-2026	Part of : RPS COLONY MADANGIR	1143	Other Outage	Planned Outage	12-02-2026	13:45	12-02-2026	14:40	0:55	0.000000	CONDUCTOR REPLACEMENT
291	12-02-2026	Part of : F-BLOCK JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1458	Other Outage	Planned Outage	12-02-2026	13:42	12-02-2026	16:47	3:05	0.000565	3PH DB REPLACEMENT
292	12-02-2026	Part of : MADANGIR VILLAGE	2125	Other Outage	Planned Outage	12-02-2026	12:53	12-02-2026	15:51	2:58	0.000544	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
293	12-02-2026	Part of : CHUNGI NO 2 KOTLA MAHINGIRAN LAL KUAN	628	Other Outage	Planned Outage	12-02-2026	11:01	12-02-2026	14:03	3:02	0.000556	DT REPLACEMENT
294	12-02-2026	Part of : G 2,K & I-BLOCK SANGAM VIHAR	3631	Other Outage	Planned Outage	12-02-2026	10:36	12-02-2026	13:42	3:06	0.000568	3PH HT AB CABLE REPLACEMENT
295	12-02-2026	Part of : POCKET C RAJU PARK SANGAM VIHAR	2139	Other Outage	Planned Outage	12-02-2026	11:31	12-02-2026	13:47	2:16	0.000416	DT REPLACEMENT
296	12-02-2026	Part of : G,L & J-BLOCK DEVL I SANGAM VIHAR	3261	Other Outage	Planned Outage	12-02-2026	09:55	12-02-2026	12:54	2:59	0.000547	3PH HT AB CABLE REPLACEMENT
297	13-02-2026	Part of : BLOCK D SANGAM VIHAR,BLOCK E SANGAM VIHAR	3566	Other Outage	Unplanned Outage	13-02-2026	12:57	13-02-2026	13:48	0:51	0.001790	CABLE FAULT
298	13-02-2026	Part of : BLOCK 4 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	123	Other Outage	Planned Outage	13-02-2026	12:25	13-02-2026	13:57	1:32	0.000281	DT REPLACEMENT
299	13-02-2026	Part of : BLOCK 19 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	828	Other Outage	Planned Outage	13-02-2026	12:02	13-02-2026	13:53	1:51	0.000339	REPLACEMET OF HT BUSHING ROD
300	13-02-2026	Part of : KHANPUR EXTENSION SANGAM VIHAR	1283	Other Outage	Planned Outage	13-02-2026	11:06	13-02-2026	13:50	2:44	0.000501	3PH HT AB CABLE REPLACEMENT PER SPAN
301	13-02-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	1149	Other Outage	Planned Outage	13-02-2026	11:07	13-02-2026	13:10	2:03	0.000376	3PH DB REPLACEMENT
302	13-02-2026	Part of : BLOCK L DEVL I SANGAM VIHAR,BLOCK J DEVL I SANGAM VIHAR	3669	Other Outage	Planned Outage	13-02-2026	10:02	13-02-2026	13:03	3:01	0.000553	3PH HT AB CABLE REPLACEMENT PER SPAN
303	14-02-2026	Part of : BLOCK J 2 DEVL I SANGAM VIHAR,	4119	Other Outage	Planned Outage	14-02-2026	11:07	14-02-2026	13:51	2:44	0.000501	3PH HT AB CABLE REPLACEMENT PER SPAN
304	14-02-2026	Part of : BLOCK A PULPEHLADPUR,	1110	Other Outage	Planned Outage	14-02-2026	11:17	14-02-2026	14:14	2:57	0.000541	3PH HT AB CABLE REPLACEMENT PER SPAN
305	14-02-2026	Part of : JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	1450	Other Outage	Planned Outage	14-02-2026	11:44	14-02-2026	13:52	2:08	0.000391	DT REPLACEMENT
306	14-02-2026	Part of : BLOCK B JJ COLONY KHANPUR,	1469	Other Outage	Planned Outage	14-02-2026	11:00	14-02-2026	13:46	2:46	0.000507	REPLACEMET OF HT BUSHING ROD
307	14-02-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,	1663	Other Outage	Planned Outage	14-02-2026	10:02	14-02-2026	12:54	2:52	0.000526	3PH HT AB CABLE REPLACEMENT PER SPAN
308	15-02-2026	Part of : BLOCK J DEVL I SANGAM VIHAR,BLOCK L DEVL I SANGAM VIHAR	4349	Other Outage	Unplanned Outage	15-02-2026	09:53	15-02-2026	10:47	0:54	0.002685	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
309	16-02-2026	Part of : CHUNGI NO 2 KOTLA MAHINGIRAN LAL KUAN	628	Other Outage	Planned Outage	16-02-2026	11:52	16-02-2026	13:45	1:53	0.000345	3PH DB REPLACEMENT
310	16-02-2026	Part of : JAWAHAR PARK SANGAM VIHAR	647	Other Outage	Planned Outage	16-02-2026	13:55	16-02-2026	16:27	2:32	0.000464	DT REPLACEMENT
311	16-02-2026	Part of : MADANGIR VILLAGE	2128	Other Outage	Planned Outage	16-02-2026	12:27	16-02-2026	15:25	2:58	0.000544	3PH DB REPLACEMENT
312	16-02-2026	Part of : C-BLOCK DR AMBEDKAR NAGAR MADANGIR	667	Other Outage	Planned Outage	16-02-2026	11:38	16-02-2026	14:40	3:02	0.000556	DT REPLACEMENT
313	16-02-2026	Part of : J 1 & J 2-BLOCK DEVL I SANGAM VIHAR	2821	Other Outage	Planned Outage	16-02-2026	10:44	16-02-2026	13:28	2:44	0.000501	3PH HT AB CABLE REPLACEMENT
314	16-02-2026	Part of : SHIV PARK,JJ COLONY DUGGAL COLONY KHANPUR,F-BLOCK KHANPUR COLONY KHANPUR,KHANPUR VILLAGE	1364	Other Outage	Planned Outage	16-02-2026	10:57	16-02-2026	13:39	2:42	0.000495	3PH HT AB CABLE REPLACEMENT
315	16-02-2026	Part of : C,G & L-BLOCK DEVL I SANGAM VIHAR	3261	Other Outage	Planned Outage	16-02-2026	10:03	16-02-2026	12:56	2:53	0.000529	3PH HT AB CABLE REPLACEMENT
316	16-02-2026	Part of : C & HR-BLOCK PULPEHLADPUR	2279	Other Outage	Planned Outage	16-02-2026	10:08	16-02-2026	12:11	2:03	0.000376	3PH HT AB CABLE REPLACEMENT
317	17-02-2026	Part of : BLOCK 3 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	1087	Other Outage	Planned Outage	17-02-2026	11:45	17-02-2026	13:30	1:45	0.000321	3PH DB REPLACEMENT
318	17-02-2026	Part of : BLOCK J1 & J2 DEVL I SANGAM VIHAR	5048	Other Outage	Planned Outage	17-02-2026	11:11	17-02-2026	13:20	2:09	0.000394	3PH HT AB CABLE REPLACEMENT PER SPAN
319	17-02-2026	Part of : BLOCK J & L DEVL I SANGAM VIHAR	3669	Other Outage	Planned Outage	17-02-2026	10:03	17-02-2026	12:55	2:52	0.000526	3PH HT AB CABLE REPLACEMENT PER SPAN
320	17-02-2026	Part of : BLOCK C PULPEHLADPUR,BLOCK R ZTO F PULPEHLADPUR	820	Other Outage	Planned Outage	17-02-2026	10:24	17-02-2026	12:33	2:09	0.000394	3PH HT AB CABLE REPLACEMENT PER SPAN
321	18-02-2026	Part of : BLOCK B DEVL I SANGAM VIHAR,	1794	Other Outage	Planned Outage	18-02-2026	11:59	18-02-2026	14:28	2:29	0.000455	3PH HT AB CABLE REPLACEMENT PER SPAN
322	18-02-2026	Part of : POCKET C JAWAHAR PARK KHANPUR,BLOCK F KHANPUR COLONY KHANPUR,POCKET A JAWAHAR PARK KHANPUR,POCKET D JAWAHAR PARK KHANPUR,	1379	Other Outage	Planned Outage	18-02-2026	11:26	18-02-2026	13:51	2:25	0.000443	3PH HT AB CABLE REPLACEMENT PER SPAN
323	18-02-2026	Part of : HR-BLOCK PULPEHLADPUR,BLOCK B PULPEHLADPUR,DDA LIG FLATS PULPEHLADPUR,BLOCK C PULPEHLADPUR,BLOCK A PULPEHLADPUR,	2777	Other Outage	Planned Outage	18-02-2026	11:00	18-02-2026	13:43	2:43	0.000498	3PH HT AB CABLE REPLACEMENT PER SPAN
324	18-02-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,BLOCK A TIGRI EXTENSION SANGAM VIHAR,	1663	Other Outage	Planned Outage	18-02-2026	09:58	18-02-2026	12:53	2:55	0.000535	3PH HT AB CABLE REPLACEMENT PER SPAN
325	19-02-2026	Part of : Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	5791	Other Outage	Planned Outage	19-02-2026	11:47	19-02-2026	12:14	0:27	0.000082	3PH HT AB CABLE REPLACEMENT
326	19-02-2026	Part of : Part of : MADANGIR VILLAGE	2127	Other Outage	Planned Outage	19-02-2026	11:35	19-02-2026	13:13	1:38	0.000299	3PH DB REPLACEMENT
327	19-02-2026	Part of : Part of : C-BLOCK PULPEHLADPUR	833	Other Outage	Planned Outage	19-02-2026	14:50	19-02-2026	16:50	2:00	0.001000	DT REPLACEMENT PER DT
328	19-02-2026	Part of : Part of : J 1 & J 2-BLOCK J 2 DEVL I SANGAM VIHAR	2827	Other Outage	Planned Outage	19-02-2026	11:46	19-02-2026	14:27	2:41	0.000492	3PH HT AB CABLE REPLACEMENT
329	19-02-2026	Part of : Part of : DDA LIG FLATS PULPEHLADPUR,C & HR-BLOCK PULPEHLADPUR	2279	Other Outage	Planned Outage	19-02-2026	10:51	19-02-2026	13:57	3:06	0.000568	3PH HT AB CABLE REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
330	19-02-2026	Part of : Part of : KHANPUR VILLAGE,SHIV PARK DUGGAL COLONY,F-BLOCK KHANPUR COLONY	855	Other Outage	Planned Outage	19-02-2026	10:54	19-02-2026	13:11	2:17	0.000419	3PH HT AB CABLE REPLACEMENT
331	19-02-2026	Part of : Part of : G & L-BLOCK DEVL I SANGAM VIHAR	3261	Other Outage	Planned Outage	19-02-2026	10:00	19-02-2026	12:55	2:55	0.000535	3PH HT AB CABLE REPLACEMENT
332	20-02-2026	Part of : L 2-BLOCK DEVL I SANGAM VIHAR,DURGA VIHAR,N-BLOCK SOUTH SAINIK FARM SAINIK FARM	2577	Other Outage	Unplanned Outage	20-02-2026	09:57	20-02-2026	11:13	1:16	0.001144	CABLE DAMAGE BY OUTSIDE AGENCY (DMRC)
333	20-02-2026	Part of : JAWAHAR PARK SANGAM VIHAR	647	Other Outage	Planned Outage	20-02-2026	12:48	20-02-2026	14:10	1:22	0.000251	REPLACEMET OF HT BUSHING ROD
334	20-02-2026	Part of : BLOCK B DEVL I SANGAM VIHAR	1397	Other Outage	Planned Outage	20-02-2026	10:44	20-02-2026	13:49	3:05	0.000565	3PH HT AB CABLE REPLACEMENT
335	20-02-2026	Part of : BLOCK J & L DEVL I SANGAM VIHAR	3669	Other Outage	Planned Outage	20-02-2026	09:57	20-02-2026	13:00	3:03	0.000559	3PH HT AB CABLE REPLACEMENT
336	21-02-2026	Part of : BLOCK 3 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	1087	Other Outage	Planned Outage	21-02-2026	13:18	21-02-2026	14:47	1:29	0.000272	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
337	21-02-2026	Part of : BLOCK F KHANPUR COLONY, POCKET A,B & E JAWAHAR PARK KHANPUR	1379	Other Outage	Planned Outage	21-02-2026	10:49	21-02-2026	13:32	2:43	0.000498	3PH HT AB CABLE REPLACEMENT PER SPAN
338	21-02-2026	Part of : BLOCK J1 & J2 DEVL I SANGAM VIHAR	2231	Other Outage	Planned Outage	21-02-2026	11:01	21-02-2026	14:01	3:00	0.000550	3PH HT AB CABLE REPLACEMENT PER SPAN
339	21-02-2026	Part of : BLOCK B TIGRI EXTENSION SANGAM VIHAR	1268	Other Outage	Planned Outage	21-02-2026	11:13	21-02-2026	13:33	2:20	0.000428	3PH DB REPLACEMENT
340	21-02-2026	Part of : BLOCK A TIGRI EXTENSION, DEOLI GAON NAI BASTI SANGAM VIHAR	1663	Other Outage	Planned Outage	21-02-2026	09:57	21-02-2026	12:54	2:57	0.000541	3PH HT AB CABLE REPLACEMENT PER SPAN
341	22-02-2026	Part of : BLOCK RZ H PULPEHLADPUR,BLOCK A PULPEHLADPUR,BLOCK R ZTO F PULPEHLADPUR,BLOCK C PULPEHLADPUR,HR-BLOCK PULPEHLADPUR	4685	Other Outage	Unplanned Outage	22-02-2026	18:22	22-02-2026	19:42	1:20	0.000000	HT SYSTEM FAULT
342	23-02-2026	Part of : BLOCK F 2 SANGAM VIHAR	1364	Other Outage	Planned Outage	23-02-2026	10:53	23-02-2026	11:18	0:25	0.000076	APPLY OF INSULATION TAPE HT/LT BUSHINGS
343	23-02-2026	Part of : KHANPUR VILLAGE,JJ COLONY DUGGAL COLONY,SHIV PARK DUGGAL COLONY	16	Other Outage	Planned Outage	23-02-2026	10:58	23-02-2026	13:33	2:35	0.000474	3PH HT AB CABLE REPLACEMENT
344	23-02-2026	Part of : MADANGIR VILLAGE	2127	Other Outage	Planned Outage	23-02-2026	11:06	23-02-2026	13:58	2:52	0.000526	3PH DB REPLACEMENT
345	23-02-2026	Part of : JAWAHAR PARK SANGAM VIHAR	647	Other Outage	Planned Outage	23-02-2026	10:59	23-02-2026	13:56	2:57	0.000541	DT REPLACEMENT
346	23-02-2026	Part of : BLOCK C,L,G & J DEVL I SANGAM VIHAR	3261	Other Outage	Planned Outage	23-02-2026	09:57	23-02-2026	12:55	2:58	0.000544	3PH HT AB CABLE REPLACEMENT
347	24-02-2026	Part of : BLOCK B TIGRI EXTENSION SANGAM VIHAR	1269	Other Outage	Planned Outage	24-02-2026	12:15	24-02-2026	14:58	2:43	0.000498	3PH DB REPLACEMENT
348	24-02-2026	Part of : BLOCK C & L DEVL I SANGAM VIHAR	3	Other Outage	Planned Outage	24-02-2026	10:46	24-02-2026	14:08	3:22	0.000617	3PH HT AB CABLE REPLACEMENT
349	24-02-2026	Part of : POCKET C RAJU PARK SANGAM VIHAR	175	Other Outage	Planned Outage	24-02-2026	11:39	24-02-2026	13:51	2:12	0.000403	3PH DB REPLACEMENT
350	24-02-2026	Part of : BLOCK A,C & D VISHWAKARMA COLONY PULPEHLADPUR	1995	Other Outage	Planned Outage	24-02-2026	11:14	24-02-2026	13:35	2:21	0.000431	3PH HT AB CABLE REPLACEMENT
351	24-02-2026	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	63	Other Outage	Planned Outage	24-02-2026	11:00	24-02-2026	13:50	2:50	0.000519	3PH DB REPLACEMENT
352	24-02-2026	Part of : TALIMABAD SANGAM VIHAR	577	Other Outage	Planned Outage	24-02-2026	10:38	24-02-2026	14:08	3:30	0.000642	DT REPLACEMENT
353	24-02-2026	Part of : BLOCK J & L DEVL I SANGAM VIHAR	3669	Other Outage	Planned Outage	24-02-2026	09:56	24-02-2026	12:55	2:59	0.000547	3PH HT AB CABLE REPLACEMENT
354	25-02-2026	Part of : MADANGIR VILLAGE	15	Other Outage	Planned Outage	25-02-2026	11:21	25-02-2026	13:43	2:22	0.000434	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING ROD
355	25-02-2026	Part of : BLOCK L DEVL I SANGAM VIHAR,BLOCK L 2 DEVL I SANGAM VIHAR	1983	Other Outage	Planned Outage	25-02-2026	10:06	25-02-2026	12:57	2:51	0.000523	3PH HT AB CABLE REPLACEMENT PER SPAN
356	26-02-2026	Part of : BLOCK G JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	884	Other Outage	Planned Outage	26-02-2026	13:29	26-02-2026	14:42	1:13	0.000223	3PH DB REPLACEMENT
357	26-02-2026	Part of : SHIV PARK DUGGAL COLONY KHANPUR,KHANPUR VILLAGE KHANPUR,	16	Other Outage	Planned Outage	26-02-2026	11:04	26-02-2026	12:48	1:44	0.000318	3PH HT AB CABLE REPLACEMENT PER SPAN
358	26-02-2026	Part of : BLOCK J 1 DEVL I SANGAM VIHAR,BLOCK J 2 DEVL I SANGAM VIHAR,	2817	Other Outage	Planned Outage	26-02-2026	10:36	26-02-2026	13:42	3:06	0.000568	3PH HT AB CABLE REPLACEMENT PER SPAN
359	26-02-2026	Part of : BLOCK L DEVL I SANGAM VIHAR,BLOCK G DEVL I SANGAM VIHAR,	3261	Other Outage	Planned Outage	26-02-2026	10:00	26-02-2026	12:55	2:55	0.000535	3PH HT AB CABLE REPLACEMENT PER SPAN
360	27-02-2026	Part of : Block J 1 Devli Sangam Vihar,Block J 2 Devli Sangam Vihar,Asola Wild Life Sanctuary Asola	5093	Other Outage	Unplanned Outage	27-02-2026	23:27	27-02-2026	23:56	0:29	0.000867	CABLE FAULT
361	27-02-2026	Part of : HTC:GARRISON ENGG MES	0	Other Outage	Unplanned Outage	27-02-2026	19:13	27-02-2026	19:43	0:30	0.000099	FAULT IN HT CONSUMER PANEL (MES)
362	27-02-2026	Part of : J-BLOCK SECTOR 5 DAKSHINPURI	1096	Other Outage	Planned Outage	27-02-2026	12:52	27-02-2026	14:08	1:16	0.000232	3PH DB REPLACEMENT
363	27-02-2026	Part of : TALIMABAD SANGAM VIHAR,H-BLOCK SANGAM VIHAR	2437	Other Outage	Planned Outage	27-02-2026	11:25	27-02-2026	12:44	1:19	0.000241	3PH HT AB CABLE REPLACEMENT
364	27-02-2026	Part of : C-BLOCK DR AMBEDKAR NAGAR MADANGIR	2277	Other Outage	Planned Outage	27-02-2026	10:55	27-02-2026	13:50	2:55	0.000535	REPLACEMENT OF HT BUSHING ROD
365	27-02-2026	Part of : BLOCK 3 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	1087	Other Outage	Planned Outage	27-02-2026	11:19	27-02-2026	13:52	2:33	0.000468	ACB REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
366	27-02-2026	Part of : J & L-BLOCK DEVI SANGAM VIHAR	3669	Other Outage	Planned Outage	27-02-2026	10:01	27-02-2026	12:55	2:54	0.000532	3PH HT AB CABLE REPLACEMENT
367	28-02-2026	Part of : GARRISON ENGG TUGLAKABAD (HT CONSUMER)	0	Other Outage	Unplanned Outage	28-02-2026	00:03	28-02-2026	00:24	0:21	0.000046	FAULT IN HT CONSUMER PANEL (MES -II)
368	28-02-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	443	Other Outage	Unplanned Outage	28-02-2026	14:36	28-02-2026	15:55	1:19	0.000605	CABLE FAULT
369	28-02-2026	Part of : TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD	9	Other Outage	Planned Outage	28-02-2026	12:52	28-02-2026	13:56	1:04	0.000196	DT REPLACEMENT
370	28-02-2026	Part of : G 1-BLOCK TALIMABAD SANGAM VIHAR	1612	Other Outage	Planned Outage	28-02-2026	12:34	28-02-2026	14:08	1:34	0.000287	3PH HT AB CABLE REPLACEMENT
371	02-02-2026	Part of : BLOCK C JOGA BAI EXTENSION OKHLA,OKHLA VILLAGE OKHLA,AZIM DAIRY OKHLA	8055	Other Outage	Unplanned Outage	02-02-2026	16:03	02-02-2026	16:43	0:40	0.001078	CABLE FAULT
372	02-02-2026	Part of : HTC:SPORTS COMPLEX JASOLA	1	Other Outage	Planned Outage	02-02-2026	12:34	02-02-2026	13:35	1:01	0.000373	GUARD WIRES SAGGING PER SPAN
373	02-02-2026	Part of : BLOCK C NEW FRIENDS COLONY EAST NEW FRIENDS COLONY,	60	Other Outage	Planned Outage	02-02-2026	11:08	02-02-2026	13:17	2:09	0.001075	TAPPING OF JUMPERS
374	03-02-2026	Part of : CRR I SUKHDEV VIHAR OKHLA	81	Other Outage	Planned Outage	03-02-2026	10:57	03-02-2026	12:53	1:56	0.000967	JUMPER REPLACEMENT PER POLE
375	03-02-2026	Part of : POCKET 12 JASOLA VIHAR	216	Other Outage	Planned Outage	03-02-2026	10:52	03-02-2026	13:08	2:16	0.001322	REPLACEMENT OF HT BUSHING ROD
376	04-02-2026	Part of : A-BLOCK TAIMOOR NAGAR NEW FRIENDS COLONY	37	Other Outage	Planned Outage	04-02-2026	11:01	04-02-2026	13:26	2:25	0.001208	REPLACEMET OF HT BUSHING ROD
377	04-02-2026	Part of : JOGA BAI OKHLA	718	Other Outage	Planned Outage	04-02-2026	12:55	04-02-2026	15:31	2:36	0.002383	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
378	05-02-2026	Part of : POCKET 12 JASOLA VIHAR	399	Other Outage	Planned Outage	05-02-2026	10:47	05-02-2026	11:47	1:00	0.000500	REPLACEMENT OF LT BUSHING ROD
379	05-02-2026	Part of : BLOCK A OKHLA	137	Other Outage	Planned Outage	05-02-2026	12:57	05-02-2026	15:33	2:36	0.001647	MEASUREMET OF INSULATION RESISTANCE,REPLACEMENT OF SILICAGEL IN BREATHER
380	05-02-2026	Part of : BLOCK C NEW FRIENDS COLONY	100	Other Outage	Planned Outage	05-02-2026	11:05	05-02-2026	13:41	2:36	0.001300	REPLACEMENT OF LT BUSHING ROD
381	06-02-2026	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR,	28	Other Outage	Unplanned Outage	06-02-2026	12:31	06-02-2026	13:39	1:08	0.000472	TREE TRIMMING
382	06-02-2026	Part of : VILLAGE JASOLA JASOLA VIHAR,	14	Other Outage	Planned Outage	06-02-2026	12:04	06-02-2026	12:45	0:41	0.000057	SUB STATION CLEANING
383	06-02-2026	Part of : JASOLA VIHAR,	24	Other Outage	Planned Outage	06-02-2026	10:11	06-02-2026	10:47	0:36	0.000250	SUB STATION CLEANING
384	07-02-2026	Part of : VILLAGE JASOLA,JASOLA VIHAR	174	Other Outage	Planned Outage	07-02-2026	10:01	07-02-2026	11:14	1:13	0.000406	REPLACEMENT OF HT BUSHING ROD
385	07-02-2026	Part of : BLOCK A OKHLA	263	Other Outage	Planned Outage	07-02-2026	13:05	07-02-2026	15:41	2:36	0.000910	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
386	07-02-2026	Part of : BLOCK C NEW FRIENDS COLONY EAST	60	Other Outage	Planned Outage	07-02-2026	11:07	07-02-2026	13:39	2:32	0.001267	REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
387	07-02-2026	Part of : JASOLA VIHAR	30	Other Outage	Planned Outage	07-02-2026	10:03	07-02-2026	12:12	2:09	0.000538	SUB STATION CLEANING
388	10-02-2026	Part of : BLOCK B TAIMOOR NAGAR NEW FRIENDS COLONY,	1069	Other Outage	Planned Outage	10-02-2026	11:02	10-02-2026	11:33	0:31	0.000258	REPLACEMENT OF LT BUSHING ROD
389	10-02-2026	Part of : BLOCK C JOGA BAI EXTENSION OKHLA,	882	Other Outage	Planned Outage	10-02-2026	12:04	10-02-2026	14:37	2:33	0.002338	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER, OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
390	10-02-2026	Part of : VILLAGE JASOLA JASOLA VIHAR,	123	Other Outage	Planned Outage	10-02-2026	10:00	10-02-2026	12:31	2:31	0.000839	REPLACEMENT OF LT BUSHING ROD
391	12-02-2026	Part of : VILLAGE JASOLA JASOLA VIHAR	188	Other Outage	Planned Outage	12-02-2026	10:02	12-02-2026	12:26	2:24	0.001200	REPLACEMENT OF HT BUSHING ROD
392	13-02-2026	Part of : BLOCK G SRINIVAS PURI	349	Other Outage	Planned Outage	13-02-2026	10:57	13-02-2026	13:42	2:45	0.001375	REPLACEMENT OF LT BUSHING ROD
393	14-02-2026	Part of : VILLAGE JASOLA JASOLA VIHAR,	149	Other Outage	Planned Outage	14-02-2026	11:03	14-02-2026	12:16	1:13	0.000710	REPLACEMET OF HT BUSHING ROD
394	15-02-2026	Part of : SUKHDEV VIHAR OKHLA	1556	Other Outage	Unplanned Outage	15-02-2026	09:51	15-02-2026	10:35	0:44	0.000513	HT SYSTEM FAULT
395	15-02-2026	Part of : BLOCK B SHAHEEN BAGH JASOLA VIHAR	651	Other Outage	Planned Outage	15-02-2026	10:45	15-02-2026	11:43	0:58	0.000564	REPLACEMENT OF GAS KIT AND OIL SEAL
396	16-02-2026	Part of : MUJEEB BAGH JAMIA NAGAR OKHLA	4908	Other Outage	Unplanned Outage	16-02-2026	19:00	16-02-2026	19:21	0:21	0.000467	FAULT IN HT O/H CIRCUIT
397	16-02-2026	Part of : POCKET 7 JASOLA VIHAR	224	Other Outage	Planned Outage	16-02-2026	10:38	16-02-2026	11:04	0:26	0.000144	REPLACEMENT OF GAS KIT AND OIL SEAL
398	16-02-2026	Part of : POCKET 12 JASOLA VIHAR	216	Other Outage	Planned Outage	16-02-2026	13:07	16-02-2026	14:49	1:42	0.000567	REPLACEMENT OF GAS KIT AND OIL SEAL
399	16-02-2026	Part of : G-BLOCK SRINIVAS PURI	1242	Other Outage	Planned Outage	16-02-2026	10:56	16-02-2026	12:17	1:21	0.000675	REPLACEMENT OF HT BUSHING ROD
400	17-02-2026	Part of : NOOR NAGAR OKHLA	182	Other Outage	Planned Outage	17-02-2026	13:55	17-02-2026	15:22	1:27	0.000604	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
401	17-02-2026	Part of : BLOCK A SHAHEEN BAGH JASOLA VIHAR	955	Other Outage	Planned Outage	17-02-2026	10:30	17-02-2026	12:49	2:19	0.000772	REPLACEMENT OF LT BUSHING ROD
402	19-02-2026	Part of : Part of : CANAL COLONY OKHLA	1	Other Outage	Planned Outage	19-02-2026	12:57	19-02-2026	15:22	2:25	0.001007	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
403	19-02-2026	Part of : Part of : N-BLOCK ABUL FAZAL ENCLAVE PART 1 JAMIA NAGAR OKHLA	1094	Other Outage	Planned Outage	19-02-2026	11:05	19-02-2026	13:12	2:07	0.000529	REPLACEMENT OF HT BUSHING ROD
404	21-02-2026	Part of : NOOR NAGAR OKHLA	182	Other Outage	Planned Outage	21-02-2026	13:00	21-02-2026	14:49	1:49	0.001817	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
405	21-02-2026	Part of : BLOCK D PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	440	Other Outage	Planned Outage	21-02-2026	10:47	21-02-2026	12:13	1:26	0.000358	REPLACEMENT OF LT BUSHING ROD
406	23-02-2026	Part of : BLOCK B TAIMOOR NAGAR NEW FRIENDS COLONY	682	Other Outage	Planned Outage	23-02-2026	11:14	23-02-2026	11:44	0:30	0.000250	REPLACEMET OF HT BUSHING ROD
407	23-02-2026	Part of : BLOCK B SHAHEEN BAGH JASOLA VIHAR	653	Other Outage	Planned Outage	23-02-2026	10:29	23-02-2026	11:21	0:52	0.000433	REPLACEMENT OF GAS KIT AND OIL SEAL
408	23-02-2026	Part of : BLOCK A OKHLA	138	Other Outage	Planned Outage	23-02-2026	12:51	23-02-2026	13:57	1:06	0.000825	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
409	23-02-2026	Part of : VILLAGE JASOLA & JASOLA VIHAR	149	Other Outage	Planned Outage	23-02-2026	13:03	23-02-2026	14:05	1:02	0.000344	REPLACEMENT OF GAS KIT AND OIL SEAL
410	24-02-2026	Part of : APPOLLO HOSPITAL (HTC)	2	Other Outage	Planned Outage	24-02-2026	09:21	24-02-2026	12:22	3:01	0.002011	GUARD WIRE LACS INSTALLTION
411	24-02-2026	Part of : BLOCK B PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	432	Other Outage	Planned Outage	24-02-2026	10:43	24-02-2026	13:09	2:26	0.000608	REPLACEMENT OF HT BUSHING ROD
412	27-02-2026	Part of : H-BLOCK SRINIVAS PURI	214	Other Outage	Planned Outage	27-02-2026	11:01	27-02-2026	13:36	2:35	0.001292	REPLACEMENT OF HT BUSHING ROD
413	01-02-2026	Part of : POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA	54	Other Outage	Planned Outage	01-02-2026	10:58	01-02-2026	13:37	2:39	0.001325	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR
414	01-02-2026	Part of : BLOCK G KAILASH COLONY GREATER KAILASH	231	Other Outage	Planned Outage	01-02-2026	12:33	01-02-2026	14:40	2:07	0.001834	REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
415	01-02-2026	Part of : NEHRU PLACE	84	Other Outage	Planned Outage	01-02-2026	12:34	01-02-2026	14:41	2:07	0.001834	REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
416	02-02-2026	Part of : BLOCK E GREATER KAILASH I GREATER KAILASH,BLOCK D KAILASH COLONY GREATER KAILASH,BLOCK M KAILASH COLONY GREATER KAILASH,KAILASH KUNJ GREATER KAILASH	1131	Other Outage	Unplanned Outage	02-02-2026	22:01	02-02-2026	23:24	1:23	0.001695	FAULT IN HT CONSUMER PANEL (A-60 KAILASH COLONY)
417	02-02-2026	Part of : BLOCK W GREATER KAILASH I GREATER KAILASH,	229	Other Outage	Planned Outage	02-02-2026	11:03	02-02-2026	14:05	3:02	0.002629	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING TIGHTENEING OF NUT BOLT
418	03-02-2026	Part of : BLOCK M GREATER KAILASH I	92	Other Outage	Planned Outage	03-02-2026	11:12	03-02-2026	13:30	2:18	0.001993	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
419	04-02-2026	Part of : BLOCK A DAYANAND COLONY,GARI EXTENSION AMRITPURI,GARHI & SHERA MOHALLA GARHI EAST OF KAILASH	4254	Other Outage	Unplanned Outage	04-02-2026	10:25	04-02-2026	11:14	0:49	0.001308	CABLE FAULT
420	04-02-2026	Part of : NATIONAL PARK LAJPAT NAGA	7	Other Outage	Unplanned Outage	04-02-2026	10:57	04-02-2026	11:49	0:52	0.001184	FAULT IN HT CONSUMER PANEL (LSR COLLEGE)
421	04-02-2026	Part of : A-BLOCK APB GARHI EAST OF KAILASH	790	Other Outage	Planned Outage	04-02-2026	09:58	04-02-2026	11:42	1:44	0.001589	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
422	05-02-2026	Part of : NEHRU PLACE	886	Other Outage	Planned Outage	05-02-2026	11:02	05-02-2026	11:53	0:51	0.000737	CHECKING VALUE OF FENCING EARTHING,SUB STATION CLEANING
423	06-02-2026	Part of : BLOCK E GREATER KAILASH I GREATER KAILASH,BLOCK D KAILASH COLONY GREATER KAILASH,KAILASH KUNJ GREATER KAILASH,BLOCK M KAILASH COLONY GREATER KAILASH	1130	Other Outage	Unplanned Outage	06-02-2026	23:52	07-02-2026	00:32	0:40	0.000389	CABLE FAULT
424	06-02-2026	Part of : NEHRU PLACE	632	Other Outage	Unplanned Outage	06-02-2026	23:52	07-02-2026	00:45	0:53	0.000052	CABLE FAULT
425	06-02-2026	Part of : BLOCK G KAILASH HILL EAST OF KAILASH,	538	Other Outage	Planned Outage	06-02-2026	10:42	06-02-2026	11:30	0:48	0.000733	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
426	07-02-2026	Part of : DEVIKA TOWER NEHRU PLACE	5	Other Outage	Planned Outage	07-02-2026	11:15	07-02-2026	11:58	0:43	0.000621	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
427	08-02-2026	Part of : NEHRU PLACE	115	Other Outage	Planned Outage	08-02-2026	11:01	08-02-2026	11:50	0:49	0.000708	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
428	10-02-2026	Part of : BLOCK M GREATER KAILASH I GREATER KAILASH,	67	Other Outage	Planned Outage	10-02-2026	10:57	10-02-2026	11:55	0:58	0.000838	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
429	11-02-2026	Part of : BLOCK S GREATER KAILASH I	73	Other Outage	Planned Outage	11-02-2026	11:30	11-02-2026	11:55	0:25	0.000361	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
430	12-02-2026	Part of : CSP FLATS EAST OF KAILASH,A& C-BLOCK APB GARHI EAST OF KAILASH,C-BLOCK KAILASH HILL EAST OF KAILASH,E-BLOCK EAST OF KAILASH,GARHI JHARIA MARIA EAST OF KAILASH	429	Other Outage	Unplanned Outage	12-02-2026	06:10	12-02-2026	06:54	0:44	0.000213	CABLE FAULT
431	12-02-2026	Part of : BUILDING NO. 43 NEHRU PLACE (HT CONSUMER)	60	Other Outage	Unplanned Outage	12-02-2026	13:00	12-02-2026	13:58	0:58	0.000838	GAS REFILLING & REPAIRING OF RMU
432	12-02-2026	Part of : W-BLOCK GREATER KAILASH-1	152	Other Outage	Planned Outage	12-02-2026	11:11	12-02-2026	11:57	0:46	0.000664	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
433	14-02-2026	Part of : NEHRU PLACE,	137	Other Outage	Planned Outage	14-02-2026	11:03	14-02-2026	13:37	2:34	0.002224	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
434	14-02-2026	Part of : POCKET E OKHLA PHASE II OKHLA INDUSTRIAL AREA,	599	Other Outage	Planned Outage	14-02-2026	10:36	14-02-2026	14:02	3:26	0.002003	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
435	16-02-2026	Part of : OKHLA SABZEE MUNDI,OKHLA INDUSTRIAL AREA PH-3	762	Other Outage	Unplanned Outage	16-02-2026	14:45	16-02-2026	15:17	0:32	0.000000	TREE TOUCHING
436	16-02-2026	Part of : NEHRU PLACE	48	Other Outage	Planned Outage	16-02-2026	11:02	16-02-2026	11:59	0:57	0.000823	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
437	17-02-2026	Part of : NEHRU PLACE	33	Other Outage	Planned Outage	17-02-2026	11:03	17-02-2026	11:55	0:52	0.000751	MEASUREMET OF INSULATION RESISTANCE,REPLACEMET OF LUGS,SUB STATION CLEANING
438	17-02-2026	Part of : POCKET Z OKHLA PHASE II OKHLA INDUSTRIAL AREA	341	Other Outage	Planned Outage	17-02-2026	11:14	17-02-2026	14:04	2:50	0.000944	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
439	19-02-2026	Part of : PUMPING STATION, GK-1 (HTC)	0	Other Outage	Unplanned Outage	19-02-2026	23:34	20-02-2026	00:26	0:52	0.000945	FAULT IN HT CONSUMER PANEL (PUMPING STATION GK-1)
440	19-02-2026	Part of : PUMPING STATION, GK-1 (HTC)	0	Other Outage	Unplanned Outage	19-02-2026	01:39	19-02-2026	02:25	0:46	0.001548	HT SYSTEM FAULT
441	19-02-2026	Part of : Part of : NEHRU PLACE	73	Other Outage	Planned Outage	19-02-2026	11:11	19-02-2026	12:04	0:53	0.000766	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
442	20-02-2026	Part of : A APB-BLOCK GARHI EAST OF KAILASH	430	Other Outage	Unplanned Outage	20-02-2026	10:09	20-02-2026	10:52	0:43	0.000114	CABLE FAULT
443	21-02-2026	Part of : NEHRU PLACE	90	Other Outage	Planned Outage	21-02-2026	10:57	21-02-2026	11:57	1:00	0.000867	MEASUREMENT OF INSULATION RESISTANCE,REPLACEMENT OF LUGS
444	22-02-2026	Part of : POCKET Y SANJAY COLONY II OKHLA PHASE II OKHLA INDUSTRIAL AREA,	937	Other Outage	Planned Outage	22-02-2026	11:08	22-02-2026	13:14	2:06	0.000875	CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
445	23-02-2026	Part of : NEHRU PLACE	89	Other Outage	Unplanned Outage	23-02-2026	11:08	23-02-2026	12:26	1:18	0.001127	CONNECTION/DISCONNECTION OF HT/LT CABLES
446	23-02-2026	Part of : BLOCK M KAILASH COLONY GREATER KAILASH	313	Other Outage	Unplanned Outage	23-02-2026	11:05	23-02-2026	12:25	1:20	0.001156	CONNECTION/DISCONNECTION OF HT/LT CABLES
447	23-02-2026	Part of : NEHRU PLACE	11	Other Outage	Planned Outage	23-02-2026	10:54	23-02-2026	12:06	1:12	0.001040	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
448	24-02-2026	Part of : POCKET Z OKHLA INDUSTRIAL AREA PHASE-2,POCKET A& Y SANJAY COLONY-2 OKHLA INDUSTRIAL AREA PHASE-2,HARKESH NAGAR	4164	Other Outage	Unplanned Outage	24-02-2026	01:09	24-02-2026	01:49	0:40	0.000278	CABLE FAULT
449	24-02-2026	Part of : POCKET D & W OKHLA PHASE II OKHLA INDUSTRIAL AREA	722	Other Outage	Planned Outage	24-02-2026	11:23	24-02-2026	13:24	2:01	0.000672	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LUGS,SUB STATION CLEANING
450	25-02-2026	Part of : NEHRU PLACE	286	Other Outage	Planned Outage	25-02-2026	10:58	25-02-2026	12:01	1:03	0.000910	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
451	26-02-2026	Part of : KALASH ENCLAVE GREATER KAILASH,BLOCK N GREATER KAILASH I GREATER KAILASH,KAILASH COLONY GREATER KAILASH,BLOCK B ZAMRUPUR VILLAGE GREATER KAILASH	2228	Other Outage	Unplanned Outage	26-02-2026	13:25	26-02-2026	14:16	0:51	0.001048	CABLE FAULT
452	26-02-2026	Part of : VIKRAM VIHAR LAJPAT NAGAR IV LAJPAT NAGAR,BLOCK D LAJPAT NAGAR IV LAJPAT NAGAR,NATIONAL PARK LAJPAT NAGAR	1121	Other Outage	Unplanned Outage	26-02-2026	13:20	26-02-2026	14:15	0:55	0.000382	CABLE FAULT
453	28-02-2026	Part of : OKHLA SABZEE MUNDI,OKHLA INDUSTRIAL AREA PH-3	761	Other Outage	Unplanned Outage	28-02-2026	11:24	28-02-2026	12:07	0:43	0.000285	CABLE FAULT
454	28-02-2026	Part of : NEHRU PLACE	55	Other Outage	Planned Outage	28-02-2026	11:10	28-02-2026	11:52	0:42	0.000607	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
455	01-02-2026	Part of : AFCONS NCRTC RRTS (HTC), HPL STAFF COLONY JUNG PURA A	0	Other Outage	Unplanned Outage	01-02-2026	12:55	01-02-2026	13:25	0:30	0.000073	CABLE FAULT
456	01-02-2026	Part of : ISBT SARAI KALE KHAN, BLOCK A GANGA VIHAR SARAI KALE KHAN, DJB BEHLOLPUR (HTC), L&T NEAR POWER GRID (HTC), CNG FILLING STN (HTC)	13	Other Outage	Unplanned Outage	01-02-2026	02:24	01-02-2026	02:58	0:34	0.001105	FAULT IN HT CONSUMER PANEL (DJB)
457	01-02-2026	Part of : BLOCK A & B GANGA VIHAR SARAI KALE KHAN, ELECTRIC CREMATION GROUND (HTC), DTL BEHLOLPUR (HTC)	209	Other Outage	Unplanned Outage	01-02-2026	00:01	01-02-2026	00:58	0:57	0.000169	CABLE FAULT
458	02-02-2026	Part of : SUNLIGHT COLONY,	94	Other Outage	Unplanned Outage	02-02-2026	10:44	02-02-2026	13:06	2:22	0.003156	MAINTENANCE/REPAIR OF RMU
459	02-02-2026	Part of : BLOCK B SOUTH EXTENSION PART 1,	472	Other Outage	Planned Outage	02-02-2026	11:24	02-02-2026	14:36	3:12	0.001600	REPLACEMENT OF HT BUSHING ROD
460	05-02-2026	Part of : ISBT SARAI KALE KHAN	4	Other Outage	Planned Outage	05-02-2026	12:52	05-02-2026	14:53	2:01	0.001849	CONDUCTOR REPLACEMENT PER SPAN
461	05-02-2026	Part of : ZAFAR NAGAR KOTLA MUBARAKPUR SOUTH EXTENSION PART 1	546	Other Outage	Planned Outage	05-02-2026	11:58	05-02-2026	16:09	4:11	0.000976	REPLACEMENT OF HT BUSHING ROD
462	05-02-2026	Part of : BLOCK A SOUTH EXTENSION PART 1	488	Other Outage	Planned Outage	05-02-2026	12:00	05-02-2026	14:28	2:28	0.001644	REPLACEMENT OF HT BUSHING INULATOR
463	05-02-2026	Part of : JAL VIHAR	2	Other Outage	Planned Outage	05-02-2026	11:57	05-02-2026	13:59	2:02	0.000271	REPLACEMENT OF HT BUSHING ROD
464	05-02-2026	Part of : PRAGATI MAIDAN	18	Other Outage	Planned Outage	05-02-2026	12:03	05-02-2026	14:25	2:22	0.001183	REPLACEMENT OF HT BUSHING ROD
465	07-02-2026	Part of : PRAGATI MAIDAN	36	Other Outage	Planned Outage	07-02-2026	11:05	07-02-2026	14:02	2:57	0.001475	REPLACEMENT OF HT BUSHING ROD
466	07-02-2026	Part of : BLOCK D SOUTH EXTENSION PART 1	414	Other Outage	Planned Outage	07-02-2026	11:06	07-02-2026	14:19	3:13	0.001072	REPLACEMENT OF HT BUSHING ROD
467	09-02-2026	Part of : PRAGATI MAIDAN	21	Other Outage	Planned Outage	09-02-2026	11:41	09-02-2026	14:46	3:05	0.001542	REPLACEMENT OF HT BUSHING ROD
468	09-02-2026	Part of : BLOCK G SOUTH EXTENSION PART 1	45	Other Outage	Planned Outage	09-02-2026	11:37	09-02-2026	14:44	3:07	0.002078	REPLACEMENT OF HT BUSHING ROD
469	10-02-2026	Part of : BLOCK C DEFENCE COLONY,DEFENCE COLONY,BLOCK A DEFENCE COLONY	1825	Other Outage	Unplanned Outage	10-02-2026	17:00	10-02-2026	17:33	0:33	0.000614	CABLE FAULT
470	10-02-2026	Part of : SANT NAGAR SUNDAR NAGAR,	10	Other Outage	Planned Outage	10-02-2026	11:41	10-02-2026	14:15	2:34	0.000428	REPLACEMENT OF LT BUSHING ROD
471	11-02-2026	Part of : TYAGRAJ STADIUM (HTC)	1	Other Outage	Unplanned Outage	11-02-2026	12:35	11-02-2026	12:50	0:15	0.000000	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
472	11-02-2026	Part of : BLOCK B SARAI KALE KHAN,BLOCK D SARAI KALE KHAN VILLAGE SARAI KALE KHAN,BLOCK A GANGA VIHAR SARAI KALE KHAN	1751	Other Outage	Unplanned Outage	11-02-2026	16:07	11-02-2026	16:46	0:39	0.000028	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
473	13-02-2026	Part of : PWD UNDER PASS NEAR NEW SUPREEM COURT (HTC)	1	Other Outage	Planned Outage	13-02-2026	10:56	13-02-2026	13:48	2:52	0.001433	REPLACEMET OF HT BUSHING ROD
474	15-02-2026	Part of : PRAGATI VIHAR	2	Other Outage	Planned Outage	15-02-2026	10:57	15-02-2026	12:58	2:01	0.000605	REPLACEMENT OF GAS KIT AND OIL SEAL
475	16-02-2026	Part of : PRAGATI MAIDAN	17	Other Outage	Planned Outage	16-02-2026	12:09	16-02-2026	14:55	2:46	0.001383	REPLACEMENT OF HT BUSHING ROD
476	23-02-2026	Part of : BLOCK N SEWA NAGAR	1165	Other Outage	Planned Outage	23-02-2026	10:44	23-02-2026	14:59	4:15	0.002833	REPLACEMET OF HT BUSHING ROD
477	23-02-2026	Part of : BLOCK B & D SARAI KALE KHAN VILLAGE,BLOCK A GANGA VIHAR SARAI KALE KHAN	2845	Other Outage	Planned Outage	23-02-2026	11:26	23-02-2026	13:28	2:02	0.001356	GUARD WIRES SAGGING
478	25-02-2026	Part of : BLOCK 18 INSTITUTIONAL AREA LODI COLONY,LODI COLONY,MEHARCHAND MARKET,LODHI ROAD QUARTERS LODI COLONY	1201	Other Outage	Unplanned Outage	25-02-2026	13:07	25-02-2026	13:57	0:50	0.000000	CABLE DAMAGED BY OUTSIDE AGENCY (UNKNOWN)
479	25-02-2026	Part of : TYAGRAJ STADIUM (HTC)	1	Other Outage	Unplanned Outage	25-02-2026	12:58	25-02-2026	13:47	0:49	0.000000	CABLE FAULT
480	26-02-2026	Part of : HTC:SOOCHNA BHAWAN, CGO COMPLEX	0	Other Outage	Unplanned Outage	26-02-2026	13:16	26-02-2026	13:59	0:43	0.000000	CABLE FAULT
481	27-02-2026	Part of : BLOCK A NIZAMUDDIN WEST	984	Other Outage	Unplanned Outage	27-02-2026	13:11	27-02-2026	13:24	0:13	0.000090	ATTENDING WEAK POINTS/HOT SPOT
482	27-02-2026	Part of : RAILWAY COLONY PRAGATI MAIDAN	16	Other Outage	Planned Outage	27-02-2026	11:07	27-02-2026	13:33	2:26	0.001217	REPLACEMENT OF HT BUSHING ROD
483	02-02-2026	Part of : CGHS DISPENSARY SEC.-5 RKP	1	Other Outage	Planned Outage	02-02-2026	11:18	02-02-2026	13:46	2:28	0.000247	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
484	03-02-2026	Part of : DHAULA KUAN ENCLAVE I	3	Other Outage	Planned Outage	03-02-2026	12:17	03-02-2026	15:09	2:52	0.000191	REPLACEMENT OF FAULTY END BOX
485	03-02-2026	Part of : RBI OFFICERS COLONY VASANT VIHAR	228	Other Outage	Planned Outage	03-02-2026	10:45	03-02-2026	13:56	3:11	0.001592	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
486	04-02-2026	Part of : H-BLOCK NANAKPURA MOTI BAGH SOUTH	749	Other Outage	Planned Outage	04-02-2026	13:57	04-02-2026	15:22	1:25	0.000354	DT REPLACEMENT
487	04-02-2026	Part of : I-BLOCK MOTI BAGH SOUTH	48	Other Outage	Planned Outage	04-02-2026	14:31	04-02-2026	16:35	2:04	0.000413	DT REPLACEMENT
488	04-02-2026	Part of : BASANT LOK VASANT VIHAR	187	Other Outage	Planned Outage	04-02-2026	10:47	04-02-2026	13:41	2:54	0.001450	INSTALLATION OF HT BOOTS,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
489	05-02-2026	Part of : NIVEDITA KUNJ SECTOR 10 RAMAKRISHNA PURAM	1026	Other Outage	Planned Outage	05-02-2026	12:26	05-02-2026	14:07	1:41	0.000421	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
490	05-02-2026	Part of : BLOCK B VASANT VIHAR	1	Other Outage	Planned Outage	05-02-2026	10:58	05-02-2026	14:13	3:15	0.001354	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
491	07-02-2026	Part of : MUNIRKA	1179	Other Outage	Planned Outage	07-02-2026	10:30	07-02-2026	13:43	3:13	0.002681	INSTALLATION OF HT BOOTS,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
492	09-02-2026	Part of : BLOCK E ANAND NIKETAN	308	Other Outage	Planned Outage	09-02-2026	14:15	09-02-2026	15:19	1:04	0.000000	ACB REPLACEMENT PER ACB
493	09-02-2026	Part of : MUNIRKA ENCLAVE	1157	Other Outage	Planned Outage	09-02-2026	11:12	09-02-2026	14:11	2:59	0.001740	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER
494	09-02-2026	Part of : JHARERA VILLAGE ASMARA LINES DELHI CANTONMENT	632	Other Outage	Planned Outage	09-02-2026	11:12	09-02-2026	13:49	2:37	0.000959	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
495	10-02-2026	Part of : SECTOR 5 RAMAKRISHNA PURAM,RBI COLONY SECTOR 6 RAMAKRISHNA PURAM,SONIA GANDHI CAMP SECTOR 6 RAMAKRISHNA PURAM,SECTOR 6 RAMAKRISHNA PURAM,EKTA VIHAR SECTOR 6 RAMAKRISHNA PURAM	1821	Other Outage	Unplanned Outage	10-02-2026	22:55	10-02-2026	23:54	0:59	0.000441	CABLE FAULT
496	10-02-2026	Part of : POCKET 2 SECTOR 2 DWARKA,	7	Other Outage	Planned Outage	10-02-2026	12:09	10-02-2026	15:10	3:01	0.000302	GUARD WIRES SAGGING PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
497	10-02-2026	Part of : BLOCK CA MUNIRKA,	89	Other Outage	Planned Outage	10-02-2026	10:36	10-02-2026	13:25	2:49	0.001408	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
498	11-02-2026	Part of : BASANT GAON VASANT VIHAR	1166	Other Outage	Planned Outage	11-02-2026	11:44	11-02-2026	13:36	1:52	0.001244	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
499	11-02-2026	Part of : SUBROTO PARK	4	Other Outage	Planned Outage	11-02-2026	12:05	11-02-2026	14:17	2:12	0.000147	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF HT BUSHING ROD
500	11-02-2026	Part of : N.I.F.P.H. FAMILY PLANNING MUNIRKA (HT CONSUMER)	1	Other Outage	Planned Outage	11-02-2026	10:51	11-02-2026	13:28	2:37	0.000872	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER
501	12-02-2026	Part of : MUNIRKA ENCLAVE	709	Other Outage	Planned Outage	12-02-2026	11:07	12-02-2026	12:56	1:49	0.000000	LT CIRCUIT MAINTENANCE
502	12-02-2026	Part of : CAPITAL COURT MUNIRKA (HT CONSUMER)	1	Other Outage	Planned Outage	12-02-2026	11:22	12-02-2026	13:38	2:16	0.000944	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
503	13-02-2026	Part of : MUNIRKA	896	Other Outage	Planned Outage	13-02-2026	12:02	13-02-2026	13:57	1:55	0.000000	CONDUCTOR REPLACEMENT PER SPAN,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
504	13-02-2026	Part of : SECTOR 1 RAMAKRISHNA PURAM	1	Other Outage	Planned Outage	13-02-2026	11:02	13-02-2026	13:41	2:39	0.000353	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
505	13-02-2026	Part of : JHARERA VILLAGE ASMARA LINES DELHI CANTONMENT	429	Other Outage	Planned Outage	13-02-2026	11:00	13-02-2026	13:23	2:23	0.000636	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
506	14-02-2026	Part of : HTC:NHSRC,NIHFW CAMPUS, MUNIRKA	1	Other Outage	Planned Outage	14-02-2026	12:06	14-02-2026	13:41	1:35	0.000317	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
507	14-02-2026	Part of : HTC:DELHI KARNATKA SANGH SEC-12, R.K.P.	1	Other Outage	Planned Outage	14-02-2026	11:14	14-02-2026	12:57	1:43	0.000143	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
508	15-02-2026	Part of : BASANT LOK VASANT VIHAR,BLOCK A VASANT VIHAR	774	Other Outage	Unplanned Outage	15-02-2026	17:42	15-02-2026	18:08	0:26	0.000253	CABLE FAULT
509	16-02-2026	Part of : JHARERA VILLAGE ASMARA LINES DELHI CANTONMENT	470	Other Outage	Planned Outage	16-02-2026	12:13	16-02-2026	13:49	1:36	0.000427	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF HT BUSHING ROD
510	16-02-2026	Part of : OLD JNU CAMPUS,NEAR BABA G MARG	1	Other Outage	Planned Outage	16-02-2026	11:35	16-02-2026	14:05	2:30	0.000625	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
511	18-02-2026	Part of : BLOCK BH MUNIRKA,	863	Other Outage	Planned Outage	18-02-2026	15:14	18-02-2026	17:08	1:54	0.002533	CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
512	18-02-2026	Part of : BLOCK H NANAKPURA MOTI BAGH SOUTH,	475	Other Outage	Planned Outage	18-02-2026	10:58	18-02-2026	12:09	1:11	0.000276	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
513	20-02-2026	Part of : BASANT LOK VASANT VIHAR	161	Other Outage	Planned Outage	20-02-2026	14:51	20-02-2026	16:01	1:10	0.001167	DT REPLACEMENT
514	20-02-2026	Part of : PRIYA CINEMA (HT CONSUMER), VASANT LOK	1	Other Outage	Planned Outage	20-02-2026	11:43	20-02-2026	13:35	1:52	0.000560	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD
515	20-02-2026	Part of : HOTEL VASANT CONTINENTAL (HT CONSUMER)	1	Other Outage	Planned Outage	20-02-2026	11:43	20-02-2026	13:34	1:51	0.000463	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
516	20-02-2026	Part of : RAMA COLONY RAMAKRISHNA PURAM	191	Other Outage	Planned Outage	20-02-2026	11:20	20-02-2026	14:37	3:17	0.001094	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
517	20-02-2026	Part of : BASANT GAON VASANT VIHAR	1166	Other Outage	Planned Outage	20-02-2026	11:55	20-02-2026	15:56	4:01	0.001941	DT REPLACEMENT
518	21-02-2026	Part of : AGI BHAWAN VASANT VIHAR (HTC)	1	Other Outage	Planned Outage	21-02-2026	14:31	21-02-2026	15:48	1:17	0.000321	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
519	21-02-2026	Part of : MIZORAM HOUSE VASANT VIHAR (HTC)	1	Other Outage	Planned Outage	21-02-2026	11:52	21-02-2026	13:12	1:20	0.000333	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
520	21-02-2026	Part of : NIVEDITA KUNJ SECTOR 10 RAMAKRISHNA PURAM	128	Other Outage	Planned Outage	21-02-2026	11:14	21-02-2026	12:54	1:40	0.000556	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD
521	22-02-2026	Part of : HTC:CPWD WEST BLOCK, R.K.PURAM	0	Other Outage	Unplanned Outage	22-02-2026	07:48	22-02-2026	08:27	0:39	0.000139	FAULT IN HT CONSUMER PANEL (CPWD)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
522	23-02-2026	Part of : VASANT VIHAR CLUB	1	Other Outage	Planned Outage	23-02-2026	14:09	23-02-2026	15:39	1:30	0.000375	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING
523	23-02-2026	Part of : BLOCK C MOTI BAGH SOUTH MARKET	458	Other Outage	Planned Outage	23-02-2026	14:06	23-02-2026	15:49	1:43	0.001717	HT SLEEVE INSTALLATION
524	23-02-2026	Part of : FSI MUNIRAKA (HT CONSUMER)	1	Other Outage	Planned Outage	23-02-2026	11:42	23-02-2026	13:06	1:24	0.000280	REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
525	23-02-2026	Part of : BLOCK G NANAKPURA MOTI BAGH SOUTH	265	Other Outage	Planned Outage	23-02-2026	10:19	23-02-2026	13:26	3:07	0.000519	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACMET OF HT BUSHING ROD
526	24-02-2026	Part of : DHAULA KUAN ENCLAVE-1	3	Other Outage	Planned Outage	24-02-2026	16:01	24-02-2026	17:02	1:01	0.000085	DT REPLACEMENT
527	24-02-2026	Part of : SECTOR 8 SHANTI NIKETAN	41	Other Outage	Planned Outage	24-02-2026	14:28	24-02-2026	16:29	2:01	0.000202	DT REPLACEMENT
528	25-02-2026	Part of : BLOCK B ANAND NIKETAN	279	Other Outage	Planned Outage	25-02-2026	14:50	25-02-2026	15:33	0:43	0.000215	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
529	25-02-2026	Part of : NIRYAT BHAWAN VASANT VIHAR (HTC)	1	Other Outage	Planned Outage	25-02-2026	11:07	25-02-2026	12:04	0:57	0.000317	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACMET OF HT BUSHING ROD
530	25-02-2026	Part of : BLOCK C WEST END GREEN	154	Other Outage	Planned Outage	25-02-2026	10:01	25-02-2026	12:11	2:10	0.000361	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
531	26-02-2026	Part of : MUNIRKA ENCLAVE MUNIRKA,	629	Other Outage	Planned Outage	26-02-2026	12:01	26-02-2026	14:08	2:07	0.000000	3PH DB REPLACEMENT,CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
532	26-02-2026	Part of : WEST BLOCK RAMAKRISHNA PURAM,	49	Other Outage	Planned Outage	26-02-2026	12:36	26-02-2026	14:43	2:07	0.000353	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD,REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
533	27-02-2026	Part of : SECTOR 2 RAMAKRISHNA PURAM	490	Other Outage	Unplanned Outage	27-02-2026	14:38	27-02-2026	14:54	0:16	0.000089	SERVICE LINE REPLACEMENT
534	27-02-2026	Part of : H-BLOCK NANAKPURA MOTI BAGH SOUTH	375	Other Outage	Planned Outage	27-02-2026	10:58	27-02-2026	11:35	0:37	0.000113	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
535	27-02-2026	Part of : BA-BLOCK MUNIRKA	415	Other Outage	Planned Outage	27-02-2026	11:49	27-02-2026	15:03	3:14	0.003233	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
536	28-02-2026	Part of : MUNIRKA	900	Other Outage	Planned Outage	28-02-2026	10:55	28-02-2026	11:52	0:57	0.000000	LT CIRCUIT MAINTENANCE
537	28-02-2026	Part of : MEGHALAYA BHAWAN (HT CONSUMER)	1	Other Outage	Planned Outage	28-02-2026	10:43	28-02-2026	12:37	1:54	0.000475	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD
538	28-02-2026	Part of : MUNIRKA	1019	Other Outage	Planned Outage	28-02-2026	10:57	28-02-2026	12:44	1:47	0.000000	LT CIRCUIT MAINTENANCE
539	28-02-2026	Part of : MUNIRKA ENCLAVE	629	Other Outage	Planned Outage	28-02-2026	12:21	28-02-2026	16:22	4:01	0.004017	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
540	02-02-2026	Part of : ROCKY AREA STONE QUARRIES SAINIK FARM,	62	Other Outage	Planned Outage	02-02-2026	11:25	02-02-2026	14:08	2:43	0.004528	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING ROD,REPLACMET OF LUGS,TIGHTENEING OF NUT BOLT
541	02-02-2026	Part of : BLOCK N SOUTH SAINIK FARM SAINIK FARM,	102	Other Outage	Planned Outage	02-02-2026	11:16	02-02-2026	14:07	2:51	0.004750	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING INSULATOR,REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS,TIGHTENEING OF NUT BOLT
542	02-02-2026	Part of : JAHANPANA MONUMENT MALVIYA NAGAR,	1	Other Outage	Planned Outage	02-02-2026	09:58	02-02-2026	13:02	3:04	0.000051	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
543	02-02-2026	Part of : KALU SARAI,	268	Other Outage	Planned Outage	02-02-2026	09:59	02-02-2026	12:50	2:51	0.000000	INSTALLATION OF HT BOOTS,REPLACEMET OF HT BUSHING ROD
544	02-02-2026	Part of : BHAVISHYANIDHI ENCLAVE MALVIYA NAGAR,	42	Other Outage	Planned Outage	02-02-2026	09:59	02-02-2026	12:59	3:00	0.000000	REPLACEMENT OF LT BUSHING ROD
545	03-02-2026	Part of : SECTOR 1 & 3 PUSHPA VIHAR,BLOCK H SAKET,KUTUB GOLF COURSE LADO SARAI	1628	Other Outage	Unplanned Outage	03-02-2026	23:52	04-02-2026	00:35	0:43	0.000211	CABLE FAULT
546	03-02-2026	Part of : BLOCK N SOUTH SAINIK FARM	40	Other Outage	Planned Outage	03-02-2026	13:49	03-02-2026	16:03	2:14	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
547	03-02-2026	Part of : BLOCK N SOUTH SAINIK FARM	19	Other Outage	Planned Outage	03-02-2026	10:54	03-02-2026	14:25	3:31	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
548	03-02-2026	Part of : BLOCK 3 SARVAPRIYA VIHAR	295	Other Outage	Planned Outage	03-02-2026	10:01	03-02-2026	12:56	2:55	0.000000	REPLACEMENT OF HT BUSHING ROD
549	04-02-2026	Part of : BLOCK 7 SARVAPRIYA VIHAR	236	Other Outage	Planned Outage	04-02-2026	10:07	04-02-2026	12:47	2:40	0.000000	REPLACEMET OF HT BUSHING ROD
550	04-02-2026	Part of : SAIYAD UL AJAIB VILLAGE SAINIK FARM	164	Other Outage	Planned Outage	04-02-2026	11:16	04-02-2026	14:14	2:58	0.004944	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN,REPLACEMENT OF CROSS-ARMS AND POLES,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
551	05-02-2026	Part of : PHASE II SHEIKH SARAI	2447	Other Outage	Planned Outage	05-02-2026	12:32	05-02-2026	13:19	0:47	0.000000	REPLACEMET OF HT BUSHING ROD
552	05-02-2026	Part of : BLOCK E SAINIK FARM	85	Other Outage	Planned Outage	05-02-2026	11:19	05-02-2026	13:50	2:31	0.004194	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS
553	05-02-2026	Part of : BLOCK F KHANPUR COLONY	31	Other Outage	Planned Outage	05-02-2026	11:00	05-02-2026	13:47	2:47	0.004639	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT BUSHING ROD
554	05-02-2026	Part of : BLOCK 13 SARVAPRIYA VIHAR	203	Other Outage	Planned Outage	05-02-2026	10:13	05-02-2026	12:23	2:10	0.000000	REPLACEMENT OF LT BUSHING INSULATOR
555	06-02-2026	Part of : BLOCK H NEB SARAI SAINIK FARM,	64	Other Outage	Planned Outage	06-02-2026	11:01	06-02-2026	13:59	2:58	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,TIGHTENEING OF NUT BOLT
556	06-02-2026	Part of : BLOCK H NEB SARAI SAINIK FARM,	59	Other Outage	Planned Outage	06-02-2026	10:59	06-02-2026	14:00	3:01	0.005028	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
557	06-02-2026	Part of : KALU SARAI,	263	Other Outage	Planned Outage	06-02-2026	10:12	06-02-2026	12:17	2:05	0.000000	REPLACEMENT OF LT BUSHING ROD
558	07-02-2026	Part of : JAGDAMBA CAMP SHEIKH SARAI	884	Other Outage	Planned Outage	07-02-2026	10:59	07-02-2026	12:54	1:55	0.000000	REPLACEMENT OF HT BUSHING ROD
559	07-02-2026	Part of : BLOCK A SHIVALIK MALVIYA NAGAR	1084	Other Outage	Planned Outage	07-02-2026	11:12	07-02-2026	13:51	2:39	0.000000	REPLACEMENT OF HT BUSHING ROD
560	07-02-2026	Part of : SAINIK FARM	48	Other Outage	Planned Outage	07-02-2026	10:46	07-02-2026	13:24	2:38	0.004389	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
561	07-02-2026	Part of : SAINIK FARMS COLONY	37	Other Outage	Planned Outage	07-02-2026	10:51	07-02-2026	14:36	3:45	0.006250	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
562	09-02-2026	Part of : SECTOR 3 PUSHPA VIHAR, ARMY SAINIK CAMP (HTC), COLLAGE OF PHARMACY (HTC)	717	Other Outage	Unplanned Outage	09-02-2026	00:31	09-02-2026	01:35	1:04	0.000383	CABLE FAULT
563	09-02-2026	Part of : BLOCK G 6 MALVIYA NAGAR	551	Other Outage	Planned Outage	09-02-2026	11:25	09-02-2026	12:43	1:18	0.000000	REPLACEMENT OF HT BUSHING ROD
564	09-02-2026	Part of : BLOCK H NEB SARAI SAINIK FARM	90	Other Outage	Planned Outage	09-02-2026	10:59	09-02-2026	13:49	2:50	0.004722	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
565	09-02-2026	Part of : BLOCK E SAINIK FARM	57	Other Outage	Planned Outage	09-02-2026	11:03	09-02-2026	13:50	2:47	0.004639	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
566	09-02-2026	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	173	Other Outage	Planned Outage	09-02-2026	09:57	09-02-2026	12:50	2:53	0.000000	REPLACEMENT OF HT BUSHING ROD
567	10-02-2026	Part of : BLOCK C MALVIYA NAGAR,	761	Other Outage	Planned Outage	10-02-2026	11:14	10-02-2026	12:03	0:49	0.000000	REPLACEMET OF HT BUSHING ROD
568	10-02-2026	Part of : BLOCK A SARVODYA ENCLAVE,	253	Other Outage	Planned Outage	10-02-2026	10:25	10-02-2026	12:50	2:25	0.000000	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT BUSHING ROD
569	11-02-2026	Part of : SECTOR 7 PUSHPA VIHAR	1	Other Outage	Planned Outage	11-02-2026	11:09	11-02-2026	13:32	2:23	0.003972	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
570	11-02-2026	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE	241	Other Outage	Planned Outage	11-02-2026	10:02	11-02-2026	12:53	2:51	0.000000	REPLACEMENT OF HT BUSHING ROD
571	11-02-2026	Part of : HAUZ RANI MALVIYA NAGAR	1618	Other Outage	Planned Outage	11-02-2026	10:52	11-02-2026	13:54	3:02	0.000000	REPLACEMENT OF HT BUSHING ROD
572	12-02-2026	Part of : A 1-BLOCK NEB SARAI,POCKET E BEES SUTRI HARIJAN BASTI,B & D-BLOCK FREEDOM FIGHTER VIHAR,D-BLOCK PARYAVARAN COMPLEX SAINIK FARM	598	Other Outage	Unplanned Outage	12-02-2026	09:25	12-02-2026	10:15	0:50	0.001295	CABLE FAULT
573	12-02-2026	Part of : J-BLOCK SAINIK FARM	16	Other Outage	Planned Outage	12-02-2026	13:10	12-02-2026	15:49	2:39	0.004417	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
574	12-02-2026	Part of : CHIRAG DELHI	565	Other Outage	Planned Outage	12-02-2026	11:20	12-02-2026	14:04	2:44	0.000000	REPLACEMENT OF HT BUSHING ROD
575	12-02-2026	Part of : E-BLOCK SAINIK FARM	40	Other Outage	Planned Outage	12-02-2026	11:36	12-02-2026	13:42	2:06	0.003500	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
576	12-02-2026	Part of : BHAVISHYANIDHI ENCLAVE MALVIYA NAGAR	63	Other Outage	Planned Outage	12-02-2026	10:03	12-02-2026	12:55	2:52	0.000000	REPLACEMENT OF HT BUSHING ROD
577	13-02-2026	Part of : BLOCK H PANCHSHEEL VIHAR SHEIKH SARAI VILLAGE	1968	Other Outage	Planned Outage	13-02-2026	12:26	13-02-2026	15:45	3:19	0.000000	REPLACEMET OF HT BUSHING ROD
578	13-02-2026	Part of : SAINIK FARM	39	Other Outage	Planned Outage	13-02-2026	10:57	13-02-2026	13:51	2:54	0.004833	CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
579	13-02-2026	Part of : SAINIK FARM	95	Other Outage	Planned Outage	13-02-2026	10:56	13-02-2026	13:50	2:54	0.004833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
580	13-02-2026	Part of : BLOCK 3 SARVAPRIYA VIHAR	273	Other Outage	Planned Outage	13-02-2026	09:58	13-02-2026	13:04	3:06	0.000000	REPLACEMENT OF LT BUSHING ROD
581	14-02-2026	Part of : SAINIK FARM,	2	Other Outage	Planned Outage	14-02-2026	13:29	14-02-2026	16:13	2:44	0.004556	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
582	14-02-2026	Part of : PANCHSHEEL EXTENSION MALVIYA NAGAR,	1796	Other Outage	Planned Outage	14-02-2026	13:35	14-02-2026	15:54	2:19	0.000000	REPLACEMET OF HT BUSHING ROD
583	14-02-2026	Part of : SAINIK FARM,	60	Other Outage	Planned Outage	14-02-2026	10:49	14-02-2026	14:04	3:15	0.005417	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
584	15-02-2026	Part of : BLOCK E SAKET,BLOCK D PARYAVARAN COMPLEX SAINIK FARM	36	Other Outage	Unplanned Outage	15-02-2026	05:19	15-02-2026	06:17	0:58	0.000177	CABLE DAMAGED BY OUTSIDE AGENCY (DMRC)
585	15-02-2026	Part of : NAI BASTI LADO SARAI,CHHATRI WALA KUNA LADO SARAI	3225	Other Outage	Unplanned Outage	15-02-2026	05:18	15-02-2026	06:23	1:05	0.000469	CABLE DAMAGED BY OUTSIDE AGENCY (DMRC)
586	15-02-2026	Part of : SAIYAD UL AJAIB EXTENSION SAINIK FARM,BUTTERFLY PARK QILA RAI PITHORA SAINIK FARM	1757	Other Outage	Unplanned Outage	15-02-2026	05:18	15-02-2026	06:23	1:05	0.000578	CABLE DAMAGED BY OUTSIDE AGENCY (DMRC)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
587	16-02-2026	Part of : B-BLOCK NAVJIVAN VIHAR MALVIYA NAGAR	139	Other Outage	Planned Outage	16-02-2026	09:57	16-02-2026	10:06	0:09	0.000000	LT CIRCUIT MAINTENANCE
588	16-02-2026	Part of : BLOCK 13 SARVAPRIYA VIHAR	119	Other Outage	Planned Outage	16-02-2026	10:00	16-02-2026	11:09	1:09	0.000000	REPLACEMENT OF HT BUSHING ROD
589	16-02-2026	Part of : B-BLOCK FREEDOM FIGHTER VIHAR SAINIK FARM,A 1-BLOCK NEB SARAI SAINIK FARM	2399	Other Outage	Planned Outage	16-02-2026	13:18	16-02-2026	15:38	2:20	0.003889	CHECKING VALUE OF FENCING EARTHING,TIGHTENEING OF NUT BOLT
590	16-02-2026	Part of : H-BLOCK NEB SARAI SAINIK FARM	64	Other Outage	Planned Outage	16-02-2026	10:42	16-02-2026	12:48	2:06	0.001575	REPLACEMENT OF HT BUSHING ROD
591	17-02-2026	Part of : POKET E BEES SUTRI HARIJAN BASTI SAINIK FARM, BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM	2496	Other Outage	Unplanned Outage	17-02-2026	12:31	17-02-2026	13:17	0:46	0.001278	SAFEGUARDING OF CABLE
592	17-02-2026	Part of : KALU SARAI	275	Other Outage	Planned Outage	17-02-2026	11:10	17-02-2026	13:07	1:57	0.000000	REPLACEMENT OF LT BUSHING ROD
593	17-02-2026	Part of : BLOCK C MALVIYA NAGAR	497	Other Outage	Planned Outage	17-02-2026	10:58	17-02-2026	11:59	1:01	0.000000	REPLACEMET OF HT BUSHING ROD
594	17-02-2026	Part of : NEW COLONY KHIDKI EXTENSION MALVIYA NAGAR	1527	Other Outage	Planned Outage	17-02-2026	10:51	17-02-2026	14:05	3:14	0.000000	REPLACEMET OF HT BUSHING ROD
595	17-02-2026	Part of : BLOCK D PARYAVARAN COMPLEX SAINIK FARM	1	Other Outage	Planned Outage	17-02-2026	10:51	17-02-2026	13:19	2:28	0.004111	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
596	18-02-2026	Part of : KUTUB GOLF COURSE LADO SARAI,SETH SARAI MEHRAULI,NAI BASTI LADO SARAI,BLOCK C QUTAB INSTITUTIONAL AREA,	933	Other Outage	Planned Outage	18-02-2026	11:57	18-02-2026	12:08	0:11	0.000306	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,REPLACEMENT OF CROSS-ARMS AND POLES
597	18-02-2026	Part of : DISTRICT PARK PHASE I SHEIKH SARAI,	1671	Other Outage	Planned Outage	18-02-2026	11:19	18-02-2026	13:03	1:44	0.000000	REPLACEMET OF HT BUSHING ROD
598	18-02-2026	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE,	236	Other Outage	Planned Outage	18-02-2026	09:59	18-02-2026	12:58	2:59	0.000000	REPLACEMENT OF LT BUSHING ROD
599	19-02-2026	Part of : Part of : SHEIKH SARAI PHASE-2	2447	Other Outage	Planned Outage	19-02-2026	12:06	19-02-2026	15:03	2:57	0.000000	REPLACEMENT OF HT BUSHING ROD
600	19-02-2026	Part of : Part of : E-BLOCK SAINIK FARM,F-BLOCK KHANPUR COLONY	616	Other Outage	Planned Outage	19-02-2026	10:58	19-02-2026	13:45	2:47	0.004639	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
601	19-02-2026	Part of : Part of : SAINIK FARMS COLONY	36	Other Outage	Planned Outage	19-02-2026	11:27	19-02-2026	13:46	2:19	0.003861	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
602	19-02-2026	Part of : Part of : ADHCHINI VILLAGE QUTAB ENCLAVE	151	Other Outage	Planned Outage	19-02-2026	10:06	19-02-2026	12:47	2:41	0.000000	REPLACEMENT OF HT BUSHING ROD
603	19-02-2026	Part of : Part of : A-BLOCK GITANJALI ENCLAVE MALVIYA NAGAR	149	Other Outage	Planned Outage	19-02-2026	09:58	19-02-2026	12:00	2:02	0.000000	LT CIRCUIT MAINTENANCE
604	20-02-2026	Part of : SARVODYA ENCLAVE	342	Other Outage	Planned Outage	20-02-2026	13:58	20-02-2026	16:22	2:24	0.000000	REPLACEMET OF HT BUSHING ROD
605	20-02-2026	Part of : BLOCK E SAINIK FARM	4	Other Outage	Planned Outage	20-02-2026	11:38	20-02-2026	13:50	2:12	0.001283	REPLACEMET OF HT BUSHING ROD
606	20-02-2026	Part of : CHIRAG DELHI	2758	Other Outage	Planned Outage	20-02-2026	11:19	20-02-2026	14:57	3:38	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
607	20-02-2026	Part of : BLOCK E SAINIK FARM	4	Other Outage	Planned Outage	20-02-2026	11:28	20-02-2026	13:52	2:24	0.001000	REPLACEMET OF HT BUSHING ROD
608	20-02-2026	Part of : BLOCK E SAINIK FARM	5	Other Outage	Planned Outage	20-02-2026	11:27	20-02-2026	13:49	2:22	0.001381	OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD
609	20-02-2026	Part of : BLOCK E SAINIK FARM	3	Other Outage	Planned Outage	20-02-2026	11:38	20-02-2026	13:48	2:10	0.001264	REPLACEMET OF HT BUSHING ROD
610	20-02-2026	Part of : BLOCK E SAINIK FARM	3	Other Outage	Planned Outage	20-02-2026	11:27	20-02-2026	13:49	2:22	0.001381	INSTALLATION OF HT BOOTS,REPLACEMENT OF HT BUSHING ROD
611	20-02-2026	Part of : BLOCK E SAINIK FARM	4	Other Outage	Planned Outage	20-02-2026	11:26	20-02-2026	13:51	2:25	0.001410	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING ROD
612	21-02-2026	Part of : BLOCK H NEB SARAI SAINIK FARM	383	Other Outage	Planned Outage	21-02-2026	13:28	21-02-2026	16:42	3:14	0.002425	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING INSULATOR
613	21-02-2026	Part of : BLOCK H NEB SARAI SAINIK FARM	57	Other Outage	Planned Outage	21-02-2026	10:50	21-02-2026	13:32	2:42	0.002025	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR
614	21-02-2026	Part of : BLOCK D DDA FLATE MALVIYA NAGAR	827	Other Outage	Planned Outage	21-02-2026	10:52	21-02-2026	14:05	3:13	0.000000	REPLACEMET OF HT BUSHING ROD
615	22-02-2026	Part of : BLOCK L MALVIYA NAGAR,BLOCK T MALVIYA NAGAR,BLOCK G 6 MALVIYA NAGAR	2688	Other Outage	Unplanned Outage	22-02-2026	16:54	22-02-2026	17:48	0:54	0.000562	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
616	23-02-2026	Part of : BLOCK C SARVODYA ENCLAVE	258	Other Outage	Planned Outage	23-02-2026	13:59	23-02-2026	17:02	3:03	0.000000	REPLACEMET OF HT BUSHING ROD
617	23-02-2026	Part of : PANCHSHEEL EXTENSION MALVIYA NAGAR	1034	Other Outage	Planned Outage	23-02-2026	10:47	23-02-2026	13:56	3:09	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
618	24-02-2026	Part of : SECTOR 1 PUSHPA VIHAR,H,N,L & J-BLOCK SAKET,ASHOK VIHAR PRESS ENCLAVE	1986	Other Outage	Unplanned Outage	24-02-2026	11:03	24-02-2026	12:09	1:06	0.001833	REPLACEMENT OF SOCKETS
619	24-02-2026	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	340	Other Outage	Planned Outage	24-02-2026	13:46	24-02-2026	16:02	2:16	0.003778	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
620	24-02-2026	Part of : BLOCK H PANCHSHEEL VIHAR SHEIKH SARAI VILLAGE	1968	Other Outage	Planned Outage	24-02-2026	10:40	24-02-2026	14:07	3:27	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD
621	24-02-2026	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	415	Other Outage	Planned Outage	24-02-2026	11:01	24-02-2026	14:26	3:25	0.005694	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
622	24-02-2026	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	349	Other Outage	Planned Outage	24-02-2026	09:58	24-02-2026	12:25	2:27	0.000000	REPLACEMENT OF HT BUSHING ROD
623	25-02-2026	Part of : SAINIK FARM	8	Other Outage	Planned Outage	25-02-2026	14:46	25-02-2026	16:24	1:38	0.002722	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
624	25-02-2026	Part of : BLOCK A PARYAVARAN COMPLEX SAINIK FARM	966	Other Outage	Planned Outage	25-02-2026	10:57	25-02-2026	14:25	3:28	0.002600	REPLACEMET OF HT BUSHING ROD
625	25-02-2026	Part of : BLOCK L MALVIYA NAGAR	2252	Other Outage	Planned Outage	25-02-2026	11:20	25-02-2026	14:22	3:02	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
626	25-02-2026	Part of : KALU SARAI	263	Other Outage	Planned Outage	25-02-2026	10:05	25-02-2026	12:23	2:18	0.000000	REPLACEMENT OF LT BUSHING ROD
627	26-02-2026	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI,	641	Other Outage	Planned Outage	26-02-2026	10:10	26-02-2026	11:59	1:49	0.000303	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT BUSHING ROD
628	26-02-2026	Part of : BLOCK C SHIVALIK MALVIYA NAGAR,BHAVISHYANIDHI ENCLAVE MALVIYA NAGAR,	1123	Other Outage	Planned Outage	26-02-2026	10:11	26-02-2026	12:01	1:50	0.000306	REPLACEMET OF HT BUSHING ROD
629	26-02-2026	Part of : SECTOR 3 PUSHPA VIHAR,	13	Other Outage	Planned Outage	26-02-2026	11:53	26-02-2026	15:08	3:15	0.005417	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
630	26-02-2026	Part of : SAINIK FARM,	184	Other Outage	Planned Outage	26-02-2026	11:09	26-02-2026	13:50	2:41	0.004472	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,TIGHTENEING OF NUT BOLT
631	26-02-2026	Part of : BLOCK L MALVIYA NAGAR,	959	Other Outage	Planned Outage	26-02-2026	10:39	26-02-2026	14:02	3:23	0.000000	REPLACEMET OF HT BUSHING ROD
632	26-02-2026	Part of : BLOCK B NAVJIVAN VIHAR MALVIYA NAGAR,	148	Other Outage	Planned Outage	26-02-2026	10:12	26-02-2026	14:06	3:54	0.000000	REPLACEMENT OF LT BUSHING ROD
633	27-02-2026	Part of : SAINIK FARMS COLONY SAINIK FARM	2	Other Outage	Planned Outage	27-02-2026	12:29	27-02-2026	15:04	2:35	0.004306	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
634	27-02-2026	Part of : H 5-BLOCK MALVIYA NAGAR	1102	Other Outage	Planned Outage	27-02-2026	10:37	27-02-2026	14:05	3:28	0.000000	REPLACEMENT OF HT BUSHING ROD
635	27-02-2026	Part of : ASHOK VIHAR PRESS ENCLAVE SAKET	150	Other Outage	Planned Outage	27-02-2026	10:59	27-02-2026	13:48	2:49	0.004694	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
636	27-02-2026	Part of : MMTG COLONY SARVODYA ENCLAVE	74	Other Outage	Planned Outage	27-02-2026	10:00	27-02-2026	13:47	3:47	0.000000	REPLACEMENT OF HT BUSHING ROD
637	28-02-2026	Part of : KUTUB GOLF COURSE LADO SARAI	12	Other Outage	Planned Outage	28-02-2026	12:37	28-02-2026	15:35	2:58	0.004944	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
638	28-02-2026	Part of : H-BLOCK SAKET	2	Other Outage	Planned Outage	28-02-2026	11:05	28-02-2026	13:16	2:11	0.003639	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
639	01-02-2026	Part of : BLOCK D & F MOLARBAND EXTENSION BADARPUR,BLOCK E1 & E2 MOLARBAND EXTENSION BADARPUR	5107	Other Outage	Unplanned Outage	01-02-2026	12:37	01-02-2026	13:14	0:37	0.001082	CABLE DAMAGED BY OUTSIDE AGENCY (IGL)
640	02-02-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND,	1006	Other Outage	Planned Outage	02-02-2026	13:44	02-02-2026	14:36	0:52	0.001156	3PH HT AB CABLE REPLACEMENT PER SPAN
641	02-02-2026	Part of : RAJ NAGAR MADANPUR KHADAR,	1665	Other Outage	Planned Outage	02-02-2026	10:58	02-02-2026	13:44	2:46	0.002306	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
642	02-02-2026	Part of : POCKET A SARITA VIHAR,	179	Other Outage	Planned Outage	02-02-2026	10:57	02-02-2026	13:42	2:45	0.001375	REPLACEMENT OF GAS KIT AND OIL SEAL
643	02-02-2026	Part of : MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR,BADARPUR EXTENSION TAJPUR BADARPUR,BLOCK A BUDH BIHAR TAJPUR PAHARI VILLAGE BADARPUR,	2412	Other Outage	Planned Outage	02-02-2026	11:15	02-02-2026	13:56	2:41	0.000447	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
644	03-02-2026	Part of : O & N-BLOCK SAURABH VIHAR	1174	Other Outage	Planned Outage	03-02-2026	11:38	03-02-2026	13:23	1:45	0.002333	3PH HT AB CABLE REPLACEMENT PER SPAN,HT BUSHING ROD REPLACEMENT
645	03-02-2026	Part of : ALI EXTENSION	236	Other Outage	Planned Outage	03-02-2026	11:35	03-02-2026	13:40	2:05	0.001042	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
646	03-02-2026	Part of : KHADDA COLONY JAIPUR	184	Other Outage	Planned Outage	03-02-2026	11:38	03-02-2026	13:40	2:02	0.000000	REPLACEMENT OF HT BUSHING ROD
647	04-02-2026	Part of : POCKET E SARITA VIHAR	174	Other Outage	Planned Outage	04-02-2026	11:02	04-02-2026	13:38	2:36	0.001300	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
648	04-02-2026	Part of : KHADDA COLONY JAIPUR	3208	Other Outage	Planned Outage	04-02-2026	11:03	04-02-2026	13:42	2:39	0.003092	3PH HT AB CABLE REPLACEMENT
649	04-02-2026	Part of : M,L,H & K-BLOCK SAURABH VIHAR	2060	Other Outage	Planned Outage	04-02-2026	11:15	04-02-2026	12:59	1:44	0.002311	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT
650	04-02-2026	Part of : C & D-BLOCK MOLARBAND EXTENSION BADARPUR	886	Other Outage	Planned Outage	04-02-2026	10:57	04-02-2026	13:40	2:43	0.000453	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT
651	04-02-2026	Part of : JAIPUR EXTN,B-BLOCK EKTA VIHAR B-BLOCK,	1775	Other Outage	Planned Outage	04-02-2026	13:58	04-02-2026	15:27	1:29	0.002719	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
652	05-02-2026	Part of : BLOCK D & F HARI NAGAR EXTN,D2-BLOCK HARI NAGAR EXTN-III	1055	Other Outage	Planned Outage	05-02-2026	13:00	05-02-2026	14:01	1:01	0.001356	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
653	05-02-2026	Part of : KHADDA COLONY JAIPUR	1959	Other Outage	Planned Outage	05-02-2026	11:29	05-02-2026	13:02	1:33	0.001292	3PH HT AB CABLE REPLACEMENT PER SPAN
654	06-02-2026	Part of : POCKET M SARITA VIHAR,	1095	Other Outage	Unplanned Outage	06-02-2026	13:25	06-02-2026	15:02	1:37	0.002156	BUS BAR COUPLING CLEANED/REPLACED/REPAIRED
655	06-02-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND,	1006	Other Outage	Planned Outage	06-02-2026	11:53	06-02-2026	13:36	1:43	0.002289	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
656	06-02-2026	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR,BLOCK D MOLARBAND EXTENSION BADARPUR,	1958	Other Outage	Planned Outage	06-02-2026	10:38	06-02-2026	13:31	2:53	0.000481	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
657	06-02-2026	Part of : KHADDA COLONY JAIPUR,	1459	Other Outage	Planned Outage	06-02-2026	11:02	06-02-2026	13:33	2:31	0.002097	3PH HT AB CABLE REPLACEMENT PER SPAN
658	07-02-2026	Part of : N & O-BLOCK SAURABH VIHAR	1174	Other Outage	Planned Outage	07-02-2026	13:50	07-02-2026	14:40	0:50	0.001111	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
659	07-02-2026	Part of : KHADDA COLONY JAIPUR	2608	Other Outage	Planned Outage	07-02-2026	10:56	07-02-2026	13:39	2:43	0.002717	3PH HT AB CABLE REPLACEMENT
660	08-02-2026	Part of : B-BLOCK MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	6	Other Outage	Planned Outage	08-02-2026	11:09	08-02-2026	13:02	1:53	0.000942	REPLACEMENT OF HT/LT CLEATS
661	09-02-2026	Part of : KHADDA COLONY JAIPUR	1796	Other Outage	Planned Outage	09-02-2026	10:58	09-02-2026	13:48	2:50	0.003778	3PH HT AB CABLE REPLACEMENT PER SPAN
662	09-02-2026	Part of : ALI EXTENSION	64	Other Outage	Planned Outage	09-02-2026	10:58	09-02-2026	13:48	2:50	0.001417	REPLACEMENT OF GAS KIT AND OIL SEAL
663	09-02-2026	Part of : BLOCK H,K,L & M SAURABH VIHAR	2060	Other Outage	Planned Outage	09-02-2026	11:28	09-02-2026	13:55	2:27	0.003267	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
664	10-02-2026	Part of : PEER BABA BASTI JAIPUR,H BLOCK SAURABH VIHAR,JAIPUR VILLAGE GURUNANAK MOHALLA,VILLAGE-JAIPUR,JAIPUR EXTN J-BLOCK,D2-BLOCK HARI NAGAR EXTN-III,JAIPUR EXTN A-BLOCK,JAIPUR,	4738	Other Outage	Unplanned Outage	10-02-2026	16:39	10-02-2026	17:58	1:19	0.001756	INSTALLATION OF RMU
665	10-02-2026	Part of : E-BLOCK HARI NAGAR EXTN,D2-BLOCK HARI NAGAR EXTN-III,F-BLOCK HARI NAGAR EXTN,	1055	Other Outage	Planned Outage	10-02-2026	11:11	10-02-2026	12:45	1:34	0.002089	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
666	10-02-2026	Part of : POCKET D SARITA VIHAR,	272	Other Outage	Planned Outage	10-02-2026	11:31	10-02-2026	12:51	1:20	0.000667	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
667	10-02-2026	Part of : KHADDA COLONY JAIPUR,	2233	Other Outage	Planned Outage	10-02-2026	11:29	10-02-2026	13:34	2:05	0.001736	3PH HT AB CABLE REPLACEMENT PER SPAN
668	11-02-2026	Part of : BLOCK C, E1 & E 2 MOLARBAND EXTENSION BADARPUR	1928	Other Outage	Planned Outage	11-02-2026	10:50	11-02-2026	13:53	3:03	0.000508	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB CABLE REPLACEMENT
669	11-02-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1460	Other Outage	Planned Outage	11-02-2026	10:58	11-02-2026	13:39	2:41	0.002236	3PH HT AB CABLE REPLACEMENT
670	12-02-2026	Part of : N & O-BLOCK SAURABH VIHAR	1174	Other Outage	Planned Outage	12-02-2026	11:41	12-02-2026	12:18	0:37	0.000822	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
671	12-02-2026	Part of : KHADDA COLONY JAIPUR	1796	Other Outage	Planned Outage	12-02-2026	11:24	12-02-2026	12:51	1:27	0.001208	3PH HT AB CABLE REPLACEMENT
672	13-02-2026	Part of : K-BLOCK SAURABH VIHAR,M-BLOCK SAURABH VIHAR,L-BLOCK SAURABH VIHAR,H BLOCK SAURABH VIHAR,JAIPUR,	2060	Other Outage	Planned Outage	13-02-2026	11:02	13-02-2026	12:22	1:20	0.001778	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
673	13-02-2026	Part of : BLOCK E1 & E2 MOLARBAND EXTENSION BADARPUR	1727	Other Outage	Planned Outage	13-02-2026	10:48	13-02-2026	12:58	2:10	0.000361	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
674	13-02-2026	Part of : KHADDA COLONY JAIPUR	314	Other Outage	Planned Outage	13-02-2026	11:08	13-02-2026	13:32	2:24	0.002000	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
675	14-02-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND,	1006	Other Outage	Planned Outage	14-02-2026	12:19	14-02-2026	12:51	0:32	0.000711	3PH HT AB CABLE REPLACEMENT PER SPAN
676	14-02-2026	Part of : E-BLOCK HARI NAGAR EXTN,D2-BLOCK HARI NAGAR EXTN-III,F-BLOCK HARI NAGAR EXTN,	1055	Other Outage	Planned Outage	14-02-2026	12:46	14-02-2026	13:59	1:13	0.001622	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
677	15-02-2026	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	7	Other Outage	Planned Outage	15-02-2026	10:55	15-02-2026	11:56	1:01	0.000508	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
678	16-02-2026	Part of : B-BLOCK MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	27	Other Outage	Unplanned Outage	16-02-2026	03:05	16-02-2026	03:52	0:47	0.000431	HT SYSTEM FAULT
679	16-02-2026	Part of : E 2-BLOCK MOLARBAND EXTENSION BADARPUR	1505	Other Outage	Planned Outage	16-02-2026	12:23	16-02-2026	13:24	1:01	0.000169	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT
680	16-02-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND	1006	Other Outage	Planned Outage	16-02-2026	11:07	16-02-2026	13:04	1:57	0.002600	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
681	16-02-2026	Part of : BADARPUR VILLAGE	1441	Other Outage	Planned Outage	16-02-2026	12:22	16-02-2026	13:44	1:22	0.000456	GUARD WIRES SAGGING
682	16-02-2026	Part of : KHADDA COLONY JAIPUR	1459	Other Outage	Planned Outage	16-02-2026	11:01	16-02-2026	13:49	2:48	0.002333	3PH HT AB CABLE REPLACEMENT
683	16-02-2026	Part of : POCKET K SARITA VIHAR	190	Other Outage	Planned Outage	16-02-2026	11:02	16-02-2026	13:50	2:48	0.001400	REPLACEMENT OF GAS KIT AND OIL SEAL
684	17-02-2026	Part of : BLOCK N & O SAURABH VIHAR	1174	Other Outage	Planned Outage	17-02-2026	11:37	17-02-2026	12:18	0:41	0.000911	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
685	17-02-2026	Part of : KHADDA COLONY JAIPUR	2608	Other Outage	Planned Outage	17-02-2026	11:32	17-02-2026	13:18	1:46	0.001178	3PH HT AB CABLE REPLACEMENT PER SPAN
686	17-02-2026	Part of : MADANPUR KHADAR VILLAGE	16	Other Outage	Planned Outage	17-02-2026	11:33	17-02-2026	13:17	1:44	0.000867	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
687	18-02-2026	Part of : K-BLOCK SAURABH VIHAR,M-BLOCK SAURABH VIHAR,L-BLOCK SAURABH VIHAR,H BLOCK SAURABH VIHAR,JAIPUR,	2060	Other Outage	Planned Outage	18-02-2026	11:41	18-02-2026	12:39	0:58	0.001289	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
688	18-02-2026	Part of : POCKET F SARITA VIHAR,	603	Other Outage	Planned Outage	18-02-2026	11:15	18-02-2026	13:17	2:02	0.001017	REPLACEMENT OF GAS KIT AND OIL SEAL
689	18-02-2026	Part of : BLOCK F MOLARBAND EXTENSION BADARPUR,BLOCK E 1 MOLARBAND EXTENSION BADARPUR,BLOCK E 2 MOLARBAND EXTENSION BADARPUR,BLOCK D MOLARBAND EXTENSION BADARPUR,	25	Other Outage	Planned Outage	18-02-2026	11:16	18-02-2026	13:37	2:21	0.000392	1PH HT AB CABLE REPLACEMENT PER SPAN
690	18-02-2026	Part of : KHADDA COLONY JAIPUR,	3208	Other Outage	Planned Outage	18-02-2026	11:14	18-02-2026	13:22	2:08	0.001778	3PH HT AB CABLE REPLACEMENT PER SPAN
691	19-02-2026	Part of : Part of : D 2,E & F-BLOCK HARI NAGAR EXTN	1055	Other Outage	Planned Outage	19-02-2026	12:25	19-02-2026	13:24	0:59	0.001311	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
692	19-02-2026	Part of : Part of : RAJ NAGAR MADANPUR KHADAR	1460	Other Outage	Planned Outage	19-02-2026	10:56	19-02-2026	13:34	2:38	0.003072	3PH HT AB CABLE REPLACEMENT
693	20-02-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND	1006	Other Outage	Planned Outage	20-02-2026	11:02	20-02-2026	13:21	2:19	0.003089	3PH HT AB CABLE REPLACEMENT,3PH HT AB END TERMINATION REPLACEMENT
694	20-02-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1665	Other Outage	Planned Outage	20-02-2026	11:14	20-02-2026	13:23	2:09	0.002508	3PH HT AB CABLE REPLACEMENT
695	21-02-2026	Part of : BLOCK J,K,N & O SAURABH VIHAR, ABC BLOCK HARI NAGAR MOLARBAND, E-BLOCK HARI NAGAR EXT PART-2	4379	Other Outage	Unplanned Outage	21-02-2026	23:19	21-02-2026	23:46	0:27	0.000240	CABLE FAULT
696	21-02-2026	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR,TAJPUR PAHARI VILLAGE BADARPUR, MEETHAPUR WATER PUMPING STN (HTC)	2039	Other Outage	Unplanned Outage	21-02-2026	02:06	21-02-2026	02:57	0:51	0.000159	CABLE FAULT
697	21-02-2026	Part of : BLOCK N & O SAURABH VIHAR	1174	Other Outage	Planned Outage	21-02-2026	13:03	21-02-2026	13:37	0:34	0.000756	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
698	21-02-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1365	Other Outage	Planned Outage	21-02-2026	11:07	21-02-2026	13:43	2:36	0.002167	3PH HT AB CABLE REPLACEMENT PER SPAN
699	22-02-2026	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR,	2	Other Outage	Planned Outage	22-02-2026	10:55	22-02-2026	12:31	1:36	0.001867	REPLACEMENT OF GAS KIT AND OIL SEAL
700	23-02-2026	Part of : Block C Molarband Extension Badarpur,Mohan Baba Nagar Tajpur Pahari Village Badarpur,Block A Molarband Extension Badarpur,Molarband Village Badarpur	2039	Other Outage	Unplanned Outage	23-02-2026	00:45	23-02-2026	01:06	0:21	0.000000	CABLE FAULT
701	23-02-2026	Part of : H,M,L & K-BLOCK SAURABH VIHAR,JAIPUR	2060	Other Outage	Planned Outage	23-02-2026	11:04	23-02-2026	13:34	2:30	0.003333	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
702	23-02-2026	Part of : MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE,BADARPUR EXTENSION	1890	Other Outage	Planned Outage	23-02-2026	10:27	23-02-2026	14:07	3:40	0.000611	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB CABLE REPLACEMENT
703	23-02-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1478	Other Outage	Planned Outage	23-02-2026	11:02	23-02-2026	13:25	2:23	0.003178	3PH HT AB CABLE REPLACEMENT
704	23-02-2026	Part of : POCKET F SARITA VIHAR	624	Other Outage	Planned Outage	23-02-2026	11:02	23-02-2026	13:24	2:22	0.002367	INSTALLATION OF BUS BAR
705	24-02-2026	Part of : GAGAN VIHAR MITHAPUR EXTENSION	1731	Other Outage	Planned Outage	24-02-2026	11:04	24-02-2026	11:58	0:54	0.000450	SUB STATION CLEANING
706	24-02-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1134	Other Outage	Planned Outage	24-02-2026	10:50	24-02-2026	12:50	2:00	0.001667	3PH HT AB CABLE REPLACEMENT
707	24-02-2026	Part of : BLOCK E & F HARI NAGAR EXTN,D2-BLOCK HARI NAGAR EXTN-III	1055	Other Outage	Planned Outage	24-02-2026	11:04	24-02-2026	13:26	2:22	0.003156	3PH HT AB CABLE REPLACEMENT,3PH HT AB END TERMINATION REPLACEMENT
708	24-02-2026	Part of : MADANPUR KHADAR VILLAGE	1780	Other Outage	Planned Outage	24-02-2026	10:49	24-02-2026	12:52	2:03	0.002392	REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
709	25-02-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND	1006	Other Outage	Planned Outage	25-02-2026	11:47	25-02-2026	13:10	1:23	0.001844	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
710	25-02-2026	Part of : MOLARBAND VILLAGE BADARPUR	2082	Other Outage	Planned Outage	25-02-2026	11:14	25-02-2026	13:44	2:30	0.004583	REPLACEMENT OF HT BUSHING ROD
711	25-02-2026	Part of : MADANPUR KHADAR VILLAGE	774	Other Outage	Planned Outage	25-02-2026	11:08	25-02-2026	13:17	2:09	0.002150	REPLACEMENT OF GAS KIT AND OIL SEAL
712	25-02-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1644	Other Outage	Planned Outage	25-02-2026	11:07	25-02-2026	13:20	2:13	0.001847	3PH HT AB CABLE REPLACEMENT PER SPAN
713	26-02-2026	Part of : KHADDA COLONY JAIPUR,	1959	Other Outage	Planned Outage	26-02-2026	11:12	26-02-2026	12:07	0:55	0.001375	3PH HT AB CABLE REPLACEMENT PER SPAN
714	26-02-2026	Part of : O-BLOCK SAURABH VIHAR,N-BLOCK SAURABH VIHAR,	1174	Other Outage	Planned Outage	26-02-2026	11:17	26-02-2026	13:17	2:00	0.002667	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
715	27-02-2026	Part of : Mohan Baba Nagar Tajpur Pahari Village Badarpur,Badarpur Extension Tajpur Badarpur,Block A Budh Bihar Tajpur Pahari Village Badarpur	3396	Other Outage	Unplanned Outage	27-02-2026	10:27	27-02-2026	10:53	0:26	0.000442	CABLE FAULT
716	27-02-2026	Part of : M,L,H & K-BLOCK SAURABH VIHAR,JAIPUR	2060	Other Outage	Planned Outage	27-02-2026	13:27	27-02-2026	14:18	0:51	0.001133	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
717	27-02-2026	Part of : KHADDA COLONY JAIPUR	1459	Other Outage	Planned Outage	27-02-2026	11:02	27-02-2026	13:22	2:20	0.001944	3PH HT AB CABLE REPLACEMENT
718	28-02-2026	Part of : A & C-BLOCK MOLARBAND EXTENSION,MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR	371	Other Outage	Planned Outage	28-02-2026	10:48	28-02-2026	12:32	1:44	0.000289	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB CABLE REPLACEMENT
719	28-02-2026	Part of : E,F & D2-BLOCK HARI NAGAR EXTN.	1055	Other Outage	Planned Outage	28-02-2026	11:08	28-02-2026	12:28	1:20	0.001778	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
720	28-02-2026	Part of : MADANPUR KHADAR VILLAGE	721	Other Outage	Planned Outage	28-02-2026	10:58	28-02-2026	13:23	2:25	0.004431	REPLACEMENT OF HT BUSHING ROD
721	28-02-2026	Part of : KHADDA COLONY JAIPUR	2608	Other Outage	Planned Outage	28-02-2026	10:58	28-02-2026	13:17	2:19	0.002896	3PH HT AB CABLE REPLACEMENT
722	28-02-2026	Part of : MOLARBAND VILLAGE BADARPUR	378	Other Outage	Planned Outage	28-02-2026	11:14	28-02-2026	13:46	2:32	0.004644	REPLACEMENT OF HT BUSHING ROD
723	01-02-2026	Part of : BLOCK F & R MAHIPALPUR VILLAGE, A,B HOTEL (HTC)	915	Other Outage	Unplanned Outage	01-02-2026	00:16	01-02-2026	00:42	0:26	0.000332	CABLE FAULT
724	02-02-2026	Part of : SECTOR D VASANT KUNJ,	21	Other Outage	Planned Outage	02-02-2026	13:10	02-02-2026	15:07	1:57	0.000488	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL
725	02-02-2026	Part of : RANGPURI PAHARI RANGPURI,	147	Other Outage	Planned Outage	02-02-2026	13:38	02-02-2026	14:44	1:06	0.000367	REPLACEMENT OF LT BUSHING ROD
726	02-02-2026	Part of : RANGPURI PAHARI RANGPURI,	142	Other Outage	Planned Outage	02-02-2026	11:14	02-02-2026	13:00	1:46	0.000589	REPLACEMENT OF LT BUSHING ROD
727	02-02-2026	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ,	866	Other Outage	Planned Outage	02-02-2026	12:17	02-02-2026	15:09	2:52	0.000478	3PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
728	02-02-2026	Part of : ROOPAM WALA KUNWA MEHRAULI,	1613	Other Outage	Planned Outage	02-02-2026	10:35	02-02-2026	14:35	4:00	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
729	02-02-2026	Part of : KAPAS HERA EXTENSION KAPAS HERA,	237	Other Outage	Planned Outage	02-02-2026	10:48	02-02-2026	12:52	2:04	0.000689	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
730	02-02-2026	Part of : PUSHANJALI FARMS,	269	Other Outage	Planned Outage	02-02-2026	10:14	02-02-2026	12:23	2:09	0.000000	BIRD SPIKES INSTALLATION PER POLE,GUARD WIRES SAGGING PER SPAN
731	03-02-2026	Part of : SAMALKA	744	Other Outage	Planned Outage	03-02-2026	10:42	03-02-2026	12:28	1:46	0.000589	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
732	03-02-2026	Part of : SECTOR D VASANT KUNJ	21	Other Outage	Planned Outage	03-02-2026	11:26	03-02-2026	13:12	1:46	0.000442	3PH DB REPLACEMENT,INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT
733	03-02-2026	Part of : MAHIPALPUR EXTENSION	340	Other Outage	Planned Outage	03-02-2026	10:37	03-02-2026	13:55	3:18	0.003025	REPLACEMENT OF HT BUSHING ROD
734	03-02-2026	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS	3528	Other Outage	Planned Outage	03-02-2026	11:04	03-02-2026	13:24	2:20	0.000000	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT
735	03-02-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	819	Other Outage	Planned Outage	03-02-2026	12:39	03-02-2026	15:11	2:32	0.000422	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
736	04-02-2026	Part of : LADHA SARAI VILLAGE MEHRAULI	2	Other Outage	Planned Outage	04-02-2026	14:16	04-02-2026	14:43	0:27	0.000300	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
737	04-02-2026	Part of : RAJOKRI VILLAGE	526	Other Outage	Planned Outage	04-02-2026	11:10	04-02-2026	12:49	1:39	0.000550	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
738	04-02-2026	Part of : GHITORNI VILLAGE	1	Other Outage	Planned Outage	04-02-2026	11:06	04-02-2026	13:40	2:34	0.000642	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,FERRULE PUNCHING LT AB
739	04-02-2026	Part of : BRAHMAPUTRA INFRASTRUCTURE (HT CONSUMER	1	Other Outage	Planned Outage	04-02-2026	11:47	04-02-2026	12:55	1:08	0.000661	REPLACEMET OF FAULTY END BOX
740	04-02-2026	Part of : NAYAK PURA BIJWASAN	569	Other Outage	Planned Outage	04-02-2026	10:57	04-02-2026	12:16	1:19	0.000000	INSTALLATION OF BUS BAR,REPLACEMET OF HT/LT CLEATS
741	04-02-2026	Part of : POCKET C SECTOR A VASANT KUNJ	40	Other Outage	Planned Outage	04-02-2026	14:11	04-02-2026	14:44	0:33	0.000000	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING INSULATOR,SUB STATION CLEANING
742	05-02-2026	Part of : GHITORNI VILLAGE	34	Other Outage	Planned Outage	05-02-2026	12:07	05-02-2026	13:52	1:45	0.000438	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
743	05-02-2026	Part of : PUSHANJALI FARMS	269	Other Outage	Planned Outage	05-02-2026	10:52	05-02-2026	13:50	2:58	0.000000	BIRD SPIKES INSTALLATION PER POLE,JUMPER REPLACEMENT PER POLE
744	05-02-2026	Part of : KAPAS HERA EXTENSION,PALAM FARMS	3350	Other Outage	Planned Outage	05-02-2026	11:20	05-02-2026	13:44	2:24	0.000800	CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD
745	05-02-2026	Part of : RUCHI VIHAR VASANT KUNJ	342	Other Outage	Planned Outage	05-02-2026	12:30	05-02-2026	14:56	2:26	0.000406	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,PRC REPLACEMET PER FEEDER
746	06-02-2026	Part of : LAKHI NATH KUTI MEHRAULI,ROOPAM WALA KUNWA MEHRAULI	3815	Other Outage	Unplanned Outage	06-02-2026	10:16	06-02-2026	11:02	0:46	0.001644	HT SYSTEM FAULT
747	06-02-2026	Part of : LAKHI NATH KUTI MEHRAULI,ROOPAM WALA KUNWA MEHRAULI,	3815	Other Outage	Unplanned Outage	06-02-2026	12:31	06-02-2026	15:24	2:53	0.000240	REPLACEMENT OF JUMPER
748	06-02-2026	Part of : DESU COLONY VASANT KUNJ,GANDHI COLONY MEHRAULI,KHANDSA COLONY MEHRAULI,	3658	Other Outage	Planned Outage	06-02-2026	14:29	06-02-2026	15:43	1:14	0.000514	BIRD SPIKES INSTALLATION PER POLE,GUARD WIRE LACS INSTALLTION PER SPAN
749	06-02-2026	Part of : DESU COLONY VASANT KUNJ,AHINSHA ENCLAVE MEHRAULI,MEHRAULI VILLAGE MEHRAULI,LADHA SARAI VILLAGE MEHRAULI,	3494	Other Outage	Planned Outage	06-02-2026	13:00	06-02-2026	14:29	1:29	0.000000	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
750	06-02-2026	Part of : BLOCK B MAHIPALPUR VILLAGE MAHIPALPUR,	555	Other Outage	Planned Outage	06-02-2026	10:34	06-02-2026	13:30	2:56	0.002689	REPLACEMENT OF LT BUSHING ROD
751	06-02-2026	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ,	514	Other Outage	Planned Outage	06-02-2026	11:14	06-02-2026	14:10	2:56	0.000000	1PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,PRC REPLACEMET PER FEEDER
752	06-02-2026	Part of : SAMALKA,	560	Other Outage	Planned Outage	06-02-2026	11:16	06-02-2026	13:22	2:06	0.000700	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF LUGS,SUB STATION CLEANING.TIGHTFENEING OF NUT BOLT
753	06-02-2026	Part of : GHITORNI VILLAGE GHITORNI,	59	Other Outage	Planned Outage	06-02-2026	10:43	06-02-2026	13:57	3:14	0.000808	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
754	06-02-2026	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS,	3528	Other Outage	Planned Outage	06-02-2026	10:01	06-02-2026	12:12	2:11	0.000000	CONDUCTOR REPLACEMET PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING
755	07-02-2026	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ,POCKET C SECTOR A VASANT KUNJ	1745	Other Outage	Unplanned Outage	07-02-2026	03:31	07-02-2026	04:17	0:46	0.000260	CABLE FAULT
756	07-02-2026	Part of : SECTOR D VASANT KUNJ	42	Other Outage	Planned Outage	07-02-2026	14:31	07-02-2026	15:17	0:46	0.000192	3PH DB REPLACEMENT,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE
757	07-02-2026	Part of : HARIJAN BASTI RAJOKRI	564	Other Outage	Planned Outage	07-02-2026	11:06	07-02-2026	12:01	0:55	0.000306	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
758	07-02-2026	Part of : BLOCK R MAHIPALPUR VILLAGE	54	Other Outage	Planned Outage	07-02-2026	13:54	07-02-2026	16:13	2:19	0.001738	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
759	07-02-2026	Part of : G D GOENKA SCHOOL NR B-10,GATE NO-4 (HT CONSUMER)	1	Other Outage	Planned Outage	07-02-2026	11:07	07-02-2026	14:09	3:02	0.000506	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
760	08-02-2026	Part of : ASSET NO. 6 & 7 AEROCIT,HOTEL LEMON TREE,OAK INFRA.	2	Other Outage	Unplanned Outage	08-02-2026	10:27	08-02-2026	10:58	0:31	0.000431	CABLE FAULT
761	09-02-2026	Part of : KAPAS HERA ESTATE,SAMALKA	2043	Other Outage	Unplanned Outage	09-02-2026	13:33	09-02-2026	16:05	2:32	0.000000	ATTEND WEAK POINT/HOT SPOT
762	09-02-2026	Part of : PALAM FARMS,PUSHPANJALI FARMS,DALMIA VIHAR BIJWASAN	635	Other Outage	Planned Outage	09-02-2026	10:27	09-02-2026	11:54	1:27	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT PER SPAN
763	09-02-2026	Part of : ANAND GRAM GHITORNI	52	Other Outage	Planned Outage	09-02-2026	11:12	09-02-2026	13:51	2:39	0.000663	JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
764	10-02-2026	Part of : PUSHPANJALI FARMS,	290	Other Outage	Planned Outage	10-02-2026	10:37	10-02-2026	12:26	1:49	0.000606	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
765	10-02-2026	Part of : PUSHPANJALI FARMS,	269	Other Outage	Planned Outage	10-02-2026	10:09	10-02-2026	11:41	1:32	0.000000	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN
766	10-02-2026	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ,	695	Other Outage	Planned Outage	10-02-2026	11:11	10-02-2026	13:55	2:44	0.000456	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER
767	10-02-2026	Part of : SECTOR D VASANT KUNJ,	71	Other Outage	Planned Outage	10-02-2026	10:26	10-02-2026	16:09	5:43	0.001429	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
768	10-02-2026	Part of : SAMALKA,KAPAS HERA ESTATE,PUSHPANJALI FARMS,KAPAS HERA EXTENSION KAPAS HERA,	3193	Other Outage	Planned Outage	10-02-2026	11:08	10-02-2026	13:10	2:02	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMET PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING
769	11-02-2026	Part of : SETH SARAI,CHRISTIAN COLONY,MEHRAULI VILLAGE,LADHA SARAI VILLAGE	1047	Other Outage	Planned Outage	11-02-2026	13:56	11-02-2026	15:01	1:05	0.000722	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
770	11-02-2026	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ	628	Other Outage	Planned Outage	11-02-2026	13:57	11-02-2026	14:59	1:02	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LUGS
771	11-02-2026	Part of : SECTOR D VASANT KUNJ	2	Other Outage	Planned Outage	11-02-2026	10:39	11-02-2026	15:01	4:22	0.001092	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,
772	11-02-2026	Part of : RUCHI VIHAR VASANT KUNJ,IAA COLONY SECTOR D VASANT KUNJ	468	Other Outage	Planned Outage	11-02-2026	10:25	11-02-2026	13:19	2:54	0.000967	HT SLEEVE INSTALLATION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
773	12-02-2026	Part of : SECTOR D VASANT KUNJ	71	Other Outage	Planned Outage	12-02-2026	13:53	12-02-2026	15:05	1:12	0.000300	JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
774	12-02-2026	Part of : POCKET C SECTOR A VASANT KUNJ	287	Other Outage	Planned Outage	12-02-2026	14:15	12-02-2026	15:50	1:35	0.001056	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
775	12-02-2026	Part of : DALMIA VIHAR BIJWASAN	135	Other Outage	Planned Outage	12-02-2026	10:11	12-02-2026	12:10	1:59	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
776	12-02-2026	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	667	Other Outage	Planned Outage	12-02-2026	10:11	12-02-2026	12:08	1:57	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING INSULATOR
777	12-02-2026	Part of : E-BLOCK MAHIPALPUR VILLAGE	1418	Other Outage	Planned Outage	12-02-2026	10:31	12-02-2026	13:25	2:54	0.002175	REPLACEMENT OF HT BUSHING ROD
778	12-02-2026	Part of : KAPAS HERA EXTENSION,PUSHPANJALI FARMS,PALAM FARMS	2198	Other Outage	Planned Outage	12-02-2026	11:04	12-02-2026	13:56	2:52	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
779	12-02-2026	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	28	Other Outage	Planned Outage	12-02-2026	10:40	12-02-2026	13:52	3:12	0.000533	LT CIRCUIT MAINTENANCE
780	13-02-2026	Part of : RANGPURI PAHARI	208	Other Outage	Planned Outage	13-02-2026	12:57	13-02-2026	13:44	0:47	0.000457	SUB STATION CLEANING
781	13-02-2026	Part of : KAPAS HERA ESTATE,AVENUE BOUGANVILLEA RANGPURI,YAWANTIKA COLONY RANGPURI	350	Other Outage	Planned Outage	13-02-2026	10:58	13-02-2026	11:34	0:36	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
782	13-02-2026	Part of : RANGPURI PAHARI	179	Other Outage	Planned Outage	13-02-2026	10:59	13-02-2026	11:46	0:47	0.000457	SUB STATION CLEANING
783	13-02-2026	Part of : RUCHI VIHAR VASANT KUNJ	1	Other Outage	Planned Outage	13-02-2026	10:44	13-02-2026	11:57	1:13	0.000203	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER,PRC REPLACEMET PER FEEDER
784	13-02-2026	Part of : SARTAJ HOTELS APARTMENT&VILLA (HTC)	1	Other Outage	Planned Outage	13-02-2026	11:04	13-02-2026	12:31	1:27	0.000846	REPLACEMET OF FAULTY END BOX
785	13-02-2026	Part of : SLASH PUR VILLAGE PALAM FARMS	476	Other Outage	Planned Outage	13-02-2026	10:19	13-02-2026	11:33	1:14	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
786	13-02-2026	Part of : GHITORNI VILLAGE	156	Other Outage	Planned Outage	13-02-2026	10:53	13-02-2026	13:01	2:08	0.000533	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE
787	13-02-2026	Part of : RUCHI VIHAR VASANT KUNJ	404	Other Outage	Planned Outage	13-02-2026	12:03	13-02-2026	14:22	2:19	0.000386	1PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER
788	14-02-2026	Part of : RAJOKRI VILLAGE RAJOKRI,HARIJAN BASTI RAJOKRI,AVENUE BOUGANVILLEA RANGPURI,	2594	Other Outage	Planned Outage	14-02-2026	11:01	14-02-2026	11:59	0:58	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
789	14-02-2026	Part of : GHITORNI VILLAGE GHITORNI,	305	Other Outage	Planned Outage	14-02-2026	11:26	14-02-2026	12:28	1:02	0.000207	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
790	14-02-2026	Part of : HTC:G D GOENKA SCHOOL	1	Other Outage	Planned Outage	14-02-2026	10:19	14-02-2026	12:38	2:19	0.000386	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
791	16-02-2026	Part of : GHITORNI VILLAGE	841	Other Outage	Planned Outage	16-02-2026	11:28	16-02-2026	12:55	1:27	0.001933	HT CONDUCTOR REPLACEMENT
792	16-02-2026	Part of : KAPAS HERA EXTENSION	903	Other Outage	Planned Outage	16-02-2026	10:46	16-02-2026	12:46	2:00	0.000667	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
793	16-02-2026	Part of : DALMIA VIHAR BIJWASAN	17	Other Outage	Planned Outage	16-02-2026	10:00	16-02-2026	11:05	1:05	0.000000	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LUGS
794	16-02-2026	Part of : CHRISTIAN COLONY MEHRAULI	785	Other Outage	Planned Outage	16-02-2026	12:24	16-02-2026	15:02	2:38	0.000000	REPLACEMENT OF HT BUSHING ROD
795	16-02-2026	Part of : HARIJAN BASTI SECTOR B VASANT KUNJ	375	Other Outage	Planned Outage	16-02-2026	11:11	16-02-2026	13:40	2:29	0.000414	LT CIRCUIT MAINTENANCE
796	17-02-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	259	Other Outage	Planned Outage	17-02-2026	11:23	17-02-2026	11:24	0:01	0.000003	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER
797	17-02-2026	Part of : KAPAS HERA EXTENSION	135	Other Outage	Planned Outage	17-02-2026	10:44	17-02-2026	11:36	0:52	0.000289	CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT/LT CLEATS
798	17-02-2026	Part of : GHITORNI VILLAGE	226	Other Outage	Planned Outage	17-02-2026	11:05	17-02-2026	13:02	1:57	0.002600	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN
799	17-02-2026	Part of : PUSHANJALI FARMS	269	Other Outage	Planned Outage	17-02-2026	09:52	17-02-2026	11:12	1:20	0.000000	CONDUCTOR REPLACEMET PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING
800	18-02-2026	Part of : PALAM FARMS,SLASH PUR VILLAGE PALAM FARMS	3551	Other Outage	Unplanned Outage	18-02-2026	08:54	18-02-2026	09:24	0:30	0.000350	TREE BRANCH FALLEN ON O/H HT LINE
801	18-02-2026	Part of : PALAM FARMS,SLASH PUR VILLAGE PALAM FARMS	3551	Other Outage	Unplanned Outage	18-02-2026	07:15	18-02-2026	07:34	0:19	0.000572	TREE BRANCH FALLEN ON O/H HT LINE
802	18-02-2026	Part of : MEHRAULI VILLAGE MEHRAULI,	2250	Other Outage	Planned Outage	18-02-2026	13:34	18-02-2026	14:43	1:09	0.000479	DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
803	18-02-2026	Part of : KAPAS HERA ESTATE,	767	Other Outage	Planned Outage	18-02-2026	10:48	18-02-2026	12:02	1:14	0.000411	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
804	19-02-2026	Part of : Part of : POCKET C SECTOR A VASANT KUNJ	221	Other Outage	Planned Outage	19-02-2026	14:10	19-02-2026	14:54	0:44	0.000000	REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
805	19-02-2026	Part of : Part of : B-BLOCK NANGAL DEWAT SECTOR D VASANT KUNJ	75	Other Outage	Planned Outage	19-02-2026	13:32	19-02-2026	15:01	1:29	0.000247	3PH DB REPLACEMENT,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB
806	19-02-2026	Part of : Part of : LAKHI NATH KUTI MEHRAULI	1570	Other Outage	Planned Outage	19-02-2026	12:00	19-02-2026	13:53	1:53	0.000628	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
807	19-02-2026	Part of : Part of : SAMALKA	974	Other Outage	Planned Outage	19-02-2026	11:15	19-02-2026	12:27	1:12	0.000400	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
808	19-02-2026	Part of : Part of : GHITORNI VILLAGE	388	Other Outage	Planned Outage	19-02-2026	10:43	19-02-2026	12:26	1:43	0.002432	INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
809	19-02-2026	Part of : Part of : PALAM FARMS,)SALVE BIJWASAN	237	Other Outage	Planned Outage	19-02-2026	09:50	19-02-2026	11:18	1:28	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE
810	20-02-2026	Part of : KHANDSA COLONY MEHRAULI	767	Other Outage	Planned Outage	20-02-2026	13:31	20-02-2026	13:54	0:23	0.000096	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
811	20-02-2026	Part of : SAMALKA	50	Other Outage	Planned Outage	20-02-2026	11:00	20-02-2026	11:32	0:32	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
812	20-02-2026	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS	3528	Other Outage	Planned Outage	20-02-2026	10:28	20-02-2026	11:09	0:41	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMET
813	20-02-2026	Part of : TEACHER COLONY MEHRAULI	536	Other Outage	Planned Outage	20-02-2026	12:21	20-02-2026	14:49	2:28	0.001644	AUXILIARY SUPPLY FOR RELAYS,CT REPLACEMET,PROPER SEALING RMU PER WAY
814	20-02-2026	Part of : GHITORNI VILLAGE	842	Other Outage	Planned Outage	20-02-2026	10:53	20-02-2026	12:58	2:05	0.000694	JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
815	20-02-2026	Part of : NALLAPAR RANGPURI,MAHIPALPUR VILLAGE	1161	Other Outage	Planned Outage	20-02-2026	11:25	20-02-2026	13:55	2:30	0.001458	REPLACEMET OF HT BUSHING ROD
816	20-02-2026	Part of : POCKET 8 SECTOR C VASANT KUNJ	484	Other Outage	Planned Outage	20-02-2026	10:33	20-02-2026	13:10	2:37	0.000436	LT CIRCUIT MAINTENANCE
817	21-02-2026	Part of : C.L.JAIN A-67 MAHIPALPUR EXTN (HTC), TAURAS HOTEL MAHIPALPUR (HTC)	2	Other Outage	Planned Outage	21-02-2026	13:11	21-02-2026	14:50	1:39	0.000963	REPLACEMET OF FAULTY END BOX
818	21-02-2026	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	667	Other Outage	Planned Outage	21-02-2026	10:58	21-02-2026	11:58	1:00	0.000000	REPLACEMET OF LUGS,SUB STATION CLEANING
819	21-02-2026	Part of : GHITORNI VILLAGE	679	Other Outage	Planned Outage	21-02-2026	11:36	21-02-2026	12:46	1:10	0.000389	JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
820	21-02-2026	Part of : RAJOKRI VILLAGE,WEST END GREENS RANGPURI,AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	1661	Other Outage	Planned Outage	21-02-2026	11:01	21-02-2026	12:17	1:16	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
821	21-02-2026	Part of : HARIJAN BASTI SECTOR B VASANT KUNJ	187	Other Outage	Planned Outage	21-02-2026	11:02	21-02-2026	13:11	2:09	0.000358	CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY
822	23-02-2026	Part of : MEHRAULI VILLAGE	1050	Other Outage	Planned Outage	23-02-2026	16:57	23-02-2026	17:07	0:10	0.000064	DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER
823	23-02-2026	Part of : KAPAS HERA EXTENSION	637	Other Outage	Planned Outage	23-02-2026	10:42	23-02-2026	12:11	1:29	0.000494	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
824	23-02-2026	Part of : PUSHANJALI FARMS	65	Other Outage	Planned Outage	23-02-2026	10:03	23-02-2026	11:32	1:29	0.000000	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET
825	23-02-2026	Part of : GHITORNI VILLAGE	1227	Other Outage	Planned Outage	23-02-2026	11:40	23-02-2026	13:42	2:02	0.000678	JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
826	23-02-2026	Part of : GHITORNI VILLAGE	388	Other Outage	Planned Outage	23-02-2026	11:25	23-02-2026	13:40	2:15	0.003188	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
827	23-02-2026	Part of : BLOCK K MAHIPALPUR VILLAGE	1881	Other Outage	Planned Outage	23-02-2026	11:00	23-02-2026	13:19	2:19	0.002510	REPLACEMET OF HT BUSHING ROD
828	23-02-2026	Part of : SECTOR D VASANT KUNJ	53	Other Outage	Planned Outage	23-02-2026	11:16	23-02-2026	13:30	2:14	0.000372	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,FERRULE PUNCHING LT AB
829	24-02-2026	Part of : NAYAK PURA BIJWASAN	2721	Other Outage	Unplanned Outage	24-02-2026	16:10	24-02-2026	16:27	0:17	0.000117	BIRDAGE
830	24-02-2026	Part of : NAYAK PURA BIJWASAN	568	Other Outage	Planned Outage	24-02-2026	10:02	24-02-2026	10:56	0:54	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
831	24-02-2026	Part of : PUSHANJALI FARMS	269	Other Outage	Planned Outage	24-02-2026	10:00	24-02-2026	10:55	0:55	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT
832	24-02-2026	Part of : TEACHER COLONY MEHRAULI	536	Other Outage	Planned Outage	24-02-2026	12:40	24-02-2026	14:36	1:56	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS
833	24-02-2026	Part of : KAPAS HERA EXTENSION	286	Other Outage	Planned Outage	24-02-2026	11:14	24-02-2026	12:39	1:25	0.000472	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD
834	25-02-2026	Part of : HARIJAN BASTI, GREWAL COLONY BIJWASAN, NAYAK PURA BIJWASAN, H.P BIJWASAN (HTC)	2722	Other Outage	Unplanned Outage	25-02-2026	10:40	25-02-2026	10:51	0:11	0.000153	HT SYSTEM FAULT
835	25-02-2026	Part of : HARIJAN BASTI, GREWAL COLONY BIJWASAN, NAYAK PURA BIJWASAN, H.P BIJWASAN (HTC)	2722	Other Outage	Unplanned Outage	25-02-2026	16:37	25-02-2026	17:17	0:40	0.000339	BIRDAGE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
836	25-02-2026	Part of : KHANDSA COLONY MEHRAULI	1070	Other Outage	Planned Outage	25-02-2026	15:11	25-02-2026	15:48	0:37	0.000206	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
837	25-02-2026	Part of : PALAM FARMS	32	Other Outage	Planned Outage	25-02-2026	10:24	25-02-2026	10:56	0:32	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
838	25-02-2026	Part of : GHITORNI VILLAGE	54	Other Outage	Planned Outage	25-02-2026	14:42	25-02-2026	15:49	1:07	0.000279	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE
839	25-02-2026	Part of : AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	468	Other Outage	Planned Outage	25-02-2026	11:01	25-02-2026	12:06	1:05	0.000361	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
840	25-02-2026	Part of : VASANT KUNJ PHASE II VASANT KUNJ	16	Other Outage	Planned Outage	25-02-2026	10:28	25-02-2026	12:57	2:29	0.000414	BIRD SPIKES INSTALLATION PER POLE,HT SLEEVE INSTALLATION PER SPAN
841	26-02-2026	Part of : RANGPURI NALLAPAR RANGPURI,RANGPURI PAHARI RANGPURI,RANGPURI	2895	Other Outage	Unplanned Outage	26-02-2026	00:05	26-02-2026	00:10	0:05	0.000097	CABLE FAULT
842	26-02-2026	Part of : PALAM FARMS,	29	Other Outage	Planned Outage	26-02-2026	10:02	26-02-2026	11:20	1:18	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF GAS KIT AND OIL SEAL
843	26-02-2026	Part of : AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI,	479	Other Outage	Planned Outage	26-02-2026	11:08	26-02-2026	14:48	3:40	0.001222	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD
844	26-02-2026	Part of : GHITORNI VILLAGE GHITORNI,	147	Other Outage	Planned Outage	26-02-2026	10:56	26-02-2026	12:56	2:00	0.000667	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
845	26-02-2026	Part of : HARIJAN BASTI SECTOR B VASANT KUNJ,	187	Other Outage	Planned Outage	26-02-2026	11:03	26-02-2026	13:34	2:31	0.000419	EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
846	27-02-2026	Part of : WEST END GREENS RANGPURI,AVENUE BOUGANVILLEA RANGPURI,HARIJAN BASTI RAJOKRI,AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	223	Other Outage	Planned Outage	27-02-2026	11:04	27-02-2026	11:37	0:33	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
847	27-02-2026	Part of : GHITORNI VILLAGE	174	Other Outage	Planned Outage	27-02-2026	12:31	27-02-2026	14:27	1:56	0.000644	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,LT AB SAGGING
848	27-02-2026	Part of : POCKET 3 SECTOR C VASANT KUNJ	273	Other Outage	Planned Outage	27-02-2026	12:14	27-02-2026	13:14	1:00	0.000167	SUB STATION CLEANING
849	27-02-2026	Part of : PALAM FARMS	19	Other Outage	Planned Outage	27-02-2026	10:48	27-02-2026	12:13	1:25	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN
850	27-02-2026	Part of : MEHRAM NAGAR EAST	930	Other Outage	Planned Outage	27-02-2026	10:46	27-02-2026	12:45	1:59	0.001488	REPLACEMENT OF HT BUSHING ROD
851	27-02-2026	Part of : RUCHI VIHAR VASANT KUNJ	66	Other Outage	Planned Outage	27-02-2026	11:10	27-02-2026	13:01	1:51	0.000308	LT CIRCUIT MAINTENANCE
852	28-02-2026	Part of : KAPAS HERA EXTENSION,KAPAS HERA ESTATE	2643	Other Outage	Planned Outage	28-02-2026	10:57	28-02-2026	11:29	0:32	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
853	28-02-2026	Part of : GHITORNI VILLAGE	224	Other Outage	Planned Outage	28-02-2026	12:19	28-02-2026	13:28	1:09	0.000288	REPLACEMENT OF HT BUSHING ROD
854	28-02-2026	Part of : NSG CAMP MEHRAM NAGAR (HT CONSUMER)	1	Other Outage	Planned Outage	28-02-2026	11:40	28-02-2026	12:45	1:05	0.000813	REPLACEMENT OF FAULTY END BOX
855	28-02-2026	Part of : ICADR PLOT 6 VASANT KUNJ (HT CONSUMER)	1	Other Outage	Planned Outage	28-02-2026	10:27	28-02-2026	11:53	1:26	0.000239	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
856	02-02-2026	Part of : NAND VIHAR SECTOR 16A DWARKA,HAR NAGAR SECTOR 16 DWARKA,HARI VIHAR SECTOR 16A DWARKA,KAKRAULA VILLAGE DWARKA,	5063	Other Outage	Unplanned Outage	02-02-2026	14:38	02-02-2026	16:17	1:39	0.000000	CONNECTION/DISCONNECTION OF LT CABLE
857	09-02-2026	Part of : TRANSIT CAMP DWARKA,VIKAS NAGAR SECTOR 15 DWARKA,TARA NAGAR DWARKA	1857	Other Outage	Unplanned Outage	09-02-2026	12:09	09-02-2026	13:52	1:43	0.000000	REPAIRING OF HVDS CIRCUIT
858	09-02-2026	Part of : RASTRAPATI BHAVAN PLOT-3 SEC-10 DWARKA (HTC)	1	Other Outage	Planned Outage	09-02-2026	12:57	09-02-2026	14:49	1:52	0.000000	REPLACEMENT OF HT BUSHING ROD
859	11-02-2026	Part of : SECTOR 4 DWARKA	316	Other Outage	Planned Outage	11-02-2026	11:21	11-02-2026	13:32	2:11	0.000000	REPLACEMENT OF HT BUSHING ROD
860	12-02-2026	Part of : SECTOR 12 DWARKA	1	Other Outage	Planned Outage	12-02-2026	12:25	12-02-2026	16:34	4:09	0.000000	REPLACEMENT OF HT BUSHING ROD
861	13-02-2026	Part of : HAR NAGAR SECTOR 16 DWARKA	1252	Other Outage	Planned Outage	13-02-2026	14:45	13-02-2026	16:18	1:33	0.000000	REPLACEMET OF HT BUSHING ROD
862	13-02-2026	Part of : BHAGWATI VIHAR BINDAPUR	1587	Other Outage	Planned Outage	13-02-2026	14:11	13-02-2026	15:18	1:07	0.000000	REPLACEMENT OF LT BUSHING ROD
863	13-02-2026	Part of : JAIN COLONY MATIALA,BLOCK A & B BHARAT NAGAR MADHU VIHAR	2591	Other Outage	Planned Outage	13-02-2026	11:19	13-02-2026	13:29	2:10	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
864	13-02-2026	Part of : TRANSIT CAMP DWARKA	545	Other Outage	Planned Outage	13-02-2026	12:57	13-02-2026	15:17	2:20	0.000000	REPLACEMENT OF LT BUSHING ROD
865	14-02-2026	Part of : NISHAT PARK SECTOR 15 DWARKA,	487	Other Outage	Planned Outage	14-02-2026	11:42	14-02-2026	13:35	1:53	0.000000	REPLACEMET OF HT BUSHING ROD
866	16-02-2026	Part of : BHARAT VIHAR DWARKA	700	Other Outage	Planned Outage	16-02-2026	14:32	16-02-2026	16:30	1:58	0.000000	LT CIRCUIT MAINTENANCE
867	16-02-2026	Part of : SUBHASH PARK MATIALA	1490	Other Outage	Planned Outage	16-02-2026	12:16	16-02-2026	14:25	2:09	0.000000	REPLACEMENT OF HT BUSHING ROD
868	16-02-2026	Part of : HAR NAGAR SECTOR 16 DWARKA	1252	Other Outage	Planned Outage	16-02-2026	11:26	16-02-2026	13:54	2:28	0.000000	REPLACEMENT OF HT BUSHING ROD
869	16-02-2026	Part of : A-BLOCK SECTOR 12 DWARKA	57	Other Outage	Planned Outage	16-02-2026	11:21	16-02-2026	13:58	2:37	0.000000	LT CIRCUIT MAINTENANCE
870	17-02-2026	Part of : SEC-3 J.J.COLONY, SECTOR 3 DWARKA	1826	Other Outage	Unplanned Outage	17-02-2026	09:22	17-02-2026	09:50	0:28	0.000000	CABLE FAULT
871	17-02-2026	Part of : TRANSIT CAMP DWARKA,VIKAS NAGAR SECTOR 15 DWARKA,TARA NAGAR DWARKA	1863	Other Outage	Planned Outage	17-02-2026	11:37	17-02-2026	13:21	1:44	0.000000	REPLACEMENT OF HT BUSHING INULATOR
872	17-02-2026	Part of : TRANSIT CAMP DWARKA	545	Other Outage	Planned Outage	17-02-2026	11:37	17-02-2026	13:20	1:43	0.000000	REPLACEMENT OF LT BUSHING ROD
873	18-02-2026	Part of : BHARAT VIHAR DWARKA,POCKET 1 SECTOR 14 DWARKA	765	Other Outage	Unplanned Outage	18-02-2026	08:18	18-02-2026	08:52	0:34	0.000262	HT SYSTEM FAULT
874	18-02-2026	Part of : BLOCK A BHARAT NAGAR MADHU VIHAR,BLOCK D UTTAM VIHAR BINDAPUR,BLOCK A3 UTTAM VIHAR BINDAPUR,BLOCK A3 UTTAM VIHAR BINDAPUR,BLOCK D UTTAM VIHAR BINDAPUR,	1661	Other Outage	Unplanned Outage	18-02-2026	11:48	18-02-2026	13:47	1:59	0.000000	BUSHING REPLACEMENT
875	18-02-2026	Part of : NAND VIHAR SECTOR 16A DWARKA,	1184	Other Outage	Planned Outage	18-02-2026	12:22	18-02-2026	13:33	1:11	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
876	19-02-2026	Part of : JAIN COLONY MATIALA,BLOCK G JAIN COLONY MATIALA,BLOCK G RAJAPURI MATIALA,SECTOR 3 DWARKA	2389	Other Outage	Unplanned Outage	19-02-2026	13:09	19-02-2026	14:07	0:58	0.000746	BIRDAGE
877	19-02-2026	Part of : Part of : BHARAT VIHAR DWARKA	2569	Other Outage	Planned Outage	19-02-2026	13:36	19-02-2026	15:27	1:51	0.000000	REPLACEMENT OF HT BUSHING ROD
878	20-02-2026	Part of : HAR NAGAR SECTOR 16 DWARKA	1252	Other Outage	Planned Outage	20-02-2026	11:00	20-02-2026	13:48	2:48	0.000000	REPLACEMET OF HT BUSHING ROD
879	20-02-2026	Part of : SECTOR 10 DWARKA	79	Other Outage	Planned Outage	20-02-2026	10:12	20-02-2026	12:34	2:22	0.000000	REPLACEMET OF HT BUSHING ROD
880	21-02-2026	Part of : BLOCK A BHARAT NAGAR MADHU VIHAR,BLOCK A3 & D UTTAM VIHAR BINDAPUR	1663	Other Outage	Unplanned Outage	21-02-2026	12:37	21-02-2026	14:32	1:55	0.000000	REPAIRING OF HVDS CIRCUIT
881	21-02-2026	Part of : NISHAT PARK SECTOR 15 DWARKA	487	Other Outage	Planned Outage	21-02-2026	11:15	21-02-2026	13:22	2:07	0.000000	REPLACEMET OF HT BUSHING ROD
882	23-02-2026	Part of : SECTOR 5 DWARKA	106	Other Outage	Planned Outage	23-02-2026	13:22	23-02-2026	15:41	2:19	0.000000	REPLACEMET OF HT BUSHING ROD
883	23-02-2026	Part of : BLOCK RZ MADHU VIHAR,BLOCK A3 UTTAM VIHAR BINDAPUR	749	Other Outage	Planned Outage	23-02-2026	11:17	23-02-2026	13:50	2:33	0.000000	REPLACEMET OF HT BUSHING ROD
884	23-02-2026	Part of : SECTOR 10 DWARKA	137	Other Outage	Planned Outage	23-02-2026	10:34	23-02-2026	12:43	2:09	0.000000	REPLACEMET OF HT BUSHING ROD
885	23-02-2026	Part of : TRANSIT CAMP DWARKA	1717	Other Outage	Planned Outage	23-02-2026	12:20	23-02-2026	14:45	2:25	0.000000	LT CIRCUIT MAINTENANCE
886	24-02-2026	Part of : NISHAT PARK,A & WZ-BLOCK PATEL GARDEN SECTOR 15 DWARKA,SURAJ VIHAR DWARKA	3901	Other Outage	Unplanned Outage	24-02-2026	12:15	24-02-2026	13:01	0:46	0.001210	HT SYSTEM FAULT
887	24-02-2026	Part of : TRANSIT CAMP DWARKA	1717	Other Outage	Planned Outage	24-02-2026	15:25	24-02-2026	16:16	0:51	0.000000	LT CIRCUIT MAINTENANCE
888	24-02-2026	Part of : TRANSIT CAMP DWARKA,BHARAT VIHAR DWARKA	2046	Other Outage	Planned Outage	24-02-2026	10:57	24-02-2026	13:56	2:59	0.000000	3PH HT AB CABLE REPLACEMENT
889	25-02-2026	Part of : BLOCK D MANSARA RAM PARK UTTAM NAGAR	904	Other Outage	Planned Outage	25-02-2026	14:17	25-02-2026	15:56	1:39	0.000000	REPLACEMENT OF LT BUSHING ROD
890	26-02-2026	Part of : BLOCK D UTTAM VIHAR BINDAPUR,	1664	Other Outage	Unplanned Outage	26-02-2026	13:12	26-02-2026	14:53	1:41	0.000000	REPAIR/REPLACEMENT WORK OF HVDS CABLE
891	26-02-2026	Part of : BLOCK A BHARAT VIHAR DWARKA,VIKAS NAGAR SECTOR 15 DWARKA,TRANSIT CAMP DWARKA,TARA NAGAR DWARKA,	1864	Other Outage	Unplanned Outage	26-02-2026	12:49	26-02-2026	14:16	1:27	0.000000	REPAIR/REPLACEMENT WORK OF HVDS CABLE
892	27-02-2026	Part of : SARV PRIYA VIHAR	0	Other Outage	Unplanned Outage	27-02-2026	09:31	27-02-2026	10:22	0:51	0.000591	HT SYSTEM FAULT
893	27-02-2026	Part of : SECTOR 11 DWARKA	133	Other Outage	Planned Outage	27-02-2026	13:54	27-02-2026	15:40	1:46	0.000000	REPLACEMENT OF HT BUSHING ROD
894	27-02-2026	Part of : SECTOR 11 DWARKA	61	Other Outage	Planned Outage	27-02-2026	10:21	27-02-2026	12:16	1:55	0.000000	REPLACEMENT OF HT BUSHING ROD
895	27-02-2026	Part of : POCKET E SECTOR 17 DWARKA	394	Other Outage	Planned Outage	27-02-2026	13:57	27-02-2026	16:33	2:36	0.000000	REPLACEMENT OF HT BUSHING ROD
896	27-02-2026	Part of : HARI VIHAR SECTOR 15 DWARKA	1001	Other Outage	Planned Outage	27-02-2026	11:46	27-02-2026	13:56	2:10	0.000000	REPLACEMENT OF HT BUSHING ROD
897	02-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	2352	Other Outage	Planned Outage	02-02-2026	15:57	02-02-2026	16:52	0:55	0.000764	REPLACEMET OF HT BUSHING ROD
898	02-02-2026	Part of : PTS(POLICE TRAINING CENTER JHARONDA)	1	Other Outage	Planned Outage	02-02-2026	13:03	02-02-2026	15:00	1:57	0.001625	REPLACEMET OF HT BUSHING ROD
899	02-02-2026	Part of : SARANGPUR VILLAGE,	14	Other Outage	Planned Outage	02-02-2026	14:45	02-02-2026	16:51	2:06	0.001750	REPLACEMET OF HT BUSHING ROD
900	02-02-2026	Part of : KAIR VILLAGE,	627	Other Outage	Planned Outage	02-02-2026	11:02	02-02-2026	13:56	2:54	0.002417	REPLACEMET OF HT BUSHING ROD
901	03-02-2026	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE	1897	Other Outage	Unplanned Outage	03-02-2026	00:34	03-02-2026	01:30	0:56	0.000260	TREE TOUCHING
902	03-02-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	28	Other Outage	Planned Outage	03-02-2026	14:06	03-02-2026	16:41	2:35	0.001722	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
903	03-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1431	Other Outage	Planned Outage	03-02-2026	12:44	03-02-2026	14:45	2:01	0.001681	REPLACEMENT OF HT BUSHING ROD
904	03-02-2026	Part of : MANDHELA KHURD VILLAGE	423	Other Outage	Planned Outage	03-02-2026	10:59	03-02-2026	13:12	2:13	0.001847	REPLACEMENT OF HT BUSHING ROD
905	04-02-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	731	Other Outage	Planned Outage	04-02-2026	14:40	04-02-2026	16:12	1:32	0.001022	REPLACEMET OF HT BUSHING ROD
906	04-02-2026	Part of : RAWTA VILLAGE	14	Other Outage	Planned Outage	04-02-2026	14:40	04-02-2026	16:24	1:44	0.001156	REPLACEMET OF HT BUSHING ROD
907	04-02-2026	Part of : BASCO COLONY ARYA NAGAR NAJAFGARH	22	Other Outage	Planned Outage	04-02-2026	14:06	04-02-2026	16:35	2:29	0.001656	REPLACEMET OF HT BUSHING ROD
908	04-02-2026	Part of : BADHOSRA	6	Other Outage	Planned Outage	04-02-2026	11:04	04-02-2026	12:52	1:48	0.001500	REPLACEMET OF HT BUSHING ROD
909	04-02-2026	Part of : MANDHELA KALAN VILLAGE	11	Other Outage	Planned Outage	04-02-2026	12:06	04-02-2026	14:01	1:55	0.001597	REPLACEMET OF HT BUSHING ROD
910	04-02-2026	Part of : SRI HANS NAGAR	523	Other Outage	Planned Outage	04-02-2026	13:42	04-02-2026	16:23	2:41	0.002236	REPLACEMENT OF HT BUSHING ROD
911	05-02-2026	Part of : MALIKPUR ZER VILLAGE,SAMAZPUR KHALSA	1963	Other Outage	Unplanned Outage	05-02-2026	18:07	05-02-2026	18:56	0:49	0.000000	CABLE FAULT
912	05-02-2026	Part of : MANDHELA KALAN VILLAGE	20	Other Outage	Planned Outage	05-02-2026	15:09	05-02-2026	16:08	0:59	0.000819	REPLACEMET OF HT BUSHING ROD
913	05-02-2026	Part of : MITRAON VILLAGE NAJAFGARH	242	Other Outage	Planned Outage	05-02-2026	15:08	05-02-2026	16:09	1:01	0.000847	REPLACEMET OF HT BUSHING ROD
914	05-02-2026	Part of : KHERA DABAS VILLAGE,JAFARPUR KALAN VILLAGE,UJWA VILLAGE	1197	Other Outage	Planned Outage	05-02-2026	12:04	05-02-2026	14:42	2:38	0.002194	GUARD WIRE LACS INSTALLTION PER SPAN
915	05-02-2026	Part of : KRISHAN VIHAR NAJAFGARH	2	Other Outage	Planned Outage	05-02-2026	11:00	05-02-2026	13:44	2:44	0.000911	REPLACEMENT OF LT BUSHING ROD
916	06-02-2026	Part of : UJWA VILLAGE,	406	Other Outage	Planned Outage	06-02-2026	14:27	06-02-2026	16:35	2:08	0.002489	REPLACEMENT OF LT BUSHING ROD
917	06-02-2026	Part of : KRISHAN VIHAR NAJAFGARH,	7	Other Outage	Planned Outage	06-02-2026	12:16	06-02-2026	14:55	2:39	0.000883	REPLACEMENT OF LT BUSHING ROD
918	06-02-2026	Part of : DHANSA VILLAGE,	267	Other Outage	Planned Outage	06-02-2026	12:10	06-02-2026	14:55	2:45	0.002292	REPLACEMENT OF HT BUSHING ROD
919	06-02-2026	Part of : MANDHELA KHURD VILLAGE,	16	Other Outage	Planned Outage	06-02-2026	11:18	06-02-2026	14:06	2:48	0.002333	REPLACEMENT OF HT BUSHING ROD
920	07-02-2026	Part of : NEHA COLONY NEW,BLOCK B NANDA ENCLAVE	320	Other Outage	Planned Outage	07-02-2026	15:10	07-02-2026	16:03	0:53	0.000736	REPLACEMENT OF HT BUSHING ROD
921	07-02-2026	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN	1	Other Outage	Planned Outage	07-02-2026	14:04	07-02-2026	16:02	1:58	0.001639	REPLACEMENT OF HT BUSHING ROD
922	07-02-2026	Part of : JAFARPUR KALAN VILLAGE	271	Other Outage	Planned Outage	07-02-2026	14:06	07-02-2026	16:02	1:56	0.001611	REPLACEMENT OF HT BUSHING ROD
923	07-02-2026	Part of : DTC DEPOT GHUMAN HERA (HT CONSUMER)	1	Other Outage	Planned Outage	07-02-2026	13:29	07-02-2026	15:41	2:12	0.001833	REPLACEMENT OF HT BUSHING ROD
924	07-02-2026	Part of : MANDHELA KHURD VILLAGE,KAIR VILLAGE,MANDHELA KALAN VILLAGE,RAWTA JAFARPUR KALAN VILLAGE,MITRAON VILLAGE NAJAFGARH	834	Other Outage	Planned Outage	07-02-2026	11:00	07-02-2026	13:18	2:18	0.001917	REPLACEMENT OF HT BUSHING ROD
925	09-02-2026	Part of : SUREHRA VILLAGE,KHERA DABAS VILLAGE,GOPAL EXTENSION II NAJAFGARH	2747	Other Outage	Planned Outage	09-02-2026	15:41	09-02-2026	16:41	1:00	0.000833	REPLACEMENT OF HT BUSHING ROD
926	09-02-2026	Part of : MALIKPUR ZER VILLAGE,JAFARPUR KALAN VILLAGE,SAMAZPUR KHALSA	1664	Other Outage	Planned Outage	09-02-2026	15:08	09-02-2026	16:44	1:36	0.001333	GUARD WIRES SAGGING PER SPAN
927	09-02-2026	Part of : GHALLBPUR VILLAGE	1	Other Outage	Planned Outage	09-02-2026	15:07	09-02-2026	16:42	1:35	0.001319	REPLACEMENT OF HT BUSHING ROD
928	09-02-2026	Part of : KRISHAN VIHAR NAJAFGARH	6	Other Outage	Planned Outage	09-02-2026	14:02	09-02-2026	15:53	1:51	0.001542	REPLACEMENT OF HT BUSHING ROD
929	09-02-2026	Part of : ISSAPUR VILLAGE,BAQAR GARH VILLAGE,BADHOSRA	3295	Other Outage	Planned Outage	09-02-2026	12:22	09-02-2026	14:07	1:45	0.001458	REPLACEMENT OF HT BUSHING ROD
930	10-02-2026	Part of : GHUMAN HERA JAINPUR VILLAGE,	1	Other Outage	Planned Outage	10-02-2026	16:01	10-02-2026	16:52	0:51	0.000567	REPLACEMET OF HT BUSHING ROD
931	10-02-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE,	1003	Other Outage	Planned Outage	10-02-2026	15:58	10-02-2026	16:50	0:52	0.000578	REPLACEMET OF HT BUSHING ROD
932	10-02-2026	Part of : GOPAL EXTENSION II NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	5	Other Outage	Planned Outage	10-02-2026	16:00	10-02-2026	16:49	0:49	0.000681	REPLACEMET OF HT BUSHING ROD
933	10-02-2026	Part of : KRISHAN VIHAR NAJAFGARH,	7	Other Outage	Planned Outage	10-02-2026	14:19	10-02-2026	16:32	2:13	0.001478	REPLACEMET OF HT BUSHING ROD
934	10-02-2026	Part of : ISSAPUR VILLAGE,BAQAR GARH VILLAGE,BADHOSRA,JAFARPUR KALAN VILLAGE,QAZIPUR VILLAGE,MANDHELA KALAN VILLAGE,	3295	Other Outage	Planned Outage	10-02-2026	13:28	10-02-2026	15:45	2:17	0.001903	REPLACEMET OF HT BUSHING ROD
935	11-02-2026	Part of : NEHA COLONY & BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	1053	Other Outage	Planned Outage	11-02-2026	15:30	11-02-2026	16:45	1:15	0.001042	REPLACEMENT OF HT BUSHING ROD
936	11-02-2026	Part of : DAURALA VILLAGE	12	Other Outage	Planned Outage	11-02-2026	15:15	11-02-2026	16:46	1:31	0.001011	REPLACEMENT OF HT BUSHING ROD
937	11-02-2026	Part of : JAFARPUR KALAN VILLAGE	448	Other Outage	Planned Outage	11-02-2026	14:49	11-02-2026	16:44	1:55	0.001278	REPLACEMENT OF HT BUSHING ROD
938	11-02-2026	Part of : JAFARPUR KALAN VILLAGE	8	Other Outage	Planned Outage	11-02-2026	14:32	11-02-2026	15:46	1:14	0.001028	REPLACEMENT OF HT BUSHING ROD
939	11-02-2026	Part of : KRISHAN VIHAR NAJAFGARH	4	Other Outage	Planned Outage	11-02-2026	14:06	11-02-2026	16:44	2:38	0.001756	REPLACEMENT OF HT BUSHING ROD
940	11-02-2026	Part of : SARANGPUR VILLAGE,QAZIPUR VILLAGE,DHANSA VILLAGE,JAFARPUR KALAN VILLAGE,ISSAPUR VILLAGE,BADHOSRA	3689	Other Outage	Planned Outage	11-02-2026	10:58	11-02-2026	13:53	2:55	0.002431	REPLACEMENT OF HT BUSHING ROD
941	12-02-2026	Part of : KHERA DABAS VILLAGE	698	Other Outage	Planned Outage	12-02-2026	13:58	12-02-2026	15:54	1:56	0.001611	REPLACEMENT OF HT BUSHING ROD
942	12-02-2026	Part of : SAMAZPUR KHALSA	190	Other Outage	Planned Outage	12-02-2026	14:08	12-02-2026	15:53	1:45	0.001750	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
943	12-02-2026	Part of : SARANGPUR VILLAGE,QAZIPUR VILLAGE,DHANSA VILLAGE,JAFARPUR KALAN VILLAGE,ISSAPUR VILLAGE,BADHOSRA	3689	Other Outage	Planned Outage	12-02-2026	11:37	12-02-2026	14:01	2:24	0.002000	REPLACEMENT OF HT BUSHING ROD
944	13-02-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	14	Other Outage	Planned Outage	13-02-2026	13:48	13-02-2026	15:38	1:50	0.001833	REPLACEMET OF HT BUSHING ROD
945	13-02-2026	Part of : BADHOSRA	318	Other Outage	Planned Outage	13-02-2026	11:16	13-02-2026	13:05	1:49	0.001514	REPLACEMET OF HT BUSHING ROD
946	13-02-2026	Part of : MANDHELA KHURD VILLAGE	16	Other Outage	Planned Outage	13-02-2026	13:25	13-02-2026	15:39	2:14	0.001861	REPLACEMET OF HT BUSHING ROD
947	13-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	2357	Other Outage	Planned Outage	13-02-2026	13:37	13-02-2026	15:39	2:02	0.001694	REPLACEMET OF HT BUSHING ROD
948	13-02-2026	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN	3	Other Outage	Planned Outage	13-02-2026	13:13	13-02-2026	15:38	2:25	0.002417	REPLACEMET OF HT BUSHING ROD
949	13-02-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	732	Other Outage	Planned Outage	13-02-2026	11:15	13-02-2026	13:28	2:13	0.002217	REPLACEMET OF HT BUSHING ROD
950	14-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,	1434	Other Outage	Planned Outage	14-02-2026	14:22	14-02-2026	16:02	1:40	0.001389	REPLACEMET OF HT BUSHING ROD
951	14-02-2026	Part of : UJWA VILLAGE,	466	Other Outage	Planned Outage	14-02-2026	14:23	14-02-2026	16:01	1:38	0.001361	REPLACEMET OF HT BUSHING ROD
952	14-02-2026	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN,	4	Other Outage	Planned Outage	14-02-2026	11:59	14-02-2026	14:26	2:27	0.002042	REPLACEMET OF HT BUSHING ROD
953	14-02-2026	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE,	1470	Other Outage	Planned Outage	14-02-2026	10:12	14-02-2026	12:40	2:28	0.002056	REPLACEMET OF HT BUSHING ROD
954	16-02-2026	Part of : DABAR ENCLAVE,NEW CRPF,FATAH VILL MITRAON,AIR FORCE STATION DHANSA,MTNL TOWER,RAWTA MOD,BAKKARGARH MOD	1	Other Outage	Unplanned Outage	16-02-2026	08:56	16-02-2026	08:58	0:02	0.000004	BIRDAGE
955	16-02-2026	Part of : KAIR VILLAGE	489	Other Outage	Planned Outage	16-02-2026	12:34	16-02-2026	14:05	1:31	0.001264	REPLACEMENT OF HT BUSHING ROD
956	16-02-2026	Part of : ISSAPUR VILLAGE	16	Other Outage	Planned Outage	16-02-2026	11:48	16-02-2026	13:44	1:56	0.001611	REPLACEMENT OF HT BUSHING ROD
957	16-02-2026	Part of : JHULJHULI VILLAGE	23	Other Outage	Planned Outage	16-02-2026	13:00	16-02-2026	15:38	2:38	0.002194	REPLACEMENT OF HT BUSHING ROD
958	16-02-2026	Part of : D-BLOCK BANGALI COLONY NAVEEN PALACE JHARODA KALAN	5	Other Outage	Planned Outage	16-02-2026	12:22	16-02-2026	14:37	2:15	0.001875	REPLACEMENT OF HT BUSHING ROD
959	16-02-2026	Part of : MALIKPUR ZER VILLAGE,JAFARPUR KALAN VILLAGE,SAMAZPUR KHALSA	1664	Other Outage	Planned Outage	16-02-2026	12:21	16-02-2026	14:37	2:16	0.001889	GUARD WIRES SAGGING
960	17-02-2026	Part of : KHERA DABAS VILLAGE	256	Other Outage	Planned Outage	17-02-2026	15:13	17-02-2026	16:50	1:37	0.001347	REPLACEMET OF HT BUSHING ROD
961	17-02-2026	Part of : MANDHELA KHURD VILLAGE	3	Other Outage	Planned Outage	17-02-2026	12:26	17-02-2026	13:58	1:32	0.001278	REPLACEMET OF HT BUSHING ROD
962	17-02-2026	Part of : BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN	3	Other Outage	Planned Outage	17-02-2026	11:13	17-02-2026	13:27	2:14	0.001489	REPLACEMET OF HT BUSHING ROD
963	17-02-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	1003	Other Outage	Planned Outage	17-02-2026	10:32	17-02-2026	12:43	2:11	0.001456	REPLACEMET OF HT BUSHING ROD
964	17-02-2026	Part of : DHANSA VILLAGE	11	Other Outage	Planned Outage	17-02-2026	10:42	17-02-2026	12:44	2:02	0.001694	REPLACEMET OF HT BUSHING ROD
965	18-02-2026	Part of : JAIN PUR VILLAGE,	5	Other Outage	Planned Outage	18-02-2026	15:51	18-02-2026	16:40	0:49	0.000817	REPLACEMENT OF HT BUSHING ROD
966	18-02-2026	Part of : KAIR VILLAGE,MANDHELA KHURD VILLAGE,	1487	Other Outage	Planned Outage	18-02-2026	15:52	18-02-2026	16:39	0:47	0.000131	REPLACEMET OF HT BUSHING ROD
967	18-02-2026	Part of : DHANSA VILLAGE,	384	Other Outage	Planned Outage	18-02-2026	14:03	18-02-2026	15:01	0:58	0.000806	REPLACEMET OF HT BUSHING ROD
968	18-02-2026	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN,	2	Other Outage	Planned Outage	18-02-2026	11:17	18-02-2026	13:39	2:22	0.001578	REPLACEMET OF HT BUSHING ROD
969	18-02-2026	Part of : SRI HANS NAGAR,	528	Other Outage	Planned Outage	18-02-2026	11:03	18-02-2026	13:39	2:36	0.002167	REPLACEMET OF HT BUSHING ROD
970	19-02-2026	Part of : Part of : Z-BLOCK CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	705	Other Outage	Planned Outage	19-02-2026	11:13	19-02-2026	13:36	2:23	0.001986	REPLACEMENT OF HT BUSHING ROD
971	19-02-2026	Part of : Part of : MALIKPUR ZER VILLAGE	336	Other Outage	Planned Outage	19-02-2026	11:33	19-02-2026	13:35	2:02	0.002033	REPLACEMENT OF HT BUSHING ROD
972	20-02-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	248	Other Outage	Planned Outage	20-02-2026	14:33	20-02-2026	16:31	1:58	0.001639	REPLACEMET OF HT BUSHING ROD
973	20-02-2026	Part of : POLICE TRAINING SCHOOL JHARODA (HT CONSUMER)	1	Other Outage	Planned Outage	20-02-2026	13:26	20-02-2026	15:23	1:57	0.001950	REPLACEMET OF HT BUSHING ROD
974	20-02-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	730	Other Outage	Planned Outage	20-02-2026	10:38	20-02-2026	12:15	1:37	0.001617	REPLACEMET OF HT BUSHING ROD
975	20-02-2026	Part of : ISSAPUR VILLAGE	45	Other Outage	Planned Outage	20-02-2026	13:55	20-02-2026	16:10	2:15	0.001875	REPLACEMET OF HT BUSHING ROD
976	21-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR, BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	2357	Other Outage	Planned Outage	21-02-2026	11:58	21-02-2026	13:06	1:08	0.000944	REPLACEMET OF HT BUSHING ROD
977	21-02-2026	Part of : KHERA DABAS VILLAGE	254	Other Outage	Planned Outage	21-02-2026	10:50	21-02-2026	12:58	2:08	0.001778	REPLACEMET OF HT BUSHING ROD
978	22-02-2026	Part of : MANDHELA KHURD VILLAGE,KAIR VILLAGE,MANDHELA KALAN VILLAGE,RAWTA JAFARPUR KALAN VILLAGE,MITRAON VILLAGE NAJAFGARH	932	Other Outage	Unplanned Outage	22-02-2026	10:15	22-02-2026	10:26	0:11	0.000102	TRANSIENT FAULT
979	23-02-2026	Part of : DHANSA VILLAGE	355	Other Outage	Planned Outage	23-02-2026	10:58	23-02-2026	12:40	1:42	0.001417	REPLACEMET OF HT BUSHING ROD
980	23-02-2026	Part of : MALIKPUR ZER VILLAGE	276	Other Outage	Planned Outage	23-02-2026	13:24	23-02-2026	15:32	2:08	0.001778	REPLACEMET OF HT BUSHING ROD
981	23-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1434	Other Outage	Planned Outage	23-02-2026	11:17	23-02-2026	13:34	2:17	0.001903	REPLACEMET OF HT BUSHING ROD
982	24-02-2026	Part of : MANDHELA KHURD VILLAGE	8	Other Outage	Planned Outage	24-02-2026	12:47	24-02-2026	14:08	1:21	0.001125	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
983	24-02-2026	Part of : ISSAPUR VILLAGE	248	Other Outage	Planned Outage	24-02-2026	11:25	24-02-2026	13:25	2:00	0.001667	REPLACEMENT OF HT BUSHING ROD
984	24-02-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	1003	Other Outage	Planned Outage	24-02-2026	12:07	24-02-2026	14:24	2:17	0.001522	REPLACEMENT OF HT BUSHING ROD
985	24-02-2026	Part of : SRI HANS NAGAR	528	Other Outage	Planned Outage	24-02-2026	11:30	24-02-2026	13:33	2:03	0.001708	REPLACEMENT OF HT BUSHING ROD
986	25-02-2026	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE	1470	Other Outage	Planned Outage	25-02-2026	11:27	25-02-2026	13:09	1:42	0.001417	REPLACEMET OF HT BUSHING ROD
987	25-02-2026	Part of : SARANGPUR VILLAGE,QAZIPUR VILLAGE,DHANSA VILLAGE	3689	Other Outage	Planned Outage	25-02-2026	10:28	25-02-2026	12:15	1:47	0.001486	REPLACEMET OF HT BUSHING ROD
988	25-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR, BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	1053	Other Outage	Planned Outage	25-02-2026	12:09	25-02-2026	14:29	2:20	0.001944	REPLACEMET OF HT BUSHING ROD
989	25-02-2026	Part of : KHERA DABAS VILLAGE,SHERPUR EXTENTION,JAFARPUR KALAN VILLAGE	1205	Other Outage	Planned Outage	25-02-2026	12:02	25-02-2026	14:37	2:35	0.002153	REPLACEMET OF HT BUSHING ROD
990	26-02-2026	Part of : GOPAL EXTENSION II NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	5	Other Outage	Planned Outage	26-02-2026	15:06	26-02-2026	16:10	1:04	0.000889	REPLACEMET OF HT BUSHING ROD
991	26-02-2026	Part of : ISSAPUR VILLAGE,	268	Other Outage	Planned Outage	26-02-2026	11:37	26-02-2026	13:34	1:57	0.001625	REPLACEMET OF HT BUSHING ROD
992	26-02-2026	Part of : MANDHELA KHURD VILLAGE,	165	Other Outage	Planned Outage	26-02-2026	11:37	26-02-2026	13:15	1:38	0.001361	REPLACEMET OF HT BUSHING ROD
993	26-02-2026	Part of : HTC:POWER G CORP.765/400KV STN GHUMANHER	1	Other Outage	Planned Outage	26-02-2026	12:56	26-02-2026	15:31	2:35	0.002153	REPLACEMET OF HT BUSHING ROD
994	27-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	3086	Other Outage	Unplanned Outage	27-02-2026	11:57	27-02-2026	12:56	0:59	0.000819	ATTENDING WEAK POINTS/HOT SPOT
995	27-02-2026	Part of : KHERA DABAS VILLAGE	160	Other Outage	Planned Outage	27-02-2026	15:09	27-02-2026	16:26	1:17	0.001283	REPLACEMENT OF HT BUSHING ROD
996	27-02-2026	Part of : SUREHRA VILLAGE	471	Other Outage	Planned Outage	27-02-2026	14:44	27-02-2026	16:16	1:32	0.001278	REPLACEMENT OF HT BUSHING ROD
997	27-02-2026	Part of : JAIN PUR VILLAGE	2	Other Outage	Planned Outage	27-02-2026	14:36	27-02-2026	16:26	1:50	0.001833	REPLACEMENT OF HT BUSHING ROD
998	27-02-2026	Part of : D-BLOCK BANGALI COLONY NAVEEN PALACE JHARODA KALAN	156	Other Outage	Planned Outage	27-02-2026	13:47	27-02-2026	15:13	1:26	0.001433	REPLACEMENT OF HT BUSHING ROD
999	27-02-2026	Part of : BAQAR GARH VILLAGE	303	Other Outage	Planned Outage	27-02-2026	11:10	27-02-2026	12:42	1:32	0.001278	REPLACEMENT OF HT BUSHING ROD
1000	27-02-2026	Part of : KAIR VILLAGE	27	Other Outage	Planned Outage	27-02-2026	13:11	27-02-2026	15:15	2:04	0.001722	REPLACEMENT OF HT BUSHING ROD
1001	28-02-2026	Part of : NEHA COLONY & B-BLOCK NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	320	Other Outage	Planned Outage	28-02-2026	14:59	28-02-2026	16:13	1:14	0.001028	REPLACEMENT OF HT BUSHING ROD
1002	28-02-2026	Part of : HAIBUTPUR	384	Other Outage	Planned Outage	28-02-2026	12:58	28-02-2026	14:11	1:13	0.001014	REPLACEMENT OF HT BUSHING ROD
1003	28-02-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	1003	Other Outage	Planned Outage	28-02-2026	12:14	28-02-2026	13:48	1:34	0.001306	REPLACEMENT OF HT BUSHING ROD
1004	01-02-2026	Part of : DISTRICT CENTRE JANAK PURI, WEST END MALL (HTC), JANAKPURI CLUB (HTC)	21	Other Outage	Unplanned Outage	01-02-2026	15:16	01-02-2026	16:08	0:52	0.000232	FAULT IN HT CONSUMER PANEL (WEST END MALL)
1005	01-02-2026	Part of : DISTRICT CENTRE JANAK PURI	79	Other Outage	Planned Outage	01-02-2026	13:49	01-02-2026	14:52	1:03	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1006	02-02-2026	Part of : CHANDAR NAGAR JANAK PURI,	137	Other Outage	Planned Outage	02-02-2026	11:54	02-02-2026	13:42	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1007	02-02-2026	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI,	621	Other Outage	Planned Outage	02-02-2026	11:34	02-02-2026	13:09	1:35	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1008	02-02-2026	Part of : POCKET D 1A JANAK PURI,	4	Other Outage	Planned Outage	02-02-2026	11:33	02-02-2026	12:52	1:19	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1009	02-02-2026	Part of : BLOCK 4 SUBHASH NAGAR,	459	Other Outage	Planned Outage	02-02-2026	11:23	02-02-2026	14:29	3:06	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1010	02-02-2026	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	550	Other Outage	Planned Outage	02-02-2026	11:33	02-02-2026	13:41	2:08	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1011	03-02-2026	Part of : BLOCK A-1 JANAK PURI	14	Other Outage	Planned Outage	03-02-2026	11:40	03-02-2026	13:36	1:56	0.000000	LT CIRCUIT MAINTENANCE
1012	03-02-2026	Part of : BLOCK B PATEL BLOCK RAGHU NAGAR DABRI	965	Other Outage	Planned Outage	03-02-2026	12:02	03-02-2026	13:32	1:30	0.000000	LT CIRCUIT MAINTENANCE
1013	03-02-2026	Part of : BLOCK EC MAYA ENCLAVE HARI NAGAR	457	Other Outage	Planned Outage	03-02-2026	12:40	03-02-2026	16:26	3:46	0.001883	DT REPLACEMENT
1014	03-02-2026	Part of : BLOCK C 4E JANAK PURI	362	Other Outage	Planned Outage	03-02-2026	12:05	03-02-2026	14:15	2:10	0.000000	LT CIRCUIT MAINTENANCE
1015	03-02-2026	Part of : BLOCK R RAJOURI GARDEN	428	Other Outage	Planned Outage	03-02-2026	11:14	03-02-2026	13:14	2:00	0.000000	LT CIRCUIT MAINTENANCE
1016	04-02-2026	Part of : A-BLOCK RAJOURI GARDEN	229	Other Outage	Planned Outage	04-02-2026	10:58	04-02-2026	13:10	2:12	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1017	04-02-2026	Part of : RZ-BLOCK MOHAN NAGAR SAGARPUR MAIN	678	Other Outage	Planned Outage	04-02-2026	11:41	04-02-2026	13:42	2:01	0.000000	LT CIRCUIT MAINTENANCE
1018	04-02-2026	Part of : EA-BLOCK MAYA ENCLAVE HARI NAGAR	165	Other Outage	Planned Outage	04-02-2026	11:24	04-02-2026	13:09	1:45	0.000000	LT CIRCUIT MAINTENANCE
1019	04-02-2026	Part of : C 4B-BLOCK JANAK PURI	537	Other Outage	Planned Outage	04-02-2026	11:42	04-02-2026	13:14	1:32	0.000000	LT CIRCUIT MAINTENANCE
1020	05-02-2026	Part of : BLOCK J 13 RAJOURI GARDEN	192	Other Outage	Planned Outage	05-02-2026	15:42	05-02-2026	16:03	0:21	0.000000	REPLACEMET OF FAULTY END BOX
1021	05-02-2026	Part of : BLOCK B FATEH NAGAR JANAK PURI	258	Other Outage	Planned Outage	05-02-2026	14:46	05-02-2026	16:02	1:16	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
1022	05-02-2026	Part of : BLOCK C2 JANAK PURI	169	Other Outage	Planned Outage	05-02-2026	11:22	05-02-2026	13:04	1:42	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1023	05-02-2026	Part of : RAJOURI GARDEN	83	Other Outage	Planned Outage	05-02-2026	11:12	05-02-2026	12:40	1:28	0.000000	OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1024	05-02-2026	Part of : BLOCK D MAYAPURI INDUSTRIAL AREA PHASE II	187	Other Outage	Planned Outage	05-02-2026	11:24	05-02-2026	13:06	1:42	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1025	05-02-2026	Part of : POCKET G HARI NAGAR JANAK PURI	1152	Other Outage	Planned Outage	05-02-2026	11:14	05-02-2026	15:02	3:48	0.001900	DT REPLACEMENT
1026	05-02-2026	Part of : POCKET B FATEH NAGAR	1185	Other Outage	Planned Outage	05-02-2026	11:28	05-02-2026	15:00	3:32	0.001178	DT REPLACEMENT
1027	05-02-2026	Part of : BLOCK 58 ASHOK NAGAR	485	Other Outage	Planned Outage	05-02-2026	10:56	05-02-2026	13:38	2:42	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1028	06-02-2026	Part of : MEENAKSHI GARDEN ASHOK NAGAR,BLOCK 1 SUBHASH NAGAR,BLOCK 1 ASHOK NAGAR	2707	Other Outage	Unplanned Outage	06-02-2026	11:34	06-02-2026	12:44	1:10	0.001566	CABLE FAULT
1029	06-02-2026	Part of : BLOCK 5 SUBHASH NAGAR,	567	Other Outage	Planned Outage	06-02-2026	10:15	06-02-2026	13:51	3:36	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1030	06-02-2026	Part of : BLOCK A-1 JANAK PURI,	107	Other Outage	Planned Outage	06-02-2026	11:39	06-02-2026	14:46	3:07	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1031	06-02-2026	Part of : POCKET D 1C LAJWANTI GARDEN JANAK PURI,	378	Other Outage	Planned Outage	06-02-2026	11:47	06-02-2026	14:30	2:43	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1032	06-02-2026	Part of : BLOCK C 2B JANAK PURI,	393	Other Outage	Planned Outage	06-02-2026	11:41	06-02-2026	13:51	2:10	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1033	07-02-2026	Part of : ADITI APARTMENTS JANAK PURI	349	Other Outage	Planned Outage	07-02-2026	11:51	07-02-2026	13:34	1:43	0.000000	LT CIRCUIT MAINTENANCE
1034	07-02-2026	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE-2	355	Other Outage	Planned Outage	07-02-2026	11:50	07-02-2026	13:33	1:43	0.000000	LT CIRCUIT MAINTENANCE
1035	07-02-2026	Part of : BLOCK J 13 RAJOURI GARDEN	548	Other Outage	Planned Outage	07-02-2026	13:55	07-02-2026	17:23	3:28	0.001733	DT REPLACEMENT
1036	07-02-2026	Part of : BLOCK 4 ASHOK NAGAR	581	Other Outage	Planned Outage	07-02-2026	11:08	07-02-2026	13:48	2:40	0.000000	LT CIRCUIT MAINTENANCE
1037	08-02-2026	Part of : DISTRICT CENTRE JANAK PURI	88	Other Outage	Planned Outage	08-02-2026	11:09	08-02-2026	13:05	1:56	0.000644	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER,REPLACEMENT OF GAS KIT AND OIL SEAL
1038	09-02-2026	Part of : MANAK VIHAR TIHAR VILLAGE	768	Other Outage	Planned Outage	09-02-2026	13:41	09-02-2026	15:27	1:46	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1039	09-02-2026	Part of : PRATAP NAGAR MAYA ENCLAVE HARI NAGAR	581	Other Outage	Planned Outage	09-02-2026	11:51	09-02-2026	13:13	1:22	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF SILICAGEL IN BREATHER
1040	09-02-2026	Part of : BLOCK A-1 JANAK PURI	28	Other Outage	Planned Outage	09-02-2026	11:45	09-02-2026	13:15	1:30	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
1041	09-02-2026	Part of : BLOCK C 1A JANAK PURI	342	Other Outage	Planned Outage	09-02-2026	11:32	09-02-2026	13:46	2:14	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1042	10-02-2026	Part of : BLOCK WZ LAJWANTI GARDEN JANAK PURI,	730	Other Outage	Planned Outage	10-02-2026	11:48	10-02-2026	13:22	1:34	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1043	10-02-2026	Part of : BLOCK CB MAYA ENCLAVE HARI NAGAR,	313	Other Outage	Planned Outage	10-02-2026	11:24	10-02-2026	14:28	3:04	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1044	10-02-2026	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI,	568	Other Outage	Planned Outage	10-02-2026	11:24	10-02-2026	13:59	2:35	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1045	10-02-2026	Part of : MANAK VIHAR TIHAR VILLAGE,	816	Other Outage	Planned Outage	10-02-2026	10:38	10-02-2026	13:58	3:20	0.000000	REPLACEMENT OF LT BUSHING ROD
1046	11-02-2026	Part of : TIHAR CENTRAL JAIL JANAK PURI	65	Other Outage	Planned Outage	11-02-2026	12:48	11-02-2026	14:17	1:29	0.000000	LT CIRCUIT MAINTENANCE
1047	11-02-2026	Part of : BLOCK C3 RAJOURI GARDEN	175	Other Outage	Planned Outage	11-02-2026	12:56	11-02-2026	16:07	3:11	0.001592	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1048	11-02-2026	Part of : POCKET S MAYAPURI INDUSTRIAL AREA PHASE II	388	Other Outage	Planned Outage	11-02-2026	11:30	11-02-2026	13:38	2:08	0.000000	LT CIRCUIT MAINTENANCE
1049	11-02-2026	Part of : BLOCK C4F JANAK PURI	658	Other Outage	Planned Outage	11-02-2026	11:36	11-02-2026	13:40	2:04	0.000000	LT CIRCUIT MAINTENANCE
1050	11-02-2026	Part of : BLOCK J BERI WALA BAGH HARI NAGAR	561	Other Outage	Planned Outage	11-02-2026	11:30	11-02-2026	14:37	3:07	0.000000	LT CIRCUIT MAINTENANCE
1051	12-02-2026	Part of : POCKET B FATEH NAGAR	676	Other Outage	Unplanned Outage	12-02-2026	12:24	12-02-2026	15:02	2:38	0.000878	LAYING OF NEW LTAB CABLE
1052	12-02-2026	Part of : WZ-BLOCK LAJWANTI GARDEN JANAK PURI	559	Other Outage	Planned Outage	12-02-2026	14:00	12-02-2026	15:22	1:22	0.000456	LT CIRCUIT MAINTENANCE
1053	12-02-2026	Part of : A 5A-BLOCK A POSSANGIPUR VILLAGE JANAK PURI	178	Other Outage	Planned Outage	12-02-2026	14:28	12-02-2026	15:38	1:10	0.000389	LT CIRCUIT MAINTENANCE
1054	12-02-2026	Part of : CA-BLOCK HARI NAGAR	480	Other Outage	Planned Outage	12-02-2026	11:30	12-02-2026	13:00	1:30	0.000500	LT CIRCUIT MAINTENANCE
1055	12-02-2026	Part of : B 3A-BLOCK JANAK PURI	433	Other Outage	Planned Outage	12-02-2026	12:28	12-02-2026	16:39	4:11	0.002440	DT REPLACEMENT
1056	12-02-2026	Part of : C 4D-BLOCK JANAK PURI	320	Other Outage	Planned Outage	12-02-2026	11:28	12-02-2026	13:29	2:01	0.000672	LT CIRCUIT MAINTENANCE
1057	12-02-2026	Part of : BLOCK 2 SUBHASH NAGAR	368	Other Outage	Planned Outage	12-02-2026	10:49	12-02-2026	13:53	3:04	0.001022	LT CIRCUIT MAINTENANCE
1058	13-02-2026	Part of : BLOCK A2,A3 & A2B ASALATPUR VILLAGE, CHANDAR NAGAR JANAK PURI	3013	Other Outage	Unplanned Outage	13-02-2026	11:31	13-02-2026	11:38	0:07	0.000000	REPAIR OF RMU
1059	13-02-2026	Part of : POSSANGIPUR VILLAGE JANAK PURI	779	Other Outage	Planned Outage	13-02-2026	12:13	13-02-2026	14:07	1:54	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
1060	13-02-2026	Part of : BLOCK D MAYAPURI INDUSTRIAL AREA PHASE II	728	Other Outage	Planned Outage	13-02-2026	12:03	13-02-2026	13:56	1:53	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1061	13-02-2026	Part of : BLOCK CB HARI NAGAR	601	Other Outage	Planned Outage	13-02-2026	11:39	13-02-2026	12:55	1:16	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF SILICAGEL IN BREATHER
1062	13-02-2026	Part of : MANAK VIHAR TIHAR VILLAGE	427	Other Outage	Planned Outage	13-02-2026	10:59	13-02-2026	13:20	2:21	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1063	13-02-2026	Part of : BLOCK C2 JANAK PURI	14	Other Outage	Planned Outage	13-02-2026	11:21	13-02-2026	14:01	2:40	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1064	13-02-2026	Part of : BLOCK 4 SUBHASH NAGAR	459	Other Outage	Planned Outage	13-02-2026	10:15	13-02-2026	13:13	2:58	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1065	14-02-2026	Part of : DELHI HAAT VIRENDER NAGAR, HTC: DILLI HAAT JANAKPURI	1	Other Outage	Unplanned Outage	14-02-2026	14:49	14-02-2026	16:33	1:44	0.000347	CABLE FAULT
1066	14-02-2026	Part of : BLOCK 3 SUBHASH NAGAR,	674	Other Outage	Planned Outage	14-02-2026	13:03	14-02-2026	14:46	1:43	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1067	14-02-2026	Part of : BLOCK 5 SUBHASH NAGAR,	567	Other Outage	Planned Outage	14-02-2026	12:46	14-02-2026	14:10	1:24	0.000000	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1068	14-02-2026	Part of : RWA COLONY JANAK PURI,	207	Other Outage	Planned Outage	14-02-2026	12:47	14-02-2026	14:05	1:18	0.000000	CLEANING OF HT BUSHING PER WAY
1069	14-02-2026	Part of : BLOCK CB MAYA ENCLAVE HARI NAGAR,	18	Other Outage	Planned Outage	14-02-2026	10:54	14-02-2026	12:54	2:00	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER , REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
1070	14-02-2026	Part of : BLOCK C3 RAJOURI GARDEN,	175	Other Outage	Planned Outage	14-02-2026	13:27	14-02-2026	16:40	3:13	0.001608	DT REPLACEMENT
1071	14-02-2026	Part of : BLOCK A NANAK PURA HARI NAGAR,	722	Other Outage	Planned Outage	14-02-2026	11:39	14-02-2026	16:39	5:00	0.002500	DT REPLACEMENT
1072	14-02-2026	Part of : HTC:WEST END MALL DISTT CENTER JANAKPURI	1	Other Outage	Planned Outage	14-02-2026	10:56	14-02-2026	13:54	2:58	0.000989	REPLACEMENT OF FAULTY END BOX
1073	14-02-2026	Part of : BLOCK B FATEH NAGAR JANAK PURI,	245	Other Outage	Planned Outage	14-02-2026	12:12	14-02-2026	14:34	2:22	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER , OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1074	14-02-2026	Part of : BLOCK WZ RC BASTI NANGAL RAYA JANAK PURI,	842	Other Outage	Planned Outage	14-02-2026	11:12	14-02-2026	14:34	3:22	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1075	14-02-2026	Part of : BLOCK 40 ASHOK NAGAR,	484	Other Outage	Planned Outage	14-02-2026	10:31	14-02-2026	13:07	2:36	0.000000	3PH DB REVAMPING,CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1076	15-02-2026	Part of : DISTRICT CENTRE JANAK PURI	88	Other Outage	Planned Outage	15-02-2026	13:54	15-02-2026	15:52	1:58	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1077	16-02-2026	Part of : A 2B-BLOCK ASALATPUR VILLAGE,DISTRICT CENTRE JANAK PURI,A 1 & A-1/ A-BLOCK JANAK PURI	2059	Other Outage	Unplanned Outage	16-02-2026	11:39	16-02-2026	12:37	0:58	0.000258	HT SYSTEM FAULT
1078	16-02-2026	Part of : G & Z-BLOCK RAJOURI GARDEN EXTENSION	846	Other Outage	Unplanned Outage	16-02-2026	10:46	16-02-2026	11:36	0:50	0.000472	CABLE FAULT
1079	16-02-2026	Part of : BLOCK 1 SUBHASH NAGAR	753	Other Outage	Planned Outage	16-02-2026	14:33	16-02-2026	15:56	1:23	0.000461	LT CIRCUIT MAINTENANCE
1080	16-02-2026	Part of : RZ-BLOCK MOHAN NAGAR SAGARPUR MAIN	1082	Other Outage	Planned Outage	16-02-2026	11:44	16-02-2026	13:44	2:00	0.000667	LT CIRCUIT MAINTENANCE
1081	16-02-2026	Part of : C 3-BLOCK JANAK PURI	7	Other Outage	Planned Outage	16-02-2026	11:28	16-02-2026	13:29	2:01	0.000672	LT CIRCUIT MAINTENANCE
1082	16-02-2026	Part of : FCI MAYAPURI (HT CONSUMER)	1	Other Outage	Planned Outage	16-02-2026	11:11	16-02-2026	12:41	1:30	0.000500	LT CIRCUIT MAINTENANCE
1083	16-02-2026	Part of : J 13-BLOCK RAJOURI GARDEN	284	Other Outage	Planned Outage	16-02-2026	13:24	16-02-2026	17:02	3:38	0.001817	DT REPLACEMENT
1084	16-02-2026	Part of : A-BLOCK NANAK PURA HARI NAGAR	722	Other Outage	Planned Outage	16-02-2026	11:56	16-02-2026	15:34	3:38	0.001817	DT REPLACEMENT
1085	16-02-2026	Part of : C-BLOCK FATEH NAGAR	579	Other Outage	Planned Outage	16-02-2026	12:14	16-02-2026	15:52	3:38	0.001817	DT REPLACEMENT
1086	16-02-2026	Part of : BLOCK 1 SUBHASH NAGAR	753	Other Outage	Planned Outage	16-02-2026	10:54	16-02-2026	14:34	3:40	0.001833	DT REPLACEMENT
1087	16-02-2026	Part of : BLOCK 3 SUBHASH NAGAR	541	Other Outage	Planned Outage	16-02-2026	10:57	16-02-2026	14:04	3:07	0.001039	LT CIRCUIT MAINTENANCE
1088	17-02-2026	Part of : BLOCK F,J,G & Z RAJOURI GARDEN	846	Other Outage	Unplanned Outage	17-02-2026	17:35	17-02-2026	17:58	0:23	0.000415	CABLE FAULT
1089	17-02-2026	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN	1168	Other Outage	Planned Outage	17-02-2026	13:07	17-02-2026	13:56	0:49	0.000408	DT REPLACEMENT
1090	17-02-2026	Part of : BLOCK S RAJOURI GARDEN	432	Other Outage	Planned Outage	17-02-2026	13:49	17-02-2026	15:08	1:19	0.000658	DT REPLACEMENT
1091	17-02-2026	Part of : BLOCK 3 & 6 SUBHASH NAGAR	3585	Other Outage	Planned Outage	17-02-2026	11:27	17-02-2026	14:16	2:49	0.000469	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT BUSHING ROD
1092	17-02-2026	Part of : POCKET D2A NANGAL RAYA JANAK PURI	451	Other Outage	Planned Outage	17-02-2026	13:03	17-02-2026	15:06	2:03	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1093	17-02-2026	Part of : MEENAKSHI GARDEN ASHOK NAGAR	487	Other Outage	Planned Outage	17-02-2026	11:26	17-02-2026	14:02	2:36	0.000000	3PH DB REVAMPING,CONDUCTOR REPLACEMENT PER SPAN
1094	17-02-2026	Part of : C-4 BLOCK JANAK PURI	311	Other Outage	Planned Outage	17-02-2026	11:40	17-02-2026	13:57	2:17	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1095	17-02-2026	Part of : BLOCK B2 SHIV NAGAR JANAK PURI	800	Other Outage	Planned Outage	17-02-2026	11:46	17-02-2026	14:17	2:31	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
1096	17-02-2026	Part of : BLOCK EC MAYA ENCLAVE HARI NAGAR	112	Other Outage	Planned Outage	17-02-2026	11:45	17-02-2026	14:15	2:30	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1097	18-02-2026	Part of : BLOCK C 5B JANAK PURI,	303	Other Outage	Planned Outage	18-02-2026	11:56	18-02-2026	13:52	1:56	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1098	18-02-2026	Part of : ADITI APARTMENTS JANAK PURI,	437	Other Outage	Planned Outage	18-02-2026	11:28	18-02-2026	13:11	1:43	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1099	18-02-2026	Part of : BLOCK A NANAK PURA HARI NAGAR,	722	Other Outage	Planned Outage	18-02-2026	12:12	18-02-2026	16:03	3:51	0.001925	DT REPLACEMENT
1100	18-02-2026	Part of : BLOCK B 3A JANAK PURI,	433	Other Outage	Planned Outage	18-02-2026	11:04	18-02-2026	16:01	4:57	0.002475	DT REPLACEMENT
1101	18-02-2026	Part of : BLOCK EC MAYA ENCLAVE HARI NAGAR,	204	Other Outage	Planned Outage	18-02-2026	11:04	18-02-2026	13:11	2:07	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1102	19-02-2026	Part of : BLOCK C 1A JANAK PURI,BLOCK C 2D JANAK PURI	1167	Other Outage	Unplanned Outage	19-02-2026	17:19	19-02-2026	17:51	0:32	0.000384	CABLE FAULT
1103	19-02-2026	Part of : Part of : POCKET B FATEH NAGAR	676	Other Outage	Planned Outage	19-02-2026	15:45	19-02-2026	16:58	1:13	0.000608	DT REPLACEMENT
1104	19-02-2026	Part of : Part of : C 2A-BLOCK JANAK PURI	471	Other Outage	Planned Outage	19-02-2026	11:26	19-02-2026	13:14	1:48	0.000000	LT CIRCUIT MAINTENANCE
1105	19-02-2026	Part of : Part of : I-BLOCK RAGHU ENCLAVE DABRI EXTENSION EAST	458	Other Outage	Planned Outage	19-02-2026	10:57	19-02-2026	14:55	3:58	0.001983	DT REPLACEMENT
1106	19-02-2026	Part of : Part of : F-BLOCK DELHI MILK SSCHEME COLONY HARI NAGAR	249	Other Outage	Planned Outage	19-02-2026	11:14	19-02-2026	13:37	2:23	0.000000	LT CIRCUIT MAINTENANCE
1107	19-02-2026	Part of : Part of : BLOCK 16 PRESS COLONY MAYAPURI	562	Other Outage	Planned Outage	19-02-2026	10:35	19-02-2026	13:20	2:45	0.000000	LT CIRCUIT MAINTENANCE
1108	20-02-2026	Part of : BLOCK 11 RAJOURI GARDEN	703	Other Outage	Planned Outage	20-02-2026	11:00	20-02-2026	12:37	1:37	0.000539	LT CIRCUIT MAINTENANCE
1109	20-02-2026	Part of : RWA COLONY JANAK PURI	50	Other Outage	Planned Outage	20-02-2026	11:50	20-02-2026	12:53	1:03	0.000350	LT CIRCUIT MAINTENANCE
1110	20-02-2026	Part of : BLOCK RZ VASHISHT PARK SAGARPUR	851	Other Outage	Planned Outage	20-02-2026	11:51	20-02-2026	13:50	1:59	0.000661	LT CIRCUIT MAINTENANCE
1111	20-02-2026	Part of : BLOCK 4 SUBHASH NAGAR	459	Other Outage	Planned Outage	20-02-2026	10:32	20-02-2026	13:40	3:08	0.001044	LT CIRCUIT MAINTENANCE
1112	20-02-2026	Part of : BLOCK H NANAK PURA HARI NAGAR	417	Other Outage	Planned Outage	20-02-2026	11:22	20-02-2026	13:48	2:26	0.000811	LT CIRCUIT MAINTENANCE
1113	21-02-2026	Part of : BLOCK A & E MAYAPURI INDUSTRIAL AREA PHASE II	252	Other Outage	Unplanned Outage	21-02-2026	13:57	21-02-2026	14:40	0:43	0.001573	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1114	21-02-2026	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST	458	Other Outage	Planned Outage	21-02-2026	14:44	21-02-2026	17:32	2:48	0.001400	DT REPLACEMENT
1115	21-02-2026	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN	1168	Other Outage	Planned Outage	21-02-2026	14:45	21-02-2026	16:55	2:10	0.001083	DT REPLACEMENT
1116	21-02-2026	Part of : POCKET B FATEH NAGAR	507	Other Outage	Planned Outage	21-02-2026	12:25	21-02-2026	16:12	3:47	0.001892	DT REPLACEMENT
1117	21-02-2026	Part of : BLOCK B 3A JANAK PURI	433	Other Outage	Planned Outage	21-02-2026	12:06	21-02-2026	15:49	3:43	0.001858	DT REPLACEMENT
1118	21-02-2026	Part of : BLOCK J RAJOURI GARDEN	316	Other Outage	Planned Outage	21-02-2026	11:00	21-02-2026	13:08	2:08	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD
1119	21-02-2026	Part of : BLOCK C MAYAPURI INDUSTRIAL AREA PHASE II	71	Other Outage	Planned Outage	21-02-2026	11:39	21-02-2026	14:13	2:34	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1120	22-02-2026	Part of : BLOCK EA MAYA ENCLAVE HARI NAGAR,	61	Other Outage	Unplanned Outage	22-02-2026	12:04	22-02-2026	13:05	1:01	0.000339	HT BUSHING REPLACEMENT
1121	22-02-2026	Part of : DISTRICT CENTRE JANAK PURI,	198	Other Outage	Planned Outage	22-02-2026	11:22	22-02-2026	13:37	2:15	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1122	23-02-2026	Part of : BLOCK RZ SAGARPUR	264	Other Outage	Planned Outage	23-02-2026	14:10	23-02-2026	15:14	1:04	0.000000	LT CIRCUIT MAINTENANCE
1123	23-02-2026	Part of : BLOCK CB MAYA ENCLAVE HARI NAGAR	1	Other Outage	Planned Outage	23-02-2026	12:36	23-02-2026	14:04	1:28	0.000000	LT CIRCUIT MAINTENANCE
1124	23-02-2026	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN	1168	Other Outage	Planned Outage	23-02-2026	13:06	23-02-2026	16:10	3:04	0.001533	DT REPLACEMENT
1125	23-02-2026	Part of : BLOCK C 6A JANAK PURI	144	Other Outage	Planned Outage	23-02-2026	11:41	23-02-2026	14:11	2:30	0.000000	LT CIRCUIT MAINTENANCE
1126	23-02-2026	Part of : BLOCK 8 PRESS COLONY MAYAPURI	326	Other Outage	Planned Outage	23-02-2026	10:56	23-02-2026	13:11	2:15	0.000000	LT CIRCUIT MAINTENANCE
1127	24-02-2026	Part of : A-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-2	188	Other Outage	Unplanned Outage	24-02-2026	17:14	24-02-2026	17:57	0:43	0.000239	MOBILE TRANSFORMER REPLACEMENT
1128	24-02-2026	Part of : A-24 MAYAPURI PH-1	1	Other Outage	Planned Outage	24-02-2026	13:09	24-02-2026	14:31	1:22	0.000456	LT CIRCUIT MAINTENANCE
1129	24-02-2026	Part of : BLOCK E RAGHU NAGAR DABRI	686	Other Outage	Planned Outage	24-02-2026	12:30	24-02-2026	13:51	1:21	0.000450	LT CIRCUIT MAINTENANCE
1130	24-02-2026	Part of : DDU HOSPITAL C BLOCK JANAK PURI	25	Other Outage	Planned Outage	24-02-2026	12:28	24-02-2026	14:24	1:56	0.000644	LT CIRCUIT MAINTENANCE
1131	24-02-2026	Part of : BLOCK B 3A JANAK PURI	433	Other Outage	Planned Outage	24-02-2026	14:57	24-02-2026	17:20	2:23	0.001192	DT REPLACEMENT
1132	24-02-2026	Part of : BLOCK B3 JANAK PURI	392	Other Outage	Planned Outage	24-02-2026	14:23	24-02-2026	17:10	2:47	0.000928	LT CIRCUIT MAINTENANCE
1133	24-02-2026	Part of : BLOCK S MEENAKSHI GARDEN ASHOK NAGAR	549	Other Outage	Planned Outage	24-02-2026	10:56	24-02-2026	13:18	2:22	0.000789	LT CIRCUIT MAINTENANCE
1134	25-02-2026	Part of : VIRENDER NAGAR, DILLI HAAT JANAKPURI (HTC)	1	Other Outage	Unplanned Outage	25-02-2026	16:58	25-02-2026	17:25	0:27	0.000000	CABLE FAULT
1135	25-02-2026	Part of : BLOCK S MEENAKSHI GARDEN ASHOK NAGAR	1383	Other Outage	Unplanned Outage	25-02-2026	09:12	25-02-2026	09:31	0:19	0.000106	CONNECTION/DISCONNETION OF HT/LT CABLES
1136	25-02-2026	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST	456	Other Outage	Planned Outage	25-02-2026	12:15	25-02-2026	13:10	0:55	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1137	25-02-2026	Part of : BLOCK 4 SUBHASH NAGAR	459	Other Outage	Planned Outage	25-02-2026	14:07	25-02-2026	15:17	1:10	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1138	25-02-2026	Part of : BLOCK 1 SUBHASH NAGAR	316	Other Outage	Planned Outage	25-02-2026	14:06	25-02-2026	15:18	1:12	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1139	25-02-2026	Part of : BLOCK C 2C JANAK PURI	121	Other Outage	Planned Outage	25-02-2026	12:37	25-02-2026	14:07	1:30	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1140	25-02-2026	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN	679	Other Outage	Planned Outage	25-02-2026	14:18	25-02-2026	16:54	2:36	0.001300	DT REPLACEMENT
1141	25-02-2026	Part of : PRESS COLONY MAYAPURI	1	Other Outage	Planned Outage	25-02-2026	11:05	25-02-2026	13:09	2:04	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF LT BUSHING ROD
1142	25-02-2026	Part of : SHIV NAGAR JANAK PURI	559	Other Outage	Planned Outage	25-02-2026	11:18	25-02-2026	14:08	2:50	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF GAS KIT AND OIL SEAL
1143	26-02-2026	Part of : BLOCK C JANAK PURI,	3	Other Outage	Planned Outage	26-02-2026	14:52	26-02-2026	16:06	1:14	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1144	26-02-2026	Part of : BLOCK J RAJOURI GARDEN EXTENSION RAJOURI GARDEN,	421	Other Outage	Planned Outage	26-02-2026	13:49	26-02-2026	15:07	1:18	0.000000	REPLACEMENT OF LT BUSHING ROD
1145	26-02-2026	Part of : BLOCK 5 SUBHASH NAGAR,	567	Other Outage	Planned Outage	26-02-2026	12:18	26-02-2026	13:34	1:16	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1146	26-02-2026	Part of : BLOCK C FATEH NAGAR,	783	Other Outage	Planned Outage	26-02-2026	15:07	26-02-2026	17:43	2:36	0.001300	DT REPLACEMENT
1147	26-02-2026	Part of : NANGAL VILLAGE DELHI CANTONMENT,	846	Other Outage	Planned Outage	26-02-2026	12:57	26-02-2026	15:06	2:09	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1148	26-02-2026	Part of : BLOCK C1 JANAK PURI,	36	Other Outage	Planned Outage	26-02-2026	11:42	26-02-2026	13:50	2:08	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1149	26-02-2026	Part of : SHIV NAGAR JANAK PURI,	442	Other Outage	Planned Outage	26-02-2026	11:43	26-02-2026	14:50	3:07	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1150	27-02-2026	Part of : Block C3A Residential Complex Janak Puri,Block C 5B Janak Puri,Block C4H Janak Puri,Block C 6B Janak Puri	2932	Other Outage	Unplanned Outage	27-02-2026	18:24	27-02-2026	19:12	0:48	0.000403	CABLE FAULT
1151	27-02-2026	Part of : Meenakshi Garden Ashok Nagar,Block 1 Subhash Nagar,Block 1 Ashok Nagar	2710	Other Outage	Unplanned Outage	27-02-2026	15:27	27-02-2026	16:17	0:50	0.000721	CABLE FAULT
1152	27-02-2026	Part of : C 2-BLOCK JANAK PURI	223	Other Outage	Planned Outage	27-02-2026	11:36	27-02-2026	13:25	1:49	0.000000	LT CIRCUIT MAINTENANCE
1153	27-02-2026	Part of : NANGLI JALAB JANAK PURI	553	Other Outage	Planned Outage	27-02-2026	11:37	27-02-2026	13:23	1:46	0.000000	LT CIRCUIT MAINTENANCE
1154	27-02-2026	Part of : DELHI CANT BOOSTER PUMP	1	Other Outage	Planned Outage	27-02-2026	11:55	27-02-2026	13:29	1:34	0.000000	LT CIRCUIT MAINTENANCE
1155	27-02-2026	Part of : J 5-BLOCK RAJOURI GARDEN EXTENSION	443	Other Outage	Planned Outage	27-02-2026	10:45	27-02-2026	13:24	2:39	0.000000	LT CIRCUIT MAINTENANCE
1156	27-02-2026	Part of : BLOCK 6 SUBHASH NAGAR	411	Other Outage	Planned Outage	27-02-2026	10:44	27-02-2026	13:26	2:42	0.000000	LT CIRCUIT MAINTENANCE
1157	28-02-2026	Part of : A 1-BLOCK JANAK PURI	28	Other Outage	Planned Outage	28-02-2026	12:54	28-02-2026	13:50	0:56	0.000000	LT CIRCUIT MAINTENANCE
1158	28-02-2026	Part of : GOI PRESS MAYAPURI (HT CONSUMER)	1	Other Outage	Planned Outage	28-02-2026	13:23	28-02-2026	15:21	1:58	0.000000	LT CIRCUIT MAINTENANCE
1159	28-02-2026	Part of : J 3-BLOCK RAJOURI GARDEN EXTENSION	454	Other Outage	Planned Outage	28-02-2026	11:17	28-02-2026	14:06	2:49	0.000000	LT CIRCUIT MAINTENANCE
1160	01-02-2026	Part of : GULSHAN PARK WEST CABIN BLOCK MUNDKA,WEST CABIN BLOCK MUNDKA	48	Other Outage	Planned Outage	01-02-2026	14:29	01-02-2026	17:00	2:31	0.000419	FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1161	01-02-2026	Part of : BLOCK A,B & C TYAGI VIHAR MUNDKA	290	Other Outage	Planned Outage	01-02-2026	13:14	01-02-2026	15:50	2:36	0.002167	GUARD WIRE LACS INSTALLTION PER SPAN
1162	01-02-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,NETAJI SUBHASH VIHAR MUNDKA	216	Other Outage	Planned Outage	01-02-2026	13:18	01-02-2026	15:51	2:33	0.000850	GUARD WIRES SAGGING PER SPAN
1163	02-02-2026	Part of : NIRMAL VIHAR BAPROLA,BANI AIR FORCE CAMP JAI VIHAR BAPROLA,TILANGPUR KOTLA	6221	Other Outage	Unplanned Outage	02-02-2026	14:04	02-02-2026	14:55	0:51	0.000551	HVDS FAULT
1164	02-02-2026	Part of : RANHOLLA,	643	Other Outage	Planned Outage	02-02-2026	13:10	02-02-2026	15:05	1:55	0.000958	REPLACEMENT OF LT BUSHING ROD
1165	03-02-2026	Part of : YADAV PARK KAMARUDDIN NAGAR	402	Other Outage	Planned Outage	03-02-2026	11:43	03-02-2026	13:23	1:40	0.000556	REPLACEMENT OF GAS KIT AND OIL SEAL
1166	03-02-2026	Part of : MUNDKA INDUSTRIAL AREA	26	Other Outage	Planned Outage	03-02-2026	11:42	03-02-2026	13:43	2:01	0.000672	SUB STATION CLEANING
1167	03-02-2026	Part of : NEW PVC MARKET TIKRI KALAN	1	Other Outage	Planned Outage	03-02-2026	11:40	03-02-2026	13:42	2:02	0.000678	REPLACEMENT OF GAS KIT AND OIL SEAL
1168	04-02-2026	Part of : TILANGPUR KOTLA,AAKASH VIHAR,RANHOLLA,NIRMAL VIHAR BAPROLA	3635	Other Outage	Planned Outage	04-02-2026	11:12	04-02-2026	12:55	1:43	0.000572	GUARD WIRES SAGGING
1169	04-02-2026	Part of : RANHOLLA	2013	Other Outage	Planned Outage	04-02-2026	11:10	04-02-2026	12:56	1:46	0.000294	GUARD WIRES SAGGING
1170	04-02-2026	Part of : BAKKARWALA VILLAGE	137	Other Outage	Planned Outage	04-02-2026	12:52	04-02-2026	15:00	2:08	0.000356	REPLACEMET OF HT BUSHING ROD
1171	05-02-2026	Part of : RAJENDRA PARK EXTENSION, BLOCK 2C NANGLOI EXTENSION	799	Other Outage	Unplanned Outage	05-02-2026	10:25	05-02-2026	11:08	0:43	0.000751	HVDS FAULT
1172	05-02-2026	Part of : TILANGPUR KOTLA	649	Other Outage	Planned Outage	05-02-2026	14:35	05-02-2026	16:19	1:44	0.001156	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1173	06-02-2026	Part of : BLOCK B YADAV PARK NANGLOI EXTENSION NANGLOI,TYAGI COLONY NANGLOI EXTENSION NANGLOI,RAJENDRA PARK NANGLOI EXTENSION NANGLOI,RAJENDRA PARK EXTENSION NANGLOI EXTENSION NANGLOI,BLOCK A 1 NANGLOI EXTENSION NANGLOI,BLOCK 1B NANGLOI EXTENSION NANGLOI,JOHAR VILLAGE NANGLOI EXTENSION NANGLOI,BLOCK 2D NANGLOI EXTENSION NANGLOI,BLOCK 4 ABC NANGLOI EXTENSION NANGLOI,RATAN BAGH NANGLOI,	5245	Other Outage	Planned Outage	06-02-2026	13:43	06-02-2026	15:25	1:42	0.001417	GUARD WIRES SAGGING PER SPAN
1174	06-02-2026	Part of : FRIENDS COLONY MUNDKA,	884	Other Outage	Planned Outage	06-02-2026	13:19	06-02-2026	15:26	2:07	0.000706	GUARD WIRES SAGGING PER SPAN
1175	06-02-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	24	Other Outage	Planned Outage	06-02-2026	13:20	06-02-2026	15:28	2:08	0.001067	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
1176	06-02-2026	Part of : NEELWAL VILLAGE,	432	Other Outage	Planned Outage	06-02-2026	11:11	06-02-2026	13:19	2:08	0.000711	REPLACEMET OF HT BUSHING ROD
1177	07-02-2026	Part of : BLOCK N AMAR COLONY NANGLOI EXTENSION	456	Other Outage	Planned Outage	07-02-2026	13:29	07-02-2026	15:21	1:52	0.000622	REPLACEMENT OF GAS KIT AND OIL SEAL
1178	07-02-2026	Part of : BLOCK C JJ COLONY 2 NANGLOI	2611	Other Outage	Planned Outage	07-02-2026	13:48	07-02-2026	15:22	1:34	0.000522	REPLACEMENT OF HT BUSHING ROD
1179	07-02-2026	Part of : HIRAN KUDNA	1384	Other Outage	Planned Outage	07-02-2026	11:33	07-02-2026	14:28	2:55	0.002431	GUARD WIRE LACS INSTALLTION
1180	08-02-2026	Part of : VEENA ENCLAVE,WEST CABIN BLOCK MUNDKA,MUNDKA INDUSTRIAL AREA	702	Other Outage	Planned Outage	08-02-2026	15:47	08-02-2026	17:05	1:18	0.000867	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1181	08-02-2026	Part of : C-BLOCK MUNDKA,VEENA ENCLAVE	736	Other Outage	Planned Outage	08-02-2026	11:38	08-02-2026	13:20	1:42	0.000850	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1182	08-02-2026	Part of : MUNDKA INDUSTRIAL AREA	85	Other Outage	Planned Outage	08-02-2026	13:41	08-02-2026	15:49	2:08	0.002133	GUARD WIRES SAGGING
1183	09-02-2026	Part of : TIKRI KALAN	2053	Other Outage	Planned Outage	09-02-2026	14:28	09-02-2026	16:06	1:38	0.000544	GUARD WIRES SAGGING PER SPAN
1184	09-02-2026	Part of : TIKRI KALAN	372	Other Outage	Planned Outage	09-02-2026	14:27	09-02-2026	16:07	1:40	0.000000	GUARD WIRES SAGGING PER SPAN
1185	09-02-2026	Part of : BLOCK 4 ABC NANGLOI EXTENSION	2139	Other Outage	Planned Outage	09-02-2026	13:24	09-02-2026	15:11	1:47	0.000000	REPLACEMENT OF LT BUSHING ROD
1186	09-02-2026	Part of : BLOCK A NANGLOI EXTENSION	350	Other Outage	Planned Outage	09-02-2026	12:54	09-02-2026	15:48	2:54	0.000967	REPLACEMENT OF HT BUSHING ROD
1187	10-02-2026	Part of : BLOCK D KUNWAR SINGH NAGAR KAMARUDDIN NAGAR,	1124	Other Outage	Planned Outage	10-02-2026	11:43	10-02-2026	13:39	1:56	0.000644	REPLACEMENT OF GAS KIT AND OIL SEAL
1188	10-02-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	5	Other Outage	Planned Outage	10-02-2026	11:28	10-02-2026	13:21	1:53	0.000314	REPLACEMET OF HT BUSHING ROD
1189	11-02-2026	Part of : BAKKARWALA VILLAGE,JI COLONY BAKARWALA	5298	Other Outage	Planned Outage	11-02-2026	12:16	11-02-2026	13:58	1:42	0.000283	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1190	11-02-2026	Part of : BABA HARIDAS NAGAR TIKRI KALAN	53	Other Outage	Planned Outage	11-02-2026	13:04	11-02-2026	15:55	2:51	0.000950	GUARD WIRE LACS INSTALLTION
1191	11-02-2026	Part of : BLOCK D,2A,2B,2D & 4ABC- NANGLOI EXTENSION,RAJENDRA PARK EXTENSION	2564	Other Outage	Planned Outage	11-02-2026	12:14	11-02-2026	14:32	2:18	0.000767	GUARD WIRES SAGGING
1192	12-02-2026	Part of : BANI CAMP (HT CONSUMER)	0	Other Outage	Unplanned Outage	12-02-2026	15:13	12-02-2026	15:52	0:39	0.000162	CABLE FAULT
1193	12-02-2026	Part of : NEW PVC MARKET,TIKRI KALAN,NETAJI SUBHASH VIHAR MUNDKA	340	Other Outage	Planned Outage	12-02-2026	14:23	12-02-2026	16:00	1:37	0.000808	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1194	12-02-2026	Part of : TIKRI KALAN,NETAJI SUBHASH VIHAR MUNDKA	1669	Other Outage	Planned Outage	12-02-2026	14:24	12-02-2026	16:02	1:38	0.000817	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1195	13-02-2026	Part of : VEENA ENCLAVE MUNDKA	63	Other Outage	Planned Outage	13-02-2026	13:39	13-02-2026	14:47	1:08	0.000378	REPLACEMENT OF LT BUSHING ROD
1196	13-02-2026	Part of : NIRMAL VIHAR BAPROLA,BANI AIR FORCE CAMP JAI VIHAR BAPROLA	1405	Other Outage	Planned Outage	13-02-2026	11:59	13-02-2026	13:45	1:46	0.000589	GUARD WIRE LACS INSTALLTION PER SPAN
1197	14-02-2026	Part of : AMAR COLONY NANGLOI EXTENSION NANGLOI,	1468	Other Outage	Planned Outage	14-02-2026	14:05	14-02-2026	16:04	1:59	0.000661	REPLACEMET OF HT BUSHING ROD
1198	14-02-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,	1799	Other Outage	Planned Outage	14-02-2026	12:54	14-02-2026	14:09	1:15	0.000208	REPLACEMET OF HT BUSHING ROD
1199	14-02-2026	Part of : NEELWAL VILLAGE,	19	Other Outage	Planned Outage	14-02-2026	11:14	14-02-2026	13:36	2:22	0.000394	REPLACEMENT OF GAS KIT AND OIL SEAL
1200	15-02-2026	Part of : TYAGI PARK MUNDKA,WEST CABIN BLOCK MUNDKA	2238	Other Outage	Unplanned Outage	15-02-2026	18:15	15-02-2026	18:46	0:31	0.000000	CABLE FAULT
1201	15-02-2026	Part of : MUNDKA EXTENSION	63	Other Outage	Planned Outage	15-02-2026	13:07	15-02-2026	14:23	1:16	0.000000	REPLACEMENT OF HT BUSHING ROD
1202	15-02-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,BLOCK B & C TYAGI VIHAR MUNDKA	318	Other Outage	Planned Outage	15-02-2026	10:32	15-02-2026	13:10	2:38	0.000878	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1203	15-02-2026	Part of : BLOCK A, B & C TYAGI VIHAR MUNDKA,VEENA ENCLAVE MUNDKA,MUNDKA INDUSTRIAL AREA MUNDKA,WEST CABIN BLOCK MUNDKA	3047	Other Outage	Planned Outage	15-02-2026	10:34	15-02-2026	13:11	2:37	0.002835	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1204	16-02-2026	Part of : MUNDKA EXTENSION	36	Other Outage	Planned Outage	16-02-2026	13:33	16-02-2026	15:17	1:44	0.000867	REPLACEMENT OF GAS KIT AND OIL SEAL
1205	16-02-2026	Part of : POCKET Y JJ COLONY 3 NANGLOI	738	Other Outage	Planned Outage	16-02-2026	12:02	16-02-2026	13:48	1:46	0.000589	REPLACEMENT OF GAS KIT AND OIL SEAL
1206	16-02-2026	Part of : RANHOLLA	1174	Other Outage	Planned Outage	16-02-2026	12:02	16-02-2026	14:41	2:39	0.000883	REPLACEMENT OF HT BUSHING ROD
1207	17-02-2026	Part of : TILANGPUR KOTLA	1330	Other Outage	Planned Outage	17-02-2026	11:07	17-02-2026	13:04	1:57	0.000975	REPLACEMENT OF GAS KIT AND OIL SEAL
1208	18-02-2026	Part of : NEW PVC MARKET TIKRI KALAN,TIKRI KALAN,NETAJI SUBHASH VIHAR MUNDKA,	340	Other Outage	Planned Outage	18-02-2026	15:14	18-02-2026	16:40	1:26	0.001433	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1209	18-02-2026	Part of : TIKRI KALAN,NETAJI SUBHASH VIHAR MUNDKA,	1669	Other Outage	Planned Outage	18-02-2026	15:13	18-02-2026	16:40	1:27	0.001450	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1210	18-02-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	7	Other Outage	Planned Outage	18-02-2026	12:23	18-02-2026	14:02	1:39	0.000550	REPLACEMET OF HT BUSHING ROD
1211	19-02-2026	Part of : Part of : MUNDKA INDUSTRIAL AREA,MUNDKA VILLAGE	2315	Other Outage	Planned Outage	19-02-2026	14:16	19-02-2026	15:56	1:40	0.000278	REPLACEMENT OF HT BUSHING ROD
1212	19-02-2026	Part of : Part of : TILANGPUR KOTLA	1092	Other Outage	Planned Outage	19-02-2026	14:19	19-02-2026	15:57	1:38	0.000272	REPLACEMENT OF HT BUSHING ROD
1213	19-02-2026	Part of : Part of : MUNDKA EXTENSION	825	Other Outage	Planned Outage	19-02-2026	11:53	19-02-2026	14:54	3:01	0.000754	REPLACEMENT OF HT BUSHING ROD
1214	19-02-2026	Part of : Part of : RATAN BAGH NANGLOI	1191	Other Outage	Planned Outage	19-02-2026	10:35	19-02-2026	13:20	2:45	0.000917	REPLACEMENT OF HT BUSHING ROD
1215	20-02-2026	Part of : TIKRI KALAN,NEELWAL VILLAGE	1435	Other Outage	Planned Outage	20-02-2026	14:00	20-02-2026	15:37	1:37	0.000539	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1216	20-02-2026	Part of : TYAGI COLONY & RAJENDRA PARK EXTENSION NANGLOI EXTENSION NANGLOI	1091	Other Outage	Planned Outage	20-02-2026	11:26	20-02-2026	13:16	1:50	0.000458	GUARD WIRE LACS INSTALLTION
1217	21-02-2026	Part of : MUNDKA EXTENSION	828	Other Outage	Planned Outage	21-02-2026	12:07	21-02-2026	14:34	2:27	0.000613	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1218	21-02-2026	Part of : NETAJI SUBHASH VIHAR MUNDKA,BLOCK C TYAGI VIHAR,TIKRI KALAN	2622	Other Outage	Planned Outage	21-02-2026	10:46	21-02-2026	13:47	3:01	0.002011	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1219	22-02-2026	Part of : WEST CABIN BLOCK MUNDKA,	661	Other Outage	Planned Outage	22-02-2026	11:56	22-02-2026	14:02	2:06	0.002100	GUARD WIRES SAGGING PER SPAN
1220	22-02-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,NETAJI SUBHASH VIHAR MUNDKA,HIRAN KUDNA,	342	Other Outage	Planned Outage	22-02-2026	10:44	22-02-2026	13:24	2:40	0.002667	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1221	23-02-2026	Part of : Laxmi Park Colony Kamaruddin Nagar,Mundka Extension Mundka,Block C Mundka,Mundka Village Mundka,Friends Colony Mundka	2980	Other Outage	Unplanned Outage	23-02-2026	13:00	23-02-2026	14:02	1:02	0.002127	CABLE FAULT
1222	23-02-2026	Part of : YADAV PARK KAMARUDDIN NAGAR	788	Other Outage	Planned Outage	23-02-2026	14:32	23-02-2026	15:38	1:06	0.000000	REPLACEMENT OF HT BUSHING INULATOR
1223	23-02-2026	Part of : AMAR COLONY NANGLOI EXTENSION	2366	Other Outage	Planned Outage	23-02-2026	10:37	23-02-2026	13:13	2:36	0.000867	REPLACEMET OF HT BUSHING ROD
1224	24-02-2026	Part of : NETAJI SUBHASH VIHAR,MUNDKA INDUSTRIAL AREA	1682	Other Outage	Planned Outage	24-02-2026	16:21	24-02-2026	17:42	1:21	0.000450	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1225	24-02-2026	Part of : JAI VIHAR KAMARUDDIN NAGAR	329	Other Outage	Planned Outage	24-02-2026	12:19	24-02-2026	13:52	1:33	0.000388	REPLACEMENT OF HT BUSHING ROD
1226	25-02-2026	Part of : BLOCK D,2D & 4ABC NANGLOI EXTENSION,RAJENDRA PARK EXTENSION	2564	Other Outage	Planned Outage	25-02-2026	12:05	25-02-2026	14:49	2:44	0.001367	GUARD WIRE LACS INSTALLTION PER SPAN
1227	25-02-2026	Part of : NEELWAL VILLAGE,TIKRI KALAN,NEW PVC MARKET TIKRI KALAN	4438	Other Outage	Planned Outage	25-02-2026	11:01	25-02-2026	13:31	2:30	0.002083	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1228	25-02-2026	Part of : TIKRI KALAN	2318	Other Outage	Planned Outage	25-02-2026	11:00	25-02-2026	13:33	2:33	0.001700	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1229	26-02-2026	Part of : TILANGPUR KOTLA,	840	Other Outage	Planned Outage	26-02-2026	13:24	26-02-2026	14:43	1:19	0.000329	REPLACEMENT OF LT BUSHING ROD
1230	26-02-2026	Part of : LOKNAYAK PURAM BAKARWALA,	57	Other Outage	Planned Outage	26-02-2026	12:58	26-02-2026	14:59	2:01	0.001008	REPLACEMET OF HT BUSHING ROD
1231	27-02-2026	Part of : NETAJI SUBHASH VIHAR,C-BLOCK TYAGI VIHAR,TIKRI KALAN,BABA HARIDAS NAGAR TIKRI KALAN	2622	Other Outage	Planned Outage	27-02-2026	10:35	27-02-2026	13:01	2:26	0.001217	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1232	28-02-2026	Part of : JOHAR VILLAGE NANGLOI EXTENSION	251	Other Outage	Planned Outage	28-02-2026	14:17	28-02-2026	15:23	1:06	0.000367	REPLACEMENT OF HT BUSHING ROD
1233	01-02-2026	Part of : PHASE 1 OM VIHAR NAWADA	1008	Other Outage	Planned Outage	01-02-2026	11:20	01-02-2026	15:22	4:02	0.001344	3PH HT AB CABLE REPLACEMENT PER SPAN
1234	02-02-2026	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,BLOCK B BHAGWATI GARDEN NAWADA	2278	Other Outage	Unplanned Outage	02-02-2026	08:01	02-02-2026	08:31	0:30	0.000641	HVDS FAULT
1235	02-02-2026	Part of : UMANG REALTECH PVT LTD	1	Other Outage	Planned Outage	02-02-2026	12:42	02-02-2026	15:16	2:34	0.000000	REPLACEMET OF HT BUSHING ROD
1236	02-02-2026	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD,	828	Other Outage	Planned Outage	02-02-2026	11:11	02-02-2026	13:52	2:41	0.000447	3PH HT AB CABLE REPLACEMENT PER SPAN
1237	03-02-2026	Part of : SEWAK PARK	3493	Other Outage	Planned Outage	03-02-2026	14:01	03-02-2026	15:58	1:57	0.000000	REPLACEMENT OF HT BUSHING ROD
1238	03-02-2026	Part of : BLOCK D,E,L & H BHAGWATI GARDEN NAWADA	2662	Other Outage	Planned Outage	03-02-2026	12:38	03-02-2026	14:41	2:03	0.000000	REPLACEMENT OF HT BUSHING ROD
1239	03-02-2026	Part of : BLOCK P & P 2 MOHAN GARDEN RAZAPUR KHURD	1378	Other Outage	Planned Outage	03-02-2026	11:34	03-02-2026	13:50	2:16	0.000378	3PH HT AB CABLE REPLACEMENT
1240	04-02-2026	Part of : NAWADA EXTENSION,A & B-BLOCK MAHAVIR ENCLAVE NAWADA	2147	Other Outage	Planned Outage	04-02-2026	13:07	04-02-2026	14:42	1:35	0.000000	3PH HT AB CABLE REPLACEMENT
1241	04-02-2026	Part of : A-BLOCK MAHAVIR ENCLAVE NAWADA	1297	Other Outage	Planned Outage	04-02-2026	15:49	04-02-2026	17:05	1:16	0.000000	LT CIRCUIT MAINTENANCE
1242	04-02-2026	Part of : R 5 & P 2-BLOCK MOHAN GARDEN RAZAPUR KHURD,H-BLOCK BHAGWATI GARDEN NAWADA	1173	Other Outage	Planned Outage	04-02-2026	11:13	04-02-2026	14:03	2:50	0.000472	3PH HT AB CABLE REPLACEMENT
1243	04-02-2026	Part of : C-BLOCK VIPIN GARDEN NAWADA,R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD,SAINIK ENCLAVE	3714	Other Outage	Planned Outage	04-02-2026	11:16	04-02-2026	13:59	2:43	0.000000	REPLACEMET OF HT BUSHING ROD
1244	05-02-2026	Part of : RAKSHA ENCLAVE, BLOCK W,WE & RK MOHAN GARDEN RAZAPUR KHURD, RAZA PUR KHURD VIKAS NAGAR	4431	Other Outage	Unplanned Outage	05-02-2026	13:19	05-02-2026	14:11	0:52	0.000887	CABLE FAULT
1245	05-02-2026	Part of : BLOCK RK & WE MOHAN GARDEN RAZAPUR KHURD	827	Other Outage	Planned Outage	05-02-2026	12:05	05-02-2026	14:57	2:52	0.000478	3PH HT AB CABLE REPLACEMENT PER SPAN
1246	05-02-2026	Part of : PHASE 1 OM VIHAR NAWADA	3042	Other Outage	Planned Outage	05-02-2026	10:58	05-02-2026	13:04	2:06	0.000700	1PH DB REVAMPING
1247	05-02-2026	Part of : BLOCK C VIPIN GARDEN NAWADA	1118	Other Outage	Planned Outage	05-02-2026	11:47	05-02-2026	13:59	2:12	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1248	05-02-2026	Part of : NAWADA EXTENSION	1494	Other Outage	Planned Outage	05-02-2026	11:59	05-02-2026	14:46	2:47	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1249	06-02-2026	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,	129	Other Outage	Planned Outage	06-02-2026	15:01	06-02-2026	16:08	1:07	0.000372	CONDUCTOR REPLACEMENT PER SPAN
1250	06-02-2026	Part of : PHASE 1 OM VIHAR NAWADA,	1008	Other Outage	Planned Outage	06-02-2026	11:57	06-02-2026	13:07	1:10	0.000000	1PH DB REVAMPING
1251	06-02-2026	Part of : BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK F ZAILDAR ENCLAVE NAWADA,NAWADA EXTENSION NAWADA,	1495	Other Outage	Planned Outage	06-02-2026	12:01	06-02-2026	14:15	2:14	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMET PER DT
1252	06-02-2026	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,	2278	Other Outage	Planned Outage	06-02-2026	11:58	06-02-2026	14:14	2:16	0.000000	REPLACEMET OF HT BUSHING ROD
1253	06-02-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	2636	Other Outage	Planned Outage	06-02-2026	11:19	06-02-2026	14:15	2:56	0.000489	3PH HT AB CABLE REPLACEMENT PER SPAN
1254	06-02-2026	Part of : LAXMI VIHAR NAWADA,	964	Other Outage	Planned Outage	06-02-2026	11:31	06-02-2026	14:13	2:42	0.000900	LT AB SAGGING PER SPAN
1255	07-02-2026	Part of : BLOCK D & H BHAGWATI GARDEN NAWADA	1575	Other Outage	Planned Outage	07-02-2026	16:13	07-02-2026	17:33	1:20	0.000000	DT REPLACEMENT PER DT
1256	07-02-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	111	Other Outage	Planned Outage	07-02-2026	14:03	07-02-2026	16:25	2:22	0.000000	LT CIRCUIT MAINTENANCE
1257	07-02-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	210	Other Outage	Planned Outage	07-02-2026	11:15	07-02-2026	13:45	2:30	0.000000	LT CIRCUIT MAINTENANCE
1258	09-02-2026	Part of : LAXMI VIHAR NAWADA	964	Other Outage	Planned Outage	09-02-2026	15:00	09-02-2026	15:50	0:50	0.000278	LT AB SAGGING PER SPAN
1259	09-02-2026	Part of : SAINIK ENCLAVE VIPIN GARDEN NAWADA	7	Other Outage	Planned Outage	09-02-2026	12:46	09-02-2026	15:33	2:47	0.000000	REPLACEMENT OF LT BUSHING ROD
1260	09-02-2026	Part of : BLOCK B MAHAVIR ENCLAVE,BLOCK F ZAILDAR ENCLAVE, NAWADA EXTENSION	1495	Other Outage	Planned Outage	09-02-2026	12:38	09-02-2026	15:00	2:22	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMENT PER DT
1261	09-02-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	1274	Other Outage	Planned Outage	09-02-2026	11:07	09-02-2026	13:56	2:49	0.000469	3PH HT AB CABLE REPLACEMENT PER SPAN
1262	10-02-2026	Part of : BLOCK L BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,	1539	Other Outage	Planned Outage	10-02-2026	15:20	10-02-2026	16:08	0:48	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMET PER DT
1263	10-02-2026	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA,	35	Other Outage	Planned Outage	10-02-2026	12:49	10-02-2026	15:36	2:47	0.000000	REPLACEMENT OF LT BUSHING ROD
1264	10-02-2026	Part of : RAZAPUR KHURD,RAZA PUR KHURD VIKAS NAGAR,	1089	Other Outage	Planned Outage	10-02-2026	11:54	10-02-2026	14:54	3:00	0.000500	3PH HT AB CABLE REPLACEMENT PER SPAN
1265	11-02-2026	Part of : BLOCK C VIPIN GARDEN NAWADA	363	Other Outage	Planned Outage	11-02-2026	12:27	11-02-2026	13:59	1:32	0.000000	LT CIRCUIT MAINTENANCE
1266	11-02-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL	820	Other Outage	Planned Outage	11-02-2026	12:24	11-02-2026	14:07	1:43	0.000000	LT CIRCUIT MAINTENANCE
1267	11-02-2026	Part of : BLOCK R, RK & WE-MOHAN GARDEN RAZAPUR KHURD	1052	Other Outage	Planned Outage	11-02-2026	11:07	11-02-2026	13:59	2:52	0.000478	3PH HT AB CABLE REPLACEMENT
1268	12-02-2026	Part of : D-BLOCK MANSARA RAM PARK UTTAM NAGAR	1408	Other Outage	Unplanned Outage	12-02-2026	13:54	12-02-2026	15:02	1:08	0.000000	REPAIRING OF LT CIRCUIT
1269	12-02-2026	Part of : OM VIHAR PHASE 2 NAWADA	1329	Other Outage	Planned Outage	12-02-2026	14:28	12-02-2026	15:26	0:58	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING
1270	12-02-2026	Part of : R & R 1-BLOCK MOHAN GARDEN RAZAPUR KHURD	1067	Other Outage	Planned Outage	12-02-2026	11:09	12-02-2026	13:48	2:39	0.000442	3PH HT AB CABLE REPLACEMENT
1271	12-02-2026	Part of : OM VIHAR PHASE 5 HASTSAL	752	Other Outage	Planned Outage	12-02-2026	11:58	12-02-2026	14:29	2:31	0.000000	LT CIRCUIT MAINTENANCE
1272	13-02-2026	Part of : BHAGWATI GARDEN EXTENSION NAWADA,LAXMI VIHAR NAWADA	5533	Other Outage	Planned Outage	13-02-2026	15:26	13-02-2026	16:33	1:07	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1273	13-02-2026	Part of : LAXMI VIHAR NAWADA,BLOCK D & H BHAGWATI GARDEN NAWADA	5533	Other Outage	Planned Outage	13-02-2026	13:12	13-02-2026	15:20	2:08	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1274	13-02-2026	Part of : BLOCK R,RK & R1 MOHAN GARDEN RAZAPUR KHURD	584	Other Outage	Planned Outage	13-02-2026	11:54	13-02-2026	15:19	3:25	0.000569	3PH HT AB CABLE REPLACEMENT PER SPAN
1275	13-02-2026	Part of : BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK F ZAILDAR ENCLAVE NAWADA,NAWADA EXTENSION	1495	Other Outage	Planned Outage	13-02-2026	11:10	13-02-2026	13:50	2:40	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMET PER DT
1276	14-02-2026	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,	738	Other Outage	Planned Outage	14-02-2026	11:31	14-02-2026	13:09	1:38	0.000272	CONDUCTOR REPLACEMENT PER SPAN
1277	14-02-2026	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,	2278	Other Outage	Planned Outage	14-02-2026	11:51	14-02-2026	14:07	2:16	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1278	14-02-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK A MAHAVIR ENCLAVE NAWADA,BLOCK L BHAGWATI GARDEN NAWADA,BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK P MOHAN GARDEN RAZAPUR KHURD,	1030	Other Outage	Planned Outage	14-02-2026	11:35	14-02-2026	14:08	2:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMENT PER DT
1279	14-02-2026	Part of : PHASE 1 OM VIHAR NAWADA,	1008	Other Outage	Planned Outage	14-02-2026	10:48	14-02-2026	13:05	2:17	0.000000	1PH DB REPLACEMENT,3PH DB REPLACEMENT
1280	16-02-2026	Part of : D-BLOCK MANSA RAM PARK UTTAM NAGAR	1639	Other Outage	Unplanned Outage	16-02-2026	17:09	16-02-2026	17:39	0:30	0.000250	BIRDAGE
1281	16-02-2026	Part of : R 5-BLOCK RMOHAN GARDEN RAZAPUR KHURD	532	Other Outage	Planned Outage	16-02-2026	15:18	16-02-2026	16:33	1:15	0.000208	REPLACEMENT OF HT BUSHING ROD
1282	16-02-2026	Part of : L-BLOCK BHAGWATI GARDEN NAWADA	2662	Other Outage	Planned Outage	16-02-2026	12:46	16-02-2026	15:34	2:48	0.000933	GUARD WIRES SAGGING
1283	16-02-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	625	Other Outage	Planned Outage	16-02-2026	11:59	16-02-2026	14:15	2:16	0.000378	REPLACEMENT OF HT BUSHING ROD
1284	16-02-2026	Part of : B-BLOCK MAHAVIR ENCLAVE NAWADA,F-BLOCK ZAILDAR ENCLAVE NAWADA	1495	Other Outage	Planned Outage	16-02-2026	11:24	16-02-2026	14:07	2:43	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMENT PER DT
1285	16-02-2026	Part of : SHANTI PARK DWARKA	468	Other Outage	Planned Outage	16-02-2026	11:13	16-02-2026	14:09	2:56	0.000000	LT CIRCUIT MAINTENANCE
1286	17-02-2026	Part of : VIPIN GARDEN EXTENSION,LAXMI VIHAR NAWADA,SAINIK ENCLAVE VIPIN GARDEN NAWADA	4820	Other Outage	Planned Outage	17-02-2026	12:08	17-02-2026	14:02	1:54	0.000633	3PH HT AB CABLE REPLACEMENT PER SPAN
1287	17-02-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	2	Other Outage	Planned Outage	17-02-2026	12:22	17-02-2026	14:03	1:41	0.000000	REPLACEMENT OF LT BUSHING ROD
1288	17-02-2026	Part of : BLOCK E & L BHAGWATI GARDEN NAWADA,BLOCK A RAMA PARK BHAGWATI GARDEN	1539	Other Outage	Planned Outage	17-02-2026	11:25	17-02-2026	13:44	2:19	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMENT PER DT
1289	17-02-2026	Part of : BLOCK B1 SEWAK PARK DWARKA	512	Other Outage	Planned Outage	17-02-2026	11:43	17-02-2026	14:00	2:17	0.000000	REPLACEMENT OF LT BUSHING ROD
1290	18-02-2026	Part of : BLOCK D BHAGWATI GARDEN NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA	2275	Other Outage	Unplanned Outage	18-02-2026	07:54	18-02-2026	08:19	0:25	0.000433	HVDS FAULT
1291	18-02-2026	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK R MOHAN GARDEN RAZAPUR KHURD,BLOCK N 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK S MOHAN GARDEN RAZAPUR KHURD,BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD	5040	Other Outage	Unplanned Outage	18-02-2026	06:30	18-02-2026	07:10	0:40	0.000608	CABLE FAULT
1292	18-02-2026	Part of : RAZAPUR KHURD,	1067	Other Outage	Planned Outage	18-02-2026	12:07	18-02-2026	13:57	1:50	0.000611	REPLACEMENT OF HT BUSHING ROD
1293	18-02-2026	Part of : BHAGWATI GARDEN NAWADA,	130	Other Outage	Planned Outage	18-02-2026	11:40	18-02-2026	14:00	2:20	0.000000	REPLACEMENT OF LT BUSHING ROD
1294	18-02-2026	Part of : BLOCK K 6 ZAILDAR ENCLAVE HASTSAL,	2258	Other Outage	Planned Outage	18-02-2026	11:03	18-02-2026	13:56	2:53	0.000000	REPLACEMENT OF LT BUSHING ROD
1295	19-02-2026	Part of : Part of : R 5 & P 2-BLOCK MOHAN GARDEN RAZAPUR KHURD,H-BLOCK BHAGWATI GARDEN NAWADA	1181	Other Outage	Planned Outage	19-02-2026	15:22	19-02-2026	16:14	0:52	0.000144	3PH HT AB CABLE REPLACEMENT
1296	19-02-2026	Part of : Part of : R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	532	Other Outage	Planned Outage	19-02-2026	12:00	19-02-2026	14:09	2:09	0.000358	REPLACEMENT OF HT BUSHING ROD
1297	19-02-2026	Part of : Part of : D & H-BLOCK BHAGWATI GARDEN NAWADA	1575	Other Outage	Planned Outage	19-02-2026	11:20	19-02-2026	14:10	2:50	0.000000	3PH HT AB CABLE REPLACEMENT
1298	19-02-2026	Part of : Part of : OM VIHAR PHASE 2 NAWADA	310	Other Outage	Planned Outage	19-02-2026	11:43	19-02-2026	14:08	2:25	0.000000	LT CIRCUIT MAINTENANCE
1299	20-02-2026	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,RAZAPUR KHURD	1776	Other Outage	Planned Outage	20-02-2026	11:59	20-02-2026	14:59	3:00	0.000500	3PH HT AB CABLE REPLACEMENT
1300	20-02-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA,BLOCK B1 SEWAK PARK DWARKA	2228	Other Outage	Planned Outage	20-02-2026	11:19	20-02-2026	13:57	2:38	0.000878	HT CONDUCTOR REPLACEMENT
1301	20-02-2026	Part of : LAXMI VIHAR NAWADA	965	Other Outage	Planned Outage	20-02-2026	11:19	20-02-2026	13:49	2:30	0.000833	CONDUCTOR REPLACEMENT
1302	20-02-2026	Part of : MOHAN GARDEN NAWADA,OM VIHAR PHASE 1 NAWADA	1259	Other Outage	Planned Outage	20-02-2026	11:29	20-02-2026	13:58	2:29	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMENT PER DT
1303	21-02-2026	Part of : SHYAM PARK NAWADA MAJRA VILLAGE NAWADA	590	Other Outage	Unplanned Outage	21-02-2026	15:12	21-02-2026	16:45	1:33	0.001292	ATTEND WEAK POINT/HOT SPOT
1304	21-02-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	463	Other Outage	Planned Outage	21-02-2026	12:02	21-02-2026	14:33	2:31	0.000419	3PH DB REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1305	21-02-2026	Part of : PHASE 1 OM VIHAR NAWADA	1093	Other Outage	Planned Outage	21-02-2026	11:10	21-02-2026	13:40	2:30	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMET PER DT
1306	21-02-2026	Part of : BLOCK B1 SEWAK PARK DWARKA	556	Other Outage	Planned Outage	21-02-2026	11:34	21-02-2026	13:39	2:05	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1307	22-02-2026	Part of : BLOCK C VIPIN GARDEN NAWADA,SAINIK ENCLAVE VIPIN GARDEN NAWADA,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	4235	Other Outage	Unplanned Outage	22-02-2026	15:18	22-02-2026	15:58	0:40	0.000225	CABLE FAULT
1308	23-02-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA	1949	Other Outage	Planned Outage	23-02-2026	12:26	23-02-2026	15:40	3:14	0.001078	REPLACEMET OF HT BUSHING ROD
1309	23-02-2026	Part of : BLOCK R MOHAN GARDEN,RAZA PUR KHURD VIKAS NAGAR	1443	Other Outage	Planned Outage	23-02-2026	11:14	23-02-2026	14:08	2:54	0.000483	3PH HT AB CABLE REPLACEMENT
1310	23-02-2026	Part of : MOHAN GARDEN NAWADA,OM VIHAR PHASE-1 NAWADA	1259	Other Outage	Planned Outage	23-02-2026	11:04	23-02-2026	14:07	3:03	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DT REPLACEMET PER DT
1311	23-02-2026	Part of : SAINIK ENCLAVE VIPIN GARDEN NAWADA,VIPIN GARDEN EXTENSION,LAXMI VIHAR NAWADA	6702	Other Outage	Planned Outage	23-02-2026	11:28	23-02-2026	14:06	2:38	0.000000	GUARD WIRE LACS INSTALLTION
1312	23-02-2026	Part of : OM VIHAR PHASE 1 NAWADA	2021	Other Outage	Planned Outage	23-02-2026	11:00	23-02-2026	13:56	2:56	0.000000	LT CIRCUIT MAINTENANCE
1313	24-02-2026	Part of : K 7-BLOCK ZAILDAR ENCLAVE HASTSAL	1587	Other Outage	Unplanned Outage	24-02-2026	12:14	24-02-2026	13:51	1:37	0.000539	REPAIRING OF HVDS CIRCUIT
1314	24-02-2026	Part of : BLOCK E & L BHAGWATI GARDEN,BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA	1540	Other Outage	Planned Outage	24-02-2026	14:36	24-02-2026	16:27	1:51	0.000617	3PH HT AB CABLE REPLACEMENT
1315	24-02-2026	Part of : BLOCK P & P2 MOHAN GARDEN RAZAPUR KHURD	1384	Other Outage	Planned Outage	24-02-2026	13:38	24-02-2026	15:30	1:52	0.000311	3PH HT AB CABLE REPLACEMENT
1316	24-02-2026	Part of : VIPIN GARDEN EXTENSION NAWADA	109	Other Outage	Planned Outage	24-02-2026	12:15	24-02-2026	14:34	2:19	0.000000	LT CIRCUIT MAINTENANCE
1317	25-02-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL	541	Other Outage	Unplanned Outage	25-02-2026	16:17	25-02-2026	17:17	1:00	0.000333	CLEANING OF BUSHING
1318	25-02-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA	1949	Other Outage	Planned Outage	25-02-2026	14:46	25-02-2026	16:03	1:17	0.000428	REPLACEMENT OF LT BUSHING ROD
1319	25-02-2026	Part of : RAZAPUR KHURD	870	Other Outage	Planned Outage	25-02-2026	11:08	25-02-2026	13:57	2:49	0.000469	3PH HT AB CABLE REPLACEMENT PER SPAN
1320	25-02-2026	Part of : BLOCK A BHAGWATI GARDEN EXTENSION NAWADA	314	Other Outage	Planned Outage	25-02-2026	12:12	25-02-2026	14:46	2:34	0.000000	REPLACEMENT OF LT BUSHING ROD
1321	26-02-2026	Part of : BLOCK E BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA,	2664	Other Outage	Planned Outage	26-02-2026	11:30	26-02-2026	13:28	1:58	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1322	26-02-2026	Part of : LAXMI VIHAR NAWADA,	965	Other Outage	Planned Outage	26-02-2026	11:31	26-02-2026	13:28	1:57	0.000650	REPLACEMENT OF LT BUSHING ROD
1323	26-02-2026	Part of : PHASE 2 OM VIHAR NAWADA,	762	Other Outage	Planned Outage	26-02-2026	14:05	26-02-2026	16:28	2:23	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1324	26-02-2026	Part of : PHASE 2 OM VIHAR NAWADA,	796	Other Outage	Planned Outage	26-02-2026	14:06	26-02-2026	16:29	2:23	0.000000	REPLACEMET OF FAULTY END BOX
1325	26-02-2026	Part of : RAZAPUR KHURD,SAI& SETHI ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,	873	Other Outage	Planned Outage	26-02-2026	11:42	26-02-2026	14:53	3:11	0.000531	3PH HT AB CABLE REPLACEMENT PER SPAN
1326	26-02-2026	Part of : PHASE 2 OM VIHAR NAWADA,	1327	Other Outage	Planned Outage	26-02-2026	11:58	26-02-2026	14:57	2:59	0.000994	REPLACEMENT OF LT BUSHING ROD
1327	27-02-2026	Part of : PHASE 2 OM VIHAR NAWADA	1326	Other Outage	Unplanned Outage	27-02-2026	13:55	27-02-2026	16:09	2:14	0.000744	JUMPER REPLACEMENT
1328	27-02-2026	Part of : W,WE & RK-BLOCK MOHAN GARDEN RAZAPUR KHURD	1948	Other Outage	Planned Outage	27-02-2026	12:22	27-02-2026	14:39	2:17	0.000381	3PH HT AB CABLE REPLACEMENT
1329	27-02-2026	Part of : H-BLOCK BHAGWATI GARDEN NAWADA,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	8	Other Outage	Planned Outage	27-02-2026	12:29	27-02-2026	14:44	2:15	0.000000	3PH HT AB CABLE REPLACEMENT
1330	27-02-2026	Part of : B-BLOCK MAHAVIR ENCLAVE,F-BLOCK ZAILDAR ENCLAVE,NAWADA EXTENSION	1494	Other Outage	Planned Outage	27-02-2026	10:57	27-02-2026	13:53	2:56	0.000978	3PH HT AB CABLE REPLACEMENT
1331	28-02-2026	Part of : OM VIHAR PHASE 2 NAWADA	475	Other Outage	Unplanned Outage	28-02-2026	11:00	28-02-2026	12:27	1:27	0.000000	REPAIRING OF LT ACB
1332	28-02-2026	Part of : R 1-BLOCK MOHAN GARDEN RAZAPUR KHURD	128	Other Outage	Planned Outage	28-02-2026	12:02	28-02-2026	14:21	2:19	0.000772	REPLACEMENT OF HT BUSHING ROD
1333	28-02-2026	Part of : E & L-BLOCK BHAGWATI GARDEN NAWADA,A-BLOCK RAMA PARK BHAGWATI GARDEN NAWADA	1541	Other Outage	Planned Outage	28-02-2026	11:33	28-02-2026	14:24	2:51	0.000950	3PH HT AB CABLE REPLACEMENT
1334	01-02-2026	Part of : UDYOG NAGAR MANGOLPURI,BLOCK G DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	831	Other Outage	Planned Outage	01-02-2026	13:24	01-02-2026	15:03	1:39	0.000000	GUARD WIRES SAGGING PER SPAN
1335	01-02-2026	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR	430	Other Outage	Planned Outage	01-02-2026	13:23	01-02-2026	15:04	1:41	0.000000	REPLACEMENT OF LT BUSHING ROD
1336	01-02-2026	Part of : BLOCK J JEEVAN NIKETAN PASCHIM VIHAR	125	Other Outage	Planned Outage	01-02-2026	11:26	01-02-2026	13:42	2:16	0.000000	REPLACEMENT OF LT BUSHING ROD
1337	01-02-2026	Part of : POCKET A NARESH PARK NANGLOI	74	Other Outage	Planned Outage	01-02-2026	11:19	01-02-2026	13:42	2:23	0.000000	REPLACEMET OF HT BUSHING ROD
1338	02-02-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,BLOCK C KAMRUDDIN NAGAR NANGLOI,BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,ADHYAPAK NAGAR NANGLOI	9035	Other Outage	Unplanned Outage	02-02-2026	17:56	02-02-2026	18:48	0:52	0.000664	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1339	02-02-2026	Part of : BAPROLLA VILLAGE,	1236	Other Outage	Planned Outage	02-02-2026	13:26	02-02-2026	14:32	1:06	0.000183	REPLACEMET OF HT BUSHING ROD
1340	02-02-2026	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,	1589	Other Outage	Planned Outage	02-02-2026	11:20	02-02-2026	14:32	3:12	0.000800	REPLACEMET OF HT BUSHING ROD
1341	02-02-2026	Part of : DASS GARDEN,	674	Other Outage	Planned Outage	02-02-2026	11:04	02-02-2026	13:52	2:48	0.000467	REPLACEMET OF HT BUSHING ROD
1342	02-02-2026	Part of : BLOCK S JAWALAPURI EXTENSION PASCHIM VIHAR,	349	Other Outage	Planned Outage	02-02-2026	11:18	02-02-2026	13:57	2:39	0.000442	REPLACEMENT OF LT BUSHING ROD
1343	03-02-2026	Part of : SHIV VIHAR NANGLOI	725	Other Outage	Planned Outage	03-02-2026	11:44	03-02-2026	14:49	3:05	0.000000	LT CIRCUIT MAINTENANCE
1344	03-02-2026	Part of : UDYOG NAGAR MANGOLPURI	385	Other Outage	Planned Outage	03-02-2026	11:03	03-02-2026	14:28	3:25	0.000000	LT CIRCUIT MAINTENANCE
1345	03-02-2026	Part of : BLOCK A 4 MIYANWALI NAGAR PASCHIM VIHAR	206	Other Outage	Planned Outage	03-02-2026	10:53	03-02-2026	14:27	3:34	0.000000	LT CIRCUIT MAINTENANCE
1346	03-02-2026	Part of : PRADHAN ENCLAVE	1482	Other Outage	Planned Outage	03-02-2026	10:49	03-02-2026	14:28	3:39	0.000000	LT CIRCUIT MAINTENANCE
1347	04-02-2026	Part of : B-BLOCK DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	18	Other Outage	Planned Outage	04-02-2026	11:17	04-02-2026	14:57	3:40	0.000611	LT CIRCUIT MAINTENANCE
1348	04-02-2026	Part of : GURUNANAK VIHAR	497	Other Outage	Planned Outage	04-02-2026	11:01	04-02-2026	14:56	3:55	0.000653	LT CIRCUIT MAINTENANCE
1349	04-02-2026	Part of : J-BLOCK JEEVAN NIKETAN PASCHIM VIHAR	153	Other Outage	Planned Outage	04-02-2026	10:57	04-02-2026	14:56	3:59	0.000664	LT CIRCUIT MAINTENANCE
1350	05-02-2026	Part of : BLOCK B AMANPURI KAMRUDDIN NAGAR,BLOCK A & B NARESH PARK EXTENSION,BLOCK D KUNWAR SINGH NAGAR KAMARUDDIN NAGAR	271	Other Outage	Planned Outage	05-02-2026	10:57	05-02-2026	14:26	3:29	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1351	05-02-2026	Part of : BLOCK GH 8 PASCHIM VIHAR	411	Other Outage	Planned Outage	05-02-2026	10:56	05-02-2026	13:42	2:46	0.000000	REPLACEMET OF FAULTY END BOX
1352	05-02-2026	Part of : BLOCK GH 12 PASCHIM VIHAR	304	Other Outage	Planned Outage	05-02-2026	11:13	05-02-2026	13:49	2:36	0.000000	REPLACEMENT OF LT BUSHING ROD
1353	05-02-2026	Part of : CHANDER VIHAR	1013	Other Outage	Planned Outage	05-02-2026	11:03	05-02-2026	13:41	2:38	0.000000	REPLACEMET OF HT BUSHING ROD
1354	05-02-2026	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR	166	Other Outage	Planned Outage	05-02-2026	10:49	05-02-2026	13:50	3:01	0.000754	REPLACEMET OF HT BUSHING ROD
1355	06-02-2026	Part of : INDER ENCLAVE PASCHIM VIHAR,	92	Other Outage	Planned Outage	06-02-2026	11:10	06-02-2026	13:22	2:12	0.000000	REPLACEMENT OF LT BUSHING ROD
1356	06-02-2026	Part of : BLOCK GH10 SUNDER VIHAR PASCHIM VIHAR,	158	Other Outage	Planned Outage	06-02-2026	10:50	06-02-2026	13:23	2:33	0.000000	REPLACEMET OF HT BUSHING ROD
1357	06-02-2026	Part of : SHRI RAM COLONY,	125	Other Outage	Planned Outage	06-02-2026	11:14	06-02-2026	13:22	2:08	0.000000	REPLACEMET OF HT BUSHING ROD
1358	06-02-2026	Part of : SHIV VIHAR NANGLOI,	1450	Other Outage	Planned Outage	06-02-2026	11:11	06-02-2026	13:24	2:13	0.000000	REPLACEMET OF HT BUSHING ROD
1359	08-02-2026	Part of : UDYOG NAGAR MANGOLPURI	421	Other Outage	Planned Outage	08-02-2026	10:02	08-02-2026	12:47	2:45	0.000000	GUARD WIRES SAGGING
1360	09-02-2026	Part of : NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	200	Other Outage	Planned Outage	09-02-2026	10:55	09-02-2026	13:46	2:51	0.000713	REPLACEMENT OF LT BUSHING ROD
1361	09-02-2026	Part of : RAIL NEER PLANT NANGLOI	838	Other Outage	Planned Outage	09-02-2026	11:33	09-02-2026	13:43	2:10	0.000722	REPLACEMENT OF HT BUSHING ROD
1362	09-02-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR	45	Other Outage	Planned Outage	09-02-2026	11:24	09-02-2026	13:44	2:20	0.000778	REPLACEMENT OF LT BUSHING ROD
1363	09-02-2026	Part of : CHANDER VIHAR	530	Other Outage	Planned Outage	09-02-2026	10:55	09-02-2026	13:44	2:49	0.000469	REPLACEMENT OF HT BUSHING ROD
1364	10-02-2026	Part of : PRADHAN ENCLAVE,	714	Other Outage	Planned Outage	10-02-2026	12:09	10-02-2026	14:46	2:37	0.000000	REPLACEMENT OF LT BUSHING ROD
1365	10-02-2026	Part of : NARESH PARK NANGLOI,BLOCK A NARESH PARK EXTENSION NANGLOI,BLOCK B NARESH PARK EXTENSION NANGLOI,	2104	Other Outage	Planned Outage	10-02-2026	10:40	10-02-2026	13:45	3:05	0.000000	3PH HT AB END TERMINATION REPLACEMENT
1366	10-02-2026	Part of : UDYOG NAGAR MANGOLPURI,	284	Other Outage	Planned Outage	10-02-2026	11:04	10-02-2026	13:27	2:23	0.000000	REPLACEMENT OF LT BUSHING ROD
1367	10-02-2026	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,	292	Other Outage	Planned Outage	10-02-2026	10:57	10-02-2026	13:46	2:49	0.000000	REPLACEMET OF HT BUSHING ROD
1368	11-02-2026	Part of : RANJEET VIHAR	22	Other Outage	Planned Outage	11-02-2026	11:29	11-02-2026	14:07	2:38	0.000439	LT CIRCUIT MAINTENANCE
1369	11-02-2026	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI	1117	Other Outage	Planned Outage	11-02-2026	11:02	11-02-2026	14:07	3:05	0.000514	LT CIRCUIT MAINTENANCE
1370	12-02-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR	145	Other Outage	Planned Outage	12-02-2026	12:53	12-02-2026	13:43	0:50	0.000278	LT CIRCUIT MAINTENANCE
1371	12-02-2026	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI,TILANGPUR KOTLA VILLAGE,RISHAL GARDEN,TILANGPUR KOTLA,RANHOLLA	8653	Other Outage	Planned Outage	12-02-2026	11:05	12-02-2026	13:41	2:36	0.000000	GUARD WIRES SAGGING
1372	13-02-2026	Part of : CHANDER VIHAR, HIMGIRI ENCLAVE, RANJEET VIHAR, UDAI VIHAR	6507	Other Outage	Unplanned Outage	13-02-2026	12:18	13-02-2026	13:01	0:43	0.000645	BIRDAGE
1373	13-02-2026	Part of : DASS GARDEN,RAJIV RATAN AWAS FLATS,PRADHAN ENCLAVE	5188	Other Outage	Planned Outage	13-02-2026	14:48	13-02-2026	16:46	1:58	0.001311	GUARD WIRES SAGGING PER SPAN
1374	13-02-2026	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1239	Other Outage	Planned Outage	13-02-2026	11:10	13-02-2026	14:31	3:21	0.000558	REPLACEMET OF HT BUSHING ROD
1375	13-02-2026	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR	197	Other Outage	Planned Outage	13-02-2026	10:54	13-02-2026	14:31	3:37	0.000603	REPLACEMET OF HT BUSHING ROD
1376	13-02-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR	34	Other Outage	Planned Outage	13-02-2026	10:58	13-02-2026	14:30	3:32	0.000589	REPLACEMET OF HT BUSHING ROD
1377	14-02-2026	Part of : GRAM SABHA COLONY,	1550	Other Outage	Planned Outage	14-02-2026	11:23	14-02-2026	13:42	2:19	0.000000	REPLACEMENT OF LT BUSHING ROD
1378	14-02-2026	Part of : GRAM SABHA COLONY,	2	Other Outage	Planned Outage	14-02-2026	11:24	14-02-2026	13:43	2:19	0.000000	REPLACEMENT OF LT BUSHING ROD
1379	14-02-2026	Part of : EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR,	64	Other Outage	Planned Outage	14-02-2026	11:25	14-02-2026	13:49	2:24	0.000000	INSTALLATION OF BUS BAR

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1380	14-02-2026	Part of : BLOCK D VANDANA VIHAR NANGLOI,	1549	Other Outage	Planned Outage	14-02-2026	10:56	14-02-2026	13:48	2:52	0.000000	REPLACEMET OF HT BUSHING ROD
1381	15-02-2026	Part of : BLOCK X JJ COLONY 3 NANGLOI	640	Other Outage	Planned Outage	15-02-2026	11:06	15-02-2026	13:04	1:58	0.000656	REPLACEMENT OF HT BUSHING ROD
1382	15-02-2026	Part of : BLOCK X JJ COLONY 3 NANGLOI	817	Other Outage	Planned Outage	15-02-2026	11:05	15-02-2026	13:03	1:58	0.000656	REPLACEMENT OF HT BUSHING ROD
1383	16-02-2026	Part of : JAI VIHAR PH-1 & 3,RANHOLLA,TILANGPUR KOTLA VILLAGE,PRATAP VIHAR	1497	Other Outage	Planned Outage	16-02-2026	11:06	16-02-2026	11:30	0:24	0.000000	GUARD WIRE LACS INSTALLTION
1384	16-02-2026	Part of : AMBIKA VIHAR PASCHIM VIHAR	385	Other Outage	Planned Outage	16-02-2026	12:12	16-02-2026	14:11	1:59	0.000331	LT CIRCUIT MAINTENANCE
1385	16-02-2026	Part of : AMBIKA VIHAR PASCHIM VIHAR	293	Other Outage	Planned Outage	16-02-2026	11:05	16-02-2026	12:17	1:12	0.000100	LT CIRCUIT MAINTENANCE
1386	16-02-2026	Part of : B-BLOCK LAXMI PARK VANDANA VIHAR NANGLOI	1667	Other Outage	Planned Outage	16-02-2026	10:56	16-02-2026	14:06	3:10	0.000528	LT CIRCUIT MAINTENANCE
1387	16-02-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR	41	Other Outage	Planned Outage	16-02-2026	11:29	16-02-2026	14:08	2:39	0.000442	LT CIRCUIT MAINTENANCE
1388	17-02-2026	Part of : JAI VIHAR PH-1,BAPROLA VILLAGE,RAJIV RATAN AWAS FLATS	6963	Other Outage	Planned Outage	17-02-2026	10:55	17-02-2026	13:39	2:44	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1389	17-02-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR,SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI	3199	Other Outage	Planned Outage	17-02-2026	10:23	17-02-2026	12:29	2:06	0.000000	GUARD WIRES SAGGING PER SPAN
1390	17-02-2026	Part of : CAMP 5 JAWALAPURI PASCHIM VIHAR	698	Other Outage	Planned Outage	17-02-2026	11:13	17-02-2026	13:41	2:28	0.000000	REPLACEMENT OF LT BUSHING ROD
1391	17-02-2026	Part of : CHANDER VIHAR	1398	Other Outage	Planned Outage	17-02-2026	10:55	17-02-2026	13:44	2:49	0.000000	REPLACEMENT OF LT BUSHING ROD
1392	18-02-2026	Part of : RAJIV RATAN AWAS FLATS,PRADHAN ENCLAVE,NANGLI VIHAR,	7663	Other Outage	Planned Outage	18-02-2026	14:21	18-02-2026	16:26	2:05	0.000000	GUARD WIRES SAGGING PER SPAN
1393	18-02-2026	Part of : BLOCK 1 SUNDER VIHAR PASCHIM VIHAR,	223	Other Outage	Planned Outage	18-02-2026	10:59	18-02-2026	13:27	2:28	0.000822	REPLACEMET OF HT BUSHING ROD
1394	18-02-2026	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,	3899	Other Outage	Planned Outage	18-02-2026	11:07	18-02-2026	13:29	2:22	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1395	18-02-2026	Part of : UDYOG NAGAR MANGOLPURI,	110	Other Outage	Planned Outage	18-02-2026	11:01	18-02-2026	13:28	2:27	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1396	18-02-2026	Part of : UDYOG NAGAR MANGOLPURI,	24	Other Outage	Planned Outage	18-02-2026	11:00	18-02-2026	13:27	2:27	0.000408	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
1397	19-02-2026	Part of : Part of : NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI	1256	Other Outage	Planned Outage	19-02-2026	11:43	19-02-2026	13:53	2:10	0.000361	LT CIRCUIT MAINTENANCE
1398	19-02-2026	Part of : Part of : BHERA ENCLAVE PASCHIM VIHAR	328	Other Outage	Planned Outage	19-02-2026	10:58	19-02-2026	13:49	2:51	0.000475	LT CIRCUIT MAINTENANCE
1399	19-02-2026	Part of : Part of : NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI	699	Other Outage	Planned Outage	19-02-2026	11:33	19-02-2026	13:48	2:15	0.000375	LT CIRCUIT MAINTENANCE
1400	20-02-2026	Part of : POCKET A NARESH PARK NANGLOI,NANGLOI JAT NANGLOI	467	Other Outage	Unplanned Outage	20-02-2026	22:03	20-02-2026	22:37	0:34	0.000657	BIRDAGE
1401	20-02-2026	Part of : NANGLI VIHAR,JAI VIHAR BAPROLA,RANHOLLA	8221	Other Outage	Planned Outage	20-02-2026	10:52	20-02-2026	12:52	2:00	0.000000	GUARD WIRES SAGGING
1402	20-02-2026	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	712	Other Outage	Planned Outage	20-02-2026	11:39	20-02-2026	13:28	1:49	0.000000	LT CIRCUIT MAINTENANCE
1403	20-02-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	1532	Other Outage	Planned Outage	20-02-2026	12:36	20-02-2026	14:37	2:01	0.000000	3PH HT AB CABLE REPLACEMENT
1404	21-02-2026	Part of : JAI VIHAR PH-1,RANHOLLA,TILANGPUR KOTLA VILLAGE	2685	Other Outage	Planned Outage	21-02-2026	11:07	21-02-2026	13:33	2:26	0.000000	GUARD WIRES SAGGING PER SPAN
1405	21-02-2026	Part of : NANGLOI JAT	277	Other Outage	Planned Outage	21-02-2026	11:08	21-02-2026	13:32	2:24	0.000800	REPLACEMET OF HT BUSHING ROD
1406	22-02-2026	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR,NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	1308	Other Outage	Unplanned Outage	22-02-2026	10:13	22-02-2026	11:00	0:47	0.001071	CABLE FAULT
1407	22-02-2026	Part of : NANGLOI JAT NANGLOI,	635	Other Outage	Planned Outage	22-02-2026	10:29	22-02-2026	12:35	2:06	0.000700	REPLACEMET OF HT BUSHING ROD
1408	23-02-2026	Part of : Baprola Village,Nangli Vihar,Jai Vihar Ph-1, Ph-3,Harphool Vihar,Prashant Enclave,Nirmal Vihar Baprola	5875	Other Outage	Unplanned Outage	23-02-2026	15:54	23-02-2026	16:40	0:46	0.000026	CABLE FAULT
1409	23-02-2026	Part of : BLOCK D DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	974	Other Outage	Planned Outage	23-02-2026	11:39	23-02-2026	13:35	1:56	0.000000	LT CIRCUIT MAINTENANCE
1410	23-02-2026	Part of : BAPROLA VILLAGE,NANGLI VIHAR,JAI VIHAR PH-1 & 3,TILANGPUR KOTLA VILLAGE,HARPHOOL VIHAR,PRASHANT ENCLAVE,NIRMAL VIHAR BAPROLA	7031	Other Outage	Planned Outage	23-02-2026	10:59	23-02-2026	13:45	2:46	0.000000	GUARD WIRES SAGGING
1411	23-02-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	895	Other Outage	Planned Outage	23-02-2026	11:07	23-02-2026	13:34	2:27	0.000000	LT CIRCUIT MAINTENANCE
1412	23-02-2026	Part of : GURUNANAK VIHAR	424	Other Outage	Planned Outage	23-02-2026	10:43	23-02-2026	13:20	2:37	0.000000	LT CIRCUIT MAINTENANCE
1413	24-02-2026	Part of : SHIV VIHAR A & B BLOCK	407	Other Outage	Planned Outage	24-02-2026	12:26	24-02-2026	13:24	0:58	0.000000	REPLACEMENT OF FAULTY END BOX
1414	24-02-2026	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	210	Other Outage	Planned Outage	24-02-2026	11:18	24-02-2026	13:23	2:05	0.000694	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1415	24-02-2026	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1978	Other Outage	Planned Outage	24-02-2026	11:18	24-02-2026	13:24	2:06	0.000525	LT CIRCUIT MAINTENANCE
1416	25-02-2026	Part of : BLOCK GH 9 PASCHIM VIHAR	53	Other Outage	Planned Outage	25-02-2026	14:48	25-02-2026	16:18	1:30	0.000375	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1417	25-02-2026	Part of : RISHAL GARDEN,RANHOLLA,TILANGPUR KOTLA VILLAGE	8821	Other Outage	Planned Outage	25-02-2026	11:09	25-02-2026	12:59	1:50	0.001222	GUARD WIRES SAGGING PER SPAN
1418	25-02-2026	Part of : BLOCK GH 9 PASCHIM VIHAR	363	Other Outage	Planned Outage	25-02-2026	11:18	25-02-2026	13:00	1:42	0.000425	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1419	25-02-2026	Part of : JAI VIHAR PH-1,RANHOLLA,PRATAP VIHAR	2688	Other Outage	Planned Outage	25-02-2026	11:07	25-02-2026	12:58	1:51	0.001542	GUARD WIRES SAGGING PER SPAN
1420	25-02-2026	Part of : CHANDER VIHAR	1349	Other Outage	Planned Outage	25-02-2026	15:23	25-02-2026	16:39	1:16	0.000211	REPLACEMENT OF LT BUSHING ROD
1421	25-02-2026	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1078	Other Outage	Planned Outage	25-02-2026	11:03	25-02-2026	13:38	2:35	0.000861	REPLACEMET OF HT BUSHING ROD
1422	25-02-2026	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	745	Other Outage	Planned Outage	25-02-2026	11:02	25-02-2026	13:37	2:35	0.000861	REPLACEMET OF HT BUSHING ROD
1423	26-02-2026	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR	1751	Other Outage	Unplanned Outage	26-02-2026	14:42	26-02-2026	15:22	0:40	0.000633	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1424	26-02-2026	Part of : BHERA ENCLAVE PASCHIM VIHAR,	151	Other Outage	Planned Outage	26-02-2026	12:20	26-02-2026	13:53	1:33	0.000000	REPLACEMET OF HT BUSHING ROD
1425	26-02-2026	Part of : BLOCK GH 9 PASCHIM VIHAR,	117	Other Outage	Planned Outage	26-02-2026	10:51	26-02-2026	12:27	1:36	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1426	26-02-2026	Part of : BLOCK GH 8 PASCHIM VIHAR,	403	Other Outage	Planned Outage	26-02-2026	14:02	26-02-2026	16:19	2:17	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1427	26-02-2026	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,	1452	Other Outage	Planned Outage	26-02-2026	10:54	26-02-2026	13:46	2:52	0.000000	REPLACEMET OF HT BUSHING ROD
1428	26-02-2026	Part of : NILOTHI VILLAGE,CHANDER VIHAR,RISALA GARDEN NILOTHI,	2824	Other Outage	Planned Outage	26-02-2026	10:56	26-02-2026	13:42	2:46	0.000000	GUARD WIRES SAGGING PER SPAN
1429	27-02-2026	Part of : Udyog Nagar Mangolpuri,Rail Neer Plant Nangloi,Block G Delhi State Industrial Development Corporation Nangloi,Block A Delhi State Industrial Development Corporation Nangloi	1483	Other Outage	Unplanned Outage	27-02-2026	03:22	27-02-2026	04:01	0:39	0.000520	CABLE FAULT
1430	27-02-2026	Part of : D-BLOCK VANDANA VIHAR NANGLOI	833	Other Outage	Planned Outage	27-02-2026	12:47	27-02-2026	13:35	0:48	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1431	27-02-2026	Part of : RANJEET VIHAR	325	Other Outage	Planned Outage	27-02-2026	11:34	27-02-2026	13:32	1:58	0.000000	LT CIRCUIT MAINTENANCE
1432	28-02-2026	Part of : UDYOG NAGAR MANGOLPURI	302	Other Outage	Unplanned Outage	28-02-2026	16:01	28-02-2026	16:44	0:43	0.000043	FAULT IN HT CONSUMER PANEL (K-29 UDYOG NAGAR)
1433	28-02-2026	Part of : RANHOLLA	1	Other Outage	Unplanned Outage	28-02-2026	12:01	28-02-2026	12:40	0:39	0.000000	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1434	28-02-2026	Part of : 2 C-BLOCK NANGLOI EXTENSION,NANGLOI JAT	2348	Other Outage	Unplanned Outage	28-02-2026	09:21	28-02-2026	09:56	0:35	0.001693	CABLE FAULT
1435	28-02-2026	Part of : SHIV VIHAR NANGLOI,B-BLOCK LAXMI PARK VANDANA VIHAR,NANGLOI JAT	3093	Other Outage	Unplanned Outage	28-02-2026	09:12	28-02-2026	09:55	0:43	0.000143	CABLE FAULT
1436	28-02-2026	Part of : GH 14-BLOCK PASCHIM VIHAR	417	Other Outage	Planned Outage	28-02-2026	14:02	28-02-2026	15:19	1:17	0.000214	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1437	28-02-2026	Part of : A & B-BLOCK SHIV VIHAR	407	Other Outage	Planned Outage	28-02-2026	13:44	28-02-2026	15:20	1:36	0.000400	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1438	28-02-2026	Part of : BLOCK GH 14 PASCHIM VIHAR	343	Other Outage	Planned Outage	28-02-2026	11:01	28-02-2026	12:42	1:41	0.000281	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1439	28-02-2026	Part of : JAI VIHAR PH-1 & 3 BAPROLA	4686	Other Outage	Planned Outage	28-02-2026	11:13	28-02-2026	12:42	1:29	0.000989	GUARD WIRES SAGGING
1440	02-02-2026	Part of : INDRA MARKET,	328	Other Outage	Planned Outage	02-02-2026	14:25	02-02-2026	16:23	1:58	0.000819	REPLACEMET OF HT BUSHING ROD
1441	02-02-2026	Part of : GOYALA DAIRY QUTUB VIHAR,GOYLA KHURD,BLOCK A GOYLA VIHAR GOYLA KHURD,BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR,	846	Other Outage	Planned Outage	02-02-2026	11:26	02-02-2026	14:26	3:00	0.000750	3PH HT AB CABLE REPLACEMENT PER SPAN
1442	02-02-2026	Part of : TODARMAL COLONY NAJAFGARH,	274	Other Outage	Planned Outage	02-02-2026	11:18	02-02-2026	13:19	2:01	0.000504	REPLACEMET OF HT BUSHING ROD
1443	02-02-2026	Part of : SHYAM KUNJ DINPUR,	1357	Other Outage	Planned Outage	02-02-2026	10:55	02-02-2026	13:47	2:52	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1444	03-02-2026	Part of : NAJAFGARH EXTENSION	0	Other Outage	Unplanned Outage	03-02-2026	07:37	03-02-2026	08:04	0:27	0.001193	CABLE FAULT
1445	03-02-2026	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	2	Other Outage	Planned Outage	03-02-2026	14:20	03-02-2026	16:03	1:43	0.000572	REPLACEMENT OF HT BUSHING ROD
1446	03-02-2026	Part of : GOPAL EXTENSION II NAJAFGARH	571	Other Outage	Planned Outage	03-02-2026	11:19	03-02-2026	13:01	1:42	0.000000	LT CIRCUIT MAINTENANCE
1447	03-02-2026	Part of : BLOCK A1 ROSHAN GARDEN MASUDABAD NAJAFGARH	581	Other Outage	Planned Outage	03-02-2026	14:44	03-02-2026	17:10	2:26	0.000608	REPLACEMENT OF HT BUSHING ROD
1448	03-02-2026	Part of : NAJAFGARH EXTENSION	725	Other Outage	Planned Outage	03-02-2026	12:54	03-02-2026	15:46	2:52	0.001194	3PH HT AB CABLE REPLACEMENT
1449	03-02-2026	Part of : ROSHAN VIHAR NAJAFGARH	362	Other Outage	Planned Outage	03-02-2026	12:00	03-02-2026	15:01	3:01	0.001006	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1450	03-02-2026	Part of : MAHESH GARDEN NANU RAM PARK NAJAFGARH	278	Other Outage	Planned Outage	03-02-2026	12:28	03-02-2026	15:16	2:48	0.001167	REPLACEMENT OF HT BUSHING ROD
1451	03-02-2026	Part of : BLOCK E & Q NEW ROSHAN PURA NAJAFGARH	906	Other Outage	Planned Outage	03-02-2026	10:51	03-02-2026	13:39	2:48	0.000000	3PH HT AB CABLE REPLACEMENT
1452	04-02-2026	Part of : QUTUB VIHAR PHASE 2	427	Other Outage	Planned Outage	04-02-2026	10:54	04-02-2026	15:58	5:04	0.005067	REPLACEMET OF FAULTY END BOX
1453	04-02-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	9	Other Outage	Planned Outage	04-02-2026	11:26	04-02-2026	13:15	1:49	0.000000	LT CIRCUIT MAINTENANCE
1454	04-02-2026	Part of : SAMTA ENCLAVE QUTUB VIHAR	987	Other Outage	Planned Outage	04-02-2026	10:54	04-02-2026	15:57	5:03	0.001263	3PH HT AB CABLE REPLACEMENT
1455	04-02-2026	Part of : E-BLOCK SHYAM VIHAR,DURGA PARK NAJAFGARH	1529	Other Outage	Planned Outage	04-02-2026	13:48	04-02-2026	15:57	2:09	0.000000	3PH HT AB CABLE REPLACEMENT
1456	05-02-2026	Part of : DHARAMPURA NAJAFGARH	1179	Other Outage	Planned Outage	05-02-2026	13:09	05-02-2026	15:56	2:47	0.000000	REPLACEMENT OF LT BUSHING ROD
1457	05-02-2026	Part of : BABA HARI DAS ENCLAVE JHARODA KALAN	2	Other Outage	Planned Outage	05-02-2026	13:39	05-02-2026	16:35	2:56	0.000000	REPLACEMENT OF LT BUSHING ROD
1458	05-02-2026	Part of : SHYAM VIHAR I,BLOCK E SHYAM VIHAR I,BLOCK X NEW ROSHAN PURA NAJAFGARH	1473	Other Outage	Planned Outage	05-02-2026	12:00	05-02-2026	15:00	3:00	0.001250	REPLACEMET OF HT BUSHING ROD
1459	05-02-2026	Part of : ROSHAN VIHAR NAJAFGARH	362	Other Outage	Planned Outage	05-02-2026	12:44	05-02-2026	15:38	2:54	0.000967	REPLACEMET OF HT BUSHING ROD
1460	05-02-2026	Part of : BABA HARIDAS ENCLAVE	502	Other Outage	Planned Outage	05-02-2026	11:41	05-02-2026	13:54	2:13	0.000000	REPLACEMENT OF LT BUSHING ROD
1461	05-02-2026	Part of : NAJAFGARH EXTENSION,BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI	847	Other Outage	Planned Outage	05-02-2026	11:33	05-02-2026	14:33	3:00	0.001250	DT REPLACEMET PER DT
1462	05-02-2026	Part of : GOYALA DAIRY QUTUB VIHAR,GOYLA KHURD,BLOCK A GOYLA VIHAR GOYLA KHURD	846	Other Outage	Planned Outage	05-02-2026	09:24	05-02-2026	12:25	3:01	0.000754	DT REPLACEMET PER DT
1463	05-02-2026	Part of : MUNIRKA KUNJ DINPUR,SHANTI VIHAR DINPUR,DURGA VIHAR I DINPUR	1009	Other Outage	Planned Outage	05-02-2026	10:08	05-02-2026	13:01	2:53	0.003844	3PH HT AB CABLE REPLACEMENT PER SPAN
1464	06-02-2026	Part of : HTC.ST.THOMAS NJF	0	Other Outage	Unplanned Outage	06-02-2026	19:15	06-02-2026	19:55	0:40	0.000000	TRANSIENT FAULT
1465	06-02-2026	Part of : NIRMAL VIHAR DICHAON KALAN,	1068	Other Outage	Planned Outage	06-02-2026	12:48	06-02-2026	14:45	1:57	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1466	06-02-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR,DATA RAM PARK DINPUR,	679	Other Outage	Planned Outage	06-02-2026	11:46	06-02-2026	13:05	1:19	0.001975	REPLACEMENT OF LT BUSHING ROD
1467	06-02-2026	Part of : LOKESH PARK EXTN NAJAFGARH,LOKESH PARK NAJAFGARH,INDRA MARKET,	683	Other Outage	Planned Outage	06-02-2026	13:44	06-02-2026	17:07	3:23	0.000000	REPLACEMENT OF LT BUSHING ROD
1468	06-02-2026	Part of : RAGHOPUR VILLAGE,	370	Other Outage	Planned Outage	06-02-2026	12:14	06-02-2026	17:03	4:49	0.001606	REPLACEMET OF HT BUSHING ROD
1469	06-02-2026	Part of : NANGLI DAIRY NANGLI SAKRAWATI,	959	Other Outage	Planned Outage	06-02-2026	11:26	06-02-2026	14:32	3:06	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1470	06-02-2026	Part of : BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI,	317	Other Outage	Planned Outage	06-02-2026	11:25	06-02-2026	14:33	3:08	0.001044	3PH HT AB CABLE REPLACEMENT PER SPAN
1471	06-02-2026	Part of : DHARAMPURA NAJAFGARH,	1369	Other Outage	Planned Outage	06-02-2026	10:52	06-02-2026	13:48	2:56	0.000000	REPLACEMET OF HT BUSHING ROD
1472	07-02-2026	Part of : SHIV ENCLAVE,SAINIK NIKETAN,SULTAN GARDEN,NEW HEERA PARK NAJAFGARH	450	Other Outage	Planned Outage	07-02-2026	12:55	07-02-2026	15:39	2:44	0.000000	3PH HT AB CABLE REPLACEMENT
1473	07-02-2026	Part of : ROSHAN VIHAR 1,DURGA VIHAR I,DURGA PARK NAJAFGARH	690	Other Outage	Planned Outage	07-02-2026	10:57	07-02-2026	13:42	2:45	0.002750	DT REPLACEMENT PER DT
1474	07-02-2026	Part of : NAJAFGARH EXTENSION,AJAY PARK MASUDABAD,NATHU RAM PARK MASUDABAD NAJAFGARH	1980	Other Outage	Planned Outage	07-02-2026	11:35	07-02-2026	14:18	2:43	0.001132	DT REPLACEMENT PER DT
1475	07-02-2026	Part of : QUTUB VIHAR PHASE 2	642	Other Outage	Planned Outage	07-02-2026	13:03	07-02-2026	15:42	2:39	0.000442	LT CIRCUIT MAINTENANCE
1476	08-02-2026	Part of : SHIV NAGAR DICHAON KALAN,TIKRI KALAN,NEELWAL VILLAGE	0	Other Outage	Unplanned Outage	08-02-2026	15:34	08-02-2026	16:18	0:44	0.009754	CABLE FAULT
1477	08-02-2026	Part of : D-BLOCK LAXMI VIHAR COLONY NANGLI SAKRAWATI	48	Other Outage	Planned Outage	08-02-2026	12:08	08-02-2026	14:48	2:40	0.000889	REPLACEMENT OF HT BUSHING ROD
1478	09-02-2026	Part of : NAJAFGARH EXTENSION,AJAY PARK MASUDABAD,NATHU RAM PARK MASUDABAD NAJAFGARH	1980	Other Outage	Planned Outage	09-02-2026	13:52	09-02-2026	16:23	2:31	0.000839	3PH HT AB CABLE REPLACEMENT PER SPAN
1479	09-02-2026	Part of : RANAJI ENCLAVE MASUDABAD NAJAFGARH	2378	Other Outage	Planned Outage	09-02-2026	14:27	09-02-2026	16:36	2:09	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1480	09-02-2026	Part of : ROSHAN VIHAR NAJAFGARH	362	Other Outage	Planned Outage	09-02-2026	12:54	09-02-2026	15:37	2:43	0.000906	REPLACEMENT OF HT BUSHING ROD
1481	09-02-2026	Part of : BLOCK A1 ROSHAN GARDEN MASUDABAD NAJAFGARH	581	Other Outage	Planned Outage	09-02-2026	11:05	09-02-2026	13:49	2:44	0.000228	REPLACEMENT OF LT BUSHING ROD
1482	09-02-2026	Part of : SHYAM VIHAR I NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH	1473	Other Outage	Planned Outage	09-02-2026	11:33	09-02-2026	13:58	2:25	0.000806	REPLACEMENT OF HT BUSHING ROD
1483	09-02-2026	Part of : PREM NAGAR NAJAFGARH	10	Other Outage	Planned Outage	09-02-2026	10:30	09-02-2026	13:13	2:43	0.004075	REPLACEMENT OF LT BUSHING ROD
1484	09-02-2026	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	2	Other Outage	Planned Outage	09-02-2026	11:06	09-02-2026	13:56	2:50	0.000944	GUARD WIRES SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1485	09-02-2026	Part of : REWLA KHANPUR VILLAGE	15	Other Outage	Planned Outage	09-02-2026	11:33	09-02-2026	14:58	3:25	0.003701	REPLACEMENT OF LT BUSHING ROD
1486	09-02-2026	Part of : NANAK HERI VILLAGE	309	Other Outage	Planned Outage	09-02-2026	11:33	09-02-2026	14:58	3:25	0.000569	REPLACEMENT OF LT BUSHING ROD
1487	10-02-2026	Part of : BLOCK B INDRA PARK MASUDABAD NAJAFGARH,	1406	Other Outage	Planned Outage	10-02-2026	12:51	10-02-2026	15:47	2:56	0.000978	DT REPLACEMET PER DT
1488	10-02-2026	Part of : BLOCK B NAVEEN PALACE JHARODA KALAN,SARASWATI KUNJ JHARODA KALAN,	1291	Other Outage	Planned Outage	10-02-2026	12:52	10-02-2026	15:48	2:56	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1489	10-02-2026	Part of : GOYALA DAIRY QUTUB VIHAR,	849	Other Outage	Planned Outage	10-02-2026	12:44	10-02-2026	15:46	3:02	0.000758	REPLACEMENT OF LT BUSHING ROD
1490	10-02-2026	Part of : QUTUB VIHAR PHASE 2 QUTUB VIHAR,	434	Other Outage	Planned Outage	10-02-2026	10:52	10-02-2026	13:50	2:58	0.003708	REPLACEMENT OF LT BUSHING ROD
1491	10-02-2026	Part of : PAPRAWAT VILLAGE,	235	Other Outage	Planned Outage	10-02-2026	10:28	10-02-2026	13:25	2:57	0.003933	REPLACEMET OF HT BUSHING ROD
1492	11-02-2026	Part of : INDRA MARKET,SAINIK ENCLAVE,LOKESH PARK EXTN NAJAFGARH,SULTAN GARDEN,LOKESH PARK NAJAFGARH,NIRMAL VIHAR DICHAON KALAN	7757	Other Outage	Unplanned Outage	11-02-2026	13:16	11-02-2026	14:13	0:57	0.001647	CABLE FAULT
1493	11-02-2026	Part of : NEW HIRA NAGAR DICHAON KALAN	140	Other Outage	Planned Outage	11-02-2026	14:50	11-02-2026	17:17	2:27	0.000000	REPLACEMENT OF HT BUSHING ROD
1494	11-02-2026	Part of : ROSHAN PURA NAJAFGARH	299	Other Outage	Planned Outage	11-02-2026	11:13	11-02-2026	13:23	2:10	0.003250	REPLACEMENT OF HT BUSHING ROD
1495	11-02-2026	Part of : ROSHAN VIHAR 1,DURGA VIHAR I,ROSHAN VIHAR,DATA RAM PARK,SHYAM ENCLAVE,BLOCK E SHYAM VIHAR I	948	Other Outage	Planned Outage	11-02-2026	11:48	11-02-2026	14:00	2:12	0.002493	REPLACEMENT OF HT BUSHING ROD
1496	11-02-2026	Part of : BHARTHAL VILLAGE DWARKA	898	Other Outage	Planned Outage	11-02-2026	10:58	11-02-2026	15:07	4:09	0.004150	REPLACEMENT OF HT BUSHING ROD
1497	11-02-2026	Part of : ROSHAN VIHAR NAJAFGARH	362	Other Outage	Planned Outage	11-02-2026	12:28	11-02-2026	17:04	4:36	0.001150	REPLACEMENT OF HT BUSHING ROD
1498	11-02-2026	Part of : SANGAM VIHAR,DHARAMPURA NAJAFGARH	1021	Other Outage	Planned Outage	11-02-2026	10:32	11-02-2026	13:09	2:37	0.000000	3PH HT AB CABLE REPLACEMENT
1499	11-02-2026	Part of : SAMTA ENCLAVE QUTUB VIHAR	218	Other Outage	Planned Outage	11-02-2026	11:46	11-02-2026	14:02	2:16	0.000000	LT CIRCUIT MAINTENANCE
1500	12-02-2026	Part of : BHARTHAL VILLAGE DWARKA	332	Other Outage	Unplanned Outage	12-02-2026	13:59	12-02-2026	14:37	0:38	0.000211	REPAIRING OF HT O/H CIRCUIT
1501	12-02-2026	Part of : A-BLOCK QUTUB VIHAR PHASE 1	1306	Other Outage	Planned Outage	12-02-2026	14:36	12-02-2026	17:12	2:36	0.000217	EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER
1502	12-02-2026	Part of : SAMTA ENCLAVE QUTUB VIHAR	632	Other Outage	Planned Outage	12-02-2026	13:34	12-02-2026	16:23	2:49	0.003521	REPLACEMENT OF HT BUSHING ROD
1503	12-02-2026	Part of : BLOCK B NAVEEN PALACE JHARODA KALAN	530	Other Outage	Planned Outage	12-02-2026	11:50	12-02-2026	14:40	2:50	0.000000	REPLACEMENT OF HT BUSHING ROD
1504	12-02-2026	Part of : GANDHI PARK,SHYAM VIHAR-2,SHIV PURI-2 DINPUR	2207	Other Outage	Planned Outage	12-02-2026	12:01	12-02-2026	14:58	2:57	0.000000	3PH HT AB CABLE REPLACEMENT
1505	12-02-2026	Part of : E-BLOCK SHYAM VIHAR-1 & X-BLOCK NEW ROSHAN PURA NAJAFGARH	1473	Other Outage	Planned Outage	12-02-2026	12:07	12-02-2026	14:41	2:34	0.000856	REPLACEMENT OF HT BUSHING ROD
1506	12-02-2026	Part of : SECTOR 27 DWARKA	32	Other Outage	Planned Outage	12-02-2026	11:11	12-02-2026	14:05	2:54	0.002900	REPLACEMENT OF HT BUSHING ROD
1507	12-02-2026	Part of : DURGA VIHAR-1 & 2 DINPUR,DATA RAM PARK,MUNIRKA KUNJ,SHANTI VIHAR	1009	Other Outage	Planned Outage	12-02-2026	10:09	12-02-2026	13:15	3:06	0.004650	REPLACEMENT OF HT BUSHING ROD
1508	12-02-2026	Part of : A-BLOCK QUTUB VIHAR PHASE-1	265	Other Outage	Planned Outage	12-02-2026	10:29	12-02-2026	13:17	2:48	0.000467	LT CIRCUIT MAINTENANCE
1509	13-02-2026	Part of : SHYAM VIHAR - II DINPUR,SHIV PURI II DINPUR, VILLAGE DEENPUR,SHYAM ENCLAVE DINPUR	5645	Other Outage	Unplanned Outage	13-02-2026	16:13	13-02-2026	17:04	0:51	0.000532	CABLE FAULT
1510	13-02-2026	Part of : ROSHAN VIHAR NAJAFGARH	362	Other Outage	Planned Outage	13-02-2026	11:27	13-02-2026	13:20	1:53	0.000628	REPLACEMET OF HT BUSHING ROD
1511	13-02-2026	Part of : BLOCK B SECTOR 19 DWARKA	449	Other Outage	Planned Outage	13-02-2026	11:27	13-02-2026	13:17	1:50	0.001833	REPLACEMET OF HT BUSHING ROD
1512	13-02-2026	Part of : SAINIK ENCLAVE	399	Other Outage	Planned Outage	13-02-2026	13:52	13-02-2026	16:11	2:19	0.000000	REPLACEMENT OF LT BUSHING ROD
1513	13-02-2026	Part of : SAINIK ENCLAVE	321	Other Outage	Planned Outage	13-02-2026	12:33	13-02-2026	15:11	2:38	0.004389	REPLACEMENT OF LT BUSHING ROD
1514	13-02-2026	Part of : NANGLI DAIRY NANGLI SAKRAWATI	958	Other Outage	Planned Outage	13-02-2026	11:53	13-02-2026	14:01	2:08	0.000711	REPLACEMET OF HT BUSHING ROD
1515	13-02-2026	Part of : BLOCK B POCHANPUR DWARKA	1004	Other Outage	Planned Outage	13-02-2026	10:29	13-02-2026	13:10	2:41	0.002683	REPLACEMET OF HT BUSHING ROD
1516	13-02-2026	Part of : DATA RAM PARK,DURGA VIHAR I,ROSHAN VIHAR 1 NAJAFGARH	679	Other Outage	Planned Outage	13-02-2026	10:58	13-02-2026	13:18	2:20	0.003111	REPLACEMENT OF LT BUSHING ROD
1517	13-02-2026	Part of : BLOCK A QUTUB VIHAR PHASE 1	1306	Other Outage	Planned Outage	13-02-2026	11:51	13-02-2026	14:02	2:11	0.000182	EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER
1518	14-02-2026	Part of : BHARTHAL VILLAGE DWARKA,SECTOR 27 DWARKA,BLOCK B POCHANPUR DWARKA,SECTOR 23 DWARKA,SECTOR 26 DWARKA,	6032	Other Outage	Unplanned Outage	14-02-2026	13:06	14-02-2026	13:22	0:16	0.000356	SAFEGUARDING OF CABLE
1519	14-02-2026	Part of : SECTOR 27 DWARKA,NANAK HERI VILLAGE,	1879	Other Outage	Unplanned Outage	14-02-2026	13:04	14-02-2026	13:21	0:17	0.000236	SAFEGUARDING OF CABLE
1520	14-02-2026	Part of : REWLA KHANPUR VILLAGE,	506	Other Outage	Planned Outage	14-02-2026	13:00	14-02-2026	14:46	1:46	0.000442	FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1521	14-02-2026	Part of : SATYAMPURAM,	1	Other Outage	Planned Outage	14-02-2026	13:43	14-02-2026	16:31	2:48	0.000000	REPLACEMENT OF LT BUSHING ROD
1522	14-02-2026	Part of : ANAND VIHAR NANGLI SAKRAWATI,ARJUN PARK NANGLI SAKRAWATI,	962	Other Outage	Planned Outage	14-02-2026	11:17	14-02-2026	14:03	2:46	0.000461	DT REPLACEMET PER DT
1523	14-02-2026	Part of : SHIKARPUR VILLAGE,	18	Other Outage	Planned Outage	14-02-2026	10:50	14-02-2026	13:33	2:43	0.003622	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1524	14-02-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR,DURGA PARK NAJAFGARH,	690	Other Outage	Planned Outage	14-02-2026	10:05	14-02-2026	12:53	2:48	0.004200	REPLACEMENT OF LT BUSHING ROD
1525	14-02-2026	Part of : SHYAM VIHAR I NAJAFGARH,SHYAM KUNJ DINPUR,	1651	Other Outage	Planned Outage	14-02-2026	10:12	14-02-2026	12:52	2:40	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1526	16-02-2026	Part of : ROSHAN VIHAR-1 NAJAFGARH,DURGA VIHAR-I,DATA RAM PARK DINPUR,E-BLOCK SHYAM VIHAR I NAJAFGARH,SHYAM ENCLAVE	3550	Other Outage	Unplanned Outage	16-02-2026	12:21	16-02-2026	13:12	0:51	0.000368	CABLE FAULT
1527	16-02-2026	Part of : SURYA VIHAR,SHIV PURI-2,GANDHI PARK,KANGANHERI VILLAGE,REWLA KHANPUR VILLAGE,BADUSARAI,CHAWLA	3694	Other Outage	Unplanned Outage	16-02-2026	12:19	16-02-2026	14:51	2:32	0.000633	CABLE FAULT
1528	16-02-2026	Part of : SECTOR 29 DWARKA	409	Other Outage	Planned Outage	16-02-2026	13:01	16-02-2026	13:56	0:55	0.000229	REPLACEMENT OF HT BUSHING ROD
1529	16-02-2026	Part of : SHYAM VIHAR-1 NAJAFGARH,X-BLOCK NEW ROSHAN PURA NAJAFGARH	1473	Other Outage	Planned Outage	16-02-2026	12:00	16-02-2026	14:51	2:51	0.000713	REPLACEMENT OF HT BUSHING ROD
1530	16-02-2026	Part of : NANGLI DAIRY NANGLI SAKRAWATI	965	Other Outage	Planned Outage	16-02-2026	12:00	16-02-2026	14:48	2:48	0.003733	REPLACEMENT OF HT BUSHING ROD
1531	16-02-2026	Part of : AGARWAL COLONY HAIBUTPUR	546	Other Outage	Planned Outage	16-02-2026	11:49	16-02-2026	14:58	3:09	0.000000	REPLACEMENT OF HT BUSHING ROD
1532	16-02-2026	Part of : E-BLOCK NEW ROSHAN PURA NAJAFGARH,DURGA PARK NAJAFGARH	1114	Other Outage	Planned Outage	16-02-2026	11:00	16-02-2026	13:54	2:54	0.000000	3PH HT AB CABLE REPLACEMENT
1533	16-02-2026	Part of : GHASIPURA	1160	Other Outage	Planned Outage	16-02-2026	11:27	16-02-2026	13:35	2:08	0.000711	DT REPLACEMENT PER DT
1534	16-02-2026	Part of : PAPRAWAT VILLAGE	235	Other Outage	Planned Outage	16-02-2026	10:52	16-02-2026	14:17	3:25	0.003986	REPLACEMENT OF HT BUSHING ROD
1535	16-02-2026	Part of : NANAK HERI VILLAGE	146	Other Outage	Planned Outage	16-02-2026	11:49	16-02-2026	14:33	2:44	0.000456	LT CIRCUIT MAINTENANCE
1536	17-02-2026	Part of : JHARODA KALAN, SHIV NAGAR DICHAON KALAN, BLOCK A NAVEEN PALACE JHARODA KALAN, BABA HARIDAS ENCLAVE	2597	Other Outage	Unplanned Outage	17-02-2026	11:07	17-02-2026	11:54	0:47	0.000813	CABLE FAULT
1537	17-02-2026	Part of : CHAWLA, SECTOR 24 & 29 DWARKA, SOMESH VIHAR CHAWLA	1781	Other Outage	Unplanned Outage	17-02-2026	09:24	17-02-2026	10:09	0:45	0.000000	CABLE DAMAGED BY OUTSIDE AGENCY (DDA)
1538	17-02-2026	Part of : NAJAFGARH EXTENSION	197	Other Outage	Planned Outage	17-02-2026	13:37	17-02-2026	16:32	2:55	0.001215	3PH HT AB CABLE REPLACEMENT PER SPAN
1539	17-02-2026	Part of : INDRA MARKET,LOKESH PARK EXTN NAJAFGARH	502	Other Outage	Planned Outage	17-02-2026	11:21	17-02-2026	14:11	2:50	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1540	17-02-2026	Part of : SECTOR 29 DWARKA	255	Other Outage	Planned Outage	17-02-2026	10:38	17-02-2026	13:19	2:41	0.000671	REPLACEMET OF HT BUSHING ROD
1541	17-02-2026	Part of : KHAIRA VILLAGE	10	Other Outage	Planned Outage	17-02-2026	10:47	17-02-2026	13:18	2:31	0.003775	REPLACEMENT OF LT BUSHING ROD
1542	17-02-2026	Part of : BLOCK B SECTOR 19 DWARKA	449	Other Outage	Planned Outage	17-02-2026	11:45	17-02-2026	14:12	2:27	0.002450	REPLACEMENT OF LT BUSHING ROD
1543	17-02-2026	Part of : DHARAMPURA NAJAFGARH	477	Other Outage	Planned Outage	17-02-2026	10:00	17-02-2026	12:43	2:43	0.000000	REPLACEMENT OF LT BUSHING ROD
1544	18-02-2026	Part of : POCHANPUR DWARKA	30	Other Outage	Unplanned Outage	18-02-2026	16:14	18-02-2026	16:18	0:04	0.000022	CABLE FAULT
1545	18-02-2026	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	19	Other Outage	Unplanned Outage	18-02-2026	12:49	18-02-2026	13:45	0:56	0.000000	CABLE FAULT
1546	18-02-2026	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	19	Other Outage	Unplanned Outage	18-02-2026	08:27	18-02-2026	09:08	0:41	0.001640	HT SYSTEM FAULT
1547	18-02-2026	Part of : SULTAN GARDEN,SAINIK NIKETAN NAJAFGARH,NEW HEERA PARK NAJAFGARH,SHIV NAGAR NAJAFGARH,INDRA MARKET,SHIV ENCLAVE NAJAFGARH,NAJAFGARH PARK COLONY NAJAFGARH,LOKESH PARK EXTN NAJAFGARH,LOKESH PARK NAJAFGARH,VIRENDRA MARKET,KRISHNA ENCLAVE SP ROAD AREA NAJAFGARH,UGGERSAIN PARK	1531	Other Outage	Planned Outage	18-02-2026	14:04	18-02-2026	14:46	0:42	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1548	18-02-2026	Part of : SULTAN GARDEN,SHIV ENCLAVE NAJAFGARH,SAINIK NIKETAN NAJAFGARH,NEW HEERA PARK NAJAFGARH,NEW HIRA NAGAR DICHAON KALAN,SHIV NAGAR DICHAON KALAN,DICHAON ENCLAVE DICHAON KALAN,NATHU RAM PARK MASUDABAD NAJAFGARH,NEELWAL VILLAGE,KRISHNA ENCLAVE SP ROAD AREA NAJAFGARH,BANI AIR FORCE CAMP JAI VIHAR BAPROLA,DICHAON KALAN VILLAGE DICHAON KALAN,NIRMAL VIHAR DICHAON KALAN,	2542	Other Outage	Planned Outage	18-02-2026	14:06	18-02-2026	14:47	0:41	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1549	18-02-2026	Part of : PREM NAGAR NAJAFGARH,	9	Other Outage	Planned Outage	18-02-2026	11:04	18-02-2026	13:01	1:57	0.002925	REPLACEMENT OF LT BUSHING ROD
1550	18-02-2026	Part of : D K FLORICULTURE PVT LTD & 57/4	1	Other Outage	Planned Outage	18-02-2026	10:03	18-02-2026	11:29	1:26	0.001672	REPLACEMET OF HT BUSHING ROD
1551	18-02-2026	Part of : KANGANHERI VILLAGE,	456	Other Outage	Planned Outage	18-02-2026	14:13	18-02-2026	16:54	2:41	0.000894	REPLACEMET OF HT BUSHING ROD
1552	19-02-2026	Part of : Part of : D-BLOCK LAXMI VIHAR COLONY NANGLI	137	Other Outage	Planned Outage	19-02-2026	11:32	19-02-2026	13:25	1:53	0.000785	DT REPLACEMENT PER DT
1553	19-02-2026	Part of : Part of : SECTOR 27 DWARKA	27	Other Outage	Planned Outage	19-02-2026	11:30	19-02-2026	13:23	1:53	0.002197	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1554	19-02-2026	Part of : Part of : B-BLOCK NAVEEN PALACE & SARASWATI KUNJ JHARODA KALAN	1291	Other Outage	Planned Outage	19-02-2026	12:12	19-02-2026	14:36	2:24	0.000000	3PH HT AB CABLE REPLACEMENT
1555	19-02-2026	Part of : Part of : E-BLOCK SHYAM VIHAR-1,X-BLOCK NEW ROSHAN PURA NAJAFGARH	1473	Other Outage	Planned Outage	19-02-2026	11:29	19-02-2026	14:18	2:49	0.000704	REPLACEMENT OF HT BUSHING ROD
1556	19-02-2026	Part of : Part of : DURGA VIHAR-I DINPUR	821	Other Outage	Planned Outage	19-02-2026	10:27	19-02-2026	13:19	2:52	0.004300	REPLACEMENT OF HT BUSHING ROD
1557	19-02-2026	Part of : Part of : SHYAM KUNJ DINPUR,E-BLOCK SHYAM VIHAR-1 NAJAFGARH	1615	Other Outage	Planned Outage	19-02-2026	10:30	19-02-2026	13:17	2:47	0.000000	3PH HT AB CABLE REPLACEMENT
1558	19-02-2026	Part of : Part of : CHAWLA	466	Other Outage	Planned Outage	19-02-2026	10:10	19-02-2026	13:03	2:53	0.000721	LT CIRCUIT MAINTENANCE
1559	20-02-2026	Part of : GANDHI PARK,SHIV PURI-2,SHYAM VIHAR-2,SURYA VIHAR,E-BLOCK E SHYAM VIHAR-1 NAJAFGARH,SHYAM ENCLAVE,SHIV PURI-1 DINPUR	5357	Other Outage	Unplanned Outage	20-02-2026	11:54	20-02-2026	12:46	0:52	0.000819	CABLE FAULT
1560	20-02-2026	Part of : CHAWLA	177	Other Outage	Planned Outage	20-02-2026	12:42	20-02-2026	13:36	0:54	0.000150	LT CIRCUIT MAINTENANCE
1561	20-02-2026	Part of : BLOCK B & D LAXMI VIHAR COLONY,NAJAFGARH EXTENSION,NANGLI SANKRANTI NANGLI SAKRAWATI,SAI BABA ENCLAVE MASUDABAD NAJAFGARH	1316	Other Outage	Planned Outage	20-02-2026	14:18	20-02-2026	15:38	1:20	0.000444	DT REPLACEMET PER DT
1562	20-02-2026	Part of : SHYAM KUNJ DINPUR	49	Other Outage	Planned Outage	20-02-2026	10:59	20-02-2026	12:07	1:08	0.000000	REPLACEMET OF HT BUSHING ROD
1563	20-02-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH	1125	Other Outage	Planned Outage	20-02-2026	11:00	20-02-2026	12:59	1:59	0.002644	REPLACEMET OF HT BUSHING ROD
1564	20-02-2026	Part of : SULTAN GARDEN,LOKESH PARK EXTN,INDRA MARKET,SAINIK ENCLAVE,LOKESH PARK,NIRMAL VIHAR DICHAON KALAN	5166	Other Outage	Planned Outage	20-02-2026	12:48	20-02-2026	15:34	2:46	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1565	20-02-2026	Part of : JANTA VIHAR,AGARWAL COLONY,BABA HARIDAS NAGAR,EKTA VIHAR & RAJIV VIHAR,DICHAON ENCLAVE DICHAON KALAN,BABA HARI DAS ENCLAVE JHARODA KALAN	4529	Other Outage	Planned Outage	20-02-2026	12:43	20-02-2026	15:32	2:49	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1566	21-02-2026	Part of : BABA HARIDAS ENCLAVE,JHARODA KALAN,SHIV NAGAR DICHAON KALAN	3034	Other Outage	Planned Outage	21-02-2026	14:26	21-02-2026	14:52	0:26	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1567	21-02-2026	Part of : SURYA VIHAR DINPUR,SHIV PURI II DINPUR,SHYAM ENCLAVE DINPUR	1117	Other Outage	Planned Outage	21-02-2026	11:59	21-02-2026	13:00	1:01	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1568	21-02-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR	297	Other Outage	Planned Outage	21-02-2026	10:46	21-02-2026	12:30	1:44	0.002600	REPLACEMENT OF LT BUSHING ROD
1569	21-02-2026	Part of : SHIKARPUR VILLAGE	23	Other Outage	Planned Outage	21-02-2026	13:06	21-02-2026	15:29	2:23	0.003575	REPLACEMENT OF LT BUSHING ROD
1570	21-02-2026	Part of : BLOCK A QUTUB VIHAR PHASE 1	1306	Other Outage	Planned Outage	21-02-2026	11:20	21-02-2026	14:00	2:40	0.003556	REPLACEMENT OF LT BUSHING ROD
1571	21-02-2026	Part of : BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI	317	Other Outage	Planned Outage	21-02-2026	10:54	21-02-2026	13:23	2:29	0.001035	3PH HT AB CABLE REPLACEMENT PER SPAN
1572	21-02-2026	Part of : SECTOR 27 DWARKA	268	Other Outage	Planned Outage	21-02-2026	10:43	21-02-2026	13:02	2:19	0.002703	REPLACEMET OF HT BUSHING ROD
1573	22-02-2026	Part of : GOYALA DAIRY QUTUB VIHAR,GOYLA KHURD,BLOCK A GOYLA VIHAR GOYLA KHURD,BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR,TAJPUR KHURD,SHYAM VIHAR - II DINPUR,PAHARWA COLONY CHAWLA,CHAWLA	2944	Other Outage	Unplanned Outage	22-02-2026	10:42	22-02-2026	11:07	0:25	0.000550	HVDS FAULT
1574	22-02-2026	Part of : SOMESH VIHAR CHAWLA,KANGANHERI VILLAGE,RAGHOPUR VILLAGE,BADUSARAI,NANAK HERI VILLAGE,CHAWLA,SECTOR 115 BAJHERA	3250	Other Outage	Unplanned Outage	22-02-2026	09:42	22-02-2026	10:21	0:39	0.001096	CABLE FAULT
1575	22-02-2026	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,	48	Other Outage	Planned Outage	22-02-2026	12:56	22-02-2026	15:34	2:38	0.001097	REPLACEMET OF HT BUSHING ROD
1576	22-02-2026	Part of : BHARTHAL VILLAGE DWARKA,	332	Other Outage	Planned Outage	22-02-2026	11:26	22-02-2026	14:05	2:39	0.000883	REPLACEMET OF HT BUSHING ROD
1577	23-02-2026	Part of : Samta Enclave Qutub Vihar,Block A Qutub Vihar Phase 1 Qutub Vihar	786	Other Outage	Unplanned Outage	23-02-2026	19:39	23-02-2026	20:19	0:40	0.000486	HT SYSTEM FAULT
1578	23-02-2026	Part of : BLOCK B POCHANPUR DWARKA	1004	Other Outage	Planned Outage	23-02-2026	15:01	23-02-2026	15:39	0:38	0.000633	REPLACEMET OF HT BUSHING ROD
1579	23-02-2026	Part of : BHARTHAL VILLAGE DWARKA,	331	Other Outage	Planned Outage	23-02-2026	15:31	23-02-2026	17:07	1:36	0.000400	REPLACEMET OF HT BUSHING ROD
1580	23-02-2026	Part of : SHYAM ENCLAVE,BLOCK E SHYAM VIHAR I NAJAFGARH	763	Other Outage	Planned Outage	23-02-2026	11:01	23-02-2026	12:29	1:28	0.000000	3PH HT AB CABLE REPLACEMENT
1581	23-02-2026	Part of : SULTAN GARDEN,LOKESH PARK EXTN,INDRA MARKET,SAINIK ENCLAVE,NIRMAL VIHAR,MAHESH GARDEN,NANU RAM PARK,VIRENDRA MARKET,AGARWAL COLONY,NEW HIRA NAGAR,BLOCK B LAXMI VIHAR COLONY,NAJAFGARH VILLAGE	5166	Other Outage	Planned Outage	23-02-2026	13:57	23-02-2026	16:18	2:21	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1582	23-02-2026	Part of : NAJAFGARH EXTENSION,AJAY PARK & NATHU RAM PARK MASUDABAD	1980	Other Outage	Planned Outage	23-02-2026	11:08	23-02-2026	13:59	2:51	0.000950	DT REPLACEMET
1583	23-02-2026	Part of : SARIKA VIHAR DINPUR	8	Other Outage	Planned Outage	23-02-2026	10:57	23-02-2026	13:01	2:04	0.003100	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1584	23-02-2026	Part of : CHAWLA	710	Other Outage	Planned Outage	23-02-2026	12:21	23-02-2026	15:02	2:41	0.000671	LT CIRCUIT MAINTENANCE
1585	24-02-2026	Part of : KAPOOR FARM HOUSE,FSS GEMINI PARK NEAR DJB STAFF	0	Other Outage	Unplanned Outage	24-02-2026	05:06	24-02-2026	05:43	0:37	0.000000	HVDS FAULT
1586	24-02-2026	Part of : NAJAFGARH EXTENSION,AJAY PARK MASUDABAD,NATHU RAM PARK MASUDABAD NAJAFGARH	1980	Other Outage	Planned Outage	24-02-2026	15:33	24-02-2026	16:12	0:39	0.000271	DT REPLACEMENT
1587	24-02-2026	Part of : SHIV NAGAR NAJAFGARH,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET	1296	Other Outage	Planned Outage	24-02-2026	13:17	24-02-2026	15:14	1:57	0.000000	3PH HT AB CABLE REPLACEMENT
1588	24-02-2026	Part of : PIND WALA KALAN VILLAGE,SHERPUR EXTENTION,KHARKHARI ROND VILLAGE	2573	Other Outage	Planned Outage	24-02-2026	13:15	24-02-2026	14:51	1:36	0.002133	REPLACEMENT OF HT BUSHING ROD
1589	24-02-2026	Part of : POCHANPUR DWARKA	912	Other Outage	Planned Outage	24-02-2026	11:50	24-02-2026	14:35	2:45	0.002750	REPLACEMENT OF HT BUSHING ROD
1590	24-02-2026	Part of : KHAIRA VILLAGE	171	Other Outage	Planned Outage	24-02-2026	11:07	24-02-2026	13:09	2:02	0.003050	REPLACEMENT OF HT BUSHING ROD
1591	25-02-2026	Part of : BLOCK B INDRA PARK MASUDABAD NAJAFGARH	1406	Other Outage	Planned Outage	25-02-2026	13:35	25-02-2026	15:10	1:35	0.000660	DT REPLACEMET PER DT
1592	25-02-2026	Part of : ASALATPUR KHAWAD	355	Other Outage	Planned Outage	25-02-2026	11:50	25-02-2026	13:17	1:27	0.001692	REPLACEMET OF HT BUSHING ROD
1593	25-02-2026	Part of : BLOCK A QUTUB VIHAR PHASE 1	118	Other Outage	Planned Outage	25-02-2026	12:26	25-02-2026	14:01	1:35	0.000000	REPLACEMENT OF LT BUSHING ROD
1594	25-02-2026	Part of : SULTAN GARDEN,SHIV ENCLAVE NAJAFGARH,SAINIK NIKETAN NAJAFGARH	2542	Other Outage	Planned Outage	25-02-2026	13:05	25-02-2026	16:03	2:58	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1595	25-02-2026	Part of : RANAJI ENCLAVE MASUDABAD NAJAFGARH	2378	Other Outage	Planned Outage	25-02-2026	11:10	25-02-2026	13:50	2:40	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1596	25-02-2026	Part of : KHARKHARI NAHA VILLAGE	19	Other Outage	Planned Outage	25-02-2026	11:10	25-02-2026	13:17	2:07	0.002117	REPLACEMET OF HT BUSHING ROD
1597	26-02-2026	Part of : SATYAMPURAM,TIKRI KALAN,JHARODA KALAN	911	Other Outage	Unplanned Outage	26-02-2026	16:28	26-02-2026	17:13	0:45	0.000800	CABLE FAULT
1598	26-02-2026	Part of : DURGA VIHAR I DINPUR,	821	Other Outage	Planned Outage	26-02-2026	11:06	26-02-2026	13:04	1:58	0.002622	REPLACEMET OF HT BUSHING ROD
1599	26-02-2026	Part of : SATYAMPURAM,JHARODA KALAN,	895	Other Outage	Planned Outage	26-02-2026	13:15	26-02-2026	15:46	2:31	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1600	26-02-2026	Part of : SHYAM VIHAR I NAJAFGARH,BLOCK E SHYAM VIHAR I NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH,	1473	Other Outage	Planned Outage	26-02-2026	12:06	26-02-2026	14:47	2:41	0.000000	REPLACEMET OF HT BUSHING ROD
1601	26-02-2026	Part of : QUTUB VIHAR PHASE 2 QUTUB VIHAR,	427	Other Outage	Planned Outage	26-02-2026	11:05	26-02-2026	13:48	2:43	0.000000	SUB STATION CLEANING
1602	26-02-2026	Part of : ANAND VIHAR NANGLI SAKRAWATI,NANGLI SANKRANTI NANGLI SAKRAWATI,	675	Other Outage	Planned Outage	26-02-2026	11:13	26-02-2026	14:04	2:51	0.000950	DT REPLACEMET PER DT
1603	26-02-2026	Part of : REWLA KHANPUR VILLAGE,	179	Other Outage	Planned Outage	26-02-2026	11:36	26-02-2026	14:23	2:47	0.000464	REPLACEMENT OF LT BUSHING ROD
1604	26-02-2026	Part of : GANDHI PARK DINPUR,SHYAM VIHAR - II DINPUR,SHIV PURI II DINPUR,	2207	Other Outage	Planned Outage	26-02-2026	10:15	26-02-2026	12:53	2:38	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1605	27-02-2026	Part of : SHYAM VIHAR-1 NAJAFGARH,SHYAM KUNJ DINPUR	573	Other Outage	Planned Outage	27-02-2026	15:02	27-02-2026	15:53	0:51	0.000283	REPLACEMENT OF HT BUSHING ROD
1606	27-02-2026	Part of : ARJUN PARK NANGLI SAKRAWATI	1453	Other Outage	Planned Outage	27-02-2026	13:51	27-02-2026	15:11	1:20	0.000333	DT REPLACEMENT
1607	27-02-2026	Part of : SARASWATI KUNJ,LOKESH PARK EXTN,B-BLOCK NAVEEN PALACE,SURYA KUNJ,DHANAK MOHALLA HAIBUTPUR,INDRA MARKET,BABA HARIDAS ENCLAVE,KRISHNA ENCLAVE,NEW VISION COLONY,SARASWATI ENCLAVE,JANTA VIHAR,AGARWAL COLONY,BABA HARIDAS NAGAR,EKTA VIHAR & RAJIV VIHAR,DICHAON ENCLAVE,BABA HARI DAS ENCLAVE JHARODA KALAN	4529	Other Outage	Planned Outage	27-02-2026	13:22	27-02-2026	15:48	2:26	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1608	27-02-2026	Part of : SULTAN GARDEN,LOKESH PARK EXTN,INDRA MARKET,SAINIK ENCLAVE,NIRMAL VIHA,MAHESH GARDEN,NANU RAM PARK,VIRENDRA MARKET,AGARWAL COLONY,NEW HIRA NAGAR,B-BLOCK LAXMI VIHAR COLONY,NAJAFGARH VILLAGE.SHIV ENCLAVE	5166	Other Outage	Planned Outage	27-02-2026	12:07	27-02-2026	14:33	2:26	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1609	27-02-2026	Part of : ROSHAN VIHAR-1 NAJAFGARH	1125	Other Outage	Planned Outage	27-02-2026	10:56	27-02-2026	13:02	2:06	0.003150	REPLACEMENT OF HT BUSHING ROD
1610	27-02-2026	Part of : SHYAM ENCLAVE DINPUR,E-BLOCK SHYAM VIHAR-1 NAJAFGARH	563	Other Outage	Planned Outage	27-02-2026	10:21	27-02-2026	13:45	3:24	0.000000	REPLACEMENT OF HT BUSHING ROD
1611	28-02-2026	Part of : BABA HARIDAS ENCLAVE,JHARODA KALAN,SHIV NAGAR DICHAON KALAN	1699	Other Outage	Planned Outage	28-02-2026	11:20	28-02-2026	11:26	0:06	0.000000	GUARD WIRE LACS INSTALLTION,JUMPER REPLACEMENT PER POLE
1612	28-02-2026	Part of : ARJUN PARK & ANAND VIHAR NANGLI SAKRAWATI	1006	Other Outage	Planned Outage	28-02-2026	12:09	28-02-2026	13:35	1:26	0.000597	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1613	28-02-2026	Part of : POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA	248	Other Outage	Planned Outage	28-02-2026	11:35	28-02-2026	13:03	1:28	0.001711	REPLACEMENT OF HT BUSHING ROD
1614	28-02-2026	Part of : ROSHAN VIHAR-1 NAJAFGARH,DURGA VIHAR-1 DINPUR	297	Other Outage	Planned Outage	28-02-2026	11:06	28-02-2026	13:15	2:09	0.003225	REPLACEMENT OF HT BUSHING ROD
1615	28-02-2026	Part of : E-BLOCK SHYAM VIHAR-1,DINARPUR EXTENSION,DURGA PARK NAJAFGARH	1529	Other Outage	Planned Outage	28-02-2026	10:12	28-02-2026	12:49	2:37	0.000000	3PH HT AB CABLE REPLACEMENT
1616	28-02-2026	Part of : TAJPUR KHURD	319	Other Outage	Planned Outage	28-02-2026	09:56	28-02-2026	12:28	2:32	0.000633	LT CIRCUIT MAINTENANCE
1617	02-02-2026	Part of : MADIPUR PUNJABI BAGH,	420	Other Outage	Planned Outage	02-02-2026	10:51	02-02-2026	13:55	3:04	0.000511	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1618	02-02-2026	Part of : RBI ENCLAVE PASCHIM VIHAR,	124	Other Outage	Planned Outage	02-02-2026	10:43	02-02-2026	13:54	3:11	0.000531	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1619	02-02-2026	Part of : HTC:ROAD NO-12 KOTHI NO-7 EAST PUNJABI BAGH	1	Other Outage	Planned Outage	02-02-2026	10:27	02-02-2026	13:55	3:28	0.000578	CT REPLACEMENT,DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,END TERMINATION COVER REPLACEMENT,PROPER SEALING RMU PER WAY,PROPER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,RELAY REPLACEMENT/VPI/FPI,SF6 GAS FILLING
1620	03-02-2026	Part of : MADIPUR PUNJABI BAGH	151	Other Outage	Planned Outage	03-02-2026	10:55	03-02-2026	14:12	3:17	0.001642	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
1621	03-02-2026	Part of : BLOCK A 6 PASCHIM VIHAR	468	Other Outage	Planned Outage	03-02-2026	10:55	03-02-2026	14:11	3:16	0.000817	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
1622	04-02-2026	Part of : JWALAHERI VILLAGE,IFCI COLONY,B 3-BLOCK PASCHIM VIHAR	1802	Other Outage	Unplanned Outage	04-02-2026	10:22	04-02-2026	11:20	0:58	0.000773	CABLE FAULT
1623	04-02-2026	Part of : A 3-BLOCK CA APARTMENTS PASCHIM VIHAR	147	Other Outage	Planned Outage	04-02-2026	10:35	04-02-2026	13:04	2:29	0.000621	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
1624	04-02-2026	Part of : BR AMBEDKAR UNIVERSITY KARAMPURA (HT CONSUMER)	1	Other Outage	Planned Outage	04-02-2026	10:08	04-02-2026	13:05	2:57	0.000492	CLEANING OF HT BUSHING PER WAY,DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,END TERMINATION COVER REPLACEMENT
1625	05-02-2026	Part of : BLOCK B 3 PASCHIM VIHAR	812	Other Outage	Planned Outage	05-02-2026	10:56	05-02-2026	12:31	1:35	0.000396	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING
1626	05-02-2026	Part of : RAILWAY COLONY NORTH SHAKURBASTI	1	Other Outage	Planned Outage	05-02-2026	11:02	05-02-2026	12:32	1:30	0.000500	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
1627	06-02-2026	Part of : BLOCK C NEW MULTAN NAGAR SHAKURBASTI,	288	Other Outage	Planned Outage	06-02-2026	11:00	06-02-2026	14:23	3:23	0.000564	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
1628	06-02-2026	Part of : PUNJABI BAGH EXTENSION PUNJABI BAGH,	115	Other Outage	Planned Outage	06-02-2026	10:21	06-02-2026	12:54	2:33	0.000850	DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1629	09-02-2026	Part of : BLOCK C & E KARAMPURA, KARAMPURA INDUSTRIAL AREA	2796	Other Outage	Unplanned Outage	09-02-2026	12:22	09-02-2026	13:20	0:58	0.001034	CABLE FAULT
1630	09-02-2026	Part of : AVTAR ENCLAVE PASCHIM VIHAR	198	Other Outage	Unplanned Outage	09-02-2026	14:01	09-02-2026	17:03	3:02	0.000506	MOBILE TRANSFORMER REPLACEMENT
1631	09-02-2026	Part of : INDIRA COLONY TRI NAGAR	1	Other Outage	Planned Outage	09-02-2026	14:39	09-02-2026	17:02	2:23	0.000397	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1632	09-02-2026	Part of : RAILWAY COLONY NORTH SHAKURBASTI	135	Other Outage	Planned Outage	09-02-2026	13:24	09-02-2026	15:37	2:13	0.000554	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF SILICAGEL IN BREATHER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1633	09-02-2026	Part of : RAILWAY COLONY NORTH SHAKURBASTI	645	Other Outage	Planned Outage	09-02-2026	11:16	09-02-2026	13:29	2:13	0.000554	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF HT BUSHING ROD
1634	10-02-2026	Part of : MADHUBAN ENCLAVE PUNJABI BAGH,	4	Other Outage	Planned Outage	10-02-2026	11:04	10-02-2026	12:57	1:53	0.000314	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1635	10-02-2026	Part of : BLOCK BG 6 PASCHIM VIHAR,	234	Other Outage	Planned Outage	10-02-2026	11:03	10-02-2026	12:56	1:53	0.000471	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1636	11-02-2026	Part of : BLOCK BG 8 PASCHIM VIHAR	116	Other Outage	Planned Outage	11-02-2026	11:12	11-02-2026	12:19	1:07	0.000744	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1637	11-02-2026	Part of : RAILWAY COLONY NORTH SHAKURBASTI	326	Other Outage	Planned Outage	11-02-2026	10:56	11-02-2026	13:32	2:36	0.000650	DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
1638	11-02-2026	Part of : BLOCK H KARAMPURA WEST	114	Other Outage	Planned Outage	11-02-2026	10:22	11-02-2026	14:55	4:33	0.000758	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1639	12-02-2026	Part of : A 2-BLOCK PASCHIM VIHAR	563	Other Outage	Unplanned Outage	12-02-2026	12:29	12-02-2026	15:18	2:49	0.000000	REPAIRED OF BUS BAR COUPLING
1640	12-02-2026	Part of : E-BLOCK NEW MULTAN NAGAR SHAKURBASTI	323	Other Outage	Planned Outage	12-02-2026	11:01	12-02-2026	12:13	1:12	0.000200	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
1641	12-02-2026	Part of : RAILWAY COLONY NORTH SHAKURBASTI	101	Other Outage	Planned Outage	12-02-2026	13:01	12-02-2026	15:23	2:22	0.000394	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
1642	13-02-2026	Part of : JANTA COLONY PASCHIM VIHAR	394	Other Outage	Planned Outage	13-02-2026	10:35	13-02-2026	12:50	2:15	0.000375	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1643	13-02-2026	Part of : BLOCK BG 6 PASCHIM VIHAR	141	Other Outage	Planned Outage	13-02-2026	10:45	13-02-2026	12:49	2:04	0.000344	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF LUGS
1644	13-02-2026	Part of : KARAMPURA INDUSTRIAL AREA	132	Other Outage	Planned Outage	13-02-2026	10:08	13-02-2026	12:48	2:40	0.000444	REPLACEMENT OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
1645	16-02-2026	Part of : A 1-BLOCK KRISHNA APARTMENT PASCHIM VIHAR	211	Other Outage	Planned Outage	16-02-2026	11:20	16-02-2026	13:13	1:53	0.000314	REPLACEMENT OF SILICAGEL IN BREATHER
1646	16-02-2026	Part of : AVTAR ENCLAVE PASCHIM VIHAR	198	Other Outage	Planned Outage	16-02-2026	11:00	16-02-2026	12:55	1:55	0.001278	DT REPLACEMENT,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
1647	16-02-2026	Part of : A-BLOCK PASCHIM PURI PASCHIM VIHAR	113	Other Outage	Planned Outage	16-02-2026	11:01	16-02-2026	12:52	1:51	0.000308	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
1648	16-02-2026	Part of : BG 3 & BG 6-BLOCK PASCHIM VIHAR	830	Other Outage	Planned Outage	16-02-2026	10:15	16-02-2026	13:12	2:57	0.000983	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN
1649	16-02-2026	Part of : KARAMPURA INDUSTRIAL AREA	1	Other Outage	Planned Outage	16-02-2026	10:00	16-02-2026	12:53	2:53	0.000481	REPLACEMENT OF HT BUSHING ROD
1650	17-02-2026	Part of : SWAYAMSIDHA COLONY PUNJABI BAGH	68	Other Outage	Planned Outage	17-02-2026	11:25	17-02-2026	13:20	1:55	0.000479	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
1651	17-02-2026	Part of : BLOCK B4 PASCHIM VIHAR	73	Other Outage	Planned Outage	17-02-2026	10:00	17-02-2026	11:28	1:28	0.000244	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1652	18-02-2026	Part of : BLOCK A 1B KRISHNA APARTMENT PASCHIM VIHAR,	298	Other Outage	Planned Outage	18-02-2026	10:55	18-02-2026	13:48	2:53	0.000481	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1653	19-02-2026	Part of : Part of : PUNJABI BAGH EXTENSION	174	Other Outage	Planned Outage	19-02-2026	12:07	19-02-2026	14:23	2:16	0.000378	LT CIRCUIT MAINTENANCE
1654	20-02-2026	Part of : POCKET GH1 PASCHIM VIHAR	153	Other Outage	Planned Outage	20-02-2026	13:13	20-02-2026	15:12	1:59	0.000331	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1655	21-02-2026	Part of : AVTAR ENCLAVE PASCHIM VIHAR	198	Other Outage	Planned Outage	21-02-2026	12:45	21-02-2026	14:24	1:39	0.001375	CONDUCTOR REPLACEMENT PER SPAN,INSTALLATION OF PHASE SEPERATOR PER SPAN
1656	23-02-2026	Part of : RBI ENCLAVE PASCHIM VIHAR	112	Other Outage	Planned Outage	23-02-2026	15:54	23-02-2026	17:26	1:32	0.001150	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1657	23-02-2026	Part of : PASCHIM VIHAR EXTENSION PASCHIM VIHAR	72	Other Outage	Planned Outage	23-02-2026	10:46	23-02-2026	12:48	2:02	0.000339	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
1658	23-02-2026	Part of : BLOCK E KARAMPURA	35	Other Outage	Planned Outage	23-02-2026	10:14	23-02-2026	12:49	2:35	0.000431	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD
1659	24-02-2026	Part of : BLOCK A 5 KRISHNA APARTMENT PASCHIM VIHAR	425	Other Outage	Planned Outage	24-02-2026	12:39	24-02-2026	14:18	1:39	0.000275	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1660	24-02-2026	Part of : AVTAR ENCLAVE PASCHIM VIHAR	198	Other Outage	Planned Outage	24-02-2026	11:39	24-02-2026	13:57	2:18	0.001533	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1661	24-02-2026	Part of : BLOCK A 5 KRISHNA APARTMENT PASCHIM VIHAR	225	Other Outage	Planned Outage	24-02-2026	10:33	24-02-2026	12:42	2:09	0.000358	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1662	26-02-2026	Part of : JANTA COLONY PASCHIM VIHAR,	11	Other Outage	Planned Outage	26-02-2026	10:39	26-02-2026	12:39	2:00	0.000500	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1663	26-02-2026	Part of : STATE BANK COLONY PASCHIM VIHAR,	882	Other Outage	Planned Outage	26-02-2026	10:54	26-02-2026	13:36	2:42	0.002250	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1664	28-02-2026	Part of : A-BLOCK JANTA COLONY PASCHIM VIHAR	272	Other Outage	Planned Outage	28-02-2026	10:28	28-02-2026	12:33	2:05	0.000347	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1665	01-02-2026	Part of : PALAM COLONY,SADH NAGAR II PALAM, KHERA VILLAGE, BLOCK R INDRA PARK PALAM	3930	Other Outage	Unplanned Outage	01-02-2026	23:04	01-02-2026	23:40	0:36	0.000331	HT SYSTEM FAULT
1666	01-02-2026	Part of : GEETANJALI PARK, BLOCK RZB SABZI MANDI SAGARPUR MAIN,VEER NAGAR SAGARPUR WEST	3853	Other Outage	Unplanned Outage	01-02-2026	15:16	01-02-2026	16:02	0:46	0.000344	CABLE FAULT
1667	01-02-2026	Part of : SECTOR 8 & 9 DWARKA,BLOCK A SECTOR 8 DWARKA, DTC DEPOT SEC-8 (HTC)	393	Other Outage	Unplanned Outage	01-02-2026	15:04	01-02-2026	16:01	0:57	0.000258	TREE BRANCH FALLEN ON O/H LINE
1668	01-02-2026	Part of : SECTOR 8 & 9 DWARKA,BLOCK A SECTOR 8 DWARKA, DTC DEPOT SEC-8 (HTC)	393	Other Outage	Unplanned Outage	01-02-2026	13:37	01-02-2026	14:26	0:49	0.000339	HT SYSTEM FAULT
1669	01-02-2026	Part of : BLOCK RZ PALAM, BLOCK E PALAM EXTENSION, SEC 7 PKT 2 DWARKA	1209	Other Outage	Unplanned Outage	01-02-2026	12:52	01-02-2026	13:38	0:46	0.000319	BIRDAGE
1670	02-02-2026	Part of : BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR,	200	Other Outage	Planned Outage	02-02-2026	13:06	02-02-2026	15:34	2:28	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF LT BUSHING ROD
1671	02-02-2026	Part of : BLOCK D PALAM EXTENSION PALAM,	1	Other Outage	Planned Outage	02-02-2026	11:40	02-02-2026	15:32	3:52	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER , OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1672	02-02-2026	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM,INDRA PARK PALEM KAILASHPURI MAIN PALAM,	2916	Other Outage	Planned Outage	02-02-2026	11:14	02-02-2026	14:16	3:02	0.000000	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
1673	03-02-2026	Part of : SECTOR 20 DWARKA	17	Other Outage	Planned Outage	03-02-2026	13:57	03-02-2026	15:48	1:51	0.000000	LT CIRCUIT MAINTENANCE
1674	03-02-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR	446	Other Outage	Planned Outage	03-02-2026	12:41	03-02-2026	14:31	1:50	0.000000	LT CIRCUIT MAINTENANCE
1675	03-02-2026	Part of : DABRI EXTENSION EAST	1533	Other Outage	Planned Outage	03-02-2026	12:16	03-02-2026	14:54	2:38	0.000000	DT REPLACEMENT
1676	03-02-2026	Part of : POCKET B KAILASHPURI EAST	1802	Other Outage	Planned Outage	03-02-2026	10:46	03-02-2026	13:57	3:11	0.000000	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
1677	03-02-2026	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN	691	Other Outage	Planned Outage	03-02-2026	13:17	03-02-2026	16:17	3:00	0.000000	LT CIRCUIT MAINTENANCE
1678	03-02-2026	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM	425	Other Outage	Planned Outage	03-02-2026	12:10	03-02-2026	14:35	2:25	0.000000	LT CIRCUIT MAINTENANCE
1679	03-02-2026	Part of : HARIJAN BASTI PALAM EXTENSION	837	Other Outage	Planned Outage	03-02-2026	11:45	03-02-2026	14:20	2:35	0.000000	LT CIRCUIT MAINTENANCE
1680	04-02-2026	Part of : A-BLOCK SECTOR 8 DWARKA	339	Other Outage	Planned Outage	04-02-2026	12:29	04-02-2026	15:22	2:53	0.000000	LT CIRCUIT MAINTENANCE
1681	04-02-2026	Part of : SECTOR 8 DWARKA	4	Other Outage	Planned Outage	04-02-2026	11:57	04-02-2026	15:19	3:22	0.000000	LT CIRCUIT MAINTENANCE
1682	04-02-2026	Part of : SECTOR 8 DWARKA	1	Other Outage	Planned Outage	04-02-2026	15:37	04-02-2026	16:01	0:24	0.000000	LT CIRCUIT MAINTENANCE
1683	04-02-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR	61	Other Outage	Planned Outage	04-02-2026	11:29	04-02-2026	14:14	2:45	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1684	04-02-2026	Part of : PALAM EXTENSION	37	Other Outage	Planned Outage	04-02-2026	11:45	04-02-2026	13:49	2:04	0.000000	LT CIRCUIT MAINTENANCE
1685	04-02-2026	Part of : A-BLOCK MAHAVIR ENCLAVE PART 1	779	Other Outage	Planned Outage	04-02-2026	10:40	04-02-2026	13:48	3:08	0.000000	LT CIRCUIT MAINTENANCE
1686	04-02-2026	Part of : PALAM VILLAGE	492	Other Outage	Planned Outage	04-02-2026	15:08	04-02-2026	15:41	0:33	0.000000	LT CIRCUIT MAINTENANCE
1687	04-02-2026	Part of : PALAM COLONY SADH NAGAR 1 PALAM	527	Other Outage	Planned Outage	04-02-2026	11:46	04-02-2026	16:03	4:17	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1688	05-02-2026	Part of : VAISHALI COLONY DASRATHPURI	259	Other Outage	Planned Outage	05-02-2026	13:39	05-02-2026	14:10	0:31	0.000000	REPLACEMENT OF LT BUSHING ROD
1689	05-02-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR	246	Other Outage	Planned Outage	05-02-2026	12:21	05-02-2026	14:09	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
1690	05-02-2026	Part of : MAHAVIR ENCLAVE PART 2	1768	Other Outage	Planned Outage	05-02-2026	11:59	05-02-2026	14:10	2:11	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,LT BUSHING REPLACEMENT
1691	05-02-2026	Part of : SECTOR 9 DWARKA	130	Other Outage	Planned Outage	05-02-2026	11:56	05-02-2026	14:07	2:11	0.000000	INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
1692	05-02-2026	Part of : VAISHALI EXTENSION DASRATHPURI	787	Other Outage	Planned Outage	05-02-2026	11:14	05-02-2026	13:40	2:26	0.000000	REPLACEMENT OF LT BUSHING ROD
1693	06-02-2026	Part of : BLOCK A 1 VIJAY ENCLAVE MAHAVIR ENCLAVE,	819	Other Outage	Planned Outage	06-02-2026	11:59	06-02-2026	13:44	1:45	0.000000	REPLACEMENT OF LT BUSHING ROD
1694	06-02-2026	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM,	693	Other Outage	Planned Outage	06-02-2026	11:55	06-02-2026	13:45	1:50	0.000000	REPLACEMENT OF LT BUSHING ROD
1695	06-02-2026	Part of : PALAM VILLAGE PALAM,	492	Other Outage	Planned Outage	06-02-2026	11:53	06-02-2026	14:01	2:08	0.000000	REPLACEMENT OF LT BUSHING ROD
1696	06-02-2026	Part of : SECTOR 20 DWARKA,	93	Other Outage	Planned Outage	06-02-2026	11:51	06-02-2026	15:02	3:11	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1697	06-02-2026	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI,	1667	Other Outage	Planned Outage	06-02-2026	12:10	06-02-2026	15:01	2:51	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD
1698	06-02-2026	Part of : MIRZAPUR MAHAVIR ENCLAVE,	341	Other Outage	Planned Outage	06-02-2026	11:52	06-02-2026	14:00	2:08	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1699	06-02-2026	Part of : PALAM COLONY MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,	540	Other Outage	Planned Outage	06-02-2026	10:53	06-02-2026	13:56	3:03	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1700	06-02-2026	Part of : BLOCK A 1 VIJAY ENCLAVE MAHAVIR ENCLAVE,	819	Other Outage	Planned Outage	06-02-2026	11:06	06-02-2026	13:59	2:53	0.001442	DT REPLACEMENT
1701	07-02-2026	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN SAGARPUR,POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM	2075	Other Outage	Unplanned Outage	07-02-2026	22:58	07-02-2026	23:25	0:27	0.000255	CABLE FAULT
1702	07-02-2026	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN	1181	Other Outage	Planned Outage	07-02-2026	14:28	07-02-2026	16:30	2:02	0.000000	LT CIRCUIT MAINTENANCE
1703	07-02-2026	Part of : POCKET 13 MANGALPURI-2 PALAM	575	Other Outage	Planned Outage	07-02-2026	13:47	07-02-2026	16:09	2:22	0.000000	LT CIRCUIT MAINTENANCE
1704	07-02-2026	Part of : BLOCK J SAGARPUR WEST	871	Other Outage	Planned Outage	07-02-2026	13:54	07-02-2026	17:26	3:32	0.000000	LT CIRCUIT MAINTENANCE
1705	07-02-2026	Part of : KHERA VILLAGE SADH NAGAR-1	425	Other Outage	Planned Outage	07-02-2026	13:03	07-02-2026	16:08	3:05	0.000000	LT CIRCUIT MAINTENANCE
1706	07-02-2026	Part of : BLOCK A MAHAVIR ENCLAVE PART-1	779	Other Outage	Planned Outage	07-02-2026	11:44	07-02-2026	14:10	2:26	0.000000	LT CIRCUIT MAINTENANCE
1707	07-02-2026	Part of : DABRI EXTENSION EAST	57	Other Outage	Planned Outage	07-02-2026	12:10	07-02-2026	15:08	2:58	0.000000	LT CIRCUIT MAINTENANCE
1708	07-02-2026	Part of : SECTOR 8 DWARKA	174	Other Outage	Planned Outage	07-02-2026	12:19	07-02-2026	14:59	2:40	0.000000	LT CIRCUIT MAINTENANCE
1709	07-02-2026	Part of : PALAM COLONY SADH NAGAR-1	389	Other Outage	Planned Outage	07-02-2026	11:47	07-02-2026	14:56	3:09	0.000000	LT CIRCUIT MAINTENANCE
1710	09-02-2026	Part of : NAVEEN KUNJ SOCIETY NARSIRPUR	254	Other Outage	Planned Outage	09-02-2026	13:58	09-02-2026	14:41	0:43	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1711	09-02-2026	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN	811	Other Outage	Planned Outage	09-02-2026	13:19	09-02-2026	14:36	1:17	0.000000	REPLACEMENT OF LT BUSHING ROD
1712	09-02-2026	Part of : PALAM COLONY SADH NAGAR 1 PALAM	527	Other Outage	Planned Outage	09-02-2026	11:06	09-02-2026	12:25	1:19	0.000000	REPLACEMENT OF FAULTY END BOX
1713	09-02-2026	Part of : BLOCK F MAHAVIR ENCLAVE PART 1	956	Other Outage	Planned Outage	09-02-2026	11:28	09-02-2026	12:47	1:19	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1714	09-02-2026	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN	1802	Other Outage	Planned Outage	09-02-2026	10:45	09-02-2026	13:57	3:12	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,LT BUSHING REPLACEMENT
1715	09-02-2026	Part of : BLOCK A1 & B VIJAY ENCLAVE MAHAVIR ENCLAVE,BLOCK A & B3 MAHAVIR ENCLAVE PART 1	819	Other Outage	Planned Outage	09-02-2026	11:03	09-02-2026	14:19	3:16	0.000000	REPLACEMENT OF HT BUSHING ROD
1716	09-02-2026	Part of : BLOCK H RAGHU NAGAR DABRI	1292	Other Outage	Planned Outage	09-02-2026	11:45	09-02-2026	15:32	3:47	0.000000	REPLACEMENT OF LT BUSHING ROD
1717	09-02-2026	Part of : BLOCK J RAJ NAGAR 2	1409	Other Outage	Planned Outage	09-02-2026	11:31	09-02-2026	14:10	2:39	0.000000	INSTALLATION OF BUS BAR,REPLACEMENT OF HT BUSHING ROD
1718	10-02-2026	Part of : DABRI VILLAGE DABRI,BLOCK B DASRATHPURI,BLOCK A MAHAVIR ENCLAVE,VAISHALI EXTENSION DASRATHPURI	1614	Other Outage	Unplanned Outage	10-02-2026	15:22	10-02-2026	16:04	0:42	0.000430	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1719	10-02-2026	Part of : BLOCK J SAGARPUR WEST SAGARPUR,	855	Other Outage	Planned Outage	10-02-2026	12:24	10-02-2026	14:07	1:43	0.000000	DT REPLACEMENT
1720	10-02-2026	Part of : MIRZAPUR MAHAVIR ENCLAVE,	264	Other Outage	Planned Outage	10-02-2026	11:24	10-02-2026	13:19	1:55	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1721	10-02-2026	Part of : SECTOR 8 DWARKA,	279	Other Outage	Planned Outage	10-02-2026	11:24	10-02-2026	13:16	1:52	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1722	10-02-2026	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,	488	Other Outage	Planned Outage	10-02-2026	11:33	10-02-2026	14:06	2:33	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1723	10-02-2026	Part of : DURGA PARK COLONY DASRATHPURI,POCKET 10 SECTOR I DASRATHPURI,BLOCK B 2 DASRATHPURI,	591	Other Outage	Planned Outage	10-02-2026	12:05	10-02-2026	14:14	2:09	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD
1724	11-02-2026	Part of : POCKET 2 & 3 SECTOR 1 DWARKA,SECTOR 1 DWARKA	1512	Other Outage	Unplanned Outage	11-02-2026	12:16	11-02-2026	13:02	0:46	0.000000	HT SYSTEM FAULT
1725	11-02-2026	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN	354	Other Outage	Planned Outage	11-02-2026	11:49	11-02-2026	13:48	1:59	0.000000	LT CIRCUIT MAINTENANCE
1726	11-02-2026	Part of : BLOCK RZ PALAM	306	Other Outage	Planned Outage	11-02-2026	11:18	11-02-2026	12:41	1:23	0.000000	LT CIRCUIT MAINTENANCE
1727	11-02-2026	Part of : SHANKAR PARK SAGARPUR EAST	632	Other Outage	Planned Outage	11-02-2026	12:03	11-02-2026	15:55	3:52	0.000000	LT CIRCUIT MAINTENANCE
1728	11-02-2026	Part of : MARBLE MKTSS- 2	1	Other Outage	Planned Outage	11-02-2026	11:34	11-02-2026	13:47	2:13	0.000000	LT CIRCUIT MAINTENANCE
1729	12-02-2026	Part of : PALAM EXTENSION	198	Other Outage	Planned Outage	12-02-2026	11:51	12-02-2026	13:49	1:58	0.000000	LT CIRCUIT MAINTENANCE
1730	12-02-2026	Part of : A-BLOCK MAHAVIR ENCLAVE PART-1	779	Other Outage	Planned Outage	12-02-2026	11:53	12-02-2026	13:31	1:38	0.000000	LT CIRCUIT MAINTENANCE
1731	12-02-2026	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY	3619	Other Outage	Planned Outage	12-02-2026	10:54	12-02-2026	14:33	3:39	0.000000	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,DT REPLACEMENT PER DT
1732	12-02-2026	Part of : KHERA VILLAGE SADH NAGAR-1	425	Other Outage	Planned Outage	12-02-2026	11:52	12-02-2026	14:03	2:11	0.000000	LT CIRCUIT MAINTENANCE
1733	12-02-2026	Part of : D-BLOCK SECTOR 8 DWARKA	341	Other Outage	Planned Outage	12-02-2026	11:03	12-02-2026	14:04	3:01	0.000000	LT CIRCUIT MAINTENANCE
1734	12-02-2026	Part of : A-BLOCK POCKET 9 PINK APARTMENTS NARSIRPUR	68	Other Outage	Planned Outage	12-02-2026	11:18	12-02-2026	14:47	3:29	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1735	13-02-2026	Part of : BLOCK B MANGALPURI II PALAM,POCKET 13 MANGALPURI II PALAM,BLOCK A SADH NAGAR II PALAM	2304	Other Outage	Unplanned Outage	13-02-2026	12:15	13-02-2026	13:07	0:52	0.000000	HT SYSTEM FAULT
1736	13-02-2026	Part of : BLOCK B MANGALPURI II PALAM,POCKET 13 MANGALPURI II PALAM,BLOCK A SADH NAGAR II PALAM	2304	Other Outage	Unplanned Outage	13-02-2026	09:34	13-02-2026	10:22	0:48	0.000000	HT SYSTEM FAULT
1737	13-02-2026	Part of : BLOCK B MANGALPURI II,POCKET 13 MANGALPURI II,BLOCK A SADH NAGAR II	4206	Other Outage	Unplanned Outage	13-02-2026	13:20	13-02-2026	13:29	0:09	0.000000	REPLACEMENT OF SOCKETS
1738	13-02-2026	Part of : SECTOR 20 DWARKA	2	Other Outage	Planned Outage	13-02-2026	13:30	13-02-2026	15:02	1:32	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMET OF HT BUSHING ROD
1739	13-02-2026	Part of : PALAM COLONY SADH NAGAR 1 PALAM	320	Other Outage	Planned Outage	13-02-2026	13:10	13-02-2026	15:03	1:53	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF LT BUSHING ROD
1740	13-02-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR	1	Other Outage	Planned Outage	13-02-2026	13:40	13-02-2026	15:07	1:27	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1741	13-02-2026	Part of : SECTOR 20 DWARKA	6	Other Outage	Planned Outage	13-02-2026	13:37	13-02-2026	15:04	1:27	0.000000	INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
1742	13-02-2026	Part of : BLOCK A1 & B VIJAY ENCLAVE MAHAVIR ENCLAVE,BLOCK A & B3 MAHAVIR ENCLAVE PART 1	819	Other Outage	Planned Outage	13-02-2026	11:06	13-02-2026	14:10	3:04	0.000000	REPLACEMET OF HT BUSHING ROD
1743	13-02-2026	Part of : BLOCK J SAGARPUR WEST	871	Other Outage	Planned Outage	13-02-2026	12:24	13-02-2026	15:37	3:13	0.000000	DT REPLACEMENT
1744	13-02-2026	Part of : PALAM VILLAGE	492	Other Outage	Planned Outage	13-02-2026	12:09	13-02-2026	14:15	2:06	0.000000	REPLACEMENT OF LT BUSHING ROD
1745	13-02-2026	Part of : BLOCK RZ SAGARPUR	1469	Other Outage	Planned Outage	13-02-2026	12:25	13-02-2026	14:41	2:16	0.000000	DT REPLACEMENT
1746	13-02-2026	Part of : BLOCK M RAIJV PARK SAGARPUR	1073	Other Outage	Planned Outage	13-02-2026	11:04	13-02-2026	13:34	2:30	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1747	14-02-2026	Part of : BLOCK A MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	779	Other Outage	Planned Outage	14-02-2026	15:00	14-02-2026	17:00	2:00	0.000000	REPLACEMENT OF LT BUSHING ROD
1748	14-02-2026	Part of : BLOCK B DASRATHPURI,	812	Other Outage	Planned Outage	14-02-2026	13:00	14-02-2026	14:39	1:39	0.000000	REPLACEMENT OF LT BUSHING ROD
1749	14-02-2026	Part of : DABRI EXTENSION EAST DABRI,	604	Other Outage	Planned Outage	14-02-2026	12:00	14-02-2026	13:47	1:47	0.000000	DT REPLACEMENT
1750	14-02-2026	Part of : POCKET 13 MANGALPURI II PALAM,	130	Other Outage	Planned Outage	14-02-2026	11:01	14-02-2026	13:33	2:32	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1751	14-02-2026	Part of : BLOCK B CHANDAR VIHAR PALAM EXTENSION PALAM,	510	Other Outage	Planned Outage	14-02-2026	11:11	14-02-2026	13:49	2:38	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1752	16-02-2026	Part of : DURGA PARK COLONY,VAISHALI COLONY,C, B 2 & F-BLOCK DASRATHPURI,POCKET 10 SECTOR-1 DASRATHPURI,A-BLOCK MAHAVIR ENCLAVE,DABRI VILLAGE	5546	Other Outage	Unplanned Outage	16-02-2026	16:50	16-02-2026	17:31	0:41	0.000228	REPAIR/REPLACEMENT OF INSULATORS
1753	16-02-2026	Part of : RZ-BLOCK GEETANJALI PARK SAGARPUR WEST	1780	Other Outage	Planned Outage	16-02-2026	12:30	16-02-2026	14:17	1:47	0.000000	LT CIRCUIT MAINTENANCE
1754	16-02-2026	Part of : A 1 & B-BLOCK VIJAY ENCLAVE MAHAVIR ENCLAVE	819	Other Outage	Planned Outage	16-02-2026	12:03	16-02-2026	14:23	2:20	0.000000	REPLACEMENT OF HT BUSHING ROD
1755	16-02-2026	Part of : POCKET B KAILASHPURI EAST & MAIN PALAM	1802	Other Outage	Planned Outage	16-02-2026	12:12	16-02-2026	14:38	2:26	0.000000	3PH HT AB CABLE REPLACEMENT
1756	16-02-2026	Part of : L-BLOCK MAHAVIR ENCLAVE PART 1	280	Other Outage	Planned Outage	16-02-2026	12:17	16-02-2026	14:18	2:01	0.000000	LT CIRCUIT MAINTENANCE
1757	16-02-2026	Part of : B 2-BLOCK DASRATHPURI	802	Other Outage	Planned Outage	16-02-2026	11:27	16-02-2026	13:45	2:18	0.000000	LT CIRCUIT MAINTENANCE
1758	16-02-2026	Part of : F-BLOCK RAJ NAGAR EXTENSION	1321	Other Outage	Planned Outage	16-02-2026	11:28	16-02-2026	13:45	2:17	0.000000	LT CIRCUIT MAINTENANCE
1759	17-02-2026	Part of : BLOCK D RAJ NAGAR 1, MANGALPURI I PALAM,	3941	Other Outage	Unplanned Outage	17-02-2026	14:17	17-02-2026	14:20	0:03	0.000000	MAKING OF END TERMINATION
1760	17-02-2026	Part of : POCKET 13 MANGALPURI I PALAM, BLOCK J PALAM	2192	Other Outage	Unplanned Outage	17-02-2026	14:14	17-02-2026	14:19	0:05	0.000000	MAKING OF END TERMINATION
1761	17-02-2026	Part of : SECTOR 8 DWARKA	199	Other Outage	Planned Outage	17-02-2026	12:03	17-02-2026	13:36	1:33	0.000000	INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1762	17-02-2026	Part of : KAILASHPURI WEST PALAM	173	Other Outage	Planned Outage	17-02-2026	12:05	17-02-2026	14:53	2:48	0.000933	3PH HT AB CABLE REPLACEMENT PER SPAN
1763	17-02-2026	Part of : BLOCK C SADH NAGAR II PALAM	1855	Other Outage	Planned Outage	17-02-2026	14:33	17-02-2026	16:49	2:16	0.000000	REPLACEMENT OF LT BUSHING ROD
1764	17-02-2026	Part of : BLOCK C MAHAVIR ENCLAVE PART 1	1061	Other Outage	Planned Outage	17-02-2026	11:26	17-02-2026	13:53	2:27	0.000000	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1765	17-02-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR	40	Other Outage	Planned Outage	17-02-2026	10:58	17-02-2026	13:52	2:54	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
1766	17-02-2026	Part of : SECTOR 7 DWARKA	100	Other Outage	Planned Outage	17-02-2026	11:25	17-02-2026	13:51	2:26	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
1767	18-02-2026	Part of : BLOCK B RAJ NAGAR 2 RAJ NAGAR,	181	Other Outage	Planned Outage	18-02-2026	13:14	18-02-2026	14:05	0:51	0.000000	REPLACEMENT OF LT BUSHING ROD
1768	18-02-2026	Part of : SECTOR 8 DWARKA,	276	Other Outage	Planned Outage	18-02-2026	14:15	18-02-2026	16:07	1:52	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1769	18-02-2026	Part of : BLOCK J SAGARPUR WEST SAGARPUR,	871	Other Outage	Planned Outage	18-02-2026	12:18	18-02-2026	13:33	1:15	0.000000	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD
1770	18-02-2026	Part of : BLOCK G SAGARPUR WEST SAGARPUR,BLOCK J SAGARPUR WEST SAGARPUR,	645	Other Outage	Planned Outage	18-02-2026	12:06	18-02-2026	13:36	1:30	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD
1771	18-02-2026	Part of : BLOCK J PALAM,	476	Other Outage	Planned Outage	18-02-2026	12:04	18-02-2026	13:34	1:30	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1772	18-02-2026	Part of : SECTOR 8 DWARKA,	329	Other Outage	Planned Outage	18-02-2026	12:07	18-02-2026	13:41	1:34	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1773	19-02-2026	Part of : Part of : A-BLOCK POCKET 9 PINK APARTMENTS NARSIRPUR	326	Other Outage	Planned Outage	19-02-2026	14:45	19-02-2026	15:39	0:54	0.000000	LT CIRCUIT MAINTENANCE
1774	19-02-2026	Part of : Part of : KHERA VILLAGE SADH NAGAR-1 PALAM	425	Other Outage	Planned Outage	19-02-2026	14:42	19-02-2026	15:42	1:00	0.000000	LT CIRCUIT MAINTENANCE
1775	19-02-2026	Part of : Part of : J-BLOCK RAJ NAGAR-2	3	Other Outage	Planned Outage	19-02-2026	14:21	19-02-2026	15:38	1:17	0.000000	LT CIRCUIT MAINTENANCE
1776	19-02-2026	Part of : Part of : PALAM VILLAGE	494	Other Outage	Planned Outage	19-02-2026	13:45	19-02-2026	16:02	2:17	0.000000	LT CIRCUIT MAINTENANCE
1777	19-02-2026	Part of : Part of : DABRI EXTENSION EAST	604	Other Outage	Planned Outage	19-02-2026	11:38	19-02-2026	14:47	3:09	0.000000	LT CIRCUIT MAINTENANCE
1778	20-02-2026	Part of : BLOCK F RAJ NAGAR EXTENSION	101	Other Outage	Planned Outage	20-02-2026	13:00	20-02-2026	14:58	1:58	0.000000	LT CIRCUIT MAINTENANCE
1779	20-02-2026	Part of : POCKET 2 SECTOR 9 DWARKA	37	Other Outage	Planned Outage	20-02-2026	13:02	20-02-2026	14:57	1:55	0.000000	LT CIRCUIT MAINTENANCE
1780	20-02-2026	Part of : BLOCK WZ RAJ NAGAR 2	478	Other Outage	Planned Outage	20-02-2026	11:58	20-02-2026	15:52	3:54	0.001300	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1781	20-02-2026	Part of : KHERA VILLAGE,SADH NAGAR II PALAM	1504	Other Outage	Planned Outage	20-02-2026	10:46	20-02-2026	12:54	2:08	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1782	20-02-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR	28	Other Outage	Planned Outage	20-02-2026	13:15	20-02-2026	15:35	2:20	0.000000	LT CIRCUIT MAINTENANCE
1783	20-02-2026	Part of : BLOCK RZ SAGARPUR	1469	Other Outage	Planned Outage	20-02-2026	12:40	20-02-2026	14:48	2:08	0.000000	LT CIRCUIT MAINTENANCE
1784	20-02-2026	Part of : BLOCK B RAJ NAGAR 2	739	Other Outage	Planned Outage	20-02-2026	10:59	20-02-2026	13:47	2:48	0.000000	LT CIRCUIT MAINTENANCE
1785	20-02-2026	Part of : SHANKAR PARK SAGARPUR EAST	633	Other Outage	Planned Outage	20-02-2026	11:13	20-02-2026	13:46	2:33	0.000000	LT CIRCUIT MAINTENANCE
1786	20-02-2026	Part of : HARIJAN BASTI PALAM EXTENSION	851	Other Outage	Planned Outage	20-02-2026	11:37	20-02-2026	13:48	2:11	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1787	21-02-2026	Part of : SECTOR 20 DWARKA, BLOCK B RAJ NAGAR 2	1385	Other Outage	Unplanned Outage	21-02-2026	15:00	21-02-2026	15:28	0:28	0.000306	TREE TOUCHING
1788	21-02-2026	Part of : SECTOR 21 DWARKA	56	Other Outage	Planned Outage	21-02-2026	13:43	21-02-2026	14:59	1:16	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
1789	21-02-2026	Part of : HARIJAN BASTI PALAM EXTENSION	851	Other Outage	Planned Outage	21-02-2026	12:02	21-02-2026	13:27	1:25	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,,REPLACEMENT OF LT BUSHING ROD
1790	21-02-2026	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1, BLOCK C & I MAHAVIR ENCLAVE PART 1	1594	Other Outage	Planned Outage	21-02-2026	12:01	21-02-2026	14:29	2:28	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN,LT BUSHING REPLACEMENT
1791	21-02-2026	Part of : BLOCK C SADH NAGAR II PALAM	1855	Other Outage	Planned Outage	21-02-2026	11:11	21-02-2026	14:03	2:52	0.000000	REPLACEMENT OF LT BUSHING ROD
1792	21-02-2026	Part of : SECTOR 21 DWARKA	100	Other Outage	Planned Outage	21-02-2026	11:11	21-02-2026	13:27	2:16	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF LT BUSHING ROD
1793	21-02-2026	Part of : PALAM VILLAGE	494	Other Outage	Planned Outage	21-02-2026	11:26	21-02-2026	13:39	2:13	0.000000	REPLACEMENT OF LT BUSHING ROD
1794	21-02-2026	Part of : BLOCK J SAGARPUR WEST	855	Other Outage	Planned Outage	21-02-2026	11:33	21-02-2026	14:23	2:50	0.000000	DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER
1795	21-02-2026	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	779	Other Outage	Planned Outage	21-02-2026	11:17	21-02-2026	14:04	2:47	0.000000	REPLACEMENT OF LT BUSHING ROD
1796	23-02-2026	Part of : BLOCK D PALAM EXTENSION	623	Other Outage	Planned Outage	23-02-2026	11:38	23-02-2026	13:31	1:53	0.000000	LT CIRCUIT MAINTENANCE
1797	23-02-2026	Part of : SHANKAR PARK SAGARPUR EAST	633	Other Outage	Planned Outage	23-02-2026	12:59	23-02-2026	15:44	2:45	0.000000	LT CIRCUIT MAINTENANCE
1798	23-02-2026	Part of : BLOCK G RAJ NAGAR 2	727	Other Outage	Planned Outage	23-02-2026	12:02	23-02-2026	14:33	2:31	0.000000	LT CIRCUIT MAINTENANCE
1799	23-02-2026	Part of : BLOCK RZ SAGARPUR	1635	Other Outage	Planned Outage	23-02-2026	12:01	23-02-2026	14:59	2:58	0.000000	LT CIRCUIT MAINTENANCE
1800	24-02-2026	Part of : DABRI EXTENSION EAST	57	Other Outage	Planned Outage	24-02-2026	12:18	24-02-2026	15:05	2:47	0.000000	LT CIRCUIT MAINTENANCE
1801	24-02-2026	Part of : BLOCK J SAGARPUR WEST	872	Other Outage	Planned Outage	24-02-2026	12:18	24-02-2026	15:05	2:47	0.000000	LT CIRCUIT MAINTENANCE
1802	24-02-2026	Part of : BLOCK C SADH NAGAR II PALAM	1857	Other Outage	Planned Outage	24-02-2026	11:57	24-02-2026	14:51	2:54	0.000000	LT CIRCUIT MAINTENANCE
1803	24-02-2026	Part of : BLOCK H RAGHU NAGAR DABRI	1293	Other Outage	Planned Outage	24-02-2026	11:28	24-02-2026	13:57	2:29	0.000000	LT CIRCUIT MAINTENANCE
1804	24-02-2026	Part of : SECTOR 21 DWARKA	121	Other Outage	Planned Outage	24-02-2026	11:00	24-02-2026	13:55	2:55	0.000000	LT CIRCUIT MAINTENANCE
1805	24-02-2026	Part of : SECTOR 21 DWARKA	110	Other Outage	Planned Outage	24-02-2026	11:00	24-02-2026	13:56	2:56	0.000000	LT CIRCUIT MAINTENANCE
1806	24-02-2026	Part of : JAGDAMBA VIHAR SAGARPUR WEST	1399	Other Outage	Planned Outage	24-02-2026	10:56	24-02-2026	13:57	3:01	0.000000	LT CIRCUIT MAINTENANCE
1807	24-02-2026	Part of : SPG COMPLEX SECT-21 DWARKA	1	Other Outage	Planned Outage	24-02-2026	11:01	24-02-2026	13:56	2:55	0.000000	LT CIRCUIT MAINTENANCE
1808	25-02-2026	Part of : INDRA PARK KAILASHPURI,POCKET B KAILASHPURI EAST MAIN PALAM	2916	Other Outage	Planned Outage	25-02-2026	11:00	25-02-2026	13:29	2:29	0.000000	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
1809	25-02-2026	Part of : PALAM VILLAGE	494	Other Outage	Planned Outage	25-02-2026	12:06	25-02-2026	14:52	2:46	0.000000	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD
1810	25-02-2026	Part of : SECTOR 20 DWARKA	4	Other Outage	Planned Outage	25-02-2026	12:03	25-02-2026	14:36	2:33	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF LT BUSHING ROD
1811	25-02-2026	Part of : SECTOR 20 DWARKA	2	Other Outage	Planned Outage	25-02-2026	12:05	25-02-2026	14:34	2:29	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
1812	25-02-2026	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	779	Other Outage	Planned Outage	25-02-2026	12:07	25-02-2026	14:31	2:24	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS
1813	25-02-2026	Part of : BLOCK C PALAM EXTENSION	875	Other Outage	Planned Outage	25-02-2026	12:04	25-02-2026	14:33	2:29	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS
1814	26-02-2026	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,SECTOR 1 DWARKA,MIRZAPUR MAHAVIR ENCLAVE	3151	Other Outage	Unplanned Outage	26-02-2026	18:20	26-02-2026	18:45	0:25	0.000049	ELECTROCUTION OF CAT
1815	26-02-2026	Part of : BLOCK RZ SAGARPUR,	1635	Other Outage	Planned Outage	26-02-2026	13:44	26-02-2026	15:38	1:54	0.000000	REPLACEMENT OF LT BUSHING ROD
1816	26-02-2026	Part of : BLOCK G VIJAY ENCLAVE MAHAVIR ENCLAVE,	1045	Other Outage	Planned Outage	26-02-2026	14:19	26-02-2026	15:37	1:18	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1817	26-02-2026	Part of : PALAM VILLAGE PALAM,	494	Other Outage	Planned Outage	26-02-2026	12:41	26-02-2026	14:27	1:46	0.000000	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1818	26-02-2026	Part of : SECTOR 20 DWARKA,	2	Other Outage	Planned Outage	26-02-2026	12:16	26-02-2026	14:21	2:05	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1819	26-02-2026	Part of : SECTOR 20 DWARKA,	11	Other Outage	Planned Outage	26-02-2026	12:30	26-02-2026	14:48	2:18	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD SUB STATION CLEANING
1820	26-02-2026	Part of : BLOCK F MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	956	Other Outage	Planned Outage	26-02-2026	11:32	26-02-2026	14:19	2:47	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD.SUB STATION CLEANING
1821	26-02-2026	Part of : BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	1466	Other Outage	Planned Outage	26-02-2026	11:35	26-02-2026	14:18	2:43	0.000000	REPLACEMENT OF LT BUSHING ROD
1822	27-02-2026	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1,SECTOR 1 DWARKA,MIRZAPUR MAHAVIR ENCLAVE	2295	Other Outage	Planned Outage	27-02-2026	11:29	27-02-2026	13:54	2:25	0.000000	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
1823	27-02-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR	28	Other Outage	Planned Outage	27-02-2026	11:57	27-02-2026	14:57	3:00	0.000000	LT CIRCUIT MAINTENANCE
1824	27-02-2026	Part of : SHANKAR PARK SAGARPUR EAST	634	Other Outage	Planned Outage	27-02-2026	12:17	27-02-2026	14:54	2:37	0.000000	LT CIRCUIT MAINTENANCE
1825	27-02-2026	Part of : J-BLOCK SAGARPUR WEST	872	Other Outage	Planned Outage	27-02-2026	11:57	27-02-2026	14:56	2:59	0.000000	LT CIRCUIT MAINTENANCE
1826	27-02-2026	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART-1	353	Other Outage	Planned Outage	27-02-2026	11:30	27-02-2026	13:52	2:22	0.000000	LT CIRCUIT MAINTENANCE
1827	27-02-2026	Part of : MAHAVIR ENCLAVE PART-2,PALAM COLONY	3619	Other Outage	Planned Outage	27-02-2026	10:59	27-02-2026	13:39	2:40	0.000000	LT CIRCUIT MAINTENANCE
1828	27-02-2026	Part of : DABRI EXTENSION EAST	57	Other Outage	Planned Outage	27-02-2026	11:06	27-02-2026	13:53	2:47	0.000000	LT CIRCUIT MAINTENANCE
1829	28-02-2026	Part of : A-BLOCK MAHAVIR ENCLAVE PART 1	780	Other Outage	Planned Outage	28-02-2026	13:46	28-02-2026	15:23	1:37	0.000000	LT CIRCUIT MAINTENANCE
1830	28-02-2026	Part of : PALAM VILLAGE	494	Other Outage	Planned Outage	28-02-2026	12:59	28-02-2026	15:23	2:24	0.000000	LT CIRCUIT MAINTENANCE
1831	28-02-2026	Part of : MAHAVIR ENCLAVE PART 2	544	Other Outage	Planned Outage	28-02-2026	12:01	28-02-2026	14:42	2:41	0.000000	LT CIRCUIT MAINTENANCE
1832	28-02-2026	Part of : MIRZAPUR MAHAVIR ENCLAVE	1338	Other Outage	Planned Outage	28-02-2026	11:24	28-02-2026	13:45	2:21	0.000000	LT CIRCUIT MAINTENANCE
1833	01-02-2026	Part of : TAGORE GARDEN EXTENSION,BLOCK A VISHAL ENCLAVE TAGORE GARDEN	2972	Other Outage	Unplanned Outage	01-02-2026	06:51	01-02-2026	07:51	1:00	0.000883	CABLE FAULT
1834	02-02-2026	Part of : BLOCK C VISHAL ENCLAVE TAGORE GARDEN EXTENSION,BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION,BLOCK D VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	2072	Other Outage	Planned Outage	02-02-2026	11:05	02-02-2026	14:31	3:26	0.000572	REPLACEMET OF HT BUSHING ROD
1835	02-02-2026	Part of : BLOCK G KHAYALA VISHNU GARDEN,	2402	Other Outage	Planned Outage	02-02-2026	12:37	02-02-2026	14:40	2:03	0.000683	REPLACEMET OF HT BUSHING ROD
1836	02-02-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	979	Other Outage	Planned Outage	02-02-2026	10:55	02-02-2026	14:27	3:32	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1837	03-02-2026	Part of : BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION	1329	Other Outage	Planned Outage	03-02-2026	11:05	03-02-2026	13:52	2:47	0.000464	REPLACEMENT OF HT BUSHING ROD
1838	03-02-2026	Part of : BLOCK WZ MAHAVIR NAGAR NEW TILAK NAGAR	702	Other Outage	Planned Outage	03-02-2026	11:12	03-02-2026	13:53	2:41	0.000447	REPLACEMENT OF HT BUSHING ROD
1839	03-02-2026	Part of : BLOCK P RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	876	Other Outage	Planned Outage	03-02-2026	10:08	03-02-2026	13:33	3:25	0.000000	LT CIRCUIT MAINTENANCE
1840	04-02-2026	Part of : WZ-BLOCK KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	578	Other Outage	Unplanned Outage	04-02-2026	10:01	04-02-2026	11:29	1:28	0.001483	CABLE FAULT
1841	04-02-2026	Part of : 4A-BLOCK TILAK NAGAR	109	Other Outage	Unplanned Outage	04-02-2026	14:23	04-02-2026	16:12	1:49	0.000303	MAKING OF END TERMINATION
1842	04-02-2026	Part of : POCKET AD TAGORE GARDEN EXTENSION	636	Other Outage	Planned Outage	04-02-2026	11:16	04-02-2026	13:58	2:42	0.000450	REPLACEMET OF HT BUSHING ROD
1843	04-02-2026	Part of : BLOCK 16 TILAK NAGAR	813	Other Outage	Planned Outage	04-02-2026	11:03	04-02-2026	13:54	2:51	0.000475	REPLACEMET OF HT BUSHING ROD
1844	05-02-2026	Part of : BLOCK S & WZ KHAYALA VISHNU GARDEN, KHAYALA VILLAGE, N-BLOCK VISHNU GARDEN	3280	Other Outage	Unplanned Outage	05-02-2026	17:57	05-02-2026	18:47	0:50	0.001431	CABLE FAULT
1845	05-02-2026	Part of : CHAND NAGAR VISHNU GARDEN	2432	Other Outage	Unplanned Outage	05-02-2026	10:10	05-02-2026	11:11	1:01	0.001803	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1846	05-02-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	979	Other Outage	Planned Outage	05-02-2026	11:26	05-02-2026	13:35	2:09	0.000358	REPLACEMET OF HT BUSHING ROD
1847	05-02-2026	Part of : BLOCK 23 TILAK NAGAR,BLOCK 4A TILAK NAGAR,BLOCK 2 TILAK NAGAR	1947	Other Outage	Planned Outage	05-02-2026	10:55	05-02-2026	13:34	2:39	0.000442	REPLACEMET OF HT BUSHING ROD
1848	06-02-2026	Part of : BLOCK EC VISHAL ENCLAVE TAGORE GARDEN EXTENSION,BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	1869	Other Outage	Unplanned Outage	06-02-2026	15:27	06-02-2026	16:48	1:21	0.000225	REPAIR/REPLACEMENT OF CONDUCTOR
1849	06-02-2026	Part of : BLOCK J KHAYALA VISHNU GARDEN,	525	Other Outage	Planned Outage	06-02-2026	11:00	06-02-2026	13:30	2:30	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1850	06-02-2026	Part of : CHAND NAGAR VISHNU GARDEN,POCKET C CHAND NAGAR VISHNU GARDEN,POCKET E SHAM NAGAR VISHNU GARDEN,	6956	Other Outage	Planned Outage	06-02-2026	11:42	06-02-2026	14:30	2:48	0.000933	REPLACEMET OF HT BUSHING ROD
1851	06-02-2026	Part of : KRISHNA PARK EXTENSION TILAK NAGAR,	911	Other Outage	Planned Outage	06-02-2026	11:35	06-02-2026	14:35	3:00	0.000500	REPLACEMET OF HT BUSHING ROD
1852	06-02-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	2238	Other Outage	Planned Outage	06-02-2026	11:00	06-02-2026	13:54	2:54	0.000483	REPLACEMET OF HT BUSHING ROD
1853	07-02-2026	Part of : BLOCK 4A, 4B, 6, 7, 8 & 9 TILAK NAGAR	1587	Other Outage	Unplanned Outage	07-02-2026	17:01	07-02-2026	17:50	0:49	0.001595	BIRDAGE
1854	07-02-2026	Part of : SANT NAGAR CHAUKHANDI VISHNU GARDEN	1316	Other Outage	Planned Outage	07-02-2026	10:59	07-02-2026	13:36	2:37	0.000872	REPLACEMENT OF HT BUSHING ROD
1855	07-02-2026	Part of : BLOCK G TILAK NAGAR	1178	Other Outage	Planned Outage	07-02-2026	11:06	07-02-2026	13:37	2:31	0.000419	REPLACEMENT OF HT BUSHING ROD
1856	07-02-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	979	Other Outage	Planned Outage	07-02-2026	10:16	07-02-2026	13:01	2:45	0.000458	LT CIRCUIT MAINTENANCE
1857	08-02-2026	Part of : A-BLOCK NURSIGH GARDEN KHAYALA VISHNU GARDEN	341	Other Outage	Planned Outage	08-02-2026	10:40	08-02-2026	13:50	3:10	0.000528	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1858	09-02-2026	Part of : BLOCK C MAHAVIR NAGAR, BLOCK 15,16 & 24 TILAK NAGAR	2653	Other Outage	Unplanned Outage	09-02-2026	13:31	09-02-2026	14:15	0:44	0.000526	CABLE FAULT
1859	09-02-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	35	Other Outage	Planned Outage	09-02-2026	11:05	09-02-2026	13:33	2:28	0.000411	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF HT BUSHING ROD
1860	09-02-2026	Part of : BLOCK P RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	879	Other Outage	Planned Outage	09-02-2026	11:04	09-02-2026	13:51	2:47	0.000000	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER
1861	10-02-2026	Part of : CHAUKHANDI VISHNU GARDEN,	3007	Other Outage	Planned Outage	10-02-2026	11:00	10-02-2026	13:49	2:49	0.000469	REPLACEMET OF HT BUSHING ROD
1862	10-02-2026	Part of : BLOCK A MAHAVIR NAGAR NEW TILAK NAGAR,	840	Other Outage	Planned Outage	10-02-2026	10:48	10-02-2026	13:40	2:52	0.000478	REPLACEMET OF HT BUSHING ROD
1863	10-02-2026	Part of : BLOCK C HARJAN COLONY TILAK NAGAR,	1028	Other Outage	Planned Outage	10-02-2026	12:16	10-02-2026	14:35	2:19	0.000579	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1864	11-02-2026	Part of : BLOCK 24 TILAK NAGAR	450	Other Outage	Planned Outage	11-02-2026	11:02	11-02-2026	13:55	2:53	0.000481	REPLACEMENT OF HT BUSHING ROD
1865	12-02-2026	Part of : J-BLOCK RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	1597	Other Outage	Planned Outage	12-02-2026	11:22	12-02-2026	13:55	2:33	0.000425	REPLACEMENT OF HT BUSHING ROD
1866	12-02-2026	Part of : WZ-BLOCK MUKERJI PARK CHAUKHANDI VISHNU GARDEN	399	Other Outage	Planned Outage	12-02-2026	12:55	12-02-2026	15:11	2:16	0.000378	REPLACEMENT OF HT BUSHING ROD
1867	12-02-2026	Part of : WZ-BLOCK KRISHNA NAGAR CHAUKHANDI VISHNU GARDEN	1824	Other Outage	Planned Outage	12-02-2026	10:59	12-02-2026	13:54	2:55	0.000486	REPLACEMENT OF HT BUSHING ROD
1868	13-02-2026	Part of : KHYLAYA BOOSTER PUMP-2 (HTC)	0	Other Outage	Unplanned Outage	13-02-2026	08:37	13-02-2026	09:28	0:51	0.000846	CABLE FAULT
1869	13-02-2026	Part of : CHAUKHANDI VISHNU GARDEN	1825	Other Outage	Planned Outage	13-02-2026	12:33	13-02-2026	13:51	1:18	0.000217	REPLACEMET OF HT BUSHING ROD
1870	13-02-2026	Part of : BLOCK F TILAK NAGAR	185	Other Outage	Planned Outage	13-02-2026	10:43	13-02-2026	12:30	1:47	0.000297	REPLACEMET OF HT BUSHING ROD
1871	13-02-2026	Part of : BLOCK G JANTA COLONY TAGORE GARDEN EXTENSION	908	Other Outage	Planned Outage	13-02-2026	10:46	13-02-2026	13:22	2:36	0.000433	REPLACEMET OF HT BUSHING ROD
1872	14-02-2026	Part of : CHAUKHANDI VISHNU GARDEN,	815	Other Outage	Planned Outage	14-02-2026	11:22	14-02-2026	13:26	2:04	0.000344	REPLACEMET OF HT BUSHING ROD
1873	14-02-2026	Part of : KRISHNA PARK EXTENSION TILAK NAGAR,	538	Other Outage	Planned Outage	14-02-2026	11:28	14-02-2026	14:01	2:33	0.000425	REPLACEMET OF HT BUSHING ROD
1874	15-02-2026	Part of : BLOCK I KHAYALA VILLAGE KHAYALA VISHNU GARDEN	474	Other Outage	Planned Outage	15-02-2026	10:20	15-02-2026	13:11	2:51	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1875	16-02-2026	Part of : H-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	986	Other Outage	Planned Outage	16-02-2026	10:38	16-02-2026	13:25	2:47	0.000464	REPLACEMENT OF HT BUSHING ROD
1876	16-02-2026	Part of : S-BLOCK KHAYALA VISHNU GARDEN	1957	Other Outage	Planned Outage	16-02-2026	10:11	16-02-2026	13:07	2:56	0.000733	REPLACEMENT OF FAULTY END BOX
1877	16-02-2026	Part of : BLOCK 6 TILAK NAGAR	255	Other Outage	Planned Outage	16-02-2026	11:23	16-02-2026	14:08	2:45	0.000458	REPLACEMENT OF HT BUSHING ROD
1878	16-02-2026	Part of : EF-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	399	Other Outage	Planned Outage	16-02-2026	10:58	16-02-2026	13:01	2:03	0.000000	LT CIRCUIT MAINTENANCE
1879	17-02-2026	Part of : BLOCK BA,EA & FB TAGORE GARDEN EXTENSION, BLOCK D TAGORE GARDEN	1952	Other Outage	Unplanned Outage	17-02-2026	11:33	17-02-2026	12:15	0:42	0.000466	HT SYSTEM FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1880	17-02-2026	Part of : BLOCK AE,CA & AE TAGORE GARDEN EXTENSION, BLOCK A VISHAL ENCLAVE TAGORE GARDEN EXTENSION	2973	Other Outage	Unplanned Outage	17-02-2026	10:42	17-02-2026	11:28	0:46	0.000958	CABLE FAULT
1881	17-02-2026	Part of : BLOCK 6 TILAK NAGAR	255	Other Outage	Unplanned Outage	17-02-2026	12:32	17-02-2026	14:47	2:15	0.000375	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
1882	17-02-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	1327	Other Outage	Planned Outage	17-02-2026	16:11	17-02-2026	17:16	1:05	0.000271	REPLACEMET OF FAULTY END BOX
1883	17-02-2026	Part of : BLOCK S1 POCKET A KRISHNA PURI TILAK NAGAR	1162	Other Outage	Planned Outage	17-02-2026	11:07	17-02-2026	13:55	2:48	0.000467	REPLACEMET OF HT BUSHING ROD
1884	18-02-2026	Part of : BLOCK D VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	478	Other Outage	Planned Outage	18-02-2026	11:21	18-02-2026	14:07	2:46	0.000461	REPLACEMET OF HT BUSHING ROD
1885	18-02-2026	Part of : BLOCK 4B TILAK NAGAR,	89	Other Outage	Planned Outage	18-02-2026	11:12	18-02-2026	14:03	2:51	0.000475	REPLACEMET OF HT BUSHING ROD
1886	18-02-2026	Part of : BLOCK D KHAYALA VISHNU GARDEN,	511	Other Outage	Planned Outage	18-02-2026	11:50	18-02-2026	14:06	2:16	0.000378	REPLACEMET OF HT BUSHING ROD
1887	19-02-2026	Part of : BLOCK C MAHAVIR NAGAR NEW TILAK NAGAR,BLOCK K MAHAVIR NAGAR NEW TILAK NAGAR	1278	Other Outage	Unplanned Outage	19-02-2026	08:21	19-02-2026	09:21	1:00	0.000485	HT SYSTEM FAULT
1888	19-02-2026	Part of : Part of : WZ-BLOCK MBS NAGAR CHAUKHANDI VISHNU GARDEN	841	Other Outage	Planned Outage	19-02-2026	11:38	19-02-2026	14:41	3:03	0.000508	REPLACEMENT OF HT BUSHING ROD
1889	19-02-2026	Part of : Part of : D-BLOCK VISHAL ENCLAVE TAGORE GARDEN EXTENSION	248	Other Outage	Planned Outage	19-02-2026	11:17	19-02-2026	14:37	3:20	0.000556	REPLACEMENT OF HT BUSHING ROD
1890	20-02-2026	Part of : MUKHERJI PARK CHAUKHANDI VISHNU GARDEN	1233	Other Outage	Unplanned Outage	20-02-2026	16:15	20-02-2026	17:09	0:54	0.000245	CABLE FAULT
1891	20-02-2026	Part of : BLOCK S4 MAHAVIR NAGAR NEW TILAK NAGAR	989	Other Outage	Planned Outage	20-02-2026	10:56	20-02-2026	13:45	2:49	0.000469	REPLACEMET OF HT BUSHING ROD
1892	20-02-2026	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	727	Other Outage	Planned Outage	20-02-2026	11:09	20-02-2026	13:23	2:14	0.000558	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1893	20-02-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	65	Other Outage	Planned Outage	20-02-2026	10:31	20-02-2026	13:25	2:54	0.000483	REPLACEMET OF HT BUSHING ROD
1894	20-02-2026	Part of : BLOCK D & G KHAYALA VISHNU GARDEN,KHAYALA VISHNU GARDEN	4344	Other Outage	Planned Outage	20-02-2026	11:07	20-02-2026	13:24	2:17	0.002664	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1895	20-02-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	1332	Other Outage	Planned Outage	20-02-2026	10:20	20-02-2026	13:20	3:00	0.000000	LT CIRCUIT MAINTENANCE
1896	21-02-2026	Part of : CHAUKHANDI VISHNU GARDEN	814	Other Outage	Planned Outage	21-02-2026	11:41	21-02-2026	13:43	2:02	0.002372	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER
1897	21-02-2026	Part of : BLOCK C MAHAVIR NAGAR NEW TILAK NAGAR	1404	Other Outage	Planned Outage	21-02-2026	11:08	21-02-2026	13:42	2:34	0.000428	REPLACEMET OF HT BUSHING ROD
1898	22-02-2026	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN,	79	Other Outage	Planned Outage	22-02-2026	10:10	22-02-2026	13:04	2:54	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1899	23-02-2026	Part of : BLOCK 4A TILAK NAGAR	109	Other Outage	Unplanned Outage	23-02-2026	09:53	23-02-2026	10:24	0:31	0.000086	CONNECTION/DISCONNECTION OF HT/LT CABLES
1900	23-02-2026	Part of : BLOCK C VISHAL ENCLAVE TAGORE GARDEN EXTENSION	751	Other Outage	Planned Outage	23-02-2026	11:06	23-02-2026	13:13	2:07	0.000353	REPLACEMET OF HT BUSHING ROD
1901	23-02-2026	Part of : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION	399	Other Outage	Planned Outage	23-02-2026	12:46	23-02-2026	15:49	3:03	0.000000	LT CIRCUIT MAINTENANCE
1902	24-02-2026	Part of : WZ-BLOCK MUKERJI PARK CHAUKHANDI VISHNU GARDEN	934	Other Outage	Unplanned Outage	24-02-2026	11:39	24-02-2026	13:18	1:39	0.000275	REPAIRING OF RMU
1903	24-02-2026	Part of : BLOCK B PRITHVI PARK TILAK NAGAR	333	Other Outage	Planned Outage	24-02-2026	10:50	24-02-2026	13:38	2:48	0.000467	REPLACEMENT OF HT BUSHING ROD
1904	24-02-2026	Part of : BLOCK D JANTA COLONY TAGORE GARDEN EXTENSION	16	Other Outage	Planned Outage	24-02-2026	10:58	24-02-2026	13:36	2:38	0.000439	REPLACEMENT OF HT BUSHING ROD
1905	24-02-2026	Part of : BLOCK S KHAYALA VISHNU GARDEN	1083	Other Outage	Planned Outage	24-02-2026	11:41	24-02-2026	14:50	3:09	0.000000	LT CIRCUIT MAINTENANCE
1906	25-02-2026	Part of : BLOCK 4A TILAK NAGAR	108	Other Outage	Unplanned Outage	25-02-2026	14:11	25-02-2026	16:21	2:10	0.000361	REPAIRING OF RMU
1907	25-02-2026	Part of : BLOCK 16 TILAK NAGAR	250	Other Outage	Planned Outage	25-02-2026	10:36	25-02-2026	13:11	2:35	0.000431	REPLACEMET OF HT BUSHING ROD
1908	25-02-2026	Part of : BLOCK WZ KESHAVPUR VEGETABLE MARKET CHAUKHANDI	89	Other Outage	Planned Outage	25-02-2026	10:25	25-02-2026	13:08	2:43	0.000453	REPLACEMET OF HT BUSHING ROD
1909	25-02-2026	Part of : BLOCK C VISHAL ENCLAVE TAGORE GARDEN EXTENSION	447	Other Outage	Planned Outage	25-02-2026	11:05	25-02-2026	14:21	3:16	0.000544	REPLACEMET OF HT BUSHING ROD
1910	25-02-2026	Part of : BLOCK C KHAYALA VISHNU GARDEN	146	Other Outage	Planned Outage	25-02-2026	11:18	25-02-2026	14:18	3:00	0.000750	REPLACEMET OF HT BUSHING ROD
1911	26-02-2026	Part of : BLOCK N SHAM NAGAR VISHNU GARDEN,BLOCK K SHAM NAGAR VISHNU GARDEN,BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN,	2800	Other Outage	Unplanned Outage	26-02-2026	14:02	26-02-2026	15:43	1:41	0.000281	CONNECTION/DISCONNECTION OF HT/LT CABLES
1912	26-02-2026	Part of : BLOCK D JANTA COLONY TAGORE GARDEN EXTENSION,	1192	Other Outage	Planned Outage	26-02-2026	10:50	26-02-2026	13:45	2:55	0.000486	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1913	26-02-2026	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN,	79	Other Outage	Planned Outage	26-02-2026	11:30	26-02-2026	13:50	2:20	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1914	26-02-2026	Part of : BLOCK A WIDOW COLONY TILAK NAGAR,	179	Other Outage	Planned Outage	26-02-2026	11:10	26-02-2026	13:46	2:36	0.000433	REPLACEMENT OF HT BUSHING ROD
1915	26-02-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION,	809	Other Outage	Planned Outage	26-02-2026	10:42	26-02-2026	13:42	3:00	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1916	27-02-2026	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN	787	Other Outage	Unplanned Outage	27-02-2026	12:06	27-02-2026	13:33	1:27	0.000363	REPAIRING OF RMU
1917	27-02-2026	Part of : S-BLOCK KHAYALA VISHNU GARDEN	1087	Other Outage	Planned Outage	27-02-2026	10:48	27-02-2026	12:46	1:58	0.000000	LT CIRCUIT MAINTENANCE
1918	27-02-2026	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	2259	Other Outage	Planned Outage	27-02-2026	12:21	27-02-2026	15:13	2:52	0.000478	REPLACEMENT OF HT BUSHING ROD
1919	27-02-2026	Part of : BLOCK 4A,5A,6,7,8,9 & 48 TILAK NAGAR	1587	Other Outage	Planned Outage	27-02-2026	12:19	27-02-2026	14:55	2:36	0.000433	REPLACEMENT OF HT BUSHING ROD
1920	27-02-2026	Part of : C-BLOCK VISHAL ENCLAVE TAGORE GARDEN EXTENSION	1165	Other Outage	Planned Outage	27-02-2026	11:15	27-02-2026	13:50	2:35	0.000431	REPLACEMENT OF HT BUSHING ROD
1921	28-02-2026	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	727	Other Outage	Planned Outage	28-02-2026	14:54	28-02-2026	17:03	2:09	0.000358	LT CIRCUIT MAINTENANCE
1922	02-02-2026	Part of : OLD JANKI PURI BINDAPUR,BLOCK E SITAPURI PART 2 SITAPURI	2451	Other Outage	Unplanned Outage	02-02-2026	16:16	02-02-2026	16:54	0:38	0.000835	HVDS FAULT
1923	02-02-2026	Part of : BLOCK H SITAPURI PART 2 SITAPURI,BLOCK A SITAPURI PART 2 SITAPURI,ANUP NAGAR ADARSH NAGAR BINDAPUR,	719	Other Outage	Planned Outage	02-02-2026	12:06	02-02-2026	13:53	1:47	0.000000	DT REPLACEMET PER DT
1924	03-02-2026	Part of : JAIN COLONY MATIALA,PARAM PURI UTTAM NAGAR,SANTOSH PARK UTTAM NAGAR	4138	Other Outage	Unplanned Outage	03-02-2026	11:10	03-02-2026	11:56	0:46	0.000036	CABLE FAULT
1925	03-02-2026	Part of : BLOCK C MAHINDRA PARK BINDAPUR	829	Other Outage	Planned Outage	03-02-2026	12:04	03-02-2026	13:49	1:45	0.000000	LT CIRCUIT MAINTENANCE
1926	03-02-2026	Part of : BLOCK E UTTAM VIHAR BINDAPUR	329	Other Outage	Planned Outage	03-02-2026	11:14	03-02-2026	13:47	2:33	0.000000	LT CIRCUIT MAINTENANCE
1927	04-02-2026	Part of : E & T-BLOCK PARAM PURI UTTAM NAGAR	4037	Other Outage	Unplanned Outage	04-02-2026	01:22	04-02-2026	02:02	0:40	0.000375	CABLE FAULT
1928	04-02-2026	Part of : F-BLOCK JEEVAN PARK BINDAPUR	1423	Other Outage	Planned Outage	04-02-2026	11:33	04-02-2026	13:57	2:24	0.000000	REPLACEMET OF HT BUSHING ROD
1929	04-02-2026	Part of : A 3-BLOCK UTTAM VIHAR BINDAPUR	160	Other Outage	Planned Outage	04-02-2026	11:16	04-02-2026	13:54	2:38	0.000000	LT CIRCUIT MAINTENANCE
1930	05-02-2026	Part of : BLOCK D2 MILAP NAGAR UTTAM NAGAR	1011	Other Outage	Planned Outage	05-02-2026	12:07	05-02-2026	13:57	1:50	0.000000	REPLACEMET OF LUGS
1931	06-02-2026	Part of : BLOCK E PARAM PURI UTTAM NAGAR,	334	Other Outage	Planned Outage	06-02-2026	11:39	06-02-2026	14:07	2:28	0.000000	REPLACEMENT OF LT BUSHING ROD
1932	06-02-2026	Part of : BLOCK B SITAPURI PART 2 SITAPURI,BLOCK A SITAPURI PART 2 SITAPURI,BLOCK E SITAPURI PART 2 SITAPURI,BLOCK H SITAPURI PART 2 SITAPURI,	998	Other Outage	Planned Outage	06-02-2026	11:44	06-02-2026	14:07	2:23	0.000000	REPLACEMENT OF LT BUSHING ROD
1933	06-02-2026	Part of : BLOCK B SITAPURI PART 2 SITAPURI,	998	Other Outage	Planned Outage	06-02-2026	11:43	06-02-2026	14:04	2:21	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1934	07-02-2026	Part of : MAHINDRA PARK BINDAPUR	1466	Other Outage	Planned Outage	07-02-2026	11:05	07-02-2026	13:28	2:23	0.000000	LT CIRCUIT MAINTENANCE
1935	08-02-2026	Part of : MAHINDRA PARK,C-BLOCK & POCKET 4 CHANAKYA PLACE-1,A 3-BLOCK HARJAN COLONY SITAPURI PART-1	5617	Other Outage	Unplanned Outage	08-02-2026	12:04	08-02-2026	12:54	0:50	0.001490	CABLE FAULT
1936	09-02-2026	Part of : BHAGWATI VIHAR, NEW UTTAM NAGAR, BLOCK C UTTAM VIHAR BINDAPUR	3304	Other Outage	Unplanned Outage	09-02-2026	12:22	09-02-2026	12:46	0:24	0.000383	CABLE FAULT
1937	09-02-2026	Part of : ANUP NAGAR ADARSH NAGAR, POCKET-4 BINDAPUR	1008	Other Outage	Unplanned Outage	09-02-2026	18:19	09-02-2026	19:10	0:51	0.000167	CABLE FAULT
1938	09-02-2026	Part of : BLOCK A 3 HARJAN COLONY SITAPURI PART 1	1138	Other Outage	Planned Outage	09-02-2026	10:58	09-02-2026	13:53	2:55	0.000000	REPLACEMENT OF LT BUSHING ROD
1939	09-02-2026	Part of : BLOCK E PARAM PURI UTTAM NAGAR	721	Other Outage	Planned Outage	09-02-2026	11:40	09-02-2026	15:00	3:20	0.000000	REPLACEMENT OF LT BUSHING ROD
1940	10-02-2026	Part of : BLOCK F JEEVAN PARK BINDAPUR,OLD JANKI PURI BINDAPUR,BLOCK C MAHINDRA PARK BINDAPUR	5391	Other Outage	Unplanned Outage	10-02-2026	14:37	10-02-2026	15:31	0:54	0.000000	CABLE FAULT
1941	10-02-2026	Part of : BLOCK O UTTAM NAGAR	1212	Other Outage	Unplanned Outage	10-02-2026	03:46	10-02-2026	04:33	0:47	0.000164	CABLE FAULT
1942	10-02-2026	Part of : BLOCK E PARAM PURI UTTAM NAGAR,	360	Other Outage	Unplanned Outage	10-02-2026	11:22	10-02-2026	12:43	1:21	0.000000	LAYING OF NEW LTAB
1943	10-02-2026	Part of : MAHAVIR ENCLAVE PART 3 MAHAVIR ENCLAVE,	1219	Other Outage	Planned Outage	10-02-2026	12:07	10-02-2026	13:57	1:50	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1944	10-02-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,	267	Other Outage	Planned Outage	10-02-2026	12:08	10-02-2026	14:52	2:44	0.000000	REPLACEMENT OF LT BUSHING ROD
1945	10-02-2026	Part of : BLOCK C UTTAM VIHAR BINDAPUR,	1596	Other Outage	Planned Outage	10-02-2026	10:58	10-02-2026	13:52	2:54	0.000000	REPLACEMENT OF LT BUSHING ROD
1946	11-02-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	738	Other Outage	Planned Outage	11-02-2026	12:18	11-02-2026	14:06	1:48	0.000000	REPLACEMENT OF HT BUSHING ROD
1947	11-02-2026	Part of : OLD JANKI PURI BINDAPUR	638	Other Outage	Planned Outage	11-02-2026	11:09	11-02-2026	14:05	2:56	0.001467	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHE
1948	12-02-2026	Part of : A-BLOCK UTTAM VIHAR BINDAPUR	23	Other Outage	Planned Outage	12-02-2026	11:37	12-02-2026	13:48	2:11	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1949	12-02-2026	Part of : E-BLOCK PARAM PURI UTTAM NAGAR	721	Other Outage	Planned Outage	12-02-2026	12:08	12-02-2026	14:28	2:20	0.000000	LT CIRCUIT MAINTENANCE
1950	13-02-2026	Part of : BLOCK B UTTAM NAGAR	2952	Other Outage	Unplanned Outage	13-02-2026	10:22	13-02-2026	10:43	0:21	0.000000	ATTEND WEAK POINT/HOT SPOT
1951	13-02-2026	Part of : BLOCK F JEEVAN PARK BINDAPUR	483	Other Outage	Unplanned Outage	13-02-2026	12:27	13-02-2026	13:52	1:25	0.000472	MOBILE TRANSFORMER REPLACEMENT
1952	13-02-2026	Part of : BLOCK B UTTAM NAGAR	2952	Other Outage	Unplanned Outage	13-02-2026	11:08	13-02-2026	12:40	1:32	0.000000	ATTEND WEAK POINT/HOT SPOT
1953	13-02-2026	Part of : BLOCK A KIRAN GARDENS UTTAM NAGAR	461	Other Outage	Planned Outage	13-02-2026	11:55	13-02-2026	15:15	3:20	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1954	16-02-2026	Part of : BHAGWATI VIHAR BINDAPUR	2029	Other Outage	Planned Outage	16-02-2026	11:55	16-02-2026	14:12	2:17	0.000000	LT CIRCUIT MAINTENANCE
1955	16-02-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	483	Other Outage	Planned Outage	16-02-2026	10:58	16-02-2026	14:01	3:03	0.001271	LT CIRCUIT MAINTENANCE
1956	17-02-2026	Part of : BLOCK C UTTAM VIHAR BINDAPUR, SUBHASH PARK EXTN., BHAGWATI VIHAR BINDAPUR	4002	Other Outage	Unplanned Outage	17-02-2026	15:45	17-02-2026	16:38	0:53	0.000571	HVDS FAULT
1957	17-02-2026	Part of : BLOCK C UTTAM VIHAR BINDAPUR, SUBHASH PARK EXTN., BHAGWATI VIHAR BINDAPUR	4002	Other Outage	Unplanned Outage	17-02-2026	13:00	17-02-2026	13:54	0:54	0.000664	HVDS FAULT
1958	17-02-2026	Part of : PARJPAT COLONY BINDAPUR	1340	Other Outage	Planned Outage	17-02-2026	12:16	17-02-2026	14:02	1:46	0.000000	REPLACEMENT OF LT BUSHING ROD
1959	17-02-2026	Part of : BLOCK C & D2 MAHINDRA PARK BINDAPUR	2451	Other Outage	Planned Outage	17-02-2026	11:12	17-02-2026	13:52	2:40	0.000000	REPLACEMET OF HT BUSHING ROD
1960	17-02-2026	Part of : BLOCK F JEEVAN PARK BINDAPUR	482	Other Outage	Planned Outage	17-02-2026	11:37	17-02-2026	13:43	2:06	0.000000	REPLACEMENT OF LT BUSHING ROD
1961	18-02-2026	Part of : NANHEY PARK OM VIHAR UTTAM NAGAR,	939	Other Outage	Planned Outage	18-02-2026	13:08	18-02-2026	14:47	1:39	0.000000	3PH DB REPLACEMENT
1962	18-02-2026	Part of : BLOCK A3 UTTAM VIHAR BINDAPUR,	443	Other Outage	Planned Outage	18-02-2026	11:28	18-02-2026	13:56	2:28	0.000000	REPLACEMENT OF LT BUSHING ROD
1963	18-02-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,	804	Other Outage	Planned Outage	18-02-2026	11:13	18-02-2026	13:54	2:41	0.000000	REPLACEMENT OF LT BUSHING ROD
1964	19-02-2026	Part of : INDIRA PARK BINDAPUR	539	Other Outage	Unplanned Outage	19-02-2026	13:01	19-02-2026	14:17	1:16	0.000000	MOBILE TRANSFORMER REPLACEMENT
1965	19-02-2026	Part of : Part of : OLD JANKI PURI BINDAPUR	2098	Other Outage	Planned Outage	19-02-2026	11:00	19-02-2026	13:51	2:51	0.000000	REPLACEMENT OF HT BUSHING ROD
1966	19-02-2026	Part of : Part of : INDIRA PARK BINDAPUR	955	Other Outage	Planned Outage	19-02-2026	10:58	19-02-2026	14:03	3:05	0.000000	REPLACEMENT OF HT BUSHING ROD
1967	19-02-2026	Part of : Part of : E-BLOCK UTTAM VIHAR BINDAPUR	196	Other Outage	Planned Outage	19-02-2026	11:53	19-02-2026	14:12	2:19	0.000000	LT CIRCUIT MAINTENANCE
1968	20-02-2026	Part of : BLOCK C CHANAKYA PLACE-I SITAPURI	1870	Other Outage	Planned Outage	20-02-2026	13:26	20-02-2026	15:00	1:34	0.000000	REPLACEMET OF HT BUSHING ROD
1969	20-02-2026	Part of : INDR A PARK RAM DATT ENCLAVE,BLOCK A RAM DATT ENCLAVE UTTAM NAGAR	3168	Other Outage	Planned Outage	20-02-2026	10:34	20-02-2026	12:43	2:09	0.000000	REPLACEMET OF HT BUSHING ROD
1970	20-02-2026	Part of : OLD JANKI PURI BINDAPUR	418	Other Outage	Planned Outage	20-02-2026	11:21	20-02-2026	13:56	2:35	0.000000	LT CIRCUIT MAINTENANCE
1971	20-02-2026	Part of : MANAS KUNJ NEW UTTAM NAGAR	1004	Other Outage	Planned Outage	20-02-2026	11:26	20-02-2026	13:57	2:31	0.000000	LT CIRCUIT MAINTENANCE
1972	23-02-2026	Part of : Parjapat Colony Bindapur,Bindapur,Anup Nagar Adarsh Nagar Bindapur,Nand Ram Park New Uttam Nagar Uttam Nagar	3051	Other Outage	Unplanned Outage	23-02-2026	10:00	23-02-2026	10:34	0:34	0.000832	BIRDAGE
1973	23-02-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,MAHAVIR ENCLAVE PART-3	266	Other Outage	Planned Outage	23-02-2026	11:17	23-02-2026	14:06	2:49	0.000000	REPLACEMET OF HT BUSHING ROD
1974	24-02-2026	Part of : A 3-BLOCK HARJAN COLONY SITAPURI PART-1	616	Other Outage	Unplanned Outage	24-02-2026	13:51	24-02-2026	15:13	1:22	0.000000	MOBILE TRANSFORMER REPLACEMENT
1975	24-02-2026	Part of : BLOCK A & H SITAPURI PART 2,ANUP NAGAR ADARSH NAGAR BINDAPUR	722	Other Outage	Planned Outage	24-02-2026	11:02	24-02-2026	13:40	2:38	0.000000	3PH HT AB CABLE REPLACEMENT
1976	24-02-2026	Part of : BLOCK T PARAM PURI UTTAM NAGAR	1319	Other Outage	Planned Outage	24-02-2026	12:26	24-02-2026	14:35	2:09	0.000000	LT CIRCUIT MAINTENANCE
1977	25-02-2026	Part of : BLOCK A,B,E & H SITAPURI PART 2	997	Other Outage	Planned Outage	25-02-2026	12:24	25-02-2026	13:48	1:24	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1978	26-02-2026	Part of : BLOCK A SITAPURI PART 2 SITAPURI,	113	Other Outage	Unplanned Outage	26-02-2026	10:48	26-02-2026	12:13	1:25	0.000000	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
1979	26-02-2026	Part of : OLD JANKI PURI BINDAPUR,	658	Other Outage	Planned Outage	26-02-2026	11:37	26-02-2026	13:27	1:50	0.000000	REPLACEMET OF HT BUSHING ROD
1980	27-02-2026	Part of : BLOCK A SITAPURI PART 2	1	Other Outage	Unplanned Outage	27-02-2026	12:21	27-02-2026	13:52	1:31	0.000379	REPAIRING OF RMU
1981	27-02-2026	Part of : E-BLOCK PARAM PURI UTTAM NAGAR	3249	Other Outage	Planned Outage	27-02-2026	11:24	27-02-2026	13:54	2:30	0.001250	ACB REPLACEMENT
1982	27-02-2026	Part of : OLD JANKI PURI BINDAPUR	548	Other Outage	Planned Outage	27-02-2026	11:13	27-02-2026	13:52	2:39	0.000000	LT CIRCUIT MAINTENANCE
1983	28-02-2026	Part of : MAHINDRA PARK BINDAPUR,POCKET 4 & C-BLOCK CHANAKYA PLACE-1, A 3-BLOCK HARJAN COLONY	5667	Other Outage	Unplanned Outage	28-02-2026	17:34	28-02-2026	18:03	0:29	0.000206	CABLE FAULT
1984	28-02-2026	Part of : E & T-BLOCK PARAM PURI UTTAM NAGAR	4038	Other Outage	Unplanned Outage	28-02-2026	17:27	28-02-2026	18:03	0:36	0.000688	CABLE FAULT
1985	28-02-2026	Part of : INDIRA PARK BINDAPUR	464	Other Outage	Unplanned Outage	28-02-2026	11:47	28-02-2026	13:19	1:32	0.000639	REPLACEMENT OF HVDS TRANSFORMER
1986	02-02-2026	Part of : PHASE 1 OM VIHAR NAWADA,	1084	Other Outage	Planned Outage	02-02-2026	11:15	02-02-2026	13:49	2:34	0.000000	REPLACEMENT OF HT BUSHING ROD
1987	02-02-2026	Part of : VIKAS NAGAR EXTN.,	1229	Other Outage	Planned Outage	02-02-2026	11:20	02-02-2026	13:52	2:32	0.000000	DT REPLACEMENT PER DT
1988	02-02-2026	Part of : MANOHAR NAGAR VIKAS PURI,	200	Other Outage	Planned Outage	02-02-2026	10:38	02-02-2026	13:01	2:23	0.000000	REPLACEMENT OF LT BUSHING ROD
1989	03-02-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE	885	Other Outage	Unplanned Outage	03-02-2026	06:07	03-02-2026	08:07	2:00	0.001098	HT SYSTEM FAULT
1990	03-02-2026	Part of : HASTSAL VIHAR,HASTSAL VILLAGE,KRISHNA COLONY	2696	Other Outage	Planned Outage	03-02-2026	10:48	03-02-2026	13:48	3:00	0.000000	GUARD WIRES SAGGING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1991	03-02-2026	Part of : BLOCK C VIKAS PURI	325	Other Outage	Planned Outage	03-02-2026	10:03	03-02-2026	12:40	2:37	0.000000	LT CIRCUIT MAINTENANCE
1992	04-02-2026	Part of : OM VIHAR PHASE 2 HASTSAL	293	Other Outage	Planned Outage	04-02-2026	11:15	04-02-2026	13:53	2:38	0.000000	LT CIRCUIT MAINTENANCE
1993	04-02-2026	Part of : VIKAS ENCLAVE,DEEPAK VIHAR EXTN.,VIKAS NAGAR EXTN.,DEEP VIHAR,VIKAS NAGAR PHASE-1,2 & 3	1918	Other Outage	Planned Outage	04-02-2026	11:11	04-02-2026	13:54	2:43	0.000000	DT REPLACEMET
1994	04-02-2026	Part of : C-BLOCK VIKAS PURI	356	Other Outage	Planned Outage	04-02-2026	10:35	04-02-2026	12:47	2:12	0.000000	LT CIRCUIT MAINTENANCE
1995	05-02-2026	Part of : BLOCK C VIKAS PURI, BODHELA VILLAGE VIKAS PURI	1546	Other Outage	Unplanned Outage	05-02-2026	15:25	05-02-2026	16:16	0:51	0.000199	HT SYSTEM FAULT
1996	05-02-2026	Part of : KRISHNA COLONY,BLOCK A 2 UTTAM NAGAR,PHASE 2 OM VIHAR HASTSAL	2298	Other Outage	Planned Outage	05-02-2026	14:02	05-02-2026	16:45	2:43	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1997	05-02-2026	Part of : HASTSAL VIHAR,KRISHNA COLONY HASTSAL VILLAGE	2696	Other Outage	Planned Outage	05-02-2026	14:02	05-02-2026	16:46	2:44	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1998	05-02-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK P MOHAN GARDEN RAZAPUR KHURD,L1A AND L- BLOCK MOHAN GARDEN,BLOCK N 1 MOHAN GARDEN RAZAPUR KHURD,AB&C-BLOCK L-2 MOHAN GARDEN,BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,	2829	Other Outage	Planned Outage	05-02-2026	11:22	05-02-2026	13:57	2:35	0.000000	DT REPLACEMET PER DT
1999	06-02-2026	Part of : SHIV VIHAR HASTSAL,BHIM ENCLAVE,VIKAS NAGAR PHASE-I,II,III,HASTSAL EXTN. AND VIKAS NAGAR PHASE-II,	4333	Other Outage	Unplanned Outage	06-02-2026	11:34	06-02-2026	12:50	1:16	0.000000	ATTEND WEAK POINT/HOT SPOT
2000	06-02-2026	Part of : GUPTA ENCLAVE,	412	Other Outage	Planned Outage	06-02-2026	13:58	06-02-2026	15:57	1:59	0.000000	CONDUCTOR REPLACEMENT PER SPAN
2001	06-02-2026	Part of : HASTSAL VIHAR HASTSAL VILLAGE HASTSAL,KRISHNA COLONY HASTSAL VILLAGE HASTSAL,	2696	Other Outage	Planned Outage	06-02-2026	12:54	06-02-2026	14:23	1:29	0.000000	GUARD WIRES SAGGING PER SPAN
2002	06-02-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL,BLOCK A 2 UTTAM NAGAR,PHASE 2 OM VIHAR HASTSAL,HOSTAL VIHAR OM VIHAR HASTSAL,	2298	Other Outage	Planned Outage	06-02-2026	12:53	06-02-2026	14:24	1:31	0.000000	GUARD WIRES SAGGING PER SPAN
2003	06-02-2026	Part of : DEEPAK VIHAR EXTN.,	875	Other Outage	Planned Outage	06-02-2026	11:27	06-02-2026	13:59	2:32	0.000000	GUARD WIRES SAGGING PER SPAN
2004	06-02-2026	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK,M-BLOCK VIKAS VIHAR COMMANDER CHOWK,VIKAS NAGAR EXTN.,SAINIK ENCLAVE,	1875	Other Outage	Planned Outage	06-02-2026	11:26	06-02-2026	13:58	2:32	0.000000	DT REPLACEMET PER DT
2005	06-02-2026	Part of : BLOCK H1 VIKAS PURI,	263	Other Outage	Planned Outage	06-02-2026	11:29	06-02-2026	13:58	2:29	0.000000	REPLACEMENT OF LT BUSHING ROD
2006	07-02-2026	Part of : VIKAS ENCLAVE,B-BLOCK VIKAS NAGAR EXTN.	237	Other Outage	Planned Outage	07-02-2026	11:49	07-02-2026	14:18	2:29	0.000000	GUARD WIRE LACS INSTALLTION
2007	07-02-2026	Part of : PRESS ENCLAVE,SURKAKHA ENCLAVE,M-BLOCK COMMONDER CHOWK,DEEPAK VIHAR,VIKAS ENCLAVE,B-BLOCK VIKAS NAGAR EXTN.	1750	Other Outage	Planned Outage	07-02-2026	11:42	07-02-2026	14:18	2:36	0.000000	DT REPLACEMENT PER DT
2008	07-02-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE	537	Other Outage	Planned Outage	07-02-2026	14:12	07-02-2026	16:25	2:13	0.000000	LT CIRCUIT MAINTENANCE
2009	07-02-2026	Part of : SHIV VIHAR WEST	981	Other Outage	Planned Outage	07-02-2026	11:47	07-02-2026	14:17	2:30	0.000000	LT CIRCUIT MAINTENANCE
2010	07-02-2026	Part of : BLOCK DG 1 VIKAS PURI	236	Other Outage	Planned Outage	07-02-2026	10:32	07-02-2026	12:57	2:25	0.000000	LT CIRCUIT MAINTENANCE
2011	09-02-2026	Part of : PHASE 1 OM VIHAR NAWADA,PHASE 3 OM VIHAR HASTSAL,PHASE 4 OM VIHAR HASTSAL	1326	Other Outage	Planned Outage	09-02-2026	12:25	09-02-2026	14:58	2:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2012	09-02-2026	Part of : K-5 EXTN. AND DEEPAK VIHAR	1695	Other Outage	Planned Outage	09-02-2026	10:47	09-02-2026	14:01	3:14	0.000000	GUARD WIRES SAGGING PER SPAN
2013	09-02-2026	Part of : GUPTA ENCLAVE	412	Other Outage	Planned Outage	09-02-2026	11:35	09-02-2026	13:54	2:19	0.000000	3PH DB REVAMPING
2014	09-02-2026	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK	1560	Other Outage	Planned Outage	09-02-2026	11:34	09-02-2026	13:50	2:16	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2015	10-02-2026	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK,SAINIK ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,SHIV VIHAR HASTSAL,A&B BLOCK VIKAS VIHAR AND SAI ENCLAVE,VIKRANT VIHAR,PRESS ENCLAVE	4683	Other Outage	Unplanned Outage	10-02-2026	03:42	10-02-2026	04:32	0:50	0.000056	HT SYSTEM FAULT
2016	10-02-2026	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK,	1875	Other Outage	Planned Outage	10-02-2026	11:28	10-02-2026	13:52	2:24	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
2017	10-02-2026	Part of : BLOCK C JJ COLONY UTTAM NAGAR,	959	Other Outage	Planned Outage	10-02-2026	11:17	10-02-2026	13:49	2:32	0.000000	REPLACEMET OF HT BUSHING ROD
2018	10-02-2026	Part of : PHASE 1 VIKAS PURI,	154	Other Outage	Planned Outage	10-02-2026	10:48	10-02-2026	13:50	3:02	0.000000	REPLACEMENT OF LT BUSHING ROD
2019	11-02-2026	Part of : D-BLOCK JJ COLONY	507	Other Outage	Planned Outage	11-02-2026	11:14	11-02-2026	13:51	2:37	0.000000	LT CIRCUIT MAINTENANCE
2020	11-02-2026	Part of : PHASE 1 VIKAS PURI	85	Other Outage	Planned Outage	11-02-2026	10:40	11-02-2026	12:54	2:14	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2021	12-02-2026	Part of : SHIV VIHAR COLONY	1794	Other Outage	Planned Outage	12-02-2026	11:34	12-02-2026	13:43	2:09	0.000000	LT CIRCUIT MAINTENANCE
2022	12-02-2026	Part of : AK MARKET VIKAS PURI	141	Other Outage	Planned Outage	12-02-2026	11:33	12-02-2026	13:42	2:09	0.000000	LT CIRCUIT MAINTENANCE
2023	13-02-2026	Part of : SAI& SETHI ENCLAVE	834	Other Outage	Planned Outage	13-02-2026	12:41	13-02-2026	15:17	2:36	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2024	13-02-2026	Part of : BLOCK A 3 UTTAM NAGAR	979	Other Outage	Planned Outage	13-02-2026	11:37	13-02-2026	13:40	2:03	0.000000	3PH DB REVAMPING
2025	13-02-2026	Part of : PHASE 1 VIKAS PURI	46	Other Outage	Planned Outage	13-02-2026	11:29	13-02-2026	13:46	2:17	0.000000	REPLACEMENT OF LT BUSHING ROD
2026	14-02-2026	Part of : VIKAS KUNJ AND VIKAS KUNJ EXTN.,SHIV VIHAR HASTSAL,DEEP ENCLAVE	3640	Other Outage	Unplanned Outage	14-02-2026	16:56	14-02-2026	17:15	0:19	0.000000	CABLE FAULT
2027	14-02-2026	Part of : PHASE 1 VIKAS PURI,	51	Other Outage	Planned Outage	14-02-2026	10:16	14-02-2026	12:33	2:17	0.000000	REPLACEMENT OF LT BUSHING ROD
2028	16-02-2026	Part of : BLOCK A 3 UTTAM NAGAR	1068	Other Outage	Planned Outage	16-02-2026	12:01	16-02-2026	14:15	2:14	0.000000	LT CIRCUIT MAINTENANCE
2029	17-02-2026	Part of : YADAV ENCLAVE, DEEP ENCLAVE, NAIDER ENCLAVE, KHUSHI RAM COLONY, VIKAS NAGAR	5792	Other Outage	Unplanned Outage	17-02-2026	16:28	17-02-2026	17:00	0:32	0.000388	CABLE FAULT
2030	17-02-2026	Part of : VIKAS NAGAR EXTN.	1229	Other Outage	Planned Outage	17-02-2026	11:23	17-02-2026	13:42	2:19	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2031	17-02-2026	Part of : BLOCK A 1 UTTAM NAGAR	791	Other Outage	Planned Outage	17-02-2026	11:54	17-02-2026	13:59	2:05	0.000000	REPLACEMENT OF LT BUSHING ROD
2032	17-02-2026	Part of : KANGRA NIKETAN VIKAS PURI	134	Other Outage	Planned Outage	17-02-2026	10:20	17-02-2026	12:39	2:19	0.000000	REPLACEMENT OF LT BUSHING ROD
2033	18-02-2026	Part of : R&S BLOCK VIKAS NAGAR,SHIV VIHAR WEST,GUPTA ENCLAVE,	961	Other Outage	Planned Outage	18-02-2026	11:27	18-02-2026	13:55	2:28	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2034	19-02-2026	Part of : K5 & K6 AND DEFENCE ENCLAVE PART-1 MOHAN GARDEN,K-5 EXTN. AND DEEPAK VIHAR,BLOCK M ZAILDAR ENCLAVE HASTSAL	6059	Other Outage	Unplanned Outage	19-02-2026	14:31	19-02-2026	14:57	0:26	0.000327	CABLE FAULT
2035	19-02-2026	Part of : Part of : ANURODHYA APARTMENTS VIKAS PURI	97	Other Outage	Planned Outage	19-02-2026	10:36	19-02-2026	12:53	2:17	0.000000	LT CIRCUIT MAINTENANCE
2036	19-02-2026	Part of : Part of : C-BLOCK VIKAS PURI	456	Other Outage	Planned Outage	19-02-2026	10:33	19-02-2026	12:53	2:20	0.000000	LT CIRCUIT MAINTENANCE
2037	20-02-2026	Part of : OM VIHAR PHASE 3 HASTSAL	1127	Other Outage	Planned Outage	20-02-2026	12:38	20-02-2026	13:55	1:17	0.000000	REPLACEMET OF FAULTY END BOX
2038	20-02-2026	Part of : YADAV ENCLAVE,VIKAS VIHAR,A&B BLOCK VIKAS VIHAR,SAI ENCLAVE,SURKAKHA ENCLAVE	1537	Other Outage	Planned Outage	20-02-2026	11:13	20-02-2026	13:48	2:35	0.000000	3PH HT AB CABLE REPLACEMENT
2039	20-02-2026	Part of : GUJRANWALA VIKAS PURI	562	Other Outage	Planned Outage	20-02-2026	10:26	20-02-2026	12:40	2:14	0.000000	LT CIRCUIT MAINTENANCE
2040	21-02-2026	Part of : KESHOPUR STAFF QUATERS VIKAS PURI, KESHOPUR PLANT (HTC), STP DJB KESHOPUR (HTC)	55	Other Outage	Unplanned Outage	21-02-2026	12:51	21-02-2026	13:21	0:30	0.000850	CABLE FAULT
2041	21-02-2026	Part of : PRESS ENCLAVE,SURKAKHA ENCLAVE AND M-BLOCK COMMONDER CHOWK,VIKAS ENCLAVE	1750	Other Outage	Planned Outage	21-02-2026	11:03	21-02-2026	13:37	2:34	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2042	21-02-2026	Part of : BLOCK M DISTRICT PARK VIKAS PURI	275	Other Outage	Planned Outage	21-02-2026	10:06	21-02-2026	12:29	2:23	0.000000	REPLACEMENT OF LT BUSHING ROD
2043	23-02-2026	Part of : VIKAS NAGAR EXTN.	1229	Other Outage	Planned Outage	23-02-2026	14:44	23-02-2026	16:18	1:34	0.000000	3PH HT AB CABLE REPLACEMENT
2044	23-02-2026	Part of : JJ COLONY UTTAM NAGAR	1022	Other Outage	Planned Outage	23-02-2026	14:02	23-02-2026	16:17	2:15	0.000000	LT CIRCUIT MAINTENANCE
2045	23-02-2026	Part of : JJ COLONY UTTAM NAGAR	1022	Other Outage	Planned Outage	23-02-2026	11:34	23-02-2026	13:52	2:18	0.000000	LT CIRCUIT MAINTENANCE
2046	23-02-2026	Part of : BLOCK GG2 VIKAS PURI	225	Other Outage	Planned Outage	23-02-2026	10:24	23-02-2026	12:44	2:20	0.000000	LT CIRCUIT MAINTENANCE
2047	24-02-2026	Part of : DDA LIG FLATS HASTSAL	568	Other Outage	Planned Outage	24-02-2026	14:29	24-02-2026	16:26	1:57	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
2048	24-02-2026	Part of : BLOCK F & S VIKAS NAGAR,SHIV VIHAR COLONY,D-BLOCK JJ COLONY	1794	Other Outage	Planned Outage	24-02-2026	10:52	24-02-2026	13:39	2:47	0.000000	3PH HT AB CABLE REPLACEMENT
2049	24-02-2026	Part of : BLOCK C JJ COLONY UTTAM NAGAR	960	Other Outage	Planned Outage	24-02-2026	11:07	24-02-2026	13:40	2:33	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
2050	24-02-2026	Part of : BLOCK H SAMAJ KALYAN APARTMENT VIKAS PURI	1	Other Outage	Planned Outage	24-02-2026	10:19	24-02-2026	12:44	2:25	0.000000	REPLACEMENT OF HT BUSHING ROD
2051	25-02-2026	Part of : VIKAS ENCLAVE, DEEPAK VIHAR EXTN.,VIKAS NAGAR EXTN.,DEEP VIHAR VIKASPURI	1919	Other Outage	Planned Outage	25-02-2026	13:14	25-02-2026	15:47	2:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2052	25-02-2026	Part of : BLOCK C JJ COLONY UTTAM NAGAR	907	Other Outage	Planned Outage	25-02-2026	12:03	25-02-2026	14:47	2:44	0.000000	REPLACEMENT OF LT BUSHING ROD
2053	25-02-2026	Part of : BLOCK H SAMAJ KALYAN APARTMENT VIKAS PURI	87	Other Outage	Planned Outage	25-02-2026	10:39	25-02-2026	12:47	2:08	0.000000	REPLACEMENT OF LT BUSHING ROD
2054	26-02-2026	Part of : BLOCK H SAMAJ KALYAN APARTMENT VIKAS PURI,	122	Other Outage	Planned Outage	26-02-2026	10:25	26-02-2026	12:22	1:57	0.000000	REPLACEMENT OF LT BUSHING ROD
2055	26-02-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL,BLOCK A 2 UTTAM NAGAR,PHASE 2 OM VIHAR HASTSAL,HOSTAL VIHAR OM VIHAR HASTSAL,	2298	Other Outage	Planned Outage	26-02-2026	11:17	26-02-2026	13:26	2:09	0.000000	DT REPLACEMET PER DT
2056	28-02-2026	Part of : OM VIHAR PHASE 5 HASTSAL	83	Other Outage	Planned Outage	28-02-2026	12:40	28-02-2026	14:29	1:49	0.000000	LT CIRCUIT MAINTENANCE
2057	28-02-2026	Part of : GUJRANWALA VIKAS PURI	146	Other Outage	Planned Outage	28-02-2026	10:29	28-02-2026	12:29	2:00	0.000000	LT CIRCUIT MAINTENANCE