

Name of Distribution Licensee: BSES Rajdhani Power Limited												
Period of Outage: JANUARY 2026												
Sr. No.	Date	Area Affected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1	02-01-2026	Part of : TUGHLAKABAD EXTN	5328	Other Outage	Unplanned Outage	02-01-2026	02:55	02-01-2026	03:36	0:41	0.000262	CABLE FAULT
2	02-01-2026	Part of : E-BLOCK MASJID MOTH	257	Other Outage	Planned Outage	02-01-2026	11:13	02-01-2026	13:45	2:32	0.000633	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
3	02-01-2026	Part of : LSC-42 KALKAJI	391	Other Outage	Planned Outage	02-01-2026	11:07	02-01-2026	13:52	2:45	0.003208	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
4	02-01-2026	Part of : GODAVARI APARTMENT	164	Other Outage	Planned Outage	02-01-2026	10:59	02-01-2026	13:50	2:51	0.000000	REPLACEMENT OF HT BUSHING ROD
5	04-01-2026	Part of : D-BLOCK OKHLA PHASE-1,INDIRA KALYAN VIHAR OKHLA PHASE-1	1095	Other Outage	Planned Outage	04-01-2026	11:00	04-01-2026	13:47	2:47	0.001160	REPLACEMENT OF LT BUSHING ROD
6	05-01-2026	Part of : YAMUNA APARTMENT,	225	Other Outage	Planned Outage	05-01-2026	10:57	05-01-2026	13:27	2:30	0.000000	MAINTENANCE OF TRANSFORMER
7	05-01-2026	Part of : J-BLOCK CR PARK,	309	Other Outage	Planned Outage	05-01-2026	11:07	05-01-2026	13:55	2:48	0.000700	MAINTENANCE OF TRANSFORMER
8	05-01-2026	Part of : LSC-59 KALKAJI,	285	Other Outage	Planned Outage	05-01-2026	11:25	05-01-2026	13:58	2:33	0.003400	MAINTENANCE OF TRANSFORMER
9	06-01-2026	Part of : M-BLOCK GK-2	473	Other Outage	Planned Outage	06-01-2026	11:13	06-01-2026	13:59	2:46	0.000922	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
10	06-01-2026	Part of : NILGIRI APARTMENT	244	Other Outage	Planned Outage	06-01-2026	11:02	06-01-2026	13:59	2:57	0.000000	REPLACEMENT OF LT BUSHING ROD
11	07-01-2026	Part of : NARMADA APARTMENT,YAMUNA APARTMENT,GODAVARI APARTMENT,ARAWALI APARTMENT,NILGIRI APARTMENT,L1-BLOCK LIG KALKA JI,ARAWALI SHOPPING CENTRE	2374	Other Outage	Unplanned Outage	07-01-2026	13:56	07-01-2026	14:33	0:37	0.000462	REPAIRING OF RMU
12	07-01-2026	Part of : H-BLOCK KALKA JI	352	Other Outage	Planned Outage	07-01-2026	11:29	07-01-2026	13:51	2:22	0.003550	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
13	07-01-2026	Part of : NARMADA APARTMENT	243	Other Outage	Planned Outage	07-01-2026	11:27	07-01-2026	13:33	2:06	0.000000	REPLACEMENT OF HT BUSHING ROD
14	08-01-2026	Part of : NILGIRI APARTMENT	297	Other Outage	Planned Outage	08-01-2026	11:07	08-01-2026	13:45	2:38	0.000000	REPLACEMENT OF LT BUSHING ROD
15	09-01-2026	Part of : 2-BLOCK KALKA JI,	227	Other Outage	Planned Outage	09-01-2026	11:21	09-01-2026	13:58	2:37	0.003925	MAINTENANCE OF TRANSFORMER
16	09-01-2026	Part of : TUGHLAKABAD EXTN,	2331	Other Outage	Planned Outage	09-01-2026	11:20	09-01-2026	13:59	2:39	0.000000	MAINTENANCE OF RMU
17	10-01-2026	Part of : W-BLOCK GK-2	160	Other Outage	Unplanned Outage	10-01-2026	05:13	10-01-2026	06:08	0:55	0.000260	HT SYSTEM FAULT
18	10-01-2026	PART OF : C-BLOCK KALKA JI	100	Other Outage	Planned Outage	10-01-2026	11:17	10-01-2026	13:43	2:26	0.003244	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
19	11-01-2026	Part of : F-BLOCK OKHLA PHASE-1	828	Other Outage	Unplanned Outage	11-01-2026	10:50	11-01-2026	12:48	1:58	0.000000	REPAIRING OF LT CIRCUIT
20	11-01-2026	Part of : B-BLOCK OKHLA INDUSTRIAL AREA PHASE-1	398	Other Outage	Planned Outage	11-01-2026	11:08	11-01-2026	14:00	2:52	0.000000	PROOPER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
21	11-01-2026	Part of : DSIDC OKHLA INDUSTRIAL AREA PHASE-1	171	Other Outage	Planned Outage	11-01-2026	11:09	11-01-2026	13:51	2:42	0.002025	REPLACEMENT OF HT BUSHING ROD
22	12-01-2026	Part of : 40-BLOCK CR PARK	536	Other Outage	Planned Outage	12-01-2026	11:08	12-01-2026	13:59	2:51	0.003800	REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
23	12-01-2026	Part of : NILGIRI APARTMENT	202	Other Outage	Planned Outage	12-01-2026	11:23	12-01-2026	13:57	2:34	0.000000	REPLACEMET OF HT BUSHING ROD
24	13-01-2026	Part of : L-BLOCK KALKA JI	504	Other Outage	Planned Outage	13-01-2026	11:15	13-01-2026	13:30	2:15	0.003375	REPLACEMENT OF LT BUSHING ROD
25	14-01-2026	Part of : 40-BLOCK CR PARK	655	Other Outage	Planned Outage	14-01-2026	11:21	14-01-2026	13:57	2:36	0.003467	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
26	15-01-2026	Part of : RISHI APARTMENT	362	Other Outage	Planned Outage	15-01-2026	11:15	15-01-2026	13:50	2:35	0.000000	REPLACEMET OF HT BUSHING ROD
27	16-01-2026	Part of : TEKHHAND VILLAGE	2270	Other Outage	Unplanned Outage	16-01-2026	19:04	16-01-2026	19:44	0:40	0.000634	FAULT IN HT CONSUMER PANEL (WESTERN RAILWAY)
28	16-01-2026	Part of : BLOCK 8 TILAK NAGAR	311	Other Outage	Planned Outage	16-01-2026	11:00	16-01-2026	13:50	2:50	0.000000	REPLACEMENT OF LT BUSHING ROD
29	17-01-2026	Part of : 16-BLOCK KALKA JI	442	Other Outage	Planned Outage	17-01-2026	11:07	17-01-2026	13:56	2:49	0.005164	MAINTENANCE OF TRANSFORMER
30	17-01-2026	Part of : MANGALA APARTMENT	467	Other Outage	Planned Outage	17-01-2026	11:06	17-01-2026	13:56	2:50	0.004722	MAINTENANCE OF TRANSFORMER
31	18-01-2026	Part of : DDA SHED OKHLA PHASE-1	110	Other Outage	Planned Outage	18-01-2026	11:28	18-01-2026	14:56	3:28	0.001156	DT REPLACEMENT
32	18-01-2026	Part of : D-BLOCK OKHLA PHASE-1	102	Other Outage	Planned Outage	18-01-2026	10:57	18-01-2026	13:53	2:56	0.002200	REPLACEMENT OF LT BUSHING ROD
33	19-01-2026	Part of : RISHI APARTMENT	72	Other Outage	Planned Outage	19-01-2026	11:16	19-01-2026	13:22	2:06	0.000000	REPLACEMET OF HT BUSHING ROD
34	19-01-2026	Part of : GOVINDPURI EXTENSION KALKAJI	1029	Other Outage	Planned Outage	19-01-2026	11:08	19-01-2026	13:16	2:08	0.004267	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
35	20-01-2026	Part of : SHAHEED RAJIV GANDHI COLONY GOVINDPURI	682	Other Outage	Planned Outage	20-01-2026	11:28	20-01-2026	13:45	2:17	0.003044	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR
36	20-01-2026	Part of : GANGA APARTMENT	199	Other Outage	Planned Outage	20-01-2026	11:28	20-01-2026	13:46	2:18	0.000000	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unreserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
37	20-01-2026	Part of : M-BLOCK GK-2	87	Other Outage	Planned Outage	20-01-2026	11:27	20-01-2026	13:44	2:17	0.000571	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
38	21-01-2026	Part of : TUGHLAKABAD EXTN,	860	Other Outage	Planned Outage	21-01-2026	11:16	21-01-2026	14:09	2:53	0.000000	TRANSFORMER MAINTENANCE
39	21-01-2026	Part of : HTC:SUBHASH KHATTAR,R2 NEHRU ENCL,KALKAJI	1	Other Outage	Planned Outage	21-01-2026	11:15	21-01-2026	14:07	2:52	0.003822	RMU MAINTENANCE
40	22-01-2026	Part of : GOVINDPURI,E-BLOCK CR PARK,GOVINDPURI EXTENSION GOVINDPURI KALKAJI	5406	Other Outage	Unplanned Outage	22-01-2026	12:22	22-01-2026	13:13	0:51	0.001059	HT SYSTEM FAULT
41	22-01-2026	Part of : I-BLOCK CR PARK	243	Other Outage	Planned Outage	22-01-2026	12:05	22-01-2026	13:50	1:45	0.000438	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
42	22-01-2026	Part of : GOVINDPURI	1075	Other Outage	Planned Outage	22-01-2026	11:05	22-01-2026	13:48	2:43	0.004075	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
43	23-01-2026	Part of : E-BLOCK KALKA JI	229	Other Outage	Planned Outage	23-01-2026	11:43	23-01-2026	14:03	2:20	0.003111	REPLACEMENT OF FAULTY END BOX
44	24-01-2026	Part of : GANGOTRI ENCLAVE	276	Other Outage	Planned Outage	24-01-2026	11:47	24-01-2026	13:53	2:06	0.000350	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD
45	25-01-2026	Part of : D-BLOCK OKHLA PHASE-1	115	Other Outage	Planned Outage	25-01-2026	10:59	25-01-2026	13:52	2:53	0.002403	REPLACEMENT OF LT BUSHING ROD
46	27-01-2026	Part of : H-BLOCK MASJID MOTH	271	Other Outage	Planned Outage	27-01-2026	12:04	27-01-2026	13:45	1:41	0.000281	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS
47	27-01-2026	Part of : TUGHLAKABAD EXTN.	3	Other Outage	Planned Outage	27-01-2026	11:13	27-01-2026	13:51	2:38	0.000000	REPLACEMENT OF HT BUSHING ROD
48	27-01-2026	Part of : TUGHLAKABAD EXTN.	721	Other Outage	Planned Outage	27-01-2026	11:08	27-01-2026	13:39	2:31	0.000000	LT CIRCUIT MAINTENANCE
49	28-01-2026	Part of : MANGALA APARTMENT	281	Other Outage	Planned Outage	28-01-2026	14:33	28-01-2026	16:55	2:22	0.000671	REPLACEMENT OF HT BUSHING ROD
50	28-01-2026	Part of : MANGALA APARTMENT	186	Other Outage	Planned Outage	28-01-2026	11:00	28-01-2026	13:55	2:55	0.000826	REPLACEMENT OF HT BUSHING ROD
51	28-01-2026	Part of : TUGHLAKABAD	2	Other Outage	Planned Outage	28-01-2026	10:59	28-01-2026	13:58	2:59	0.000000	REPLACEMENT OF HT BUSHING ROD
52	28-01-2026	Part of : W-BLOCK GK-2	121	Other Outage	Planned Outage	28-01-2026	11:23	28-01-2026	13:56	2:33	0.000850	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
53	29-01-2026	Part of : TUGHLAKABAD EXTN	2831	Other Outage	Unplanned Outage	29-01-2026	00:58	29-01-2026	01:43	0:45	0.000330	ELECTROCUTION OF MONKEY
54	29-01-2026	Part of : B-BLOCK CR PARK,	293	Other Outage	Planned Outage	29-01-2026	11:16	29-01-2026	13:54	2:38	0.000000	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
55	29-01-2026	Part of : A14-BLOCK KALKA JI EXTN_DDA FLATS KALKAJI,	767	Other Outage	Planned Outage	29-01-2026	11:08	29-01-2026	13:55	2:47	0.000000	REPLACEMENT OF LT BUSHING ROD
56	30-01-2026	Part of : S-BLOCK GK-2,GANGOTRI ENCLAVE, K R MANGLAM SCHOOL (HTC)	1214	Other Outage	Unplanned Outage	30-01-2026	15:01	30-01-2026	15:53	0:52	0.001182	FAULT IN HT CONSUMER PANEL (K R MANGLAM SCHOOL)
57	30-01-2026	Part of : E-BLOCK KALKA JI	177	Other Outage	Planned Outage	30-01-2026	15:23	30-01-2026	16:28	1:05	0.001444	CLEANING OF HT BUSHING PER WAY,CT REPLACEMENT,DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
58	30-01-2026	Part of : A14-BLOCK KALKA JI EXTN_DDA FLATS KALKAJI	365	Other Outage	Planned Outage	30-01-2026	10:59	30-01-2026	13:53	2:54	0.000000	REPLACEMENT OF HT BUSHING ROD
59	31-01-2026	Part of : NAVJEEVAN CAMP	936	Other Outage	Planned Outage	31-01-2026	11:02	31-01-2026	13:53	2:51	0.000000	REPLACEMENT OF HT BUSHING ROD
60	31-01-2026	Part of : GANGA APARTMENT	199	Other Outage	Planned Outage	31-01-2026	11:02	31-01-2026	13:52	2:50	0.000000	DT REPLACEMENT
61	31-01-2026	Part of : E-BLOCK MASJID MOTH	288	Other Outage	Planned Outage	31-01-2026	11:52	31-01-2026	13:54	2:02	0.000000	LT CIRCUIT MAINTENANCE
62	02-01-2026	Part of : CHHATARPUR ENCLAVE	578	Other Outage	Planned Outage	02-01-2026	12:28	02-01-2026	15:46	3:18	0.000550	REPLACEMENT OF HT BUSHING ROD
63	02-01-2026	Part of : BLOCK D CHHATARPUR VILLAGE CHHATARPUR,BLOCK C CHHATARPUR EXTENSION CHHATARPUR,CHHATARPUR,BLOCK G CHHATARPUR VILLAGE	4632	Other Outage	Planned Outage	02-01-2026	10:34	02-01-2026	15:05	4:31	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
64	02-01-2026	Part of : BLOCK E AYA NAGAR EXTENSION AYA NAGAR	909	Other Outage	Planned Outage	02-01-2026	10:44	02-01-2026	13:16	2:32	0.000000	3PH DB REVAMPING
65	02-01-2026	Part of : GADPUR FARM DLF FARMS	622	Other Outage	Planned Outage	02-01-2026	10:28	02-01-2026	14:44	4:16	0.000000	3PH DB REPLACEMENT,3PH DB REVAMPING,LT AB SAGGING PER SPAN
66	03-01-2026	Part of : BLOCK C CHHATARPUR EXTENSION	356	Other Outage	Planned Outage	03-01-2026	14:22	03-01-2026	16:00	1:38	0.000000	REPLACEMENT OF HT BUSHING ROD
67	03-01-2026	Part of : JAUNAPUR VILLAGE	22	Other Outage	Planned Outage	03-01-2026	10:08	03-01-2026	15:03	4:55	0.000000	LT CIRCUIT MAINTENANCE
68	05-01-2026	Part of : ASOLA,ASOLA WILD LIFE SANCTUARY ASOLA	1636	Other Outage	Unplanned Outage	05-01-2026	18:52	05-01-2026	19:26	0:34	0.000501	BIRDAGE
69	05-01-2026	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR,	834	Other Outage	Planned Outage	05-01-2026	10:56	05-01-2026	13:10	2:14	0.002047	MAINTENANCE OF TRANSFORMER
70	05-01-2026	Part of : DLF FARMS,BLOCK C CHHATARPUR EXTENSION CHHATARPUR,	380	Other Outage	Planned Outage	05-01-2026	10:57	05-01-2026	14:30	3:33	0.000592	MAINTENANCE OF HT O/H CIRCUIT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
71	05-01-2026	Part of : SAT BARI,ANSAL VILLAS SAT BARI,	3516	Other Outage	Planned Outage	05-01-2026	11:20	05-01-2026	14:16	2:56	0.000098	MAINTENANCE OF HT O/H CIRCUIT
72	05-01-2026	Part of : MANDI VILLAGE,	492	Other Outage	Planned Outage	05-01-2026	10:57	05-01-2026	15:16	4:19	0.000000	MAINTENANCE OF LT CIRCUIT
73	06-01-2026	Part of : AYA NAGAR PHASE 1 AYA NAGAR	958	Other Outage	Planned Outage	06-01-2026	10:56	06-01-2026	12:59	2:03	0.001879	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
74	06-01-2026	Part of : DLF FARMS	12	Other Outage	Planned Outage	06-01-2026	11:12	06-01-2026	13:29	2:17	0.000000	REPLACEMENT OF HT BUSHING ROD
75	06-01-2026	Part of : DERA VILLAGE,JAUNAPUR VILLAGE JAUNAPUR,NEW GAWALPAHARI VILLAGE,FATEHPUR BERI,ASOLA	534	Other Outage	Planned Outage	06-01-2026	11:16	06-01-2026	14:49	3:33	0.000000	CONDUCTOR REPLACEMENT PER SPAN,GUARD WIRE LACS INSTALLTION PER SPAN
76	06-01-2026	Part of : GADPUR FARM DLF FARMS,GADAIPUR DLF FARMS,GADAIPUR JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,SULTANPUR	1488	Other Outage	Planned Outage	06-01-2026	10:57	06-01-2026	13:00	2:03	0.000683	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
77	07-01-2026	Part of : DR AMBEDKAR COLONY CHHATARPUR	492	Other Outage	Planned Outage	07-01-2026	13:33	07-01-2026	16:14	2:41	0.000000	REPLACEMENT OF HT BUSHING ROD
78	07-01-2026	Part of : CHHATARPUR ENCLAVE	581	Other Outage	Planned Outage	07-01-2026	12:41	07-01-2026	16:04	3:23	0.000000	REPLACEMENT OF HT BUSHING ROD
79	07-01-2026	Part of : AYA NAGAR VILLAGE	1455	Other Outage	Planned Outage	07-01-2026	11:31	07-01-2026	15:34	4:03	0.000945	3PH DB REVAMPING,JUMPER REPLACEMENT PER POLE
80	07-01-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE	820	Other Outage	Planned Outage	07-01-2026	10:35	07-01-2026	14:10	3:35	0.000000	REPLACEMENT OF HT BUSHING ROD
81	07-01-2026	Part of : MANDI VILLAGE	42	Other Outage	Planned Outage	07-01-2026	10:59	07-01-2026	15:00	4:01	0.000000	PRC REPLACEMENT
82	08-01-2026	Part of : SULTANPUR	1064	Other Outage	Planned Outage	08-01-2026	11:08	08-01-2026	11:47	0:39	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,REPLACEMET OF LUGS,SUB STATION CLEANING
83	08-01-2026	Part of : AYA NAGAR VILLAGE	1455	Other Outage	Planned Outage	08-01-2026	11:03	08-01-2026	14:57	3:54	0.000910	1PH DB REPLACEMENT,3PH DB REVAMPING,LT AB SAGGING PER SPAN
84	08-01-2026	Part of : BLOCK C CHHATARPUR EXTENSION	331	Other Outage	Planned Outage	08-01-2026	10:42	08-01-2026	14:09	3:27	0.000000	REPLACEMET OF HT BUSHING ROD
85	08-01-2026	Part of : SULTANPUR	1251	Other Outage	Planned Outage	08-01-2026	11:07	08-01-2026	14:56	3:49	0.000000	3PH DB REPLACEMENT,PRC REPLACEMET PER FEEDER
86	09-01-2026	Part of : CHHATARPUR ENCLAVE CHHATARPUR,PHASE 2 CHHATARPUR ENCLAVE CHHATARPUR,RAJPUR KHURD VILLAGE CHHATARPUR,PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR,MITTAL GARDEN SAINIK FARM	5924	Other Outage	Unplanned Outage	09-01-2026	09:07	09-01-2026	09:43	0:36	0.000000	CABLE FAULT
87	09-01-2026	Part of : CHHATARPUR ENCLAVE CHHATARPUR,PHASE 2 CHHATARPUR ENCLAVE CHHATARPUR,RAJPUR KHURD VILLAGE CHHATARPUR,PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR,MITTAL GARDEN SAINIK FARM	5924	Other Outage	Unplanned Outage	09-01-2026	07:53	09-01-2026	08:46	0:53	0.000000	HT SYSTEM FAULT
88	09-01-2026	Part of : DERA VILLAGE,NEW GAWALPAHARI VILLAGE,MANDI VILLAGE,GAWALPAHARI VILLAGE,AMBEDKAR COLONY MANDI	2269	Other Outage	Planned Outage	09-01-2026	11:10	09-01-2026	13:15	2:05	0.000347	MAINTENANCE OF TRANSFORMER
89	09-01-2026	Part of : AYA NAGAR VILLAGE AYA NAGAR,	1273	Other Outage	Planned Outage	09-01-2026	11:09	09-01-2026	14:36	3:27	0.000000	MAINTENANCE OF LT CIRCUIT
90	10-01-2026	PART OF : GADPUR FARM DLF FARMS	36	Other Outage	Planned Outage	10-01-2026	13:28	10-01-2026	13:54	0:26	0.000000	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER
91	10-01-2026	PART OF : DR AMBEDKAR COLONY CHHATARPUR,RAJPUR KHURD VILLAGE CHHATARPUR,PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR	642	Other Outage	Planned Outage	10-01-2026	15:17	10-01-2026	16:37	1:20	0.000222	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
92	10-01-2026	PART OF : DLF FARMS,BLOCK C CHHATARPUR EXTENSION	648	Other Outage	Planned Outage	10-01-2026	11:01	10-01-2026	14:24	3:23	0.000564	REPLACEMENT OF GAS KIT AND OIL SEAL
93	10-01-2026	PART OF : RAJPUR KHURD EXTENSION CHHATARPUR	174	Other Outage	Planned Outage	10-01-2026	10:40	10-01-2026	14:25	3:45	0.000000	REPLACEMENT OF HT BUSHING ROD
94	10-01-2026	PART OF : AYA NAGAR VILLAGE AYA NAGAR	1273	Other Outage	Planned Outage	10-01-2026	11:04	10-01-2026	15:47	4:43	0.000000	3PH DB REVAMPING,LT AB SAGGING PER SPAN
95	12-01-2026	Part of : DLF FARMS,BLOCK C CHHATARPUR EXTENSION	430	Other Outage	Unplanned Outage	12-01-2026	04:44	12-01-2026	05:18	0:34	0.000000	HT SYSTEM FAULT
96	12-01-2026	Part of : DLF FARMS,BLOCK C CHHATARPUR EXTENSION	430	Other Outage	Unplanned Outage	12-01-2026	03:25	12-01-2026	04:09	0:44	0.001076	HT SYSTEM FAULT
97	12-01-2026	Part of : ASOLA	201	Other Outage	Planned Outage	12-01-2026	13:32	12-01-2026	15:15	1:43	0.000000	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
98	12-01-2026	Part of : CHHATARPUR	501	Other Outage	Planned Outage	12-01-2026	13:29	12-01-2026	16:12	2:43	0.000453	REPLACEMET OF HT BUSHING ROD
99	12-01-2026	Part of : BLOCK C CHHATARPUR EXTENSION	386	Other Outage	Planned Outage	12-01-2026	12:14	12-01-2026	15:18	3:04	0.000000	REPLACEMET OF HT BUSHING ROD
100	12-01-2026	Part of : SULTANPUR	1230	Other Outage	Planned Outage	12-01-2026	11:02	12-01-2026	14:48	3:46	0.000000	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE
101	13-01-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	3934	Other Outage	Planned Outage	13-01-2026	15:14	13-01-2026	16:11	0:57	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
102	13-01-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	1467	Other Outage	Planned Outage	13-01-2026	13:48	13-01-2026	15:14	1:26	0.000239	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
103	13-01-2026	Part of : SULTANPUR,JAUNAPUR VILLAGE JAUNAPUR,RADHEY MOHAN DRIVE,DLF FARMS,GADAIPUR JAUNAPUR	70	Other Outage	Planned Outage	13-01-2026	10:50	13-01-2026	15:23	4:33	0.000758	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
104	13-01-2026	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR	1262	Other Outage	Planned Outage	13-01-2026	11:31	13-01-2026	16:09	4:38	0.001081	3PH DB REVAMPING
105	13-01-2026	Part of : CHANDAN HOLA	68	Other Outage	Planned Outage	13-01-2026	11:31	13-01-2026	14:22	2:51	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING
106	14-01-2026	Part of : SAT BARI	79	Other Outage	Planned Outage	14-01-2026	12:55	14-01-2026	13:09	0:14	0.000000	JUMPER REPLACEMENT & GUARD WIRES SAGGING PER SPAN
107	14-01-2026	Part of : CHHATARPUR ENCLAVE CHHATARPUR	591	Other Outage	Planned Outage	14-01-2026	13:31	14-01-2026	17:01	3:30	0.002917	LT CIRCUIT END BOX INSTALLATION
108	15-01-2026	Part of : HARGOVIND ENCLAVE	0	Other Outage	Unplanned Outage	15-01-2026	02:31	15-01-2026	03:30	0:59	0.000369	CABLE FAULT
109	15-01-2026	Part of : DR AMBEDKAR COLONY CHHATARPUR	176	Other Outage	Planned Outage	15-01-2026	13:49	15-01-2026	16:34	2:45	0.001146	REPLACEMET OF HT BUSHING ROD
110	15-01-2026	Part of : ASOLA	175	Other Outage	Planned Outage	15-01-2026	13:39	15-01-2026	15:52	2:13	0.000000	CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET
111	15-01-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE	835	Other Outage	Planned Outage	15-01-2026	11:24	15-01-2026	13:26	2:02	0.000000	REPLACEMET OF HT BUSHING ROD
112	15-01-2026	Part of : AYA NAGAR VILLAGE	223	Other Outage	Planned Outage	15-01-2026	13:39	15-01-2026	15:59	2:20	0.000000	LT CIRCUIT MAINTENANCE
113	15-01-2026	Part of : SULTANPUR	204	Other Outage	Planned Outage	15-01-2026	11:39	15-01-2026	15:58	4:19	0.000000	LT CIRCUIT MAINTENANCE
114	16-01-2026	Part of : ASOLA,ASOLA WILD LIFE SANCTUARY	1645	Other Outage	Unplanned Outage	16-01-2026	15:55	16-01-2026	16:38	0:43	0.000615	BIRDAGE
115	16-01-2026	Part of : RADHEY MOHAN DRIVE	13	Other Outage	Planned Outage	16-01-2026	13:35	16-01-2026	14:56	1:21	0.000000	CONDUCTOR REPLACEMET PER SPAN,GUARD WIRE LACS INSTALLTION PER SPAN
116	16-01-2026	Part of : POCKET B KATWARIA SARAI	1489	Other Outage	Planned Outage	16-01-2026	11:23	16-01-2026	13:40	2:17	0.000381	OIL TOP UP IN TRANSFORMER,TIGHTENEING OF NUT BOLT
117	16-01-2026	Part of : BALAJI ESTATE KALKAJI	748	Other Outage	Planned Outage	16-01-2026	10:21	16-01-2026	14:06	3:45	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
118	17-01-2026	Part of : DERA VILLAGE	48	Other Outage	Planned Outage	17-01-2026	12:16	17-01-2026	13:46	1:30	0.000000	MAINTENANCE OF LT CIRCUIT
119	17-01-2026	Part of : BHATI KALAN	396	Other Outage	Planned Outage	17-01-2026	14:01	17-01-2026	17:49	3:48	0.000000	MAINTENANCE OF HT O/H CIRCUIT
120	17-01-2026	Part of : C BLOCK CHHATARPUR EXTENSION CHHATARPUR	165	Other Outage	Planned Outage	17-01-2026	13:28	17-01-2026	16:30	3:02	0.000000	MAINTENANCE OF TRANSFORMER
121	17-01-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	3944	Other Outage	Planned Outage	17-01-2026	12:26	17-01-2026	16:38	4:12	0.000700	MAINTENANCE OF HT O/H CIRCUIT
122	17-01-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	81	Other Outage	Planned Outage	17-01-2026	10:48	17-01-2026	13:31	2:43	0.000000	MAINTENANCE OF TRANSFORMER
123	18-01-2026	Part of : AVLON HOTEL SULTANPUR (HTC), SULTANPUR VILLAGE	818	Other Outage	Unplanned Outage	18-01-2026	11:22	18-01-2026	11:50	0:28	0.000398	HT SYSTEM FAULT
124	19-01-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE	668	Other Outage	Planned Outage	19-01-2026	15:38	19-01-2026	16:41	1:03	0.000000	REPLACEMET OF HT/LT CLEATS
125	19-01-2026	Part of : PHASE 1 CHHATARPUR ENCLAVE	1001	Other Outage	Planned Outage	19-01-2026	15:01	19-01-2026	16:40	1:39	0.000000	REPLACEMET OF HT/LT CLEATS
126	19-01-2026	Part of : SULTANPUR	392	Other Outage	Planned Outage	19-01-2026	13:05	19-01-2026	14:26	1:21	0.000675	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD
127	19-01-2026	Part of : FATEHPUR BERI	82	Other Outage	Planned Outage	19-01-2026	12:29	19-01-2026	14:19	1:50	0.000000	CONDUCTOR REPLACEMET PER SPAN,HT SLEEVE INSTALLATION,JUMPER REPLACEMENT PER POLE
128	19-01-2026	Part of : DR AMBEDKAR COLONY CHHATARPUR	494	Other Outage	Planned Outage	19-01-2026	13:48	19-01-2026	16:40	2:52	0.000000	REPLACEMET OF HT BUSHING ROD
129	19-01-2026	Part of : CHHATARPUR	501	Other Outage	Planned Outage	19-01-2026	14:05	19-01-2026	16:39	2:34	0.000428	REPLACEMET OF HT BUSHING ROD
130	19-01-2026	Part of : MITTAL GARDEN SAINIK FARM,DR AMBEDKAR COLONY CHHATARPUR	211	Other Outage	Planned Outage	19-01-2026	10:27	19-01-2026	15:00	4:33	0.000000	3PH HT AB END TERMINATION REPLACEMENT
131	19-01-2026	Part of : MANDI VILLAGE	788	Other Outage	Planned Outage	19-01-2026	11:09	19-01-2026	12:40	1:31	0.000000	LT CIRCUIT MAINTENANCE WORK
132	20-01-2026	Part of : MAIDAN GARHI VILLAGE CHHATARPUR, ANSAL VILLAS SAT BARI, ASOLA WILD LIFE SANCTUARY ASOLA, RAJPUR KHURD EXTENSION	344	Other Outage	Unplanned Outage	20-01-2026	13:52	20-01-2026	15:04	1:12	0.000876	CABLE FAULT
133	20-01-2026	Part of : DERA VILLAGE	572	Other Outage	Planned Outage	20-01-2026	11:02	20-01-2026	12:24	1:22	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,TIGHTENEING OF NUT BOLT
134	20-01-2026	Part of : POCKET A & B DR AMBEDKAR COLONY,DR AMBEDKAR COLONY CHHATARPUR	1038	Other Outage	Planned Outage	20-01-2026	10:39	20-01-2026	14:49	4:10	0.000000	GUARD WIRES SAGGING PER SPAN
135	20-01-2026	Part of : AMBEDKAR COLONY MANDI,MANDI VILLAGE,SULTANPUR	3835	Other Outage	Planned Outage	20-01-2026	10:34	20-01-2026	15:37	5:03	0.001683	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
136	21-01-2026	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR,GADPUR FARM DLF FARMS	1076	Other Outage	Unplanned Outage	21-01-2026	19:29	21-01-2026	20:10	0:41	0.000000	CABLE FAULT
137	21-01-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR,	341	Other Outage	Planned Outage	21-01-2026	11:21	21-01-2026	12:31	1:10	0.000000	TRANSFORMER MAINTENANCE
138	21-01-2026	Part of : JAUNAPUR VILLAGE JAUNAPUR,	601	Other Outage	Planned Outage	21-01-2026	10:31	21-01-2026	14:07	3:36	0.000000	LT CIRCUIT MAINTENANCE
139	21-01-2026	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION AYA NAGAR,	1484	Other Outage	Planned Outage	21-01-2026	10:36	21-01-2026	16:40	6:04	0.001416	HT CIRCUIT MAINTENANCE
140	22-01-2026	Part of : CHHATARPUR	29	Other Outage	Unplanned Outage	22-01-2026	16:28	22-01-2026	17:21	0:53	0.000000	BIRDAGE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
141	22-01-2026	Part of : MANGLAPURI VILLAGE SULTANPUR,SULTANPUR,ARJUN GARH AYA NAGAR,AYA NAGAR PHASE 1 AYA NAGAR	639	Other Outage	Unplanned Outage	22-01-2026	14:31	22-01-2026	15:26	0:55	0.000458	CONNECTION OF HT/LT CABLES
142	22-01-2026	Part of : BHATI KALAN	610	Other Outage	Planned Outage	22-01-2026	12:53	22-01-2026	13:46	0:53	0.000000	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING,GUARD WIRE LACS INSTALLTION PER SPAN
143	22-01-2026	Part of : SULTANPUR	80	Other Outage	Planned Outage	22-01-2026	11:03	22-01-2026	13:00	1:57	0.000325	3PH DB REVAMPING,JUMPER REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER
144	22-01-2026	Part of : DLF FARMS	6	Other Outage	Planned Outage	22-01-2026	10:43	22-01-2026	14:24	3:41	0.000000	REPLACEMENT OF FAULTY END BOX
145	22-01-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	685	Other Outage	Planned Outage	22-01-2026	10:32	22-01-2026	14:27	3:55	0.000000	HT SLEEVE INSTALLATION PER SPAN,JUMPER REPLACEMENT PER POLE
146	22-01-2026	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR	1262	Other Outage	Planned Outage	22-01-2026	11:31	22-01-2026	12:58	1:27	0.000000	JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
147	22-01-2026	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR	1306	Other Outage	Planned Outage	22-01-2026	10:50	22-01-2026	15:03	4:13	0.000000	1PH DB REPLACEMENT,3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
148	23-01-2026	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION	1488	Other Outage	Planned Outage	23-01-2026	14:54	23-01-2026	15:42	0:48	0.000187	3PH DB REVAMPING,LT AB SAGGING
149	24-01-2026	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION	1488	Other Outage	Planned Outage	24-01-2026	12:18	24-01-2026	13:54	1:36	0.000373	3PH DB REVAMPING,LT AB SAGGING PER SPAN
150	24-01-2026	Part of : DERA VILLAGE,NEW GAWALPAHARI VILLAGE,MANDI VILLAGE	2269	Other Outage	Planned Outage	24-01-2026	11:08	24-01-2026	12:53	1:45	0.000583	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
151	24-01-2026	Part of : DERA VILLAGE,BHATI KALAN,NEW GAWALPAHARI VILLAGE	3032	Other Outage	Planned Outage	24-01-2026	11:56	24-01-2026	14:54	2:58	0.000000	REPLACEMET OF LUGS,SUB STATION CLEANING
152	24-01-2026	Part of : PHASE-V AYA NAGAR EXTENSION	183	Other Outage	Planned Outage	24-01-2026	11:07	24-01-2026	15:53	4:46	0.000000	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE
153	27-01-2026	Part of : CHHATARPUR	765	Other Outage	Planned Outage	27-01-2026	15:14	27-01-2026	15:38	0:24	0.000067	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
154	27-01-2026	Part of : SULTANPUR	1251	Other Outage	Planned Outage	27-01-2026	13:22	27-01-2026	13:40	0:18	0.000000	LT CIRCUIT MAINTENANCE
155	27-01-2026	Part of : BLOCK C CHHATARPUR EXTENSION,DLF FARMS CHHATARPUR	648	Other Outage	Planned Outage	27-01-2026	14:22	27-01-2026	15:55	1:33	0.000258	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
156	27-01-2026	Part of : MANGLAPURI VILLAGE,SULTANPUR,ARJUN GARH,AYA NAGAR PHASE 1	113	Other Outage	Planned Outage	27-01-2026	13:53	27-01-2026	15:36	1:43	0.000286	REPLACEMET OF HT BUSHING ROD
157	27-01-2026	Part of : BLOCK C CHHATARPUR EXTENSION,BLOCK A1 CHHATARPUR VILLAGE,ANSAL VILLAS SAT BARI,RAJPUR KHURD VILLAGE	908	Other Outage	Planned Outage	27-01-2026	11:04	27-01-2026	13:03	1:59	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
158	27-01-2026	Part of : BLOCK G AYA NAGAR EXTENSION	1306	Other Outage	Planned Outage	27-01-2026	13:25	27-01-2026	15:35	2:10	0.000000	LT CIRCUIT MAINTENANCE
159	28-01-2026	Part of : MAIDAN GARHI VILLAGE, ANSAL VILLAS SAT BARI, ASOLA WILD LIFE SANCTUARY, RAJPUR KHURD EXTENSION	343	Other Outage	Unplanned Outage	28-01-2026	03:52	28-01-2026	04:12	0:20	0.000254	CABLE FAULT
160	28-01-2026	Part of : AYA NAGAR VILLAGE	3569	Other Outage	Unplanned Outage	28-01-2026	14:30	28-01-2026	15:38	1:08	0.000000	SHIFTING OF CABLE
161	28-01-2026	Part of : BHATI KALAN	612	Other Outage	Planned Outage	28-01-2026	12:25	28-01-2026	13:41	1:16	0.000000	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
162	28-01-2026	Part of : BLOCK D CHHATARPUR VILLAGE,BLOCK C CHHATARPUR EXTENSION	4632	Other Outage	Planned Outage	28-01-2026	10:57	28-01-2026	14:02	3:05	0.000000	REPLACEMET OF HT BUSHING ROD
163	28-01-2026	Part of : BLOCK G AYA NAGAR EXTENSION	1306	Other Outage	Planned Outage	28-01-2026	11:23	28-01-2026	16:10	4:47	0.000000	JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
164	29-01-2026	Part of : FATEHPUR BERI,	472	Other Outage	Planned Outage	29-01-2026	12:09	29-01-2026	17:35	5:26	0.000181	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
165	29-01-2026	Part of : SULTANPUR,	51	Other Outage	Planned Outage	29-01-2026	11:15	29-01-2026	13:27	2:12	0.000000	3PH DB REVAMPING,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
166	29-01-2026	Part of : BLOCK E AYA NAGAR EXTENSION AYA NAGAR,	6	Other Outage	Planned Outage	29-01-2026	11:14	29-01-2026	15:13	3:59	0.000929	3PH DB REVAMPING,LT AB SAGGING PER SPAN
167	30-01-2026	Part of : CHANDAN HOLA,FATEHPUR BERI,ANSAL VILLAS SAT BARI,ASOLA	1806	Other Outage	Unplanned Outage	30-01-2026	15:22	30-01-2026	16:49	1:27	0.000638	CABLE FAULT
168	30-01-2026	Part of : SULTANPUR	392	Other Outage	Planned Outage	30-01-2026	13:13	30-01-2026	13:34	0:21	0.000175	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
169	30-01-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE CHHATARPUR,ANSAL VILLAS SAT BARI	1574	Other Outage	Planned Outage	30-01-2026	14:01	30-01-2026	16:10	2:09	0.000000	GUARD WIRES SAGGING PER SPAN
170	30-01-2026	Part of : DLF FARMS,SULTANPUR,CHHATARPUR	160	Other Outage	Planned Outage	30-01-2026	12:10	30-01-2026	15:43	3:33	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
171	30-01-2026	Part of : SULTANPUR	356	Other Outage	Planned Outage	30-01-2026	13:34	30-01-2026	15:59	2:25	0.000403	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
172	30-01-2026	Part of : RADHEY MOHAN DRIVE,JAUNAPUR VILLAGE JAUNAPUR,DLF FARMS,FATEHPUR BERI,CHANDAN HOLA,ANSAL VILLAS SAT BARI	812	Other Outage	Planned Outage	30-01-2026	11:08	30-01-2026	13:12	2:04	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,SUB STATION CLEANING
173	30-01-2026	Part of : SULTANPUR,JAUNAPUR VILLAGE JAUNAPUR,RADHEY MOHAN DRIVE,DLF FARMS,GADAIPUR JAUNAPUR	70	Other Outage	Planned Outage	30-01-2026	10:39	30-01-2026	15:23	4:44	0.000789	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
174	30-01-2026	Part of : BLOCK E AYA NAGAR EXTENSION AYA NAGAR	6	Other Outage	Planned Outage	30-01-2026	12:15	30-01-2026	15:13	2:58	0.000000	1PH DB REVAMPING,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
175	31-01-2026	Part of : ASOLA	434	Other Outage	Unplanned Outage	31-01-2026	16:46	31-01-2026	17:37	0:51	0.000528	CABLE DAMAGE BY OUTSIDE AGENCY (PWD)
176	31-01-2026	Part of : G-BLOCK AYA NAGAR EXTENSION	585	Other Outage	Planned Outage	31-01-2026	13:32	31-01-2026	14:11	0:39	0.000000	LT CIRCUIT MAINTENANCE
177	01-01-2026	Part of : BLOCK D SOUTH EXTENSION II	406	Other Outage	Unplanned Outage	01-01-2026	03:04	01-01-2026	03:59	0:55	0.000000	HT SYSTEM FAULT
178	02-01-2026	Part of : SHAHPUR JAT VILLAGE SIRI FORT	498	Other Outage	Planned Outage	02-01-2026	12:30	02-01-2026	15:16	2:46	0.000922	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
179	02-01-2026	Part of : BLOCK B QUTAB INSTITUTIONAL AREA	105	Other Outage	Planned Outage	02-01-2026	11:59	02-01-2026	14:31	2:32	0.000211	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
180	03-01-2026	Part of : BHARTI SCHOOL	1	Other Outage	Planned Outage	03-01-2026	12:49	03-01-2026	13:20	0:31	0.000060	CLEANING OF HT BUSHING PER WAY,PROOPER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
181	03-01-2026	Part of : AYUR VIGYAN NAGAR SADIQ NAGAR	79	Other Outage	Planned Outage	03-01-2026	14:26	03-01-2026	15:49	1:23	0.000231	CHECKING OF EARTHING VALUE USING ONLINE TESTER
182	03-01-2026	Part of : SIRIFORT SPORTS COMPLEX	1	Other Outage	Planned Outage	03-01-2026	11:52	03-01-2026	14:20	2:28	0.000206	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
183	03-01-2026	Part of : SECTOR 1 SADIQ NAGAR	936	Other Outage	Planned Outage	03-01-2026	11:00	03-01-2026	13:21	2:21	0.000901	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER
184	04-01-2026	Part of : BLOCK C QUTAB INSTITUTIONAL AREA	2	Other Outage	Planned Outage	04-01-2026	10:43	04-01-2026	11:14	0:31	0.000026	CONDUCTOR REPLACEMENT PER SPAN,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
185	05-01-2026	Part of : BLOCK A HAUZ KHAS,	295	Other Outage	Planned Outage	05-01-2026	14:44	05-01-2026	17:08	2:24	0.000000	MAINTENANCE OF LT CIRCUIT
186	05-01-2026	Part of : BLOCK B 7 ARJUN NAGAR SAFDARJUNG ENCLAVE,	828	Other Outage	Planned Outage	05-01-2026	11:09	05-01-2026	13:45	2:36	0.000650	MAINTENANCE OF TRANSFORMER
187	05-01-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE,	1402	Other Outage	Planned Outage	05-01-2026	11:29	05-01-2026	13:46	2:17	0.000571	MAINTENANCE OF LT CIRCUIT
188	05-01-2026	Part of : GAUTAM NAGAR,	418	Other Outage	Planned Outage	05-01-2026	11:15	05-01-2026	15:07	3:52	0.000644	MAINTENANCE OF TRANSFORMER
189	06-01-2026	Part of : HAZOORI LAL N SONS PVT.LTD. D-6 (HTC) ,NDSE	1	Other Outage	Planned Outage	06-01-2026	12:14	06-01-2026	13:41	1:27	0.000121	CHECKING OF EARTHING VALUE USING ONLINE TESTER
190	06-01-2026	Part of : SHAHPUR JAT VILLAGE SIRI FORT	412	Other Outage	Planned Outage	06-01-2026	12:00	06-01-2026	13:01	1:01	0.000119	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
191	07-01-2026	Part of : ASIAN GAMES VILLAGE COMPLEX SIRI FORT	472	Other Outage	Unplanned Outage	07-01-2026	14:39	07-01-2026	15:15	0:36	0.000000	CABLE FAULT
192	07-01-2026	Part of : SHAHPUR JAT VILLAGE SIRI FORT	521	Other Outage	Planned Outage	07-01-2026	11:18	07-01-2026	14:43	3:25	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
193	07-01-2026	Part of : BLOCK F GREEN PARK	183	Other Outage	Planned Outage	07-01-2026	11:06	07-01-2026	13:08	2:02	0.000407	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
194	08-01-2026	Part of : BLOCK L GREEN PARK	287	Other Outage	Planned Outage	08-01-2026	15:44	08-01-2026	17:25	1:41	0.000281	REPLACEMET OF FAULTY END BOX,SF6 GAS FILLING
195	08-01-2026	Part of : BLOCK D SOAMI NAGAR SOUTH SOAMI NAGAR	338	Other Outage	Planned Outage	08-01-2026	13:32	08-01-2026	14:36	1:04	0.000053	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,TIGHTENEING OF NUT BOLT
196	09-01-2026	Part of : SHAHPUR JAT VILLAGE SIRI FORT,	734	Other Outage	Planned Outage	09-01-2026	14:23	09-01-2026	16:27	2:04	0.000000	MAINTENANCE OF LT CIRCUIT
197	09-01-2026	Part of : POCKET B KATWARIA SARAI,	674	Other Outage	Planned Outage	09-01-2026	13:03	09-01-2026	16:26	3:23	0.000000	MAINTENANCE OF TRANSFORMER
198	09-01-2026	Part of : BLOCK Q GREEN PARK EXTENSION GREEN PARK,	402	Other Outage	Planned Outage	09-01-2026	11:08	09-01-2026	13:15	2:07	0.000353	MAINTENANCE OF TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
199	09-01-2026	Part of : BLOCK S PANCHSHILA PARK SOUTH PANCHSHILA PARK,	185	Other Outage	Planned Outage	09-01-2026	11:04	09-01-2026	14:01	2:57	0.000000	MAINTENANCE OF TRANSFORMER
200	09-01-2026	Part of : GAUTAM NAGAR,	418	Other Outage	Planned Outage	09-01-2026	11:38	09-01-2026	15:35	3:57	0.000527	MAINTENANCE OF LT CIRCUIT
201	10-01-2026	Part of : BLOCK A GREEN PARK EXTENSION GREEN PARK,BLOCK F GREEN PARK,BLOCK A GREEN PARK,YUSUF SARAI,INSTITUTIONAL AREA HAUZ KHAS	1349	Other Outage	Unplanned Outage	10-01-2026	01:04	10-01-2026	01:47	0:43	0.000155	CABLE FAULT
202	10-01-2026	PART OF : ASIAN GAMES VILLAGE COMPLEX SIRI FORT	206	Other Outage	Planned Outage	10-01-2026	11:13	10-01-2026	13:44	2:31	0.000461	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
203	10-01-2026	PART OF : GAUTAM NAGAR	318	Other Outage	Planned Outage	10-01-2026	11:02	10-01-2026	14:17	3:15	0.000433	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
204	11-01-2026	Part of : A,F & L-BLOCK GREEN PARK	1173	Other Outage	Unplanned Outage	11-01-2026	15:50	11-01-2026	16:18	0:28	0.000622	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
205	12-01-2026	Part of : LAL GUMBAD BASTI SADHNA ENCLAVE PANCHSHILA PARK	479	Other Outage	Planned Outage	12-01-2026	14:20	12-01-2026	15:22	1:02	0.000052	RELAY REPLACEMET/VPI/FPI
206	12-01-2026	Part of : BLOCK Q GREEN PARK EXTENSION	292	Other Outage	Planned Outage	12-01-2026	11:15	12-01-2026	13:47	2:32	0.000844	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
207	13-01-2026	Part of : *(HKS288)HTC NT FOR HANDI CAPPED 9-S.J.S. MA*	1	Other Outage	Planned Outage	13-01-2026	11:33	13-01-2026	13:23	1:50	0.000153	CLEANING OF HT BUSHING PER WAY,PROOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
208	13-01-2026	Part of : BLOCK E HAUZ KHAS	346	Other Outage	Planned Outage	13-01-2026	10:57	13-01-2026	12:01	1:04	0.000142	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
209	13-01-2026	Part of : BLOCK B 7 ARJUN NAGAR SAFDARJUNG ENCLAVE	649	Other Outage	Planned Outage	13-01-2026	11:15	13-01-2026	15:11	3:56	0.001311	DT REPLACEMENT
210	13-01-2026	Part of : GAUTAM NAGAR	418	Other Outage	Planned Outage	13-01-2026	08:46	13-01-2026	13:26	4:40	0.000544	LT AB SAGGING PER SPAN
211	14-01-2026	Part of : A 1 BLOCK NAUROJI NAGAR SAFDARJUNG ENCLAVE	834	Other Outage	Unplanned Outage	14-01-2026	14:51	14-01-2026	15:24	0:33	0.000550	CABLE FAULT
212	14-01-2026	Part of : HTC:IIFT	1	Other Outage	Planned Outage	14-01-2026	12:37	14-01-2026	13:18	0:41	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
213	14-01-2026	Part of : HTC:KARAMPA INTERNATIONAL, B19 & 20, QIA	1	Other Outage	Planned Outage	14-01-2026	13:17	14-01-2026	14:01	0:44	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
214	14-01-2026	Part of : B 7 BLOCK ARJUN NAGAR SAFDARJUNG ENCLAVE	176	Other Outage	Planned Outage	14-01-2026	11:06	14-01-2026	13:42	2:36	0.000650	REPLACEMENT OF GAS KIT AND OIL SEAL
215	14-01-2026	Part of : S BLOCK PANCHSHILA PARK SOUTH	185	Other Outage	Planned Outage	14-01-2026	11:23	14-01-2026	13:59	2:36	0.000433	REPLACEMENT OF HT/LT CLEATS & OIL TOP UP IN TRANSFORMER
216	15-01-2026	Part of : GAUTAM NAGAR	1236	Other Outage	Planned Outage	15-01-2026	11:09	15-01-2026	14:25	3:16	0.001960	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
217	15-01-2026	Part of : BLOCK F POLICE COLONY HAUZ KHAS	115	Other Outage	Planned Outage	15-01-2026	11:15	15-01-2026	14:40	3:25	0.000285	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
218	16-01-2026	Part of : IIT (HT CONSUMER)	1	Other Outage	Unplanned Outage	16-01-2026	15:27	16-01-2026	16:13	0:46	0.000754	FAULT IN HT CONSUMER PANEL (IIT)
219	16-01-2026	Part of : RANGPURI PAHARI	394	Other Outage	Planned Outage	16-01-2026	11:47	16-01-2026	12:18	0:31	0.000026	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
220	16-01-2026	Part of : RAJ NAGAR MADANPUR KHADAR	295	Other Outage	Planned Outage	16-01-2026	10:59	16-01-2026	12:17	1:18	0.000152	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
221	16-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	1318	Other Outage	Planned Outage	16-01-2026	11:49	16-01-2026	16:09	4:20	0.000361	REPLACEMENT OF GAS KIT AND OIL SEAL
222	17-01-2026	Part of : Y BLOCK HAUZ KHAS	122	Other Outage	Planned Outage	17-01-2026	12:53	17-01-2026	14:29	1:36	0.000453	MAINTENANCE OF TRANSFORMER
223	17-01-2026	Part of : ANAND LOK SADIQ NAGAR	532	Other Outage	Planned Outage	17-01-2026	11:07	17-01-2026	14:16	3:09	0.001575	MAINTENANCE OF TRANSFORMER
224	17-01-2026	Part of : HTC:PANCHSHEEL CLUB OPP PANCHSHEELFLYOVER	1	Other Outage	Planned Outage	17-01-2026	11:07	17-01-2026	14:16	3:09	0.000158	MAINTENANCE OF RMU
225	17-01-2026	Part of : PANCHSHILA PARK NORTH PANCHSHILA PARK	204	Other Outage	Planned Outage	17-01-2026	12:50	17-01-2026	16:48	3:58	0.000198	MAINTENANCE OF LT CIRCUIT
226	18-01-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE, B-5 S.D.A, EYE HOSPITAL (HTC)	1889	Other Outage	Unplanned Outage	18-01-2026	04:01	18-01-2026	05:00	0:59	0.001169	CABLE FAULT
227	18-01-2026	Part of : GULMOHAR PARK, HAUZ KHAS	332	Other Outage	Unplanned Outage	18-01-2026	02:57	18-01-2026	03:55	0:58	0.000322	CABLE FAULT
228	19-01-2026	Part of : A 1-BLOCK NAUROJI NAGAR SAFDARJUNG ENCLAVE	834	Other Outage	Unplanned Outage	19-01-2026	18:01	19-01-2026	18:40	0:39	0.000715	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
229	19-01-2026	Part of : PANCHSHILA PARK NORTH	399	Other Outage	Planned Outage	19-01-2026	11:35	19-01-2026	13:01	1:26	0.000167	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
230	20-01-2026	Part of : LAL GUMBAD BASTI SADHNA ENCLAVE PANCHSHILA PARK	314	Other Outage	Planned Outage	20-01-2026	11:47	20-01-2026	12:06	0:19	0.000016	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
231	20-01-2026	Part of : ASIAN GAMES VILLAGE COMPLEX SIRI FORT	158	Other Outage	Planned Outage	20-01-2026	13:44	20-01-2026	14:21	0:37	0.000031	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
232	20-01-2026	Part of : SIRI FORT INSTITUTIONAL AREA SIRI FORT	19	Other Outage	Planned Outage	20-01-2026	11:22	20-01-2026	13:44	2:22	0.000197	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
233	21-01-2026	Part of : BLOCK C PANCHSHEEL ENCLAVE,	521	Other Outage	Planned Outage	21-01-2026	11:19	21-01-2026	13:28	2:09	0.000000	TRANSFORMER MAINTENANCE
234	22-01-2026	Part of : ASIAN GAMES VILLAGE COMPLEX SIRI FORT	471	Other Outage	Unplanned Outage	22-01-2026	00:11	22-01-2026	01:05	0:54	0.000720	CABLE FAULT
235	22-01-2026	Part of : BLOCK L GREEN PARK	176	Other Outage	Unplanned Outage	22-01-2026	13:05	22-01-2026	14:57	1:52	0.000000	REPAIRING OF DEFECTIVE MECHANISM
236	22-01-2026	Part of : ASIAN GAMES VILLAGE COMPLEX SIRI FORT	265	Other Outage	Planned Outage	22-01-2026	11:33	22-01-2026	15:02	3:29	0.000813	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
237	23-01-2026	Part of : DEER PARK HAUZ KHAS	126	Other Outage	Unplanned Outage	23-01-2026	23:43	24-01-2026	00:29	0:46	0.000616	FAULT IN HT CONSUMER PANEL (R.K.KHANNA STADIUM)
238	24-01-2026	Part of : BEER SARAI, JAWAHAR LAL NEHRU UNIVERSITY, IIT MINI CAMPUS	90	Other Outage	Unplanned Outage	24-01-2026	16:46	24-01-2026	17:31	0:45	0.001602	FAULT IN HT CONSUMER PANEL (IIT MINI CAMPUS)
239	24-01-2026	Part of : BLOCK A & B KATWARIA SARAI,POCKET B KATWARIA SARAI	4323	Other Outage	Planned Outage	24-01-2026	13:24	24-01-2026	13:48	0:24	0.000267	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
240	24-01-2026	Part of : GURUNANAK FOUNDATION	54	Other Outage	Planned Outage	24-01-2026	11:21	24-01-2026	12:26	1:05	0.000253	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
241	24-01-2026	Part of : BLOCK E SOUTH EXTENSION II	104	Other Outage	Planned Outage	24-01-2026	10:53	24-01-2026	13:45	2:52	0.000764	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
242	24-01-2026	Part of : PHD HOUSE HAUZ KHAS (HT CONSUMER)	1	Other Outage	Planned Outage	24-01-2026	11:34	24-01-2026	13:50	2:16	0.000113	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY
243	27-01-2026	Part of : GAUTAM NAGAR,SUDARSHAN CINEMA	1153	Other Outage	Unplanned Outage	27-01-2026	16:03	27-01-2026	16:45	0:42	0.000502	TREE TOUCHING
244	27-01-2026	Part of : BLOCK S PANCHSHILA PARK SOUTH	130	Other Outage	Planned Outage	27-01-2026	12:46	27-01-2026	14:23	1:37	0.000189	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
245	27-01-2026	Part of : SIRI FORT INSTITUTIONAL AREA	3	Other Outage	Planned Outage	27-01-2026	11:29	27-01-2026	12:47	1:18	0.000108	DT REPLACEMENT
246	27-01-2026	Part of : BLOCK B 6 HUMAYUNPUR SAFDARJUNG ENCLAVE	401	Other Outage	Planned Outage	27-01-2026	11:03	27-01-2026	12:21	1:18	0.000433	LT CIRCUIT MAINTENANCE
247	27-01-2026	Part of : BLOCK M SOUTH EXTENSION II	213	Other Outage	Planned Outage	27-01-2026	10:53	27-01-2026	13:49	2:56	0.000831	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
248	28-01-2026	Part of : BLOCK C GREEN PARK EXTENSION	503	Other Outage	Planned Outage	28-01-2026	11:11	28-01-2026	12:58	1:47	0.000297	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
249	28-01-2026	Part of : BLOCK E HAUZ KHAS	265	Other Outage	Planned Outage	28-01-2026	13:34	28-01-2026	16:54	3:20	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
250	29-01-2026	Part of : AYUR VIGYAN NAGAR SADIQ NAGAR,ANDREWS GANJ EXTENSION ANDREWS GANJ	274	Other Outage	Unplanned Outage	29-01-2026	22:12	29-01-2026	22:57	0:45	0.000000	CABLE FAULT
251	29-01-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE,	913	Other Outage	Unplanned Outage	29-01-2026	12:04	29-01-2026	13:56	1:52	0.000000	MOBILE TRANSFORMER REPLACEMENT
252	29-01-2026	Part of : BLOCK N PANCHSHILA PARK NORTH PANCHSHILA PARK,	62	Other Outage	Planned Outage	29-01-2026	12:09	29-01-2026	16:46	4:37	0.000616	DT REPLACEMENT
253	29-01-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE,	409	Other Outage	Planned Outage	29-01-2026	11:24	29-01-2026	14:06	2:42	0.000675	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
254	30-01-2026	Part of : IIT NO.3 (HTC)	2	Other Outage	Planned Outage	30-01-2026	14:09	30-01-2026	14:14	0:05	0.000004	BIRD SPIKES INSTALLATION PER POLE
255	30-01-2026	Part of : BHARTI SCHOOLL, IIT (HTC)	1	Other Outage	Planned Outage	30-01-2026	12:54	30-01-2026	14:17	1:23	0.000484	RELAY REPLACEMENT/VP/FP/PI
256	30-01-2026	Part of : BEER SARAI	61	Other Outage	Planned Outage	30-01-2026	11:42	30-01-2026	13:02	1:20	0.000267	TIGHTENEING OF NUT BOLT
257	30-01-2026	Part of : BLOCK B 7 ARJUN NAGAR SAFDARJUNG ENCLAVE	235	Other Outage	Planned Outage	30-01-2026	11:07	30-01-2026	13:14	2:07	0.000529	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
258	31-01-2026	Part of : SIRI FORT INSTITUTIONAL AREA	3	Other Outage	Planned Outage	31-01-2026	11:25	31-01-2026	12:12	0:47	0.000026	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
259	31-01-2026	Part of : DEER PARK HAUZ KHAS	124	Other Outage	Planned Outage	31-01-2026	11:03	31-01-2026	13:12	2:09	0.000358	LT CIRCUIT MAINTENANCE
260	01-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,BLOCK L DEVL I SANGAM VIHAR	2900	Other Outage	Unplanned Outage	01-01-2026	14:20	01-01-2026	14:44	0:24	0.000420	HVDS FAULT
261	01-01-2026	Part of : BLOCK B DEVL I SANGAM VIHAR,BLOCK L 2 DEVL I SANGAM VIHAR,DURGA VIHAR DEVL I SANGAM VIHAR	3864	Other Outage	Unplanned Outage	01-01-2026	15:37	01-01-2026	16:21	0:44	0.001772	HVDS FAULT
262	01-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,	3760	Other Outage	Planned Outage	01-01-2026	09:57	01-01-2026	14:19	4:22	0.000801	3PH HT AB CABLE REPLACEMENT PER SPAN
263	02-01-2026	Part of : GARRISON ENGG (HTC)	1	Other Outage	Planned Outage	02-01-2026	14:59	02-01-2026	15:54	0:55	0.000153	CONDUCTOR REPLACEMENT PER SPAN
264	02-01-2026	Part of : BLOCK B JJ COLONY KHANPUR	1471	Other Outage	Planned Outage	02-01-2026	11:32	02-01-2026	15:00	3:28	0.000636	REPLACEMENT OF LT BUSHING ROD
265	02-01-2026	Part of : BLOCK RZ H PULPEHLADPUR,BLOCK A PULPEHLADPUR	788	Other Outage	Planned Outage	02-01-2026	11:07	02-01-2026	14:17	3:10	0.000581	SUB STATION CLEANING
266	02-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	1096	Other Outage	Planned Outage	02-01-2026	09:56	02-01-2026	12:55	2:59	0.000547	3PH HT AB CABLE REPLACEMENT PER SPAN
267	03-01-2026	Part of : TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD	26	Other Outage	Unplanned Outage	03-01-2026	11:27	03-01-2026	12:01	0:34	0.000000	REPAIRING OF RMU
268	03-01-2026	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	903	Other Outage	Planned Outage	03-01-2026	12:15	03-01-2026	15:59	3:44	0.000684	DT REPLACEMENT
269	03-01-2026	Part of : BLOCK I 2 & J 2 BLOCK DEVL I SANGAM VIHAR	4109	Other Outage	Planned Outage	03-01-2026	10:58	03-01-2026	13:59	3:01	0.000553	3PH HT AB CABLE REPLACEMENT
270	03-01-2026	Part of : TUGHLAKABAD INSTITUTIONAL AREA	28	Other Outage	Planned Outage	03-01-2026	11:27	03-01-2026	14:07	2:40	0.000489	REPLACEMENT OF HT BUSHING ROD
271	03-01-2026	Part of : BLOCK A PULPEHLADPUR	23	Other Outage	Planned Outage	03-01-2026	11:03	03-01-2026	16:01	4:58	0.000911	REPLACEMENT OF HT BUSHING ROD
272	03-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	2511	Other Outage	Planned Outage	03-01-2026	11:39	03-01-2026	14:24	2:45	0.000504	3PH HT AB CABLE REPLACEMENT
273	05-01-2026	Part of : DDA PARK LAL KUAN,BLOCK A VISHWAKARMA COLONY PULPEHLADPUR,LAL KUAN,CHUNGI NO 2 KOTLA MAHINGIRAN LAL KUAN,BLOCK D VISHWAKARMA COLONY PULPEHLADPUR,BLOCK C VISHWAKARMA COLONY PULPEHLADPUR	4178	Other Outage	Unplanned Outage	05-01-2026	12:49	05-01-2026	13:35	0:46	0.000409	HT SYSTEM FAULT
274	05-01-2026	Part of : BLOCK 1 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,	2902	Other Outage	Planned Outage	05-01-2026	15:43	05-01-2026	16:01	0:18	0.000055	MAINTENANCE OF HT O/H CIRCUIT
275	05-01-2026	Part of : BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,	8	Other Outage	Planned Outage	05-01-2026	11:33	05-01-2026	12:11	0:38	0.000116	MAINTENANCE OF TRANSFORMER
276	05-01-2026	Part of : BLOCK G 1 TALIMABAD SANGAM VIHAR,	1602	Other Outage	Planned Outage	05-01-2026	11:02	05-01-2026	13:54	2:52	0.000526	MAINTENANCE OF HVDS CIRCUIT
277	05-01-2026	Part of : BLOCK 4 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,	3653	Other Outage	Planned Outage	05-01-2026	12:45	05-01-2026	15:34	2:49	0.000516	MAINTENANCE OF TRANSFORMER
278	05-01-2026	Part of : BLOCK 1 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,	2907	Other Outage	Planned Outage	05-01-2026	11:01	05-01-2026	15:23	4:22	0.000801	MAINTENANCE OF TRANSFORMER
279	05-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,	3760	Other Outage	Planned Outage	05-01-2026	11:03	05-01-2026	14:01	2:58	0.000544	MAINTENANCE OF HVDS CIRCUIT
280	06-01-2026	Part of : SHIV PARK DUGGAL COLONY KHANPUR,POCKET B DUGGAL COLONY KHANPUR,KHANPUR VILLAGE KHANPUR,JJ COLONY DUGGAL COLONY KHANPUR,BLOCK F KHANPUR COLONY KHANPUR	4689	Other Outage	Unplanned Outage	06-01-2026	10:11	06-01-2026	10:53	0:42	0.001202	CABLE FAULT
281	06-01-2026	Part of : BLOCK C PULPEHLADPUR,BLOCK R ZTO F PULPEHLADPUR,BLOCK A PULPEHLADPUR,BLOCK RZ H PULPEHLADPUR	6047	Other Outage	Unplanned Outage	06-01-2026	00:46	06-01-2026	01:24	0:38	0.000274	HVDS FAULT
282	06-01-2026	Part of : DURGA VIHAR DEVL I SANGAM VIHAR	948	Other Outage	Unplanned Outage	06-01-2026	14:11	06-01-2026	14:45	0:34	0.000000	REPAIRING OF RMU
283	06-01-2026	Part of : BLOCK R ZTO F PULPEHLADPUR,BLOCK C PULPEHLADPUR	2078	Other Outage	Planned Outage	06-01-2026	11:58	06-01-2026	15:03	3:05	0.000565	3PH HT AB CABLE REPLACEMENT PER SPAN
284	06-01-2026	Part of : KHANPUR VILLAGE KHANPUR	994	Other Outage	Planned Outage	06-01-2026	11:25	06-01-2026	14:54	3:29	0.000639	REPLACEMENT OF LT BUSHING ROD
285	06-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	3931	Other Outage	Planned Outage	06-01-2026	10:02	06-01-2026	14:40	4:38	0.000849	3PH HT AB CABLE REPLACEMENT PER SPAN
286	07-01-2026	Part of : POCKET C RAJU PARK SANGAM VIHAR	799	Other Outage	Planned Outage	07-01-2026	11:16	07-01-2026	13:45	2:29	0.000455	3PH HT AB CABLE REPLACEMENT
287	07-01-2026	Part of : BLOCK F 2 SANGAM VIHAR	1295	Other Outage	Planned Outage	07-01-2026	10:31	07-01-2026	14:21	3:50	0.000703	3PH HT AB CABLE REPLACEMENT
288	07-01-2026	Part of : BLOCK A VISHWAKARMA COLONY PULPEHLADPUR	1	Other Outage	Planned Outage	07-01-2026	11:08	07-01-2026	14:13	3:05	0.000565	3PH HT AB CABLE REPLACEMENT
289	07-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	2511	Other Outage	Planned Outage	07-01-2026	10:22	07-01-2026	14:04	3:42	0.000678	3PH HT AB CABLE REPLACEMENT
290	08-01-2026	Part of : BLOCK K SANGAM VIHAR,BLOCK G 2 SANGAM VIHAR,BLOCK I 1 SANGAM VIHAR	3633	Other Outage	Planned Outage	08-01-2026	10:59	08-01-2026	13:48	2:49	0.000516	3PH HT AB CABLE REPLACEMENT PER SPAN
291	08-01-2026	Part of : JAWAHAR PARK SANGAM VIHAR	101	Other Outage	Planned Outage	08-01-2026	10:58	08-01-2026	13:57	2:59	0.000547	3PH HT AB CABLE REPLACEMENT PER SPAN
292	08-01-2026	Part of : BLOCK A VISHWAKARMA COLONY PULPEHLADPUR	1	Other Outage	Planned Outage	08-01-2026	11:07	08-01-2026	13:41	2:34	0.000471	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						Remarks
						From		To		Duration	Unservd (MU) due to outage	
						Date	Time	Date	Time			
293	09-01-2026	Part of : BLOCK 1 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,BLOCK 2 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	8828	Other Outage	Planned Outage	09-01-2026	13:38	09-01-2026	16:41	3:03	0.000559	MAINTENANCE OF HT O/H CIRCUIT
294	09-01-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,JAWAHAR PARK SANGAM VIHAR,POCKET A JAWAHAR PARK KHANPUR	844	Other Outage	Planned Outage	09-01-2026	11:04	09-01-2026	14:26	3:22	0.000617	MAINTENANCE OF HVDS
295	09-01-2026	Part of : BLOCK B SECTOR 5 DAKSHINPURI,BLOCK A SECTOR 5 DAKSHINPURI,	1712	Other Outage	Planned Outage	09-01-2026	11:22	09-01-2026	14:19	2:57	0.000541	MAINTENANCE OF HT O/H CIRCUIT
296	09-01-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR,	3760	Other Outage	Planned Outage	09-01-2026	10:01	09-01-2026	12:47	2:46	0.000507	MAINTENANCE OF HVDS
297	10-01-2026	Part of : BLOCK D JJ COLONY KHANPUR,BLOCK B JJ COLONY KHANPUR,KHANPUR VILLAGE KHANPUR	3054	Other Outage	Unplanned Outage	10-01-2026	08:01	10-01-2026	08:50	0:49	0.000939	HT SYSTEM FAULT
298	10-01-2026	PART OF : SHIV PARK DUGGAL COLONY KHANPUR,KHANPUR VILLAGE KHANPUR,BLOCK F KHANPUR COLONY KHANPUR	16	Other Outage	Planned Outage	10-01-2026	11:22	10-01-2026	14:18	2:56	0.000538	3PH HT AB CABLE REPLACEMENT PER SPAN
299	10-01-2026	PART OF : BLOCK A PULPEHLADPUR,HR-BLOCK PULPEHLADPUR	1099	Other Outage	Planned Outage	10-01-2026	11:07	10-01-2026	14:00	2:53	0.000529	3PH HT AB CABLE REPLACEMENT PER SPAN
300	10-01-2026	PART OF : BLOCK J 1 & J2 DEVLII SANGAM VIHAR	2236	Other Outage	Planned Outage	10-01-2026	11:10	10-01-2026	14:31	3:21	0.000614	3PH HT AB CABLE REPLACEMENT PER SPAN
301	10-01-2026	PART OF : BLOCK L 2 DEVLII SANGAM VIHAR	2835	Other Outage	Planned Outage	10-01-2026	10:04	10-01-2026	15:28	5:24	0.000990	3PH HT AB CABLE REPLACEMENT PER SPAN
302	11-01-2026	Part of : D & E-BLOCK SANGAM VIHAR	4334	Other Outage	Unplanned Outage	11-01-2026	01:10	11-01-2026	02:11	1:01	0.000441	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
303	12-01-2026	Part of : TIGRI EXTENSION SANGAM VIHAR	1415	Other Outage	Planned Outage	12-01-2026	12:34	12-01-2026	13:12	0:38	0.000116	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
304	12-01-2026	Part of : MADANGIR VILLAGE	2341	Other Outage	Planned Outage	12-01-2026	12:54	12-01-2026	15:50	2:56	0.000538	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
305	12-01-2026	Part of : PREM NAGAR TUGHLAKABAD	578	Other Outage	Planned Outage	12-01-2026	11:55	12-01-2026	14:36	2:41	0.000492	REPLACEMENT OF LT BUSHING ROD
306	12-01-2026	Part of : BLOCK B PULPEHLADPUR,HR-BLOCK PULPEHLADPUR	496	Other Outage	Planned Outage	12-01-2026	11:18	12-01-2026	14:01	2:43	0.000498	3PH HT AB CABLE REPLACEMENT PER SPAN
307	12-01-2026	Part of : TALIMABAD SANGAM VIHAR,BLOCK E,F2 & G2 SANGAM VIHAR	2554	Other Outage	Planned Outage	12-01-2026	10:36	12-01-2026	14:42	4:06	0.000752	3PH HT AB CABLE REPLACEMENT PER SPAN
308	12-01-2026	Part of : BLOCK J SECTOR 5 DAKSHINPURI	938	Other Outage	Planned Outage	12-01-2026	11:25	12-01-2026	16:02	4:37	0.000846	DT REPLACEMENT
309	12-01-2026	Part of : SHIV PARK DUGGAL COLONY KHANPUR,KHANPUR VILLAGE,JJ COLONY DUGGAL COLONY KHANPUR	2985	Other Outage	Planned Outage	12-01-2026	11:17	12-01-2026	14:49	3:32	0.000648	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
310	12-01-2026	Part of : DURGA VIHAR DEVLII SANGAM VIHAR	786	Other Outage	Planned Outage	12-01-2026	11:02	12-01-2026	14:59	3:57	0.000724	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
311	12-01-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	1566	Other Outage	Planned Outage	12-01-2026	10:07	12-01-2026	13:33	3:26	0.000629	3PH HT AB CABLE REPLACEMENT PER SPAN
312	12-01-2026	Part of : POCKET A,B,C & D JAWAHAR PARK KHANPUR,BLOCK F KHANPUR COLONY	1377	Other Outage	Planned Outage	12-01-2026	10:41	12-01-2026	14:22	3:41	0.000675	3PH HT AB CABLE REPLACEMENT PER SPAN
313	13-01-2026	Part of : TALIMABAD SANGAM VIHAR	1396	Other Outage	Planned Outage	13-01-2026	11:47	13-01-2026	13:41	1:54	0.000348	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
314	13-01-2026	Part of : BLOCK A SECTOR 5 DAKSHINPURI,BLOCK B SECTOR 5 DAKSHINPURI	1712	Other Outage	Planned Outage	13-01-2026	12:04	13-01-2026	14:38	2:34	0.000471	3PH DB REPLACEMENT
315	13-01-2026	Part of : POCKET C RAJU PARK SANGAM VIHAR	799	Other Outage	Planned Outage	13-01-2026	11:01	13-01-2026	13:36	2:35	0.000474	3PH HT AB CABLE REPLACEMENT PER SPAN
316	13-01-2026	Part of : BLOCK G 2 SANGAM VIHAR,BLOCK G 1 TALIMABAD SANGAM VIHAR,BLOCK H SANGAM VIHAR,TALIMABAD SANGAM VIHAR	2443	Other Outage	Planned Outage	13-01-2026	10:56	13-01-2026	14:40	3:44	0.000684	3PH HT AB CABLE REPLACEMENT PER SPAN
317	13-01-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	3760	Other Outage	Planned Outage	13-01-2026	10:07	13-01-2026	15:33	5:26	0.000996	3PH HT AB CABLE REPLACEMENT PER SPAN
318	13-01-2026	Part of : BLOCK D VISHWAKARMA COLONY PULPEHLADPUR	1972	Other Outage	Planned Outage	13-01-2026	11:06	13-01-2026	14:07	3:01	0.000553	3PH HT AB CABLE REPLACEMENT PER SPAN
319	14-01-2026	Part of : 19 BLOCK DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	1790	Other Outage	Planned Outage	14-01-2026	12:15	14-01-2026	14:12	1:57	0.000358	REPLACEMENT OF LT BUSHING ROD
320	14-01-2026	Part of : JAWAHAR PARK SANGAM VIHAR,POCKET C JAWAHAR PARK KHANPUR	101	Other Outage	Planned Outage	14-01-2026	10:11	14-01-2026	13:01	2:50	0.000519	HVDS HT AB CABLE REPLACEMENT
321	15-01-2026	Part of : BLOCK J SECTOR 5 DAKSHINPURI	938	Other Outage	Planned Outage	15-01-2026	13:00	15-01-2026	16:04	3:04	0.000562	DT REPLACEMENT
322	15-01-2026	Part of : BLOCK H & G 2 SANGAM VIHAR TALIMABAD	2443	Other Outage	Planned Outage	15-01-2026	10:54	15-01-2026	14:38	3:44	0.000684	3PH HT AB CABLE REPLACEMENT
323	15-01-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,POCKET A,D & E JAWAHAR PARK KHANPUR	844	Other Outage	Planned Outage	15-01-2026	10:28	15-01-2026	13:21	2:53	0.000529	3PH HT AB CABLE REPLACEMENT
324	15-01-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	2511	Other Outage	Planned Outage	15-01-2026	09:56	15-01-2026	14:18	4:22	0.000801	3PH HT AB CABLE REPLACEMENT
325	15-01-2026	Part of : HR-BLOCK PULPEHLADPUR	2253	Other Outage	Planned Outage	15-01-2026	10:42	15-01-2026	13:29	2:47	0.000510	3PH HT AB CABLE REPLACEMENT
326	16-01-2026	Part of : BLOCK F DR AMBEDKAR NAGAR MADANGIR	1202	Other Outage	Planned Outage	16-01-2026	15:46	16-01-2026	16:35	0:49	0.000150	3PH DB REPLACEMENT
327	16-01-2026	Part of : MADANGIR VILLAGE	889	Other Outage	Planned Outage	16-01-2026	14:36	16-01-2026	16:34	1:58	0.000361	3PH DB REPLACEMENT
328	16-01-2026	Part of : TIGRI EXTENSION SANGAM VIHAR	1324	Other Outage	Planned Outage	16-01-2026	14:39	16-01-2026	16:26	1:47	0.000327	DT REPLACEMENT
329	16-01-2026	Part of : BLOCK A LAL KUAN	933	Other Outage	Planned Outage	16-01-2026	12:27	16-01-2026	14:02	1:35	0.000290	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						Remarks
						From		To		Duration	Unservd (MU) due to outage	
						Date	Time	Date	Time			
330	16-01-2026	Part of : BLOCK C DR AMBEDKAR NAGAR MADANGIR	1408	Other Outage	Planned Outage	16-01-2026	13:37	16-01-2026	16:06	2:29	0.000455	3PH DB REPLACEMENT
331	16-01-2026	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1440	Other Outage	Planned Outage	16-01-2026	13:31	16-01-2026	16:09	2:38	0.000483	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
332	16-01-2026	Part of : JWALAHARI VILLAGE PASCHIM VIHAR	1972	Other Outage	Planned Outage	16-01-2026	11:08	16-01-2026	14:07	2:59	0.000547	3PH HT AB CABLE REPLACEMENT PER SPAN
333	16-01-2026	Part of : BADOHOSRA	4120	Other Outage	Planned Outage	16-01-2026	10:54	16-01-2026	14:16	3:22	0.000617	3PH HT AB CABLE REPLACEMENT PER SPAN
334	16-01-2026	Part of : BLOCK B KATWARIA SARAI	786	Other Outage	Planned Outage	16-01-2026	11:28	16-01-2026	17:31	6:03	0.001109	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
335	16-01-2026	Part of : SECTOR 6 DWARKA	511	Other Outage	Planned Outage	16-01-2026	10:18	16-01-2026	14:44	4:26	0.000813	3PH HT AB CABLE REPLACEMENT PER SPAN
336	16-01-2026	Part of : SHAHEEN BAGH JASOLA VIHAR	1096	Other Outage	Planned Outage	16-01-2026	10:06	16-01-2026	17:17	7:11	0.001317	3PH HT AB CABLE REPLACEMENT PER SPAN
337	17-01-2026	Part of : DAKSHINPURI EXTENSION SECTOR 6 ,BLOCK J SECTOR 5 DAKSHINPURI,BLOCK 1 DAKSHINPURI EXTENSION	7987	Other Outage	Planned Outage	17-01-2026	14:58	17-01-2026	16:32	1:34	0.000287	MAINTENANCE OF HT O/H CIRCUIT
338	17-01-2026	Part of : AIRFORCE STATION TUGHLAKABAD	3	Other Outage	Planned Outage	17-01-2026	11:24	17-01-2026	12:52	1:28	0.000269	MAINTENANCE OF TRANSFORMER
339	17-01-2026	Part of : DR AMBEDKAR NAGAR MADANGIR	1807	Other Outage	Planned Outage	17-01-2026	14:31	17-01-2026	16:43	2:12	0.000403	MAINTENANCE OF HT O/H CIRCUIT
340	17-01-2026	Part of : F BLOCK SANGAM VIHAR	1259	Other Outage	Planned Outage	17-01-2026	13:37	17-01-2026	16:19	2:42	0.000495	MAINTENANCE OF TRANSFORMER
341	17-01-2026	Part of : VAYUSENA VIHAR VAYUSENABAD	2894	Other Outage	Planned Outage	17-01-2026	13:22	17-01-2026	16:44	3:22	0.000617	MAINTENANCE OF TRANSFORMER
342	17-01-2026	Part of : BLOCK J 2 DEVL I SANGAM VIHAR,BLOCK F 2 SANGAM VIHAR,BLOCK C DEVL I SANGAM VIHAR	5439	Other Outage	Planned Outage	17-01-2026	11:49	17-01-2026	15:45	3:56	0.000721	MAINTENANCE OF RMU
343	17-01-2026	Part of : J 1 BLOCK DEVL I SANGAM VIHAR,BLOCK J 2 DEVL I SANGAM VIHAR	2822	Other Outage	Planned Outage	17-01-2026	10:42	17-01-2026	14:18	3:36	0.000660	MAINTENANCE OF HVDS CIRCUIT
344	17-01-2026	Part of : JAWAHAR PARK KHANPUR	1377	Other Outage	Planned Outage	17-01-2026	10:29	17-01-2026	14:01	3:32	0.000648	MAINTENANCE OF HVDS CIRCUIT
345	17-01-2026	Part of : L 2 BLOCK DEVL I SANGAM VIHAR,	2511	Other Outage	Planned Outage	17-01-2026	09:55	17-01-2026	14:52	4:57	0.000908	MAINTENANCE OF HVDS CIRCUIT
346	19-01-2026	Part of : KHANPUR VILLAGE	1788	Other Outage	Unplanned Outage	19-01-2026	15:35	19-01-2026	16:13	0:38	0.000000	MAINTENANCE/REPAIR OF RMU
347	19-01-2026	Part of : TIGRI EXTENSION SANGAM VIHAR	1324	Other Outage	Planned Outage	19-01-2026	12:37	19-01-2026	13:16	0:39	0.000119	3PH DB REPLACEMENT
348	19-01-2026	Part of : BLOCK G JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	871	Other Outage	Planned Outage	19-01-2026	13:17	19-01-2026	15:54	2:37	0.000480	DT REPLACEMENT
349	19-01-2026	Part of : BLOCK F JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1451	Other Outage	Planned Outage	19-01-2026	13:09	19-01-2026	15:53	2:44	0.000501	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
350	19-01-2026	Part of : KHANPUR EXTENSION,SANGAM VIHAR,KHANPUR VILLAGE,BLOCK G SECTOR 5 DAKSHINPURI,POCKET A DUGGAL COLONY	1241	Other Outage	Planned Outage	19-01-2026	10:27	19-01-2026	13:22	2:55	0.000535	3PH HT AB CABLE REPLACEMENT
351	19-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	3931	Other Outage	Planned Outage	19-01-2026	10:10	19-01-2026	15:33	5:23	0.000987	3PH HT AB CABLE REPLACEMENT
352	20-01-2026	Part of : BLOCK A & D VISHWAKARMA COLONY PULPEHLADPUR	1972	Other Outage	Planned Outage	20-01-2026	10:51	20-01-2026	11:53	1:02	0.000189	3PH HT AB CABLE REPLACEMENT PER SPAN
353	20-01-2026	Part of : POCKET D JAWAHAR PARK KHANPUR,BLOCK F KHANPUR COLONY	1381	Other Outage	Planned Outage	20-01-2026	10:58	20-01-2026	13:24	2:26	0.000446	3PH HT AB CABLE REPLACEMENT PER SPAN
354	20-01-2026	Part of : BLOCK B DEVL I SANGAM VIHAR	1791	Other Outage	Planned Outage	20-01-2026	10:38	20-01-2026	14:50	4:12	0.000770	3PH HT AB CABLE REPLACEMENT PER SPAN
355	20-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	3760	Other Outage	Planned Outage	20-01-2026	10:15	20-01-2026	14:46	4:31	0.000828	3PH HT AB CABLE REPLACEMENT PER SPAN
356	21-01-2026	Part of : BLOCK G 1 TALIMABAD SANGAM VIHAR,TALIMABAD SANGAM VIHAR,BLOCK H SANGAM VIHAR	2938	Other Outage	Unplanned Outage	21-01-2026	14:58	21-01-2026	15:37	0:39	0.000556	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
357	21-01-2026	Part of : BLOCK F 2 SANGAM VIHAR,BLOCK F SANGAM VIHAR	4395	Other Outage	Unplanned Outage	21-01-2026	09:28	21-01-2026	10:11	0:43	0.001670	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
358	21-01-2026	Part of : DR AMBEDKAR NAGAR MADANGIR,	1807	Other Outage	Planned Outage	21-01-2026	12:18	21-01-2026	12:59	0:41	0.000125	HT CIRCUIT MAINTENANCE
359	21-01-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,TIGRI EXTENSION TIGRI SANGAM VIHAR,	1584	Other Outage	Planned Outage	21-01-2026	14:07	21-01-2026	17:42	3:35	0.000657	TRANSFORMER MAINTENANCE
360	21-01-2026	Part of : BLOCK B DEVL I SANGAM VIHAR,	2336	Other Outage	Planned Outage	21-01-2026	10:30	21-01-2026	15:17	4:47	0.000877	HVDS MAINTENANCE
361	21-01-2026	Part of : KHANPUR VILLAGE KHANPUR,SHIV PARK DUGGAL COLONY KHANPUR,BLOCK F KHANPUR COLONY KHANPUR,	16	Other Outage	Planned Outage	21-01-2026	10:03	21-01-2026	12:57	2:54	0.000532	HVDS MAINTENANCE
362	21-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,	1096	Other Outage	Planned Outage	21-01-2026	10:20	21-01-2026	14:07	3:47	0.000694	HVDS MAINTENANCE
363	22-01-2026	Part of : VAYUSENA VIHAR VAYUSENABAD	2895	Other Outage	Planned Outage	22-01-2026	14:38	22-01-2026	16:33	1:55	0.000351	3PH DB REPLACEMENT
364	22-01-2026	Part of : TALIMABAD SANGAM VIHAR	1395	Other Outage	Planned Outage	22-01-2026	12:17	22-01-2026	15:44	3:27	0.000633	3PH DB REPLACEMENT
365	22-01-2026	Part of : MADANGIR VILLAGE MADANGIR	2337	Other Outage	Planned Outage	22-01-2026	12:11	22-01-2026	16:00	3:49	0.000700	DT REPLACEMENT
366	22-01-2026	Part of : BLOCK B DEVL I SANGAM VIHAR	1396	Other Outage	Planned Outage	22-01-2026	10:37	22-01-2026	15:01	4:24	0.000807	3PH HT AB CABLE REPLACEMENT PER SPAN
367	22-01-2026	Part of : DURGA VIHAR DEVL I SANGAM VIHAR	786	Other Outage	Planned Outage	22-01-2026	11:20	22-01-2026	16:56	5:36	0.001027	3PH DB REPLACEMENT
368	22-01-2026	Part of : POCKET B JAWAHAR PARK KHANPUR,DURGA VIHAR DEVL I SANGAM VIHAR	511	Other Outage	Planned Outage	22-01-2026	10:34	22-01-2026	12:42	2:08	0.000391	3PH HT AB CABLE REPLACEMENT PER SPAN
369	22-01-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	2511	Other Outage	Planned Outage	22-01-2026	10:20	22-01-2026	15:14	4:54	0.000898	3PH HT AB CABLE REPLACEMENT PER SPAN
370	23-01-2026	Part of : DURGA VIHAR & L 2-BLOCK DEVL I SANGAM VIHAR	5935	Other Outage	Unplanned Outage	23-01-2026	11:41	23-01-2026	12:00	0:19	0.000106	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
371	23-01-2026	Part of : BLOCK 1 & 19 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,BLOCK J SECTOR 5 DAKSHINPURI	7992	Other Outage	Unplanned Outage	23-01-2026	15:46	23-01-2026	16:26	0:40	0.000556	CABLE FAULT
372	24-01-2026	Part of : BLOCK 1,2 & 4 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,BLOCK A SECTOR 5 DAKSHINPURI	8842	Other Outage	Unplanned Outage	24-01-2026	05:51	24-01-2026	06:12	0:21	0.000099	CABLE FAULT
373	24-01-2026	Part of : JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1450	Other Outage	Unplanned Outage	24-01-2026	11:38	24-01-2026	15:09	3:31	0.000000	MOBILE TRANSFORMER REPLACEMENT
374	24-01-2026	Part of : KHANPUR VILLAGE KHANPUR,SHIV PARK DUGGAL COLONY KHANPUR	1326	Other Outage	Planned Outage	24-01-2026	11:40	24-01-2026	12:45	1:05	0.000199	3PH HT AB CABLE REPLACEMENT PER SPAN
375	24-01-2026	Part of : BLOCK 4 DAKSHINPURI EXTENSION SECTOR 6 ,BLOCK 14 DAKSHINPURI EXTENSION SECTOR 6	4017	Other Outage	Planned Outage	24-01-2026	13:42	24-01-2026	16:17	2:35	0.000474	DT REPLACEMENT
376	24-01-2026	Part of : BLOCK H & G 2 SANGAM VIHAR	215	Other Outage	Planned Outage	24-01-2026	10:48	24-01-2026	13:57	3:09	0.000578	3PH HT AB CABLE REPLACEMENT PER SPAN
377	24-01-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	1096	Other Outage	Planned Outage	24-01-2026	10:20	24-01-2026	14:23	4:03	0.000743	3PH HT AB CABLE REPLACEMENT PER SPAN
378	24-01-2026	Part of : VAYUSENA VIHAR VAYUSENABAD	2894	Other Outage	Planned Outage	24-01-2026	11:57	24-01-2026	15:47	3:50	0.000703	3PH DB REPLACEMENT
379	25-01-2026	Part of : BLOCK J 1 DEVLII SANGAM VIHAR,BLOCK J 2 DEVLII SANGAM VIHAR,ASOLA WILD LIFE SANCTUARY ASOLA	5066	Other Outage	Unplanned Outage	25-01-2026	12:49	25-01-2026	13:20	0:31	0.000815	CABLE FAULT
380	25-01-2026	Part of : BLOCK F 2 SANGAM VIHAR,BLOCK F SANGAM VIHAR	4403	Other Outage	Unplanned Outage	25-01-2026	14:55	25-01-2026	15:37	0:42	0.001569	CABLE FAULT
381	25-01-2026	Part of : RPS COLONY MADANGIR,POCKET A DUGGAL COLONY KHANPUR,KHANPUR EXTENSION SANGAM VIHAR,KHANPUR VILLAGE KHANPUR	1630	Other Outage	Unplanned Outage	25-01-2026	03:55	25-01-2026	04:42	0:47	0.000212	CABLE FAULT
382	25-01-2026	Part of : VAYUSENA VIHAR VAYUSENABAD	2894	Other Outage	Unplanned Outage	25-01-2026	12:09	25-01-2026	15:10	3:01	0.001257	LAYING OF NEW LTAB CIRCUIT
383	25-01-2026	Part of : BLOCK F JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1453	Other Outage	Planned Outage	25-01-2026	11:06	25-01-2026	14:06	3:00	0.000550	3PH DB REPLACEMENT
384	25-01-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	1148	Other Outage	Planned Outage	25-01-2026	10:53	25-01-2026	16:42	5:49	0.001066	DT REPLACEMENT
385	25-01-2026	Part of : BLOCK 19 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	1790	Other Outage	Planned Outage	25-01-2026	10:46	25-01-2026	14:09	3:23	0.000620	3PH DB REPLACEMENT
386	27-01-2026	Part of : G-BLOCK JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	3058	Other Outage	Unplanned Outage	27-01-2026	11:20	27-01-2026	13:19	1:59	0.000364	MOBILE TRANSFORMER REPLACEMENT
387	27-01-2026	Part of : POCKET A,B & D JAWAHAR PARK KHANPUR,BLOCK F KHANPUR COLONY	1382	Other Outage	Planned Outage	27-01-2026	10:32	27-01-2026	12:29	1:57	0.000358	3PH HT AB CABLE REPLACEMENT
388	27-01-2026	Part of : BLOCK K,I & G 2 SANGAM VIHAR,ASOLA WILD LIFE SANCTUARY, TUGHLAKABAD	3633	Other Outage	Planned Outage	27-01-2026	12:49	27-01-2026	15:21	2:32	0.000464	3PH HT AB CABLE REPLACEMENT
389	27-01-2026	Part of : VAYUSENA VIHAR VAYUSENABAD	2894	Other Outage	Planned Outage	27-01-2026	11:22	27-01-2026	15:19	3:57	0.000724	3PH DB REPLACEMENT
390	27-01-2026	Part of : TUGHLAKABAD	1	Other Outage	Planned Outage	27-01-2026	11:34	27-01-2026	13:49	2:15	0.000413	REPLACEMET OF HT BUSHING ROD
391	27-01-2026	Part of : BLOCK L & J DEVLII SANGAM VIHAR	3670	Other Outage	Planned Outage	27-01-2026	10:14	27-01-2026	15:13	4:59	0.000914	3PH HT AB CABLE REPLACEMENT
392	27-01-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	3760	Other Outage	Planned Outage	27-01-2026	10:16	27-01-2026	12:28	2:12	0.000403	3PH HT AB CABLE REPLACEMENT
393	28-01-2026	Part of : BLOCK 4 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	3652	Other Outage	Unplanned Outage	28-01-2026	12:16	28-01-2026	12:52	0:36	0.000110	CHECK PROTECTION CIRCUIT
394	28-01-2026	Part of : MADANGIR VILLAGE	2341	Other Outage	Unplanned Outage	28-01-2026	12:14	28-01-2026	14:27	2:13	0.000406	LT ACB LEAD REPLACEMENT
395	28-01-2026	Part of : VAYUSENA VIHAR VAYUSENABAD	2897	Other Outage	Unplanned Outage	28-01-2026	11:57	28-01-2026	14:26	2:29	0.000455	LAYING OF NEW LTAB
396	28-01-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	1148	Other Outage	Planned Outage	28-01-2026	13:27	28-01-2026	14:14	0:47	0.000144	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
397	28-01-2026	Part of : BLOCK C DEVLII SANGAM VIHAR	3	Other Outage	Planned Outage	28-01-2026	11:11	28-01-2026	14:31	3:20	0.000611	3PH HT AB CABLE REPLACEMENT PER SPAN
398	28-01-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,JAWAHAR PARK SANGAM VIHAR	844	Other Outage	Planned Outage	28-01-2026	11:08	28-01-2026	14:25	3:17	0.000602	3PH HT AB CABLE REPLACEMENT PER SPAN
399	28-01-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	1096	Other Outage	Planned Outage	28-01-2026	10:02	28-01-2026	16:14	6:12	0.001137	3PH HT AB CABLE REPLACEMENT PER SPAN
400	29-01-2026	Part of : RPS COLONY MADANGIR,POCKET A DUGGAL COLONY KHANPUR,KHANPUR EXTENSION SANGAM VIHAR,KHANPUR VILLAGE KHANPUR,BLOCK G SECTOR 5 DAKSHINPURI,JAWAHAR PARK SANGAM VIHAR	1630	Other Outage	Unplanned Outage	29-01-2026	03:58	29-01-2026	04:27	0:29	0.000029	HVDS FAULT
401	29-01-2026	Part of : RPS COLONY MADANGIR,POCKET A DUGGAL COLONY KHANPUR,KHANPUR EXTENSION SANGAM VIHAR,KHANPUR VILLAGE KHANPUR,BLOCK G SECTOR 5 DAKSHINPURI,JAWAHAR PARK SANGAM VIHAR	1630	Other Outage	Unplanned Outage	29-01-2026	02:55	29-01-2026	03:27	0:32	0.000039	HVDS FAULT
402	29-01-2026	Part of : BLOCK F JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	1455	Other Outage	Unplanned Outage	29-01-2026	15:17	29-01-2026	17:07	1:50	0.000611	LAYING OF NEW LTAB
403	29-01-2026	Part of : MADANGIR VILLAGE MADANGIR,	2341	Other Outage	Unplanned Outage	29-01-2026	13:19	29-01-2026	14:43	1:24	0.000467	LAYING OF NEW LTAB
404	29-01-2026	Part of : DR AMBEDKAR NAGAR MADANGIR,	1807	Other Outage	Unplanned Outage	29-01-2026	13:26	29-01-2026	15:47	2:21	0.000783	LAYING OF NEW LTAB
405	29-01-2026	Part of : VAYUSENA VIHAR VAYUSENABAD,	2897	Other Outage	Unplanned Outage	29-01-2026	11:13	29-01-2026	14:57	3:44	0.001244	LAYING OF NEW LTAB

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
406	29-01-2026	Part of : HTC:HT SWG:DMST	1	Other Outage	Planned Outage	29-01-2026	12:15	29-01-2026	14:57	2:42	0.000495	REPLACEMET OF HT BUSHING ROD
407	29-01-2026	Part of : BLOCK J 2 DEVLJI SANGAM VIHAR,BLOCK I 2 SANGAM VIHAR,	4120	Other Outage	Planned Outage	29-01-2026	10:53	29-01-2026	14:36	3:43	0.000681	3PH HT AB CABLE REPLACEMENT PER SPAN
408	29-01-2026	Part of : BLOCK B PULPEHLADPUR,BLOCK A PULPEHLADPUR,HR-BLOCK PULPEHLADPUR,	496	Other Outage	Planned Outage	29-01-2026	11:09	29-01-2026	13:43	2:34	0.000471	3PH HT AB CABLE REPLACEMENT PER SPAN
409	29-01-2026	Part of : BLOCK L 2 DEVLJI SANGAM VIHAR,	3760	Other Outage	Planned Outage	29-01-2026	10:14	29-01-2026	14:07	3:53	0.000712	3PH HT AB CABLE REPLACEMENT PER SPAN
410	30-01-2026	Part of : RPS COLONY MADANGIR	821	Other Outage	Unplanned Outage	30-01-2026	16:50	30-01-2026	17:02	0:12	0.000000	SHIFTING OF CABLE
411	30-01-2026	Part of : KHANPUR EXTENSION SANGAM VIHAR,KHANPUR VILLAGE KHANPUR,POCKET A DUGGAL COLONY KHANPUR,BLOCK G SECTOR 5 DAKSHINPURI	1284	Other Outage	Planned Outage	30-01-2026	10:58	30-01-2026	13:58	3:00	0.000550	3PH HT AB CABLE REPLACEMENT PER SPAN
412	30-01-2026	Part of : BLOCK L 2 DEVLJI SANGAM VIHAR	2511	Other Outage	Planned Outage	30-01-2026	10:03	30-01-2026	13:17	3:14	0.000593	3PH HT AB CABLE REPLACEMENT PER SPAN
413	31-01-2026	Part of : RPS COLONY MADANGIR,POCKET A DUGGAL COLONY,KHANPUR VILLAGE & EXTENSION,SANGAM VIHAR,G-BLOCK SECTOR 5 DAKSHINPURI,JAWAHAR PARK	1630	Other Outage	Unplanned Outage	31-01-2026	04:28	31-01-2026	04:58	0:30	0.000044	CABLE FAULT
414	31-01-2026	Part of : RPS COLONY MADANGIR,I-BLOCK JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	2762	Other Outage	Unplanned Outage	31-01-2026	03:58	31-01-2026	04:44	0:46	0.000362	CABLE FAULT
415	31-01-2026	Part of : G-BLOCK JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	3053	Other Outage	Unplanned Outage	31-01-2026	12:59	31-01-2026	15:57	2:58	0.000000	LAYING OF NEW LTAB
416	31-01-2026	Part of : A & B-BLOCK SECTOR 5 DAKSHINPURI	2694	Other Outage	Unplanned Outage	31-01-2026	12:56	31-01-2026	15:57	3:01	0.000000	LAYING OF NEW LTAB
417	31-01-2026	Part of : POCKET A JAWAHAR PARK KHANPUR	1958	Other Outage	Planned Outage	31-01-2026	13:45	31-01-2026	16:25	2:40	0.000489	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
418	31-01-2026	Part of : TALIMABAD SANGAM VIHAR,H & G 2-BLOCK SANGAM VIHAR	2443	Other Outage	Planned Outage	31-01-2026	10:49	31-01-2026	14:15	3:26	0.000629	3PH HT AB CABLE REPLACEMENT
419	31-01-2026	Part of : A,B & HR-BLOCK PULPEHLADPUR	496	Other Outage	Planned Outage	31-01-2026	11:03	31-01-2026	14:17	3:14	0.000593	3PH HT AB CABLE REPLACEMENT
420	31-01-2026	Part of : L 2-BLOCK DEVLJI SANGAM VIHAR	3760	Other Outage	Planned Outage	31-01-2026	11:15	31-01-2026	14:34	3:19	0.000608	3PH HT AB CABLE REPLACEMENT
421	01-01-2026	Part of : VILLAGE JASOLA JASOLA VIHAR,	233	Other Outage	Planned Outage	01-01-2026	10:22	01-01-2026	12:04	1:42	0.001133	REPLACEMET OF HT BUSHING ROD
422	02-01-2026	Part of : BLOCK A NEW FRIENDS COLONY WEST NEW FRIENDS COLONY	98	Other Outage	Planned Outage	02-01-2026	12:48	02-01-2026	13:48	1:00	0.001000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
423	03-01-2026	Part of : BLOCK C NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	57	Other Outage	Planned Outage	03-01-2026	11:01	03-01-2026	13:59	2:58	0.002967	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
424	05-01-2026	Part of : JAMIA NAGAR OKHLA,	11	Other Outage	Planned Outage	05-01-2026	13:05	05-01-2026	14:39	1:34	0.001567	MAINTENANCE OF HT O/H CIRCUIT
425	06-01-2026	Part of : BATLA HOUSE OKHLA	4008	Other Outage	Unplanned Outage	06-01-2026	13:04	06-01-2026	13:44	0:40	0.001256	CABLE FAULT
426	06-01-2026	Part of : BLOCK F SHAHEEN BAGH JASOLA VIHAR	347	Other Outage	Planned Outage	06-01-2026	10:27	06-01-2026	12:32	2:05	0.001389	REPLACEMENT OF HT BUSHING ROD
427	08-01-2026	Part of : HAZI COLONY, GHAFAR MANZIL COLONY JAMIA NAGAR OKHLA,NOOR NAGAR OKHLA	4057	Other Outage	Unplanned Outage	08-01-2026	17:30	08-01-2026	18:04	0:34	0.000850	CABLE FAULT
428	08-01-2026	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR (HTC), 66 NO.STAFF QUARTERS AT STP OKHLA, DJB NEAR APOLLO HOSPITAL (HTC)	82	Other Outage	Unplanned Outage	08-01-2026	09:01	08-01-2026	09:51	0:50	0.000069	FAULT IN HT CONSUMER PANEL (OSD PLANT)
429	08-01-2026	Part of : BLOCK A OKHLA	83	Other Outage	Planned Outage	08-01-2026	13:10	08-01-2026	15:21	2:11	0.002183	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
430	08-01-2026	Part of : BLOCK D NEW FRIENDS COLONY EAST	118	Other Outage	Planned Outage	08-01-2026	11:07	08-01-2026	13:25	2:18	0.002300	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
431	08-01-2026	Part of : SHAHEEN BAGH JASOLA VIHAR	191	Other Outage	Planned Outage	08-01-2026	10:29	08-01-2026	12:34	2:05	0.001389	REPLACEMET OF HT BUSHING ROD
432	09-01-2026	Part of : JAMIA NAGAR OKHLA,	9	Other Outage	Planned Outage	09-01-2026	11:08	09-01-2026	12:57	1:49	0.001363	MAINTENANCE OF TRANSFORMER
433	10-01-2026	PART OF : BLOCK A NEW FRIENDS COLONY WEST NEW FRIENDS COLONY	98	Other Outage	Planned Outage	10-01-2026	14:14	10-01-2026	16:03	1:49	0.000666	SF6 GAS FILLING
434	10-01-2026	PART OF : BLOCK A TAIMOOR NAGAR NEW FRIENDS COLONY	489	Other Outage	Planned Outage	10-01-2026	11:03	10-01-2026	15:38	4:35	0.004583	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
435	11-01-2026	Part of : VILLAGE JASOLA & JASOLA VIHAR	167	Other Outage	Planned Outage	11-01-2026	10:55	11-01-2026	11:35	0:40	0.000556	REPLACEMENT OF HT BUSHING ROD
436	12-01-2026	Part of : BLOCK F MAHARANI BAGH,BLOCK A NEW FRIENDS COLONY EAST	536	Other Outage	Planned Outage	12-01-2026	11:10	12-01-2026	14:07	2:57	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD
437	13-01-2026	Part of : BLOCK D PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	417	Other Outage	Planned Outage	13-01-2026	10:06	13-01-2026	12:28	2:22	0.000592	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
438	13-01-2026	Part of : NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	81	Other Outage	Planned Outage	13-01-2026	10:58	13-01-2026	14:05	3:07	0.003117	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
439	13-01-2026	Part of : MUJEEB BAGH JAMIA NAGAR OKHLA	108	Other Outage	Planned Outage	13-01-2026	12:58	13-01-2026	15:46	2:48	0.002800	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
440	14-01-2026	Part of : NOOR NAGAR OKHLA	3795	Other Outage	Unplanned Outage	14-01-2026	17:09	14-01-2026	17:37	0:28	0.000754	CABLE FAULT
441	15-01-2026	Part of : BLOCK B TAIMOOR NAGAR NEW FRIENDS COLONY	673	Other Outage	Planned Outage	15-01-2026	10:57	15-01-2026	13:49	2:52	0.002867	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS,TAPPING OF JUMPERS
442	15-01-2026	Part of : POCKET 1 JASOLA VIHAR	171	Other Outage	Planned Outage	15-01-2026	10:30	15-01-2026	12:57	2:27	0.000613	REPLACEMET OF HT BUSHING ROD
443	16-01-2026	Part of : SHAHEEN BAGH JASOLA VIHAR	193	Other Outage	Planned Outage	16-01-2026	13:00	16-01-2026	14:07	1:07	0.000782	REPLACEMENT OF GAS KIT AND OIL SEAL
444	16-01-2026	Part of : UDYOG NAGAR MANGOLPURI	8	Other Outage	Planned Outage	16-01-2026	10:17	16-01-2026	11:25	1:08	0.000793	REPLACEMENT OF GAS KIT AND OIL SEAL
445	16-01-2026	Part of : BLOCK B DAYANAND COLONY LAJPAT NAGAR	348	Other Outage	Planned Outage	16-01-2026	11:03	16-01-2026	13:04	2:01	0.001008	CONDUCTOR REPLACEMET PER SPAN
446	17-01-2026	Part of : POCKET 1 JASOLA VIHAR	213	Other Outage	Unplanned Outage	17-01-2026	13:44	17-01-2026	14:14	0:30	0.000175	MAINTENANCE/REPAIR OF RMU
447	17-01-2026	Part of : JASOLA VIHAR	29	Other Outage	Planned Outage	17-01-2026	10:50	17-01-2026	12:26	1:36	0.000000	MAINTENANCE OF TRANSFORMER
448	17-01-2026	Part of : A BLOCK OKHLA	84	Other Outage	Planned Outage	17-01-2026	13:16	17-01-2026	15:39	2:23	0.002383	MAINTENANCE OF TRANSFORMER
449	19-01-2026	Part of : MUJEEB BAGH JAMIA NAGAR OKHLA	459	Other Outage	Planned Outage	19-01-2026	12:57	19-01-2026	14:02	1:05	0.001083	APPLY OF INSULATION TAPE HT/LT BUSHINGS,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
450	19-01-2026	Part of : VILLAGE JASOLA & JASOLA VIHAR	15	Other Outage	Planned Outage	19-01-2026	10:08	19-01-2026	12:30	2:22	0.000000	REPLACEMET OF HT BUSHING ROD
451	20-01-2026	Part of : BLOCK A NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	55	Other Outage	Planned Outage	20-01-2026	11:07	20-01-2026	13:59	2:52	0.001911	TAPPING OF JUMPERS
452	21-01-2026	Part of : JASOLA VIHAR,	25	Other Outage	Planned Outage	21-01-2026	10:40	21-01-2026	12:24	1:44	0.000578	TRANSFORMER MAINTENANCE
453	21-01-2026	Part of : BLOCK C KALINDI COLONY NEW FRIENDS COLONY,	41	Other Outage	Planned Outage	21-01-2026	11:08	21-01-2026	13:28	2:20	0.001167	HT CIRCUIT MAINTENANCE
454	22-01-2026	Part of : BLOCK B MAHARANI BAGH NEW FRIENDS COLONY,BLOCK D NEW FRIENDS COLONY EAST NEW FRIENDS COLONY,BHARAT NAGAR NEW FRIENDS COLONY,BLOCK C NEW FRIENDS COLONY	1324	Other Outage	Unplanned Outage	22-01-2026	11:03	22-01-2026	13:48	2:45	0.002750	ATTENDING WEAK POINTS/HOT SPOT
455	22-01-2026	Part of : POCKET B SUKHDEV VIHAR OKHLA	314	Other Outage	Planned Outage	22-01-2026	10:58	22-01-2026	13:41	2:43	0.001811	TAPPING OF JUMPERS
456	22-01-2026	Part of : BLOCK B SHAHEEN BAGH JASOLA VIHAR	630	Other Outage	Planned Outage	22-01-2026	10:08	22-01-2026	12:38	2:30	0.001250	REPLACEMENT OF LT BUSHING ROD
457	23-01-2026	Part of : D-BLOCK NEW FRIENDS COLONY EAST	619	Other Outage	Planned Outage	23-01-2026	13:00	23-01-2026	14:18	1:18	0.000867	JUMPER REPLACEMENT PER POLE
458	23-01-2026	Part of : A-BLOCK NEW FRIENDS COLONY	84	Other Outage	Planned Outage	23-01-2026	13:00	23-01-2026	14:17	1:17	0.000642	SF6 GAS FILLING
459	24-01-2026	Part of : BLOCK A OKHLA	80	Other Outage	Planned Outage	24-01-2026	13:04	24-01-2026	16:10	3:06	0.003100	REPLACEMENT OF LT BUSHING ROD
460	24-01-2026	Part of : BLOCK B NEW FRIENDS COLONY	95	Other Outage	Planned Outage	24-01-2026	11:04	24-01-2026	13:20	2:16	0.001133	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
461	27-01-2026	Part of : BLOCK C NEW FRIENDS COLONY	135	Other Outage	Planned Outage	27-01-2026	11:04	27-01-2026	12:14	1:10	0.000583	TAPPING OF JUMPERS
462	27-01-2026	Part of : BLOCK J PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	959	Other Outage	Planned Outage	27-01-2026	11:50	27-01-2026	14:26	2:36	0.000000	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
463	28-01-2026	Part of : TATA TELE SERVICES, THE MEERA CORPORATE HOUSE, DJB SPS BATLA HOUSE (HTC), BATLA HOUSE OKHLA	313	Other Outage	Unplanned Outage	28-01-2026	17:15	28-01-2026	17:54	0:39	0.000271	CABLE FAULT
464	28-01-2026	Part of : HOLY FAMILY HOSPITAL, OKHLA EFFLUENT PLANT (HTC), JAMIA NAGAR OKHLA	17	Other Outage	Unplanned Outage	28-01-2026	16:46	28-01-2026	17:20	0:34	0.000288	CABLE FAULT
465	28-01-2026	Part of : KHIZARABAD VILLAGE, BLOCK B & C NEW FRIENDS COLONY, TAIMOOR NAGAR EXTN., LIONS HOSPITAL (HTC)	3254	Other Outage	Unplanned Outage	28-01-2026	16:43	28-01-2026	17:19	0:36	0.001107	CABLE FAULT
466	28-01-2026	Part of : NOOR NAGAR OKHLA	184	Other Outage	Planned Outage	28-01-2026	12:53	28-01-2026	15:23	2:30	0.002083	REPLACEMENT OF LT BUSHING ROD
467	28-01-2026	Part of : POCKET 12 JASOLA VIHAR	389	Other Outage	Planned Outage	28-01-2026	10:22	28-01-2026	12:35	2:13	0.000739	REPLACEMET OF HT BUSHING ROD
468	29-01-2026	Part of : HTC:DON BOSCO SCHOOL SUKHDAVE VIHAR, DELHI SOCIETY MEN RETARDED CHILDREN	0	Other Outage	Unplanned Outage	29-01-2026	17:49	29-01-2026	18:21	0:32	0.001220	CABLE FAULT
469	30-01-2026	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR,CRRI SUKHDEV VIHAR OKHLA,SUKHDEV VIHAR OKHLA	336	Other Outage	Planned Outage	30-01-2026	11:06	30-01-2026	13:28	2:22	0.000868	CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE
470	31-01-2026	Part of : A-BLOCK NEW FRIENDS COLONY	160	Other Outage	Planned Outage	31-01-2026	12:50	31-01-2026	15:37	2:47	0.002783	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
471	02-01-2026	Part of : BLOCK D EAST OF KAILASH	43	Other Outage	Planned Outage	02-01-2026	10:01	02-01-2026	12:40	2:39	0.002429	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
472	04-01-2026	Part of : I.F.C.I. TOWER (HT CONSUMER)	1	Other Outage	Unplanned Outage	04-01-2026	20:20	04-01-2026	20:56	0:36	0.000240	HT SYSTEM FAULT
473	04-01-2026	Part of : NEHRU PLACE CAMPUS, BUILDING NO.-56 & 57 NEHRU PLACE, IFCI PARKING NEHRU PLACE	637	Other Outage	Unplanned Outage	04-01-2026	19:58	04-01-2026	20:48	0:50	0.000833	HT SYSTEM FAULT
474	04-01-2026	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA	17	Other Outage	Planned Outage	04-01-2026	11:24	04-01-2026	14:38	3:14	0.001347	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,SUB STATION CLEANING
475	04-01-2026	Part of : NEHRU PLACE	93	Other Outage	Planned Outage	04-01-2026	11:08	04-01-2026	13:13	2:05	0.001806	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,SUB STATION CLEANING
476	05-01-2026	Part of : OKHLA SABZEE MUNDI OKHLA INDUSTRIAL AREA	764	Other Outage	Unplanned Outage	05-01-2026	16:28	05-01-2026	17:10	0:42	0.000315	CABLE FAULT
477	05-01-2026	Part of : KAILASH KUNJ GREATER KAILASH,	105	Other Outage	Planned Outage	05-01-2026	11:36	05-01-2026	14:30	2:54	0.002513	MAINTENANCE OF TRANSFORMER
478	05-01-2026	Part of : BLOCK K LAJPAT NAGAR IV LAJPAT NAGAR,	170	Other Outage	Planned Outage	05-01-2026	09:58	05-01-2026	12:47	2:49	0.002582	MAINTENANCE OF TRANSFORMER
479	06-01-2026	Part of : SANT NAGAR EAST OF KAILASH,BLOCK A APB GARHI EAST OF KAILASH,BLOCK B AMRITPURI GARHI EAST OF KAILASH,BLOCK C APB GARHI EAST OF KAILASH	5796	Other Outage	Unplanned Outage	06-01-2026	12:25	06-01-2026	13:10	0:45	0.001300	HT SYSTEM FAULT
480	06-01-2026	Part of : BLOCK D KAILASH COLONY GREATER KAILASH	313	Other Outage	Planned Outage	06-01-2026	11:21	06-01-2026	14:07	2:46	0.002398	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
481	07-01-2026	Part of : HARKESH NAGAR,POCKET A & Y SANJAY COLONY,POCKET Z OKHLA INDUSTRIAL AREA PHASE-2	4144	Other Outage	Unplanned Outage	07-01-2026	15:23	07-01-2026	15:43	0:20	0.000422	CABLE FAULT
482	07-01-2026	Part of : BLOCK D EAST OF KAILASH	480	Other Outage	Planned Outage	07-01-2026	09:48	07-01-2026	12:31	2:43	0.002490	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
483	08-01-2026	Part of : KRISHI VIHAR GREATER KAILASH	157	Other Outage	Planned Outage	08-01-2026	11:49	08-01-2026	15:22	3:33	0.003077	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
484	08-01-2026	Part of : BLOCK A EAST OF KAILASH	343	Other Outage	Planned Outage	08-01-2026	09:46	08-01-2026	13:44	3:58	0.003636	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
485	09-01-2026	Part of : BLOCK W GREATER KAILASH I GREATER KAILASH,SIRI FORT	931	Other Outage	Unplanned Outage	09-01-2026	18:28	09-01-2026	19:16	0:48	0.001480	CABLE FAULT
486	09-01-2026	Part of : KALASH ENCLAVE GREATER KAILASH,KAILASH COLONY GREATER KAILASH,BLOCK B ZAMRUDPUR VILLAGE GREATER KAILASH	1495	Other Outage	Unplanned Outage	09-01-2026	09:31	09-01-2026	10:05	0:34	0.000774	CABLE FAULT
487	10-01-2026	PART OF : NEHRU PLACE	71	Other Outage	Planned Outage	10-01-2026	10:59	10-01-2026	13:00	2:01	0.001748	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
488	11-01-2026	Part of : NEHRU PLACE	1	Other Outage	Unplanned Outage	11-01-2026	12:49	11-01-2026	15:02	2:13	0.001921	REPAIRING OF RMU
489	11-01-2026	Part of : NEHRU PLACE	1	Other Outage	Unplanned Outage	11-01-2026	12:46	11-01-2026	15:02	2:16	0.001964	REPAIRING OF RMU
490	11-01-2026	Part of : POCKET D OKHLA INDUSTRIAL AREA PHASE-2	16	Other Outage	Planned Outage	11-01-2026	11:21	11-01-2026	15:44	4:23	0.002557	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
491	11-01-2026	Part of : NEHRU PLACE	56	Other Outage	Planned Outage	11-01-2026	11:21	11-01-2026	13:54	2:33	0.002210	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
492	12-01-2026	Part of : BLOCK G KAILASH HILL EAST OF KAILASH	248	Other Outage	Planned Outage	12-01-2026	10:24	12-01-2026	13:23	2:59	0.001989	REPLACEMET OF LUGS,SUB STATION CLEANING
493	13-01-2026	Part of : BLOCK B EAST OF KAILASH	311	Other Outage	Planned Outage	13-01-2026	13:18	13-01-2026	14:51	1:33	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
494	14-01-2026	Part of : A BLOCK APB GARHI EAST OF KAILASH	1595	Other Outage	Planned Outage	14-01-2026	10:00	14-01-2026	12:29	2:29	0.002276	REPLACEMENT OF GAS KIT AND OIL SEAL
495	15-01-2026	Part of : MASJID MOTH PHASE I GREATER KAILASH	177	Other Outage	Planned Outage	15-01-2026	11:16	15-01-2026	14:21	3:05	0.002672	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
496	16-01-2026	Part of : PUNJABI BAGH EXTENSION	645	Other Outage	Planned Outage	16-01-2026	10:08	16-01-2026	14:47	4:39	0.004030	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
497	17-01-2026	Part of : NEHRU PLACE	170	Other Outage	Planned Outage	17-01-2026	10:48	17-01-2026	13:12	2:24	0.002080	MAINTENANCE OF TRANSFORMER
498	17-01-2026	Part of : NATIONAL PARK LAJPAT NAGAR	71	Other Outage	Planned Outage	17-01-2026	10:00	17-01-2026	12:38	2:38	0.001975	MAINTENANCE OF TRANSFORMER
499	18-01-2026	Part of : POCKET Z OKHLA PHASE II OKHLA INDUSTRIAL AREA	48	Other Outage	Planned Outage	18-01-2026	11:06	18-01-2026	15:08	4:02	0.002689	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
500	18-01-2026	Part of : BUILDING NO.-13 NEHRU PLACE	98	Other Outage	Planned Outage	18-01-2026	11:13	18-01-2026	15:54	4:41	0.004059	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER
501	19-01-2026	Part of : MASJID MOTH PHASE-1 GREATER KAILASH	89	Other Outage	Planned Outage	19-01-2026	10:41	19-01-2026	13:59	3:18	0.002860	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
502	20-01-2026	Part of : DEVIKA TOWER, BUILDING NO.- 20 & 28 NEHRU PLACE, MINIMAL HOSPITAL, (HTC), PARAS CINEMA NEHRU PLACE (HTC)	420	Other Outage	Unplanned Outage	20-01-2026	09:31	20-01-2026	10:20	0:49	0.000742	FAULT IN HT CONSUMER PANEL (MINIMAL HOSPITAL)
503	20-01-2026	Part of : BLOCK M GREATER KAILASH I	76	Other Outage	Planned Outage	20-01-2026	11:29	20-01-2026	14:04	2:35	0.002239	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
504	20-01-2026	Part of : BLOCK D EAST OF KAILASH	142	Other Outage	Planned Outage	20-01-2026	09:59	20-01-2026	12:41	2:42	0.002340	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
505	21-01-2026	Part of : POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA,BLOCK A OKHLA PHASE II OKHLA INDUSTRIAL AREA	725	Other Outage	Unplanned Outage	21-01-2026	13:33	21-01-2026	14:24	0:51	0.000468	CABLE FAULT
506	21-01-2026	Part of : SANT NAGAR EAST OF KAILASH,BLOCK D EAST OF KAILASH	3165	Other Outage	Unplanned Outage	21-01-2026	12:01	21-01-2026	13:13	1:12	0.000870	DISTRIBUTION TRANSFORMER FAULTY
507	21-01-2026	Part of : BLOCK S GREATER KAILASH I GREATER KAILASH,	647	Other Outage	Planned Outage	21-01-2026	10:54	21-01-2026	14:42	3:48	0.003293	TRANSFORMER MAINTENANCE
508	21-01-2026	Part of : BLOCK B DAYANAND COLONY LAJPAT NAGAR,	548	Other Outage	Planned Outage	21-01-2026	09:59	21-01-2026	12:43	2:44	0.002369	TRANSFORMER MAINTENANCE
509	22-01-2026	Part of : BLOCK A OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA	725	Other Outage	Unplanned Outage	22-01-2026	17:11	22-01-2026	18:05	0:54	0.000615	CABLE FAULT
510	22-01-2026	Part of : BLOCK C GREATER KAILASH I GREATER KAILASH	716	Other Outage	Unplanned Outage	22-01-2026	15:07	22-01-2026	15:59	0:52	0.000560	HT SYSTEM FAULT
511	22-01-2026	Part of : BLOCK N GREATER KAILASH I GREATER KAILASH	215	Other Outage	Planned Outage	22-01-2026	11:30	22-01-2026	12:25	0:55	0.000794	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
512	23-01-2026	Part of : E-BLOCK EAST OF KAILASH	673	Other Outage	Planned Outage	23-01-2026	10:00	23-01-2026	12:15	2:15	0.001950	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
513	24-01-2026	Part of : NATIONAL PARK LAJPAT NAGAR	34	Other Outage	Planned Outage	24-01-2026	10:22	24-01-2026	13:47	3:25	0.002563	REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
514	24-01-2026	Part of : NEHRU PLACE	137	Other Outage	Planned Outage	24-01-2026	10:31	24-01-2026	12:57	2:26	0.002109	CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
515	25-01-2026	Part of : BLOCK W GREATER KAILASH I GREATER KAILASH,SIRI FORT	931	Other Outage	Unplanned Outage	25-01-2026	10:01	25-01-2026	10:53	0:52	0.001115	CABLE FAULT
516	25-01-2026	Part of : NEHRU PLACE	74	Other Outage	Planned Outage	25-01-2026	12:39	25-01-2026	14:07	1:28	0.001271	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
517	25-01-2026	Part of : POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA	95	Other Outage	Planned Outage	25-01-2026	10:39	25-01-2026	14:12	3:33	0.002367	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
518	27-01-2026	Part of : POCKET B,D,E & W OKHLA INDUSTRIAL AREA PHASE-2	1	Other Outage	Unplanned Outage	27-01-2026	04:00	27-01-2026	04:49	0:49	0.000000	CABLE FAULT
519	27-01-2026	Part of : BUILDING NO.-13,14,15 & 98, TELEPHONE EX.NEHRU PLACE	535	Other Outage	Unplanned Outage	27-01-2026	02:01	27-01-2026	03:13	1:12	0.000109	CABLE FAULT
520	28-01-2026	Part of : KALASH ENCLAVE GREATER KAILASH,KAILASH COLONY,BLOCK B ZAMRUDPUR VILLAGE	1500	Other Outage	Unplanned Outage	28-01-2026	14:35	28-01-2026	15:56	1:21	0.000720	SHIFTING OF CABLE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
521	28-01-2026	Part of : BLOCK W GREATER KAILASH I	213	Other Outage	Planned Outage	28-01-2026	10:48	28-01-2026	14:41	3:53	0.003366	REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
522	29-01-2026	Part of : KALASH ENCLAVE GREATER KAILASH,KAILASH COLONY GREATER KAILASH,BLOCK B ZAMRUPUR VILLAGE GREATER KAILASH,	1502	Other Outage	Planned Outage	29-01-2026	11:21	29-01-2026	13:40	2:19	0.000386	SUB STATION CLEANING
523	29-01-2026	Part of : BLOCK A GREATER KAILASH I GREATER KAILASH,	36	Other Outage	Planned Outage	29-01-2026	11:22	29-01-2026	13:41	2:19	0.002008	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
524	31-01-2026	Part of : E-BLOCK EAST OF KAILASH	668	Other Outage	Planned Outage	31-01-2026	10:20	31-01-2026	11:35	1:15	0.001083	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
525	02-01-2026	Part of : BLOCK G LAJPAT NAGAR I LAJPAT NAGAR	389	Other Outage	Planned Outage	02-01-2026	12:21	02-01-2026	16:00	3:39	0.000730	REPLACEMENT OF LT BUSHING ROD
526	02-01-2026	Part of : POCKET C SIDDHARTHA NAGAR	881	Other Outage	Planned Outage	02-01-2026	12:36	02-01-2026	15:42	3:06	0.001550	REPLACEMENT OF HT BUSHING ROD
527	02-01-2026	Part of : NIZAMUDDIN WEST	619	Other Outage	Planned Outage	02-01-2026	11:45	02-01-2026	15:29	3:44	0.001867	REPLACEMENT OF HT BUSHING ROD
528	02-01-2026	Part of : BLOCK F LAJPAT NAGAR III LAJPAT NAGAR	316	Other Outage	Planned Outage	02-01-2026	11:35	02-01-2026	15:31	3:56	0.000656	REPLACEMENT OF HT BUSHING ROD
529	02-01-2026	Part of : KASTURBA NAGAR SEWA NAGAR	64	Other Outage	Planned Outage	02-01-2026	11:36	02-01-2026	15:27	3:51	0.000963	REPLACEMENT OF LT BUSHING ROD
530	02-01-2026	Part of : BLOCK B DEFENCE COLONY	154	Other Outage	Planned Outage	02-01-2026	11:40	02-01-2026	15:28	3:48	0.000633	REPLACEMENT OF HT BUSHING ROD
531	03-01-2026	Part of : GPO N.O-1 (HT CONSUMER)	0	Other Outage	Unplanned Outage	03-01-2026	17:04	03-01-2026	17:47	0:43	0.000096	FAULT IN HT CONSUMER PANEL (GPO N.O-1)
532	03-01-2026	Part of : CGO COMPLEX PRAGATI VIHAR	3	Other Outage	Planned Outage	03-01-2026	11:30	03-01-2026	13:33	2:03	0.000342	REPLACEMENT OF HT BUSHING ROD
533	03-01-2026	Part of : BLOCKA, B & D SARAI KALE KHAN	2793	Other Outage	Planned Outage	03-01-2026	11:31	03-01-2026	15:02	3:31	0.007326	GUARD WIRE LACS INSTALLTION
534	03-01-2026	Part of : BLOCK E LAJPAT NAGAR-3	422	Other Outage	Planned Outage	03-01-2026	11:04	03-01-2026	15:27	4:23	0.000877	REPLACEMENT OF HT BUSHING ROD
535	05-01-2026	Part of : BLOCK B SEWA NAGAR,BLOCK M SEWA NAGAR,KASTURBA NAGAR SEWA NAGAR	2802	Other Outage	Unplanned Outage	05-01-2026	17:19	05-01-2026	18:10	0:51	0.000836	CABLE FAULT
536	05-01-2026	Part of : RISHI NAGAR SOUTH EXTENSION PART 1,	226	Other Outage	Planned Outage	05-01-2026	11:45	05-01-2026	14:24	2:39	0.000442	MAINTENANCE OF TRANSFORMER
537	05-01-2026	Part of : NIZAMUDDIN WEST,	669	Other Outage	Planned Outage	05-01-2026	11:30	05-01-2026	14:27	2:57	0.000738	MAINTENANCE OF TRANSFORMER
538	05-01-2026	Part of : BLOCK C SOUTH EXTENSION PART 1,	175	Other Outage	Planned Outage	05-01-2026	11:34	05-01-2026	15:19	3:45	0.000625	MAINTENANCE OF TRANSFORMER
539	05-01-2026	Part of : ISBT SARAI KALE KHAN SARAI KALE KHAN,	1	Other Outage	Planned Outage	05-01-2026	11:32	05-01-2026	14:09	2:37	0.001308	MAINTENANCE OF TRANSFORMER
540	05-01-2026	Part of : JAL VIHAR,	240	Other Outage	Planned Outage	05-01-2026	11:22	05-01-2026	15:35	4:13	0.001827	MAINTENANCE OF TRANSFORMER
541	06-01-2026	Part of : GAS TURBINE POWER STATION IP ESTATE	8	Other Outage	Planned Outage	06-01-2026	12:41	06-01-2026	15:42	3:01	0.001106	RELAY REPLACEMENT/VPI/FPI
542	06-01-2026	Part of : BLOCK H LAJPAT NAGAR II LAJPAT NAGAR,BLOCK L LAJPAT NAGAR II LAJPAT NAGAR	788	Other Outage	Planned Outage	06-01-2026	11:21	06-01-2026	16:01	4:40	0.002722	REPLACEMENT OF HT BUSHING ROD
543	07-01-2026	Part of : VIDYUT VIHAR PHASE 1 SUNLIGHT COLONY	240	Other Outage	Unplanned Outage	07-01-2026	14:39	07-01-2026	15:59	1:20	0.000000	REPAIRING OF RMU
544	07-01-2026	Part of : BLOCK H SOUTH EXTENSION PART 1	1553	Other Outage	Planned Outage	07-01-2026	11:40	07-01-2026	15:48	4:08	0.001722	REPLACEMENT OF HT BUSHING ROD
545	07-01-2026	Part of : JAL VIHAR	579	Other Outage	Planned Outage	07-01-2026	11:46	07-01-2026	16:23	4:37	0.003078	REPLACEMENT OF HT BUSHING ROD
546	08-01-2026	Part of : WAZIR NAGAR SOUTH EXTENSION PART 1	670	Other Outage	Planned Outage	08-01-2026	12:17	08-01-2026	16:33	4:16	0.000853	REPLACEMET OF HT BUSHING ROD
547	09-01-2026	Part of : BAPU PARK KOTLA MUBARAKPUR SOUTH EXTENSION PART 1,	1516	Other Outage	Planned Outage	09-01-2026	11:49	09-01-2026	14:53	3:04	0.001022	MAINTENANCE OF TRANSFORMER
548	09-01-2026	Part of : BLOCK H LAJPAT NAGAR II LAJPAT NAGAR,BLOCK L LAJPAT NAGAR II LAJPAT NAGAR,	788	Other Outage	Planned Outage	09-01-2026	10:59	09-01-2026	13:59	3:00	0.000600	MAINTENANCE OF TRANSFORMER
549	09-01-2026	Part of : BLOCK J SOUTH EXTENSION PART 1,	342	Other Outage	Planned Outage	09-01-2026	11:01	09-01-2026	14:02	3:01	0.001508	MAINTENANCE OF TRANSFORMER
550	10-01-2026	Part of : RISHI NAGAR SOUTH EXTENSION PART 1,PREM NAGAR BK DUTT COLONY	2137	Other Outage	Unplanned Outage	10-01-2026	15:58	10-01-2026	16:50	0:52	0.000433	CABLE FAULT
551	10-01-2026	PART OF : BLOCK F LAJPAT NAGAR II LAJPAT NAGAR	629	Other Outage	Planned Outage	10-01-2026	10:57	10-01-2026	12:39	1:42	0.000397	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
552	10-01-2026	PART OF : CGO COMPLEX PRAGATI VIHAR	271	Other Outage	Planned Outage	10-01-2026	11:46	10-01-2026	14:33	2:47	0.000232	REPLACEMENT OF HT BUSHING ROD
553	10-01-2026	PART OF : BLOCK E NIZAMUDDIN WEST	242	Other Outage	Planned Outage	10-01-2026	10:59	10-01-2026	14:54	3:55	0.000653	REPLACEMENT OF HT BUSHING ROD
554	12-01-2026	Part of : NATIONAL ZOOLOGICAL PARK SUNDAR NAGAR	73	Other Outage	Planned Outage	12-01-2026	12:45	12-01-2026	15:37	2:52	0.000478	REPLACEMET OF HT BUSHING ROD
555	12-01-2026	Part of : VIDYUT VIHAR PHASE 1 SUNLIGHT COLONY	151	Other Outage	Planned Outage	12-01-2026	11:36	12-01-2026	13:58	2:22	0.004339	JUMPER REPLACEMENT PER POLE
556	12-01-2026	Part of : BLOCK M LAJPAT NAGAR III	374	Other Outage	Planned Outage	12-01-2026	11:19	12-01-2026	14:54	3:35	0.001553	REPLACEMET OF HT BUSHING ROD
557	13-01-2026	Part of : INA TYPE A QUARTERS INA COLONY,AVIATION COLONY INA COLONY,INA COLONY	1084	Other Outage	Unplanned Outage	13-01-2026	23:43	14-01-2026	00:05	0:22	0.000215	CABLE FAULT
558	14-01-2026	Part of : B BLOCK SEWA NAGAR,BLOCK M SEWA NAGAR,KASTURBA NAGAR SEWA NAGAR	2809	Other Outage	Unplanned Outage	14-01-2026	15:54	14-01-2026	16:47	0:53	0.000780	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
559	15-01-2026	Part of : CGO COMPLEX PRAGATI VIHAR	3	Other Outage	Unplanned Outage	15-01-2026	18:03	15-01-2026	18:52	0:49	0.001089	FAULT IN HT CONSUMER PANEL (CGO COMPLEX)
560	15-01-2026	Part of : BLOCK F LAJPAT NAGAR-3	152	Other Outage	Planned Outage	15-01-2026	12:37	15-01-2026	15:39	3:02	0.000708	REPLACEMENT OF GAS KIT AND OIL SEAL
561	15-01-2026	Part of : SUNDAR NAGAR	94	Other Outage	Planned Outage	15-01-2026	12:01	15-01-2026	14:39	2:38	0.001317	REPLACEMET OF HT BUSHING ROD
562	15-01-2026	Part of : GAS TURBINE POWER STATION IP ESTATE	1	Other Outage	Planned Outage	15-01-2026	11:59	15-01-2026	14:33	2:34	0.000086	REPLACEMET OF HT BUSHING ROD
563	15-01-2026	Part of : MAHAVEER NAGAR BHOLA NAGAR SOUTH EXTENSION PART 1	535	Other Outage	Planned Outage	15-01-2026	11:13	15-01-2026	13:19	2:06	0.000630	REPLACEMET OF HT BUSHING ROD
564	16-01-2026	Part of : BLOCK BA TAGORE GARDEN EXTENSION	372	Other Outage	Planned Outage	16-01-2026	11:02	16-01-2026	13:59	2:57	0.000983	REPLACEMET OF HT BUSHING ROD
565	17-01-2026	Part of : INA COLONY	7	Other Outage	Planned Outage	17-01-2026	10:58	17-01-2026	15:15	4:17	0.000714	MAINTENANCE OF TRANSFORMER
566	17-01-2026	Part of : NATIONAL ZOOLOGICAL PARK SUNDAR NAGAR	63	Other Outage	Planned Outage	17-01-2026	10:59	17-01-2026	14:21	3:22	0.001683	MAINTENANCE OF TRANSFORMER
567	17-01-2026	Part of : VIDYUT VIHAR PHASE 1 SUNLIGHT COLONY	151	Other Outage	Planned Outage	17-01-2026	10:31	17-01-2026	14:01	3:30	0.006417	MAINTENANCE OF HT O/H CIRCUIT
568	18-01-2026	Part of : NCRTC RESIDENTIAL COMPLEX JANGPURA (HTC)	0	Other Outage	Unplanned Outage	18-01-2026	13:46	18-01-2026	15:25	1:39	0.001843	HT SYSTEM FAULT
569	18-01-2026	Part of : AFCONS NCRTC RRTS PROJECT, HPL STAFF COLONY JUNG PURA A	0	Other Outage	Unplanned Outage	18-01-2026	13:44	18-01-2026	15:14	1:30	0.003100	HT SYSTEM FAULT
570	19-01-2026	Part of : BLOCK E LAJPAT NAGAR-1	452	Other Outage	Planned Outage	19-01-2026	11:06	19-01-2026	14:02	2:56	0.000978	REPLACEMET OF HT BUSHING ROD
571	21-01-2026	Part of : BLOCK P JANGUPURA EXTENSION JANGPURA,BLOCK D JANGUPURA EXTENSION JANGPURA,RAILWAY STATION LAJPAT NAGAR	2410	Other Outage	Unplanned Outage	21-01-2026	16:16	21-01-2026	17:02	0:46	0.000000	CABLE FAULT
572	22-01-2026	Part of : BLOCK D SARAI KALE KHAN VILLAGE SARAI KALE KHAN,BLOCK B SARAI KALE KHAN,BLOCK A GANGA VIHAR SARAI KALE KHAN	1735	Other Outage	Unplanned Outage	22-01-2026	17:13	22-01-2026	17:47	0:34	0.000175	CABLE FAULT
573	23-01-2026	Part of : NIZAMUDDIN EAST,A & B-BLOCK SARAI KALE KHAN,BEHLLOLPUR BANGAR SARAI KALE KHAN	3061	Other Outage	Unplanned Outage	23-01-2026	12:10	23-01-2026	12:43	0:33	0.001155	CABLE FAULT
574	24-01-2026	Part of : BLOCK D DEFENCE COLONY	91	Other Outage	Planned Outage	24-01-2026	11:47	24-01-2026	16:41	4:54	0.000980	DT REPLACEMENT
575	24-01-2026	Part of : KILOKARI PHASE 1 SUNLIGHT COLONY	1047	Other Outage	Planned Outage	24-01-2026	11:32	24-01-2026	14:05	2:33	0.000935	REPLACEMET OF HT BUSHING ROD
576	28-01-2026	Part of : BLOCK F LAJPAT NAGAR II	629	Other Outage	Planned Outage	28-01-2026	12:04	28-01-2026	14:58	2:54	0.000677	REPLACEMENT OF LT BUSHING ROD
577	30-01-2026	Part of : BLOCK M JANGUPURA EXTENSION JANGPURA	349	Other Outage	Planned Outage	30-01-2026	11:33	30-01-2026	14:09	2:36	0.001170	REPLACEMENT OF HT BUSHING ROD
578	31-01-2026	Part of : BHAGAWAN NAGAR PHASE 2, SUNLIGHT COLONY	1056	Other Outage	Planned Outage	31-01-2026	11:04	31-01-2026	12:28	1:24	0.001750	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER
579	02-01-2026	Part of : CAMP COMMANDT AIR HQ,WEST BLK-VI (HTC)	1	Other Outage	Planned Outage	02-01-2026	12:50	02-01-2026	14:04	1:14	0.000308	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
580	02-01-2026	Part of : EAST BLOCK ADARSH BASTI RAMAKRISHNA PURAM	2	Other Outage	Planned Outage	02-01-2026	10:59	02-01-2026	12:52	1:53	0.000628	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF LT BUSHING ROD
581	03-01-2026	Part of : DHAULA KUAN ENCLAVE	41	Other Outage	Planned Outage	03-01-2026	11:05	03-01-2026	14:16	3:11	0.000478	REPLACEMENT OF HT BUSHING ROD
582	03-01-2026	Part of : VASANT ENCLAVE VASANT VIHAR	1156	Other Outage	Planned Outage	03-01-2026	10:38	03-01-2026	14:25	3:47	0.008197	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
583	04-01-2026	Part of : MUNIRKA VIHAR,BLOCK A & F MUNIRKA	4186	Other Outage	Planned Outage	04-01-2026	11:17	04-01-2026	14:59	3:42	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
584	05-01-2026	Part of : SATYA NIKETAN MOTI BAGH SOUTH,	341	Other Outage	Planned Outage	05-01-2026	10:28	05-01-2026	11:35	1:07	0.000223	MAINTENANCE OF TRANSFORMER
585	06-01-2026	Part of : HYATT HOTEL, B.C.PLACE (HTC)	1	Other Outage	Planned Outage	06-01-2026	11:53	06-01-2026	12:19	0:26	0.000072	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
586	06-01-2026	Part of : BLOCK H NANAKPURA MOTI BAGH SOUTH	1086	Other Outage	Planned Outage	06-01-2026	11:20	06-01-2026	13:11	1:51	0.000123	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
587	06-01-2026	Part of : BASANT LOK VASANT VIHAR	39	Other Outage	Planned Outage	06-01-2026	10:59	06-01-2026	13:59	3:00	0.001250	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
588	07-01-2026	Part of : BLOCK D 2 WEST END COLONY	67	Other Outage	Planned Outage	07-01-2026	11:05	07-01-2026	12:42	1:37	0.000216	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
589	07-01-2026	Part of : NIVEDITA KUNJ SECTOR 10 RAMAKRISHNA PURAM	61	Other Outage	Planned Outage	07-01-2026	11:20	07-01-2026	14:00	2:40	0.001556	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
590	08-01-2026	Part of : WEST BLOCK RAMAKRISHNA PURAM	94	Other Outage	Planned Outage	08-01-2026	11:32	08-01-2026	14:29	2:57	0.001721	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF BUS BAR
591	08-01-2026	Part of : CGHC COLONY VASANT VIHAR	132	Other Outage	Planned Outage	08-01-2026	10:44	08-01-2026	15:41	4:57	0.001650	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS
592	09-01-2026	Part of : POLICE COLONY SECTOR 12 RAMAKRISHNA PURAM,	72	Other Outage	Unplanned Outage	09-01-2026	11:54	09-01-2026	14:10	2:16	0.000189	MOBILE TRANSFORMER REPLACEMENT
593	09-01-2026	Part of : NIVEDITA KUNJ SECTOR 10 RAMAKRISHNA PURAM,	164	Other Outage	Planned Outage	09-01-2026	11:40	09-01-2026	14:21	2:41	0.000447	MAINTENANCE OF HT O/H CIRCUIT
594	10-01-2026	Part of : BLOCK D 2 WEST END,BLOCK C WEST END,BLOCK A WEST END,SECTOR 2 SHANTI NIKETAN,SECTOR 1 SHANTI NIKETAN	821	Other Outage	Unplanned Outage	10-01-2026	16:10	10-01-2026	17:02	0:52	0.001401	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
595	10-01-2026	Part of : SUBROTO PARK,JHARERA VILLAGE ASMARA LINES DELHI CANTONMENT,POCKET 2 SECTOR 2 DWARKA	2703	Other Outage	Unplanned Outage	10-01-2026	12:58	10-01-2026	13:47	0:49	0.001021	CABLE FAULT
596	10-01-2026	PART OF : BHIKAJI CAMA PLACE RAMAKRISHNA PURAM	99	Other Outage	Planned Outage	10-01-2026	15:45	10-01-2026	17:13	1:28	0.000733	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
597	10-01-2026	PART OF : SOUTH CAMPUS MOTI BAGH SOUTH	1	Other Outage	Planned Outage	10-01-2026	14:09	10-01-2026	15:25	1:16	0.000084	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
598	10-01-2026	PART OF : SOUTH CAMPUS MOTI BAGH SOUTH	4	Other Outage	Planned Outage	10-01-2026	12:15	10-01-2026	13:21	1:06	0.000110	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF HT BUSHING ROD
599	10-01-2026	PART OF : MOHAMMADPUR RAMAKRISHNA PURAM	607	Other Outage	Planned Outage	10-01-2026	11:06	10-01-2026	14:26	3:20	0.000833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
600	10-01-2026	PART OF : BLOCK B VASANT VIHAR	288	Other Outage	Planned Outage	10-01-2026	10:18	10-01-2026	13:56	3:38	0.002119	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
601	12-01-2026	Part of : MOTILAL NEHRU COLLEGE (HTC)	1	Other Outage	Planned Outage	12-01-2026	11:14	12-01-2026	12:00	0:46	0.000051	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
602	12-01-2026	Part of : GURUDWARA MOTIBAGH (HTC)	1	Other Outage	Planned Outage	12-01-2026	14:45	12-01-2026	15:49	1:04	0.000089	REPLACEMENT OF GAS KIT AND OIL SEAL
603	12-01-2026	Part of : JHARERA VILLAGE ASMARA LINES DELHI CANTONMENT	473	Other Outage	Planned Outage	12-01-2026	15:11	12-01-2026	16:41	1:30	0.000000	GUARD WIRES SAGGING PER SPAN,TAPPING OF JUMPERS
604	12-01-2026	Part of : RAMA COLONY RAMAKRISHNA PURAM	170	Other Outage	Planned Outage	12-01-2026	11:01	12-01-2026	14:28	3:27	0.001150	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS
605	12-01-2026	Part of : MUNIRKA ENCLAVE	701	Other Outage	Planned Outage	12-01-2026	10:52	12-01-2026	14:20	3:28	0.004044	REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
606	13-01-2026	Part of : BLOCK BD MUNIRKA,BLOCK BC MUNIRKA	539	Other Outage	Planned Outage	13-01-2026	11:03	13-01-2026	14:40	3:37	0.003315	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
607	13-01-2026	Part of : BLOCK E MOTI BAGH SOUTH	1106	Other Outage	Planned Outage	13-01-2026	10:04	13-01-2026	13:27	3:23	0.000677	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
608	14-01-2026	Part of : HTC:PWD DHAULA KUAN FLYOVER	1	Other Outage	Planned Outage	14-01-2026	11:59	14-01-2026	13:38	1:39	0.000165	REPLACEMENT OF GAS KIT AND OIL SEAL
609	14-01-2026	Part of : RAMA COLONY RAMAKRISHNA PURAM	202	Other Outage	Planned Outage	14-01-2026	11:14	14-01-2026	14:49	3:35	0.001194	REPLACEMENT OF HT/LT CLEATS & OIL TOP UP IN TRANSFORMER
610	15-01-2026	Part of : 6 DAKSHINPURI	1	Other Outage	Planned Outage	15-01-2026	11:23	15-01-2026	13:45	2:22	0.000316	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
611	15-01-2026	Part of : BLOCK F MUNIRKA	507	Other Outage	Planned Outage	15-01-2026	10:49	15-01-2026	14:34	3:45	0.003750	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD
612	16-01-2026	Part of : BLOCK B ANAND NIKETAN	281	Other Outage	Planned Outage	16-01-2026	14:05	16-01-2026	15:05	1:00	0.000200	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
613	16-01-2026	Part of : VASANT ENCLAVE VASANT VIHAR	1	Other Outage	Planned Outage	16-01-2026	14:29	16-01-2026	16:50	2:21	0.000000	DT REPLACEMENT
614	16-01-2026	Part of : PREM NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	187	Other Outage	Planned Outage	16-01-2026	11:01	16-01-2026	16:21	5:20	0.002667	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD
615	16-01-2026	Part of : BLOCK A HAUZ KHAS	128	Other Outage	Planned Outage	16-01-2026	11:02	16-01-2026	15:34	4:32	0.001662	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
616	16-01-2026	Part of : POCKET B JAWAHAR PARK KHANPUR,DURGA VIHAR DEVLII SANGAM VIHAR	341	Other Outage	Planned Outage	16-01-2026	10:20	16-01-2026	13:16	2:56	0.000587	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
617	17-01-2026	Part of : HTC:AUGUST KRANTI	1	Other Outage	Planned Outage	17-01-2026	11:09	17-01-2026	13:07	1:58	0.000262	MAINTENANCE OF TRANSFORMER
618	17-01-2026	Part of : HTC:MISO SEWA BHAWAN, WEST BLK, R.K.PURAM	1	Other Outage	Planned Outage	17-01-2026	14:52	17-01-2026	17:34	2:42	0.000000	MAINTENANCE OF RMU
619	17-01-2026	Part of : HTC:TRIKOOT NO.-3, B.C.PLACE	1	Other Outage	Planned Outage	17-01-2026	13:52	17-01-2026	16:04	2:12	0.000183	MAINTENANCE OF TRANSFORMER
620	18-01-2026	Part of : MES B.I.LINES (HTC)	1	Other Outage	Planned Outage	18-01-2026	11:18	18-01-2026	16:14	4:56	0.004522	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
621	19-01-2026	Part of : B H-BLOCK MUNIRKA	3506	Other Outage	Unplanned Outage	19-01-2026	09:49	19-01-2026	10:42	0:53	0.001295	CABLE FAULT
622	19-01-2026	Part of : JINDAL STRIPS B.C.PLACE	1	Other Outage	Planned Outage	19-01-2026	11:45	19-01-2026	14:06	2:21	0.000196	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
623	20-01-2026	Part of : IGL RKPURAM, SEC-3 NEAR OUTER RING ROAD	1	Other Outage	Planned Outage	20-01-2026	11:31	20-01-2026	13:44	2:13	0.000296	INSTALLATION OF HT BOOTS,REPLACEMET OF HT BUSHING ROD
624	20-01-2026	Part of : BLOCK A MUNIRKA	104	Other Outage	Planned Outage	20-01-2026	10:40	20-01-2026	15:00	4:20	0.006139	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
625	21-01-2026	Part of : HTC:EIL (MAIN) B.C.PLACE	1	Other Outage	Planned Outage	21-01-2026	12:40	21-01-2026	14:32	1:52	0.000622	TRANSFORMER MAINTENANCE
626	22-01-2026	Part of : SECTOR 3 RAMAKRISHNA PURAM, IGL (HTC)	1461	Other Outage	Unplanned Outage	22-01-2026	11:13	22-01-2026	11:49	0:36	0.000304	FAULT IN HT CONSUMER PANEL (IGL)
627	22-01-2026	Part of : MUNIRKA ENCLAVE MUNIRKA	627	Other Outage	Planned Outage	22-01-2026	10:46	22-01-2026	17:12	6:26	0.008578	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
628	23-01-2026	Part of : B & E-BLOCK VASANT VIHAR	874	Other Outage	Unplanned Outage	23-01-2026	21:10	23-01-2026	21:56	0:46	0.002491	CABLE FAULT
629	24-01-2026	Part of : PCRA BHAWAN BLDG.NO-10 (HT CONSUMER)	1	Other Outage	Planned Outage	24-01-2026	14:46	24-01-2026	15:44	0:58	0.000129	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
630	24-01-2026	Part of : NEAR HUDCO VISHALA PLOT NO-14 B.C.PLACE	1	Other Outage	Planned Outage	24-01-2026	12:12	24-01-2026	13:57	1:45	0.000146	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
631	24-01-2026	Part of : BASANT LOK VASANT VIHAR	675	Other Outage	Planned Outage	24-01-2026	12:28	24-01-2026	15:18	2:50	0.000472	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
632	26-01-2026	Part of : EIL (ANNEXE) B.C.PLACE (HT CONSUMER)	1	Other Outage	Planned Outage	26-01-2026	11:17	26-01-2026	12:39	1:22	0.000569	REPLACEMENT OF LT BUSHING ROD, GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD
633	27-01-2026	Part of : BASANT LOK VASANT VIHAR	309	Other Outage	Unplanned Outage	27-01-2026	12:21	27-01-2026	13:32	1:11	0.000000	DIGGING ON CABLE ROUTE
634	27-01-2026	Part of : ASIAN NEWS INTERNATIONAL SEC-9 RKP (HT CONSUMER)	1	Other Outage	Planned Outage	27-01-2026	13:56	27-01-2026	15:06	1:10	0.000194	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD
635	27-01-2026	Part of : SANGAM CINEMA SECTOR-9 R.K.PURAM (HT CONSUMER)	1	Other Outage	Planned Outage	27-01-2026	10:52	27-01-2026	12:36	1:44	0.000231	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
636	27-01-2026	Part of : VASANT ENCLAVE VASANT VIHAR	610	Other Outage	Planned Outage	27-01-2026	10:42	27-01-2026	14:05	3:23	0.002256	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
637	28-01-2026	Part of : SECTOR 5 & 6 R.K PURAM,SONIA GANDHI CAMP,RBI COLONY, VAN VIGAYAN BHAWAN SECTOR-5 R.K PURAM (HTC)	1826	Other Outage	Unplanned Outage	28-01-2026	17:19	28-01-2026	18:05	0:46	0.000441	CABLE FAULT
638	28-01-2026	Part of : EIL B.C.PLACE (HTC)	1	Other Outage	Planned Outage	28-01-2026	11:21	28-01-2026	14:02	2:41	0.000358	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT/LT CLEATS
639	29-01-2026	Part of : HTC:DENTAL COUNCIL OF INDIA	1	Other Outage	Planned Outage	29-01-2026	10:56	29-01-2026	12:48	1:52	0.000156	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
640	29-01-2026	Part of : HTC:TAMIL SANGAM, SECTOR-5, R.K.PURAM	1	Other Outage	Planned Outage	29-01-2026	14:31	29-01-2026	17:04	2:33	0.000213	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
641	29-01-2026	Part of : VASANT ENCLAVE VASANT VIHAR,	46	Other Outage	Planned Outage	29-01-2026	10:37	29-01-2026	13:17	2:40	0.001333	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,TIGHTENEING OF NUT BOLT
642	30-01-2026	Part of : BLOCK C MOTI BAGH SOUTH MARKET MOTI BAGH SOUTH	457	Other Outage	Planned Outage	30-01-2026	12:06	30-01-2026	13:29	1:23	0.000369	END TERMINATION COVER REPLACEMENT,REPLACEMENT OF FAULTY END BOX
643	31-01-2026	Part of : INDIAN AIR LINES AND AIR INDIA ESTATE VASANT VIHAR	5	Other Outage	Planned Outage	31-01-2026	10:22	31-01-2026	13:26	3:04	0.001022	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
644	01-01-2026	Part of : BLOCK L MALVIYA NAGAR,	2252	Other Outage	Planned Outage	01-01-2026	10:32	01-01-2026	11:32	1:00	0.000000	REPLACMET OF HT BUSHING ROD
645	01-01-2026	Part of : BLOCK H SAKET,	501	Other Outage	Planned Outage	01-01-2026	11:09	01-01-2026	13:58	2:49	0.004694	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS,TIGHTENEING OF NUT BOLT
646	01-01-2026	Part of : BLOCK E SAINIK FARM,	29	Other Outage	Planned Outage	01-01-2026	11:34	01-01-2026	14:01	2:27	0.004083	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
647	01-01-2026	Part of : POLICE TRAINING CENTRE NAVJIVAN VIHAR MALVIYA NAGAR,	181	Other Outage	Planned Outage	01-01-2026	10:20	01-01-2026	12:22	2:02	0.000068	REPLACEMENT OF LT BUSHING ROD
648	02-01-2026	Part of : POLICE TRAINING CENTRE NAVJIVAN VIHAR MALVIYA NAGAR	381	Other Outage	Planned Outage	02-01-2026	11:18	02-01-2026	12:47	1:29	0.000247	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
649	02-01-2026	Part of : E.E.,PWD, PTS, MALVIA NAGAR	1	Other Outage	Planned Outage	02-01-2026	11:20	02-01-2026	12:44	1:24	0.000000	PROPER SEALING RMU PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
650	02-01-2026	Part of : BLOCK B SARVODYA ENCLAVE	192	Other Outage	Planned Outage	02-01-2026	11:23	02-01-2026	13:03	1:40	0.000000	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
651	02-01-2026	Part of : BLOCK L MALVIYA NAGAR	960	Other Outage	Planned Outage	02-01-2026	11:17	02-01-2026	14:47	3:30	0.000000	REPLACEMENT OF HT BUSHING ROD
652	02-01-2026	Part of : BLOCK G 11 MALVIYA NAGAR	1294	Other Outage	Planned Outage	02-01-2026	11:41	02-01-2026	14:46	3:05	0.000514	REPLACEMENT OF HT BUSHING ROD
653	02-01-2026	Part of : BLOCK J SAKET	169	Other Outage	Planned Outage	02-01-2026	11:26	02-01-2026	13:51	2:25	0.004028	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
654	03-01-2026	Part of : BLOCK H 5 MALVIYA NAGAR	1102	Other Outage	Planned Outage	03-01-2026	11:12	03-01-2026	13:10	1:58	0.000000	REPLACEMENT OF HT BUSHING ROD
655	03-01-2026	Part of : ASHOK VIHAR PRESS ENCLAVE SAKET	75	Other Outage	Planned Outage	03-01-2026	11:13	03-01-2026	14:25	3:12	0.005333	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING
656	04-01-2026	Part of : BLOCK E & F SAKET,SAINIK FARM,SECTOR 2 PUSHPA VIHAR	1172	Other Outage	Unplanned Outage	04-01-2026	01:01	04-01-2026	01:57	0:56	0.000560	CABLE FAULT
657	05-01-2026	Part of : BLOCK H 5 MALVIYA NAGAR,	1114	Other Outage	Planned Outage	05-01-2026	11:57	05-01-2026	15:07	3:10	0.000000	MAINTENANCE OF TRANSFORMER
658	05-01-2026	Part of : BLOCK A SHIVALIK MALVIYA NAGAR,	783	Other Outage	Planned Outage	05-01-2026	11:01	05-01-2026	14:13	3:12	0.000000	MAINTENANCE OF TRANSFORMER
659	05-01-2026	Part of : BLOCK F SAKET,	497	Other Outage	Planned Outage	05-01-2026	11:05	05-01-2026	13:53	2:48	0.004667	MAINTENANCE OF TRANSFORMER
660	05-01-2026	Part of : MMTC COLONY SARVODYA ENCLAVE,	126	Other Outage	Planned Outage	05-01-2026	10:04	05-01-2026	12:12	2:08	0.000071	MAINTENANCE OF TRANSFORMER
661	06-01-2026	Part of : NEW COLONY KHIDKI EXTENSION MALVIYA NAGAR	1527	Other Outage	Planned Outage	06-01-2026	10:46	06-01-2026	14:11	3:25	0.000000	REPLACEMENT OF HT BUSHING ROD
662	06-01-2026	Part of : BLOCK N SAKET	465	Other Outage	Planned Outage	06-01-2026	10:59	06-01-2026	14:38	3:39	0.006083	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
663	06-01-2026	Part of : BLOCK F GITANJALI ENCLAVE MALVIYA NAGAR	170	Other Outage	Planned Outage	06-01-2026	10:19	06-01-2026	12:23	2:04	0.000069	REPLACEMENT OF HT BUSHING ROD
664	07-01-2026	Part of : FREEDOM FIGHTER VIHAR,BLOCK A,C,D & E PARYAVARAN COMPLEX	2461	Other Outage	Planned Outage	07-01-2026	12:53	07-01-2026	16:23	3:30	0.005833	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,HT BUSHING ROD REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
665	07-01-2026	Part of : BLOCK C SHIVALIK & BHAVISHYANIDHI ENCLAVE MALVIYA NAGAR	1126	Other Outage	Planned Outage	07-01-2026	11:38	07-01-2026	14:24	2:46	0.000000	REPLACEMENT OF HT BUSHING ROD
666	07-01-2026	Part of : MMTC COLONY SARVODYA ENCLAVE	7	Other Outage	Planned Outage	07-01-2026	10:16	07-01-2026	12:49	2:33	0.000085	REPLACEMENT OF HT BUSHING ROD
667	08-01-2026	Part of : BLOCK B & D FREEDOM FIGHTER VIHAR SAINIK FARM,POCKET E BEES SUTRI HARIJAN BASTI,BLOCK A 1 NEB SARAI SAINIK FARM	599	Other Outage	Unplanned Outage	08-01-2026	15:44	08-01-2026	16:17	0:33	0.000917	ATTEND WEAK POINT/HOT SPOT
668	08-01-2026	Part of : BLOCK C MALVIYA NAGAR	764	Other Outage	Planned Outage	08-01-2026	09:09	08-01-2026	10:35	1:26	0.000239	REPLACEMET OF HT BUSHING ROD
669	08-01-2026	Part of : BLOCK B SARVODYA ENCLAVE	1	Other Outage	Planned Outage	08-01-2026	14:03	08-01-2026	16:41	2:38	0.000088	REPLACEMENT OF LT BUSHING ROD
670	08-01-2026	Part of : BEGUMPUR	1171	Other Outage	Planned Outage	08-01-2026	11:45	08-01-2026	14:33	2:48	0.000000	REPLACEMET OF HT BUSHING ROD
671	08-01-2026	Part of : BLOCK D SAKET,SECTOR 3 PUSHPA VIHAR,BLOCK H SAKET,KUTUB GOLF COURSE LADO SARAI	2046	Other Outage	Planned Outage	08-01-2026	11:26	08-01-2026	13:56	2:30	0.004167	CONDUCTOR REPLACEMET PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES,TIGHTENING OF HARDWARE FITTINGS
672	08-01-2026	Part of : SAIYAD UL AJAIB EXTENSION SAINIK FARM,BLOCK D SAKET,BUTTERFLY PARK QILA RAI PITHORA SAINIK FARM	2890	Other Outage	Planned Outage	08-01-2026	11:26	08-01-2026	13:57	2:31	0.004194	CONDUCTOR REPLACEMET PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
673	09-01-2026	Part of : BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM,POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,SAINIK FARM,	2412	Other Outage	Unplanned Outage	09-01-2026	12:55	09-01-2026	13:51	0:56	0.001556	REPAIRING OF HT O/H CIRCUIT
674	09-01-2026	Part of : SAINIK FARM,BLOCK G NEB SARAI SAINIK FARM,BLOCK B SAINIK FARMS COLONY SAINIK FARM,SECTOR 6 PUSHPA VIHAR,BLOCK E SAINIK FARM,	401	Other Outage	Unplanned Outage	09-01-2026	12:53	09-01-2026	13:50	0:57	0.001583	REPAIRING OF HT O/H CIRCUIT
675	09-01-2026	Part of : BLOCK D DDA FLATE MALVIYA NAGAR,	828	Other Outage	Planned Outage	09-01-2026	11:32	09-01-2026	14:10	2:38	0.000000	MAINTENANCE OF TRANSFORMER
676	09-01-2026	Part of : BLOCK H 5 MALVIYA NAGAR,	1114	Other Outage	Planned Outage	09-01-2026	11:31	09-01-2026	14:14	2:43	0.000453	MAINTENANCE OF TRANSFORMER
677	09-01-2026	Part of : SAINIK FARM,	44	Other Outage	Planned Outage	09-01-2026	11:15	09-01-2026	13:59	2:44	0.004556	MAINTENANCE OF TRANSFORMER
678	09-01-2026	Part of : LADO SARAI EXTENSION LADO SARAI,BANDALO WALA MOHALLA LADO SARAI,CHHATRI WALA KUNA LADO SARAI	2424	Other Outage	Planned Outage	09-01-2026	11:17	09-01-2026	14:00	2:43	0.004528	MAINTENANCE OF HT O/H CIRCUIT
679	09-01-2026	Part of : MMTC COLONY SARVODYA ENCLAVE,	73	Other Outage	Planned Outage	09-01-2026	10:04	09-01-2026	12:13	2:09	0.000072	MAINTENANCE OF TRANSFORMER
680	10-01-2026	PART OF : BLOCK J SAINIK FARM	71	Other Outage	Planned Outage	10-01-2026	14:18	10-01-2026	16:50	2:32	0.004222	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
681	10-01-2026	PART OF : PCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	1121	Other Outage	Planned Outage	10-01-2026	14:34	10-01-2026	16:51	2:17	0.003806	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
682	10-01-2026	PART OF : BLOCK L MALVIYA NAGAR	960	Other Outage	Planned Outage	10-01-2026	11:14	10-01-2026	13:36	2:22	0.000394	REPLACEMENT OF HT BUSHING ROD
683	10-01-2026	PART OF : BLOCK H NEB SARAI SAINIK FARM	49	Other Outage	Planned Outage	10-01-2026	11:08	10-01-2026	14:18	3:10	0.005278	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
684	12-01-2026	Part of : BLOCK A SHIVALIK MALVIYA NAGAR	783	Other Outage	Planned Outage	12-01-2026	10:38	12-01-2026	14:04	3:26	0.000572	REPLACEMET OF HT BUSHING ROD
685	12-01-2026	Part of : ROCKY AREA STONE QUARRIES SAINIK FARM,BLOCK N SOUTH SAINIK FARM	1231	Other Outage	Planned Outage	12-01-2026	11:19	12-01-2026	13:50	2:31	0.004194	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE
686	12-01-2026	Part of : BHAVISHYANIDHI ENCLAVE MALVIYA NAGAR	44	Other Outage	Planned Outage	12-01-2026	10:19	12-01-2026	13:03	2:44	0.000046	REPLACEMET OF HT BUSHING ROD
687	13-01-2026	Part of : BLOCK C MALVIYA NAGAR	764	Other Outage	Planned Outage	13-01-2026	14:31	13-01-2026	14:44	0:13	0.000000	REPLACEMENT OF HT BUSHING ROD
688	13-01-2026	Part of : BLOCK H NEB SARAI SAINIK FARM,BLOCK A 1 NEB SARAI SAINIK FARM,ROCKY AREA STONE QUARRIES SAINIK FARM	615	Other Outage	Planned Outage	13-01-2026	11:09	13-01-2026	11:59	0:50	0.001389	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN
689	13-01-2026	Part of : POLICE TRAINING CENTRE NAVJIVAN VIHAR MALVIYA NAGAR	199	Other Outage	Planned Outage	13-01-2026	12:09	13-01-2026	13:39	1:30	0.000050	REPLACEMENT OF HT BUSHING ROD
690	13-01-2026	Part of : AUROBINDO COLLEGE MALVIYA NAGAR	1	Other Outage	Planned Outage	13-01-2026	09:52	13-01-2026	11:40	1:48	0.000270	CLEANING OF HT BUSHING PER WAY,DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
691	13-01-2026	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI	1603	Other Outage	Planned Outage	13-01-2026	10:59	13-01-2026	14:13	3:14	0.000000	REPLACEMENT OF HT BUSHING ROD
692	14-01-2026	Part of : E BLOCK SAINIK FARM,SAINIK FARMS COLONY SAINIK FARM,BLOCK F KHANPUR COLONY	615	Other Outage	Unplanned Outage	14-01-2026	23:57	15-01-2026	00:15	0:18	0.000065	CABLE FAULT
693	14-01-2026	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE,VIJAY MANDAL ENCLAVE KALU SARAI	638	Other Outage	Planned Outage	14-01-2026	09:55	14-01-2026	11:55	2:00	0.000033	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
694	14-01-2026	Part of : A BLOCK DDA FLATE SAKET	246	Other Outage	Planned Outage	14-01-2026	11:33	14-01-2026	15:49	4:16	0.007111	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
695	14-01-2026	Part of : DISTRICT PARK PHASE I SHEIKH SARAI	1671	Other Outage	Planned Outage	14-01-2026	13:04	14-01-2026	15:47	2:43	0.000000	REPLACEMENT OF HT BUSHING ROD
696	14-01-2026	Part of : HTC:3 WAY I/D RMU IN GARDEN OF FIVE SENC	1	Other Outage	Planned Outage	14-01-2026	11:19	14-01-2026	14:51	3:32	0.005889	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES
697	15-01-2026	Part of : BLOCK E SAINIK FARM,BLOCK H NEB SARAI SAINIK FARM	147	Other Outage	Planned Outage	15-01-2026	11:23	15-01-2026	13:50	2:27	0.004083	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN,CONNECTING OF NEW EARTHING PER EARTHIN
698	15-01-2026	Part of : BLOCK C SAKET	312	Other Outage	Planned Outage	15-01-2026	11:33	15-01-2026	13:49	2:16	0.003778	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER.
699	15-01-2026	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	16	Other Outage	Planned Outage	15-01-2026	10:12	15-01-2026	12:49	2:37	0.000044	REPLACEMET OF HT BUSHING ROD
700	16-01-2026	Part of : FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK A PARYAVARAN COMPLEX SAINIK FARM	5135	Other Outage	Planned Outage	16-01-2026	14:59	16-01-2026	16:42	1:43	0.002861	BIRD SPIKES INSTALLATION PER POLE
701	16-01-2026	Part of : BLOCK A KARAN MARKET NANGAL RAYA JANAK PURI	173	Other Outage	Planned Outage	16-01-2026	13:57	16-01-2026	15:51	1:54	0.000000	3PH DB REVAMPING
702	16-01-2026	Part of : JAI VIHAR KAMARUDDIN NAGAR	134	Other Outage	Planned Outage	16-01-2026	10:58	16-01-2026	13:48	2:50	0.004722	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
703	16-01-2026	Part of : SATYA NIKETAN MOTI BAGH SOUTH	515	Other Outage	Planned Outage	16-01-2026	10:08	16-01-2026	14:16	4:08	0.000000	REPLACEMET OF HT BUSHING ROD
704	16-01-2026	Part of : BLOCK L 2 DEVLI SANGAM VIHAR	150	Other Outage	Planned Outage	16-01-2026	10:16	16-01-2026	12:43	2:27	0.000082	REPLACEMET OF HT BUSHING ROD
705	17-01-2026	Part of : A 1 BLOCK NEB SARAI,POCKET E BEES SUTRI HARIJAN BASTI,BLOCK D FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK D PARYAVARAN COMPLEX SAINIK FARM	599	Other Outage	Unplanned Outage	17-01-2026	18:34	17-01-2026	19:25	0:51	0.001118	CABLE FAULT
706	17-01-2026	Part of : SAINIK FARMS COLONY SAINIK FARM	29	Other Outage	Planned Outage	17-01-2026	13:22	17-01-2026	16:38	3:16	0.005444	MAINTENANCE OF TRANSFORMER
707	17-01-2026	Part of : E BLOCK SAKET	32	Other Outage	Planned Outage	17-01-2026	11:04	17-01-2026	14:46	3:42	0.006167	MAINTENANCE OF TRANSFORMER
708	19-01-2026	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	4	Other Outage	Planned Outage	19-01-2026	10:04	19-01-2026	12:03	1:59	0.000066	REPLACEMET OF HT BUSHING ROD
709	19-01-2026	Part of : D-184 FREEDOM FIGHTER ENCLAVE	2241	Other Outage	Planned Outage	19-01-2026	13:33	19-01-2026	16:01	2:28	0.004111	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
710	19-01-2026	Part of : SAIYAD UL AJAIB VILLAGE SAINIK FARM	784	Other Outage	Planned Outage	19-01-2026	12:14	19-01-2026	14:54	2:40	0.004444	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,CT REPLACEMET,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
711	19-01-2026	Part of : BLOCK D SAKET	165	Other Outage	Planned Outage	19-01-2026	11:01	19-01-2026	13:44	2:43	0.004528	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
712	20-01-2026	Part of : BLOCK G 11 MALVIYA NAGAR	1285	Other Outage	Planned Outage	20-01-2026	13:21	20-01-2026	13:54	0:33	0.000000	REPLACEMET OF HT BUSHING ROD
713	20-01-2026	Part of : SECTOR 3 PUSHPA VIHAR	266	Other Outage	Planned Outage	20-01-2026	14:23	20-01-2026	16:00	1:37	0.002694	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
714	20-01-2026	Part of : FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK A & D PARYAVARAN COMPLEX SAINIK FARM	2464	Other Outage	Planned Outage	20-01-2026	11:31	20-01-2026	13:49	2:18	0.003833	3PH HT AB END TERMINATION REPLACEMENT
715	20-01-2026	Part of : BLOCK G DDA FLATS SAKET	431	Other Outage	Planned Outage	20-01-2026	11:22	20-01-2026	13:48	2:26	0.004867	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
716	20-01-2026	Part of : KUTUB GOLF COURSE LADO SARAI	1	Other Outage	Planned Outage	20-01-2026	10:17	20-01-2026	13:28	3:11	0.000053	REPLACEMENT OF LT BUSHING ROD
717	21-01-2026	Part of : POKKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,	1121	Other Outage	Planned Outage	21-01-2026	12:00	21-01-2026	15:30	3:30	0.005833	HVDS MAINTENANCE
718	21-01-2026	Part of : BLOCK F SAKET,	157	Other Outage	Planned Outage	21-01-2026	11:15	21-01-2026	15:04	3:49	0.006997	TRANSFORMER MAINTENANCE
719	21-01-2026	Part of : BEGUMPUR,	389	Other Outage	Planned Outage	21-01-2026	10:30	21-01-2026	13:24	2:54	0.000000	TRANSFORMER MAINTENANCE
720	22-01-2026	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI	1603	Other Outage	Planned Outage	22-01-2026	14:39	22-01-2026	15:09	0:30	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
721	22-01-2026	Part of : BLOCK G SAKET	257	Other Outage	Planned Outage	22-01-2026	10:52	22-01-2026	12:37	1:45	0.002917	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
722	22-01-2026	Part of : BLOCK E SAKET	113	Other Outage	Planned Outage	22-01-2026	12:58	22-01-2026	15:51	2:53	0.004806	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
723	23-01-2026	Part of : L&T ANUPAM M.B.ROAD (HT CONSUMER)	0	Other Outage	Unplanned Outage	23-01-2026	20:52	23-01-2026	21:14	0:22	0.000092	FAULT IN HT CONSUMER PANEL (L&T ANUPAM)
724	23-01-2026	Part of : BLOCK J SAKET	241	Other Outage	Planned Outage	23-01-2026	11:48	23-01-2026	14:08	2:20	0.001750	REPLACEMENT OF HT BUSHING ROD
725	23-01-2026	Part of : BLOCK J SAKET	640	Other Outage	Planned Outage	23-01-2026	11:48	23-01-2026	14:07	2:19	0.001738	REPLACEMENT OF HT BUSHING ROD
726	24-01-2026	Part of : BLOCK B NAVJIVAN VIHAR MALVIYA NAGAR	276	Other Outage	Planned Outage	24-01-2026	09:58	24-01-2026	11:58	2:00	0.000000	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF LT BUSHING ROD
727	24-01-2026	Part of : BLOCK D SAKET	199	Other Outage	Planned Outage	24-01-2026	14:14	24-01-2026	16:54	2:40	0.004444	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE
728	24-01-2026	Part of : BLOCK D SAKET	234	Other Outage	Planned Outage	24-01-2026	10:50	24-01-2026	14:17	3:27	0.005750	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
729	27-01-2026	Part of : PTS COLONY (HT CONSUMER)	1	Other Outage	Planned Outage	27-01-2026	14:19	27-01-2026	15:15	0:56	0.000000	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
730	27-01-2026	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE	234	Other Outage	Planned Outage	27-01-2026	10:14	27-01-2026	13:04	2:50	0.000094	REPLACEMET OF HT BUSHING ROD
731	28-01-2026	Part of : AUROBINDO COLLEGE MALVIYA NAGAR	1	Other Outage	Planned Outage	28-01-2026	14:37	28-01-2026	15:46	1:09	0.000000	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
732	28-01-2026	Part of : BLOCK H NEB SARAI SAINIK FARM	94	Other Outage	Planned Outage	28-01-2026	10:58	28-01-2026	13:50	2:52	0.004778	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF HT/LT CLEATS,REPLACEMET OF LUGS
733	29-01-2026	Part of : HTC: L&T ANUPAM, M.B.ROAD	0	Other Outage	Unplanned Outage	29-01-2026	04:33	29-01-2026	05:19	0:46	0.000907	HT SYSTEM FAULT
734	29-01-2026	Part of : POCKET L PHASE II SHEIKH SARAI,POCKET K PHASE II SHEIKH SARAI	1406	Other Outage	Unplanned Outage	29-01-2026	22:32	29-01-2026	23:07	0:35	0.000000	TRANSIENT FAULT
735	29-01-2026	Part of : SAINIK FARMS COLONY SAINIK FARM,	44	Other Outage	Planned Outage	29-01-2026	12:48	29-01-2026	16:03	3:15	0.005417	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,TIGHTENEING OF NUT BOLT
736	29-01-2026	Part of : SAINIK FARMS COLONY SAINIK FARM,	63	Other Outage	Planned Outage	29-01-2026	10:57	29-01-2026	13:47	2:50	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
737	29-01-2026	Part of : BLOCK F GITANJALI ENCLAVE MALVIYA NAGAR,	170	Other Outage	Planned Outage	29-01-2026	10:01	29-01-2026	12:41	2:40	0.000089	REPLACEMET OF HT BUSHING ROD
738	29-01-2026	Part of : MAIDAN GARHI VILLAGE CHHATARPUR,MITTAL GARDEN SAINIK FARM,BEES SUTRI HARIJAN BASTI SAINIK FARM,	413	Other Outage	Planned Outage	29-01-2026	10:47	29-01-2026	14:28	3:41	0.006139	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
739	30-01-2026	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE,VIJAY MANDAL ENCLAVE KALU SARAI	649	Other Outage	Unplanned Outage	30-01-2026	18:22	30-01-2026	19:15	0:53	0.000331	TRANSFORMER FAULT
740	30-01-2026	Part of : BLOCK G 11 MALVIYA NAGAR,BLOCK F 2 MALVIYA NAGAR,BLOCK B SHIVALIK MALVIYA NAGAR,BLOCK H 5 MALVIYA NAGAR	4587	Other Outage	Unplanned Outage	30-01-2026	15:08	30-01-2026	16:20	1:12	0.000000	REPAIRING OF RMU
741	30-01-2026	Part of : ROCKY AREA STONE QUARRIES SAINIK FARM	63	Other Outage	Planned Outage	30-01-2026	15:08	30-01-2026	17:00	1:52	0.003111	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
742	30-01-2026	Part of : BLOCK B KHIDKI EXTENSION MALVIYA NAGAR	744	Other Outage	Planned Outage	30-01-2026	10:19	30-01-2026	14:23	4:04	0.000000	REPLACEMENT OF HT BUSHING ROD
743	30-01-2026	Part of : MMTC COLONY SARVODYA ENCLAVE	7	Other Outage	Planned Outage	30-01-2026	10:02	30-01-2026	12:38	2:36	0.000087	REPLACEMENT OF LT BUSHING ROD
744	30-01-2026	Part of : BLOCK N SOUTH SAINIK FARM SAINIK FARM	99	Other Outage	Planned Outage	30-01-2026	11:33	30-01-2026	13:47	2:14	0.003722	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
745	31-01-2026	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	5	Other Outage	Planned Outage	31-01-2026	14:02	31-01-2026	15:10	1:08	0.000019	REPLACEMENT OF HT BUSHING ROD
746	31-01-2026	Part of : E-BLOCK SAINIK FARM	55	Other Outage	Planned Outage	31-01-2026	13:35	31-01-2026	15:36	2:01	0.003361	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
747	31-01-2026	Part of : BEES SUTRI HARIJAN BASTI SAINIK FARM	892	Other Outage	Planned Outage	31-01-2026	10:33	31-01-2026	13:59	3:26	0.005722	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
748	31-01-2026	Part of : E-BLOCK SAINIK FARM	30	Other Outage	Planned Outage	31-01-2026	10:55	31-01-2026	13:57	3:02	0.005056	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
749	31-01-2026	Part of : A,B & C-BLOCK SARVODYA ENCLAVE,MMTC COLONY,VIJAY MANDAL ENCLAVE KALU SARAI	431	Other Outage	Planned Outage	31-01-2026	10:08	31-01-2026	12:41	2:33	0.000850	GUARD WIRES SAGGING
750	31-01-2026	Part of : KALU SARAI	263	Other Outage	Planned Outage	31-01-2026	09:57	31-01-2026	12:38	2:41	0.000000	REPLACEMENT OF HT BUSHING ROD
751	02-01-2026	Part of : GAGAN VIHAR MITHAPUR EXTENSION MITHAPUR	1713	Other Outage	Planned Outage	02-01-2026	11:42	02-01-2026	12:24	0:42	0.000467	REPLACEMENT OF FAULTY END BOX
752	02-01-2026	Part of : MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR,BLOCK A MOLARBAND EXTENSION BADARPUR	369	Other Outage	Planned Outage	02-01-2026	11:06	02-01-2026	13:46	2:40	0.000667	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,HT BUSHING ROD REPLACEMENT,INSULATOR REPLACEMENT,LT BUSHING REPLACEMENT
753	02-01-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1640	Other Outage	Planned Outage	02-01-2026	11:02	02-01-2026	13:04	2:02	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
754	03-01-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1393	Other Outage	Planned Outage	03-01-2026	11:03	03-01-2026	13:52	2:49	0.000000	3PH HT AB CABLE REPLACEMENT
755	03-01-2026	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR	21	Other Outage	Planned Outage	03-01-2026	11:15	03-01-2026	13:57	2:42	0.000900	HT CONDUCTOR REPLACEMENT
756	05-01-2026	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR,ALI VILLAGE ALI,ALI EXTENSION ALI	1333	Other Outage	Unplanned Outage	05-01-2026	04:55	05-01-2026	05:33	0:38	0.000021	HT SYSTEM FAULT
757	05-01-2026	Part of : MITHAPUR,	1675	Other Outage	Planned Outage	05-01-2026	11:51	05-01-2026	13:48	1:57	0.001300	MAINTENANCE OF RMU
758	05-01-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND,	976	Other Outage	Planned Outage	05-01-2026	11:13	05-01-2026	13:48	2:35	0.003875	MAINTENANCE OF HVDS CIRCUIT
759	06-01-2026	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR	716	Other Outage	Planned Outage	06-01-2026	12:31	06-01-2026	13:36	1:05	0.000361	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
760	06-01-2026	Part of : O-BLOCK SAURABH VIHAR,N-BLOCK SAURABH VIHAR	1175	Other Outage	Planned Outage	06-01-2026	11:59	06-01-2026	14:58	2:59	0.004475	3PH HT AB CABLE REPLACEMENT PER SPAN
761	06-01-2026	Part of : POCKET E SARITA VIHAR	340	Other Outage	Planned Outage	06-01-2026	10:58	06-01-2026	13:24	2:26	0.002839	REPLACEMENT OF GAS KIT AND OIL SEAL
762	06-01-2026	Part of : BADARPUR VILLAGE BADARPUR	779	Other Outage	Planned Outage	06-01-2026	11:14	06-01-2026	13:40	2:26	0.000000	ACB REPLACEMENT PER ACB
763	07-01-2026	Part of : F,H,K,L & M-BLOCK SAURABH VIHAR	2076	Other Outage	Unplanned Outage	07-01-2026	11:28	07-01-2026	12:11	0:43	0.000000	HT SYSTEM FAULT
764	07-01-2026	Part of : N & O-BLOCK SAURABH VIHAR,E-BLOCK HARI NAGAR EXT PART-2	1353	Other Outage	Planned Outage	07-01-2026	11:01	07-01-2026	13:37	2:36	0.003900	3PH HT AB CABLE REPLACEMENT PER SPAN,ST.TH JOINT ON 1PH HT AB
765	08-01-2026	Part of : KHADDA COLONY JAIPUR	1667	Other Outage	Planned Outage	08-01-2026	11:20	08-01-2026	13:17	1:57	0.001950	3PH HT AB END TERMINATION REPLACEMENT
766	08-01-2026	Part of : BLOCK E 2 MOLARBAND EXTENSION BADARPUR	1488	Other Outage	Planned Outage	08-01-2026	11:17	08-01-2026	15:33	4:16	0.001422	3PH HT AB CABLE REPLACEMENT PER SPAN
767	09-01-2026	Part of : OM NAGAR MOLARBAND,	709	Other Outage	Planned Outage	09-01-2026	14:01	09-01-2026	15:04	1:03	0.001925	MAINTENANCE OF RMU
768	09-01-2026	Part of : BLOCK E 1 MOLARBAND EXTENSION BADARPUR,BLOCK E 2 MOLARBAND EXTENSION BADARPUR	1721	Other Outage	Planned Outage	09-01-2026	11:37	09-01-2026	13:34	1:57	0.000650	MAINTENANCE OF HVDS
769	09-01-2026	Part of : KHADDA COLONY JAIPUR,	2185	Other Outage	Planned Outage	09-01-2026	11:03	09-01-2026	13:27	2:24	0.002000	MAINTENANCE OF HVDS
770	10-01-2026	PART OF : KHADDA COLONY JAIPUR	1667	Other Outage	Planned Outage	10-01-2026	11:16	10-01-2026	13:45	2:29	0.002483	3PH HT AB END TERMINATION REPLACEMENT
771	10-01-2026	PART OF : BLOCK E1, E2 & F MOLARBAND EXTENSION BADARPUR	14	Other Outage	Planned Outage	10-01-2026	11:49	10-01-2026	13:51	2:02	0.000339	3PH HT AB CABLE REPLACEMENT PER SPAN
772	10-01-2026	PART OF : POCKET F SARITA VIHAR	603	Other Outage	Planned Outage	10-01-2026	11:15	10-01-2026	13:36	2:21	0.000000	REPLACEMENT OF FAULTY END BOX
773	12-01-2026	Part of : D2-BLOCK HARI NAGAR EXTN-III,PEER BABA BASTI JAIPUR,VILLAGE JAIPUR	2530	Other Outage	Planned Outage	12-01-2026	10:56	12-01-2026	12:41	1:45	0.001167	CONDUCTOR REPLACEMET PER SPAN,GUARD WIRES SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
774	12-01-2026	Part of : POCKET M SARITA VIHAR	1086	Other Outage	Planned Outage	12-01-2026	10:59	12-01-2026	12:07	1:08	0.001133	REPLACEMENT OF GAS KIT AND OIL SEAL
775	12-01-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1458	Other Outage	Planned Outage	12-01-2026	10:59	12-01-2026	13:42	2:43	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
776	12-01-2026	Part of : ROOP NAGAR MOLARBAND	976	Other Outage	Planned Outage	12-01-2026	10:56	12-01-2026	13:52	2:56	0.004400	3PH HT AB CABLE REPLACEMENT PER SPAN,INSULATOR REPLACEMENT
777	13-01-2026	Part of : GAYATRI KUNJ ALI	1409	Other Outage	Planned Outage	13-01-2026	11:36	13-01-2026	12:26	0:50	0.001069	REPLACEMENT OF GAS KIT AND OIL SEAL
778	13-01-2026	Part of : O-BLOCK SAURABH VIHAR,N-BLOCK SAURABH VIHAR	1175	Other Outage	Planned Outage	13-01-2026	11:23	13-01-2026	13:39	2:16	0.003400	3PH HT AB CABLE REPLACEMENT PER SPAN,HT BUSHING ROD REPLACEMENT
779	13-01-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1500	Other Outage	Planned Outage	13-01-2026	11:14	13-01-2026	13:42	2:28	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
780	14-01-2026	Part of : N-BLOCK SAURABH VIHAR,O-BLOCK SAURABH VIHAR,E-BLOCK HARI NAGAR EXT PART-2	1353	Other Outage	Planned Outage	14-01-2026	11:47	14-01-2026	12:59	1:12	0.001800	HVDS HT AB CABLE REPLACEMENT
781	14-01-2026	Part of : ALI VIHAR ALI	300	Other Outage	Planned Outage	14-01-2026	11:04	14-01-2026	13:29	2:25	0.002014	INSTALLATION OF BUS BAR
782	14-01-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1131	Other Outage	Planned Outage	14-01-2026	11:04	14-01-2026	13:28	2:24	0.000000	HVDS HT AB CABLE REPLACEMENT
783	15-01-2026	Part of : RAJ NAGAR MADANPUR KHADAR	391	Other Outage	Planned Outage	15-01-2026	11:01	15-01-2026	13:22	2:21	0.002350	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
784	16-01-2026	Part of : SHERPUR EXTENTION,PIND WALA KALAN VILLAGE,KHERA DABAS VILLAGE	644	Other Outage	Planned Outage	16-01-2026	11:02	16-01-2026	13:40	2:38	0.002633	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
785	17-01-2026	Part of : J BLOCK SAURABH VIHAR,D-BLOCK SAURABH,B-BLOCK SAURABH VIHAR,E-BLOCK HARI NAGAR EXT PART-2	1639	Other Outage	Unplanned Outage	17-01-2026	03:55	17-01-2026	04:31	0:36	0.000272	HVDS FAULT
786	17-01-2026	Part of : POCKET F SARITA VIHAR	603	Other Outage	Planned Outage	17-01-2026	10:58	17-01-2026	12:26	1:28	0.000489	MAINTENANCE OF RMU
787	17-01-2026	Part of : MADANPUR KHADAR	221	Other Outage	Planned Outage	17-01-2026	10:58	17-01-2026	13:39	2:41	0.001789	MAINTENANCE OF TRANSFORMER
788	18-01-2026	Part of : SHIV PURI MEETHAPUR, LAKHPAT COLONY MEETHAPUR, MEETHAPUR VILLAGE	3704	Other Outage	Unplanned Outage	18-01-2026	19:19	18-01-2026	19:51	0:32	0.000552	CABLE FAULT
789	18-01-2026	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR, ALI EXTENSION	1890	Other Outage	Unplanned Outage	18-01-2026	03:50	18-01-2026	04:33	0:43	0.000000	CABLE FAULT
790	19-01-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND	976	Other Outage	Planned Outage	19-01-2026	11:08	19-01-2026	13:01	1:53	0.002825	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
791	19-01-2026	Part of : ALI VILLAGE	1217	Other Outage	Planned Outage	19-01-2026	10:56	19-01-2026	13:38	2:42	0.003465	SUB STATION CLEANING
792	19-01-2026	Part of : KHADDA COLONY JAIPUR	1784	Other Outage	Planned Outage	19-01-2026	10:56	19-01-2026	13:40	2:44	0.000000	3PH HT AB CABLE REPLACEMENT
793	20-01-2026	Part of : E-BLOCK HARI NAGAR EXT PART-2	1142	Other Outage	Planned Outage	20-01-2026	11:48	20-01-2026	12:45	0:57	0.000396	REPLACEMENT OF GAS KIT AND OIL SEAL
794	20-01-2026	Part of : LALU COLONY ALI,ALI VIHAR ALI	1605	Other Outage	Planned Outage	20-01-2026	11:18	20-01-2026	13:09	1:51	0.001542	REPLACEMENT OF GAS KIT AND OIL SEAL
795	20-01-2026	Part of : O-BLOCK SAURABH VIHAR,N-BLOCK SAURABH VIHAR	1175	Other Outage	Planned Outage	20-01-2026	11:36	20-01-2026	13:28	1:52	0.002489	3PH HT AB CABLE REPLACEMENT PER SPAN,HT BUSHING ROD REPLACEMENT
796	20-01-2026	Part of : KHADDA COLONY JAIPUR	3191	Other Outage	Planned Outage	20-01-2026	11:04	20-01-2026	13:20	2:16	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
797	21-01-2026	Part of : O-BLOCK SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND,K-BLOCK SAURABH VIHAR,RAJ NAGAR MADANPUR KHADAR	4360	Other Outage	Unplanned Outage	21-01-2026	10:13	21-01-2026	10:42	0:29	0.000709	ELECTROCUTION OF CAT
798	21-01-2026	Part of : E-BLOCK HARI NAGAR EXT PART-2,N-BLOCK SAURABH VIHAR,O-BLOCK SAURABH VIHAR,	1353	Other Outage	Planned Outage	21-01-2026	13:12	21-01-2026	14:38	1:26	0.002150	HVDS MAINTENANCE
799	21-01-2026	Part of : BLOCK E 1 MOLARBAND EXTENSION BADARPUR,BLOCK C MOLARBAND EXTENSION BADARPUR	1923	Other Outage	Planned Outage	21-01-2026	11:02	21-01-2026	12:09	1:07	0.000372	HVDS MAINTENANCE
800	21-01-2026	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR,	1801	Other Outage	Planned Outage	21-01-2026	11:15	21-01-2026	13:21	2:06	0.002100	TRANSFORMER MAINTENANCE
801	21-01-2026	Part of : KHADDA COLONY JAIPUR,	1939	Other Outage	Planned Outage	21-01-2026	11:14	21-01-2026	13:17	2:03	0.000000	HVDS MAINTENANCE
802	22-01-2026	Part of : POCKET G SARITA VIHAR,POCKET F SARITA VIHAR,POCKET L SARITA VIHAR,POCKET I SARITA VIHAR,POCKET K SARITA VIHAR	2144	Other Outage	Unplanned Outage	22-01-2026	09:55	22-01-2026	10:29	0:34	0.001061	CABLE FAULT
803	22-01-2026	Part of : KHADDA COLONY JAIPUR	1667	Other Outage	Planned Outage	22-01-2026	11:10	22-01-2026	13:31	2:21	0.001958	3PH HT AB CABLE REPLACEMENT PER SPAN
804	23-01-2026	Part of : C,D & E1-BLOCK MOLARBAND EXTENSION BADARPUR,MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR	3217	Other Outage	Unplanned Outage	23-01-2026	11:39	23-01-2026	12:18	0:39	0.000758	HVDS FAULT
805	23-01-2026	Part of : C,D & E1-BLOCK MOLARBAND EXTENSION BADARPUR,MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR	3217	Other Outage	Unplanned Outage	23-01-2026	09:29	23-01-2026	10:02	0:33	0.000229	HVDS FAULT
806	24-01-2026	Part of : BLOCK D & F MOLARBAND EXTENSION BADARPUR	14	Other Outage	Planned Outage	24-01-2026	11:34	24-01-2026	13:44	2:10	0.001444	3PH DB REPLACEMENT
807	24-01-2026	Part of : KHADDA COLONY JAIPUR	1667	Other Outage	Planned Outage	24-01-2026	10:57	24-01-2026	13:46	2:49	0.002347	3PH HT AB CABLE REPLACEMENT PER SPAN
808	26-01-2026	Part of : BLOCK E MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	151	Other Outage	Unplanned Outage	26-01-2026	11:28	26-01-2026	11:51	0:23	0.000083	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
809	26-01-2026	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR,BADARPUR EXTENSION TAJPUR BADARPUR	4026	Other Outage	Unplanned Outage	26-01-2026	14:10	26-01-2026	14:51	0:41	0.000611	HVDS FAULT
810	27-01-2026	Part of : C-BLOCK MOLARBAND EXTENSION,BADARPUR EXTENSION, TAJPUR	4026	Other Outage	Unplanned Outage	27-01-2026	12:10	27-01-2026	12:28	0:18	0.000320	TREE TOUCHING
811	27-01-2026	Part of : GAYATRI KUNJ,LALU COLONY,JAGDAMPA CAMP	501	Other Outage	Unplanned Outage	27-01-2026	16:21	27-01-2026	17:04	0:43	0.000979	CABLE FAULT
812	27-01-2026	Part of : N & O-BLOCK SAURABH VIHAR	1175	Other Outage	Planned Outage	27-01-2026	11:06	27-01-2026	12:56	1:50	0.002750	DT REPLACEMET PER DT,ST.TH JOINT ON 1PH HT AB,ST.TH JOINT ON 3PH HT AB
813	28-01-2026	Part of : BLOCK N & O SAURABH VIHAR,E-BLOCK HARI NAGAR EXT PART-2	1353	Other Outage	Planned Outage	28-01-2026	12:49	28-01-2026	13:50	1:01	0.000339	3PH HT AB CABLE REPLACEMENT PER SPAN
814	28-01-2026	Part of : I-BLOCK HARI NAGAR EXTN,ABC BLOCK HARI NAGAR MOLARBAND	2343	Other Outage	Planned Outage	28-01-2026	12:15	28-01-2026	13:48	1:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
815	28-01-2026	Part of : KHADDA COLONY JAIPUR	1667	Other Outage	Planned Outage	28-01-2026	11:06	28-01-2026	13:14	2:08	0.001778	3PH HT AB CABLE REPLACEMENT PER SPAN
816	29-01-2026	Part of : BLOCK E MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	87	Other Outage	Unplanned Outage	29-01-2026	23:25	29-01-2026	23:55	0:30	0.000167	CABLE FAULT
817	29-01-2026	Part of : ROOP NAGAR MOLARBAND,OM NAGAR MOLARBAND,	976	Other Outage	Planned Outage	29-01-2026	11:07	29-01-2026	11:48	0:41	0.001025	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
818	29-01-2026	Part of : KHADDA COLONY JAIPUR,	1667	Other Outage	Planned Outage	29-01-2026	10:48	29-01-2026	13:19	2:31	0.002097	3PH HT AB CABLE REPLACEMENT PER SPAN
819	30-01-2026	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR,MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR,BLOCK A MOLARBAND EXTENSION BADARPUR	374	Other Outage	Planned Outage	30-01-2026	12:58	30-01-2026	14:22	1:24	0.000933	3PH DB REPLACEMENT
820	30-01-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1430	Other Outage	Planned Outage	30-01-2026	10:57	30-01-2026	13:27	2:30	0.002083	3PH HT AB CABLE REPLACEMENT PER SPAN
821	30-01-2026	Part of : KHADDA COLONY JAIPUR	2185	Other Outage	Planned Outage	30-01-2026	10:58	30-01-2026	13:26	2:28	0.001644	3PH HT AB CABLE REPLACEMENT PER SPAN
822	31-01-2026	Part of : E-BLOCK HARI NAGAR EXT PART-2,N & O-BLOCK SAURABH VIHAR	1353	Other Outage	Planned Outage	31-01-2026	12:33	31-01-2026	14:01	1:28	0.002200	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB CABLE REPLACEMENT
823	31-01-2026	Part of : KHADDA COLONY JAIPUR	1667	Other Outage	Planned Outage	31-01-2026	11:00	31-01-2026	13:35	2:35	0.002153	3PH HT AB CABLE REPLACEMENT
824	31-01-2026	Part of : BADARPUR EXTENSION,TAJPUR BADARPUR,MOHAN BABA NAGAR	1882	Other Outage	Planned Outage	31-01-2026	11:06	31-01-2026	13:42	2:36	0.000867	HT CONDUCTOR REPLACEMENT
825	01-01-2026	Part of : BRIJBASI COLONY MEHRAULI,	1097	Other Outage	Planned Outage	01-01-2026	12:34	01-01-2026	13:05	0:31	0.000034	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
826	01-01-2026	Part of : GHITORNI VILLAGE GHITORNI,	896	Other Outage	Planned Outage	01-01-2026	11:34	01-01-2026	13:09	1:35	0.000317	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
827	01-01-2026	Part of : BLOCK R MAHIPALPUR VILLAGE MAHIPALPUR,INDIRA GANDHI INTERNATIONAL AIRPORT,	6	Other Outage	Planned Outage	01-01-2026	10:42	01-01-2026	13:58	3:16	0.001906	REPLACEMENT OF LT BUSHING ROD
828	01-01-2026	Part of : SECTOR D VASANT KUNJ,	112	Other Outage	Planned Outage	01-01-2026	10:44	01-01-2026	13:40	2:56	0.000489	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
829	02-01-2026	Part of : POCKET 3 SECTOR C VASANT KUNJ,POCKET 1 SECTOR C VASANT KUNJ	990	Other Outage	Unplanned Outage	02-01-2026	17:49	02-01-2026	18:27	0:38	0.000359	CABLE FAULT
830	02-01-2026	Part of : POCKET 4 SECTOR C VASANT KUNJ,VASANT KUNJ PHASE II VASANT KUNJ	44	Other Outage	Unplanned Outage	02-01-2026	12:04	02-01-2026	12:48	0:44	0.000269	FAULT IN HT CONSUMER PANEL (JAGAT GURU INSTITUTIONAL AREA)
831	02-01-2026	Part of : RAJOKRI VILLAGE RAJOKRI	342	Other Outage	Planned Outage	02-01-2026	12:56	02-01-2026	13:19	0:23	0.000153	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
832	02-01-2026	Part of : PALAM FARMS,PUSHPANJALI FARMS,DALMIA VIHAR BIJWASAN	610	Other Outage	Planned Outage	02-01-2026	10:02	02-01-2026	11:01	0:59	0.000000	CONDUCTOR REPLACEMENT PER SPAN,TIGHTENING OF HARDWARE FITTINGS
833	02-01-2026	Part of : RANGPURI PAHARI RANGPURI	148	Other Outage	Planned Outage	02-01-2026	10:47	02-01-2026	13:51	3:04	0.001533	REPLACEMENT OF HT BUSHING ROD
834	02-01-2026	Part of : TEACHER COLONY MEHRAULI	531	Other Outage	Planned Outage	02-01-2026	10:39	02-01-2026	13:51	3:12	0.002133	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
835	02-01-2026	Part of : ANAND GRAM GHITORNI	2	Other Outage	Planned Outage	02-01-2026	11:18	02-01-2026	13:33	2:15	0.000375	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
836	02-01-2026	Part of : IAA COLONY SECTOR D VASANT KUNJ	91	Other Outage	Planned Outage	02-01-2026	10:38	02-01-2026	13:34	2:56	0.000489	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
837	03-01-2026	Part of : KAPAS HERA EXTENSION	646	Other Outage	Planned Outage	03-01-2026	11:05	03-01-2026	12:30	1:25	0.000543	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING
838	03-01-2026	Part of : ROOPAM WALA KUNWA MEHRAULI	1159	Other Outage	Planned Outage	03-01-2026	10:58	03-01-2026	14:15	3:17	0.002189	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING BUSHING ROD
839	03-01-2026	Part of : GHITORNI VILLAGE	667	Other Outage	Planned Outage	03-01-2026	11:00	03-01-2026	13:36	2:36	0.000520	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
840	03-01-2026	Part of : POCKET 6 SECTOR D VASANT KUNJ	177	Other Outage	Planned Outage	03-01-2026	11:02	03-01-2026	14:07	3:05	0.000514	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
841	04-01-2026	Part of : BLOCK E, L & R MAHIPALPUR VILLAGE MAHIPALPUR	4022	Other Outage	Unplanned Outage	04-01-2026	04:31	04-01-2026	04:58	0:27	0.000000	CABLE FAULT
842	05-01-2026	Part of : GHITORNI VILLAGE GHITORNI,	691	Other Outage	Planned Outage	05-01-2026	11:14	05-01-2026	13:49	2:35	0.000603	MAINTENANCE OF TRANSFORMER
843	05-01-2026	Part of : POCKET 8 SECTOR C VASANT KUNJ,	2	Other Outage	Planned Outage	05-01-2026	10:57	05-01-2026	13:56	2:59	0.000497	MAINTENANCE OF TRANSFORMER
844	05-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI,	21	Other Outage	Planned Outage	05-01-2026	10:32	05-01-2026	13:48	3:16	0.001906	MAINTENANCE OF TRANSFORMER
845	05-01-2026	Part of : PUSHPANJALI FARMS,	18	Other Outage	Planned Outage	05-01-2026	10:01	05-01-2026	12:24	2:23	0.000000	MAINTENANCE OF HT O/H CIRCUIT
846	06-01-2026	Part of : TEACHER COLONY MEHRAULI	880	Other Outage	Planned Outage	06-01-2026	12:52	06-01-2026	14:24	1:32	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
847	06-01-2026	Part of : ANAND GRAM GHITORNI	28	Other Outage	Planned Outage	06-01-2026	11:41	06-01-2026	14:40	2:59	0.000597	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
848	06-01-2026	Part of : RANGPURI PAHARI RANGPURI	159	Other Outage	Planned Outage	06-01-2026	10:46	06-01-2026	13:46	3:00	0.002250	REPLACEMENT OF LT BUSHING ROD
849	06-01-2026	Part of : POCKET 3 SECTOR D VASANT KUNJ	213	Other Outage	Planned Outage	06-01-2026	10:50	06-01-2026	13:50	3:00	0.000600	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
850	06-01-2026	Part of : MAHIPALPUR	1	Other Outage	Planned Outage	06-01-2026	11:15	06-01-2026	14:06	2:51	0.000475	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
851	07-01-2026	Part of : SAMALKA	82	Other Outage	Unplanned Outage	07-01-2026	22:25	07-01-2026	22:49	0:24	0.000540	CABLE FAULT
852	07-01-2026	Part of : DALMIA VIHAR BIJWASAN	122	Other Outage	Planned Outage	07-01-2026	10:53	07-01-2026	11:52	0:59	0.000000	REPLACEMENT OF HT BUSHING ROD
853	07-01-2026	Part of : GHITORNI VILLAGE	1130	Other Outage	Planned Outage	07-01-2026	14:00	07-01-2026	15:52	1:52	0.000373	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
854	07-01-2026	Part of : WEST END GREENS RANGPURI	3	Other Outage	Planned Outage	07-01-2026	12:23	07-01-2026	14:31	2:08	0.001244	REPLACEMENT OF HT BUSHING ROD
855	07-01-2026	Part of : ANAND GRAM GHITORNI	186	Other Outage	Planned Outage	07-01-2026	11:02	07-01-2026	14:00	2:58	0.000494	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
856	07-01-2026	Part of : LAKHI NATH KUTI MEHRAULI	667	Other Outage	Planned Outage	07-01-2026	10:11	07-01-2026	12:35	2:24	0.001600	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
857	07-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	10	Other Outage	Planned Outage	07-01-2026	10:41	07-01-2026	12:50	2:09	0.001254	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
858	08-01-2026	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	548	Other Outage	Planned Outage	08-01-2026	11:11	08-01-2026	12:53	1:42	0.000000	AUXILARY SUPPLY FOR RELAYS,REPLACEMET OF FAULTY END BOX
859	08-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	2	Other Outage	Planned Outage	08-01-2026	10:58	08-01-2026	12:12	1:14	0.000719	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMET OF LUGS
860	08-01-2026	Part of : ANAND GRAM GHITORNI	57	Other Outage	Planned Outage	08-01-2026	11:01	08-01-2026	13:14	2:13	0.000369	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
861	08-01-2026	Part of : RANGPURI PAHARI	168	Other Outage	Planned Outage	08-01-2026	10:43	08-01-2026	13:57	3:14	0.002425	REPLACEMENT OF LT BUSHING ROD
862	08-01-2026	Part of : POCKET 8 SECTOR D VASANT KUNJ	245	Other Outage	Planned Outage	08-01-2026	10:44	08-01-2026	13:40	2:56	0.000489	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
863	08-01-2026	Part of : POCKET 9 SECTOR C VASANT KUNJ	243	Other Outage	Planned Outage	08-01-2026	10:49	08-01-2026	13:51	3:02	0.000506	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
864	08-01-2026	Part of : TEACHER COLONY MEHRAULI	286	Other Outage	Planned Outage	08-01-2026	10:36	08-01-2026	13:57	3:21	0.002233	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
865	09-01-2026	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ,POCKET C.SECTOR A VASANT KUNJ	1730	Other Outage	Unplanned Outage	09-01-2026	16:16	09-01-2026	16:53	0:37	0.000565	BIRADGE
866	09-01-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ,	800	Other Outage	Planned Outage	09-01-2026	14:01	09-01-2026	15:01	1:00	0.000167	MAINTENANCE OF RMU
867	09-01-2026	Part of : ANAND GRAM GHITORNI,	49	Other Outage	Planned Outage	09-01-2026	12:01	09-01-2026	13:42	1:41	0.000337	MAINTENANCE OF TRANSFORMER
868	09-01-2026	Part of : PALAM FARMS,	6	Other Outage	Planned Outage	09-01-2026	12:20	09-01-2026	13:53	1:33	0.000000	MAINTENANCE OF TRANSFORMER
869	09-01-2026	Part of : KAPAS HERA EXTENSION KAPAS HERA,PALAM FARMS,PUSHPANJALI FARMS,	1872	Other Outage	Planned Outage	09-01-2026	10:13	09-01-2026	11:38	1:25	0.000000	MAINTENANCE OF HT O/H CIRCUIT
870	09-01-2026	Part of : KAPAS HERA EXTENSION KAPAS HERA,	238	Other Outage	Planned Outage	09-01-2026	11:06	09-01-2026	13:10	2:04	0.001206	MAINTENANCE OF TRANSFORMER
871	09-01-2026	Part of : WEST END GREENS RANGPURI,	9	Other Outage	Planned Outage	09-01-2026	10:57	09-01-2026	13:25	2:28	0.001439	MAINTENANCE OF TRANSFORMER
872	09-01-2026	Part of : POCKET 8 SECTOR C VASANT KUNJ,	147	Other Outage	Planned Outage	09-01-2026	10:43	09-01-2026	13:43	3:00	0.000500	MAINTENANCE OF TRANSFORMER
873	10-01-2026	PART OF : KISHANGARH VILLAGE SECTOR A VASANT KUNJ	1278	Other Outage	Planned Outage	10-01-2026	13:01	10-01-2026	13:09	0:08	0.000089	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
874	10-01-2026	PART OF : INDIRA GANDHI INTERNATIONAL AIRPORT	2	Other Outage	Planned Outage	10-01-2026	14:07	10-01-2026	16:01	1:54	0.002375	REPLACEMENT OF LT BUSHING ROD
875	10-01-2026	PART OF : DALMIA VIHAR BIJWASAN	273	Other Outage	Planned Outage	10-01-2026	11:33	10-01-2026	12:55	1:22	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
876	10-01-2026	PART OF : ROOPAM WALA KUNWA MEHRAULI,LAKHI NATH KUTI MEHRAULI	2878	Other Outage	Planned Outage	10-01-2026	10:29	10-01-2026	13:50	3:21	0.000000	BIRD SPIKES INSTALLATION PER POLE,HT SLEEVE INSTALLATION PER SPAN,JUMPER REPLACEMENT PER POLE
877	10-01-2026	PART OF : LAKHI NATH KUTI MEHRAULI,ROOPAM WALA KUNWA MEHRAULI	3789	Other Outage	Planned Outage	10-01-2026	10:27	10-01-2026	13:35	3:08	0.000000	CONDUCTOR REPLACEMENT PER SPAN,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
878	10-01-2026	PART OF : KAPAS HERA ESTATE	458	Other Outage	Planned Outage	10-01-2026	10:55	10-01-2026	13:31	2:36	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
879	10-01-2026	PART OF : ANAND GRAM GHITORNI	148	Other Outage	Planned Outage	10-01-2026	11:13	10-01-2026	13:21	2:08	0.000427	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
880	10-01-2026	PART OF : POCKET 2 SECTOR C VASANT KUNJ	519	Other Outage	Planned Outage	10-01-2026	10:57	10-01-2026	13:50	2:53	0.000481	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
881	12-01-2026	Part of : AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	468	Other Outage	Planned Outage	12-01-2026	11:49	12-01-2026	13:30	1:41	0.000673	APPLY OF INSULATION TAPE HT/LT BUSHINGS
882	12-01-2026	Part of : ANAND GRAM GHITORNI	81	Other Outage	Planned Outage	12-01-2026	11:09	12-01-2026	13:01	1:52	0.000467	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT PER SPAN
883	12-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	14	Other Outage	Planned Outage	12-01-2026	10:52	12-01-2026	12:10	1:18	0.000758	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
884	12-01-2026	Part of : POCKET 9 SECTOR C VASANT KUNJ	233	Other Outage	Planned Outage	12-01-2026	10:31	12-01-2026	13:26	2:55	0.000486	MEASUREMENT OF INSULATION RESISTANCE
885	12-01-2026	Part of : RANGPURI PAHARI	83	Other Outage	Planned Outage	12-01-2026	11:01	12-01-2026	14:21	3:20	0.001667	REPLACEMENT OF LT BUSHING ROD
886	12-01-2026	Part of : PALAM FARMS,SLASH PUR VILLAGE PALAM FARMS	3442	Other Outage	Planned Outage	12-01-2026	10:11	12-01-2026	12:33	2:22	0.000000	BIRD SPIKES INSTALLATION PER POLE,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
887	13-01-2026	Part of : GHITORNI VILLAGE GHITORNI	0	Other Outage	Unplanned Outage	13-01-2026	19:07	13-01-2026	19:40	0:33	0.000000	CABLE FAULT
888	13-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	8	Other Outage	Planned Outage	13-01-2026	10:50	13-01-2026	11:38	0:48	0.000467	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
889	13-01-2026	Part of : PUSHPANJALI FARMS	280	Other Outage	Planned Outage	13-01-2026	11:40	13-01-2026	13:06	1:26	0.000000	3PH DB REPLACEMENT
890	13-01-2026	Part of : SECTOR D VASANT KUNJ	219	Other Outage	Planned Outage	13-01-2026	11:01	13-01-2026	13:25	2:24	0.002600	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
891	13-01-2026	Part of : POCKET 8 SECTOR C VASANT KUNJ	625	Other Outage	Planned Outage	13-01-2026	11:02	13-01-2026	14:02	3:00	0.000500	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
892	13-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	447	Other Outage	Planned Outage	13-01-2026	11:20	13-01-2026	13:29	2:09	0.000000	CONDUCTOR REPLACEMENT PER SPAN
893	14-01-2026	Part of : MEHRAULI VILLAGE MEHRAULI,LADHA SARAI VILLAGE MEHRAULI	1044	Other Outage	Planned Outage	14-01-2026	15:06	14-01-2026	16:02	0:56	0.000622	JUMPER REPLACEMENT & GUARD WIRES SAGGING PER SPAN
894	14-01-2026	Part of : GHITORNI VILLAGE GHITORNI	1218	Other Outage	Planned Outage	14-01-2026	14:06	14-01-2026	15:40	1:34	0.000392	REPLACEMENT OF GAS KIT AND OIL SEAL
895	14-01-2026	Part of : R BLOCK MAHIPALPUR VILLAGE MAHIPALPUR	2	Other Outage	Planned Outage	14-01-2026	11:19	14-01-2026	13:19	2:00	0.001500	REPLACEMENT OF LT BUSHING ROD
896	14-01-2026	Part of : PALAM FARMS,SLASH PUR VILLAGE PALAM FARMS	3442	Other Outage	Planned Outage	14-01-2026	11:27	14-01-2026	13:06	1:39	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES
897	15-01-2026	Part of : SLASH PUR VILLAGE PALAM FARMS	1251	Other Outage	Planned Outage	15-01-2026	15:47	15-01-2026	16:01	0:14	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
898	15-01-2026	Part of : ARJUN GARH AYA NAGAR	51	Other Outage	Planned Outage	15-01-2026	13:07	15-01-2026	14:11	1:04	0.000213	REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
899	15-01-2026	Part of : GHITORNI VILLAGE	177	Other Outage	Planned Outage	15-01-2026	11:39	15-01-2026	14:22	2:43	0.000453	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
900	15-01-2026	Part of : HARIJAN BASTI RAJOKRI	11	Other Outage	Planned Outage	15-01-2026	10:54	15-01-2026	13:43	2:49	0.001643	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
901	15-01-2026	Part of : POCKET 8 SECTOR C VASANT KUNJ	277	Other Outage	Planned Outage	15-01-2026	11:13	15-01-2026	14:09	2:56	0.000489	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
902	15-01-2026	Part of : AHINSHA ENCLAVE MEHRAULI	449	Other Outage	Planned Outage	15-01-2026	11:10	15-01-2026	13:55	2:45	0.001833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
903	15-01-2026	Part of : INDIRA GANDHI INTERNATIONAL AIRPORT	1	Other Outage	Planned Outage	15-01-2026	10:57	15-01-2026	13:20	2:23	0.000794	REPLACEMET OF HT BUSHING ROD
904	16-01-2026	Part of : BLOCK A,B & B1 SEWAK PARK DWARKA,SHANTI PARK DWARKA	1872	Other Outage	Planned Outage	16-01-2026	11:53	16-01-2026	13:21	1:28	0.000000	GUARD WIRES SAGGING PER SPAN
905	16-01-2026	Part of : BLOCK A DDA FLATE SAKET	180	Other Outage	Planned Outage	16-01-2026	11:11	16-01-2026	13:06	1:55	0.000639	REPLACEMENT OF LT BUSHING ROD
906	16-01-2026	Part of : BLOCK M VINOBA PURI LAJPAT NAGAR II	59	Other Outage	Planned Outage	16-01-2026	11:01	16-01-2026	12:55	1:54	0.000317	INSTALLATION OF BUS BAR,SUB STATION CLEANING
907	16-01-2026	Part of : BLOCK A & D VISHWAKARMA COLONY PULPEHLADPUR	229	Other Outage	Planned Outage	16-01-2026	10:26	16-01-2026	13:23	2:57	0.000492	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
908	16-01-2026	Part of : CHIRAG DELHI	29	Other Outage	Planned Outage	16-01-2026	11:02	16-01-2026	13:24	2:22	0.001381	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER
909	17-01-2026	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS	3525	Other Outage	Unplanned Outage	17-01-2026	15:55	17-01-2026	16:23	0:28	0.000668	BIRDAGE
910	17-01-2026	Part of : ROOPAM WALA KUNWA MEHRAULI,LAKHI NATH KUTI MEHRAULI	1471	Other Outage	Unplanned Outage	17-01-2026	12:25	17-01-2026	13:02	0:37	0.000337	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
911	17-01-2026	Part of : ANAND GRAM GHITORNI,GHITORNI VILLAGE GHITORNI	2223	Other Outage	Unplanned Outage	17-01-2026	10:43	17-01-2026	11:33	0:50	0.001151	CABLE FAULT
912	17-01-2026	Part of : HTC:TEMP JKUMAR AEROCITY	0	Other Outage	Unplanned Outage	17-01-2026	03:43	17-01-2026	04:19	0:36	0.000000	FAULT IN HT CONSUMER PANEL (J KUMAR AEROCITY)
913	17-01-2026	Part of : SETH SARAI MEHRAULI	1	Other Outage	Planned Outage	17-01-2026	15:00	17-01-2026	16:50	1:50	0.001222	MAINTENANCE OF TRANSFORMER
914	17-01-2026	Part of : GHITORNI VILLAGE	42	Other Outage	Planned Outage	17-01-2026	11:45	17-01-2026	14:20	2:35	0.004736	MAINTENANCE OF HT O/H CIRCUIT
915	17-01-2026	Part of : POCKET 9 SECTOR C VASANT KUNJ	163	Other Outage	Planned Outage	17-01-2026	10:17	17-01-2026	13:11	2:54	0.000483	MAINTENANCE OF TRANSFORMER
916	17-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	13	Other Outage	Planned Outage	17-01-2026	11:04	17-01-2026	13:48	2:44	0.001594	MAINTENANCE OF TRANSFORMER
917	19-01-2026	Part of : WEST END GREENS RANGPURI,AVENUE BOUGANVILLEA,HARIJAN BASTI RAJOKRI,AVENUE JHAKARANDA GOLDEN GRITERS	213	Other Outage	Unplanned Outage	19-01-2026	02:33	19-01-2026	03:01	0:28	0.000000	TREE TOUCHING
918	19-01-2026	Part of : NAYAK PURA BIJWASAN	579	Other Outage	Planned Outage	19-01-2026	10:52	19-01-2026	12:01	1:09	0.000000	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
919	19-01-2026	Part of : SAMALKA	744	Other Outage	Planned Outage	19-01-2026	10:45	19-01-2026	12:19	1:34	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
920	19-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	9	Other Outage	Planned Outage	19-01-2026	10:46	19-01-2026	12:19	1:33	0.000904	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER
921	19-01-2026	Part of : POCKET 9 SECTOR C VASANT KUNJ	156	Other Outage	Planned Outage	19-01-2026	12:02	19-01-2026	14:56	2:54	0.000483	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
922	19-01-2026	Part of : POCKET 2 SECTOR C VASANT KUNJ	225	Other Outage	Planned Outage	19-01-2026	10:40	19-01-2026	13:39	2:59	0.000497	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
923	19-01-2026	Part of : MAHIPALPUR VILLAGE	768	Other Outage	Planned Outage	19-01-2026	10:57	19-01-2026	14:57	4:00	0.003667	REPLACEMET OF HT BUSHING ROD
924	19-01-2026	Part of : WEST END GREENS RANGPURI	9	Other Outage	Planned Outage	19-01-2026	10:57	19-01-2026	14:57	4:00	0.001667	REPLACEMET OF HT BUSHING ROD
925	20-01-2026	Part of : MEHRAULI VILLAGE	667	Other Outage	Planned Outage	20-01-2026	15:18	20-01-2026	15:45	0:27	0.000300	APPLY OF INSULATION TAPE HT/LT BUSHINGS
926	20-01-2026	Part of : GHITORNI VILLAGE	147	Other Outage	Planned Outage	20-01-2026	11:19	20-01-2026	13:32	2:13	0.000369	SUB STATION CLEANING
927	20-01-2026	Part of : SAMALKA	559	Other Outage	Planned Outage	20-01-2026	10:41	20-01-2026	12:56	2:15	0.000563	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS
928	20-01-2026	Part of : KAPAS HERA EXTENSION	703	Other Outage	Planned Outage	20-01-2026	10:42	20-01-2026	12:55	2:13	0.001293	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
929	20-01-2026	Part of : SLASH PUR VILLAGE PALAM FARMS	1251	Other Outage	Planned Outage	20-01-2026	10:40	20-01-2026	12:41	2:01	0.000000	TAPPING OF UG CABLE TO OH JUMPER CONNECTION,TIGHTENING OF HARDWARE FITTINGS
930	20-01-2026	Part of : RANGPURI PAHARI	99	Other Outage	Planned Outage	20-01-2026	11:20	20-01-2026	13:30	2:10	0.000903	REPLACEMENT OF LT BUSHING ROD
931	20-01-2026	Part of : BADIWALA KUA MEHRAULI,ISLAM COLONY MEHRAULI	2397	Other Outage	Planned Outage	20-01-2026	10:31	20-01-2026	12:35	2:04	0.001378	GUARD WIRE LACS INSTALLTION PER SPAN,TAPPING OF JUMPERS
932	21-01-2026	Part of : WEST END GREENS RANGPURI,	7	Other Outage	Planned Outage	21-01-2026	13:20	21-01-2026	15:24	2:04	0.000861	TRANSFORMER MAINTENANCE
933	21-01-2026	Part of : GHITORNI VILLAGE GHITORNI,	679	Other Outage	Planned Outage	21-01-2026	11:51	21-01-2026	14:39	2:48	0.005133	TRANSFORMER MAINTENANCE
934	21-01-2026	Part of : SECTOR D VASANT KUNJ,	25	Other Outage	Planned Outage	21-01-2026	11:37	21-01-2026	14:31	2:54	0.000483	HT CIRCUIT MAINTENANCE
935	22-01-2026	Part of : DALMIA VIHAR BIJWASAN	335	Other Outage	Planned Outage	22-01-2026	10:59	22-01-2026	12:10	1:11	0.000000	HT SLEEVE INSTALLATION PER SPAN,TIGHTENING OF HARDWARE FITTINGS
936	22-01-2026	Part of : ROOPAM WALA KUNWA MEHRAULI,LAKHI NATH KUTI MEHRAULI	2881	Other Outage	Planned Outage	22-01-2026	10:04	22-01-2026	14:04	4:00	0.000000	CONDUCTOR REPLACEMENT PER SPAN,HT SLEEVE INSTALLATION PER SPAN,JUMPER REPLACEMENT PER POLE,TAPPING OF JUMPERS
937	22-01-2026	Part of : LAKHI NATH KUTI MEHRAULI,ROOPAM WALA KUNWA MEHRAULI	3792	Other Outage	Planned Outage	22-01-2026	10:04	22-01-2026	14:05	4:01	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE
938	22-01-2026	Part of : POCKET 6 SECTOR C VASANT KUNJ	24	Other Outage	Planned Outage	22-01-2026	10:18	22-01-2026	13:18	3:00	0.000500	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
939	23-01-2026	Part of : AVENUE BOUGANVILLEA RANGPURI	18	Other Outage	Planned Outage	23-01-2026	13:32	23-01-2026	15:17	1:45	0.000583	REPLACEMENT OF HT BUSHING ROD
940	24-01-2026	Part of : MES MARRIED ACOMODATION RANGPURI (HTC)	1	Other Outage	Unplanned Outage	24-01-2026	18:17	24-01-2026	18:33	0:16	0.000071	CABLE FAULT
941	24-01-2026	Part of : KAPAS HERA ESTATE	1	Other Outage	Planned Outage	24-01-2026	11:09	24-01-2026	11:35	0:26	0.000253	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
942	24-01-2026	Part of : ANAND GRAM GHITORNI	33	Other Outage	Planned Outage	24-01-2026	16:15	24-01-2026	17:02	0:47	0.000157	INSTALLATION OF BUS BAR,TIGHTENEING OF NUT BOLT
943	24-01-2026	Part of : POCKET 2 SECTOR C VASANT KUNJ	260	Other Outage	Planned Outage	24-01-2026	10:30	24-01-2026	13:22	2:52	0.000478	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
944	24-01-2026	Part of : RANGPURI PAHARI	189	Other Outage	Planned Outage	24-01-2026	10:57	24-01-2026	13:04	2:07	0.000706	REPLACEMENT OF LT BUSHING ROD
945	25-01-2026	Part of : MAHIPALPUR VILLAGE	498	Other Outage	Unplanned Outage	25-01-2026	10:39	25-01-2026	11:09	0:30	0.000175	CABLE FAULT
946	27-01-2026	Part of : POCKET 3 SECTOR B VASANT KUNJ	155	Other Outage	Planned Outage	27-01-2026	14:54	27-01-2026	16:02	1:08	0.000189	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
947	27-01-2026	Part of : KAPAS HERA ESTATE	1	Other Outage	Planned Outage	27-01-2026	10:46	27-01-2026	12:20	1:34	0.000653	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER
948	27-01-2026	Part of : MEHRAULI VILLAGE	668	Other Outage	Planned Outage	27-01-2026	13:50	27-01-2026	16:12	2:22	0.000394	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
949	27-01-2026	Part of : TEACHER COLONY,LAKHI NATH KUTI,,BRAHMAN MOHALLA MEHRAULI,POCKET 4,5,6 SECTOR B VASANT KUNJ	2399	Other Outage	Planned Outage	27-01-2026	10:53	27-01-2026	14:42	3:49	0.002544	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE
950	27-01-2026	Part of : WEST END GREENS RANGPURI	11	Other Outage	Planned Outage	27-01-2026	10:42	27-01-2026	13:16	2:34	0.001069	REPLACEMET OF HT BUSHING ROD
951	28-01-2026	Part of : AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	467	Other Outage	Planned Outage	28-01-2026	10:44	28-01-2026	12:01	1:17	0.000749	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF GAS KIT AND OIL SEAL
952	28-01-2026	Part of : ANAND GRAM GHITORNI	21	Other Outage	Planned Outage	28-01-2026	10:44	28-01-2026	14:08	3:24	0.000567	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
953	28-01-2026	Part of : RANGPURI NALLAPAR	253	Other Outage	Planned Outage	28-01-2026	10:57	28-01-2026	13:55	2:58	0.000000	REPLACEMENT OF LT BUSHING ROD
954	29-01-2026	Part of : POCKET 9 SECTOR C VASANT KUNJ,	176	Other Outage	Planned Outage	29-01-2026	10:42	29-01-2026	13:32	2:50	0.000472	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
955	29-01-2026	Part of : RANGPURI PAHARI RANGPURI,	218	Other Outage	Planned Outage	29-01-2026	11:03	29-01-2026	13:59	2:56	0.000000	REPLACEMENT OF LT BUSHING ROD
956	30-01-2026	Part of : BADIWALA KUA MEHRAULI,ISLAM COLONY MEHRAULI,POCKET A SECTOR A VASANT KUNJ,KALKA DASS MEHRAULI	2399	Other Outage	Planned Outage	30-01-2026	13:03	30-01-2026	13:55	0:52	0.000578	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE
957	30-01-2026	Part of : POCKET A SECTOR A VASANT KUNJ	762	Other Outage	Planned Outage	30-01-2026	12:52	30-01-2026	13:23	0:31	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
958	30-01-2026	Part of : CHRISTIAN COLONY MEHRAULI	414	Other Outage	Planned Outage	30-01-2026	12:51	30-01-2026	14:22	1:31	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
959	30-01-2026	Part of : KAPAS HERA ESTATE	1	Other Outage	Planned Outage	30-01-2026	11:09	30-01-2026	12:25	1:16	0.000739	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
960	30-01-2026	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	1073	Other Outage	Planned Outage	30-01-2026	11:08	30-01-2026	15:55	4:47	0.000000	TAPPING OF JUMPERS ,TAPPING OF UG CABLE TO OH JUMPER CONNECTION,TIGHTENING OF HARDWARE FITTINGS
961	30-01-2026	Part of : SECTOR D VASANT KUNJ	21	Other Outage	Planned Outage	30-01-2026	10:53	30-01-2026	13:01	2:08	0.000427	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
962	30-01-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	621	Other Outage	Planned Outage	30-01-2026	10:47	30-01-2026	13:43	2:56	0.000489	REPLACEMENT OF LT BUSHING ROD
963	30-01-2026	Part of : INDIRA GANDHI INTERNATIONAL AIRPORT	6	Other Outage	Planned Outage	30-01-2026	10:58	30-01-2026	13:15	2:17	0.000951	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
964	31-01-2026	Part of : CPRF PLOT NO-8(HT CONSUMER)	1	Other Outage	Planned Outage	31-01-2026	14:26	31-01-2026	16:01	1:35	0.000264	INSTALLATION OF BUS BAR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
965	31-01-2026	Part of : GHITORNI VILLAGE	219	Other Outage	Planned Outage	31-01-2026	13:44	31-01-2026	15:57	2:13	0.000369	REPLACEMENT OF HT BUSHING ROD
966	31-01-2026	Part of : POCKET 8 SECTOR C VASANT KUNJ	6	Other Outage	Planned Outage	31-01-2026	11:04	31-01-2026	13:53	2:49	0.000469	REPLACEMENT OF HT BUSHING ROD
967	31-01-2026	Part of : R-BLOCK MAHIPALPUR VILLAGE	1	Other Outage	Planned Outage	31-01-2026	10:57	31-01-2026	14:14	3:17	0.001915	REPLACEMENT OF HT BUSHING ROD
968	01-01-2026	Part of : SUBHASH PARK MATIALA,NANHEY PARK OM VIHAR UTTAM NAGAR,BLOCK B OM VIHAR UTTAM NAGAR,SUKH RAM PARK MATIALA,JAIN PARK OM VIHAR UTTAM NAGAR,GURPREET NAGAR MATIALA,BLOCK E MATIALA,BLOCK B MANSA RAM PARK UTTAM NAGAR,SECTOR 3 DWARKA	5762	Other Outage	Unplanned Outage	01-01-2026	04:55	01-01-2026	05:34	0:39	0.000293	HVDS FAULT
969	01-01-2026	Part of : HARI VIHAR SECTOR 15 DWARKA,RAJU ENCLAVE SECTOR 15 DWARKA,	1056	Other Outage	Planned Outage	01-01-2026	11:37	01-01-2026	13:48	2:11	0.000000	REPLACEMENT OF HT BUSHING ROD
970	02-01-2026	Part of : SECTOR 3 DWARKA	213	Other Outage	Planned Outage	02-01-2026	14:47	02-01-2026	16:49	2:02	0.000000	REPLACEMENT OF HT BUSHING ROD
971	03-01-2026	Part of : SECTOR 11 DWARKA,POCKET 1 SECTOR-5	1851	Other Outage	Planned Outage	03-01-2026	14:06	03-01-2026	16:09	2:03	0.000000	REPLACEMENT OF HT BUSHING ROD
972	04-01-2026	Part of : SECTOR 4 DWARKA	341	Other Outage	Unplanned Outage	04-01-2026	21:16	04-01-2026	21:49	0:33	0.000092	CABLE FAULT
973	05-01-2026	Part of : BLOCK G VISWAS PARK MATIALA,BLOCK B SANJAY ENCLAVE UTTAM NAGAR	1724	Other Outage	Planned Outage	05-01-2026	12:04	05-01-2026	14:43	2:39	0.000000	MAINTENANCE OF TRANSFORMER
974	05-01-2026	Part of : SECTOR 6 DWARKA,	193	Other Outage	Planned Outage	05-01-2026	10:57	05-01-2026	13:22	2:25	0.000000	MAINTENANCE OF TRANSFORMER
975	05-01-2026	Part of : SECTOR 3 DWARKA,	153	Other Outage	Planned Outage	05-01-2026	11:22	05-01-2026	13:29	2:07	0.000000	MAINTENANCE OF TRANSFORMER
976	06-01-2026	Part of : SECTOR 12 DWARKA	76	Other Outage	Planned Outage	06-01-2026	14:55	06-01-2026	16:38	1:43	0.000000	REPLACEMENT OF HT BUSHING ROD
977	07-01-2026	Part of : JAIN COLONY MATIALA	4506	Other Outage	Planned Outage	07-01-2026	11:27	07-01-2026	13:16	1:49	0.000000	REPLACEMENT OF HT BUSHING ROD
978	08-01-2026	Part of : POCKET 1 & 2 SECTOR 19 DWARKA,POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA,BLOCK B SECTOR 19 DWARKA,SECTOR 10 DWARKA	1727	Other Outage	Unplanned Outage	08-01-2026	17:28	08-01-2026	18:32	1:04	0.001067	CABLE FAULT
979	09-01-2026	Part of : BLOCK G VISWAS PARK MATIALA,BLOCK B SANJAY ENCLAVE UTTAM NAGAR,BLOCK A SANJAY ENCLAVE UTTAM NAGAR,BHAGWATI VIHAR BINDAPUR,BLOCK B SUBHASH PARK MATIALA	3029	Other Outage	Unplanned Outage	09-01-2026	01:55	09-01-2026	02:50	0:55	0.000336	CABLE FAULT
980	09-01-2026	Part of : BLOCK D UTTAM VIHAR BINDAPUR,BLOCK A BHARAT NAGAR MADHU VIHAR,BLOCK A3 UTTAM VIHAR BINDAPUR	1638	Other Outage	Planned Outage	09-01-2026	11:09	09-01-2026	13:22	2:13	0.000000	MAINTENANCE OF TRANSFORMER
981	10-01-2026	Part of : SECTOR 13 DWARKA,BHARAT VIHAR DWARKA,RAJU PARAK EXTENSION DWARKA	3223	Other Outage	Unplanned Outage	10-01-2026	06:04	10-01-2026	06:53	0:49	0.000463	TREE TOUCHING
982	10-01-2026	PART OF : C-BLOCK MADHU VIHAR,BLOCK RZ MADHU VIHAR	1228	Other Outage	Planned Outage	10-01-2026	12:35	10-01-2026	14:22	1:47	0.000000	REPLACEMENT OF HT BUSHING ROD
983	11-01-2026	Part of : NISHAT PARK,A & WZ-BLOCK PATEL GARDEN,SECTOR 15 DWARKA,SURAJ VIHAR DWARKA	3883	Other Outage	Unplanned Outage	11-01-2026	13:58	11-01-2026	14:41	0:43	0.000836	CABLE FAULT
984	12-01-2026	Part of : BLOCK G VISWAS PARK,BLOCK A & B SANJAY ENCLAVE,BHAGWATI VIHAR BINDAPUR	1724	Other Outage	Planned Outage	12-01-2026	11:14	12-01-2026	13:39	2:25	0.000000	REPLACEMENT OF HT BUSHING ROD
985	13-01-2026	Part of : SECTOR 3 DWARKA,BLOCK A RAJAPURI MATIALA	1885	Other Outage	Unplanned Outage	13-01-2026	02:34	13-01-2026	02:55	0:21	0.000204	CABLE FAULT
986	13-01-2026	Part of : ISPATIKA PLOT-29 SEC-4 (HTC)	1	Other Outage	Unplanned Outage	13-01-2026	12:34	13-01-2026	13:12	0:38	0.000095	CABLE FAULT
987	13-01-2026	Part of : BLOCK G JAIN COLONY MATIALA,JAIN COLONY MATIALA	1796	Other Outage	Unplanned Outage	13-01-2026	11:21	13-01-2026	13:17	1:56	0.000000	REPAIRING OF RMU
988	14-01-2026	Part of : SECTOR 3 DWARKA	210	Other Outage	Planned Outage	14-01-2026	16:04	14-01-2026	17:14	1:10	0.000000	REPLACEMENT OF HT BUSHING ROD
989	17-01-2026	Part of : D-BLOCK MADHU VIHAR,SECTOR 6 DWARKA	2306	Other Outage	Unplanned Outage	17-01-2026	09:40	17-01-2026	10:01	0:21	0.000000	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
990	18-01-2026	Part of : SECTOR 6 DWARKA	877	Other Outage	Unplanned Outage	18-01-2026	12:58	18-01-2026	13:54	0:56	0.000920	HT SYSTEM FAULT
991	20-01-2026	Part of : TRANSIT CAMP DWARKA, SEC-15 SHYAM VIHAR, BHARAT VIHAR DWARKA, POKET 1 SECTOR 14 DWARKA	2267	Other Outage	Unplanned Outage	20-01-2026	09:07	20-01-2026	10:01	0:54	0.001393	HVDS FAULT
992	24-01-2026	Part of : C-BLOCK MADHU VIHAR,BLOCK RZ MADHU VIHAR	1228	Other Outage	Planned Outage	24-01-2026	11:18	24-01-2026	13:32	2:14	0.000000	REPLACEMET OF HT BUSHING ROD
993	25-01-2026	Part of : SECTOR 13 DWARKA	1111	Other Outage	Unplanned Outage	25-01-2026	13:55	25-01-2026	14:33	0:38	0.000488	CABLE FAULT
994	25-01-2026	Part of : BHARAT VIHAR DWARKA	697	Other Outage	Unplanned Outage	25-01-2026	15:05	25-01-2026	16:52	1:47	0.000000	REPAIRING OF LT ACB
995	26-01-2026	Part of : KAKRAULA VILLAGE DWARKA,POCKET 3 SECTOR 16B DWARKA,TRANSIT CAMP DWARKA	1972	Other Outage	Unplanned Outage	26-01-2026	01:58	26-01-2026	03:01	1:03	0.000569	CABLE FAULT
996	29-01-2026	Part of : MAHAVIR ENCLAVE PART 3 MAHAVIR ENCLAVE,	1819	Other Outage	Unplanned Outage	29-01-2026	12:26	29-01-2026	14:15	1:49	0.000000	CONNECTION/DISCONNECTION OF LT CABLE
997	29-01-2026	Part of : BHARAT VIHAR DWARKA,	697	Other Outage	Unplanned Outage	29-01-2026	12:15	29-01-2026	14:01	1:46	0.000000	INSTALLATION OF ADDITIONAL TRANSFORMER
998	29-01-2026	Part of : SECTOR 3 DWARKA,	140	Other Outage	Planned Outage	29-01-2026	15:32	29-01-2026	16:53	1:21	0.000000	REPLACEMENT OF LT BUSHING ROD
999	31-01-2026	Part of : PRODYOGIKI SEC-3 PLOT-11 DWARKA (HT CONSUMER)	1	Other Outage	Planned Outage	31-01-2026	12:52	31-01-2026	13:44	0:52	0.000000	REPLACEMENT OF HT BUSHING ROD
1000	01-01-2026	Part of : MANDHELA KALAN VILLAGE,	38	Other Outage	Planned Outage	01-01-2026	15:48	01-01-2026	16:47	0:59	0.000164	REPLACEMET OF HT BUSHING ROD
1001	01-01-2026	Part of : MALIKPUR ZER VILLAGE,	401	Other Outage	Planned Outage	01-01-2026	15:09	01-01-2026	16:47	1:38	0.000272	REPLACEMENT OF LT BUSHING ROD
1002	01-01-2026	Part of : MITRAON VILLAGE NAJAFGARH,KAIR VILLAGE,SUREHRA VILLAGE,	1530	Other Outage	Planned Outage	01-01-2026	15:45	01-01-2026	16:47	1:02	0.000861	GUARD WIRES SAGGING PER SPAN
1003	01-01-2026	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	691	Other Outage	Planned Outage	01-01-2026	15:46	01-01-2026	16:48	1:02	0.000861	REPLACEMET OF HT BUSHING ROD
1004	01-01-2026	Part of : GHALLBPUR VILLAGE,	1	Other Outage	Planned Outage	01-01-2026	13:04	01-01-2026	15:46	2:42	0.000450	REPLACEMENT OF LT BUSHING ROD
1005	01-01-2026	Part of : SHYAM ENCAVE NAJAFGARH,	310	Other Outage	Planned Outage	01-01-2026	12:35	01-01-2026	15:03	2:28	0.000411	REPLACEMENT OF LT BUSHING ROD
1006	02-01-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	248	Other Outage	Planned Outage	02-01-2026	14:55	02-01-2026	16:56	2:01	0.000336	REPLACEMENT OF LT BUSHING ROD
1007	02-01-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1406	Other Outage	Planned Outage	02-01-2026	12:15	02-01-2026	14:59	2:44	0.002278	REPLACEMENT OF HT BUSHING ROD
1008	02-01-2026	Part of : SHYAM ENCAVE NAJAFGARH	314	Other Outage	Planned Outage	02-01-2026	12:39	02-01-2026	14:47	2:08	0.001778	REPLACEMENT OF HT BUSHING ROD
1009	03-01-2026	Part of : SARANGPUR VILLAGE,QAZIPUR VILLAGE,DHANSA VILLAGE,JAFARPUR KALAN VILLAGE,ISSAPUR VILLAGE,BADHOSRA	3709	Other Outage	Unplanned Outage	03-01-2026	11:16	03-01-2026	11:55	0:39	0.000563	CABLE FAULT
1010	03-01-2026	Part of : SRI HANS NAGAR	510	Other Outage	Planned Outage	03-01-2026	14:58	03-01-2026	15:54	0:56	0.000778	REPLACEMENT OF HT BUSHING ROD
1011	03-01-2026	Part of : JAFARPUR KALAN VILLAGE	1	Other Outage	Planned Outage	03-01-2026	11:06	03-01-2026	13:54	2:48	0.000467	REPLACEMENT OF HT BUSHING ROD
1012	03-01-2026	Part of : MANDHELA KALAN VILLAGE	281	Other Outage	Planned Outage	03-01-2026	11:17	03-01-2026	13:25	2:08	0.001778	REPLACEMENT OF HT BUSHING ROD
1013	05-01-2026	Part of : MITRAON VILLAGE NAJAFGARH,KAIR VILLAGE,SUREHRA VILLAGE,	1530	Other Outage	Planned Outage	05-01-2026	14:05	05-01-2026	16:47	2:42	0.002250	MAINTENANCE OF HT O/H CIRCUIT
1014	05-01-2026	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	105	Other Outage	Planned Outage	05-01-2026	14:11	05-01-2026	16:46	2:35	0.002153	MAINTENANCE OF TRANSFORMER
1015	05-01-2026	Part of : SHYAM ENCAVE NAJAFGARH,	314	Other Outage	Planned Outage	05-01-2026	12:48	05-01-2026	15:57	3:09	0.002625	MAINTENANCE OF TRANSFORMER
1016	05-01-2026	Part of : JAFARPUR KALAN VILLAGE,	61	Other Outage	Planned Outage	05-01-2026	11:13	05-01-2026	13:52	2:39	0.000442	MAINTENANCE OF TRANSFORMER
1017	06-01-2026	Part of : MANDHELA KHURD VILLAGE	429	Other Outage	Planned Outage	06-01-2026	12:30	06-01-2026	14:01	1:31	0.000253	REPLACEMENT OF HT BUSHING ROD
1018	06-01-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	320	Other Outage	Planned Outage	06-01-2026	14:10	06-01-2026	16:16	2:06	0.000700	REPLACEMENT OF LT BUSHING ROD
1019	06-01-2026	Part of : BADHOSRA	315	Other Outage	Planned Outage	06-01-2026	11:22	06-01-2026	13:28	2:06	0.000350	REPLACEMENT OF LT BUSHING ROD
1020	07-01-2026	Part of : SRI HANS NAGAR	510	Other Outage	Planned Outage	07-01-2026	15:47	07-01-2026	16:42	0:55	0.000764	REPLACEMENT OF HT BUSHING ROD
1021	07-01-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	260	Other Outage	Planned Outage	07-01-2026	14:12	07-01-2026	16:42	2:30	0.002083	REPLACEMENT OF HT BUSHING ROD
1022	07-01-2026	Part of : MANDHELA KHURD VILLAGE	3	Other Outage	Planned Outage	07-01-2026	11:58	07-01-2026	14:16	2:18	0.000383	REPLACEMENT OF HT BUSHING ROD
1023	07-01-2026	Part of : JAFARPUR KALAN VILLAGE	1	Other Outage	Planned Outage	07-01-2026	11:15	07-01-2026	13:52	2:37	0.000436	REPLACEMENT OF HT BUSHING ROD
1024	08-01-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	1183	Other Outage	Planned Outage	08-01-2026	15:27	08-01-2026	16:45	1:18	0.000217	REPLACEMENT OF LT BUSHING ROD
1025	08-01-2026	Part of : MANDHELA KHURD VILLAGE	30	Other Outage	Planned Outage	08-01-2026	13:15	08-01-2026	15:09	1:54	0.000317	REPLACEMET OF HT BUSHING ROD
1026	08-01-2026	Part of : SAMAZPUR KHALSA	190	Other Outage	Planned Outage	08-01-2026	14:26	08-01-2026	16:46	2:20	0.000389	REPLACEMET OF HT BUSHING ROD
1027	08-01-2026	Part of : GOPAL EXTENSION II,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	5	Other Outage	Planned Outage	08-01-2026	14:37	08-01-2026	16:45	2:08	0.001778	REPLACEMENT OF LT BUSHING ROD
1028	08-01-2026	Part of : DHANSA VILLAGE	355	Other Outage	Planned Outage	08-01-2026	11:06	08-01-2026	13:57	2:51	0.000475	REPLACEMENT OF LT BUSHING ROD
1029	08-01-2026	Part of : MITRAON VILLAGE NAJAFGARH,KAIR VILLAGE,SUREHRA VILLAGE	1530	Other Outage	Planned Outage	08-01-2026	11:01	08-01-2026	13:56	2:55	0.002431	GUARD WIRES SAGGING PER SPAN
1030	09-01-2026	Part of : MANDHELA KALAN VILLAGE,	12	Other Outage	Planned Outage	09-01-2026	12:35	09-01-2026	14:33	1:58	0.000328	MAINTENANCE OF TRANSFORMER
1031	09-01-2026	Part of : BADHOSRA,	455	Other Outage	Planned Outage	09-01-2026	11:36	09-01-2026	13:32	1:56	0.000322	MAINTENANCE OF TRANSFORMER
1032	09-01-2026	Part of : SHYAM ENCAVE NAJAFGARH,	478	Other Outage	Planned Outage	09-01-2026	12:40	09-01-2026	14:50	2:10	0.000361	MAINTENANCE OF TRANSFORMER
1033	09-01-2026	Part of : RAWTA VILLAGE,	21	Other Outage	Planned Outage	09-01-2026	12:12	09-01-2026	14:51	2:39	0.000442	MAINTENANCE OF TRANSFORMER
1034	09-01-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE,	997	Other Outage	Planned Outage	09-01-2026	11:23	09-01-2026	13:57	2:34	0.000428	MAINTENANCE OF TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1035	10-01-2026	PART OF : KHERA DABAS VILLAGE	136	Other Outage	Planned Outage	10-01-2026	14:06	10-01-2026	15:46	1:40	0.000278	REPLACEMENT OF HT BUSHING ROD
1036	10-01-2026	PART OF : MANDHELA KALAN VILLAGE	481	Other Outage	Planned Outage	10-01-2026	13:16	10-01-2026	14:32	1:16	0.001056	REPLACEMENT OF HT BUSHING ROD
1037	10-01-2026	PART OF : KRISHAN VIHAR NAJAFGARH	11	Other Outage	Planned Outage	10-01-2026	13:59	10-01-2026	16:16	2:17	0.001903	REPLACEMENT OF HT BUSHING ROD
1038	10-01-2026	PART OF : SUREHRA VILLAGE	213	Other Outage	Planned Outage	10-01-2026	13:56	10-01-2026	16:16	2:20	0.001944	REPLACEMENT OF HT BUSHING ROD
1039	10-01-2026	PART OF : MITRAON VILLAGE NAJAFGARH	377	Other Outage	Planned Outage	10-01-2026	12:53	10-01-2026	14:56	2:03	0.001708	REPLACEMENT OF HT BUSHING ROD
1040	12-01-2026	Part of : SRI HANS NAGAR, VILLAGE MITRAON, VILLAGE SURAKHPUR	8	Other Outage	Unplanned Outage	12-01-2026	04:52	12-01-2026	05:06	0:14	0.000000	TREE TOUCHING
1041	12-01-2026	Part of : KHARKHARI ROND VILLAGE,KHERA DABAS VILLAGE	2718	Other Outage	Planned Outage	12-01-2026	15:27	12-01-2026	16:41	1:14	0.001028	REPLACEMET OF HT BUSHING ROD
1042	12-01-2026	Part of : MANDHELA KHURD VILLAGE	3	Other Outage	Planned Outage	12-01-2026	13:59	12-01-2026	16:06	2:07	0.001764	REPLACEMENT OF LT BUSHING ROD
1043	12-01-2026	Part of : SARSWATI ENCLAVE GOPAL NAGAR NAJAFGARH	2	Other Outage	Planned Outage	12-01-2026	12:53	12-01-2026	15:52	2:59	0.000497	REPLACEMET OF HT BUSHING ROD
1044	12-01-2026	Part of : GHALLBPUR VILLAGE	1	Other Outage	Planned Outage	12-01-2026	11:23	12-01-2026	13:57	2:34	0.000428	REPLACEMET OF HT BUSHING ROD
1045	13-01-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	717	Other Outage	Planned Outage	13-01-2026	16:02	13-01-2026	16:51	0:49	0.000136	REPLACEMENT OF HT BUSHING ROD
1046	13-01-2026	Part of : MANDHELA KHURD VILLAGE	161	Other Outage	Planned Outage	13-01-2026	15:14	13-01-2026	16:19	1:05	0.000181	REPLACEMENT OF HT BUSHING ROD
1047	13-01-2026	Part of : MITRAON VILLAGE NAJAFGARH,KAIR VILLAGE,SUREHRA VILLAGE	1530	Other Outage	Planned Outage	13-01-2026	14:52	13-01-2026	16:52	2:00	0.001667	GUARD WIRES SAGGING PER SPAN
1048	13-01-2026	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	691	Other Outage	Planned Outage	13-01-2026	13:23	13-01-2026	16:04	2:41	0.002236	REPLACEMENT OF LT BUSHING ROD
1049	14-01-2026	Part of : DARYAPUR KHURD VILLAGE	1	Other Outage	Planned Outage	14-01-2026	12:06	14-01-2026	14:31	2:25	0.000403	REPLACEMENT OF LT BUSHING ROD
1050	15-01-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	14	Other Outage	Planned Outage	15-01-2026	14:42	15-01-2026	16:36	1:54	0.001583	REPLACEMET OF HT BUSHING ROD
1051	15-01-2026	Part of : SAMAZPUR KHALSA	358	Other Outage	Planned Outage	15-01-2026	14:16	15-01-2026	16:37	2:21	0.000392	REPLACEMET OF HT BUSHING ROD
1052	15-01-2026	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	691	Other Outage	Planned Outage	15-01-2026	12:32	15-01-2026	15:25	2:53	0.002403	REPLACEMET OF HT BUSHING ROD
1053	15-01-2026	Part of : KAIR VILLAGE	27	Other Outage	Planned Outage	15-01-2026	12:19	15-01-2026	14:23	2:04	0.000344	REPLACEMET OF HT BUSHING ROD
1054	15-01-2026	Part of : MITRAON VILLAGE,KAIR VILLAGE,SUREHRA VILLAGE	1530	Other Outage	Planned Outage	15-01-2026	11:02	15-01-2026	13:52	2:50	0.002361	GUARD WIRES SAGGING
1055	16-01-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	1053	Other Outage	Planned Outage	16-01-2026	15:27	16-01-2026	16:32	1:05	0.000903	REPLACEMENT OF LT BUSHING ROD
1056	16-01-2026	Part of : JHULJHULI VILLAGE	24	Other Outage	Planned Outage	16-01-2026	13:03	16-01-2026	15:29	2:26	0.000406	REPLACEMENT OF LT BUSHING ROD
1057	16-01-2026	Part of : MANDHELA KHURD VILLAGE	30	Other Outage	Planned Outage	16-01-2026	12:24	16-01-2026	14:59	2:35	0.000431	REPLACEMET OF HT BUSHING ROD
1058	16-01-2026	Part of : POCKET 8 SECTOR C VASANT KUNJ	384	Other Outage	Planned Outage	16-01-2026	11:05	16-01-2026	14:01	2:56	0.000489	REPLACEMENT OF HT BUSHING ROD
1059	16-01-2026	Part of : BLOCK E VASANT VIHAR	190	Other Outage	Planned Outage	16-01-2026	10:59	16-01-2026	14:00	3:01	0.000503	REPLACEMET OF HT BUSHING ROD
1060	17-01-2026	Part of : MITRAON VILLAGE NAJAFGARH,KAIR VILLAGE,SUREHRA VILLAGE	1530	Other Outage	Planned Outage	17-01-2026	17:25	17-01-2026	17:46	0:21	0.000292	MAINTENANCE OF HT O/H CIRCUIT
1061	17-01-2026	Part of : HAIBUTPUR	3	Other Outage	Planned Outage	17-01-2026	16:25	17-01-2026	17:24	0:59	0.000819	MAINTENANCE OF TRANSFORMER
1062	17-01-2026	Part of : MANDHELA KALAN VILLAGE	8	Other Outage	Planned Outage	17-01-2026	11:28	17-01-2026	13:34	2:06	0.001750	MAINTENANCE OF TRANSFORMER
1063	19-01-2026	Part of : GOPAL EXTENSION-2,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	5	Other Outage	Planned Outage	19-01-2026	15:30	19-01-2026	16:53	1:23	0.001153	REPLACEMET OF HT BUSHING ROD
1064	19-01-2026	Part of : GHUMANHERA	7	Other Outage	Planned Outage	19-01-2026	15:09	19-01-2026	16:50	1:41	0.000281	REPLACEMET OF HT BUSHING ROD
1065	19-01-2026	Part of : KRISHAN VIHAR NAJAFGARH	10	Other Outage	Planned Outage	19-01-2026	15:31	19-01-2026	16:52	1:21	0.001125	REPLACEMET OF HT BUSHING ROD
1066	19-01-2026	Part of : DHANSA VILLAGE	384	Other Outage	Planned Outage	19-01-2026	11:04	19-01-2026	13:49	2:45	0.002292	REPLACEMET OF HT BUSHING ROD
1067	20-01-2026	Part of : UJWA VILLAGE	529	Other Outage	Planned Outage	20-01-2026	15:15	20-01-2026	16:11	0:56	0.000622	REPLACEMET OF HT BUSHING ROD
1068	20-01-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1406	Other Outage	Planned Outage	20-01-2026	15:16	20-01-2026	16:47	1:31	0.000506	REPLACEMET OF HT BUSHING ROD
1069	20-01-2026	Part of : NANU RAM PARK NAJAFGARH	29	Other Outage	Planned Outage	20-01-2026	15:15	20-01-2026	16:48	1:33	0.001033	REPLACEMET OF HT BUSHING ROD
1070	20-01-2026	Part of : SARANGPUR VILLAGE	367	Other Outage	Planned Outage	20-01-2026	12:22	20-01-2026	14:57	2:35	0.002153	REPLACEMET OF HT BUSHING ROD
1071	20-01-2026	Part of : DHANSA VILLAGE	27	Other Outage	Planned Outage	20-01-2026	11:03	20-01-2026	13:31	2:28	0.000411	REPLACEMET OF HT BUSHING ROD
1072	21-01-2026	Part of : HAIBUTPURA EXTENSION HAIBUTPUR,	437	Other Outage	Planned Outage	21-01-2026	16:18	21-01-2026	16:55	0:37	0.000514	TRANSFORMER MAINTENANCE
1073	21-01-2026	Part of : MITRAON VILLAGE NAJAFGARH,	592	Other Outage	Planned Outage	21-01-2026	16:22	21-01-2026	16:57	0:35	0.000486	TRANSFORMER MAINTENANCE
1074	21-01-2026	Part of : MALIKPUR ZER VILLAGE,	277	Other Outage	Planned Outage	21-01-2026	15:58	21-01-2026	16:56	0:58	0.000644	TRANSFORMER MAINTENANCE
1075	21-01-2026	Part of : MANDHELA KALAN VILLAGE,	4	Other Outage	Planned Outage	21-01-2026	13:27	21-01-2026	15:06	1:39	0.000275	TRANSFORMER MAINTENANCE
1076	21-01-2026	Part of : QAZIPUR VILLAGE,	273	Other Outage	Planned Outage	21-01-2026	11:15	21-01-2026	13:39	2:24	0.000400	TRANSFORMER MAINTENANCE
1077	22-01-2026	Part of : MANDHELA KHURD VILLAGE,MANDHELA KALAN VILLAGE,KAIR VILLAGE,MITRAON VILLAGE NAJAFGARH,RAWTA JAFARPUR KALAN VILLAGE	930	Other Outage	Unplanned Outage	22-01-2026	13:49	22-01-2026	14:15	0:26	0.000092	CABLE FAULT
1078	22-01-2026	Part of : BASCO COLONY ARYA NAGAR NAJAFGARH	3	Other Outage	Planned Outage	22-01-2026	15:51	22-01-2026	16:39	0:48	0.000667	REPLACEMENT OF HT BUSHING ROD
1079	22-01-2026	Part of : MANDHELA KALAN VILLAGE	8	Other Outage	Planned Outage	22-01-2026	15:41	22-01-2026	16:38	0:57	0.000158	REPLACEMENT OF HT BUSHING ROD
1080	22-01-2026	Part of : SUREHRA VILLAGE	466	Other Outage	Planned Outage	22-01-2026	13:55	22-01-2026	16:37	2:42	0.002250	REPLACEMENT OF HT BUSHING ROD
1081	22-01-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	731	Other Outage	Planned Outage	22-01-2026	12:35	22-01-2026	14:55	2:20	0.001556	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1082	23-01-2026	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE	1899	Other Outage	Unplanned Outage	23-01-2026	07:42	23-01-2026	08:07	0:25	0.000000	CABLE FAULT
1083	24-01-2026	Part of : MANDHELA KALAN VILLAGE, KAIR VILLAGE	1899	Other Outage	Unplanned Outage	24-01-2026	10:16	24-01-2026	10:19	0:03	0.000039	HT SYSTEM FAULT
1084	24-01-2026	Part of : BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	547	Other Outage	Planned Outage	24-01-2026	12:20	24-01-2026	14:17	1:57	0.001625	REPLACEMET OF HT BUSHING ROD
1085	24-01-2026	Part of : GHALLBPUR VILLAGE,SARANGPUR VILLAGE	2091	Other Outage	Planned Outage	24-01-2026	14:46	24-01-2026	17:20	2:34	0.002139	GUARD WIRES SAGGING PER SPAN
1086	24-01-2026	Part of : HAIBUTPURA EXTENSION HAIBUTPUR	437	Other Outage	Planned Outage	24-01-2026	11:47	24-01-2026	14:18	2:31	0.002097	REPLACEMENT OF HT BUSHING ROD
1087	27-01-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	399	Other Outage	Planned Outage	27-01-2026	15:02	27-01-2026	16:38	1:36	0.000267	REPLACEMENT OF HT BUSHING ROD
1088	27-01-2026	Part of : ISSAPUR VILLAGE	315	Other Outage	Planned Outage	27-01-2026	12:28	27-01-2026	14:07	1:39	0.000275	REPLACEMENT OF HT BUSHING ROD
1089	27-01-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	1003	Other Outage	Planned Outage	27-01-2026	14:22	27-01-2026	16:28	2:06	0.001750	REPLACEMENT OF HT BUSHING ROD
1090	27-01-2026	Part of : BABA HARI DAS ENCLAVE JHARODA KALAN	1	Other Outage	Planned Outage	27-01-2026	12:12	27-01-2026	14:57	2:45	0.002292	REPLACEMENT OF HT BUSHING ROD
1091	28-01-2026	Part of : UJWA VILLAGE	468	Other Outage	Planned Outage	28-01-2026	15:21	28-01-2026	16:46	1:25	0.001181	REPLACEMENT OF HT BUSHING ROD
1092	28-01-2026	Part of : GOPAL NAGAR NAJAFGARH,SARSWATI ENCLAVE GOPAL NAGAR NAJAFGARH	2408	Other Outage	Planned Outage	28-01-2026	15:27	28-01-2026	16:47	1:20	0.000444	REPLACEMENT OF HT BUSHING ROD
1093	28-01-2026	Part of : MANDHELA KALAN VILLAGE	5	Other Outage	Planned Outage	28-01-2026	12:28	28-01-2026	14:24	1:56	0.000322	REPLACEMENT OF HT BUSHING ROD
1094	28-01-2026	Part of : JHULJHULI VILLAGE	7	Other Outage	Planned Outage	28-01-2026	14:12	28-01-2026	16:47	2:35	0.000431	REPLACEMENT OF HT BUSHING ROD
1095	28-01-2026	Part of : BADHOSRA	840	Other Outage	Planned Outage	28-01-2026	11:52	28-01-2026	13:52	2:00	0.000333	REPLACEMENT OF HT BUSHING ROD
1096	29-01-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,	1053	Other Outage	Planned Outage	29-01-2026	15:08	29-01-2026	16:49	1:41	0.001403	REPLACEMENT OF LT BUSHING ROD
1097	29-01-2026	Part of : KHERA DABAS VILLAGE,	160	Other Outage	Planned Outage	29-01-2026	15:06	29-01-2026	16:48	1:42	0.001417	REPLACEMENT OF HT BUSHING ROD
1098	29-01-2026	Part of : PREM NAGAR GOPAL NAGAR NAJAFGARH,SHIV VIHAR COLONY GOPAL NAGAR NAJAFGARH,NAJAFGARH VILLAGE NAJAFGARH,	446	Other Outage	Planned Outage	29-01-2026	12:02	29-01-2026	14:54	2:52	0.002389	REPLACEMENT OF LT BUSHING ROD
1099	29-01-2026	Part of : DHANSA VILLAGE,	146	Other Outage	Planned Outage	29-01-2026	12:53	29-01-2026	14:55	2:02	0.000339	REPLACEMENT OF HT BUSHING ROD
1100	29-01-2026	Part of : METRO TRANSIT PVT LTD, KAIR BUS DEPOT	1	Other Outage	Planned Outage	29-01-2026	11:32	29-01-2026	14:53	3:21	0.000558	REPLACEMENT OF LT BUSHING ROD
1101	30-01-2026	Part of : SHYAM ENCAVE NAJAFGARH,BASCO COLONY ARYA NAGAR NAJAFGARH	495	Other Outage	Planned Outage	30-01-2026	16:15	30-01-2026	16:47	0:32	0.000444	REPLACEMENT OF LT BUSHING ROD
1102	30-01-2026	Part of : KHERA DABAS VILLAGE	691	Other Outage	Planned Outage	30-01-2026	16:14	30-01-2026	16:48	0:34	0.000472	REPLACEMENT OF LT BUSHING ROD
1103	30-01-2026	Part of : MALIKPUR ZER VILLAGE	401	Other Outage	Planned Outage	30-01-2026	15:00	30-01-2026	16:45	1:45	0.001458	REPLACEMENT OF HT BUSHING ROD
1104	30-01-2026	Part of : MANDHELA KHURD VILLAGE	2	Other Outage	Planned Outage	30-01-2026	11:14	30-01-2026	13:30	2:16	0.000378	REPLACEMENT OF HT BUSHING ROD
1105	30-01-2026	Part of : ISSAPUR VILLAGE	247	Other Outage	Planned Outage	30-01-2026	11:27	30-01-2026	13:49	2:22	0.000394	REPLACEMENT OF HT BUSHING ROD
1106	30-01-2026	Part of : DARYAPUR KHURD VILLAGE	2	Other Outage	Planned Outage	30-01-2026	11:02	30-01-2026	13:48	2:46	0.000461	REPLACEMENT OF HT BUSHING ROD
1107	31-01-2026	Part of : MITRAON VILLAGE NAJAFGARH	307	Other Outage	Planned Outage	31-01-2026	13:51	31-01-2026	15:04	1:13	0.001014	REPLACEMENT OF HT BUSHING ROD
1108	31-01-2026	Part of : MANDHELA KALAN VILLAGE	13	Other Outage	Planned Outage	31-01-2026	13:50	31-01-2026	15:52	2:02	0.001694	REPLACEMENT OF HT BUSHING ROD
1109	31-01-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	732	Other Outage	Planned Outage	31-01-2026	11:02	31-01-2026	13:54	2:52	0.002389	REPLACEMENT OF HT BUSHING ROD
1110	01-01-2026	Part of : BLOCK B PRESS COLONY MAYAPURI,	645	Other Outage	Planned Outage	01-01-2026	11:41	01-01-2026	13:24	1:43	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1111	01-01-2026	Part of : BLOCK WZ NANGAL RAYA JANAK PURI,	987	Other Outage	Planned Outage	01-01-2026	12:08	01-01-2026	14:07	1:59	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1112	01-01-2026	Part of : MEENAKSHI GARDEN ASHOK NAGAR,	485	Other Outage	Planned Outage	01-01-2026	11:21	01-01-2026	14:15	2:54	0.000967	REPLACEMENT OF GAS KIT AND OIL SEAL
1113	01-01-2026	Part of : BLOCK 6 SUBHASH NAGAR,	412	Other Outage	Planned Outage	01-01-2026	11:11	01-01-2026	13:40	2:29	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1114	01-01-2026	Part of : BLOCK B3 JANAK PURI,	388	Other Outage	Planned Outage	01-01-2026	11:25	01-01-2026	13:39	2:14	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1115	02-01-2026	Part of : TIHAR CENTRAL JAIL JANAK PURI,POCKET D 1 JANAK PURI	1144	Other Outage	Unplanned Outage	02-01-2026	20:55	02-01-2026	22:12	1:17	0.000984	CABLE FAULT
1116	02-01-2026	Part of : BLOCK 3 ASHOK NAGAR	331	Other Outage	Planned Outage	02-01-2026	11:16	02-01-2026	16:07	4:51	0.002425	DT REPLACEMENT
1117	02-01-2026	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI,BLOCK C 5B JANAK PURI,BLOCK C4H JANAK PURI	2953	Other Outage	Planned Outage	02-01-2026	11:37	02-01-2026	14:21	2:44	0.000911	BIRD SPIKES INSTALLATION PER POLE,GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1118	02-01-2026	Part of : MULTILEVEL PARKING, JANAKPURI (HTC)	1	Other Outage	Planned Outage	02-01-2026	08:17	02-01-2026	11:20	3:03	0.004067	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,REPLACEMENT OF FAULTY END BOX

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1119	02-01-2026	Part of : DELHI MILK SSCHEME COLONY HARI NAGAR	28	Other Outage	Planned Outage	02-01-2026	11:29	02-01-2026	14:23	2:54	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1120	02-01-2026	Part of : BLOCK B 3A JANAK PURI	408	Other Outage	Planned Outage	02-01-2026	11:30	02-01-2026	14:23	2:53	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
1121	02-01-2026	Part of : BLOCK 58 ASHOK NAGAR	490	Other Outage	Planned Outage	02-01-2026	11:19	02-01-2026	15:24	4:05	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1122	02-01-2026	Part of : BLOCK B PATEL BLOCK RAGHU NAGAR DABRI	958	Other Outage	Planned Outage	02-01-2026	11:34	02-01-2026	14:25	2:51	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1123	03-01-2026	Part of : B-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-1	399	Other Outage	Unplanned Outage	03-01-2026	13:40	03-01-2026	14:38	0:58	0.000016	CABLE FAULT
1124	03-01-2026	Part of : BLOCK 40 ASHOK NAGAR	403	Other Outage	Planned Outage	03-01-2026	11:43	03-01-2026	13:30	1:47	0.000000	LT CIRCUIT MAINTENANCE
1125	03-01-2026	Part of : BLOCK A 3 ALSALATPUR VILLAGE JANAK PURI	160	Other Outage	Planned Outage	03-01-2026	11:04	03-01-2026	14:59	3:55	0.001958	DT REPLACEMENT
1126	03-01-2026	Part of : POCKET D2A NANGAL RAYA JANAK PURI	450	Other Outage	Planned Outage	03-01-2026	11:28	03-01-2026	13:34	2:06	0.000000	LT CIRCUIT MAINTENANCE
1127	03-01-2026	Part of : BLOCK A&I MAYAPURI INDUSTRIAL	121	Other Outage	Planned Outage	03-01-2026	11:28	03-01-2026	14:26	2:58	0.000000	LT CIRCUIT MAINTENANCE
1128	03-01-2026	Part of : BLOCK C 6A JANAK PURI	88	Other Outage	Planned Outage	03-01-2026	12:20	03-01-2026	14:38	2:18	0.000000	LT CIRCUIT MAINTENANCE
1129	03-01-2026	Part of : BLOCK B 3A JANAK PURI	419	Other Outage	Planned Outage	03-01-2026	11:06	03-01-2026	14:02	2:56	0.000000	LT CIRCUIT MAINTENANCE
1130	03-01-2026	Part of : BLOCK J 5 RAJOURI GARDEN EXTENSION	441	Other Outage	Planned Outage	03-01-2026	10:49	03-01-2026	13:51	3:02	0.000000	LT CIRCUIT MAINTENANCE
1131	05-01-2026	Part of : POSSANGIPUR VILLAGE JANAK PURI,	409	Other Outage	Planned Outage	05-01-2026	12:17	05-01-2026	14:49	2:32	0.000844	MAINTENANCE OF LT CIRCUIT
1132	05-01-2026	Part of : BLOCK B FATEH NAGAR JANAK PURI,	247	Other Outage	Planned Outage	05-01-2026	12:27	05-01-2026	15:35	3:08	0.001044	MAINTENANCE OF LT TRANSFORMER
1133	05-01-2026	Part of : SHIV NAGAR EXTENSION JANAK PURI,	541	Other Outage	Planned Outage	05-01-2026	11:50	05-01-2026	15:34	3:44	0.001867	MAINTENANCE OF TRANSFORMER
1134	05-01-2026	Part of : BLOCK WZ PADAM BASTI NANGAL RAYA JANAK PURI,	508	Other Outage	Planned Outage	05-01-2026	11:23	05-01-2026	13:45	2:22	0.000789	MAINTENANCE OF LT CIRCUIT
1135	05-01-2026	Part of : BLOCK 1 ASHOK NAGAR,	515	Other Outage	Planned Outage	05-01-2026	11:09	05-01-2026	13:42	2:33	0.000850	MAINTENANCE OF LT TRANSFORMER
1136	05-01-2026	Part of : RWA COLONY JANAK PURI,	120	Other Outage	Planned Outage	05-01-2026	11:57	05-01-2026	14:02	2:05	0.000694	MAINTENANCE OF LT TRANSFORMER
1137	05-01-2026	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI,	30	Other Outage	Planned Outage	05-01-2026	11:11	05-01-2026	13:43	2:32	0.000844	MAINTENANCE OF LT TRANSFORMER
1138	06-01-2026	Part of : SHOPPING CENTER MAYAPURI	0	Other Outage	Unplanned Outage	06-01-2026	16:25	06-01-2026	17:40	1:15	0.003146	CABLE FAULT
1139	06-01-2026	Part of : BLOCK A 3 ALSALATPUR VILLAGE JANAK PURI	160	Other Outage	Planned Outage	06-01-2026	12:24	06-01-2026	16:10	3:46	0.001883	DT REPLACEMENT
1140	06-01-2026	Part of : MEENAKSHI GARDEN ASHOK NAGAR	485	Other Outage	Planned Outage	06-01-2026	11:37	06-01-2026	15:27	3:50	0.001917	DT REPLACEMENT
1141	06-01-2026	Part of : POCKET B 1 B 1 MARKET SUPER BAZAR JANAK PURI	105	Other Outage	Planned Outage	06-01-2026	11:16	06-01-2026	13:44	2:28	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1142	06-01-2026	Part of : BLOCK C 6A JANAK PURI	39	Other Outage	Planned Outage	06-01-2026	11:36	06-01-2026	14:33	2:57	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1143	06-01-2026	Part of : BOLOCK C KHAJAN BASTI MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	107	Other Outage	Planned Outage	06-01-2026	11:19	06-01-2026	15:28	4:09	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1144	06-01-2026	Part of : MCD MARKET ASHOK NAGAR	698	Other Outage	Planned Outage	06-01-2026	11:17	06-01-2026	15:30	4:13	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1145	06-01-2026	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN SAGARPUR	1064	Other Outage	Planned Outage	06-01-2026	11:42	06-01-2026	14:59	3:17	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1146	07-01-2026	Part of : RWA COLONY JANAK PURI	135	Other Outage	Planned Outage	07-01-2026	12:39	07-01-2026	13:48	1:09	0.000383	LT CIRCUIT MAINTENANCE
1147	07-01-2026	Part of : BLOCK RZ VASHISHT PARK SAGARPUR	857	Other Outage	Planned Outage	07-01-2026	12:41	07-01-2026	15:15	2:34	0.000856	LT CIRCUIT MAINTENANCE
1148	07-01-2026	Part of : BLOCK 4 ASHOK NAGAR	566	Other Outage	Planned Outage	07-01-2026	11:17	07-01-2026	13:46	2:29	0.000828	LT CIRCUIT MAINTENANCE
1149	07-01-2026	Part of : BLOCK B2 SHIV NAGAR JANAK PURI	272	Other Outage	Planned Outage	07-01-2026	11:15	07-01-2026	13:44	2:29	0.000828	LT CIRCUIT MAINTENANCE
1150	07-01-2026	Part of : BLOCK CA HARI NAGAR	302	Other Outage	Planned Outage	07-01-2026	11:57	07-01-2026	14:12	2:15	0.000750	LT CIRCUIT MAINTENANCE
1151	08-01-2026	Part of : SHIV NAGAR EXTENSION JANAK PURI	541	Other Outage	Planned Outage	08-01-2026	13:52	08-01-2026	15:44	1:52	0.000933	DT REPLACEMENT
1152	08-01-2026	Part of : BLOCK J RAJOURI GARDEN EXTENSION	410	Other Outage	Planned Outage	08-01-2026	12:03	08-01-2026	17:10	5:07	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1153	08-01-2026	Part of : NANGAL VILLAGE DELHI CANTONMENT	630	Other Outage	Planned Outage	08-01-2026	12:44	08-01-2026	15:25	2:41	0.000000	3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1154	08-01-2026	Part of : BLOCK C 2A JANAK PURI	474	Other Outage	Planned Outage	08-01-2026	12:24	08-01-2026	15:23	2:59	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER,REPLACEMENT OF GAS KIT AND OIL SEAL
1155	08-01-2026	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE I	57	Other Outage	Planned Outage	08-01-2026	11:02	08-01-2026	13:58	2:56	0.000000	MEASUREMET OF INSULATION RESISTANCE,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1156	08-01-2026	Part of : BLOCK B 2B JANAK PURI	164	Other Outage	Planned Outage	08-01-2026	11:20	08-01-2026	14:10	2:50	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1157	08-01-2026	Part of : BLOCK J BERI WALA BAGH HARI NAGAR	564	Other Outage	Planned Outage	08-01-2026	11:04	08-01-2026	13:56	2:52	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD
1158	09-01-2026	Part of : POCKET G HARI NAGAR JANAK PURI	2697	Other Outage	Unplanned Outage	09-01-2026	13:34	09-01-2026	14:32	0:58	0.001643	CABLE FAULT
1159	09-01-2026	Part of : BLOCK 6 SUBHASH NAGAR,	784	Other Outage	Planned Outage	09-01-2026	13:32	09-01-2026	14:37	1:05	0.000000	MAINTENANCE OF LT TRANSFORMER
1160	09-01-2026	Part of : BLOCK 3 ASHOK NAGAR,	1266	Other Outage	Planned Outage	09-01-2026	12:07	09-01-2026	16:00	3:53	0.001942	MAINTENANCE OF TRANSFORMER
1161	09-01-2026	Part of : BLOCK BD GURUNANAK PURA JANAK PURI,	348	Other Outage	Planned Outage	09-01-2026	11:28	09-01-2026	14:46	3:18	0.000000	MAINTENANCE OF LT TRANSFORMER
1162	09-01-2026	Part of : BLOCK RZ SAGARPUR,	261	Other Outage	Planned Outage	09-01-2026	11:28	09-01-2026	14:45	3:17	0.000000	MAINTENANCE OF LT CIRCUIT
1163	09-01-2026	Part of : BLOCK C 2C JANAK PURI,	362	Other Outage	Planned Outage	09-01-2026	12:05	09-01-2026	14:30	2:25	0.000000	MAINTENANCE OF LT TRANSFORMER
1164	09-01-2026	Part of : BLOCK J RAJOURI GARDEN,	269	Other Outage	Planned Outage	09-01-2026	11:27	09-01-2026	14:29	3:02	0.000000	MAINTENANCE OF LT TRANSFORMER
1165	09-01-2026	Part of : BLOCK V RAJOURI GARDEN,	239	Other Outage	Planned Outage	09-01-2026	11:27	09-01-2026	14:29	3:02	0.000000	MAINTENANCE OF LT CIRCUIT
1166	10-01-2026	Part of : BLOCK 2 SUBHASH NAGAR	1683	Other Outage	Unplanned Outage	10-01-2026	11:07	10-01-2026	11:58	0:51	0.001119	CABLE FAULT
1167	10-01-2026	Part of : HARI ENCLAVE HARI NAGAR,BLOCK J BERI WALA BAGH HARI NAGAR	787	Other Outage	Unplanned Outage	10-01-2026	05:40	10-01-2026	06:56	1:16	0.000211	FAULT IN HT CONSUMER PANEL (GURU TEG BAHADUR ENGG.COLLEGE)
1168	10-01-2026	PART OF : BLOCK 40 ASHOK NAGAR	1136	Other Outage	Planned Outage	10-01-2026	13:20	10-01-2026	17:10	3:50	0.001917	DT REPLACEMENT
1169	10-01-2026	PART OF : BLOCK BB JANAK PURI	474	Other Outage	Planned Outage	10-01-2026	11:19	10-01-2026	14:56	3:37	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1170	10-01-2026	PART OF : BLOCK E RAGHU NAGAR DABRI	673	Other Outage	Planned Outage	10-01-2026	11:23	10-01-2026	15:32	4:09	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1171	10-01-2026	PART OF : POCKET UB ASHA PARK FATEH NAGAR	572	Other Outage	Planned Outage	10-01-2026	11:20	10-01-2026	14:54	3:34	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1172	10-01-2026	PART OF : BLOCK 4 SUBHASH NAGAR	355	Other Outage	Planned Outage	10-01-2026	11:05	10-01-2026	14:47	3:42	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1173	12-01-2026	Part of : POCKET G HARI NAGAR JANAK PURI	2697	Other Outage	Planned Outage	12-01-2026	14:20	12-01-2026	15:19	0:59	0.000000	3PH DB REPLACEMENT
1174	12-01-2026	Part of : BHARTI COLLEGE JANAKPURI	1	Other Outage	Planned Outage	12-01-2026	14:06	12-01-2026	15:17	1:11	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
1175	12-01-2026	Part of : NANGAL VILLAGE DELHI CANTONMENT	638	Other Outage	Planned Outage	12-01-2026	13:27	12-01-2026	17:07	3:40	0.001833	DT REPLACEMENT
1176	12-01-2026	Part of : POSSANGIPUR VILLAGE JANAK PURI	409	Other Outage	Planned Outage	12-01-2026	13:25	12-01-2026	17:03	3:38	0.001817	DT REPLACEMENT
1177	12-01-2026	Part of : SHIV NAGAR EXTENSION JANAK PURI	541	Other Outage	Planned Outage	12-01-2026	13:22	12-01-2026	17:22	4:00	0.002000	DT REPLACEMENT
1178	12-01-2026	Part of : BLOCK V RAJOURI GARDEN	241	Other Outage	Planned Outage	12-01-2026	10:51	12-01-2026	14:50	3:59	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1179	12-01-2026	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST	449	Other Outage	Planned Outage	12-01-2026	11:42	12-01-2026	15:21	3:39	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1180	12-01-2026	Part of : BLOCK WH MAYAPURI INDUSTRIAL AREA PHASE I	52	Other Outage	Planned Outage	12-01-2026	11:16	12-01-2026	14:12	2:56	0.000000	OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1181	12-01-2026	Part of : BLOCK BA GURUNANAK PURA JANAK PURI	339	Other Outage	Planned Outage	12-01-2026	11:03	12-01-2026	13:54	2:51	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
1182	13-01-2026	Part of : A1, JANAK PURI	0	Other Outage	Unplanned Outage	13-01-2026	11:41	13-01-2026	12:13	0:32	0.000249	TRANSIENT FAULT
1183	13-01-2026	Part of : BLOCK A KARAN MARKET NANGAL RAYA JANAK PURI	205	Other Outage	Planned Outage	13-01-2026	11:55	13-01-2026	13:30	1:35	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
1184	13-01-2026	Part of : BLOCK A 3 ASALATPUR VILLAGE JANAK PURI	229	Other Outage	Planned Outage	13-01-2026	11:24	13-01-2026	14:24	3:00	0.001500	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1185	13-01-2026	Part of : BLOCK MS NANAK PURA HARI NAGAR	371	Other Outage	Planned Outage	13-01-2026	11:21	13-01-2026	13:47	2:26	0.000406	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1186	13-01-2026	Part of : BLOCK BE SHIV NAGAR JANAK PURI	269	Other Outage	Planned Outage	13-01-2026	11:55	13-01-2026	14:26	2:31	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1187	13-01-2026	Part of : BLOCK 1 SUBHASH NAGAR	156	Other Outage	Planned Outage	13-01-2026	11:11	13-01-2026	14:03	2:52	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1188	14-01-2026	Part of : CHHOTI SUBJI MANDI JANAK PURI,PREM NAGAR JANAK PURI	1897	Other Outage	Unplanned Outage	14-01-2026	06:58	14-01-2026	07:54	0:56	0.000914	CABLE FAULT
1189	14-01-2026	Part of : POCKET DL HARI NAGAR	261	Other Outage	Unplanned Outage	14-01-2026	12:50	14-01-2026	16:14	3:24	0.000567	MOBILE TRANSFORMER REPLACEMENT
1190	14-01-2026	Part of : BLOCK J RAJOURI GARDEN EXTENSION RAJOURI GARDEN	244	Other Outage	Planned Outage	14-01-2026	13:53	14-01-2026	15:29	1:36	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1191	14-01-2026	Part of : PRESS COLONY MAYAPURI	306	Other Outage	Planned Outage	14-01-2026	12:09	14-01-2026	13:56	1:47	0.000000	REPLACEMENT OF HT/LT CLEATS & OIL TOP UP IN TRANSFORMER
1192	14-01-2026	Part of : BLOCK 3 ASHOK NAGAR	402	Other Outage	Planned Outage	14-01-2026	12:53	14-01-2026	17:42	4:49	0.002408	DT REPLACEMENT
1193	14-01-2026	Part of : BLOCK BF JANAK PURI	379	Other Outage	Planned Outage	14-01-2026	12:09	14-01-2026	15:32	3:23	0.000000	REPLACEMENT OF HT/LT CLEATS & OIL TOP UP IN TRANSFORMER
1194	14-01-2026	Part of : BLOCK J 5 RAJOURI GARDEN EXTENSION RAJOURI GARDEN	441	Other Outage	Planned Outage	14-01-2026	10:47	14-01-2026	13:54	3:07	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1195	15-01-2026	Part of : BE-BLOCK HARI NAGAR	525	Other Outage	Unplanned Outage	15-01-2026	13:39	15-01-2026	15:28	1:49	0.001211	MOBILE TRANSFORMER REPLACEMENT
1196	15-01-2026	Part of : BLOCK C JANAK PURI	3	Other Outage	Planned Outage	15-01-2026	13:33	15-01-2026	14:02	0:29	0.000161	LT CIRCUIT MAINTENANCE
1197	15-01-2026	Part of : BLOCK 40 ASHOK NAGAR	456	Other Outage	Planned Outage	15-01-2026	14:25	15-01-2026	17:46	3:21	0.001675	DT REPLACEMENT
1198	15-01-2026	Part of : TIHAR CENTRAL JAIL JANAK PURI	12	Other Outage	Planned Outage	15-01-2026	12:06	15-01-2026	14:31	2:25	0.000806	LT CIRCUIT MAINTENANCE
1199	15-01-2026	Part of : BLOCK WH MAYAPURI INDUSTRIAL AREA PHASE-1	1	Other Outage	Planned Outage	15-01-2026	11:32	15-01-2026	13:47	2:15	0.000750	LT CIRCUIT MAINTENANCE
1200	15-01-2026	Part of : BLOCK B3 JANAK PURI	388	Other Outage	Planned Outage	15-01-2026	11:31	15-01-2026	14:01	2:30	0.000833	LT CIRCUIT MAINTENANCE
1201	15-01-2026	Part of : BLOCK J 9 RAJOURI GARDEN EXTENSION	706	Other Outage	Planned Outage	15-01-2026	11:19	15-01-2026	13:36	2:17	0.000761	LT CIRCUIT MAINTENANCE
1202	16-01-2026	Part of : PHASE 4 OM VIHAR HASTSAL	927	Other Outage	Planned Outage	16-01-2026	12:10	16-01-2026	13:28	1:18	0.000000	1PH DB REVAMPING,3PH DB REVAMPING
1203	16-01-2026	Part of : VIKRANT ENCLAVE PRESS COLONY MAYAPURI	454	Other Outage	Planned Outage	16-01-2026	12:07	16-01-2026	17:33	5:26	0.002717	DT REPLACEMENT
1204	16-01-2026	Part of : NANGAL VILLAGE DELHI CANTONMENT	845	Other Outage	Planned Outage	16-01-2026	12:45	16-01-2026	17:15	4:30	0.002625	DT REPLACEMENT
1205	16-01-2026	Part of : MEENAKSHI GARDEN ASHOK NAGAR	484	Other Outage	Planned Outage	16-01-2026	12:35	16-01-2026	17:36	5:01	0.002508	DT REPLACEMENT
1206	16-01-2026	Part of : SHIV NAGAR EXTENSION JANAK PURI	541	Other Outage	Planned Outage	16-01-2026	11:58	16-01-2026	16:11	4:13	0.002108	DT REPLACEMENT
1207	16-01-2026	Part of : TIHAR CENTRAL JAIL JANAK PURI	435	Other Outage	Planned Outage	16-01-2026	14:30	16-01-2026	17:25	2:55	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1208	16-01-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	186	Other Outage	Planned Outage	16-01-2026	12:01	16-01-2026	14:30	2:29	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1209	16-01-2026	Part of : PALAM EXTENSION	442	Other Outage	Planned Outage	16-01-2026	11:15	16-01-2026	13:29	2:14	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1210	16-01-2026	Part of : BLOCK B 3A JANAK PURI	408	Other Outage	Planned Outage	16-01-2026	11:17	16-01-2026	14:29	3:12	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1211	17-01-2026	Part of : 16 BLOCK PRESS COLONY MAYAPURI	1404	Other Outage	Unplanned Outage	17-01-2026	14:33	17-01-2026	16:23	1:50	0.000611	MOBILE TRANSFORMER REPLACEMENT
1212	17-01-2026	Part of : POCKET DL HARI NAGAR	261	Other Outage	Unplanned Outage	17-01-2026	14:31	17-01-2026	16:22	1:51	0.000617	MOBILE TRANSFORMER REPLACEMENT
1213	17-01-2026	Part of : POCKET UB ASHA PARK FATEH NAGAR	574	Other Outage	Planned Outage	17-01-2026	14:41	17-01-2026	17:50	3:09	0.001575	MAINTENANCE OF TRANSFORMER
1214	17-01-2026	Part of : HTC:BAGGER HOME	1	Other Outage	Planned Outage	17-01-2026	12:59	17-01-2026	15:20	2:21	0.000000	MAINTENANCE OF RMU
1215	17-01-2026	Part of : G BLOCK RAJOURI GARDEN	333	Other Outage	Planned Outage	17-01-2026	11:04	17-01-2026	13:10	2:06	0.000000	MAINTENANCE OF LT TRANSFORMER
1216	17-01-2026	Part of : B 3A BLOCK JANAK PURI	419	Other Outage	Planned Outage	17-01-2026	12:02	17-01-2026	15:19	3:17	0.000000	MAINTENANCE OF LT TRANSFORMER
1217	18-01-2026	Part of : BLOCK WZ NANGAL RAYA JANAK PURI, MOHAN NAGAR SAGARPUR MAIN	4327	Other Outage	Unplanned Outage	18-01-2026	01:10	18-01-2026	02:14	1:04	0.000301	CABLE FAULT
1218	18-01-2026	Part of : BLOCK 1 SUBHASH NAGAR	746	Other Outage	Unplanned Outage	18-01-2026	10:58	18-01-2026	12:57	1:59	0.000661	REPLACEMENT OF LT TRANSFORMER
1219	18-01-2026	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I	299	Other Outage	Planned Outage	18-01-2026	13:25	18-01-2026	16:15	2:50	0.001417	REPLACEMENT OF LT BUSHING ROD
1220	19-01-2026	Part of : SHIV NAGAR EXTENSION JANAK PURI	541	Other Outage	Unplanned Outage	19-01-2026	16:16	19-01-2026	17:38	1:22	0.000228	TRANSFORMER REPLACEMENT
1221	19-01-2026	Part of : BLOCK BE HARI NAGAR	526	Other Outage	Planned Outage	19-01-2026	13:26	19-01-2026	17:40	4:14	0.002117	DT REPLACEMENT
1222	19-01-2026	Part of : BLOCK G RAJOURI GARDEN	320	Other Outage	Planned Outage	19-01-2026	13:26	19-01-2026	16:51	3:25	0.001708	DT REPLACEMENT
1223	19-01-2026	Part of : BLOCK 40 ASHOK NAGAR	1136	Other Outage	Planned Outage	19-01-2026	13:27	19-01-2026	16:52	3:25	0.001708	DT REPLACEMENT
1224	19-01-2026	Part of : POCKET G HARI NAGAR JANAK PURI	934	Other Outage	Planned Outage	19-01-2026	11:30	19-01-2026	15:25	3:55	0.000000	DT REPLACEMENT
1225	19-01-2026	Part of : DELHI CANTT RAILWAY	1	Other Outage	Planned Outage	19-01-2026	11:20	19-01-2026	12:12	0:52	0.000000	LT CIRCUIT MAINTENANCE WORK
1226	19-01-2026	Part of : BLOCK B 3A JANAK PURI	355	Other Outage	Planned Outage	19-01-2026	10:54	19-01-2026	14:08	3:14	0.000000	LT CIRCUIT MAINTENANCE WORK
1227	19-01-2026	Part of : SHIV NAGAR EXTENSION JANAK PURI	281	Other Outage	Planned Outage	19-01-2026	10:58	19-01-2026	14:07	3:09	0.000000	LT CIRCUIT MAINTENANCE WORK

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1228	19-01-2026	Part of : BLOCK J 8 RAJOURI GARDEN EXTENSION	188	Other Outage	Planned Outage	19-01-2026	10:54	19-01-2026	13:42	2:48	0.000000	LT CIRCUIT MAINTENANCE WORK
1229	19-01-2026	Part of : BLOCK C 2C JANAK PURI	418	Other Outage	Planned Outage	19-01-2026	11:31	19-01-2026	14:09	2:38	0.000000	LT CIRCUIT MAINTENANCE WORK
1230	20-01-2026	Part of : POCKET UB ASHA PARK FATEH NAGAR,BLOCK B & C FATEH NAGAR	3706	Other Outage	Unplanned Outage	20-01-2026	13:11	20-01-2026	15:48	2:37	0.000872	TRANSFORMER REPLACEMENT
1231	20-01-2026	Part of : BLOCK A NANAK PURA HARI NAGAR	723	Other Outage	Unplanned Outage	20-01-2026	13:02	20-01-2026	15:33	2:31	0.000419	TRANSFORMER REPLACEMENT
1232	20-01-2026	Part of : POCKET G HARI NAGAR JANAK PURI	729	Other Outage	Unplanned Outage	20-01-2026	12:07	20-01-2026	15:30	3:23	0.001128	TRANSFORMER REPLACEMENT
1233	20-01-2026	Part of : CCRA BUILDING (HT CONSUMER)	1	Other Outage	Planned Outage	20-01-2026	14:32	20-01-2026	16:00	1:28	0.000000	PROPER SEALING RMU PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
1234	20-01-2026	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI	630	Other Outage	Planned Outage	20-01-2026	11:39	20-01-2026	13:07	1:28	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1235	20-01-2026	Part of : VIKRANT ENCLAVE PRESS COLONY MAYAPURI	454	Other Outage	Planned Outage	20-01-2026	12:44	20-01-2026	17:08	4:24	0.002200	DT REPLACEMENT
1236	20-01-2026	Part of : POCKET B 1 B 1 MARKET SUPER BAZAR JANAK PURI	105	Other Outage	Planned Outage	20-01-2026	13:28	20-01-2026	16:25	2:57	0.000000	OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1237	20-01-2026	Part of : BLOCK G RAJOURI GARDEN	311	Other Outage	Planned Outage	20-01-2026	10:54	20-01-2026	13:39	2:45	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1238	20-01-2026	Part of : BOLOCK C KHAJAN BASTI MAYAPURI INDUSTRIAL AREA PHASE II	612	Other Outage	Planned Outage	20-01-2026	11:13	20-01-2026	14:21	3:08	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1239	21-01-2026	Part of : POCKET G HARI NAGAR JANAK PURI,POCKET A 1 DTC COLONY MAYA ENCLAVE HARI NAGAR	2392	Other Outage	Unplanned Outage	21-01-2026	11:30	21-01-2026	13:31	2:01	0.000672	TRANSFORMER REPLACEMENT
1240	21-01-2026	Part of : BLOCK B2 SHIV NAGAR JANAK PURI,	272	Other Outage	Planned Outage	21-01-2026	14:14	21-01-2026	15:41	1:27	0.000000	LT TRANSFORMER MAINTENANCE
1241	21-01-2026	Part of : HTC:DELHI CANT BOOSTER PUMP	1	Other Outage	Planned Outage	21-01-2026	13:37	21-01-2026	14:44	1:07	0.000000	LT RMU MAINTENANCE
1242	21-01-2026	Part of : POCKET DL HARI NAGAR,	261	Other Outage	Planned Outage	21-01-2026	14:00	21-01-2026	17:26	3:26	0.001717	TRANSFORMER MAINTENANCE
1243	21-01-2026	Part of : BLOCK 4 SUBHASH NAGAR,	350	Other Outage	Planned Outage	21-01-2026	11:43	21-01-2026	17:50	6:07	0.003058	RMU MAINTENANCE
1244	21-01-2026	Part of : BLOCK 16 PRESS COLONY MAYAPURI,	1103	Other Outage	Planned Outage	21-01-2026	13:21	21-01-2026	17:33	4:12	0.002100	TRANSFORMER MAINTENANCE
1245	21-01-2026	Part of : BLOCK C4B JANAK PURI,	535	Other Outage	Planned Outage	21-01-2026	11:37	21-01-2026	14:04	2:27	0.000000	LT TRANSFORMER MAINTENANCE
1246	21-01-2026	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI,	14	Other Outage	Planned Outage	21-01-2026	11:15	21-01-2026	14:15	3:00	0.000000	LT TRANSFORMER MAINTENANCE
1247	21-01-2026	Part of : BLOCK C3 RAJOURI GARDEN,	174	Other Outage	Planned Outage	21-01-2026	12:00	21-01-2026	14:43	2:43	0.000000	LT TRANSFORMER MAINTENANCE
1248	22-01-2026	Part of : BLOCK C1 JANAK PURI	3	Other Outage	Planned Outage	22-01-2026	16:23	22-01-2026	17:12	0:49	0.000000	EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,JUMPER REPLACEMENT PER POLE
1249	22-01-2026	Part of : D-1 JANAKPURI	1	Other Outage	Planned Outage	22-01-2026	11:38	22-01-2026	12:27	0:49	0.000000	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
1250	22-01-2026	Part of : BLOCK B 2B JANAK PURI	164	Other Outage	Planned Outage	22-01-2026	10:57	22-01-2026	14:08	3:11	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1251	22-01-2026	Part of : BLOCK C4F JANAK PURI	495	Other Outage	Planned Outage	22-01-2026	11:55	22-01-2026	14:09	2:14	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1252	22-01-2026	Part of : BLOCK EC MAYA ENCLAVE HARI NAGAR	460	Other Outage	Planned Outage	22-01-2026	11:40	22-01-2026	15:23	3:43	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER
1253	22-01-2026	Part of : BLOCK N RAJOURI GARDEN	319	Other Outage	Planned Outage	22-01-2026	10:58	22-01-2026	13:53	2:55	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1254	23-01-2026	Part of : SHIV NAGAR,POCKET G HARI NAGAR, C-BOLOCK JANAK PURI,POCKET A 1 DTC COLONY MAYA ENCLAVE HARI NAGAR	2392	Other Outage	Unplanned Outage	23-01-2026	14:10	23-01-2026	14:33	0:23	0.000128	TREE TRIMMING
1255	23-01-2026	Part of : BLOCK 16 PRESS COLONY MAYAPURI	1103	Other Outage	Planned Outage	23-01-2026	14:15	23-01-2026	17:43	3:28	0.001733	DT REPLACEMENT
1256	24-01-2026	Part of : BLOCK R RAJOURI GARDEN	430	Other Outage	Planned Outage	24-01-2026	11:33	24-01-2026	12:23	0:50	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1257	24-01-2026	Part of : NARI NIKETAN JANAKPURI	1	Other Outage	Planned Outage	24-01-2026	13:39	24-01-2026	14:45	1:06	0.000000	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY
1258	24-01-2026	Part of : POCKET DL HARI NAGAR	261	Other Outage	Planned Outage	24-01-2026	12:07	24-01-2026	17:12	5:05	0.002542	DT REPLACEMENT
1259	24-01-2026	Part of : BLOCK BB JANAK PURI	474	Other Outage	Planned Outage	24-01-2026	11:35	24-01-2026	14:52	3:17	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1260	24-01-2026	Part of : BLOCK CB MAYA ENCLAVE HARI NAGAR	30	Other Outage	Planned Outage	24-01-2026	11:12	24-01-2026	13:39	2:27	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1261	25-01-2026	Part of : BLOCK B PRESS COLONY MAYAPURI	572	Other Outage	Unplanned Outage	25-01-2026	14:01	25-01-2026	16:37	2:36	0.000433	MOBILE TRANSFORMER REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1262	26-01-2026	Part of : CHHOTI SUBJI MANDI JANAK PURI,PREM NAGAR JANAK PURI	1895	Other Outage	Unplanned Outage	26-01-2026	16:31	26-01-2026	17:23	0:52	0.000605	CABLE FAULT
1263	27-01-2026	Part of : BLOCK C3 JANAK PURI	729	Other Outage	Planned Outage	27-01-2026	14:07	27-01-2026	16:00	1:53	0.000628	LT CIRCUIT MAINTENANCE
1264	27-01-2026	Part of : BLOCK S RAJOURI GARDEN	201	Other Outage	Planned Outage	27-01-2026	11:08	27-01-2026	13:02	1:54	0.000633	LT CIRCUIT MAINTENANCE
1265	28-01-2026	Part of : BLOCK C4F JANAK PURI	643	Other Outage	Planned Outage	28-01-2026	12:00	28-01-2026	14:37	2:37	0.000000	OIL TOP UP IN TRANSFORMER,REPLACEMENT OF GAS KIT AND OIL SEAL
1266	28-01-2026	Part of : BLOCK BD GURUNANAK PURA JANAK PURI	348	Other Outage	Planned Outage	28-01-2026	12:08	28-01-2026	15:07	2:59	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
1267	28-01-2026	Part of : BLOCK J 13 RAJOURI GARDEN	194	Other Outage	Planned Outage	28-01-2026	11:00	28-01-2026	13:26	2:26	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1268	29-01-2026	Part of : BLOCK C 1A JANAK PURI,BLOCK C 2D JANAK PURI	1169	Other Outage	Unplanned Outage	29-01-2026	00:10	29-01-2026	01:16	1:06	0.000889	CABLE FAULT
1269	29-01-2026	Part of : BLOCK EC MAYA ENCLAVE HARI NAGAR,	457	Other Outage	Planned Outage	29-01-2026	13:32	29-01-2026	17:48	4:16	0.002133	DT REPLACEMENT
1270	29-01-2026	Part of : BLOCK C 2B JANAK PURI,	380	Other Outage	Planned Outage	29-01-2026	12:07	29-01-2026	14:16	2:09	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1271	29-01-2026	Part of : BLOCK BF JANAK PURI,	379	Other Outage	Planned Outage	29-01-2026	11:40	29-01-2026	14:14	2:34	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1272	29-01-2026	Part of : POCKET WS1 MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	150	Other Outage	Planned Outage	29-01-2026	11:11	29-01-2026	14:03	2:52	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1273	29-01-2026	Part of : BLOCK J 13 RAJOURI GARDEN,	283	Other Outage	Planned Outage	29-01-2026	10:58	29-01-2026	13:24	2:26	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1274	30-01-2026	Part of : BLOCK B FATEH NAGAR JANAK PURI	246	Other Outage	Planned Outage	30-01-2026	13:53	30-01-2026	14:29	0:36	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1275	30-01-2026	Part of : POCKET G HARI NAGAR JANAK PURI	932	Other Outage	Planned Outage	30-01-2026	10:36	30-01-2026	16:11	5:35	0.001861	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1276	30-01-2026	Part of : HARI ENCLAVE HARI NAGAR	2	Other Outage	Planned Outage	30-01-2026	10:58	30-01-2026	14:17	3:19	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1277	30-01-2026	Part of : BLOCK 16 PRESS COLONY MAYAPURI	126	Other Outage	Planned Outage	30-01-2026	11:02	30-01-2026	13:58	2:56	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1278	31-01-2026	Part of : PRESS COLONY MAYAPURI	1	Other Outage	Unplanned Outage	31-01-2026	03:22	31-01-2026	04:10	0:48	0.000152	CABLE FAULT
1279	31-01-2026	Part of : C 1A-BLOCK JANAK PURI	355	Other Outage	Planned Outage	31-01-2026	11:37	31-01-2026	14:49	3:12	0.000000	LT CIRCUIT MAINTENANCE
1280	31-01-2026	Part of : NANGAL RAYA JANAK PURI	880	Other Outage	Planned Outage	31-01-2026	11:31	31-01-2026	13:40	2:09	0.000000	LT CIRCUIT MAINTENANCE
1281	31-01-2026	Part of : J-BLOCK RAJOURI GARDEN	230	Other Outage	Planned Outage	31-01-2026	11:29	31-01-2026	13:31	2:02	0.000678	LT CIRCUIT MAINTENANCE
1282	31-01-2026	Part of : B-BLOCK FATEH NAGAR JANAK PURI	378	Other Outage	Planned Outage	31-01-2026	11:31	31-01-2026	13:34	2:03	0.000000	LT CIRCUIT MAINTENANCE
1283	01-01-2026	Part of : BLOCK C JJ COLONY 2 NANGLOI,	2591	Other Outage	Planned Outage	01-01-2026	14:55	01-01-2026	17:36	2:41	0.001342	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1284	01-01-2026	Part of : VEENA ENCLAVE MUNDKA,	83	Other Outage	Planned Outage	01-01-2026	12:49	01-01-2026	14:58	2:09	0.000717	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1285	02-01-2026	Part of : NETAJI SUBHASH VIHAR MUNDKA	11	Other Outage	Planned Outage	02-01-2026	15:13	02-01-2026	16:05	0:52	0.000289	SUB STATION CLEANING
1286	02-01-2026	Part of : BLOCK C YADAV PARK NANGLOI EXTENSION NANGLOI	396	Other Outage	Planned Outage	02-01-2026	15:17	02-01-2026	16:10	0:53	0.000294	REPLACEMENT OF LT BUSHING ROD
1287	02-01-2026	Part of : NIRMAL VIHAR BAPROLA,BANI AIR FORCE CAMP JAI VIHAR BAPROLA	1064	Other Outage	Planned Outage	02-01-2026	11:25	02-01-2026	14:26	3:01	0.001508	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1288	03-01-2026	Part of : YADAV PARK KAMARUDDIN NAGAR	374	Other Outage	Planned Outage	03-01-2026	12:37	03-01-2026	16:01	3:24	0.001133	REPLACEMENT OF HT BUSHING ROD
1289	03-01-2026	Part of : BLOCK B MUNDKA	444	Other Outage	Planned Outage	03-01-2026	11:15	03-01-2026	13:51	2:36	0.002167	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1290	04-01-2026	Part of : MUNDKA EXTENSION,BLOCK C MUNDKA,MUNDKA VILLAGE	525	Other Outage	Planned Outage	04-01-2026	12:46	04-01-2026	15:43	2:57	0.004917	REPLACEMENT OF GAS KIT AND OIL SEAL
1291	04-01-2026	Part of : SAVITA VIHAR MUNDKA,MUNDKA EXTENSION	537	Other Outage	Planned Outage	04-01-2026	12:45	04-01-2026	15:42	2:57	0.005900	REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1292	04-01-2026	Part of : MUNDKA INDUSTRIAL AREA	34	Other Outage	Planned Outage	04-01-2026	13:05	04-01-2026	15:12	2:07	0.001411	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1293	04-01-2026	Part of : WEST CABIN BLOCK MUNDKA	664	Other Outage	Planned Outage	04-01-2026	12:23	04-01-2026	14:54	2:31	0.000839	LT AB SAGGING PER SPAN
1294	04-01-2026	Part of : WEST CABIN BLOCK MUNDKA	18	Other Outage	Planned Outage	04-01-2026	11:07	04-01-2026	13:56	2:49	0.000704	REPLACEMET OF HT BUSHING ROD
1295	04-01-2026	Part of : WEST CABIN BLOCK MUNDKA	564	Other Outage	Planned Outage	04-01-2026	11:07	04-01-2026	13:54	2:47	0.000928	REPLACEMET OF FAULTY END BOX
1296	04-01-2026	Part of : WEST CABIN BLOCK MUNDKA	30	Other Outage	Planned Outage	04-01-2026	10:29	04-01-2026	13:51	3:22	0.001122	REPLACEMET OF HT BUSHING ROD
1297	05-01-2026	Part of : JJ COLONY 1 NANGLOI,BLOCK A JJ COLONY 2 NANGLOI,BLOCK C JJ COLONY 2 NANGLOI,POCKET Y JJ COLONY 3 NANGLOI	5137	Other Outage	Unplanned Outage	05-01-2026	13:43	05-01-2026	14:20	0:37	0.000709	CABLE FAULT
1298	05-01-2026	Part of : TILANGPUR KOTLA,RANHOLLA,	745	Other Outage	Planned Outage	05-01-2026	11:14	05-01-2026	13:11	1:57	0.002600	MAINTENANCE OF HT O/H CIRCUIT
1299	05-01-2026	Part of : BAKKARWALA VILLAGE BAKARWALA,	1326	Other Outage	Planned Outage	05-01-2026	11:57	05-01-2026	14:23	2:26	0.001217	MAINTENANCE OF TRANSFORMER
1300	06-01-2026	Part of : WEST CABIN BLOCK MUNDKA,GULSHAN PARK WEST CABIN BLOCK MUNDKA	253	Other Outage	Unplanned Outage	06-01-2026	15:16	06-01-2026	15:59	0:43	0.002293	CABLE FAULT
1301	06-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	662	Other Outage	Planned Outage	06-01-2026	12:01	06-01-2026	13:21	1:20	0.000667	SUB STATION CLEANING
1302	06-01-2026	Part of : HIRAN KUDNA	423	Other Outage	Planned Outage	06-01-2026	11:32	06-01-2026	13:43	2:11	0.000728	REPLACEMENT OF HT BUSHING ROD
1303	07-01-2026	Part of : RAJENDRA PARK EXTENSION,RAJENDRA PARK,TYAGI COLONY,BLOCK A 1 NANGLOI EXTENSION,JOHAR VILLAGE	1112	Other Outage	Planned Outage	07-01-2026	11:41	07-01-2026	13:50	2:09	0.001075	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1304	07-01-2026	Part of : TIKRI KALAN	1110	Other Outage	Planned Outage	07-01-2026	11:05	07-01-2026	13:34	2:29	0.000621	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1305	07-01-2026	Part of : JOHAR VILLAGE NANGLOI EXTENSION	248	Other Outage	Planned Outage	07-01-2026	11:32	07-01-2026	13:49	2:17	0.001142	REPLACEMENT OF GAS KIT AND OIL SEAL
1306	08-01-2026	Part of : LAXMI PARK COLONY,MUNDKA EXTENSION,MUNDKA VILLAGE MUNDKA	3009	Other Outage	Unplanned Outage	08-01-2026	21:13	08-01-2026	22:06	0:53	0.000000	HVDS FAULT
1307	08-01-2026	Part of : BLOCK B YADAV PARK NANGLOI EXTENSION,TYAGI COLONY NANGLOI EXTENSION,RAJENDRA PARK NANGLOI EXTENSION NANGLOI, NANGLOI EXTENSION	7171	Other Outage	Unplanned Outage	08-01-2026	15:13	08-01-2026	16:06	0:53	0.000442	CABLE FAULT
1308	08-01-2026	Part of : AAKASH VIHAR	859	Other Outage	Planned Outage	08-01-2026	14:41	08-01-2026	15:52	1:11	0.000394	REPLACEMET OF HT BUSHING ROD
1309	08-01-2026	Part of : POCKET C LOKNAYAK PURAM BAKARWALA	205	Other Outage	Planned Outage	08-01-2026	11:35	08-01-2026	14:34	2:59	0.001989	SUB STATION CLEANING
1310	09-01-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	47	Other Outage	Planned Outage	09-01-2026	14:02	09-01-2026	15:14	1:12	0.000400	MAINTENANCE OF TRANSFORMER
1311	10-01-2026	PART OF : MUNDKA INDUSTRIAL AREA MUNDKA	7	Other Outage	Planned Outage	10-01-2026	13:01	10-01-2026	15:43	2:42	0.001350	REPLACEMENT OF HT BUSHING ROD
1312	10-01-2026	PART OF : MUNDKA VILLAGE MUNDKA	1689	Other Outage	Planned Outage	10-01-2026	12:31	10-01-2026	15:23	2:52	0.004778	REPLACEMENT OF FAULTY END BOX
1313	10-01-2026	PART OF : BLOCK D KUNWAR SINGH NAGAR KAMARUDDIN NAGAR	1126	Other Outage	Planned Outage	10-01-2026	10:52	10-01-2026	13:44	2:52	0.000717	REPLACEMENT OF HT BUSHING ROD
1314	11-01-2026	Part of : MUNDKA EXTENSION,MUNDKA INDUSTRIAL AREA,JAI VIHAR KAMARUDDIN NAGAR,MUNDKA VILLAGE,SAVITA VIHAR	305	Other Outage	Unplanned Outage	11-01-2026	10:13	11-01-2026	11:06	0:53	0.000618	CABLE FAULT
1315	11-01-2026	Part of : NEELWAL VILLAGE	597	Other Outage	Planned Outage	11-01-2026	14:01	11-01-2026	14:43	0:42	0.000350	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
1316	11-01-2026	Part of : TIKRI KALAN	1101	Other Outage	Planned Outage	11-01-2026	13:18	11-01-2026	14:03	0:45	0.000375	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
1317	11-01-2026	Part of : TIKRI KALAN	1296	Other Outage	Planned Outage	11-01-2026	10:04	11-01-2026	10:38	0:34	0.000189	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
1318	11-01-2026	Part of : HIRAN KUDNA	394	Other Outage	Planned Outage	11-01-2026	14:40	11-01-2026	16:18	1:38	0.000544	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
1319	11-01-2026	Part of : MUNDKA INDUSTRIAL AREA	19	Other Outage	Planned Outage	11-01-2026	12:16	11-01-2026	15:08	2:52	0.001433	REPLACEMENT OF GAS KIT AND OIL SEAL
1320	11-01-2026	Part of : VEENA ENCLAVE WEST CABIN BLOCK MUNDKA	13	Other Outage	Planned Outage	11-01-2026	11:01	11-01-2026	13:22	2:21	0.000783	REPLACEMENT OF HT BUSHING ROD
1321	11-01-2026	Part of : MUNDKA INDUSTRIAL AREA	104	Other Outage	Planned Outage	11-01-2026	10:35	11-01-2026	13:20	2:45	0.002292	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1322	12-01-2026	Part of : BLOCK B MUNDKA	450	Other Outage	Planned Outage	12-01-2026	12:16	12-01-2026	13:51	1:35	0.000792	GUARD WIRES SAGGING PER SPAN
1323	12-01-2026	Part of : BAKKARWALA VILLAGE	1085	Other Outage	Planned Outage	12-01-2026	12:15	12-01-2026	14:19	2:04	0.001033	SUB STATION CLEANING
1324	12-01-2026	Part of : TIKRI KALAN	258	Other Outage	Planned Outage	12-01-2026	11:10	12-01-2026	13:16	2:06	0.000700	REPLACEMENT OF LT BUSHING ROD
1325	12-01-2026	Part of : NIRMAL VIHAR BAPROLA	588	Other Outage	Planned Outage	12-01-2026	11:31	12-01-2026	14:16	2:45	0.000917	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1326	12-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	1633	Other Outage	Planned Outage	12-01-2026	11:25	12-01-2026	14:18	2:53	0.000961	REPLACEMET OF HT BUSHING ROD
1327	13-01-2026	Part of : RANHOLLA	387	Other Outage	Planned Outage	13-01-2026	11:50	13-01-2026	14:06	2:16	0.001133	SUB STATION CLEANING
1328	14-01-2026	Part of : AAKASH VIHAR	859	Other Outage	Planned Outage	14-01-2026	15:24	14-01-2026	16:44	1:20	0.000444	REPLACEMENT OF HT BUSHING ROD
1329	14-01-2026	Part of : RAJENDRA PARK EXTENSION NANGLOI EXTENSION NANGLOI,A,B,C & D BLOCK NANGLOI EXTENSION NANGLOI	2576	Other Outage	Planned Outage	14-01-2026	13:35	14-01-2026	15:27	1:52	0.001867	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES
1330	15-01-2026	Part of : TILANGPUR KOTLA,RANHOLLA,AAKASH VIHAR,NIRMAL VIHAR BAPROLA	4105	Other Outage	Unplanned Outage	15-01-2026	15:28	15-01-2026	16:48	1:20	0.000000	TO CONNECT EARTHING/FAULT IN RMU
1331	15-01-2026	Part of : BLOCK 4 ABC NANGLOI EXTENSION	2118	Other Outage	Planned Outage	15-01-2026	11:43	15-01-2026	14:39	2:56	0.001222	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
1332	15-01-2026	Part of : MUNDKA VILLAGE	622	Other Outage	Planned Outage	15-01-2026	11:03	15-01-2026	13:38	2:35	0.000431	REPLACEMET OF HT BUSHING ROD
1333	15-01-2026	Part of : HIRAN KUDNA	73	Other Outage	Planned Outage	15-01-2026	11:27	15-01-2026	14:01	2:34	0.000856	REPLACEMET OF HT BUSHING ROD
1334	16-01-2026	Part of : NIRMAL VIHAR BAPROLA,BANI AIR FORCE CAMP JAI VIHAR BAPROLA,TILANGPUR KOTLA	6210	Other Outage	Unplanned Outage	16-01-2026	14:00	16-01-2026	14:48	0:48	0.000493	CABLE FAULT
1335	16-01-2026	Part of : NEW PVC MARKET TIKRI KALAN,TIKRI KALAN	340	Other Outage	Unplanned Outage	16-01-2026	13:29	16-01-2026	14:04	0:35	0.000117	HT SYSTEM FAULT
1336	16-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,RANHOLLA	4707	Other Outage	Planned Outage	16-01-2026	12:45	16-01-2026	14:03	1:18	0.001517	JUMPER REPLACEMENT PER POLE
1337	16-01-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	274	Other Outage	Planned Outage	16-01-2026	11:28	16-01-2026	13:44	2:16	0.000567	REPLACEMET OF HT BUSHING ROD
1338	17-01-2026	Part of : JOHAR VILLAGE NANGLOI EXTENSION NANGLOI	356	Other Outage	Planned Outage	17-01-2026	13:03	17-01-2026	14:15	1:12	0.000300	MAINTENANCE OF TRANSFORMER
1339	17-01-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA	21	Other Outage	Planned Outage	17-01-2026	11:12	17-01-2026	13:53	2:41	0.001118	MAINTENANCE OF TRANSFORMER
1340	17-01-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	70	Other Outage	Planned Outage	17-01-2026	11:32	17-01-2026	14:17	2:45	0.001375	MAINTENANCE OF TRANSFORMER
1341	18-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	1137	Other Outage	Unplanned Outage	18-01-2026	14:30	18-01-2026	16:05	1:35	0.000000	REPAIRING OF CONDUCTOR ON HT POLE
1342	18-01-2026	Part of : BLOCK A NANGLOI EXTENSION	935	Other Outage	Planned Outage	18-01-2026	12:21	18-01-2026	13:53	1:32	0.000767	SUB STATION CLEANING
1343	18-01-2026	Part of : MUNDKA INDUSTRIAL AREA,TYAGI VIHAR MUNDKA	313	Other Outage	Planned Outage	18-01-2026	11:17	18-01-2026	13:28	2:11	0.001819	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1344	18-01-2026	Part of : IOC PLANT GHEVARA MORE (HTC)	1	Other Outage	Planned Outage	18-01-2026	11:18	18-01-2026	13:28	2:10	0.001083	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1345	19-01-2026	Part of : BLOCK A JJ COLONY 2 NANGLOI	1557	Other Outage	Planned Outage	19-01-2026	14:23	19-01-2026	16:04	1:41	0.000281	REPLACEMET OF HT BUSHING ROD
1346	19-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	777	Other Outage	Planned Outage	19-01-2026	12:05	19-01-2026	13:35	1:30	0.001000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1347	19-01-2026	Part of : TIKRI KALAN	34	Other Outage	Planned Outage	19-01-2026	10:28	19-01-2026	12:18	1:50	0.000306	REPLACEMET OF HT BUSHING ROD
1348	19-01-2026	Part of : FRIENDS COLONY MUNDKA	864	Other Outage	Planned Outage	19-01-2026	12:35	19-01-2026	14:38	2:03	0.001367	REPLACEMET OF HT BUSHING ROD
1349	19-01-2026	Part of : TILANGPUR KOTLA	840	Other Outage	Planned Outage	19-01-2026	12:26	19-01-2026	14:40	2:14	0.000558	HT CONDUCTOR REPLACEMENT
1350	20-01-2026	Part of : MUNDKA EXTENSION	61	Other Outage	Planned Outage	20-01-2026	15:28	20-01-2026	17:00	1:32	0.000000	REPLACEMET OF HT BUSHING ROD
1351	20-01-2026	Part of : BLOCK C MUNDKA,VEENA ENCLAVE MUNDKA	736	Other Outage	Planned Outage	20-01-2026	15:27	20-01-2026	17:01	1:34	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1352	20-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,JAI VIHAR KAMARUDDIN NAGAR	5999	Other Outage	Planned Outage	20-01-2026	15:29	20-01-2026	16:59	1:30	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1353	20-01-2026	Part of : RANHOLLA	382	Other Outage	Planned Outage	20-01-2026	13:56	20-01-2026	16:16	2:20	0.000778	CONDUCTOR REPLACEMENT PER SPAN
1354	20-01-2026	Part of : YADAV PARK KAMARUDDIN NAGAR	788	Other Outage	Planned Outage	20-01-2026	13:33	20-01-2026	16:01	2:28	0.000822	REPLACEMENT OF GAS KIT AND OIL SEAL
1355	21-01-2026	Part of : NEELWAL VILLAGE,TIKRI KALAN,NEW PVC MARKET TIKRI KALAN,NETAJI SUBHASH VIHAR MUNDKA	4436	Other Outage	Unplanned Outage	21-01-2026	13:45	21-01-2026	14:20	0:35	0.000000	CABLE FAULT
1356	21-01-2026	Part of : TIKRI KALAN,	173	Other Outage	Planned Outage	21-01-2026	15:33	21-01-2026	16:23	0:50	0.000417	TRANSFORMER MAINTENANCE
1357	21-01-2026	Part of : JJ COLONY BAKARWALA,	197	Other Outage	Planned Outage	21-01-2026	14:35	21-01-2026	15:59	1:24	0.000467	TRANSFORMER MAINTENANCE
1358	21-01-2026	Part of : YADAV PARK KAMARUDDIN NAGAR,	374	Other Outage	Planned Outage	21-01-2026	11:35	21-01-2026	13:32	1:57	0.000975	TRANSFORMER MAINTENANCE
1359	22-01-2026	Part of : BLOCK 2C NANGLOI EXTENSION NANGLOI,BLOCK 2B NANGLOI EXTENSION NANGLOI,RAJENDRA PARK EXTENSION NANGLOI EXTENSION NANGLOI	8954	Other Outage	Unplanned Outage	22-01-2026	11:03	22-01-2026	13:38	2:35	0.000000	REPAIRING OF RMU
1360	22-01-2026	Part of : JJ COLONY 1 NANGLOI,BLOCK A JJ COLONY 2 NANGLOI,BLOCK C JJ COLONY 2 NANGLOI,POCKET Y JJ COLONY 3 NANGLOI	7726	Other Outage	Unplanned Outage	22-01-2026	11:00	22-01-2026	13:36	2:36	0.000000	REPAIRING OF RMU
1361	22-01-2026	Part of : RANHOLLA	621	Other Outage	Planned Outage	22-01-2026	12:23	22-01-2026	14:15	1:52	0.000622	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1362	22-01-2026	Part of : POCKET C LOKNAYAK PURAM BAKARWALA	205	Other Outage	Planned Outage	22-01-2026	12:22	22-01-2026	14:57	2:35	0.000861	GUARD WIRES SAGGING PER SPAN
1363	23-01-2026	Part of : NIRMAL VIHAR BAPROLA,BANI AIR FORCE CAMP JAI VIHAR BAPROLA,TILANGPUR KOTLA	6219	Other Outage	Unplanned Outage	23-01-2026	09:33	23-01-2026	09:58	0:25	0.000199	HVDS FAULT
1364	23-01-2026	Part of : B,C & D-BLOCK MUNDKA,SAVITA VIHAR,FRIENDS COLONY	4618	Other Outage	Unplanned Outage	23-01-2026	09:33	23-01-2026	10:25	0:52	0.001939	HVDS FAULT
1365	23-01-2026	Part of : LAKKARWALA NAJAFGARH ROAD	0	Other Outage	Unplanned Outage	23-01-2026	09:24	23-01-2026	10:15	0:51	0.000000	HVDS FAULT
1366	23-01-2026	Part of : TIKRI KALAN	765	Other Outage	Planned Outage	23-01-2026	14:50	23-01-2026	15:47	0:57	0.000317	REPLACEMENT OF HT BUSHING ROD
1367	24-01-2026	Part of : RAJENDRA PARK EXTENSION, BLOCK 2C NANGLOI EXTENSION	797	Other Outage	Unplanned Outage	24-01-2026	13:40	24-01-2026	14:11	0:31	0.000391	HVDS FAULT
1368	24-01-2026	Part of : BABA HARIDAS NAGAR TIKRI KALAN	39	Other Outage	Planned Outage	24-01-2026	16:26	24-01-2026	17:33	1:07	0.000372	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES
1369	24-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	781	Other Outage	Planned Outage	24-01-2026	11:04	24-01-2026	13:54	2:50	0.000944	CONDUCTOR REPLACEMET PER SPAN
1370	25-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	781	Other Outage	Planned Outage	25-01-2026	10:19	25-01-2026	13:17	2:58	0.000989	GUARD WIRES SAGGING PER SPAN
1371	25-01-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA	15	Other Outage	Planned Outage	25-01-2026	10:40	25-01-2026	13:54	3:14	0.001617	REPLACEMENT OF GAS KIT AND OIL SEAL
1372	26-01-2026	Part of : WEST CABIN BLOCK MUNDKA,GULSHAN PARK WEST CABIN BLOCK MUNDKA	286	Other Outage	Unplanned Outage	26-01-2026	18:18	26-01-2026	18:43	0:25	0.000201	HVDS FAULT
1373	26-01-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,NETAJI SUBHASH VIHAR MUNDKA	211	Other Outage	Unplanned Outage	26-01-2026	15:46	26-01-2026	16:20	0:34	0.000034	CABLE FAULT
1374	27-01-2026	Part of : NETAJI SUBHASH VIHAR MUNDKA	184	Other Outage	Planned Outage	27-01-2026	13:57	27-01-2026	15:38	1:41	0.001403	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1375	28-01-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	1138	Other Outage	Unplanned Outage	28-01-2026	10:12	28-01-2026	12:09	1:57	0.000000	CONNECTION/DISCONNECTION OF HT/LT CABLES
1376	28-01-2026	Part of : BLOCK A JJ COLONY 2 NANGLOI	1511	Other Outage	Planned Outage	28-01-2026	12:25	28-01-2026	14:13	1:48	0.000600	REPLACEMET OF HT BUSHING ROD
1377	28-01-2026	Part of : BLOCK C TYAGI VIHAR MUNDKA	3	Other Outage	Planned Outage	28-01-2026	11:00	28-01-2026	12:54	1:54	0.000633	REPLACEMENT OF GAS KIT AND OIL SEAL
1378	28-01-2026	Part of : BLOCK N AMAR COLONY NANGLOI EXTENSION	1564	Other Outage	Planned Outage	28-01-2026	12:32	28-01-2026	14:37	2:05	0.000694	REPLACEMET OF HT BUSHING ROD
1379	28-01-2026	Part of : POCKET B2 LOKNAYAK PURAM BAKARWALA	235	Other Outage	Planned Outage	28-01-2026	12:33	28-01-2026	14:38	2:05	0.000694	REPLACEMET OF HT BUSHING ROD
1380	28-01-2026	Part of : POCKET A LOKNAYAK PURAM BAKARWALA	8	Other Outage	Planned Outage	28-01-2026	12:33	28-01-2026	14:38	2:05	0.000694	GUARD WIRES SAGGING PER SPAN
1381	29-01-2026	Part of : BLOCK B MUNDKA,SAVITA VIHAR MUNDKA,FRIENDS COLONY MUNDKA,BLOCK C MUNDKA,BLOCK D MUNDKA	4619	Other Outage	Unplanned Outage	29-01-2026	10:46	29-01-2026	11:35	0:49	0.002428	CABLE FAULT
1382	29-01-2026	Part of : TILANGPUR KOTLA,	814	Other Outage	Planned Outage	29-01-2026	15:39	29-01-2026	16:40	1:01	0.000339	REPLACEMET OF HT BUSHING ROD
1383	29-01-2026	Part of : POCKET C LOKNAYAK PURAM BAKARWALA,	211	Other Outage	Planned Outage	29-01-2026	13:20	29-01-2026	14:58	1:38	0.001089	REPLACEMENT OF GAS KIT AND OIL SEAL
1384	29-01-2026	Part of : TIKRI KALAN,	648	Other Outage	Planned Outage	29-01-2026	10:54	29-01-2026	12:42	1:48	0.001200	REPLACEMET OF HT BUSHING ROD
1385	29-01-2026	Part of : RANHOLLA,	245	Other Outage	Planned Outage	29-01-2026	13:18	29-01-2026	15:48	2:30	0.001250	REPLACEMENT OF LT BUSHING ROD
1386	30-01-2026	Part of : BLOCK C MUNDKA,VEENA ENCLAVE MUNDKA	736	Other Outage	Planned Outage	30-01-2026	14:58	30-01-2026	16:07	1:09	0.000958	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1387	30-01-2026	Part of : RANHOLLA	1415	Other Outage	Planned Outage	30-01-2026	13:04	30-01-2026	14:42	1:38	0.000681	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1388	30-01-2026	Part of : BANI AIR FORCE CAMP JAI VIHAR BAPROLA	748	Other Outage	Planned Outage	30-01-2026	13:04	30-01-2026	14:43	1:39	0.000413	REPLACEMENT OF HT BUSHING ROD
1389	30-01-2026	Part of : BLOCK C TYAGI VIHAR MUNDKA	3	Other Outage	Planned Outage	30-01-2026	14:43	30-01-2026	15:56	1:13	0.000406	REPLACEMENT OF GAS KIT AND OIL SEAL
1390	30-01-2026	Part of : MUNDKA EXTENSION MUNDKA	82	Other Outage	Planned Outage	30-01-2026	12:26	30-01-2026	14:41	2:15	0.001125	REPLACEMENT OF LT BUSHING ROD
1391	31-01-2026	Part of : TILANGPUR KOTLA	1329	Other Outage	Planned Outage	31-01-2026	12:10	31-01-2026	13:31	1:21	0.000450	REPLACEMENT OF HT BUSHING ROD
1392	31-01-2026	Part of : JJ COLONY BAKARWALA	159	Other Outage	Planned Outage	31-01-2026	11:23	31-01-2026	14:05	2:42	0.000900	REPLACEMENT OF GAS KIT AND OIL SEAL
1393	31-01-2026	Part of : RATAN BAGH NANGLOI	1190	Other Outage	Planned Outage	31-01-2026	11:22	31-01-2026	14:05	2:43	0.000906	REPLACEMENT OF GAS KIT AND OIL SEAL
1394	01-01-2026	Part of : A,B&C-BLOCK MAHARANI ENCLAVE,NAWADA EXTENSION NAWADA,BLOCK K 6 ZAILDAR ENCLAVE HASTSAL,KRISHNA COLONY HASTSAL VILLAGE HASTSAL,BLOCK K 7 ZAILDAR ENCLAVE HASTSAL,BLOCK K 5 ZAILDAR ENCLAVE HASTSAL,BLOCK K 4 ZAILDAR ENCLAVE HASTSAL,RAJAN VIHAR AND D-BLOCK VIJAY NAGAR	6103	Other Outage	Unplanned Outage	01-01-2026	14:26	01-01-2026	14:57	0:31	0.000964	HT SYSTEM FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1395	01-01-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK WE MOHAN GARDEN RAZAPUR KHURD	5047	Other Outage	Unplanned Outage	01-01-2026	04:52	01-01-2026	05:25	0:33	0.000211	HT SYSTEM FAULT
1396	01-01-2026	Part of : BLOCK H BHAGWATI GARDEN NAWADA,LAXMI VIHAR NAWADA,BLOCK D BHAGWATI GARDEN NAWADA	5214	Other Outage	Planned Outage	01-01-2026	14:59	01-01-2026	16:45	1:46	0.000000	REPLACEMENT OF LT BUSHING ROD
1397	01-01-2026	Part of : BLOCK C VIPIN GARDEN NAWADA,	1113	Other Outage	Planned Outage	01-01-2026	12:15	01-01-2026	14:22	2:07	0.000000	REPLACEMENT OF HT BUSHING ROD
1398	01-01-2026	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD	1052	Other Outage	Planned Outage	01-01-2026	11:04	01-01-2026	13:54	2:50	0.000142	1PH HT AB END TERMINATION REPLACEMENT
1399	02-01-2026	Part of : BLOCK A SEWAK PARK DWARKA,BLOCK B1 SEWAK PARK DWARKA,BLOCK B SEWAK PARK DWARKA,BLOCK C SEWAK PARK DWARKA	3454	Other Outage	Planned Outage	02-01-2026	13:59	02-01-2026	16:47	2:48	0.000000	REPLACEMENT OF LT BUSHING ROD
1400	02-01-2026	Part of : PHASE 1 OM VIHAR NAWADA	977	Other Outage	Planned Outage	02-01-2026	12:45	02-01-2026	14:51	2:06	0.000700	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB CABLE REPLACEMENT PER SPAN
1401	02-01-2026	Part of : BLOCK B SEWAK PARK DWARKA	1370	Other Outage	Planned Outage	02-01-2026	11:22	02-01-2026	13:52	2:30	0.000833	DT REPLACEMENT
1402	02-01-2026	Part of : BLOCK E BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA	2660	Other Outage	Planned Outage	02-01-2026	11:23	02-01-2026	13:53	2:30	0.000000	REPLACEMENT OF HT BUSHING ROD
1403	02-01-2026	Part of : RAZAPUR KHURD	1064	Other Outage	Planned Outage	02-01-2026	11:11	02-01-2026	13:54	2:43	0.000453	REPLACEMENT OF LT BUSHING ROD
1404	03-01-2026	Part of : MOHAN GARDEN NAWADA,OM VIHAR PHASE 1	1374	Other Outage	Planned Outage	03-01-2026	13:31	03-01-2026	15:26	1:55	0.001597	3PH HT AB CABLE REPLACEMENT
1405	03-01-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA	1528	Other Outage	Planned Outage	03-01-2026	15:24	03-01-2026	17:36	2:12	0.001833	3PH HT AB CABLE REPLACEMENT
1406	03-01-2026	Part of : BLOCK C VIPIN GARDEN NAWADA	596	Other Outage	Planned Outage	03-01-2026	11:16	03-01-2026	13:39	2:23	0.000000	REPLACEMENT OF HT BUSHING ROD
1407	03-01-2026	Part of : RAZAPUR KHURD,VIKAS KUNJ	874	Other Outage	Planned Outage	03-01-2026	11:32	03-01-2026	13:40	2:08	0.000711	3PH HT AB CABLE REPLACEMENT
1408	05-01-2026	Part of : BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK F ZAILDAR ENCLAVE NAWADA	1507	Other Outage	Planned Outage	05-01-2026	15:02	05-01-2026	16:10	1:08	0.000944	MAINTENANCE OF HVDS CIRCUIT
1409	05-01-2026	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,	903	Other Outage	Planned Outage	05-01-2026	14:05	05-01-2026	16:08	2:03	0.000683	MAINTENANCE OF HVDS CIRCUIT
1410	05-01-2026	Part of : NAWADA EXTENSION NAWADA,BLOCK A MAHAVIR ENCLAVE NAWADA	2118	Other Outage	Planned Outage	05-01-2026	13:02	05-01-2026	15:36	2:34	0.002139	MAINTENANCE OF HVDS CIRCUIT
1411	05-01-2026	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA,	253	Other Outage	Planned Outage	05-01-2026	12:42	05-01-2026	15:38	2:56	0.000000	MAINTENANCE OF TRANSFORMER
1412	05-01-2026	Part of : BLOCK E BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA	2660	Other Outage	Planned Outage	05-01-2026	11:41	05-01-2026	14:26	2:45	0.000917	MAINTENANCE OF HT O/H CIRCUIT
1413	05-01-2026	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD	1052	Other Outage	Planned Outage	05-01-2026	11:34	05-01-2026	13:56	2:22	0.000394	MAINTENANCE OF HVDS CIRCUIT
1414	06-01-2026	Part of : RAZAPUR KHURD,RAZA PUR KHURD VIKAS NAGAR	713	Other Outage	Planned Outage	06-01-2026	14:05	06-01-2026	16:15	2:10	0.000361	3PH HT AB CABLE REPLACEMENT PER SPAN
1415	06-01-2026	Part of : MOHAN GARDEN NAWADA,PHASE 1 OM VIHAR NAWADA	1374	Other Outage	Planned Outage	06-01-2026	11:59	06-01-2026	14:50	2:51	0.002375	3PH HT AB CABLE REPLACEMENT PER SPAN
1416	06-01-2026	Part of : BLOCK N1, P2, R 1 & R5 MOHAN GARDEN RAZAPUR KHURD	2908	Other Outage	Planned Outage	06-01-2026	11:30	06-01-2026	13:49	2:19	0.000386	3PH HT AB CABLE REPLACEMENT PER SPAN
1417	06-01-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA	1353	Other Outage	Planned Outage	06-01-2026	11:22	06-01-2026	13:53	2:31	0.000000	REPLACEMENT OF HT BUSHING ROD
1418	07-01-2026	Part of : BLOCK D MANSARA RAM PARK UTTAM NAGAR	231	Other Outage	Planned Outage	07-01-2026	15:28	07-01-2026	16:22	0:54	0.000000	REPLACEMENT OF HT BUSHING ROD
1419	07-01-2026	Part of : LAXMI VIHAR NAWADA	963	Other Outage	Planned Outage	07-01-2026	12:21	07-01-2026	14:48	2:27	0.000000	REPLACEMENT OF HT BUSHING ROD
1420	07-01-2026	Part of : BLOCK P, P 2 & R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK H & L BHAGWATI GARDEN NAWADA	1947	Other Outage	Planned Outage	07-01-2026	12:06	07-01-2026	15:04	2:58	0.000494	3PH HT AB CABLE REPLACEMENT
1421	07-01-2026	Part of : OM VIHAR PHASE 5 HASTSAL	3035	Other Outage	Planned Outage	07-01-2026	11:57	07-01-2026	14:42	2:45	0.000000	LT CIRCUIT MAINTENANCE
1422	08-01-2026	Part of : BLOCK A RAMA PARK,BLOCK B,D & E BHAGWATI GARDEN NAWADA	1634	Other Outage	Planned Outage	08-01-2026	12:26	08-01-2026	14:33	2:07	0.000000	REPLACEMENT OF HT BUSHING ROD
1423	08-01-2026	Part of : BLOCK B1 SEWAK PARK DWARKA	904	Other Outage	Planned Outage	08-01-2026	12:27	08-01-2026	14:32	2:05	0.000694	DT REPLACEMENT
1424	08-01-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	522	Other Outage	Planned Outage	08-01-2026	11:37	08-01-2026	13:51	2:14	0.000744	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
1425	08-01-2026	Part of : PHASE 1 OM VIHAR NAWADA	232	Other Outage	Planned Outage	08-01-2026	12:09	08-01-2026	14:29	2:20	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1426	09-01-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA	1528	Other Outage	Planned Outage	09-01-2026	14:35	09-01-2026	16:37	2:02	0.001694	MAINTENANCE OF HVDS
1427	09-01-2026	Part of : BLOCK H BHAGWATI GARDEN NAWADA,	852	Other Outage	Planned Outage	09-01-2026	12:48	09-01-2026	16:36	3:48	0.000000	MAINTENANCE OF TRANSFORMER
1428	09-01-2026	Part of : MOHAN GARDEN NAWADA,PHASE 1 OM VIHAR NAWADA,	1374	Other Outage	Planned Outage	09-01-2026	11:10	09-01-2026	14:01	2:51	0.002375	MAINTENANCE OF HVDS

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						Remarks
						From		To		Duration	Unservd (MU) due to outage	
						Date	Time	Date	Time			
1429	09-01-2026	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK P MOHAN GARDEN RAZAPUR KHURD,	1366	Other Outage	Planned Outage	09-01-2026	11:22	09-01-2026	14:00	2:38	0.000439	MAINTENANCE OF HVDS
1430	10-01-2026	PART OF : BLOCK K 5 ZAILDAR ENCLAVE HASTSAL	1580	Other Outage	Planned Outage	10-01-2026	13:44	10-01-2026	16:54	3:10	0.001056	3PH HT AB CABLE REPLACEMENT PER SPAN
1431	10-01-2026	PART OF : BLOCK D BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA	1571	Other Outage	Planned Outage	10-01-2026	12:00	10-01-2026	15:14	3:14	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1432	10-01-2026	PART OF : BLOCK B SEWAK PARK DWARKA	1373	Other Outage	Planned Outage	10-01-2026	12:46	10-01-2026	15:17	2:31	0.000839	DT REPLACEMENT
1433	10-01-2026	PART OF : BLOCK WE MOHAN GARDEN RAZAPUR KHURD	967	Other Outage	Planned Outage	10-01-2026	11:27	10-01-2026	13:47	2:20	0.000000	REPLACEMENT OF HT BUSHING ROD
1434	12-01-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	1184	Other Outage	Planned Outage	12-01-2026	15:55	12-01-2026	16:17	0:22	0.000122	CONDUCTOR REPLACEMENT PER SPAN
1435	12-01-2026	Part of : RAZA PUR KHURD VIKAS NAGAR,BLOCK WE MOHAN GARDEN	1473	Other Outage	Planned Outage	12-01-2026	15:21	12-01-2026	15:50	0:29	0.000081	3PH HT AB CABLE REPLACEMENT PER SPAN
1436	12-01-2026	Part of : NAWADA EXTENSION,BLOCK A & B MAHAVIR ENCLAVE NAWADA	2118	Other Outage	Planned Outage	12-01-2026	15:26	12-01-2026	16:16	0:50	0.000694	3PH HT AB CABLE REPLACEMENT PER SPAN
1437	12-01-2026	Part of : BLOCK B MAHAVIR ENCLAVE,BLOCK F ZAILDAR ENCLAVE,NAWADA EXTENSION	1507	Other Outage	Planned Outage	12-01-2026	12:06	12-01-2026	14:32	2:26	0.002028	3PH HT AB CABLE REPLACEMENT PER SPAN
1438	12-01-2026	Part of : BLOCK B SEWAK PARK DWARKA	1375	Other Outage	Planned Outage	12-01-2026	12:00	12-01-2026	14:04	2:04	0.000689	DT REPLACEMENT
1439	12-01-2026	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD	904	Other Outage	Planned Outage	12-01-2026	11:37	12-01-2026	14:10	2:33	0.000425	3PH HT AB CABLE REPLACEMENT PER SPAN
1440	12-01-2026	Part of : BLOCK D,EH & L BHAGWATI GARDEN NAWADA	2660	Other Outage	Planned Outage	12-01-2026	11:59	12-01-2026	14:11	2:12	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1441	13-01-2026	Part of : MOHAN GARDEN NAWADA,PHASE 1 OM VIHAR NAWADA	1374	Other Outage	Planned Outage	13-01-2026	16:27	13-01-2026	16:48	0:21	0.000292	3PH HT AB CABLE REPLACEMENT PER SPAN
1442	13-01-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK B, D, E & L BHAGWATI GARDEN NAWADA	6151	Other Outage	Planned Outage	13-01-2026	12:06	13-01-2026	14:05	1:59	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1443	13-01-2026	Part of : BLOCK B1 SEWAK PARK DWARKA	905	Other Outage	Planned Outage	13-01-2026	12:50	13-01-2026	13:59	1:09	0.000383	DT REPLACEMENT
1444	13-01-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	1270	Other Outage	Planned Outage	13-01-2026	14:13	13-01-2026	16:47	2:34	0.000428	3PH HT AB CABLE REPLACEMENT PER SPAN
1445	13-01-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA	1528	Other Outage	Planned Outage	13-01-2026	12:17	13-01-2026	14:54	2:37	0.002181	3PH HT AB CABLE REPLACEMENT PER SPAN
1446	13-01-2026	Part of : BLOCK L BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA	2661	Other Outage	Planned Outage	13-01-2026	11:35	13-01-2026	14:03	2:28	0.000822	CONDUCTOR REPLACEMENT PER SPAN
1447	13-01-2026	Part of : BLOCK RK MOHAN GARDEN RAZAPUR KHURD,BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK W MOHAN GARDEN RAZAPUR KHURD	1939	Other Outage	Planned Outage	13-01-2026	11:11	13-01-2026	14:06	2:55	0.000486	3PH HT AB CABLE REPLACEMENT PER SPAN
1448	14-01-2026	Part of : R 5 BLOCK MOHAN GARDEN RAZAPUR KHURD	532	Other Outage	Planned Outage	14-01-2026	15:24	14-01-2026	16:54	1:30	0.000250	REPLACEMENT OF LT BUSHING ROD
1449	14-01-2026	Part of : H BLOCK BHAGWATI GARDEN NAWADA	852	Other Outage	Planned Outage	14-01-2026	13:12	14-01-2026	15:36	2:24	0.000000	HVDS HT AB CABLE REPLACEMENT
1450	14-01-2026	Part of : PHASE 2 OM VIHAR NAWADA	778	Other Outage	Planned Outage	14-01-2026	12:14	14-01-2026	15:35	3:21	0.001117	LT CIRCUIT CONDUCTOR REPLACEMENT
1451	14-01-2026	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD	734	Other Outage	Planned Outage	14-01-2026	12:05	14-01-2026	15:12	3:07	0.000000	LT CIRCUIT DB REPLACEMENT
1452	15-01-2026	Part of : BLOCK R,RK & WE-MOHAN GARDEN RAZAPUR KHURD	1041	Other Outage	Planned Outage	15-01-2026	15:04	15-01-2026	15:46	0:42	0.000117	3PH HT AB CABLE REPLACEMENT
1453	15-01-2026	Part of : BLOCK D & H BHAGWATI GARDEN NAWADA	1571	Other Outage	Planned Outage	15-01-2026	12:59	15-01-2026	15:30	2:31	0.000000	3PH HT AB CABLE REPLACEMENT
1454	15-01-2026	Part of : RAZA PUR KHURD VIKAS NAGAR,BLOCK WE & RK MOHAN GARDEN RAZAPUR KHURD	2280	Other Outage	Planned Outage	15-01-2026	12:15	15-01-2026	15:04	2:49	0.000939	1PH HT AB END TERMINATION REPLACEMENT
1455	15-01-2026	Part of : BLOCK B SEWAK PARK DWARKA	1375	Other Outage	Planned Outage	15-01-2026	11:44	15-01-2026	14:58	3:14	0.001078	DT REPLACEMENT
1456	15-01-2026	Part of : NAWADA EXTENSION	505	Other Outage	Planned Outage	15-01-2026	12:01	15-01-2026	14:55	2:54	0.000000	LT CIRCUIT MAINTENANCE
1457	16-01-2026	Part of : S BLOCK NEAR GANDHI CHOWK,R3 B MOHAN GARDEN, SAINIK ENCLAVE SECTOR 2	8808	Other Outage	Unplanned Outage	16-01-2026	15:05	16-01-2026	16:01	0:56	0.000000	CABLE FAULT
1458	16-01-2026	Part of : RISHI APARTMENT	2660	Other Outage	Planned Outage	16-01-2026	12:16	16-01-2026	13:33	1:17	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1459	16-01-2026	Part of : POCKET 1 SECTOR B VASANT KUNJ	3481	Other Outage	Planned Outage	16-01-2026	12:14	16-01-2026	13:33	1:19	0.000439	DT REPLACEMENT
1460	16-01-2026	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD	129	Other Outage	Planned Outage	16-01-2026	15:00	16-01-2026	17:16	2:16	0.000756	CONDUCTOR REPLACEMENT PER SPAN
1461	16-01-2026	Part of : BLOCK RK & WE MOHAN GARDEN RAZAPUR KHURD	817	Other Outage	Planned Outage	16-01-2026	12:01	16-01-2026	14:49	2:48	0.000467	3PH HT AB CABLE REPLACEMENT PER SPAN
1462	16-01-2026	Part of : BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK F ZAILDAR ENCLAVE NAWADA	1507	Other Outage	Planned Outage	16-01-2026	12:25	16-01-2026	14:52	2:27	0.002042	3PH HT AB CABLE REPLACEMENT PER SPAN
1463	17-01-2026	Part of : A,E & L BLOCK RAMA PARK BHAGWATI GARDEN NAWADA	1528	Other Outage	Planned Outage	17-01-2026	14:02	17-01-2026	16:55	2:53	0.002403	MAINTENANCE OF HVDS CIRCUIT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1464	17-01-2026	Part of : B BLOCK SEWAK PARK DWARKA	1376	Other Outage	Planned Outage	17-01-2026	12:39	17-01-2026	15:56	3:17	0.001094	MAINTENANCE OF TRANSFORMER
1465	17-01-2026	Part of : L BLOCK BHAGWATI GARDEN NAWADA	1533	Other Outage	Planned Outage	17-01-2026	12:32	17-01-2026	15:09	2:37	0.000872	MAINTENANCE OF HVDS CIRCUIT
1466	17-01-2026	Part of : PHASE 2 OM VIHAR NAWADA	980	Other Outage	Planned Outage	17-01-2026	12:39	17-01-2026	15:08	2:29	0.000828	MAINTENANCE OF TRANSFORMER
1467	17-01-2026	Part of : MOHAN GARDEN NAWADA,PHASE 1 OM VIHAR NAWADA	1374	Other Outage	Planned Outage	17-01-2026	11:04	17-01-2026	13:51	2:47	0.002319	MAINTENANCE OF HVDS CIRCUIT
1468	17-01-2026	Part of : R 5 BLOCK MOHAN GARDEN RAZAPUR KHURD	424	Other Outage	Planned Outage	17-01-2026	11:08	17-01-2026	13:52	2:44	0.000456	MAINTENANCE OF TRANSFORMER
1469	19-01-2026	Part of : H-BLOCK BHAGWATI GARDEN NAWADA,R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	4215	Other Outage	Unplanned Outage	19-01-2026	16:49	19-01-2026	17:44	0:55	0.000769	CABLE FAULT
1470	19-01-2026	Part of : MOHAN GARDEN	2661	Other Outage	Planned Outage	19-01-2026	15:38	19-01-2026	17:43	2:05	0.000000	3PH HT AB CABLE REPLACEMENT
1471	19-01-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL	1431	Other Outage	Planned Outage	19-01-2026	11:32	19-01-2026	14:01	2:29	0.000828	1PH HT AB CABLE REPLACEMENT,DB REVAMPING,DT REPLACEMET PER DT
1472	19-01-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	2623	Other Outage	Planned Outage	19-01-2026	11:13	19-01-2026	14:00	2:47	0.000464	3PH HT AB CABLE REPLACEMENT
1473	19-01-2026	Part of : BLOCK B SEWAK PARK DWARKA	1383	Other Outage	Planned Outage	19-01-2026	11:39	19-01-2026	14:07	2:28	0.000822	DT REPLACEMENT
1474	19-01-2026	Part of : BLOCK B1 SEWAK PARK DWARKA	905	Other Outage	Planned Outage	19-01-2026	11:46	19-01-2026	14:08	2:22	0.000789	DT REPLACEMENT
1475	20-01-2026	Part of : BLOCK A MAHAVIR ENCLAVE NAWADA	889	Other Outage	Unplanned Outage	20-01-2026	12:32	20-01-2026	13:48	1:16	0.000422	REPAIR OF RMU
1476	20-01-2026	Part of : BLOCK A MAHAVIR ENCLAVE NAWADA	389	Other Outage	Unplanned Outage	20-01-2026	11:05	20-01-2026	12:40	1:35	0.000528	REPAIR OF RMU
1477	20-01-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E & L BHAGWATI GARDEN NAWADA	1528	Other Outage	Planned Outage	20-01-2026	15:20	20-01-2026	16:42	1:22	0.001139	3PH HT AB CABLE REPLACEMENT PER SPAN
1478	20-01-2026	Part of : LAXMI VIHAR NAWADA	965	Other Outage	Planned Outage	20-01-2026	15:18	20-01-2026	16:42	1:24	0.000467	CONDUCTOR REPLACEMENT PER SPAN
1479	20-01-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA	1939	Other Outage	Planned Outage	20-01-2026	12:18	20-01-2026	13:46	1:28	0.000489	CONDUCTOR REPLACEMENT PER SPAN
1480	20-01-2026	Part of : BLOCK A SEWAK PARK DWARKA	491	Other Outage	Planned Outage	20-01-2026	15:19	20-01-2026	16:40	1:21	0.000000	3PH DB REVAMPING
1481	20-01-2026	Part of : RAZA PUR KHURD VIKAS NAGAR,RAZAPUR KHURD	1435	Other Outage	Planned Outage	20-01-2026	14:06	20-01-2026	16:41	2:35	0.000431	3PH HT AB CABLE REPLACEMENT PER SPAN
1482	20-01-2026	Part of : MOHAN GARDEN NAWADA,PHASE 1 OM VIHAR NAWADA	1374	Other Outage	Planned Outage	20-01-2026	11:20	20-01-2026	13:45	2:25	0.002014	3PH HT AB CABLE REPLACEMENT PER SPAN
1483	20-01-2026	Part of : BLOCK K 7 ZAILDAR ENCLAVE HASTSAL	1584	Other Outage	Planned Outage	20-01-2026	11:32	20-01-2026	13:44	2:12	0.000733	DT REPLACEMET PER DT
1484	20-01-2026	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD	1173	Other Outage	Planned Outage	20-01-2026	11:05	20-01-2026	13:45	2:40	0.000889	DT REPLACEMET PER DT
1485	21-01-2026	Part of : PHASE 2 OM VIHAR NAWADA,	796	Other Outage	Unplanned Outage	21-01-2026	14:56	21-01-2026	15:57	1:01	0.000000	REPAIRING OF LT RMU
1486	21-01-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA	1536	Other Outage	Unplanned Outage	21-01-2026	14:07	21-01-2026	15:33	1:26	0.000000	REPAIRING OF RMU
1487	21-01-2026	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK N 1 MOHAN GARDEN RAZAPUR KHURD	2926	Other Outage	Unplanned Outage	21-01-2026	14:00	21-01-2026	15:32	1:32	0.000256	REPAIRING OF HVDS CIRCUIT
1488	21-01-2026	Part of : PHASE 2 OM VIHAR NAWADA,	550	Other Outage	Planned Outage	21-01-2026	11:41	21-01-2026	13:40	1:59	0.000000	LT TRANSFORMER MAINTENANCE
1489	21-01-2026	Part of : BLOCK D MANSARA RAM PARK UTTAM NAGAR,	1404	Other Outage	Planned Outage	21-01-2026	12:24	21-01-2026	14:45	2:21	0.000000	LT CIRCUIT MAINTENANCE
1490	21-01-2026	Part of : RAZA PUR KHURD VIKAS NAGAR,	1158	Other Outage	Planned Outage	21-01-2026	11:33	21-01-2026	13:44	2:11	0.000364	TRANSFORMER MAINTENANCE
1491	22-01-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	2624	Other Outage	Planned Outage	22-01-2026	14:58	22-01-2026	17:31	2:33	0.000850	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
1492	22-01-2026	Part of : BLOCK L BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA	2662	Other Outage	Planned Outage	22-01-2026	14:55	22-01-2026	17:28	2:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1493	22-01-2026	Part of : PHASE 1 OM VIHAR NAWADA	1008	Other Outage	Planned Outage	22-01-2026	15:03	22-01-2026	17:32	2:29	0.000828	3PH HT AB CABLE REPLACEMENT PER SPAN
1494	22-01-2026	Part of : BLOCK B SEWAK PARK DWARKA	1384	Other Outage	Planned Outage	22-01-2026	12:01	22-01-2026	14:55	2:54	0.000000	REPLACEMENT OF LT BUSHING ROD
1495	22-01-2026	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK P MOHAN GARDEN RAZAPUR KHURD	1366	Other Outage	Planned Outage	22-01-2026	12:32	22-01-2026	14:56	2:24	0.000400	3PH HT AB CABLE REPLACEMENT PER SPAN
1496	22-01-2026	Part of : PHASE 1 OM VIHAR NAWADA	1008	Other Outage	Planned Outage	22-01-2026	10:57	22-01-2026	13:56	2:59	0.000994	3PH HT AB END TERMINATION REPLACEMENT
1497	23-01-2026	Part of : R3 B MOHAN GARDEN,SHIV SHAKTI,K-5 EXTN NEAR DIWEDI OFFICE,RAHUL CHOWK,CHANDNI FARM DRY	6661	Other Outage	Unplanned Outage	23-01-2026	08:09	23-01-2026	09:01	0:52	0.001170	CABLE FAULT
1498	23-01-2026	Part of : RK & WE-BLOCK MOHAN GARDEN RAZAPUR KHURD	827	Other Outage	Unplanned Outage	23-01-2026	13:54	23-01-2026	15:09	1:15	0.000417	REPAIRING OF HVDS CABLE
1499	23-01-2026	Part of : OM VIHAR PHASE 1 NAWADA	765	Other Outage	Unplanned Outage	23-01-2026	13:40	23-01-2026	15:07	1:27	0.000000	REPAIRING OF HVDS CABLE
1500	23-01-2026	Part of : R-BLOCK MOHAN GARDEN,RAZAPUR KHURD	1439	Other Outage	Planned Outage	23-01-2026	15:46	23-01-2026	16:45	0:59	0.000328	3PH HT AB CABLE REPLACEMENT
1501	24-01-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA	1528	Other Outage	Planned Outage	24-01-2026	14:47	24-01-2026	16:32	1:45	0.001458	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1502	24-01-2026	Part of : BLOCK E & H BHAGWATI GARDEN NAWADA	2660	Other Outage	Planned Outage	24-01-2026	12:45	24-01-2026	15:31	2:46	0.000922	CONDUCTOR REPLACEMENT PER SPAN
1503	24-01-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL	1430	Other Outage	Planned Outage	24-01-2026	11:20	24-01-2026	14:03	2:43	0.000906	3PH HT AB CABLE REPLACEMENT PER SPAN
1504	24-01-2026	Part of : BLOCK N 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL	2908	Other Outage	Planned Outage	24-01-2026	11:25	24-01-2026	14:02	2:37	0.000436	3PH HT AB CABLE REPLACEMENT PER SPAN
1505	24-01-2026	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	1173	Other Outage	Planned Outage	24-01-2026	14:18	24-01-2026	16:34	2:16	0.000756	3PH HT AB CABLE REPLACEMENT PER SPAN
1506	24-01-2026	Part of : BLOCK B SEWAK PARK DWARKA	1367	Other Outage	Planned Outage	24-01-2026	12:38	24-01-2026	15:32	2:54	0.000000	REPLACEMENT OF LT BUSHING ROD
1507	25-01-2026	Part of : BLOCK B1 SEWAK PARK DWARKA	905	Other Outage	Unplanned Outage	25-01-2026	13:19	25-01-2026	14:37	1:18	0.000433	REPAIRING OF LT ACB
1508	25-01-2026	Part of : PHASE 2 OM VIHAR NAWADA	980	Other Outage	Unplanned Outage	25-01-2026	12:32	25-01-2026	14:04	1:32	0.000000	LAYING OF NEW LTAB
1509	25-01-2026	Part of : PHASE 2 OM VIHAR NAWADA	980	Other Outage	Unplanned Outage	25-01-2026	10:27	25-01-2026	11:46	1:19	0.000000	REPAIRING OF LTAB CIRCUIT
1510	27-01-2026	Part of : R,R 1,R 5,N 1,P 2 & S-BLOCK MOHAN GARDEN RAZAPUR KHURD,M-BLOCK ZAILDAR ENCLAVE HASTSAL	5140	Other Outage	Unplanned Outage	27-01-2026	02:55	27-01-2026	03:28	0:33	0.000000	CABLE FAULT
1511	27-01-2026	Part of : D,H,R & L-BLOCK BHAGWATI GARDEN NAWADA	2659	Other Outage	Planned Outage	27-01-2026	14:51	27-01-2026	17:51	3:00	0.001000	HT CONDUCTOR REPLACEMENT
1512	27-01-2026	Part of : BLOCK B SEWAK PARK DWARKA	1387	Other Outage	Planned Outage	27-01-2026	14:49	27-01-2026	17:36	2:47	0.000928	REPLACEMET OF HT BUSHING ROD
1513	27-01-2026	Part of : OM VIHAR PHASE 2 NAWADA	1329	Other Outage	Planned Outage	27-01-2026	12:59	27-01-2026	15:34	2:35	0.000861	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1514	27-01-2026	Part of : VIPIN GARDEN EXTENSION NAWADA	1130	Other Outage	Planned Outage	27-01-2026	14:52	27-01-2026	17:35	2:43	0.000000	LT CIRCUIT MAINTENANCE
1515	27-01-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	880	Other Outage	Planned Outage	27-01-2026	12:09	27-01-2026	14:32	2:23	0.000000	LT CIRCUIT MAINTENANCE
1516	28-01-2026	Part of : BLOCK R,RK & WE MOHAN GARDEN RAZAPUR KHURD	1041	Other Outage	Planned Outage	28-01-2026	14:09	28-01-2026	16:16	2:07	0.000353	3PH HT AB CABLE REPLACEMENT PER SPAN
1517	28-01-2026	Part of : BLOCK B SEWAK PARK DWARKA	1387	Other Outage	Planned Outage	28-01-2026	14:03	28-01-2026	16:18	2:15	0.000750	REPLACEMENT OF LT BUSHING ROD
1518	28-01-2026	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD	897	Other Outage	Planned Outage	28-01-2026	10:58	28-01-2026	13:44	2:46	0.000461	3PH HT AB CABLE REPLACEMENT PER SPAN
1519	28-01-2026	Part of : BHAGWATI GARDEN NAWADA	130	Other Outage	Planned Outage	28-01-2026	11:20	28-01-2026	14:05	2:45	0.000000	3PH DB REVAMPING
1520	29-01-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA,JAI BHARAT ENCLAVE BHAGWATI GARDEN NAWADA,ROSHAN GARDEN BHAGWATI GARDEN NAWADA	3023	Other Outage	Unplanned Outage	29-01-2026	10:34	29-01-2026	11:01	0:27	0.000042	CABLE FAULT
1521	29-01-2026	Part of : PHASE 2 OM VIHAR NAWADA,	980	Other Outage	Planned Outage	29-01-2026	14:00	29-01-2026	15:53	1:53	0.000628	REPLACEMENT OF LT BUSHING ROD
1522	29-01-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	1	Other Outage	Planned Outage	29-01-2026	11:52	29-01-2026	14:55	3:03	0.000000	REPLACEMET OF HT BUSHING ROD
1523	29-01-2026	Part of : BLOCK H BHAGWATI GARDEN NAWADA,	857	Other Outage	Planned Outage	29-01-2026	12:00	29-01-2026	14:32	2:32	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1524	30-01-2026	Part of : BLOCK H BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA	16	Other Outage	Unplanned Outage	30-01-2026	11:31	30-01-2026	12:55	1:24	0.000700	REPAIRING OF HVDS CIRCUIT
1525	30-01-2026	Part of : BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK F ZAILDAR ENCLAVE NAWADA,NAWADA EXTENSION NAWADA	1507	Other Outage	Planned Outage	30-01-2026	11:09	30-01-2026	14:06	2:57	0.002458	3PH HT AB CABLE REPLACEMENT PER SPAN
1526	30-01-2026	Part of : RAZAPUR KHURD,SAI& SETHI ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE	872	Other Outage	Planned Outage	30-01-2026	11:32	30-01-2026	15:17	3:45	0.000625	3PH HT AB CABLE REPLACEMENT PER SPAN
1527	31-01-2026	Part of : B-BLOCK BHAGWATI GARDEN NAWADA	1350	Other Outage	Unplanned Outage	31-01-2026	12:06	31-01-2026	13:53	1:47	0.000743	LAYING OF NEW LTAB
1528	31-01-2026	Part of : B-BLOCK BHAGWATI GARDEN NAWADA	1940	Other Outage	Planned Outage	31-01-2026	12:07	31-01-2026	13:52	1:45	0.000000	REPLACEMENT OF HT BUSHING ROD
1529	31-01-2026	Part of : RAZA PUR KHURD VIKAS NAGAR,RK & WE-BLOCK WE MOHAN GARDEN	2292	Other Outage	Planned Outage	31-01-2026	13:01	31-01-2026	15:41	2:40	0.000444	3PH HT AB CABLE REPLACEMENT
1530	31-01-2026	Part of : OM VIHAR PHASE 2 NAWADA	1329	Other Outage	Planned Outage	31-01-2026	11:01	31-01-2026	13:52	2:51	0.000950	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1531	31-01-2026	Part of : OM VIHAR PHASE 1 NAWADA	1008	Other Outage	Planned Outage	31-01-2026	11:30	31-01-2026	13:53	2:23	0.000794	3PH DB REPLACEMENT
1532	01-01-2026	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI	1649	Other Outage	Unplanned Outage	01-01-2026	05:01	01-01-2026	06:39	1:38	0.001388	TRANSIENT FAULT
1533	02-01-2026	Part of : BHERA ENCLAVE PASCHIM VIHAR	131	Other Outage	Planned Outage	02-01-2026	14:44	02-01-2026	16:15	1:31	0.000000	REPLACEMENT OF HT BUSHING ROD
1534	02-01-2026	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	107	Other Outage	Planned Outage	02-01-2026	11:09	02-01-2026	14:47	3:38	0.000000	REPLACEMENT OF HT BUSHING ROD
1535	02-01-2026	Part of : NANGLOI SAIYED VILLAGE PASCHIM VIHAR	609	Other Outage	Planned Outage	02-01-2026	11:38	02-01-2026	14:48	3:10	0.000000	REPLACEMENT OF LT BUSHING ROD
1536	02-01-2026	Part of : CHANDER VIHAR	674	Other Outage	Planned Outage	02-01-2026	11:33	02-01-2026	14:50	3:17	0.000000	REPLACEMENT OF HT BUSHING ROD
1537	02-01-2026	Part of : BLOCK D VANDANA VIHAR NANGLOI	1185	Other Outage	Planned Outage	02-01-2026	11:03	02-01-2026	14:45	3:42	0.000925	REPLACEMENT OF LT BUSHING ROD
1538	03-01-2026	Part of : B-BLOCK AMANPURI KAMRUDDIN NAGAR,A-BLOCK A,B & - NARESH PARK EXTENSION NANGLOI	3979	Other Outage	Unplanned Outage	03-01-2026	07:49	03-01-2026	08:31	0:42	0.000327	HT POLE BROKEN BY UNKNOWN VEHICLE
1539	03-01-2026	Part of : TILANGPUR KOTLA VILLAGE	543	Other Outage	Planned Outage	03-01-2026	11:29	03-01-2026	13:22	1:53	0.000785	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						Remarks
						From		To		Duration	Unservd (MU) due to outage	
						Date	Time	Date	Time			
1540	03-01-2026	Part of : PIRA GARHI VILLAGE ,BHERA ENCLAVE PASCHIM VIHAR,NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR,	1027	Other Outage	Planned Outage	03-01-2026	11:29	03-01-2026	14:03	2:34	0.000000	REPLACEMENT OF HT BUSHING ROD
1541	03-01-2026	Part of : RANHOLLA	143	Other Outage	Planned Outage	03-01-2026	10:26	03-01-2026	14:03	3:37	0.000603	REPLACEMENT OF HT BUSHING ROD
1542	03-01-2026	Part of : BLOCK D VANDANA VIHAR NANGLOI	1534	Other Outage	Planned Outage	03-01-2026	12:38	03-01-2026	15:01	2:23	0.000397	LT CIRCUIT MAINTENANCE
1543	04-01-2026	Part of : UDYOG NAGAR MANGOLPURI	20	Other Outage	Planned Outage	04-01-2026	13:48	04-01-2026	16:12	2:24	0.000000	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS,REPLACEMET OF FAULTY END BOX
1544	04-01-2026	Part of : UDYOG NAGAR MANGOLPURI	11	Other Outage	Planned Outage	04-01-2026	11:07	04-01-2026	13:44	2:37	0.000000	JUMPER REPLACEMENT PER POLE, TAPPING OF UG CABLE TO OH JUMPER CONNECTION
1545	04-01-2026	Part of : NANGLOI JAT,POCKET A NARESH PARK NANGLOI	472	Other Outage	Planned Outage	04-01-2026	11:38	04-01-2026	13:48	2:10	0.000000	GUARD WIRES SAGGING PER SPAN
1546	04-01-2026	Part of : BLOCK A & B NARESH PARK EXTENSION,BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI	4219	Other Outage	Planned Outage	04-01-2026	11:43	04-01-2026	13:45	2:02	0.000000	GUARD WIRES SAGGING PER SPAN
1547	05-01-2026	Part of : UDAI VIHAR,RANJEET VIHAR,	1665	Other Outage	Planned Outage	05-01-2026	14:23	05-01-2026	16:05	1:42	0.001133	MAINTENANCE OF RMU
1548	05-01-2026	Part of : BLOCK NS MIYANWALI NAGAR PASCHIM VIHAR,	307	Other Outage	Planned Outage	05-01-2026	13:40	05-01-2026	15:59	2:19	0.000386	MAINTENANCE OF LT TRANSFORMER
1549	05-01-2026	Part of : BLOCK L JJ COLONY 3 NANGLOI,	861	Other Outage	Planned Outage	05-01-2026	12:23	05-01-2026	15:56	3:33	0.000592	MAINTENANCE OF RMU
1550	05-01-2026	Part of : BLOCK GH 8 PASCHIM VIHAR,	197	Other Outage	Planned Outage	05-01-2026	10:37	05-01-2026	13:44	3:07	0.000519	MAINTENANCE OF LT TRANSFORMER
1551	05-01-2026	Part of : BLOCK GH5 PASCHIM VIHAR,	615	Other Outage	Planned Outage	05-01-2026	10:27	05-01-2026	13:43	3:16	0.000544	MAINTENANCE OF LT TRANSFORMER
1552	05-01-2026	Part of : RAJIV RATAN AWAS FLATS,	113	Other Outage	Planned Outage	05-01-2026	11:08	05-01-2026	13:43	2:35	0.000431	MAINTENANCE OF LT TRANSFORMER
1553	05-01-2026	Part of : BLOCK GH 14 PASCHIM VIHAR,	107	Other Outage	Planned Outage	05-01-2026	11:11	05-01-2026	13:44	2:33	0.000425	MAINTENANCE OF LT TRANSFORMER
1554	06-01-2026	Part of : NARESH PARK NANGLOI,NANGLOI JAT NANGLOI,POCKET A NARESH PARK NANGLOI	467	Other Outage	Unplanned Outage	06-01-2026	17:40	06-01-2026	18:16	0:36	0.001670	CABLE FAULT
1555	06-01-2026	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR,NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	1150	Other Outage	Planned Outage	06-01-2026	11:35	06-01-2026	14:13	2:38	0.000000	GUARD WIRES SAGGING PER SPAN
1556	06-01-2026	Part of : RANHOLLA	143	Other Outage	Planned Outage	06-01-2026	10:36	06-01-2026	14:15	3:39	0.000000	REPLACEMENT OF HT BUSHING ROD
1557	06-01-2026	Part of : ADHYAPAK NAGAR NANGLOI	1037	Other Outage	Planned Outage	06-01-2026	11:14	06-01-2026	14:14	3:00	0.000000	REPLACEMENT OF HT BUSHING ROD
1558	06-01-2026	Part of : CAMP 5 JAWALAPURI PASCHIM VIHAR	680	Other Outage	Planned Outage	06-01-2026	10:53	06-01-2026	13:55	3:02	0.000000	REPLACEMENT OF HT BUSHING ROD
1559	06-01-2026	Part of : JAI VIHAR PH-1, PH-3	818	Other Outage	Planned Outage	06-01-2026	10:58	06-01-2026	13:55	2:57	0.000000	REPLACEMENT OF HT BUSHING ROD
1560	07-01-2026	Part of : PIRA GARHI VILLAGE,EKTA ENCLAVE,NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	1308	Other Outage	Unplanned Outage	07-01-2026	17:50	07-01-2026	18:39	0:49	0.000490	CABLE FAULT
1561	07-01-2026	Part of : GH 6 WHITE APPARTMENTS PASCHIM VIHAR	197	Other Outage	Planned Outage	07-01-2026	13:14	07-01-2026	15:08	1:54	0.000317	LT CIRCUIT MAINTENANCE
1562	07-01-2026	Part of : BLOCK A 3 MIYANWALI NAGAR PASCHIM VIHAR	225	Other Outage	Planned Outage	07-01-2026	12:15	07-01-2026	15:00	2:45	0.000917	REPLACEMENT OF HT BUSHING ROD
1563	07-01-2026	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	712	Other Outage	Planned Outage	07-01-2026	11:29	07-01-2026	14:07	2:38	0.000219	LT CIRCUIT MAINTENANCE
1564	07-01-2026	Part of : DASS GARDEN	602	Other Outage	Planned Outage	07-01-2026	11:11	07-01-2026	13:39	2:28	0.000617	LT CIRCUIT MAINTENANCE
1565	08-01-2026	Part of : BLOCK X JJ COLONY 3 NANGLOI	909	Other Outage	Planned Outage	08-01-2026	11:04	08-01-2026	13:56	2:52	0.001194	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1566	08-01-2026	Part of : TEK CHAND COLONY	831	Other Outage	Planned Outage	08-01-2026	10:54	08-01-2026	13:54	3:00	0.001000	REPLACEMENT OF LT BUSHING ROD
1567	08-01-2026	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	1716	Other Outage	Planned Outage	08-01-2026	11:23	08-01-2026	13:53	2:30	0.000833	REPLACEMENT OF HT BUSHING ROD
1568	09-01-2026	Part of : BLOCK A JAWALAPURI PASCHIM VIHAR,	974	Other Outage	Planned Outage	09-01-2026	12:25	09-01-2026	13:43	1:18	0.000217	MAINTENANCE OF LT TRANSFORMER
1569	09-01-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,	1142	Other Outage	Planned Outage	09-01-2026	11:06	09-01-2026	15:07	4:01	0.000669	MAINTENANCE OF LT TRANSFORMER
1570	09-01-2026	Part of : AMBIKA VIHAR PASCHIM VIHAR,	386	Other Outage	Planned Outage	09-01-2026	10:17	09-01-2026	15:06	4:49	0.000803	MAINTENANCE OF LT CIRCUIT
1571	09-01-2026	Part of : RANHOLLA,	143	Other Outage	Planned Outage	09-01-2026	11:01	09-01-2026	13:41	2:40	0.000444	MAINTENANCE OF LT TRANSFORMER
1572	09-01-2026	Part of : RAJIV RATAN AWAS FLATS,	171	Other Outage	Planned Outage	09-01-2026	11:20	09-01-2026	15:07	3:47	0.000631	MAINTENANCE OF LT TRANSFORMER
1573	09-01-2026	Part of : BLOCK GH 8 PASCHIM VIHAR,	199	Other Outage	Planned Outage	09-01-2026	11:02	09-01-2026	15:06	4:04	0.000678	MAINTENANCE OF LT TRANSFORMER
1574	10-01-2026	Part of : RANHOLLA,JAI VIHAR PH-1, PH-3,PRATAP VIHAR,TILANGPUR KOTLA VILLAGE	1496	Other Outage	Unplanned Outage	10-01-2026	09:10	10-01-2026	09:53	0:43	0.000753	HT SYSTEM FAULT
1575	10-01-2026	Part of : RISHAL GARDEN,RANHOLLA,TILANGPUR KOTLA VILLAGE,TILANGPUR KOTLA,SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI	8353	Other Outage	Unplanned Outage	10-01-2026	09:10	10-01-2026	09:53	0:43	0.001171	HT SYSTEM FAULT
1576	10-01-2026	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI	1648	Other Outage	Unplanned Outage	10-01-2026	05:49	10-01-2026	06:41	0:52	0.000881	BIRDAGE
1577	10-01-2026	PART OF : BLOCK RR MIYANWALI NAGAR PASCHIM VIHAR	416	Other Outage	Planned Outage	10-01-2026	11:08	10-01-2026	14:50	3:42	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1578	10-01-2026	PART OF : PRASHANT ENCLAVE	995	Other Outage	Planned Outage	10-01-2026	11:07	10-01-2026	14:49	3:42	0.000000	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1579	10-01-2026	PART OF : BLOCK J JEEVAN NIKETAN PASCHIM VIHAR	125	Other Outage	Planned Outage	10-01-2026	11:05	10-01-2026	14:50	3:45	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1580	11-01-2026	Part of : A & B-BLOCK JAWALAPURI PASCHIM VIHAR,G-BLOCK NIHAL VIHAR,A-BLOCK VANDANA VIHAR,RAO VIHAR,HANUMAN ENCLAVE,SHIV VIHAR NANGLOI	9153	Other Outage	Unplanned Outage	11-01-2026	14:07	11-01-2026	14:45	0:38	0.000908	CABLE FAULT
1581	11-01-2026	Part of : A & B-BLOCK JAWALAPURI PASCHIM VIHAR,G-BLOCK NIHAL VIHAR,A-BLOCK VANDANA VIHAR,RAO VIHAR,HANUMAN ENCLAVE,SHIV VIHAR NANGLOI	9153	Other Outage	Unplanned Outage	11-01-2026	11:52	11-01-2026	12:38	0:46	0.001917	BIRDAGE
1582	11-01-2026	Part of : NANGLOI JAT NANGLOI	230	Other Outage	Planned Outage	11-01-2026	11:01	11-01-2026	16:45	5:44	0.001433	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1583	11-01-2026	Part of : UDYOG NAGAR MANGOLPURI	420	Other Outage	Planned Outage	11-01-2026	11:08	11-01-2026	13:44	2:36	0.002167	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1584	12-01-2026	Part of : UDYOG NAGAR MANGOLPURI	415	Other Outage	Unplanned Outage	12-01-2026	11:30	12-01-2026	11:56	0:26	0.001300	HT SYSTEM FAULT
1585	12-01-2026	Part of : TEK CHAND COLONY,CHANDER VIHAR,SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	2679	Other Outage	Planned Outage	12-01-2026	12:34	12-01-2026	13:31	0:57	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1586	12-01-2026	Part of : CHANDER VIHAR,RANJEET VIHAR,BLOCK G UDAY VIHAR 2 ADHYAPAK NAGAR NANGLOI	3330	Other Outage	Planned Outage	12-01-2026	12:33	12-01-2026	13:30	0:57	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1587	12-01-2026	Part of : UDAI VIHAR,RANJEET VIHAR	325	Other Outage	Planned Outage	12-01-2026	12:35	12-01-2026	13:32	0:57	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1588	12-01-2026	Part of : RANHOLLA	214	Other Outage	Planned Outage	12-01-2026	15:25	12-01-2026	16:45	1:20	0.000000	REPLACEMENT OF LT BUSHING ROD
1589	12-01-2026	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	712	Other Outage	Planned Outage	12-01-2026	14:09	12-01-2026	16:06	1:57	0.000650	REPLACEMET OF HT BUSHING ROD
1590	12-01-2026	Part of : BLOCK GH 8 PASCHIM VIHAR	207	Other Outage	Planned Outage	12-01-2026	11:17	12-01-2026	13:28	2:11	0.000728	REPLACEMET OF HT BUSHING ROD
1591	12-01-2026	Part of : RAIL NEER PLANT NANGLOI	835	Other Outage	Planned Outage	12-01-2026	10:54	12-01-2026	13:29	2:35	0.000861	REPLACEMET OF HT BUSHING ROD
1592	13-01-2026	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI,TILANGPUR KOTLA VILLAGE,RISHAL GARDEN,TILANGPUR KOTLA,RANHOLLA	8525	Other Outage	Unplanned Outage	13-01-2026	15:24	13-01-2026	16:15	0:51	0.001063	BIRDAGE
1593	13-01-2026	Part of : RANHOLLA	143	Other Outage	Planned Outage	13-01-2026	13:19	13-01-2026	15:24	2:05	0.000347	REPLACEMENT OF HT BUSHING ROD
1594	13-01-2026	Part of : DASS GARDEN	1079	Other Outage	Planned Outage	13-01-2026	13:57	13-01-2026	16:41	2:44	0.002278	REPLACEMENT OF LT BUSHING ROD
1595	13-01-2026	Part of : NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI	994	Other Outage	Planned Outage	13-01-2026	10:44	13-01-2026	14:02	3:18	0.001100	REPLACEMENT OF HT BUSHING ROD
1596	13-01-2026	Part of : BLOCK GH 12 PASCHIM VIHAR	115	Other Outage	Planned Outage	13-01-2026	11:01	13-01-2026	14:01	3:00	0.000400	REPLACEMENT OF LT BUSHING ROD
1597	13-01-2026	Part of : AMBIKA VIHAR PASCHIM VIHAR	386	Other Outage	Planned Outage	13-01-2026	11:01	13-01-2026	14:02	3:01	0.000603	REPLACEMENT OF LT BUSHING ROD
1598	14-01-2026	Part of : NANGLI VIHAR,JAI VIHAR BAPROLA,RANHOLLA	7990	Other Outage	Unplanned Outage	14-01-2026	10:40	14-01-2026	11:13	0:33	0.002745	HT SYSTEM FAULT
1599	14-01-2026	Part of : JAI VIHAR BAPROLA,JAI VIHAR PH-1, PH-3,BAPROLA VILLAGE,TILANGPUR KOTLA VILLAGE	6942	Other Outage	Planned Outage	14-01-2026	11:10	14-01-2026	11:11	0:01	0.000000	JUMPER REPLACEMENT & GUARD WIRES SAGGING PER SPAN
1600	14-01-2026	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	339	Other Outage	Planned Outage	14-01-2026	13:28	14-01-2026	15:11	1:43	0.000000	REPLACEMENT OF HT BUSHING ROD
1601	14-01-2026	Part of : NANGLOI JAT NANGLOI	627	Other Outage	Planned Outage	14-01-2026	11:01	14-01-2026	14:19	3:18	0.000000	REPLACEMENT OF HT BUSHING ROD
1602	14-01-2026	Part of : BLOCK J JEEVAN NIKETAN PASCHIM VIHAR	125	Other Outage	Planned Outage	14-01-2026	11:00	14-01-2026	14:16	3:16	0.000000	REPLACEMENT OF HT BUSHING ROD
1603	15-01-2026	Part of : SHIV VIHAR NANGLOI	1439	Other Outage	Planned Outage	15-01-2026	14:24	15-01-2026	16:32	2:08	0.000711	REPLACEMET OF HT BUSHING ROD
1604	15-01-2026	Part of : JAI VIHAR PH-1 & 3	4671	Other Outage	Planned Outage	15-01-2026	10:54	15-01-2026	12:56	2:02	0.001186	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1605	15-01-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR	34	Other Outage	Planned Outage	15-01-2026	12:49	15-01-2026	15:51	3:02	0.000253	LT CIRCUIT MAINTENANCE
1606	15-01-2026	Part of : HARPHOOL VIHAR	3327	Other Outage	Planned Outage	15-01-2026	12:43	15-01-2026	14:53	2:10	0.001444	LT CIRCUIT MAINTENANCE
1607	15-01-2026	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI	900	Other Outage	Planned Outage	15-01-2026	11:09	15-01-2026	14:05	2:56	0.000587	LT CIRCUIT MAINTENANCE
1608	15-01-2026	Part of : BLOCK A MIRA BAGH PASCHIM VIHAR	188	Other Outage	Planned Outage	15-01-2026	11:49	15-01-2026	14:02	2:13	0.000739	LT CIRCUIT MAINTENANCE
1609	16-01-2026	Part of : JWALLA PURI, UDYOG NAGAR	3	Other Outage	Unplanned Outage	16-01-2026	10:41	16-01-2026	11:18	0:37	0.000021	HT SYSTEM FAULT
1610	16-01-2026	Part of : SHIV VIHAR NANGLOI,VANDANA VIHAR NANGLOI,RAO VIHAR NANGLOI,HANUMAN ENCLAVE NANGLOI	6617	Other Outage	Unplanned Outage	16-01-2026	06:20	16-01-2026	07:06	0:46	0.001009	HT SYSTEM FAULT
1611	16-01-2026	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	391	Other Outage	Planned Outage	16-01-2026	15:33	16-01-2026	16:27	0:54	0.000000	REPLACEMET OF HT BUSHING ROD
1612	16-01-2026	Part of : BLOCK J 2 DEVLII SANGAM VIHAR	955	Other Outage	Planned Outage	16-01-2026	11:00	16-01-2026	13:30	2:30	0.000000	GUARD WIRES SAGGING PER SPAN
1613	16-01-2026	Part of : BLOCK C WEST END	1528	Other Outage	Planned Outage	16-01-2026	11:15	16-01-2026	13:32	2:17	0.000951	3PH HT AB CABLE REPLACEMENT PER SPAN
1614	16-01-2026	Part of : JAI VIHAR PH-1, PH-3	386	Other Outage	Planned Outage	16-01-2026	10:57	16-01-2026	13:36	2:39	0.000883	REPLACEMET OF HT BUSHING ROD
1615	16-01-2026	Part of : BLOCK H KESHOPUR INDUSTRIAL AREA VIKAS PURI	950	Other Outage	Planned Outage	16-01-2026	11:17	16-01-2026	13:34	2:17	0.000761	REPLACEMET OF HT BUSHING ROD
1616	17-01-2026	Part of : VIKASPURI EXTN,GRAM SABHA COLONY,TEACHER VIHAR,GURUNANAK VIHAR	2840	Other Outage	Planned Outage	17-01-2026	11:18	17-01-2026	11:42	0:24	0.000067	MAINTENANCE OF HT O/H CIRCUIT
1617	17-01-2026	Part of : CHANDER VIHAR	515	Other Outage	Planned Outage	17-01-2026	14:23	17-01-2026	16:23	2:00	0.000333	MAINTENANCE OF LT TRANSFORMER
1618	17-01-2026	Part of : SHIV VIHAR NANGLOI	1388	Other Outage	Planned Outage	17-01-2026	11:22	17-01-2026	13:56	2:34	0.000428	MAINTENANCE OF LT TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						Remarks
						From		To		Duration	Unservd (MU) due to outage	
						Date	Time	Date	Time			
1619	17-01-2026	Part of : NANGLOI SAIYED VILLAGE PASCHIM VIHAR	606	Other Outage	Planned Outage	17-01-2026	11:13	17-01-2026	14:23	3:10	0.000528	MAINTENANCE OF LT TRANSFORMER
1620	17-01-2026	Part of : J BLOCK JEEVAN NIKETAN PASCHIM VIHAR	125	Other Outage	Planned Outage	17-01-2026	11:22	17-01-2026	14:25	3:03	0.000508	MAINTENANCE OF LT TRANSFORMER
1621	18-01-2026	Part of : UDYOG NAGAR MANGOLPURI	426	Other Outage	Planned Outage	18-01-2026	11:11	18-01-2026	14:23	3:12	0.000000	GUARD WIRES SAGGING PER SPAN
1622	18-01-2026	Part of : NARESH PARK NANGLOI	517	Other Outage	Planned Outage	18-01-2026	11:12	18-01-2026	14:24	3:12	0.000000	REPLACEMENT OF LT BUSHING ROD
1623	19-01-2026	Part of : NILOTHI VILLAGE,CHANDER VIHAR,RISALA GARDEN NILOTHI	2810	Other Outage	Planned Outage	19-01-2026	14:41	19-01-2026	16:49	2:08	0.001600	GUARD WIRES SAGGING,JUMPER REPLACEMENT PER POLE
1624	19-01-2026	Part of : BLOCK GH 14 PASCHIM VIHAR	210	Other Outage	Planned Outage	19-01-2026	12:50	19-01-2026	14:04	1:14	0.000206	LT CIRCUIT MAINTENANCE WORK
1625	19-01-2026	Part of : BLOCK E VANDANA VIHAR NANGLOI	1642	Other Outage	Planned Outage	19-01-2026	10:55	19-01-2026	14:05	3:10	0.001056	LT CIRCUIT MAINTENANCE WORK
1626	19-01-2026	Part of : NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	323	Other Outage	Planned Outage	19-01-2026	11:11	19-01-2026	14:03	2:52	0.000717	LT CIRCUIT MAINTENANCE WORK
1627	19-01-2026	Part of : BLOCK S JAWALAPURI EXTENSION PASCHIM VIHAR	463	Other Outage	Planned Outage	19-01-2026	11:16	19-01-2026	14:01	2:45	0.000229	LT CIRCUIT MAINTENANCE WORK
1628	19-01-2026	Part of : VIKASPURI EXTN.	1082	Other Outage	Planned Outage	19-01-2026	11:10	19-01-2026	14:02	2:52	0.001911	LT CIRCUIT MAINTENANCE WORK
1629	19-01-2026	Part of : AMBIKA VIHAR PASCHIM VIHAR	386	Other Outage	Planned Outage	19-01-2026	10:59	19-01-2026	14:02	3:03	0.000610	LT CIRCUIT MAINTENANCE WORK
1630	20-01-2026	Part of : HANUMAN ENCLAVE NANGLOI,SHIV VIHAR NANGLOI,RAO VIHAR NANGLOI	1077	Other Outage	Planned Outage	20-01-2026	13:47	20-01-2026	15:30	1:43	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1631	20-01-2026	Part of : UDYOG NAGAR MANGOLPURI	213	Other Outage	Planned Outage	20-01-2026	11:31	20-01-2026	13:43	2:12	0.000733	REPLACEMENT OF LT BUSHING ROD
1632	20-01-2026	Part of : JAI VIHAR BAPROLA	1252	Other Outage	Planned Outage	20-01-2026	11:22	20-01-2026	13:45	2:23	0.000000	REPLACEMET OF HT BUSHING ROD
1633	20-01-2026	Part of : BLOCK J JEEVAN NIKETAN PASCHIM VIHAR	153	Other Outage	Planned Outage	20-01-2026	11:21	20-01-2026	13:41	2:20	0.000000	REPLACEMET OF HT BUSHING ROD
1634	21-01-2026	Part of : JAI VIHAR BAPROLA,	183	Other Outage	Planned Outage	21-01-2026	11:04	21-01-2026	14:45	3:41	0.000000	LT TRANSFORMER MAINTENANCE
1635	21-01-2026	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,	661	Other Outage	Planned Outage	21-01-2026	11:04	21-01-2026	14:49	3:45	0.000000	LT TRANSFORMER MAINTENANCE
1636	21-01-2026	Part of : BLOCK D DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI,	978	Other Outage	Planned Outage	21-01-2026	11:03	21-01-2026	14:48	3:45	0.000000	LT TRANSFORMER MAINTENANCE
1637	22-01-2026	Part of : BLOCK A MIRA BAGH PASCHIM VIHAR	321	Other Outage	Planned Outage	22-01-2026	15:04	22-01-2026	16:57	1:53	0.000314	REPLACEMENT OF FAULTY END BOX
1638	22-01-2026	Part of : BLOCK A 3 MIYANWALI NAGAR PASCHIM VIHAR	235	Other Outage	Planned Outage	22-01-2026	11:55	22-01-2026	15:01	3:06	0.000517	REPLACEMENT OF HT BUSHING ROD
1639	22-01-2026	Part of : RANHOLLA	143	Other Outage	Planned Outage	22-01-2026	11:20	22-01-2026	13:43	2:23	0.000397	REPLACEMENT OF HT BUSHING ROD
1640	22-01-2026	Part of : AMBIKA VIHAR PASCHIM VIHAR	386	Other Outage	Planned Outage	22-01-2026	11:01	22-01-2026	14:59	3:58	0.000661	REPLACEMENT OF HT BUSHING ROD
1641	22-01-2026	Part of : JAI VIHAR PH-1, PH-3	31	Other Outage	Planned Outage	22-01-2026	10:58	22-01-2026	14:58	4:00	0.000667	REPLACEMENT OF HT BUSHING ROD
1642	23-01-2026	Part of : B-BLOCK AMANPURI & D-BLOCK KUNWAR SINGH NAGAR KAMRUDDIN NAGAR NANGLOI,A,B & I-BLOCK NARESH PARK EXTENSION NANGLOI	4259	Other Outage	Unplanned Outage	23-01-2026	12:36	23-01-2026	13:26	0:50	0.002778	HVDS FAULT
1643	23-01-2026	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI,TILANGPUR KOTLA VILLAGE,RISHAL GARDEN,TILANGPUR KOTLA,RANHOLLA	8544	Other Outage	Unplanned Outage	23-01-2026	11:24	23-01-2026	12:15	0:51	0.001445	TRANSIENT FAULT
1644	23-01-2026	Part of : RISALA GARDEN,NILOTHI VILLAGE,CHANDER VIHAR	2139	Other Outage	Unplanned Outage	23-01-2026	09:40	23-01-2026	10:32	0:52	0.000246	TRANSIENT FAULT
1645	23-01-2026	Part of : A & B-BLOCK JAWALAPURI PASCHIM VIHAR,G-BLOCK NIHAL VIHAR ADHYAPAK NAGAR,A-BLOCK VANDANA VIHAR,RAO VIHAR,HANUMAN ENCLAVE,SHIV VIHAR NANGLOI	10508	Other Outage	Unplanned Outage	23-01-2026	08:20	23-01-2026	09:13	0:53	0.002356	HVDS FAULT
1646	24-01-2026	Part of : BLOCK 13 SUNDER VIHAR PASCHIM VIHAR	404	Other Outage	Planned Outage	24-01-2026	12:32	24-01-2026	13:37	1:05	0.000361	REPLACEMET OF HT BUSHING ROD
1647	24-01-2026	Part of : JAI VIHAR PH-1	69	Other Outage	Planned Outage	24-01-2026	11:44	24-01-2026	13:36	1:52	0.000622	REPLACEMET OF HT BUSHING ROD
1648	24-01-2026	Part of : RANHOLLA	2	Other Outage	Planned Outage	24-01-2026	14:49	24-01-2026	16:52	2:03	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1649	24-01-2026	Part of : NARESH PARK NANGLOI	13	Other Outage	Planned Outage	24-01-2026	10:49	24-01-2026	13:37	2:48	0.000933	REPLACEMENT OF LT BUSHING ROD
1650	25-01-2026	Part of : BAPROLA VILLAGE,NANGLI VIHAR,JAI VIHAR PH-1, PH-3,HARPHOOL VIHAR,PRASHANT ENCLAVE,NIRMAL VIHAR BAPROLA	5842	Other Outage	Unplanned Outage	25-01-2026	04:10	25-01-2026	04:30	0:20	0.000614	CABLE FAULT
1651	25-01-2026	Part of : PRADHAN ENCLAVE	713	Other Outage	Planned Outage	25-01-2026	12:16	25-01-2026	15:37	3:21	0.000558	REPLACEMENT OF HT BUSHING ROD
1652	25-01-2026	Part of : BLOCK J JEEVAN NIKETAN PASCHIM VIHAR	125	Other Outage	Planned Outage	25-01-2026	11:15	25-01-2026	13:45	2:30	0.000417	REPLACEMENT OF HT BUSHING ROD
1653	27-01-2026	Part of : UDYOG NAGAR MANGOLPURI	301	Other Outage	Unplanned Outage	27-01-2026	11:25	27-01-2026	12:11	0:46	0.000043	TREE TOUCHING
1654	28-01-2026	Part of : BLOCK E & J JEEVAN NIKETAN PASCHIM VIHAR, LIC COLONY, AMBIKA VIHAR, SUNDER VIHAR	712	Other Outage	Unplanned Outage	28-01-2026	15:59	28-01-2026	16:21	0:22	0.000306	CABLE FAULT
1655	28-01-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR	107	Other Outage	Planned Outage	28-01-2026	11:54	28-01-2026	13:41	1:47	0.000000	REPLACEMET OF HT BUSHING ROD
1656	28-01-2026	Part of : BLOCK GH 12 & GH 13 PASCHIM VIHAR,GURU HARKISHAN NAGAR PASCHIM VIHAR	1982	Other Outage	Planned Outage	28-01-2026	10:55	28-01-2026	13:40	2:45	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1657	28-01-2026	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1124	Other Outage	Planned Outage	28-01-2026	14:15	28-01-2026	16:27	2:12	0.000000	REPLACEMENT OF LT BUSHING ROD
1658	28-01-2026	Part of : NANGLI VIHAR	1922	Other Outage	Planned Outage	28-01-2026	10:52	28-01-2026	13:42	2:50	0.000944	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1659	29-01-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR,	105	Other Outage	Planned Outage	29-01-2026	11:59	29-01-2026	13:49	1:50	0.000306	REPLACEMET OF HT BUSHING ROD
1660	29-01-2026	Part of : BLOCK J JEEVAN NIKETAN PASCHIM VIHAR,	153	Other Outage	Planned Outage	29-01-2026	10:52	29-01-2026	14:15	3:23	0.000564	REPLACEMET OF HT BUSHING ROD
1661	29-01-2026	Part of : JAI VIHAR PH-1, PH-3,	1515	Other Outage	Planned Outage	29-01-2026	11:03	29-01-2026	14:15	3:12	0.000533	REPLACEMET OF HT BUSHING ROD
1662	29-01-2026	Part of : BHERA ENCLAVE PASCHIM VIHAR,	317	Other Outage	Planned Outage	29-01-2026	10:53	29-01-2026	14:15	3:22	0.000561	REPLACEMET OF HT BUSHING ROD
1663	30-01-2026	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR	1752	Other Outage	Unplanned Outage	30-01-2026	17:55	30-01-2026	18:39	0:44	0.000475	HT SYSTEM FAULT
1664	30-01-2026	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR,BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,BLOCK A VANDANA VIHAR NANGLOI,BLOCK A JAWALAPURI PASCHIM VIHAR,RAO VIHAR NANGLOI,HANUMAN ENCLAVE NANGLOI,SHIV VIHAR NANGLOI	9183	Other Outage	Unplanned Outage	30-01-2026	11:28	30-01-2026	12:02	0:34	0.001686	HT SYSTEM FAULT
1665	30-01-2026	Part of : BLOCK 2C NANGLOI EXTENSION NANGLOI,NANGLOI JAT NANGLOI	2346	Other Outage	Unplanned Outage	30-01-2026	11:28	30-01-2026	12:02	0:34	0.001731	HT SYSTEM FAULT
1666	30-01-2026	Part of : BLOCK H VANDANA VIHAR NANGLOI,BLOCK F VANDANA VIHAR NANGLOI	3713	Other Outage	Unplanned Outage	30-01-2026	07:46	30-01-2026	08:31	0:45	0.000736	CABLE FAULT
1667	30-01-2026	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI,TILANGPUR KOTLA VILLAGE,RISHAL GARDEN,TILANGPUR KOTLA,RANHOLLA	8606	Other Outage	Planned Outage	30-01-2026	11:03	30-01-2026	15:08	4:05	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1668	30-01-2026	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI	1606	Other Outage	Planned Outage	30-01-2026	11:13	30-01-2026	13:54	2:41	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1669	30-01-2026	Part of : JAI VIHAR PH-1, PH-3,RANHOLLA,TILANGPUR KOTLA VILLAGE,PRATAP VIHAR	2682	Other Outage	Planned Outage	30-01-2026	11:05	30-01-2026	15:09	4:04	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1670	30-01-2026	Part of : SHIV VIHAR NANGLOI	1449	Other Outage	Planned Outage	30-01-2026	14:19	30-01-2026	16:19	2:00	0.000667	REPLACEMENT OF LT BUSHING ROD
1671	30-01-2026	Part of : UDYOG NAGAR MANGOLPURI	282	Other Outage	Planned Outage	30-01-2026	11:06	30-01-2026	13:53	2:47	0.000000	REPLACEMENT OF LT BUSHING ROD
1672	31-01-2026	Part of : EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR	130	Other Outage	Planned Outage	31-01-2026	12:53	31-01-2026	14:17	1:24	0.000467	LT CIRCUIT MAINTENANCE
1673	31-01-2026	Part of : DASS GARDEN	954	Other Outage	Planned Outage	31-01-2026	13:12	31-01-2026	14:32	1:20	0.001111	LT CIRCUIT MAINTENANCE
1674	31-01-2026	Part of : G-BLOCK NIHAL VIHAR,NAMDHARI COLONY,DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	6695	Other Outage	Planned Outage	31-01-2026	11:57	31-01-2026	15:04	3:07	0.001299	GUARD WIRES SAGGING
1675	31-01-2026	Part of : VANDANA VIHAR NANGLOI	1937	Other Outage	Planned Outage	31-01-2026	10:55	31-01-2026	14:01	3:06	0.000517	3PH HT AB CABLE REPLACEMENT
1676	31-01-2026	Part of : VIRAT APARTMENT,C & -BLOCK JAWALAPURI CAMP 5 JAWALAPURI PASCHIM VIHAR	2660	Other Outage	Planned Outage	31-01-2026	11:52	31-01-2026	13:59	2:07	0.000000	GUARD WIRES SAGGING
1677	31-01-2026	Part of : RISHAL GARDEN	1528	Other Outage	Planned Outage	31-01-2026	11:31	31-01-2026	13:59	2:28	0.001644	LT CIRCUIT MAINTENANCE
1678	01-01-2026	Part of : KHAIRA VILLAGE,KHARKHARI NAHA VILLAGE,PAPRAWAT VILLAGE,PREM NAGAR PAPRAWAT VILLAGE,DURGA VIHAR II DINPUR,DURGA VIHAR I DINPUR	3931	Other Outage	Unplanned Outage	01-01-2026	04:40	01-01-2026	05:15	0:35	0.000224	HVDS FAULT
1679	01-01-2026	Part of : GANDHI PARK, VILL. KANGANHERI, OSHODHAM MANDIR NEAR PANDWALA MORE	3680	Other Outage	Unplanned Outage	01-01-2026	04:34	01-01-2026	05:08	0:34	0.000227	TREE TOUCHING
1680	01-01-2026	Part of : SHYAM KUNJ DINPUR,	520	Other Outage	Planned Outage	01-01-2026	15:26	01-01-2026	16:26	1:00	0.000500	REPLACEMENT OF LT BUSHING ROD
1681	01-01-2026	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,	14	Other Outage	Planned Outage	01-01-2026	12:57	01-01-2026	15:24	2:27	0.001225	REPLACEMET OF HT BUSHING ROD
1682	01-01-2026	Part of : PREM NAGAR PAPRAWAT VILLAGE,	194	Other Outage	Planned Outage	01-01-2026	12:57	01-01-2026	15:25	2:28	0.000822	REPLACEMET OF HT BUSHING ROD
1683	01-01-2026	Part of : BADUSARAI,	511	Other Outage	Planned Outage	01-01-2026	13:43	01-01-2026	16:08	2:25	0.003021	REPLACEMENT OF LT BUSHING ROD
1684	02-01-2026	Part of : SHIV NAGAR NAJAFGARH,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,LOKESH PARK NAJAFGARH	1282	Other Outage	Planned Outage	02-01-2026	15:29	02-01-2026	17:10	1:41	0.000561	REPLACEMENT OF HT BUSHING ROD
1685	02-01-2026	Part of : ARJUN PARK NANGLI SAKRAWATI	106	Other Outage	Planned Outage	02-01-2026	11:34	02-01-2026	13:44	2:10	0.000000	SUB STATION CLEANING
1686	02-01-2026	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	405	Other Outage	Planned Outage	02-01-2026	11:33	02-01-2026	14:06	2:33	0.001700	REPLACEMENT OF LT BUSHING ROD
1687	02-01-2026	Part of : CHAWLA	698	Other Outage	Planned Outage	02-01-2026	11:06	02-01-2026	13:39	2:33	0.002380	REPLACEMENT OF LT BUSHING ROD
1688	02-01-2026	Part of : PREM NAGAR NAJAFGARH	345	Other Outage	Planned Outage	02-01-2026	10:50	02-01-2026	13:33	2:43	0.003169	3PH HT AB CABLE REPLACEMENT PER SPAN
1689	03-01-2026	Part of : SHYAM KUNJ DINPUR,	521	Other Outage	Unplanned Outage	03-01-2026	13:35	03-01-2026	15:04	1:29	0.000742	REPAIRING OF RMU
1690	03-01-2026	Part of : NEW HEERA PARK NAJAFGARH	64	Other Outage	Planned Outage	03-01-2026	12:49	03-01-2026	14:47	1:58	0.000656	REPLACEMENT OF HT BUSHING ROD
1691	03-01-2026	Part of : DHARAMPURA NAJAFGARH	343	Other Outage	Planned Outage	03-01-2026	11:31	03-01-2026	14:16	2:45	0.001375	REPLACEMENT OF CROSS-ARMS AND POLES
1692	03-01-2026	Part of : SECTOR 29 DWARKA	409	Other Outage	Planned Outage	03-01-2026	11:13	03-01-2026	13:42	2:29	0.000000	REPLACEMENT OF HT BUSHING ROD
1693	03-01-2026	Part of : NANGLI SANKRANTI	587	Other Outage	Planned Outage	03-01-2026	11:06	03-01-2026	13:39	2:33	0.000850	REPLACEMENT OF HT BUSHING ROD
1694	03-01-2026	Part of : QUTUB VIHAR PHASE 2	27	Other Outage	Planned Outage	03-01-2026	11:32	03-01-2026	14:17	2:45	0.003850	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1695	05-01-2026	Part of : BLOCK Q NEW ROSHAN PURA NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH,BLOCK E NEW ROSHAN PURA NAJAFGARH,SANGAM VIHAR DHARAMPURA NAJAFGARH,DURGA PARK NAJAFGARH,ROSHANPURA COLONY NAJAFGARH	5811	Other Outage	Unplanned Outage	05-01-2026	08:22	05-01-2026	09:02	0:40	0.000000	CABLE FAULT
1696	05-01-2026	Part of : BLOCK Q NEW ROSHAN PURA NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH,BLOCK E NEW ROSHAN PURA NAJAFGARH,SANGAM VIHAR DHARAMPURA NAJAFGARH,DURGA PARK NAJAFGARH,ROSHANPURA COLONY NAJAFGARH	5811	Other Outage	Unplanned Outage	05-01-2026	07:19	05-01-2026	07:57	0:38	0.000581	TRANSIENT FAULT
1697	05-01-2026	Part of : SHYAM VIHAR I NAJAFGARH,BLOCK E SHYAM VIHAR I NAJAFGARH	1467	Other Outage	Planned Outage	05-01-2026	12:03	05-01-2026	15:06	3:03	0.001525	MAINTENANCE OF TRANSFORMER
1698	06-01-2026	Part of : NANGLI DAIRY NANGLI SAKRAWATI	18	Other Outage	Planned Outage	06-01-2026	13:19	06-01-2026	14:43	1:24	0.000467	REPLACEMENT OF HT BUSHING ROD
1699	06-01-2026	Part of : DURGA VIHAR I DINPUR,DURGA VIHAR II DINPUR	162	Other Outage	Planned Outage	06-01-2026	12:59	06-01-2026	14:24	1:25	0.001417	3PH HT AB CABLE REPLACEMENT PER SPAN
1700	06-01-2026	Part of : SURYA KUNJ HAIBUTPUR,DHANAK MOHALLA HAIBUTPUR,JANTA VIHAR HAIBUTPUR	215	Other Outage	Planned Outage	06-01-2026	13:14	06-01-2026	16:02	2:48	0.000933	3PH HT AB CABLE REPLACEMENT PER SPAN
1701	06-01-2026	Part of : QUTUB VIHAR PHASE 2 QUTUB VIHAR	431	Other Outage	Planned Outage	06-01-2026	11:06	06-01-2026	13:25	2:19	0.002934	REPLACEMENT OF HT BUSHING ROD
1702	06-01-2026	Part of : SECTOR 27 DWARKA	358	Other Outage	Planned Outage	06-01-2026	11:54	06-01-2026	14:41	2:47	0.000000	REPLACEMENT OF LT BUSHING ROD
1703	07-01-2026	Part of : SULTAN GARDEN	92	Other Outage	Planned Outage	07-01-2026	13:50	07-01-2026	16:18	2:28	0.001233	REPLACEMENT OF HT BUSHING ROD
1704	07-01-2026	Part of : SHYAM VIHAR I NAJAFGARH	558	Other Outage	Planned Outage	07-01-2026	11:17	07-01-2026	14:19	3:02	0.001517	REPLACEMENT OF HT BUSHING ROD
1705	07-01-2026	Part of : BLOCK B POCHANPUR DWARKA	447	Other Outage	Planned Outage	07-01-2026	10:55	07-01-2026	13:57	3:02	0.000000	REPLACEMENT OF HT BUSHING ROD
1706	07-01-2026	Part of : REWLA KHANPUR VILLAGE	16	Other Outage	Planned Outage	07-01-2026	10:05	07-01-2026	12:52	2:47	0.003526	REPLACEMENT OF HT BUSHING ROD
1707	08-01-2026	Part of : SECTOR 27 DWARKA, BHARTHAL VILLAGE DWARKA	4210	Other Outage	Unplanned Outage	08-01-2026	15:28	08-01-2026	16:00	0:32	0.000533	CABLE FAULT
1708	08-01-2026	Part of : SAMTA ENCLAVE QUTUB VIHAR	610	Other Outage	Planned Outage	08-01-2026	13:25	08-01-2026	15:48	2:23	0.002939	REPLACEMET OF HT BUSHING ROD
1709	08-01-2026	Part of : SECTOR 27 DWARKA	1	Other Outage	Planned Outage	08-01-2026	10:58	08-01-2026	13:25	2:27	0.000000	REPLACEMENT OF LT BUSHING ROD
1710	08-01-2026	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	587	Other Outage	Planned Outage	08-01-2026	11:23	08-01-2026	14:33	3:10	0.001056	REPLACEMET OF HT BUSHING ROD
1711	08-01-2026	Part of : PREM NAGAR NAJAFGARH,ROSHAN PURA NAJAFGARH	741	Other Outage	Planned Outage	08-01-2026	11:14	08-01-2026	13:54	2:40	0.002667	3PH HT AB CABLE REPLACEMENT PER SPAN
1712	08-01-2026	Part of : SHYAM KUNJ DINPUR	521	Other Outage	Planned Outage	08-01-2026	11:22	08-01-2026	13:58	2:36	0.001300	REPLACEMET OF HT BUSHING ROD
1713	08-01-2026	Part of : SHYAM VIHAR I NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH	1467	Other Outage	Planned Outage	08-01-2026	10:57	08-01-2026	13:22	2:25	0.001208	REPLACEMENT OF LT BUSHING ROD
1714	09-01-2026	Part of : BLOCK E SHYAM VIHAR I NAJAFGARH,SHYAM VIHAR I NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH,	1471	Other Outage	Unplanned Outage	09-01-2026	12:26	09-01-2026	13:36	1:10	0.000194	REPAIRING OF HT O/H CIRCUIT
1715	09-01-2026	Part of : SHIV NAGAR NAJAFGARH,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,LOKESH PARK NAJAFGARH	1282	Other Outage	Planned Outage	09-01-2026	13:13	09-01-2026	15:53	2:40	0.001778	MAINTENANCE OF HVDS
1716	09-01-2026	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,	14	Other Outage	Planned Outage	09-01-2026	13:17	09-01-2026	16:40	3:23	0.001128	MAINTENANCE OF TRANSFORMER
1717	09-01-2026	Part of : GOYALA DAIRY QUTUB VIHAR,GOYLA KHURD,BLOCK A GOYLA VIHAR GOYLA KHURD,BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR	2045	Other Outage	Planned Outage	09-01-2026	13:14	09-01-2026	15:43	2:29	0.003104	MAINTENANCE OF RMU
1718	09-01-2026	Part of : BLOCK E SHYAM VIHAR I NAJAFGARH,SHYAM ENCLAVE DINPUR,SHIV PURI I DINPUR,	941	Other Outage	Planned Outage	09-01-2026	11:01	09-01-2026	13:52	2:51	0.001425	MAINTENANCE OF TRANSFORMER
1719	09-01-2026	Part of : ROSHAN VIHAR I NAJAFGARH,DURGA VIHAR I DINPUR,	517	Other Outage	Planned Outage	09-01-2026	11:25	09-01-2026	13:30	2:05	0.002083	MAINTENANCE OF HVDS
1720	09-01-2026	Part of : SURYA VIHAR DINPUR,SHIV PURI II DINPUR,GANDHI PARK DINPUR,	513	Other Outage	Planned Outage	09-01-2026	11:23	09-01-2026	15:45	4:22	0.004949	MAINTENANCE OF HVDS
1721	10-01-2026	Part of : SURYA VIHAR DINPUR,SHIV PURI II DINPUR,GANDHI PARK DINPUR,KANGANHERI VILLAGE,REWLA KHANPUR VILLAGE,BADUSARAI, CHAWLA	3685	Other Outage	Unplanned Outage	10-01-2026	04:13	10-01-2026	04:58	0:45	0.000200	CABLE FAULT
1722	10-01-2026	PART OF : BLOCK B POCHANPUR DWARKA	1004	Other Outage	Planned Outage	10-01-2026	11:20	10-01-2026	13:21	2:01	0.000000	REPLACEMENT OF LT BUSHING ROD
1723	10-01-2026	PART OF : ROSHAN PURA NAJAFGARH	291	Other Outage	Planned Outage	10-01-2026	11:32	10-01-2026	14:14	2:42	0.002700	3PH HT AB CABLE REPLACEMENT PER SPAN
1724	10-01-2026	PART OF : SAMTA ENCLAVE QUTUB VIHAR	825	Other Outage	Planned Outage	10-01-2026	11:14	10-01-2026	13:43	2:29	0.002442	REPLACEMENT OF HT BUSHING ROD
1725	10-01-2026	PART OF : SARASWATI KUNJ JHARODA KALAN	555	Other Outage	Planned Outage	10-01-2026	11:34	10-01-2026	14:14	2:40	0.001333	REPLACEMENT OF HT BUSHING ROD
1726	10-01-2026	PART OF : GANDHI PARK DINPUR,SHYAM VIHAR - II DINPUR,SHIV PURI II DINPUR	2148	Other Outage	Planned Outage	10-01-2026	11:02	10-01-2026	13:41	2:39	0.001325	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1727	11-01-2026	Part of : CHAWLA VILLAGE	512	Other Outage	Unplanned Outage	11-01-2026	20:13	11-01-2026	20:55	0:42	0.000385	CABLE DAMAGE BY OUTSIDE AGENCY (UNKNOWN AGENCY)
1728	12-01-2026	Part of : SANGAM VIHAR DHARAMPURA,DHARAMPURA NAJAFGARH	1005	Other Outage	Planned Outage	12-01-2026	15:35	12-01-2026	16:44	1:09	0.000479	REPLACEMET OF HT BUSHING ROD
1729	12-01-2026	Part of : REWLA KHANPUR VILLAGE	915	Other Outage	Planned Outage	12-01-2026	14:28	12-01-2026	16:38	2:10	0.003250	REPLACEMET OF HT BUSHING ROD
1730	12-01-2026	Part of : PREM NAGAR NAJAFGARH,ROSHAN PURA NAJAFGARH	731	Other Outage	Planned Outage	12-01-2026	11:33	12-01-2026	13:58	2:25	0.002417	3PH HT AB CABLE REPLACEMENT PER SPAN
1731	12-01-2026	Part of : BLOCK B SECTOR 19 DWARKA	449	Other Outage	Planned Outage	12-01-2026	12:21	12-01-2026	14:52	2:31	0.000629	CONDUCTOR REPLACEMENT PER SPAN
1732	12-01-2026	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	283	Other Outage	Planned Outage	12-01-2026	10:51	12-01-2026	13:30	2:39	0.001104	REPLACEMENT OF LT BUSHING ROD
1733	13-01-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR	296	Other Outage	Planned Outage	13-01-2026	13:24	13-01-2026	16:05	2:41	0.002683	3PH HT AB CABLE REPLACEMENT PER SPAN
1734	13-01-2026	Part of : ANAND VIHAR NANGLI SAKRAWATI	101	Other Outage	Planned Outage	13-01-2026	12:40	13-01-2026	15:15	2:35	0.000861	REPLACEMENT OF HT BUSHING ROD
1735	13-01-2026	Part of : HASANPUR VILLAGE	247	Other Outage	Planned Outage	13-01-2026	11:12	13-01-2026	13:24	2:12	0.000000	REPLACEMENT OF LT BUSHING ROD
1736	13-01-2026	Part of : NEW HIRA NAGAR DICHAON KALAN	427	Other Outage	Planned Outage	13-01-2026	10:50	13-01-2026	13:21	2:31	0.000839	REPLACEMENT OF LT BUSHING ROD
1737	13-01-2026	Part of : SECTOR 27 DWARKA	60	Other Outage	Planned Outage	13-01-2026	11:14	13-01-2026	13:23	2:09	0.000000	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD
1738	13-01-2026	Part of : BADUSARAI	906	Other Outage	Planned Outage	13-01-2026	12:36	13-01-2026	15:14	2:38	0.003950	REPLACEMENT OF HT BUSHING ROD
1739	13-01-2026	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	664	Other Outage	Planned Outage	13-01-2026	10:34	13-01-2026	13:19	2:45	0.001375	REPLACEMENT OF HT BUSHING ROD
1740	14-01-2026	Part of : E BLOCK NEW ROSHAN PURA NAJAFGARH	405	Other Outage	Planned Outage	14-01-2026	11:51	14-01-2026	14:08	2:17	0.000761	REPLACEMENT OF HT BUSHING ROD
1741	14-01-2026	Part of : SHIKARPUR VILLAGE	18	Other Outage	Planned Outage	14-01-2026	11:39	14-01-2026	14:07	2:28	0.000000	REPLACEMENT OF LT BUSHING ROD
1742	14-01-2026	Part of : BSF CHAWLA,KHELGAON ,11KV SUBSTATION,NJF	1	Other Outage	Planned Outage	14-01-2026	12:35	14-01-2026	15:10	2:35	0.000861	REPLACEMENT OF HT BUSHING ROD
1743	14-01-2026	Part of : CHAWLA	1133	Other Outage	Planned Outage	14-01-2026	11:41	14-01-2026	14:09	2:28	0.003700	REPLACEMENT OF LT BUSHING ROD
1744	15-01-2026	Part of : BLOCK A GOYLA DAIRY QUTUB VIHAR,GOYLA KHURD VIHAR GOYLA KHURD	2045	Other Outage	Planned Outage	15-01-2026	12:07	15-01-2026	14:44	2:37	0.002617	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1745	15-01-2026	Part of : ASALETPUR KHAWAD VILLAGE	191	Other Outage	Planned Outage	15-01-2026	11:46	15-01-2026	14:25	2:39	0.000000	REPLACEMET OF HT BUSHING ROD
1746	15-01-2026	Part of : BLOCK I,E & X SHYAM VIHAR I NAJAFGARH	1467	Other Outage	Planned Outage	15-01-2026	11:14	15-01-2026	14:00	2:46	0.001383	REPLACEMET OF HT BUSHING ROD
1747	15-01-2026	Part of : NAJAFGARH EXTENSION	197	Other Outage	Planned Outage	15-01-2026	12:36	15-01-2026	15:22	2:46	0.001153	REPLACEMET OF HT BUSHING ROD
1748	15-01-2026	Part of : BLOCK B NAVEEN PALACE JHARODA KALAN,SARASWATI KUNJ JHARODA KALAN	1280	Other Outage	Planned Outage	15-01-2026	11:41	15-01-2026	14:25	2:44	0.000911	3PH HT AB CABLE REPLACEMENT
1749	15-01-2026	Part of : KANGANHERI VILLAGE	803	Other Outage	Planned Outage	15-01-2026	11:15	15-01-2026	13:49	2:34	0.003850	REPLACEMET OF HT BUSHING ROD
1750	15-01-2026	Part of : DATA RAM PARK,DURGA VIHAR,ROSHAN VIHAR	676	Other Outage	Planned Outage	15-01-2026	10:37	15-01-2026	13:14	2:37	0.002617	3PH HT AB CABLE REPLACEMENT
1751	16-01-2026	Part of : NAJAFGARH EXTENSION	723	Other Outage	Planned Outage	16-01-2026	15:30	16-01-2026	17:04	1:34	0.000522	3PH HT AB CABLE REPLACEMENT PER SPAN
1752	16-01-2026	Part of : SECTOR 24 DWARKA,SAMTA ENCLAVE QUTUB VIHAR	5266	Other Outage	Planned Outage	16-01-2026	14:34	16-01-2026	16:35	2:01	0.003025	REPLACEMENT OF LT BUSHING ROD
1753	16-01-2026	Part of : KAPAS HERA EXTENSION KAPAS HERA,PALAM FARMS,PUSHPANJALI FARMS	171	Other Outage	Planned Outage	16-01-2026	11:03	16-01-2026	14:05	3:02	0.003033	3PH HT AB CABLE REPLACEMENT PER SPAN
1754	16-01-2026	Part of : POCKET EL HARI NAGAR	930	Other Outage	Planned Outage	16-01-2026	10:14	16-01-2026	13:18	3:04	0.001278	REPLACEMENT OF HT BUSHING INULATOR
1755	17-01-2026	Part of : D BLOCK LAXMI VIHAR COLONY NANGLI SAKRAWATI	140	Other Outage	Planned Outage	17-01-2026	13:29	17-01-2026	16:03	2:34	0.000856	MAINTENANCE OF HVDS CIRCUIT
1756	17-01-2026	Part of : DHARAMPURA NAJAFGARH,BLOCK E NEW ROSHAN PURA NAJAFGARH	1007	Other Outage	Planned Outage	17-01-2026	10:57	17-01-2026	13:47	2:50	0.001417	MAINTENANCE OF TRANSFORMER
1757	17-01-2026	Part of : A BLOCK QUTUB VIHAR PHASE 1 QUTUB VIHAR	115	Other Outage	Planned Outage	17-01-2026	11:09	17-01-2026	13:50	2:41	0.004025	MAINTENANCE OF TRANSFORMER
1758	17-01-2026	Part of : DATA RAM PARK DINPUR	372	Other Outage	Planned Outage	17-01-2026	11:07	17-01-2026	13:49	2:42	0.004050	MAINTENANCE OF HVDS CIRCUIT
1759	19-01-2026	Part of : NIRMAL VIHAR DICHAON KALAN	1066	Other Outage	Planned Outage	19-01-2026	14:55	19-01-2026	16:23	1:28	0.000733	REPLACEMET OF HT BUSHING ROD
1760	19-01-2026	Part of : RANAJI ENCLAVE MASUDABAD NAJAFGARH	2308	Other Outage	Planned Outage	19-01-2026	11:58	19-01-2026	14:54	2:56	0.001222	3PH HT AB CABLE REPLACEMENT
1761	19-01-2026	Part of : SHYAM VIHAR-1 NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH	1467	Other Outage	Planned Outage	19-01-2026	12:00	19-01-2026	14:57	2:57	0.001475	REPLACEMET OF HT BUSHING ROD
1762	19-01-2026	Part of : BLOCK A QUTUB VIHAR PHASE-1	257	Other Outage	Planned Outage	19-01-2026	11:09	19-01-2026	15:13	4:04	0.004067	REPLACEMENT OF GAS KIT AND OIL SEAL
1763	20-01-2026	Part of : SHIV ENCLAVE NAJAFGARH,SAINIK NIKETAN NAJAFGARH,SULTAN GARDEN	445	Other Outage	Planned Outage	20-01-2026	13:52	20-01-2026	16:23	2:31	0.000839	3PH HT AB CABLE REPLACEMENT PER SPAN
1764	20-01-2026	Part of : CHAWLA,RAGHOPUR VILLAGE	26	Other Outage	Planned Outage	20-01-2026	10:47	20-01-2026	14:19	3:32	0.003533	REPLACEMENT OF GAS KIT AND OIL SEAL
1765	20-01-2026	Part of : BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI	320	Other Outage	Planned Outage	20-01-2026	11:12	20-01-2026	14:17	3:05	0.001028	DT REPLACEMET PER DT
1766	20-01-2026	Part of : POCHANPUR DWARKA	905	Other Outage	Planned Outage	20-01-2026	10:42	20-01-2026	13:40	2:58	0.000000	REPLACEMENT OF LT BUSHING ROD
1767	20-01-2026	Part of : ROSHAN PURA NAJAFGARH,PREM NAGAR NAJAFGARH	205	Other Outage	Planned Outage	20-01-2026	11:04	20-01-2026	13:26	2:22	0.003550	3PH HT AB CABLE REPLACEMENT PER SPAN
1768	20-01-2026	Part of : SANGAM VIHAR DHARAMPURA NAJAFGARH	508	Other Outage	Planned Outage	20-01-2026	10:29	20-01-2026	13:15	2:46	0.001153	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1769	21-01-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR,DURGA PARK NAJAFGARH,	673	Other Outage	Planned Outage	21-01-2026	11:11	21-01-2026	13:50	2:39	0.002650	HVDS MAINTENANCE
1770	21-01-2026	Part of : QUTUB VIHAR PHASE 2 QUTUB VIHAR,	635	Other Outage	Planned Outage	21-01-2026	12:02	21-01-2026	15:04	3:02	0.003033	TRANSFORMER MAINTENANCE
1771	21-01-2026	Part of : NAJAFGARH EXTENSION NAJAFGARH,AJAY PARK MASUDABAD NAJAFGARH,NATHU RAM PARK MASUDABAD NAJAFGARH,	724	Other Outage	Planned Outage	21-01-2026	11:24	21-01-2026	14:11	2:47	0.000928	HVDS MAINTENANCE
1772	21-01-2026	Part of : BLOCK Q NEW ROSHAN PURA NAJAFGARH,ROSHANPURA COLONY NAJAFGARH,	841	Other Outage	Planned Outage	21-01-2026	10:22	21-01-2026	12:40	2:18	0.001150	HVDS MAINTENANCE
1773	22-01-2026	Part of : NIRMAL VIHAR DICHAON KALAN	1067	Other Outage	Unplanned Outage	22-01-2026	16:16	22-01-2026	17:13	0:57	0.001425	ATTENDING WEAK POINTS/HOT SPOT
1774	22-01-2026	Part of : NIRMAL VIHAR DICHAON KALAN	1067	Other Outage	Unplanned Outage	22-01-2026	13:54	22-01-2026	14:53	0:59	0.000656	REPAIRING OF HTAB CIRCUIT
1775	22-01-2026	Part of : NAJAFGARH EXTENSION NAJAFGARH,AJAY PARK MASUDABAD NAJAFGARH,NATHU RAM PARK MASUDABAD NAJAFGARH	724	Other Outage	Planned Outage	22-01-2026	15:07	22-01-2026	17:11	2:04	0.000689	DT REPLACEMENT PER DT
1776	22-01-2026	Part of : SHYAM VIHAR I NAJAFGARH,BLOCK E SHYAM VIHAR I NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH	1467	Other Outage	Planned Outage	22-01-2026	12:46	22-01-2026	15:46	3:00	0.001500	REPLACEMENT OF LT BUSHING ROD
1777	22-01-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH	1107	Other Outage	Planned Outage	22-01-2026	10:41	22-01-2026	13:34	2:53	0.004325	3PH HT AB CABLE REPLACEMENT PER SPAN
1778	22-01-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR,DURGA PARK NAJAFGARH	689	Other Outage	Planned Outage	22-01-2026	11:00	22-01-2026	13:54	2:54	0.002900	REPLACEMENT OF LT BUSHING ROD
1779	22-01-2026	Part of : NANAK HERI VILLAGE,RAGHOPUR VILLAGE	816	Other Outage	Planned Outage	22-01-2026	11:16	22-01-2026	14:33	3:17	0.004925	REPLACEMENT OF GAS KIT AND OIL SEAL
1780	22-01-2026	Part of : GOYALA DAIRY QUTUB VIHAR	228	Other Outage	Planned Outage	22-01-2026	14:29	22-01-2026	17:10	2:41	0.000000	LT AB SAGGING PER SPAN
1781	23-01-2026	Part of : NANGLI SANKRANTI & NANGLI SAKRAWATI,B-BLOCK INDRA PARK MASUDABAD NAJAFGARH	735	Other Outage	Unplanned Outage	23-01-2026	09:50	23-01-2026	10:43	0:53	0.000000	CABLE FAULT
1782	23-01-2026	Part of : NANGLI SANKRANTI & NANGLI SAKRAWATI,B-BLOCK INDRA PARK MASUDABAD NAJAFGARH	978	Other Outage	Unplanned Outage	23-01-2026	07:54	23-01-2026	08:29	0:35	0.000700	TREE TOUCHING
1783	24-01-2026	Part of : LOKESH PARK EXTN NAJAFGARH, INDRA MARKET, NEW HIRA NAGAR DICHAON KALAN	7743	Other Outage	Unplanned Outage	24-01-2026	08:35	24-01-2026	08:53	0:18	0.000185	CABLE FAULT
1784	24-01-2026	Part of : GOYALA DAIRY QUTUB VIHAR,GOYALA KHURD	2037	Other Outage	Planned Outage	24-01-2026	11:10	24-01-2026	12:53	1:43	0.001717	REPLACEMENT OF GAS KIT AND OIL SEAL
1785	24-01-2026	Part of : ANAND VIHAR NANGLI SAKRAWATI,NANGLI SANKRANTI NANGLI SAKRAWATI	679	Other Outage	Planned Outage	24-01-2026	11:07	24-01-2026	13:38	2:31	0.000839	3PH HT AB CABLE REPLACEMENT PER SPAN
1786	24-01-2026	Part of : ASALATPUR KHAWAD	339	Other Outage	Planned Outage	24-01-2026	11:55	24-01-2026	14:43	2:48	0.000000	REPLACEMENT OF LT BUSHING ROD
1787	24-01-2026	Part of : RANAJI ENCLAVE MASUDABAD NAJAFGARH	877	Other Outage	Planned Outage	24-01-2026	10:51	24-01-2026	12:55	2:04	0.001206	3PH HT AB CABLE REPLACEMENT PER SPAN
1788	24-01-2026	Part of : SECTOR 27 DWARKA	1	Other Outage	Planned Outage	24-01-2026	10:51	24-01-2026	12:52	2:01	0.000000	REPLACEMENT OF LT BUSHING ROD
1789	24-01-2026	Part of : SULTAN GARDEN	504	Other Outage	Planned Outage	24-01-2026	11:53	24-01-2026	14:43	2:50	0.000944	REPLACEMENT OF LT BUSHING ROD
1790	24-01-2026	Part of : TODARMAL COLONY NAJAFGARH	409	Other Outage	Planned Outage	24-01-2026	10:38	24-01-2026	13:21	2:43	0.004075	3PH HT AB CABLE REPLACEMENT PER SPAN
1791	27-01-2026	Part of : BLOCK B NAVEEN PALACE & SARASWATI KUNJ JHARODA KALAN	1280	Other Outage	Planned Outage	27-01-2026	13:15	27-01-2026	16:07	2:52	0.000956	REPLACEMENT OF HT BUSHING ROD
1792	27-01-2026	Part of : BLOCK A QUTUB VIHAR PHASE 1,GOYALA DAIRY	329	Other Outage	Planned Outage	27-01-2026	12:06	27-01-2026	15:25	3:19	0.003317	REPLACEMENT OF GAS KIT AND OIL SEAL
1793	27-01-2026	Part of : TODARMAL COLONY NAJAFGARH	160	Other Outage	Planned Outage	27-01-2026	12:01	27-01-2026	14:28	2:27	0.003675	3PH HT AB CABLE REPLACEMENT
1794	27-01-2026	Part of : SECTOR 27 DWARKA	3	Other Outage	Planned Outage	27-01-2026	11:59	27-01-2026	14:02	2:03	0.000000	REPLACEMENT OF HT BUSHING ROD
1795	28-01-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH	167	Other Outage	Planned Outage	28-01-2026	11:38	28-01-2026	13:32	1:54	0.002850	3PH HT AB CABLE REPLACEMENT PER SPAN
1796	28-01-2026	Part of : DHARAMPURA NAJAFGARH	1176	Other Outage	Planned Outage	28-01-2026	11:23	28-01-2026	15:34	4:11	0.002092	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD
1797	28-01-2026	Part of : SURYA VIHAR DINPUR,SHIV PURI II DINPUR,GANDHI PARK DINPUR,KANGANHERI VILLAGE	2601	Other Outage	Planned Outage	28-01-2026	11:46	28-01-2026	14:51	3:05	0.003597	REPLACEMENT OF GAS KIT AND OIL SEAL
1798	28-01-2026	Part of : BLOCK B SECTOR 19 DWARKA	449	Other Outage	Planned Outage	28-01-2026	11:48	28-01-2026	17:24	5:36	0.004667	REPLACEMENT OF HT BUSHING ROD
1799	28-01-2026	Part of : ARJUN PARK NANGLI SAKRAWATI,ANAND VIHAR NANGLI SAKRAWATI	1013	Other Outage	Planned Outage	28-01-2026	11:34	28-01-2026	14:11	2:37	0.000872	3PH HT AB CABLE REPLACEMENT PER SPAN
1800	29-01-2026	Part of : BLOCK B POCHANPUR DWARKA,	1004	Other Outage	Planned Outage	29-01-2026	13:07	29-01-2026	14:25	1:18	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1801	29-01-2026	Part of : JHARODA KALAN,	465	Other Outage	Planned Outage	29-01-2026	13:42	29-01-2026	16:59	3:17	0.003283	REPLACEMENT OF HT BUSHING ROD
1802	29-01-2026	Part of : SAMTA ENCLAVE QUTUB VIHAR,	1157	Other Outage	Planned Outage	29-01-2026	13:08	29-01-2026	16:59	3:51	0.003850	REPLACEMENT OF GAS KIT AND OIL SEAL
1803	29-01-2026	Part of : TODARMAL COLONY NAJAFGARH,ROSHAN VIHAR NAJAFGARH,	344	Other Outage	Planned Outage	29-01-2026	11:16	29-01-2026	14:13	2:57	0.004425	3PH HT AB CABLE REPLACEMENT PER SPAN
1804	29-01-2026	Part of : BLOCK Q NEW ROSHAN PURA NAJAFGARH,	236	Other Outage	Planned Outage	29-01-2026	10:06	29-01-2026	12:58	2:52	0.001433	3PH HT AB CABLE REPLACEMENT PER SPAN
1805	30-01-2026	Part of : BLOCK A1 ROSHAN GARDEN MASUDABAD NAJAFGARH	582	Other Outage	Planned Outage	30-01-2026	16:05	30-01-2026	17:04	0:59	0.000328	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1806	30-01-2026	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	2	Other Outage	Planned Outage	30-01-2026	16:03	30-01-2026	17:09	1:06	0.000458	REPLACEMENT OF HT BUSHING ROD
1807	30-01-2026	Part of : QUTUB VIHAR PHASE 2 QUTUB VIHAR,SOMESH VIHAR CHAWLA,CHAWLA	4702	Other Outage	Planned Outage	30-01-2026	11:08	30-01-2026	15:08	4:00	0.007333	GUARD WIRE LACS INSTALLTION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1808	30-01-2026	Part of : GOYALA DAIRY QUTUB VIHAR,GOYLA KHURD,BLOCK A GOYLA KHURD,GOYLA BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR,PAHARWA COLONY CHAWLA	1	Other Outage	Planned Outage	30-01-2026	11:37	30-01-2026	15:10	3:33	0.003550	REPLACEMENT OF GAS KIT AND OIL SEAL
1809	30-01-2026	Part of : DURGA VIHAR II DINPUR,DURGA VIHAR I DINPUR,DATA RAM PARK DINPUR,MUNIRKA KUNJ DINPUR,SHANTI VIHAR DINPUR	997	Other Outage	Planned Outage	30-01-2026	11:15	30-01-2026	13:40	2:25	0.002819	3PH HT AB CABLE REPLACEMENT PER SPAN
1810	30-01-2026	Part of : LOKESH PARK EXTN NAJAFGARH,LOKESH PARK NAJAFGARH,INDRA MARKET	685	Other Outage	Planned Outage	30-01-2026	11:29	30-01-2026	15:12	3:43	0.001239	3PH HT AB CABLE REPLACEMENT PER SPAN
1811	30-01-2026	Part of : BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR	560	Other Outage	Planned Outage	30-01-2026	10:39	30-01-2026	15:11	4:32	0.001133	LT AB SAGGING PER SPAN
1812	31-01-2026	Part of : SURYA VIHAR,SHIV PURI-2,GANDHI PARK,KANGANHERI VILLAGE,REWLA KHANPUR VILLAGE,BADUSARAI,CHAWLA	2602	Other Outage	Planned Outage	31-01-2026	11:16	31-01-2026	13:10	1:54	0.001900	REPLACEMENT OF GAS KIT AND OIL SEAL
1813	31-01-2026	Part of : A-BLOCK QUTUB VIHAR PHASE 1	745	Other Outage	Planned Outage	31-01-2026	11:40	31-01-2026	13:18	1:38	0.000272	LT CIRCUIT MAINTENANCE
1814	31-01-2026	Part of : SHIV ENCLAVE,SAINIK NIKETAN,SULTAN GARDEN,NEW HEERA PARK NAJAFGARH	445	Other Outage	Planned Outage	31-01-2026	12:22	31-01-2026	15:02	2:40	0.000889	3PH HT AB CABLE REPLACEMENT
1815	31-01-2026	Part of : NIRMAL VIHAR DICHANON KALAN	1067	Other Outage	Planned Outage	31-01-2026	11:06	31-01-2026	13:59	2:53	0.000961	REPLACEMENT OF HT BUSHING ROD
1816	31-01-2026	Part of : NAJAFGARH EXTENSION	197	Other Outage	Planned Outage	31-01-2026	11:51	31-01-2026	14:33	2:42	0.001350	REPLACEMENT OF HT BUSHING ROD
1817	31-01-2026	Part of : DURGA VIHAR I DINPUR	807	Other Outage	Planned Outage	31-01-2026	10:42	31-01-2026	13:30	2:48	0.004200	3PH HT AB CABLE REPLACEMENT
1818	02-01-2026	Part of : PASCHIM VIHAR EXTENSION PASCHIM VIHAR,RAILWAY COLONY NORTH SHAKURBASTI,MADHUBAN ENCLAVE PUNJABI BAGH	2478	Other Outage	Unplanned Outage	02-01-2026	00:46	02-01-2026	01:37	0:51	0.000567	CABLE FAULT
1819	02-01-2026	Part of : BLOCK C NEW MULTAN NAGAR SHAKURBASTI	1147	Other Outage	Unplanned Outage	02-01-2026	12:03	02-01-2026	12:17	0:14	0.000000	REPAIRING OF TRANSFORMER
1820	02-01-2026	Part of : BLOCK A 1 KRISHNA APARTMENT PASCHIM VIHAR	225	Other Outage	Unplanned Outage	02-01-2026	15:27	02-01-2026	16:18	0:51	0.000000	MOBILE TRANSFORMER REPLACEMENT
1821	02-01-2026	Part of : RAILWAY PRESS (HTC)	1	Other Outage	Planned Outage	02-01-2026	10:59	02-01-2026	11:57	0:58	0.000000	PROOPER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,RELAY REPLACEMENT/VPI/EPI
1822	02-01-2026	Part of : BLOCK A 3 CA APARTMENTS PASCHIM VIHAR	49	Other Outage	Planned Outage	02-01-2026	14:28	02-01-2026	16:12	1:44	0.000289	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1823	02-01-2026	Part of : WEST PUNJABI BAGH PUNJABI BAGH	342	Other Outage	Planned Outage	02-01-2026	12:29	02-01-2026	15:15	2:46	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
1824	02-01-2026	Part of : BLOCK A 3 CA APARTMENTS PASCHIM VIHAR	83	Other Outage	Planned Outage	02-01-2026	11:01	02-01-2026	14:30	3:29	0.000581	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
1825	03-01-2026	Part of : GH 4-BLOCK STATE BANK COLONY PASCHIM VIHAR	147	Other Outage	Unplanned Outage	03-01-2026	13:50	03-01-2026	16:21	2:31	0.000629	REPAIRING OF DEFECTIVE MECHANISM
1826	03-01-2026	Part of : WEST PUNJABI BAGH	76	Other Outage	Planned Outage	03-01-2026	10:31	03-01-2026	13:32	3:01	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
1827	05-01-2026	Part of : IFCI COLONY PASCHIM VIHAR,	402	Other Outage	Planned Outage	05-01-2026	11:13	05-01-2026	13:35	2:22	0.000592	MAINTENANCE OF TRANSFORMER
1828	05-01-2026	Part of : WEST PUNJABI BAGH PUNJABI BAGH,	323	Other Outage	Planned Outage	05-01-2026	10:28	05-01-2026	14:45	4:17	0.000000	MAINTENANCE OF TRANSFORMER
1829	05-01-2026	Part of : HTC:130 TRANSPORT CENTER	1	Other Outage	Planned Outage	05-01-2026	10:13	05-01-2026	14:22	4:09	0.000000	MAINTENANCE OF RMU
1830	06-01-2026	Part of : BLOCK G PUSHKAR ENCLAVE PASCHIM VIHAR	412	Other Outage	Planned Outage	06-01-2026	11:38	06-01-2026	13:59	2:21	0.000392	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1831	06-01-2026	Part of : BLOCK B MADAN PARK PUNJABI BAGH EAST PUNJABI BAGH	150	Other Outage	Planned Outage	06-01-2026	10:31	06-01-2026	14:01	3:30	0.000875	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1832	06-01-2026	Part of : BLOCK C SHIVAJI PARK PUNJABI BAGH	35	Other Outage	Planned Outage	06-01-2026	10:35	06-01-2026	14:00	3:25	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1833	08-01-2026	Part of : ARIHANT NAGAR PUNJABI BAGH,PUNJABI BAGH EXTENSION,WEST PUNJABI BAGH, BOOSTER PUMP (HTC)	1537	Other Outage	Unplanned Outage	08-01-2026	18:08	08-01-2026	18:57	0:49	0.001089	FAULT IN HT CONSUMER PANEL (BOOSTER PUMP)
1834	08-01-2026	Part of : WEST PUNJABI BAGH	213	Other Outage	Planned Outage	08-01-2026	10:56	08-01-2026	14:18	3:22	0.000000	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
1835	08-01-2026	Part of : SPS DJB RING ROAD PUNJABI BAGH (HTC)	1	Other Outage	Planned Outage	08-01-2026	10:10	08-01-2026	14:24	4:14	0.000000	CLEANING OF HT BUSHING PER WAY,PROOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
1836	09-01-2026	Part of : BLOCK D SURYA ENCLAVE SHAKURBASTI,	232	Other Outage	Planned Outage	09-01-2026	11:04	09-01-2026	15:22	4:18	0.000717	MAINTENANCE OF TRANSFORMER
1837	09-01-2026	Part of : PUNJABI BAGH EXTENSION PUNJABI BAGH,	410	Other Outage	Planned Outage	09-01-2026	10:24	09-01-2026	14:35	4:11	0.000000	MAINTENANCE OF TRANSFORMER
1838	10-01-2026	Part of : WEST PUNJABI BAGH PUNJABI BAGH	864	Other Outage	Unplanned Outage	10-01-2026	13:31	10-01-2026	14:20	0:49	0.000789	CABLE FAULT
1839	12-01-2026	Part of : BLOCK BG 6 PASCHIM VIHAR	310	Other Outage	Planned Outage	12-01-2026	11:18	12-01-2026	14:41	3:23	0.000564	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1840	12-01-2026	Part of : PUNJABI BAGH EXTENSION	421	Other Outage	Planned Outage	12-01-2026	10:42	12-01-2026	14:07	3:25	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1841	13-01-2026	Part of : PUNJABI BAGH EXTENSION PUNJABI BAGH	258	Other Outage	Planned Outage	13-01-2026	10:45	13-01-2026	12:01	1:16	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF SILICAGEL IN BREATHEREAINING
1842	13-01-2026	Part of : 19 A PUNJABI BAGH (HTC)	1	Other Outage	Planned Outage	13-01-2026	13:00	13-01-2026	16:11	3:11	0.000000	CLEANING OF HT BUSHING PER WAY,PROOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,RELAY REPLACEMENT/VPI/FPI
1843	13-01-2026	Part of : 10 A PUNJABI BAGH (HTC)	1	Other Outage	Planned Outage	13-01-2026	10:45	13-01-2026	13:03	2:18	0.000000	CLEANING OF HT BUSHING PER WAY,PROOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,RELAY REPLACEMENT/VPI/FPI
1844	14-01-2026	Part of : MADIPUR PUNJABI BAGH,LAL QUARTER ARIHANT NAGAR,RAILWAY COLONY NORTH SHAKURBASTI,PUNJABI BAGH APARTMENT	3294	Other Outage	Unplanned Outage	14-01-2026	13:22	14-01-2026	14:20	0:58	0.001767	HT SYSTEM FAULT
1845	14-01-2026	Part of : WEST PUNJABI BAGH ,PUNJABI BAGH EXTENSION	1087	Other Outage	Unplanned Outage	14-01-2026	09:55	14-01-2026	10:51	0:56	0.001185	BIRADGE
1846	14-01-2026	Part of : AVTAR ENCLAVE PASCHIM VIHAR	644	Other Outage	Planned Outage	14-01-2026	10:57	14-01-2026	14:22	3:25	0.000854	REPLACEMENT OF GAS KIT AND OIL SEAL
1847	15-01-2026	Part of : PUNJABI BAGH EXTENSION	265	Other Outage	Planned Outage	15-01-2026	10:58	15-01-2026	15:04	4:06	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF SILICAGEL IN BREATHER
1848	15-01-2026	Part of : BLOCK A 3 CA APARTMENTS PASCHIM VIHAR	25	Other Outage	Planned Outage	15-01-2026	10:58	15-01-2026	15:05	4:07	0.000686	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
1849	16-01-2026	Part of : JWALAHARI VILLAGE PASCHIM VIHAR	297	Other Outage	Planned Outage	16-01-2026	13:49	16-01-2026	14:46	0:57	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1850	16-01-2026	Part of : POCKET B KAILASHPURI EAST MAIN PALAM,BLOCK RZ KAMAL PARK KAILASHPURI MAIN PALAM	138	Other Outage	Planned Outage	16-01-2026	11:13	16-01-2026	13:49	2:36	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1851	16-01-2026	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE	184	Other Outage	Planned Outage	16-01-2026	10:41	16-01-2026	13:56	3:15	0.000542	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
1852	17-01-2026	Part of : KARAMPURA INDUSTRIAL AREA KARAMPURA,BLOCK C KARAMPURA MARKET KARAMPURA	1642	Other Outage	Unplanned Outage	17-01-2026	12:10	17-01-2026	12:56	0:46	0.000375	HT SYSTEM FAULT
1853	18-01-2026	Part of : SWAYAMSIDHA COLONY,PUNJABI BAGH APARTMENT,ARIHANT NAGAR PUNJABI BAGH	2027	Other Outage	Unplanned Outage	18-01-2026	12:42	18-01-2026	12:52	0:10	0.000139	REPAIRING OF RMU
1854	19-01-2026	Part of : A & P-BLOCK NEW MOTI NAGAR,KARAMPURA INDUSTRIAL AREA,HOUSE COMPLEX MARKET KARAMPURA INDUSTRIAL AREA	1498	Other Outage	Unplanned Outage	19-01-2026	10:43	19-01-2026	11:28	0:45	0.000910	HT SYSTEM FAULT
1855	19-01-2026	Part of : B-BLOCK PASCHIM PURI PASCHIM VIHAR	394	Other Outage	Unplanned Outage	19-01-2026	15:48	19-01-2026	16:47	0:59	0.000164	MOBILE TRANSFORMER REPLACEMENT
1856	19-01-2026	Part of : WEST PUNJABI BAGH	76	Other Outage	Unplanned Outage	19-01-2026	14:26	19-01-2026	15:51	1:25	0.000354	MOBILE TRANSFORMER REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1857	19-01-2026	Part of : COTTAGE ENCLAVE PASCHIM VIHAR	323	Other Outage	Planned Outage	19-01-2026	11:25	19-01-2026	12:31	1:06	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
1858	19-01-2026	Part of : COTTAGE ENCLAVE PASCHIM VIHAR	114	Other Outage	Planned Outage	19-01-2026	12:30	19-01-2026	14:56	2:26	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
1859	19-01-2026	Part of : KRK HOSPITALITY NAJAFGARH ROAD (HT CONSUMER)	1	Other Outage	Planned Outage	19-01-2026	10:13	19-01-2026	14:14	4:01	0.001004	CONNECTING OF NEW EARTHING PER EARTHING,GUARD WIRE LACS INSTALLTION
1860	20-01-2026	Part of : BLOCK H & I KARAMPURA WEST, PUNJABI BAGH COOPERATIVE HOUSING SOCEITY PUNJABI BAGH EAST, T.C. BLOCK NEW MOTI NAGAR	2884	Other Outage	Unplanned Outage	20-01-2026	14:39	20-01-2026	14:53	0:14	0.000097	CABLE FAULT
1861	20-01-2026	Part of : WEST PUNJABI BAGH	286	Other Outage	Planned Outage	20-01-2026	10:25	20-01-2026	13:41	3:16	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
1862	20-01-2026	Part of : POCKET GH1 PASCHIM VIHAR	112	Other Outage	Planned Outage	20-01-2026	10:50	20-01-2026	13:35	2:45	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
1863	21-01-2026	Part of : POCKET GH2 DISTRICT PARK PASCHIM VIHAR,BLOCK A PASCHIM VIHAR,BLOCK C NEW MULTAN NAGAR SHAKURBASTI,POCKET GH1 PASCHIM VIHAR	2585	Other Outage	Unplanned Outage	21-01-2026	16:19	21-01-2026	17:10	0:51	0.000676	TRANSIENT FAULT
1864	21-01-2026	Part of : BLOCK C SURYA ENCLAVE SHAKURBASTI,BLOCK M SURYA ENCLAVE SHAKURBASTI,NEW MULTAN NAGAR SHAKURBASTI	2098	Other Outage	Unplanned Outage	21-01-2026	13:07	21-01-2026	13:47	0:40	0.000110	BIRDAGE
1865	21-01-2026	Part of : BLOCK BG 1 PASCHIM VIHAR,	283	Other Outage	Unplanned Outage	21-01-2026	13:32	21-01-2026	16:50	3:18	0.000000	TRANSFORMER REPLACEMENT
1866	21-01-2026	Part of : BLOCK A PASCHIM VIHAR,	12	Other Outage	Planned Outage	21-01-2026	10:38	21-01-2026	12:37	1:59	0.000000	TRANSFORMER MAINTENANCE
1867	21-01-2026	Part of : WEST PUNJABI BAGH PUNJABI BAGH,	19	Other Outage	Planned Outage	21-01-2026	11:08	21-01-2026	14:01	2:53	0.000481	TRANSFORMER MAINTENANCE
1868	22-01-2026	Part of : POCKET 1 PASCHIM PURI PASCHIM VIHAR,POCKET 3 PASCHIM PURI PASCHIM VIHAR	2037	Other Outage	Unplanned Outage	22-01-2026	16:22	22-01-2026	17:08	0:46	0.000256	CABLE FAULT
1869	22-01-2026	Part of : POCKET GH2 DISTRICT PARK PASCHIM VIHAR,BLOCK E NEW MULTAN NAGAR SHAKURBASTI,BLOCK A PASCHIM VIHAR,POCKET GH1 PASCHIM VIHAR	2584	Other Outage	Unplanned Outage	22-01-2026	13:10	22-01-2026	13:53	0:43	0.000375	CABLE FAULT
1870	22-01-2026	Part of : DIVISHA PROJECTS (HTC) ,8A NJF ROAD	1	Other Outage	Planned Outage	22-01-2026	13:13	22-01-2026	13:52	0:39	0.000162	CONNECTING OF NEW EARTHING PER EARTHING,GUARD WIRE LACS INSTALLTION PER SPAN
1871	22-01-2026	Part of : INDIRA COLONY TRI NAGAR	828	Other Outage	Planned Outage	22-01-2026	13:51	22-01-2026	16:11	2:20	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER
1872	22-01-2026	Part of : BLOCK A 6 PASCHIM VIHAR	76	Other Outage	Planned Outage	22-01-2026	10:27	22-01-2026	13:11	2:44	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1873	22-01-2026	Part of : BLOCK H SHIVAJI PARK PUNJABI BAGH	130	Other Outage	Planned Outage	22-01-2026	10:31	22-01-2026	13:41	3:10	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1874	23-01-2026	Part of : MADIPUR PUNJABI BAGH,LAL QUARTER ARIHANT NAGAR,RAILWAY COLONY NORTH SHAKURBASTI,PUNJABI BAGH APARTMENT	3291	Other Outage	Unplanned Outage	23-01-2026	09:22	23-01-2026	10:37	1:15	0.001188	CABLE FAULT
1875	23-01-2026	Part of : POCKET 1 ,A & B-BLOCK PASCHIM PURI PASCHIM VIHAR,WEST PUNJABI BAGH	3140	Other Outage	Unplanned Outage	23-01-2026	08:02	23-01-2026	09:54	1:52	0.001680	CABLE FAULT
1876	24-01-2026	Part of : WEST PUNJABI BAGH, JANTA COLONY PASCHIM VIHAR, MADIPUR COLONY	4351	Other Outage	Unplanned Outage	24-01-2026	04:38	24-01-2026	05:09	0:31	0.000310	CABLE FAULT
1877	25-01-2026	Part of : BLOCK A 5 KRISHNA APARTMENT PASCHIM VIHAR,POCKET GH2 DISTRICT PARK PASCHIM VIHAR,BLOCK A 5B PASCHIM VIHAR	2539	Other Outage	Unplanned Outage	25-01-2026	17:49	25-01-2026	18:41	0:52	0.000479	CABLE FAULT
1878	26-01-2026	Part of : BLOCK E JANTA COLONY PASCHIM VIHAR,PASCHIM VIHAR EXTENSION PASCHIM VIHAR	4542	Other Outage	Unplanned Outage	26-01-2026	00:55	26-01-2026	01:19	0:24	0.000160	CABLE FAULT
1879	27-01-2026	Part of : BLOCK A 2 PASCHIM VIHAR	156	Other Outage	Planned Outage	27-01-2026	10:26	27-01-2026	12:26	2:00	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1880	27-01-2026	Part of : GOLDEN PARK TRI NAGAR	13	Other Outage	Planned Outage	27-01-2026	10:20	27-01-2026	12:19	1:59	0.000000	CLEANING OF HT BUSHING PER WAY,PROOPER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
1881	27-01-2026	Part of : BLOCK A 2 PASCHIM VIHAR	241	Other Outage	Planned Outage	27-01-2026	12:24	27-01-2026	14:53	2:29	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
1882	28-01-2026	Part of : BLOCK A 4 NAV BHARAT APPARTEMENTS PASCHIM VIHAR	114	Other Outage	Planned Outage	28-01-2026	12:29	28-01-2026	13:39	1:10	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
1883	28-01-2026	Part of : BLOCK B PASCHIM PURI PASCHIM VIHAR	365	Other Outage	Planned Outage	28-01-2026	11:14	28-01-2026	13:34	2:20	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
1884	28-01-2026	Part of : PUNJABI BAGH COOPERATIVE HOUSING SOCEITY PUNJABI BAGH EAST	369	Other Outage	Planned Outage	28-01-2026	10:26	28-01-2026	13:45	3:19	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
1885	28-01-2026	Part of : BLOCK A 4 NAV BHARAT APPARTEMENTS PASCHIM VIHAR	66	Other Outage	Planned Outage	28-01-2026	10:30	28-01-2026	12:31	2:01	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD
1886	29-01-2026	Part of : HTC: ACTION CANCER HOSPITAL, HTC:BALAJI HOSPITAL PASCHIM VIHAR	0	Other Outage	Unplanned Outage	29-01-2026	12:19	29-01-2026	13:38	1:19	0.001274	FAULT IN HT CONSUMER PANEL (ACTION CANCER HOSPITAL)
1887	29-01-2026	Part of : BLOCK A 4 NAV BHARAT APPARTEMENTS PASCHIM VIHAR,	130	Other Outage	Planned Outage	29-01-2026	12:52	29-01-2026	13:41	0:49	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1888	29-01-2026	Part of : BLOCK A 4 NAV BHARAT APPARTEMENTS PASCHIM VIHAR,	115	Other Outage	Planned Outage	29-01-2026	11:33	29-01-2026	12:54	1:21	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1889	29-01-2026	Part of : PUNJABI BAGH EXTENSION PUNJABI BAGH,	163	Other Outage	Planned Outage	29-01-2026	10:39	29-01-2026	13:43	3:04	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1890	29-01-2026	Part of : BLOCK D MANOHAR PARK PUNJABI BAGH EAST PUNJABI BAGH,	446	Other Outage	Planned Outage	29-01-2026	10:43	29-01-2026	13:43	3:00	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER , REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1891	30-01-2026	Part of : BLOCK F SUDARSHAN PARK	14	Other Outage	Planned Outage	30-01-2026	14:53	30-01-2026	16:34	1:41	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1892	30-01-2026	Part of : RAILWAY COLONY NORTH SHAKURBASTI	4	Other Outage	Planned Outage	30-01-2026	12:21	30-01-2026	13:48	1:27	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1893	30-01-2026	Part of : SHIVA ENCLAVE PASCHIM VIHAR	188	Other Outage	Planned Outage	30-01-2026	12:22	30-01-2026	13:47	1:25	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1894	30-01-2026	Part of : MADHUBAN ENCLAVE PUNJABI BAGH	750	Other Outage	Planned Outage	30-01-2026	10:34	30-01-2026	12:23	1:49	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1895	30-01-2026	Part of : SHIVA ENCLAVE PASCHIM VIHAR	161	Other Outage	Planned Outage	30-01-2026	10:34	30-01-2026	12:22	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1896	31-01-2026	Part of : A 2B-BLOCK PASCHIM VIHAR	1	Other Outage	Planned Outage	31-01-2026	11:00	31-01-2026	15:15	4:15	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF SILICAGEL IN BREATHER
1897	31-01-2026	Part of : WEST PUNJABI BAGH	127	Other Outage	Planned Outage	31-01-2026	10:59	31-01-2026	15:14	4:15	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF SILICAGEL IN BREATHER
1898	01-01-2026	Part of : POCKET 2 SECTOR 1 DWARKA,SECTOR 1 DWARKA,POCKET 3 SECTOR 1 DWARKA	1513	Other Outage	Unplanned Outage	01-01-2026	05:01	01-01-2026	05:37	0:36	0.000000	HT SYSTEM FAULT
1899	01-01-2026	Part of : INDRA PARK PALEM KAILASHPURI MAIN PALAM,POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM	3528	Other Outage	Planned Outage	01-01-2026	12:13	01-01-2026	13:50	1:37	0.000539	1PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,LT BUSHING REPLACEMENT
1900	01-01-2026	Part of : SECTOR 1 DWARKA,	598	Other Outage	Planned Outage	01-01-2026	11:39	01-01-2026	13:50	2:11	0.000728	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1901	01-01-2026	Part of : HTC:MOUNT EVEREST CGHS, PT-17, SEC-9,DWK	1	Other Outage	Planned Outage	01-01-2026	11:13	01-01-2026	13:56	2:43	0.000906	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
1902	02-01-2026	Part of : BLOCK F DASRATHPURI	967	Other Outage	Planned Outage	02-01-2026	12:28	02-01-2026	13:18	0:50	0.000139	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1903	02-01-2026	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM	2062	Other Outage	Planned Outage	02-01-2026	10:51	02-01-2026	13:33	2:42	0.000900	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
1904	02-01-2026	Part of : MANGALPURI I PALAM	1065	Other Outage	Planned Outage	02-01-2026	12:06	02-01-2026	14:54	2:48	0.000933	LT AB SAGGING PER SPAN
1905	02-01-2026	Part of : BLOCK A SECTOR 8 DWARKA	183	Other Outage	Planned Outage	02-01-2026	10:59	02-01-2026	13:16	2:17	0.000761	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
1906	02-01-2026	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1	450	Other Outage	Planned Outage	02-01-2026	11:13	02-01-2026	13:17	2:04	0.000689	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
1907	02-01-2026	Part of : BLOCK H SITAPURI PART 2 SITAPURI	1734	Other Outage	Planned Outage	02-01-2026	11:01	02-01-2026	13:52	2:51	0.000950	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
1908	02-01-2026	Part of : BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR	872	Other Outage	Planned Outage	02-01-2026	10:22	02-01-2026	13:15	2:53	0.000961	LT AB SAGGING PER SPAN
1909	03-01-2026	Part of : MIRZAPUR MAHAVIR ENCLAVE,NANDA BLOCK MAHAVIR ENCLAVE PART-1	1633	Other Outage	Unplanned Outage	03-01-2026	03:26	03-01-2026	04:15	0:49	0.000327	HT SYSTEM FAULT
1910	03-01-2026	Part of : POCKET 10 SECTOR I DASRATHPURI	152	Other Outage	Planned Outage	03-01-2026	13:29	03-01-2026	14:52	1:23	0.000231	LT CIRCUIT MAINTENANCE
1911	03-01-2026	Part of : DABRI VILLAGE	688	Other Outage	Planned Outage	03-01-2026	11:58	03-01-2026	14:16	2:18	0.000383	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING ,OIL TOP UP IN TRANSFORMER
1912	03-01-2026	Part of : BLOCK C SADH NAGAR II PALAM	923	Other Outage	Planned Outage	03-01-2026	10:36	03-01-2026	13:23	2:47	0.000000	LT CIRCUIT MAINTENANCE
1913	03-01-2026	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1	538	Other Outage	Planned Outage	03-01-2026	11:30	03-01-2026	14:16	2:46	0.000922	LT CIRCUIT MAINTENANCE
1914	05-01-2026	Part of : SECTOR 23 DWARKA,	220	Other Outage	Planned Outage	05-01-2026	12:43	05-01-2026	13:36	0:53	0.000294	MAINTENANCE OF LT CIRCUIT
1915	05-01-2026	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,	973	Other Outage	Planned Outage	05-01-2026	14:14	05-01-2026	16:11	1:57	0.000650	MAINTENANCE OF HVDS CIRCUIT
1916	05-01-2026	Part of : BLOCK G VIJAY ENCLAVE MAHAVIR ENCLAVE,	2421	Other Outage	Planned Outage	05-01-2026	12:59	05-01-2026	14:08	1:09	0.000192	MAINTENANCE OF TRANSFORMER
1917	05-01-2026	Part of : VAISHALI COLONY DASRATHPURI,	259	Other Outage	Planned Outage	05-01-2026	11:54	05-01-2026	14:43	2:49	0.000939	MAINTENANCE OF LT CIRCUIT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1918	05-01-2026	Part of : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE,	483	Other Outage	Planned Outage	05-01-2026	10:57	05-01-2026	13:44	2:47	0.000928	MAINTENANCE OF LT TRANSFORMER
1919	05-01-2026	Part of : PALAM COLONY SADH NAGAR 1 PALAM,	1388	Other Outage	Planned Outage	05-01-2026	11:20	05-01-2026	14:07	2:47	0.000928	MAINTENANCE OF LT TRANSFORMER
1920	06-01-2026	Part of : SECTOR 9 DWARKA	4	Other Outage	Planned Outage	06-01-2026	15:38	06-01-2026	16:32	0:54	0.000300	SUB STATION CLEANING
1921	06-01-2026	Part of : SECTOR 9 DWARKA	38	Other Outage	Planned Outage	06-01-2026	14:00	06-01-2026	15:27	1:27	0.000483	SUB STATION CLEANING
1922	06-01-2026	Part of : SECTOR 9 DWARKA	1	Other Outage	Planned Outage	06-01-2026	10:51	06-01-2026	12:23	1:32	0.000511	SUB STATION CLEANING
1923	06-01-2026	Part of : BLOCK G SAGARPUR WEST SAGARPUR,BLOCK J SAGARPUR WEST SAGARPUR	647	Other Outage	Planned Outage	06-01-2026	11:32	06-01-2026	14:25	2:53	0.000961	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,HT BUSHING ROD REPLACEMENT
1924	06-01-2026	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM	2062	Other Outage	Planned Outage	06-01-2026	11:04	06-01-2026	13:57	2:53	0.000961	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
1925	06-01-2026	Part of : VAISHALI EXTENSION DASRATHPURI	607	Other Outage	Planned Outage	06-01-2026	12:25	06-01-2026	15:20	2:55	0.000972	LT AB SAGGING PER SPAN
1926	06-01-2026	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI	1665	Other Outage	Planned Outage	06-01-2026	12:35	06-01-2026	15:26	2:51	0.000950	LT AB SAGGING PER SPAN
1927	06-01-2026	Part of : SECTOR 7 DWARKA	198	Other Outage	Planned Outage	06-01-2026	11:20	06-01-2026	14:12	2:52	0.000956	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER,OIL TOP UP IN TRANSFORMER
1928	06-01-2026	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM	331	Other Outage	Planned Outage	06-01-2026	11:49	06-01-2026	14:40	2:51	0.000950	LT AB SAGGING PER SPAN
1929	06-01-2026	Part of : BLOCK A RAJ NAGAR 1 RAJ NAGAR	976	Other Outage	Planned Outage	06-01-2026	12:05	06-01-2026	14:06	2:01	0.000672	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL
1930	07-01-2026	Part of : B-BLOCK SADH NAGAR-2 PALAM	1470	Other Outage	Unplanned Outage	07-01-2026	03:01	07-01-2026	03:35	0:34	0.000123	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1931	07-01-2026	Part of : SECTOR 8 DWARKA	2	Other Outage	Planned Outage	07-01-2026	15:36	07-01-2026	16:45	1:09	0.000383	LT CIRCUIT MAINTENANCE
1932	07-01-2026	Part of : SECTOR 9 DWARKA	54	Other Outage	Planned Outage	07-01-2026	12:59	07-01-2026	14:29	1:30	0.000500	LT CIRCUIT MAINTENANCE
1933	07-01-2026	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	778	Other Outage	Planned Outage	07-01-2026	11:37	07-01-2026	13:02	1:25	0.000236	LT CIRCUIT MAINTENANCE
1934	07-01-2026	Part of : SECTOR 8 DWARKA	3	Other Outage	Planned Outage	07-01-2026	11:00	07-01-2026	12:20	1:20	0.000444	LT CIRCUIT MAINTENANCE
1935	07-01-2026	Part of : INDRA PARK PALEM KAILASHPURI MAIN	2902	Other Outage	Planned Outage	07-01-2026	10:27	07-01-2026	13:13	2:46	0.000922	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
1936	07-01-2026	Part of : PALAM VILLAGE PALAM	40	Other Outage	Planned Outage	07-01-2026	11:10	07-01-2026	14:00	2:50	0.000944	LT CIRCUIT MAINTENANCE
1937	07-01-2026	Part of : POCKET 10 SECTOR I DASRATHPURI	366	Other Outage	Planned Outage	07-01-2026	11:32	07-01-2026	14:20	2:48	0.000933	LT CIRCUIT MAINTENANCE
1938	07-01-2026	Part of : BLOCK P RAJ NAGAR EXTENSION	379	Other Outage	Planned Outage	07-01-2026	11:19	07-01-2026	14:11	2:52	0.000956	LT CIRCUIT MAINTENANCE
1939	07-01-2026	Part of : BLOCK P RAJ NAGAR EXTENSION	870	Other Outage	Planned Outage	07-01-2026	11:43	07-01-2026	14:32	2:49	0.000939	LT CIRCUIT MAINTENANCE
1940	08-01-2026	Part of : SECTOR 8 DWARKA	5	Other Outage	Planned Outage	08-01-2026	15:44	08-01-2026	16:44	1:00	0.000333	SUB STATION CLEANING
1941	08-01-2026	Part of : BLOCK B SECTOR 8 DWARKA	1	Other Outage	Planned Outage	08-01-2026	13:33	08-01-2026	15:09	1:36	0.000533	SUB STATION CLEANING
1942	08-01-2026	Part of : SECTOR 20 DWARKA	2	Other Outage	Planned Outage	08-01-2026	12:06	08-01-2026	13:11	1:05	0.000361	SUB STATION CLEANING
1943	08-01-2026	Part of : MAHAVIR ENCLAVE PART 2	1081	Other Outage	Planned Outage	08-01-2026	11:13	08-01-2026	14:03	2:50	0.000944	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
1944	08-01-2026	Part of : MANGALPURI I PALAM	1062	Other Outage	Planned Outage	08-01-2026	13:36	08-01-2026	16:01	2:25	0.000806	LT AB SAGGING PER SPAN
1945	08-01-2026	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM	414	Other Outage	Planned Outage	08-01-2026	12:31	08-01-2026	15:23	2:52	0.000956	LT AB SAGGING PER SPAN
1946	08-01-2026	Part of : BLOCK D PALAM EXTENSION	622	Other Outage	Planned Outage	08-01-2026	11:47	08-01-2026	14:32	2:45	0.000917	LT AB SAGGING PER SPAN
1947	08-01-2026	Part of : BLOCK C SADH NAGAR II PALAM	754	Other Outage	Planned Outage	08-01-2026	10:58	08-01-2026	13:49	2:51	0.000950	LT AB SAGGING PER SPAN
1948	08-01-2026	Part of : BLOCK R RAGHU NAGAR DABRI	708	Other Outage	Planned Outage	08-01-2026	11:07	08-01-2026	13:57	2:50	0.000944	LT AB SAGGING PER SPAN
1949	08-01-2026	Part of : BLOCK B 2 DASRATHPURI	796	Other Outage	Planned Outage	08-01-2026	11:08	08-01-2026	13:58	2:50	0.000944	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
1950	08-01-2026	Part of : POCKET 1 SECTOR 9 DWARKA	87	Other Outage	Planned Outage	08-01-2026	11:02	08-01-2026	13:51	2:49	0.000939	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR
1951	08-01-2026	Part of : PALAM VILLAGE PALAM	752	Other Outage	Planned Outage	08-01-2026	10:59	08-01-2026	13:50	2:51	0.000950	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1952	09-01-2026	Part of : BLOCK D SECTOR 8 DWARKA,	1	Other Outage	Planned Outage	09-01-2026	15:21	09-01-2026	16:29	1:08	0.000189	MAINTENANCE OF LT TRANSFORMER
1953	09-01-2026	Part of : SECTOR 20 DWARKA,	2	Other Outage	Planned Outage	09-01-2026	12:46	09-01-2026	14:34	1:48	0.000600	MAINTENANCE OF LT TRANSFORMER
1954	09-01-2026	Part of : SECTOR 20 DWARKA,	1	Other Outage	Planned Outage	09-01-2026	11:18	09-01-2026	12:37	1:19	0.000439	MAINTENANCE OF LT TRANSFORMER
1955	09-01-2026	Part of : HTC:SEC-23 PLOT-1 NEW KANCHAN JANGA APPT	1	Other Outage	Planned Outage	09-01-2026	12:06	09-01-2026	15:51	3:45	0.001250	MAINTENANCE OF RMU
1956	09-01-2026	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM,	331	Other Outage	Planned Outage	09-01-2026	12:27	09-01-2026	15:23	2:56	0.000978	MAINTENANCE OF LT CIRCUIT
1957	09-01-2026	Part of : HTC:SEC-22 PLOT-15A KESHV KUNJ	1	Other Outage	Planned Outage	09-01-2026	12:04	09-01-2026	15:53	3:49	0.001272	MAINTENANCE OF RMU

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1958	09-01-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR,	153	Other Outage	Planned Outage	09-01-2026	12:10	09-01-2026	15:01	2:51	0.000950	MAINTENANCE OF LT TRANSFORMER
1959	09-01-2026	Part of : SECTOR 7 DWARKA,	22	Other Outage	Planned Outage	09-01-2026	11:13	09-01-2026	14:04	2:51	0.000950	MAINTENANCE OF LT TRANSFORMER
1960	09-01-2026	Part of : PALAM VILLAGE PALAM,	490	Other Outage	Planned Outage	09-01-2026	11:16	09-01-2026	14:06	2:50	0.000944	MAINTENANCE OF LT CIRCUIT
1961	09-01-2026	Part of : SECTOR 9 DWARKA,	70	Other Outage	Planned Outage	09-01-2026	11:13	09-01-2026	14:05	2:52	0.000956	MAINTENANCE OF LT TRANSFORMER
1962	09-01-2026	Part of : KAILASHPURI MAIN PALAM,KAILASHPURI WEST PALAM,	2062	Other Outage	Planned Outage	09-01-2026	10:45	09-01-2026	13:29	2:44	0.000911	MAINTENANCE OF HVDS
1963	10-01-2026	Part of : SECTOR 22 DWARKA,SECTOR 23 DWARKA,POCKET 1 SECTOR 22 DWARKA,SECTOR 20 DWARKA	1428	Other Outage	Unplanned Outage	10-01-2026	15:18	10-01-2026	15:50	0:32	0.000720	HT SYSTEM FAULT
1964	10-01-2026	PART OF : SECTOR 20 DWARKA	3	Other Outage	Planned Outage	10-01-2026	11:48	10-01-2026	12:26	0:38	0.000211	SUB STATION CLEANING
1965	10-01-2026	PART OF : SECTOR 22 DWARKA	16	Other Outage	Planned Outage	10-01-2026	15:02	10-01-2026	16:04	1:02	0.000344	SUB STATION CLEANING
1966	10-01-2026	PART OF : BLOCK A 1 VIJAY ENCLAVE MAHAVIR ENCLAVE	822	Other Outage	Planned Outage	10-01-2026	14:29	10-01-2026	16:06	1:37	0.000539	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1967	10-01-2026	PART OF : SECTOR 23 DWARKA	3	Other Outage	Planned Outage	10-01-2026	12:43	10-01-2026	13:57	1:14	0.000411	SUB STATION CLEANING
1968	10-01-2026	PART OF : POCKET 13 MANGALPURI I PALAM	462	Other Outage	Planned Outage	10-01-2026	10:49	10-01-2026	14:38	3:49	0.001272	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1969	10-01-2026	PART OF : IB SEC.9 (HTC)	1	Other Outage	Planned Outage	10-01-2026	11:21	10-01-2026	15:14	3:53	0.001294	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1970	10-01-2026	PART OF : SANT MOHALLA SAGARPUR MAIN SAGARPUR	1245	Other Outage	Planned Outage	10-01-2026	11:26	10-01-2026	15:15	3:49	0.001272	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1971	10-01-2026	PART OF : BLOCK A RAJ NAGAR 1 RAJ NAGAR	963	Other Outage	Planned Outage	10-01-2026	10:32	10-01-2026	14:22	3:50	0.001278	DT REPLACEMENT
1972	10-01-2026	PART OF : MAHAVIR ENCLAVE PART 2	1761	Other Outage	Planned Outage	10-01-2026	11:23	10-01-2026	13:46	2:23	0.000794	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
1973	10-01-2026	PART OF : PALAM EXTENSION PALAM	192	Other Outage	Planned Outage	10-01-2026	11:28	10-01-2026	14:18	2:50	0.000944	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1974	10-01-2026	PART OF : BLOCK B SECTOR 8 DWARKA	127	Other Outage	Planned Outage	10-01-2026	11:20	10-01-2026	14:15	2:55	0.000972	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1975	10-01-2026	PART OF : BLOCK D PALAM EXTENSION PALAM	622	Other Outage	Planned Outage	10-01-2026	11:29	10-01-2026	14:16	2:47	0.000928	LT AB SAGGING PER SPAN
1976	10-01-2026	PART OF : BLOCK B CHANDAR VIHAR PALAM EXTENSION PALAM	529	Other Outage	Planned Outage	10-01-2026	11:29	10-01-2026	14:17	2:48	0.000933	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1977	11-01-2026	Part of : SERVICE CENTRE SEC-20 DWARKA	0	Other Outage	Unplanned Outage	11-01-2026	12:53	11-01-2026	13:22	0:29	0.000064	CABLE DAMAGE BY OUTSIDE AGENCY (DTC)
1978	11-01-2026	Part of : SHIKSHA BHARTI EDU. SOCIETY SEC-08 DWARKA (HT CONSUMER)	1	Other Outage	Planned Outage	11-01-2026	14:08	11-01-2026	16:04	1:56	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1979	11-01-2026	Part of : MEDICAL COUNCIL OF INDIA SEC 8, DWARKA (HT CONSUMER)	1	Other Outage	Planned Outage	11-01-2026	14:08	11-01-2026	16:05	1:57	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1980	12-01-2026	Part of : POCKET 4 SECTOR 1 DWARKA	55	Other Outage	Planned Outage	12-01-2026	12:45	12-01-2026	14:09	1:24	0.000467	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
1981	12-01-2026	Part of : BLOCK B2 & C DASRATHPURI,DURGA PARK COLONY DASRATHPURI	870	Other Outage	Planned Outage	12-01-2026	12:47	12-01-2026	15:34	2:47	0.000928	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
1982	12-01-2026	Part of : POCKET B KAILASHPURI EAST,INDIRA PARK EXTENSION KAILASHPURI MAIN	1801	Other Outage	Planned Outage	12-01-2026	11:05	12-01-2026	13:57	2:52	0.000956	1PH HT AB END TERMINATION REPLACEMENT,LT BUSHING REPLACEMENT
1983	12-01-2026	Part of : BLOCK H RAGHU NAGAR DABRI	1290	Other Outage	Planned Outage	12-01-2026	13:12	12-01-2026	16:14	3:02	0.001011	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
1984	12-01-2026	Part of : SADH NAGAR II PALAM	560	Other Outage	Planned Outage	12-01-2026	11:40	12-01-2026	14:31	2:51	0.000950	LT AB SAGGING PER SPAN
1985	13-01-2026	Part of : BLOCK B RAJ NAGAR 2 RAJ NAGAR	181	Other Outage	Planned Outage	13-01-2026	12:16	13-01-2026	12:59	0:43	0.000239	LT AB SAGGING PER SPAN
1986	13-01-2026	Part of : CRPF MAHILA BN SEC-8 (HTC)	2	Other Outage	Planned Outage	13-01-2026	11:47	13-01-2026	15:39	3:52	0.001289	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1987	13-01-2026	Part of : SEC-7 PLOT-3 RASHI APPT (HTC)	1	Other Outage	Planned Outage	13-01-2026	11:27	13-01-2026	14:20	2:53	0.000961	AUXILARY SUPPLY FOR RELAYS,DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,REPLACEMENT OF FAULTY END BOX
1988	13-01-2026	Part of : BLOCK RZ SHIV PURI SAGARPUR WEST SAGARPUR,JAGDAMBA VIHAR SAGARPUR WEST SAGARPUR	4765	Other Outage	Planned Outage	13-01-2026	10:10	13-01-2026	12:50	2:40	0.000889	DT REPLACEMENT
1989	13-01-2026	Part of : SECTOR 9 DWARKA	129	Other Outage	Planned Outage	13-01-2026	10:40	13-01-2026	14:37	3:57	0.001317	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1990	13-01-2026	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM,INDRA PARK PALEM KAILASHPURI MAIN PALAM,KAILASHPURI MAIN PALAM	2902	Other Outage	Planned Outage	13-01-2026	10:13	13-01-2026	12:57	2:44	0.000911	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
1991	13-01-2026	Part of : BLOCK RZ SAGARPUR	157	Other Outage	Planned Outage	13-01-2026	12:22	13-01-2026	14:42	2:20	0.000778	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER
1992	13-01-2026	Part of : POCKET 1 SECTOR 9 DWARKA	123	Other Outage	Planned Outage	13-01-2026	12:29	13-01-2026	15:05	2:36	0.000867	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF HT BUSHING ROD
1993	13-01-2026	Part of : BLOCK D PALAM EXTENSION PALAM	622	Other Outage	Planned Outage	13-01-2026	12:17	13-01-2026	15:06	2:49	0.000939	LT AB SAGGING PER SPAN
1994	13-01-2026	Part of : PALAM VILLAGE PALAM	490	Other Outage	Planned Outage	13-01-2026	12:15	13-01-2026	15:06	2:51	0.000950	LT AB SAGGING PER SPAN
1995	13-01-2026	Part of : BLOCK R RAGHU NAGAR DABRI	708	Other Outage	Planned Outage	13-01-2026	11:00	13-01-2026	13:51	2:51	0.000950	LT AB SAGGING PER SPAN
1996	13-01-2026	Part of : SECTOR 7 DWARKA	3	Other Outage	Planned Outage	13-01-2026	11:28	13-01-2026	14:19	2:51	0.000950	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1997	14-01-2026	Part of : PALAM COLONY SADH NAGAR 1 ,SADH NAGAR II PALAM,KHERA VILLAGE ,BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM	3921	Other Outage	Unplanned Outage	14-01-2026	19:04	14-01-2026	19:37	0:33	0.000549	HT SYSTEM FAULT
1998	14-01-2026	Part of : BLOCK A RAJ NAGAR 1 RAJ NAGAR	879	Other Outage	Planned Outage	14-01-2026	11:14	14-01-2026	12:33	1:19	0.000219	LT CIRCUIT AB SAGGING
1999	14-01-2026	Part of : POCKET 2 SECTOR 9 DWARKA	89	Other Outage	Planned Outage	14-01-2026	14:17	14-01-2026	16:35	2:18	0.000767	REPLACEMENT OF HT/LT CLEATS & OIL TOP UP IN TRANSFORMER
2000	14-01-2026	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI	442	Other Outage	Planned Outage	14-01-2026	11:27	14-01-2026	14:15	2:48	0.000933	REPLACEMENT OF HT/LT CLEATS & OIL TOP UP IN TRANSFORMER
2001	15-01-2026	Part of : PLOT-18 B CROWN RESIDENCY	1	Other Outage	Planned Outage	15-01-2026	14:03	15-01-2026	14:48	0:45	0.000250	GUARD WIRE LACS INSTALLTION
2002	15-01-2026	Part of : BLOCK J SAGARPUR WEST	868	Other Outage	Planned Outage	15-01-2026	14:45	15-01-2026	16:10	1:25	0.000472	LT CIRCUIT MAINTENANCE
2003	15-01-2026	Part of : BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR	326	Other Outage	Planned Outage	15-01-2026	11:39	15-01-2026	14:25	2:46	0.000922	DT REPLACEMENT
2004	15-01-2026	Part of : KAILASHPURI MAIN,KAILASHPURI WEST,INDIRA PARK EXTENSION	2062	Other Outage	Planned Outage	15-01-2026	10:50	15-01-2026	13:33	2:43	0.000906	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
2005	15-01-2026	Part of : BLOCK C SADH NAGAR II PALAM	924	Other Outage	Planned Outage	15-01-2026	11:05	15-01-2026	13:49	2:44	0.000911	LT CIRCUIT MAINTENANCE
2006	15-01-2026	Part of : BLOCK RZ PALAM	305	Other Outage	Planned Outage	15-01-2026	11:31	15-01-2026	14:21	2:50	0.000944	LT CIRCUIT MAINTENANCE
2007	15-01-2026	Part of : SECTOR 1 DWARKA	381	Other Outage	Planned Outage	15-01-2026	11:30	15-01-2026	14:21	2:51	0.000950	LT CIRCUIT MAINTENANCE
2008	15-01-2026	Part of : POCKET 2 SECTOR 9 DWARKA	84	Other Outage	Planned Outage	15-01-2026	11:44	15-01-2026	14:36	2:52	0.000956	LT CIRCUIT MAINTENANCE
2009	15-01-2026	Part of : BLOCK G SAGARPUR WEST	1217	Other Outage	Planned Outage	15-01-2026	11:49	15-01-2026	14:38	2:49	0.000939	LT CIRCUIT MAINTENANCE
2010	16-01-2026	Part of : BLOCK RZ PALAM,PALAM EXTENSION	3080	Other Outage	Unplanned Outage	16-01-2026	16:25	16-01-2026	17:01	0:36	0.000512	CABLE FAULT
2011	16-01-2026	Part of : BLOCK D UTTAM VIHAR BINDAPUR,BLOCK A BHARAT NAGAR MADHU VIHAR	1	Other Outage	Planned Outage	16-01-2026	12:34	16-01-2026	16:34	4:00	0.001333	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2012	16-01-2026	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,BHERA ENCLAVE PASCHIM VIHAR	2611	Other Outage	Planned Outage	16-01-2026	11:16	16-01-2026	14:04	2:48	0.000933	DB REVAMPING,LT BUSHING REPLACEMENT
2013	16-01-2026	Part of : BLOCK B RAJ NAGAR 2	94	Other Outage	Planned Outage	16-01-2026	11:13	16-01-2026	14:03	2:50	0.000944	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
2014	16-01-2026	Part of : BLOCK D JJ COLONY UTTAM NAGAR	1908	Other Outage	Planned Outage	16-01-2026	11:40	16-01-2026	14:34	2:54	0.000967	LT AB SAGGING PER SPAN
2015	16-01-2026	Part of : AMBIKA VIHAR PASCHIM VIHAR	54	Other Outage	Planned Outage	16-01-2026	11:45	16-01-2026	14:36	2:51	0.000950	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR
2016	16-01-2026	Part of : BLOCK B 3A JANAK PURI	1200	Other Outage	Planned Outage	16-01-2026	11:38	16-01-2026	14:30	2:52	0.000956	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR
2017	17-01-2026	Part of : BLOCK RZ PALAM	172	Other Outage	Planned Outage	17-01-2026	12:04	17-01-2026	13:35	1:31	0.000506	MAINTENANCE OF LT TRANSFORMER
2018	17-01-2026	Part of : B BLOCK DASRATHPURI	913	Other Outage	Planned Outage	17-01-2026	11:59	17-01-2026	15:52	3:53	0.001294	MAINTENANCE OF RMU
2019	17-01-2026	Part of : POCKET 13 MANGALPURI II PALAM	746	Other Outage	Planned Outage	17-01-2026	11:05	17-01-2026	14:51	3:46	0.001256	MAINTENANCE OF RMU
2020	17-01-2026	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE	1761	Other Outage	Planned Outage	17-01-2026	11:41	17-01-2026	14:29	2:48	0.000933	MAINTENANCE OF HVDS CIRCUIT
2021	17-01-2026	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM	331	Other Outage	Planned Outage	17-01-2026	14:51	17-01-2026	16:56	2:05	0.000694	MAINTENANCE OF LT CIRCUIT
2022	17-01-2026	Part of : R BLOCK RAGHU NAGAR DABRI	723	Other Outage	Planned Outage	17-01-2026	13:53	17-01-2026	16:19	2:26	0.000406	MAINTENANCE OF LT CIRCUIT
2023	17-01-2026	Part of : D BLOCK PALAM EXTENSION PALAM	622	Other Outage	Planned Outage	17-01-2026	11:38	17-01-2026	14:28	2:50	0.000944	MAINTENANCE OF LT CIRCUIT
2024	17-01-2026	Part of : VAISHALI EXTENSION DASRATHPURI	608	Other Outage	Planned Outage	17-01-2026	11:38	17-01-2026	14:29	2:51	0.000950	MAINTENANCE OF LT CIRCUIT
2025	17-01-2026	Part of : A BLOCK SITAPURI PART 1 SITAPURI	541	Other Outage	Planned Outage	17-01-2026	10:48	17-01-2026	12:57	2:09	0.001039	MAINTENANCE OF LT TRANSFORMER
2026	17-01-2026	Part of : A BLOCK RAJ NAGAR 1 RAJ NAGAR	963	Other Outage	Planned Outage	17-01-2026	10:32	17-01-2026	13:34	3:02	0.001011	MAINTENANCE OF LT CIRCUIT
2027	18-01-2026	Part of : BLOCK B RAJ NAGAR 2	181	Other Outage	Unplanned Outage	18-01-2026	12:48	18-01-2026	16:36	3:48	0.000000	JOINTING OF NEW LT CABLE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2028	18-01-2026	Part of : BLOCK RZ PALAM	306	Other Outage	Unplanned Outage	18-01-2026	11:30	18-01-2026	14:59	3:29	0.000000	JOINTING OF NEW LT CABLE
2029	19-01-2026	Part of : VAISHALI COLONY DASRATHPURI	259	Other Outage	Planned Outage	19-01-2026	13:44	19-01-2026	16:43	2:59	0.000994	REPLACEMENT OF CROSS-ARMS AND POLES
2030	19-01-2026	Part of : SEC-7 PLOT- 19 MEGHDOOT APPTT	1	Other Outage	Planned Outage	19-01-2026	11:22	19-01-2026	14:13	2:51	0.000950	AUXILARY SUPPLY FOR RELAYS,END TERMINATION COVER REPLACEMENT,REPLACEMET OF FAULTY END BOX
2031	19-01-2026	Part of : BLOCK RZ SHIV PURI SAGARPUR WEST	1163	Other Outage	Planned Outage	19-01-2026	10:44	19-01-2026	13:41	2:57	0.000983	REPLACEMET OF HT BUSHING ROD
2032	19-01-2026	Part of : INDRA PARK PALEM KAILASHPURI MAIN PALAM	2902	Other Outage	Planned Outage	19-01-2026	10:43	19-01-2026	13:40	2:57	0.000983	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2033	19-01-2026	Part of : BLOCK A SITAPURI PART 1	972	Other Outage	Planned Outage	19-01-2026	12:21	19-01-2026	14:03	1:42	0.000567	LT CIRCUIT MAINTENANCE WORK
2034	19-01-2026	Part of : PALAM VILLAGE	490	Other Outage	Planned Outage	19-01-2026	12:23	19-01-2026	14:03	1:40	0.000556	LT CIRCUIT MAINTENANCE WORK
2035	19-01-2026	Part of : BLOCK RZ PALAM	306	Other Outage	Planned Outage	19-01-2026	12:22	19-01-2026	15:11	2:49	0.000939	LT CIRCUIT MAINTENANCE WORK
2036	20-01-2026	Part of : BLOCK B DASRATHPURI,DABRI VILLAGE DABRI,VAISHALI EXTENSION DASRATHPURI	246	Other Outage	Planned Outage	20-01-2026	14:04	20-01-2026	15:02	0:58	0.000161	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2037	20-01-2026	Part of : BLOCK D PALAM EXTENSION	622	Other Outage	Planned Outage	20-01-2026	12:44	20-01-2026	13:44	1:00	0.000333	LT AB SAGGING PER SPAN
2038	20-01-2026	Part of : BLOCK F RAJ NAGAR EXTENSION	2596	Other Outage	Planned Outage	20-01-2026	11:14	20-01-2026	14:01	2:47	0.000928	1PH HT AB CABLE REPLACEMENT PER SPAN,LT BUSHING REPLACEMENT
2039	20-01-2026	Part of : BLOCK RZ PALAM	1107	Other Outage	Planned Outage	20-01-2026	11:16	20-01-2026	14:03	2:47	0.000928	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD
2040	20-01-2026	Part of : BLOCK A RAJ NAGAR 1	969	Other Outage	Planned Outage	20-01-2026	11:03	20-01-2026	14:00	2:57	0.000983	LT AB SAGGING PER SPAN
2041	21-01-2026	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1362	Other Outage	Planned Outage	21-01-2026	13:09	21-01-2026	16:04	2:55	0.000972	LT CIRCUIT MAINTENANCE
2042	21-01-2026	Part of : BLOCK G SAGARPUR WEST SAGARPUR,BLOCK J SAGARPUR WEST SAGARPUR,	647	Other Outage	Planned Outage	21-01-2026	12:16	21-01-2026	14:47	2:31	0.000839	HVDS MAINTENANCE
2043	21-01-2026	Part of : SECTOR 8 DWARKA,	129	Other Outage	Planned Outage	21-01-2026	11:31	21-01-2026	14:24	2:53	0.000961	LT TRANSFORMER MAINTENANCE
2044	21-01-2026	Part of : PALAM EXTENSION PALAM,	58	Other Outage	Planned Outage	21-01-2026	11:18	21-01-2026	14:07	2:49	0.000939	RMU MAINTENANCE
2045	21-01-2026	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM,	2062	Other Outage	Planned Outage	21-01-2026	10:56	21-01-2026	13:51	2:55	0.000972	HVDS MAINTENANCE
2046	22-01-2026	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,BLOCK RZ KAMAL PARK KAILASHPURI MAIN PALAM	1801	Other Outage	Planned Outage	22-01-2026	10:32	22-01-2026	13:18	2:46	0.000922	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2047	22-01-2026	Part of : BLOCK A RAJ NAGAR 1 RAJ NAGAR	1075	Other Outage	Planned Outage	22-01-2026	14:13	22-01-2026	15:18	1:05	0.000361	LT AB SAGGING PER SPAN
2048	22-01-2026	Part of : BLOCK B RAJ NAGAR 2 RAJ NAGAR	1911	Other Outage	Planned Outage	22-01-2026	11:15	22-01-2026	13:02	1:47	0.000297	LT AB SAGGING PER SPAN
2049	22-01-2026	Part of : BLOCK H RAGHU NAGAR DABRI	1292	Other Outage	Planned Outage	22-01-2026	14:15	22-01-2026	16:57	2:42	0.000900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
2050	22-01-2026	Part of : BLOCK RZ PALAM	495	Other Outage	Planned Outage	22-01-2026	12:27	22-01-2026	15:20	2:53	0.000961	LT AB SAGGING PER SPAN
2051	22-01-2026	Part of : BLOCK J RAJ NAGAR 2 RAJ NAGAR	1410	Other Outage	Planned Outage	22-01-2026	12:08	22-01-2026	15:01	2:53	0.000961	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
2052	22-01-2026	Part of : PALAM EXTENSION PALAM	37	Other Outage	Planned Outage	22-01-2026	11:15	22-01-2026	14:10	2:55	0.000972	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
2053	22-01-2026	Part of : BLOCK R RAGHU NAGAR DABRI	679	Other Outage	Planned Outage	22-01-2026	11:13	22-01-2026	14:11	2:58	0.000989	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
2054	23-01-2026	Part of : A-BLOCK SECTOR 8 DWARKA,SECTOR 9 DWARKA	395	Other Outage	Unplanned Outage	23-01-2026	10:55	23-01-2026	11:26	0:31	0.000964	TREE TOUCHING
2055	23-01-2026	Part of : BALMIKI VIHAR ,SADH NAGAR-2 PALAM,R-BLOCK INDRA PARK PALEM KAILASHPURI MAIN	4498	Other Outage	Unplanned Outage	23-01-2026	10:28	23-01-2026	11:01	0:33	0.000000	TREE TOUCHING
2056	23-01-2026	Part of : SEC-8,DWARKA,SHASTRI MARG RAJ NAGAR	3387	Other Outage	Unplanned Outage	23-01-2026	10:09	23-01-2026	10:44	0:35	0.000097	TREE TOUCHING
2057	24-01-2026	Part of : BLOCK B & G RAJ NAGAR 2, SECTOR 8 DWARKA	5278	Other Outage	Unplanned Outage	24-01-2026	19:15	24-01-2026	19:48	0:33	0.000733	TREE TOUCHING
2058	24-01-2026	Part of : BLOCK B & G RAJ NAGAR 2, SECTOR 8 DWARKA	5278	Other Outage	Unplanned Outage	24-01-2026	18:10	24-01-2026	18:56	0:46	0.000588	HT SYSTEM FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2059	24-01-2026	Part of : PALAM COLONY SADH NAGAR 1	389	Other Outage	Planned Outage	24-01-2026	13:47	24-01-2026	15:31	1:44	0.000289	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD
2060	24-01-2026	Part of : PALAM EXTENSION	142	Other Outage	Planned Outage	24-01-2026	13:46	24-01-2026	15:32	1:46	0.000294	INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER
2061	24-01-2026	Part of : KAILASHPURI MAIN PALAM,KAILASHPURI WEST PALAM	2062	Other Outage	Planned Outage	24-01-2026	11:18	24-01-2026	13:32	2:14	0.000372	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2062	24-01-2026	Part of : BLOCK F RAJ NAGAR EXTENSION	1362	Other Outage	Planned Outage	24-01-2026	11:54	24-01-2026	14:45	2:51	0.000950	LT AB SAGGING PER SPAN
2063	25-01-2026	Part of : PALAM VIHAR SADH NAGAR 1 PALAM	2733	Other Outage	Unplanned Outage	25-01-2026	14:10	25-01-2026	14:52	0:42	0.000528	BIRDAGE
2064	27-01-2026	Part of : SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION	64	Other Outage	Planned Outage	27-01-2026	13:43	27-01-2026	15:34	1:51	0.000308	BIRD SPIKES INSTALLATION PER POLE,HT SLEEVE INSTALLATION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
2065	27-01-2026	Part of : BLOCK B RAJ NAGAR 2	1911	Other Outage	Planned Outage	27-01-2026	13:04	27-01-2026	14:47	1:43	0.000286	LT AB MAINTENANCE WORK
2066	27-01-2026	Part of : BLOCK D PALAM EXTENSION	607	Other Outage	Planned Outage	27-01-2026	12:03	27-01-2026	13:53	1:50	0.000306	LT CIRCUIT MAINTENANCE
2067	27-01-2026	Part of : BAGDAULA VILLAGE SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION	478	Other Outage	Planned Outage	27-01-2026	13:44	27-01-2026	16:12	2:28	0.000411	BIRD SPIKES INSTALLATION PER POLE,HT SLEEVE INSTALLATION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
2068	27-01-2026	Part of : BLOCK F RAJ NAGAR EXTENSION	1362	Other Outage	Planned Outage	27-01-2026	13:03	27-01-2026	15:48	2:45	0.000917	LT AB MAINTENANCE WORK
2069	27-01-2026	Part of : BLOCK RZ PALAM	306	Other Outage	Planned Outage	27-01-2026	13:10	27-01-2026	15:48	2:38	0.000878	LT AB MAINTENANCE WORK
2070	27-01-2026	Part of : POKKET 6 SECTOR 1 NARSIRPUR	243	Other Outage	Planned Outage	27-01-2026	12:46	27-01-2026	15:34	2:48	0.000933	LT CIRCUIT MAINTENANCE
2071	28-01-2026	Part of : SARGODA APPT., PALAM EXTENSION	375	Other Outage	Unplanned Outage	28-01-2026	01:43	28-01-2026	01:54	0:11	0.000058	HT SYSTEM FAULT
2072	28-01-2026	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY MAHAVIR ENCLAVE PART 2	1761	Other Outage	Planned Outage	28-01-2026	11:10	28-01-2026	13:46	2:36	0.000867	1PH HT AB END TERMINATION REPLACEMENT,LT BUSHING REPLACEMENT
2073	28-01-2026	Part of : BLOCK A RAJ NAGAR 1	873	Other Outage	Planned Outage	28-01-2026	12:48	28-01-2026	15:37	2:49	0.000939	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
2074	28-01-2026	Part of : BLOCK RZ PALAM	305	Other Outage	Planned Outage	28-01-2026	12:33	28-01-2026	14:35	2:02	0.000339	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
2075	28-01-2026	Part of : BLOCK F RAJ NAGAR EXTENSION	1362	Other Outage	Planned Outage	28-01-2026	12:30	28-01-2026	15:24	2:54	0.000967	LT AB SAGGING PER SPAN
2076	28-01-2026	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	779	Other Outage	Planned Outage	28-01-2026	11:24	28-01-2026	13:24	2:00	0.000333	LT AB SAGGING PER SPAN
2077	28-01-2026	Part of : BLOCK C SADH NAGAR II PALAM	961	Other Outage	Planned Outage	28-01-2026	10:50	28-01-2026	13:45	2:55	0.000972	LT AB SAGGING PER SPAN
2078	28-01-2026	Part of : BLOCK A 1 VIJAY ENCLAVE MAHAVIR ENCLAVE	819	Other Outage	Planned Outage	28-01-2026	11:24	28-01-2026	13:24	2:00	0.000333	LT AB SAGGING PER SPAN
2079	28-01-2026	Part of : BLOCK B 2 DASRATHPURI	697	Other Outage	Planned Outage	28-01-2026	11:27	28-01-2026	14:13	2:46	0.000922	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
2080	29-01-2026	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1362	Other Outage	Planned Outage	29-01-2026	13:00	29-01-2026	14:36	1:36	0.000267	LT AB SAGGING PER SPAN
2081	29-01-2026	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM,POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,INDRA PARK PALEM KAILASHPURI MAIN PALAM,	2902	Other Outage	Planned Outage	29-01-2026	12:53	29-01-2026	14:34	1:41	0.000561	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2082	29-01-2026	Part of : BLOCK C DASRATHPURI,BLOCK B 2 DASRATHPURI,	870	Other Outage	Planned Outage	29-01-2026	12:05	29-01-2026	14:01	1:56	0.000322	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT
2083	29-01-2026	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1192	Other Outage	Planned Outage	29-01-2026	12:00	29-01-2026	14:18	2:18	0.000767	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
2084	29-01-2026	Part of : PALAM EXTENSION PALAM,	158	Other Outage	Planned Outage	29-01-2026	11:12	29-01-2026	14:01	2:49	0.000939	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
2085	30-01-2026	Part of : VAISHALI COLONY DASRATHPURI	259	Other Outage	Planned Outage	30-01-2026	11:48	30-01-2026	14:38	2:50	0.000944	CONDUCTOR REPLACEMENT PER SPAN
2086	30-01-2026	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM	2062	Other Outage	Planned Outage	30-01-2026	10:45	30-01-2026	13:33	2:48	0.000933	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING,LT BUSHING REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2087	30-01-2026	Part of : SECTOR 9 DWARKA	8	Other Outage	Planned Outage	30-01-2026	12:21	30-01-2026	15:14	2:53	0.000961	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
2088	30-01-2026	Part of : BLOCK A 1 VIJAY ENCLAVE MAHAVIR ENCLAVE	819	Other Outage	Planned Outage	30-01-2026	11:30	30-01-2026	14:24	2:54	0.000967	LT AB SAGGING PER SPAN
2089	30-01-2026	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1	175	Other Outage	Planned Outage	30-01-2026	11:31	30-01-2026	14:24	2:53	0.000961	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
2090	31-01-2026	Part of : PALAM VILLAGE	468	Other Outage	Planned Outage	31-01-2026	11:28	31-01-2026	13:16	1:48	0.000600	LT CIRCUIT MAINTENANCE
2091	31-01-2026	Part of : POCKET B KAILASHPURI EAST & MAIN PALAM,INDIRA PARK EXTENSION	1801	Other Outage	Planned Outage	31-01-2026	10:34	31-01-2026	13:25	2:51	0.000950	1PH HT AB END TERMINATION REPLACEMENT,DB REVAMPING
2092	31-01-2026	Part of : A-BLOCK MAHAVIR ENCLAVE PART 1	779	Other Outage	Planned Outage	31-01-2026	12:46	31-01-2026	15:45	2:59	0.000994	LT CIRCUIT MAINTENANCE
2093	01-01-2026	Part of : BLOCK G KHAYALA VISHNU GARDEN,	2403	Other Outage	Planned Outage	01-01-2026	11:03	01-01-2026	13:40	2:37	0.003053	REPLACEMENT OF GAS KIT AND OIL SEAL
2094	01-01-2026	Part of : POCKET A RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	10	Other Outage	Planned Outage	01-01-2026	11:04	01-01-2026	13:40	2:36	0.000433	REPLACEMET OF HT BUSHING ROD
2095	02-01-2026	Part of : KRISHNA PARK EXTENSION TILAK NAGAR	626	Other Outage	Planned Outage	02-01-2026	10:47	02-01-2026	13:58	3:11	0.000796	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2096	02-01-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	592	Other Outage	Planned Outage	02-01-2026	11:07	02-01-2026	14:11	3:04	0.000511	REPLACEMENT OF HT BUSHING ROD
2097	02-01-2026	Part of : CHAUKHANDI VISHNU GARDEN	1221	Other Outage	Planned Outage	02-01-2026	11:06	02-01-2026	14:15	3:09	0.000525	REPLACEMENT OF HT BUSHING ROD
2098	02-01-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	809	Other Outage	Planned Outage	02-01-2026	11:07	02-01-2026	14:11	3:04	0.000511	REPLACEMENT OF HT BUSHING ROD
2099	03-01-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	1313	Other Outage	Planned Outage	03-01-2026	11:53	03-01-2026	15:13	3:20	0.000833	REPLACEMENT OF HT BUSHING ROD
2100	05-01-2026	Part of : CHAUKHANDI VISHNU GARDEN	2638	Other Outage	Unplanned Outage	05-01-2026	16:37	05-01-2026	17:32	0:55	0.000749	CABLE FAULT
2101	05-01-2026	Part of : BLOCK RZ KHAYALA VISHNU GARDEN,	254	Other Outage	Planned Outage	05-01-2026	10:59	05-01-2026	13:57	2:58	0.000494	MAINTENANCE OF TRANSFORMER
2102	05-01-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	975	Other Outage	Planned Outage	05-01-2026	10:24	05-01-2026	13:44	3:20	0.000556	MAINTENANCE OF TRANSFORMER
2103	05-01-2026	Part of : BLOCK RG RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	837	Other Outage	Planned Outage	05-01-2026	10:25	05-01-2026	13:45	3:20	0.000833	MAINTENANCE OF TRANSFORMER
2104	05-01-2026	Part of : BLOCK 17 CENTRAL MARKET TILAK NAGAR,	479	Other Outage	Planned Outage	05-01-2026	11:00	05-01-2026	14:01	3:01	0.000503	MAINTENANCE OF TRANSFORMER
2105	06-01-2026	Part of : DTC DEPOT,KESHOPUR EV CHARGING (HTC)	0	Other Outage	Unplanned Outage	06-01-2026	13:55	06-01-2026	14:53	0:58	0.002239	FAULT IN HT CONSUMER PANEL (DTC DEPOT)
2106	06-01-2026	Part of : BLOCK 6 TILAK NAGAR,BLOCK 7 TILAK NAGAR,BLOCK 4B TILAK NAGAR,BLOCK 9 NURSERY TILAK NAGAR,BLOCK 8 TILAK NAGAR,BLOCK 5A TILAK NAGAR,BLOCK 4A TILAK NAGAR	1587	Other Outage	Unplanned Outage	06-01-2026	15:04	06-01-2026	16:11	1:07	0.001619	CABLE FAULT
2107	06-01-2026	Part of : BLOCK J RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	809	Other Outage	Planned Outage	06-01-2026	10:59	06-01-2026	14:19	3:20	0.000556	REPLACEMENT OF HT BUSHING ROD
2108	06-01-2026	Part of : BLOCK RG RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	696	Other Outage	Planned Outage	06-01-2026	10:59	06-01-2026	14:18	3:19	0.000553	REPLACEMENT OF HT BUSHING ROD
2109	06-01-2026	Part of : BLOCK 12 TILAK NAGAR	567	Other Outage	Planned Outage	06-01-2026	11:00	06-01-2026	14:21	3:21	0.000838	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2110	07-01-2026	Part of : POCKET AD TAGORE GARDEN EXTENSION	468	Other Outage	Planned Outage	07-01-2026	11:01	07-01-2026	13:22	2:21	0.000392	REPLACEMENT OF HT BUSHING ROD
2111	07-01-2026	Part of : BLOCK C VISHAL ENCLAVE EXTENSION	749	Other Outage	Planned Outage	07-01-2026	11:04	07-01-2026	14:25	3:21	0.000558	REPLACEMENT OF HT BUSHING ROD
2112	07-01-2026	Part of : BLOCK H JANTA COLONY TAGORE GARDEN EXTENSION	972	Other Outage	Planned Outage	07-01-2026	11:04	07-01-2026	14:26	3:22	0.000842	REPLACEMENT OF HT BUSHING ROD
2113	07-01-2026	Part of : BLOCK 4A TILAK NAGAR	115	Other Outage	Planned Outage	07-01-2026	11:01	07-01-2026	14:24	3:23	0.000846	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2114	07-01-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	189	Other Outage	Planned Outage	07-01-2026	11:02	07-01-2026	13:25	2:23	0.000000	LT CIRCUIT MAINTENANCE
2115	08-01-2026	Part of : RAVI NAGAR, CHAUKHANDI VISHNU GARDEN	2639	Other Outage	Unplanned Outage	08-01-2026	13:09	08-01-2026	14:35	1:26	0.000000	HT SYSTEM FAULT
2116	08-01-2026	Part of : BLOCK 18 TILAK NAGAR	158	Other Outage	Planned Outage	08-01-2026	10:55	08-01-2026	14:11	3:16	0.000817	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2117	09-01-2026	Part of : BLOCK S1 POCKET A KRISHNA PURI TILAK NAGAR,	1175	Other Outage	Planned Outage	09-01-2026	10:58	09-01-2026	13:12	2:14	0.000372	MAINTENANCE OF TRANSFORMER
2118	09-01-2026	Part of : BLOCK RG RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	260	Other Outage	Planned Outage	09-01-2026	11:01	09-01-2026	13:14	2:13	0.000554	MAINTENANCE OF TRANSFORMER
2119	09-01-2026	Part of : BLOCK N SHAM NAGAR VISHNU GARDEN,	1422	Other Outage	Planned Outage	09-01-2026	11:00	09-01-2026	14:12	3:12	0.000533	MAINTENANCE OF TRANSFORMER
2120	09-01-2026	Part of : BLOCK 4A TILAK NAGAR,	196	Other Outage	Planned Outage	09-01-2026	10:59	09-01-2026	14:14	3:15	0.000813	MAINTENANCE OF TRANSFORMER
2121	10-01-2026	PART OF : KHAYALA VISHNU GARDEN	476	Other Outage	Planned Outage	10-01-2026	13:21	10-01-2026	16:20	2:59	0.000497	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2122	10-01-2026	PART OF : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN	938	Other Outage	Planned Outage	10-01-2026	12:53	10-01-2026	16:18	3:25	0.000569	REPLACEMENT OF HT BUSHING ROD
2123	10-01-2026	PART OF : BLOCK 4B TILAK NAGAR	90	Other Outage	Planned Outage	10-01-2026	11:17	10-01-2026	14:17	3:00	0.000750	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2124	10-01-2026	PART OF : CHAUKHANDI VISHNU GARDEN	1221	Other Outage	Planned Outage	10-01-2026	10:58	10-01-2026	14:30	3:32	0.000589	REPLACEMENT OF HT BUSHING ROD
2125	10-01-2026	PART OF : BLOCK F TAGORE GARDEN TAGORE GARDEN EXTENSION	1180	Other Outage	Planned Outage	10-01-2026	10:35	10-01-2026	13:48	3:13	0.000536	LT AB SAGGING PER SPAN
2126	10-01-2026	PART OF : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION	398	Other Outage	Planned Outage	10-01-2026	11:16	10-01-2026	14:22	3:06	0.000000	LT AB SAGGING PER SPAN
2127	10-01-2026	PART OF : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	607	Other Outage	Planned Outage	10-01-2026	11:07	10-01-2026	14:25	3:18	0.000000	LT AB SAGGING PER SPAN
2128	12-01-2026	Part of : BLOCK 2 TILAK NAGAR	206	Other Outage	Planned Outage	12-01-2026	10:53	12-01-2026	14:04	3:11	0.000796	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2129	12-01-2026	Part of : BLOCK J RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	812	Other Outage	Planned Outage	12-01-2026	10:55	12-01-2026	13:06	2:11	0.000000	LT AB SAGGING PER SPAN
2130	13-01-2026	Part of : BLOCK D KHAYALA VISHNU GARDEN	510	Other Outage	Planned Outage	13-01-2026	13:03	13-01-2026	14:59	1:56	0.000000	3PH DB REPLACEMENT
2131	13-01-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	979	Other Outage	Planned Outage	13-01-2026	11:17	13-01-2026	14:02	2:45	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
2132	14-01-2026	Part of : CA BLOCK TAGORE GARDEN TAGORE GARDEN EXTENSION	450	Other Outage	Planned Outage	14-01-2026	11:03	14-01-2026	13:47	2:44	0.000683	REPLACEMENT OF HT BUSHING ROD
2133	15-01-2026	Part of : POCKET AD & BLOCK D,6,N & FA TAGORE GARDEN EXTENSION	4241	Other Outage	Planned Outage	15-01-2026	11:02	15-01-2026	14:10	3:08	0.000783	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2134	15-01-2026	Part of : BLOCK C HARJAN COLONY TILAK NAGAR	1015	Other Outage	Planned Outage	15-01-2026	10:43	15-01-2026	14:21	3:38	0.000908	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2135	15-01-2026	Part of : BLOCK F TAGORE GARDEN EXTENSION	405	Other Outage	Planned Outage	15-01-2026	11:01	15-01-2026	14:23	3:22	0.000000	LT CIRCUIT MAINTENANCE
2136	16-01-2026	Part of : POCKET 2 SECTOR 9 DWARKA	1320	Other Outage	Planned Outage	16-01-2026	12:22	16-01-2026	13:53	1:31	0.000000	3PH DB REPLACEMENT
2137	16-01-2026	Part of : PANCHSHILA PARK NORTH PANCHSHILA PARK	88	Other Outage	Planned Outage	16-01-2026	11:04	16-01-2026	14:11	3:07	0.000779	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2138	16-01-2026	Part of : BLOCK A & H SITAPURI PART 2,ANUP NAGAR ADARSH NAGAR BINDAPUR	621	Other Outage	Planned Outage	16-01-2026	11:13	16-01-2026	14:09	2:56	0.000489	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
2139	17-01-2026	Part of : TILAK NAGAR BLOCK 1	354	Other Outage	Planned Outage	17-01-2026	10:58	17-01-2026	14:17	3:19	0.000829	MAINTENANCE OF TRANSFORMER
2140	17-01-2026	Part of : H BLOCK KHAYALA VISHNU GARDEN	2937	Other Outage	Planned Outage	17-01-2026	10:58	17-01-2026	14:14	3:16	0.000544	MAINTENANCE OF TRANSFORMER
2141	17-01-2026	Part of : EF BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	397	Other Outage	Planned Outage	17-01-2026	12:09	17-01-2026	15:11	3:02	0.000000	MAINTENANCE OF LT CIRCUIT
2142	19-01-2026	Part of : WZ-BLOCK KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	527	Other Outage	Unplanned Outage	19-01-2026	16:06	19-01-2026	17:43	1:37	0.000269	ATTENDING WEAK POINTS/HOT SPOT
2143	19-01-2026	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	1392	Other Outage	Planned Outage	19-01-2026	11:13	19-01-2026	12:56	1:43	0.000286	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2144	19-01-2026	Part of : BLOCK S KHAYALA VISHNU GARDEN	1842	Other Outage	Planned Outage	19-01-2026	11:12	19-01-2026	14:07	2:55	0.000486	REPLACEMENT OF HT BUSHING ROD
2145	19-01-2026	Part of : KESHO PUR MANDI-2,DTC DEPOT,KESHOPUR EV CHARGING	527	Other Outage	Planned Outage	19-01-2026	11:16	19-01-2026	15:18	4:02	0.000672	CONDUCTOR REPLACEMENT PER SPAN,HT SLEEVE INSTALLATION
2146	19-01-2026	Part of : B-BLOCK GANESH NAGAR,TILAK NAGAR,ITI TILAK NAGAR	2872	Other Outage	Planned Outage	19-01-2026	10:36	19-01-2026	14:30	3:54	0.000650	CONDUCTOR REPLACEMENT PER SPAN,HT SLEEVE INSTALLATION
2147	19-01-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	1324	Other Outage	Planned Outage	19-01-2026	11:15	19-01-2026	14:08	2:53	0.000000	LT CIRCUIT MAINTENANCE WORK
2148	20-01-2026	Part of : KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	574	Other Outage	Unplanned Outage	20-01-2026	11:10	20-01-2026	12:19	1:09	0.001121	HT SYSTEM FAULT
2149	20-01-2026	Part of : KRISHNA PARK EXTENSION TILAK NAGAR	193	Other Outage	Planned Outage	20-01-2026	11:32	20-01-2026	13:41	2:09	0.000538	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2150	20-01-2026	Part of : TAGORE GARDEN EXTENSION	999	Other Outage	Planned Outage	20-01-2026	11:33	20-01-2026	13:42	2:09	0.000358	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2151	20-01-2026	Part of : BLOCK T KHAYALA VISHNU GARDEN	20	Other Outage	Planned Outage	20-01-2026	11:56	20-01-2026	14:38	2:42	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
2152	21-01-2026	Part of : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION,	397	Other Outage	Planned Outage	21-01-2026	11:53	21-01-2026	15:06	3:13	0.000000	LT CIRCUIT MAINTENANCE
2153	21-01-2026	Part of : BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	424	Other Outage	Planned Outage	21-01-2026	11:05	21-01-2026	14:04	2:59	0.000497	TRANSFORMER MAINTENANCE
2154	21-01-2026	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN,	1216	Other Outage	Planned Outage	21-01-2026	11:20	21-01-2026	15:02	3:42	0.000617	TRANSFORMER MAINTENANCE
2155	22-01-2026	Part of : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION,SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	2156	Other Outage	Planned Outage	22-01-2026	10:40	22-01-2026	14:12	3:32	0.000883	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2156	22-01-2026	Part of : BLOCK WZ MAJ BHUPENDRA SINGH NAGAR CHAUKHANDI VISHNU GARDEN	429	Other Outage	Planned Outage	22-01-2026	10:59	22-01-2026	14:05	3:06	0.000775	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2157	22-01-2026	Part of : BLOCK WZ MBS NAGAR CHAUKHANDI VISHNU GARDEN	628	Other Outage	Planned Outage	22-01-2026	11:32	22-01-2026	15:04	3:32	0.000589	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2158	22-01-2026	Part of : BLOCK WZ MBS NAGAR CHAUKHANDI VISHNU GARDEN	1458	Other Outage	Planned Outage	22-01-2026	11:34	22-01-2026	10:02	3:28	0.000578	REPLACEMENT OF HT BUSHING ROD
2159	22-01-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	979	Other Outage	Planned Outage	22-01-2026	10:55	22-01-2026	14:32	3:37	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
2160	24-01-2026	Part of : RAGHUBIR NAGAR, BLOCK D,G & R JANTA COLONY, SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	5541	Other Outage	Unplanned Outage	24-01-2026	05:16	24-01-2026	06:10	0:54	0.000211	CABLE FAULT
2161	24-01-2026	Part of : BLOCK 24 TILAK NAGAR	1199	Other Outage	Planned Outage	24-01-2026	11:16	24-01-2026	14:03	2:47	0.000464	REPLACEMET OF HT BUSHING ROD
2162	24-01-2026	Part of : BLOCK F TAGORE GARDEN EXTENSION	832	Other Outage	Planned Outage	24-01-2026	10:48	24-01-2026	13:49	3:01	0.000754	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2163	24-01-2026	Part of : BLOCK RG RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	696	Other Outage	Planned Outage	24-01-2026	10:37	24-01-2026	13:21	2:44	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
2164	25-01-2026	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN,KHAYALA VISHNU GARDEN,BLOCK J KHAYALA VISHNU GARDEN	2767	Other Outage	Unplanned Outage	25-01-2026	17:13	25-01-2026	18:09	0:56	0.001442	CABLE FAULT
2165	25-01-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	804	Other Outage	Planned Outage	25-01-2026	11:56	25-01-2026	14:02	2:06	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
2166	25-01-2026	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN	78	Other Outage	Planned Outage	25-01-2026	10:19	25-01-2026	14:00	3:41	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
2167	25-01-2026	Part of : BLOCK J KHAYALA VISHNU GARDEN	524	Other Outage	Planned Outage	25-01-2026	12:47	25-01-2026	16:19	3:32	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
2168	27-01-2026	Part of : WZ-BLOCK MUKERJI PARK,CHAUKHANDI VISHNU GARDEN	1236	Other Outage	Unplanned Outage	27-01-2026	11:37	27-01-2026	12:44	1:07	0.000866	HT SYSTEM FAULT
2169	27-01-2026	Part of : EF-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	246	Other Outage	Planned Outage	27-01-2026	13:21	27-01-2026	15:39	2:18	0.000575	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2170	27-01-2026	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN	761	Other Outage	Planned Outage	27-01-2026	13:21	27-01-2026	15:40	2:19	0.000386	REPLACEMET OF HT BUSHING ROD
2171	27-01-2026	Part of : BLOCK 4A TILAK NAGAR	111	Other Outage	Planned Outage	27-01-2026	12:20	27-01-2026	15:27	3:07	0.000779	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2172	27-01-2026	Part of : BLOCK H JANTA COLONY TAGORE GARDEN EXTENSION	975	Other Outage	Planned Outage	27-01-2026	10:06	27-01-2026	13:32	3:26	0.000572	LT CIRCUIT MAINTENANCE
2173	28-01-2026	Part of : BLOCK 24 TILAK NAGAR	1194	Other Outage	Planned Outage	28-01-2026	11:22	28-01-2026	14:43	3:21	0.000838	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2174	28-01-2026	Part of : POCKET C CHAND NAGAR VISHNU GARDEN	1377	Other Outage	Planned Outage	28-01-2026	11:23	28-01-2026	14:56	3:33	0.000592	REPLACEMET OF HT BUSHING ROD
2175	28-01-2026	Part of : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION	447	Other Outage	Planned Outage	28-01-2026	11:23	28-01-2026	14:44	3:21	0.000838	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2176	28-01-2026	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	979	Other Outage	Planned Outage	28-01-2026	10:06	28-01-2026	13:35	3:29	0.000000	CONDUCTOR REPLACEMENT PER SPAN,INSTALLATION OF PHASE SEPERATOR PER SPAN
2177	29-01-2026	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION,BLOCK EC VISHAL ENCLAVE TAGORE GARDEN EXTENSION,BLOCK A VISHAL ENCLAVE TAGORE GARDEN EXTENSION,BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION,SHIVAJI PALACE VISHAL ENCLAVE TAGORE GARDEN EXTENSION.	2512	Other Outage	Planned Outage	29-01-2026	11:05	29-01-2026	14:36	3:31	0.000879	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2178	29-01-2026	Part of : BLOCK C GANESH NAGAR TILAK NAGAR,	837	Other Outage	Planned Outage	29-01-2026	11:05	29-01-2026	14:35	3:30	0.000875	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
2179	30-01-2026	Part of : BLOCK B PRITHVI PARK TILAK NAGAR	1385	Other Outage	Planned Outage	30-01-2026	13:10	30-01-2026	15:50	2:40	0.000667	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2180	30-01-2026	Part of : BLOCK A VISHAL ENCLAVE TAGORE GARDEN EXTENSION	208	Other Outage	Planned Outage	30-01-2026	11:08	30-01-2026	13:49	2:41	0.000447	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2181	31-01-2026	Part of : D,G & R-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION,SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	5541	Other Outage	Unplanned Outage	31-01-2026	13:23	31-01-2026	14:48	1:25	0.000236	REPAIRING OF CONDUCTOR
2182	31-01-2026	Part of : A-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	2589	Other Outage	Planned Outage	31-01-2026	11:32	31-01-2026	13:27	1:55	0.000479	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2183	31-01-2026	Part of : RAVI NAGAR,WZ-BLOCK KHAYALA VISHNU GARDEN	2001	Other Outage	Planned Outage	31-01-2026	10:36	31-01-2026	13:47	3:11	0.000531	REPLACEMENT OF HT BUSHING ROD
2184	31-01-2026	Part of : K-BLOCK MAHAVIR NAGAR NEW TILAK NAGAR	440	Other Outage	Planned Outage	31-01-2026	11:30	31-01-2026	14:47	3:17	0.000821	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
2185	02-01-2026	Part of : MAHINDRA PARK BINDAPUR	1472	Other Outage	Planned Outage	02-01-2026	12:26	02-01-2026	13:52	1:26	0.000526	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2186	05-01-2026	Part of : GULABHI BAGH OM VIHAR UTTAM NAGAR	925	Other Outage	Unplanned Outage	05-01-2026	11:09	05-01-2026	12:35	1:26	0.000000	REPAIRING OF CONDUCTOR ON LT POLE
2187	05-01-2026	Part of : OLD JANKI PURI BINDAPUR,	656	Other Outage	Planned Outage	05-01-2026	15:36	05-01-2026	16:07	0:31	0.000000	MAINTENANCE OF RMU
2188	05-01-2026	Part of : OLD JANKI PURI BINDAPUR,BLOCK F JEEVAN PARK BINDAPUR	6580	Other Outage	Planned Outage	05-01-2026	14:37	05-01-2026	15:38	1:01	0.000000	MAINTENANCE OF RMU
2189	05-01-2026	Part of : OLD JANKI PURI BINDAPUR,	550	Other Outage	Planned Outage	05-01-2026	13:04	05-01-2026	14:29	1:25	0.000000	MAINTENANCE OF LT TRANSFORMER
2190	05-01-2026	Part of : OLD JANKI PURI BINDAPUR,	657	Other Outage	Planned Outage	05-01-2026	13:05	05-01-2026	14:29	1:24	0.000000	MAINTENANCE OF LT CIRCUIT
2191	05-01-2026	Part of : BLOCK C UTTAM VIHAR BINDAPUR,	1	Other Outage	Planned Outage	05-01-2026	11:44	05-01-2026	14:27	2:43	0.000996	MAINTENANCE OF LT TRANSFORMER
2192	05-01-2026	Part of : MAHAVIR ENCLAVE PART 3 MAHAVIR ENCLAVE,ANUP NAGAR ADARSH NAGAR BINDAPUR,	269	Other Outage	Planned Outage	05-01-2026	10:55	05-01-2026	14:25	3:30	0.001750	MAINTENANCE OF TRANSFORMER
2193	06-01-2026	Part of : BLOCK E PARAM PURI UTTAM NAGAR	2086	Other Outage	Planned Outage	06-01-2026	13:43	06-01-2026	16:14	2:31	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
2194	06-01-2026	Part of : INDIRA PARK BINDAPUR	854	Other Outage	Planned Outage	06-01-2026	11:06	06-01-2026	13:50	2:44	0.000683	3PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
2195	06-01-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	469	Other Outage	Planned Outage	06-01-2026	11:18	06-01-2026	13:49	2:31	0.001049	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
2196	07-01-2026	Part of : INDIRA PARK BINDAPUR	962	Other Outage	Planned Outage	07-01-2026	15:03	07-01-2026	16:21	1:18	0.000650	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
2197	07-01-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	1281	Other Outage	Planned Outage	07-01-2026	11:09	07-01-2026	13:55	2:46	0.001383	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
2198	08-01-2026	Part of : BLOCK A & H SITAPURI PART 2,ANUP NAGAR ADARSH NAGAR BINDAPUR	691	Other Outage	Planned Outage	08-01-2026	11:23	08-01-2026	13:32	2:09	0.001075	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
2199	08-01-2026	Part of : BLOCK A UTTAM VIHAR BINDAPUR	445	Other Outage	Planned Outage	08-01-2026	11:17	08-01-2026	13:33	2:16	0.001133	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
2200	09-01-2026	Part of : OLD JANKI PURI BINDAPUR,	416	Other Outage	Planned Outage	09-01-2026	11:42	09-01-2026	13:59	2:17	0.001142	MAINTENANCE OF TRANSFORMER
2201	10-01-2026	Part of : BLOCK D2 MILAP NAGAR UTTAM NAGAR	410	Other Outage	Unplanned Outage	10-01-2026	12:08	10-01-2026	13:09	1:01	0.000000	REPLACEMENT OF DAMAGE POLE
2202	12-01-2026	Part of : JEEVAN PARK,OLD JANKI PURI BINDAPUR,BLOCK C & D2 MAHINDRA PARK BINDAPUR	5750	Other Outage	Unplanned Outage	12-01-2026	12:57	12-01-2026	13:46	0:49	0.000817	CABLE FAULT
2203	12-01-2026	Part of : OLD JANKI PURI BINDAPUR	3273	Other Outage	Planned Outage	12-01-2026	12:32	12-01-2026	14:10	1:38	0.000817	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
2204	12-01-2026	Part of : BLOCK C & D2 MILAP NAGAR UTTAM NAGAR	2818	Other Outage	Planned Outage	12-01-2026	13:52	12-01-2026	16:15	2:23	0.000000	REPLACEMET OF HT BUSHING ROD
2205	13-01-2026	Part of : BLOCK B UTTAM NAGAR,BLOCK O UTTAM NAGAR	4154	Other Outage	Unplanned Outage	13-01-2026	08:00	13-01-2026	08:31	0:31	0.000267	CABLE FAULT
2206	13-01-2026	Part of : BLOCK F JEEVAN PARK BINDAPUR,OLD JANKI PURI BINDAPUR,BLOCK C MAHINDRA PARK BINDAPUR	5377	Other Outage	Unplanned Outage	13-01-2026	16:34	13-01-2026	17:11	0:37	0.000000	CABLE FAULT
2207	13-01-2026	Part of : UTTAM NAGAR EAST UTTAM NAGAR,NEW UTTAM NAGAR UTTAM NAGAR,BLOCK C MILAP NAGAR UTTAM NAGAR,BLOCK D2 MILAP NAGAR UTTAM NAGAR	6613	Other Outage	Unplanned Outage	13-01-2026	03:35	13-01-2026	04:31	0:56	0.000000	CABLE FAULT
2208	13-01-2026	Part of : BLOCK A UTTAM VIHAR BINDAPUR	23	Other Outage	Planned Outage	13-01-2026	12:11	13-01-2026	13:58	1:47	0.000000	CONDUCTOR REPLACEMENT PER SPAN
2209	13-01-2026	Part of : BLOCK B SITAPURI PART 2 SITAPURI	1000	Other Outage	Planned Outage	13-01-2026	11:09	13-01-2026	14:04	2:55	0.001458	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
2210	13-01-2026	Part of : BLOCK T PARAM PURI UTTAM NAGAR	1188	Other Outage	Planned Outage	13-01-2026	11:51	13-01-2026	14:56	3:05	0.000000	REPLACEMENT OF HT BUSHING ROD
2211	14-01-2026	Part of : PARJAPAT COLONY BINDAPUR,ANUP NAGAR ADARSH NAGAR BINDAPUR,NAND RAM PARK NEW UTTAM NAGAR UTTAM NAGAR	3049	Other Outage	Unplanned Outage	14-01-2026	00:19	14-01-2026	00:49	0:30	0.000195	CABLE FAULT
2212	14-01-2026	Part of : MANAS KUNJ NEW UTTAM NAGAR UTTAM NAGAR,PARJAPAT COLONY BINDAPUR	3443	Other Outage	Unplanned Outage	14-01-2026	00:16	14-01-2026	00:50	0:34	0.000574	CABLE FAULT
2213	15-01-2026	Part of : BLOCK A SITAPURI PART 2	1829	Other Outage	Planned Outage	15-01-2026	13:01	15-01-2026	15:32	2:31	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2214	15-01-2026	Part of : NANHEY PARK OM VIHAR UTTAM NAGAR	938	Other Outage	Planned Outage	15-01-2026	11:33	15-01-2026	13:57	2:24	0.000000	REPLACEMET OF HT BUSHING ROD
2215	15-01-2026	Part of : BLOCK C MAHINDRA PARK BINDAPUR	804	Other Outage	Planned Outage	15-01-2026	11:32	15-01-2026	13:57	2:25	0.001128	LT CIRCUIT MAINTENANCE
2216	15-01-2026	Part of : BLOCK E PARAM PURI UTTAM NAGAR	779	Other Outage	Planned Outage	15-01-2026	11:32	15-01-2026	13:58	2:26	0.000000	LT CIRCUIT MAINTENANCE
2217	16-01-2026	Part of : BLOCK B 2 DASRATHPURI	1173	Other Outage	Planned Outage	16-01-2026	12:03	16-01-2026	13:24	1:21	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2218	16-01-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE	691	Other Outage	Planned Outage	16-01-2026	11:19	16-01-2026	13:26	2:07	0.001058	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
2219	17-01-2026	Part of : BHAGAT ENCLAVE BINDAPUR,UTTAM VIHAR BINDAPUR	3494	Other Outage	Unplanned Outage	17-01-2026	12:22	17-01-2026	13:14	0:52	0.001274	CABLE FAULT
2220	17-01-2026	Part of : NANHEY PARK OM VIHAR UTTAM NAGAR	939	Other Outage	Unplanned Outage	17-01-2026	15:35	17-01-2026	16:58	1:23	0.000000	REPAIR OF LT CIRCUIT
2221	19-01-2026	Part of : E-BLOCK PARAM PURI UTTAM NAGAR	2484	Other Outage	Unplanned Outage	19-01-2026	10:01	19-01-2026	11:22	1:21	0.000530	CABLE FAULT
2222	19-01-2026	Part of : BLOCK F JEEVAN PARK BINDAPUR	1410	Other Outage	Planned Outage	19-01-2026	11:48	19-01-2026	14:04	2:16	0.001133	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
2223	19-01-2026	Part of : BLOCK B UTTAM NAGAR	706	Other Outage	Planned Outage	19-01-2026	11:12	19-01-2026	14:02	2:50	0.000000	LT CIRCUIT MAINTENANCE WORK
2224	21-01-2026	Part of : BLOCK C MAHINDRA PARK BINDAPUR,	829	Other Outage	Unplanned Outage	21-01-2026	12:17	21-01-2026	14:44	2:27	0.000000	JOINTING OF NEW LT CABLE
2225	21-01-2026	Part of : BLOCK E SITAPURI PART 2 SITAPURI,BLOCK B SITAPURI PART 2 SITAPURI	996	Other Outage	Planned Outage	21-01-2026	13:33	21-01-2026	15:07	1:34	0.000783	TRANSFORMER MAINTENANCE
2226	21-01-2026	Part of : BLOCK O UTTAM NAGAR,	427	Other Outage	Planned Outage	21-01-2026	11:44	21-01-2026	14:45	3:01	0.000000	LT TRANSFORMER MAINTENANCE
2227	22-01-2026	Part of : BLOCK C MAHINDRA PARK BINDAPUR	829	Other Outage	Unplanned Outage	22-01-2026	13:46	22-01-2026	15:34	1:48	0.000000	ATTENDING WEAK POINTS/HOT SPOT
2228	22-01-2026	Part of : BLOCK C MAHINDRA PARK BINDAPUR	829	Other Outage	Unplanned Outage	22-01-2026	13:44	22-01-2026	15:31	1:47	0.000000	REPAIRING OF HTAB CIRCUIT
2229	22-01-2026	Part of : INDIRA PARK BINDAPUR	465	Other Outage	Planned Outage	22-01-2026	11:49	22-01-2026	13:54	2:05	0.001042	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
2230	22-01-2026	Part of : MANAS KUNJ NEW UTTAM NAGAR UTTAM NAGAR	1253	Other Outage	Planned Outage	22-01-2026	11:23	22-01-2026	13:53	2:30	0.000000	REPLACEMENT OF HT BUSHING ROD
2231	24-01-2026	Part of : SANTOSH PARK UTTAM NAGAR	1433	Other Outage	Unplanned Outage	24-01-2026	14:45	24-01-2026	15:54	1:09	0.000000	ATTEND WEAK POINT/HOT SPOT
2232	24-01-2026	Part of : POCKET 4 CHANAKYA PLACE I SITAPURI	343	Other Outage	Planned Outage	24-01-2026	11:04	24-01-2026	14:04	3:00	0.000000	CONDUCTOR REPLACEMENT PER SPAN
2233	27-01-2026	Part of : D-BLOCK JJ COLONY UTTAM NAGAR	1314	Other Outage	Unplanned Outage	27-01-2026	02:28	27-01-2026	02:49	0:21	0.000050	CABLE FAULT
2234	27-01-2026	Part of : A 3,D,E & F-BLOCK UTTAM VIHAR BINDAPUR	5144	Other Outage	Unplanned Outage	27-01-2026	14:55	27-01-2026	15:54	0:59	0.001164	CABLE FAULT
2235	27-01-2026	Part of : BLOCK E PARAM PURI UTTAM NAGAR	353	Other Outage	Planned Outage	27-01-2026	12:49	27-01-2026	16:01	3:12	0.000000	LT CIRCUIT MAINTENANCE
2236	27-01-2026	Part of : BLOCK F JEEVAN PARK BINDAPUR	505	Other Outage	Planned Outage	27-01-2026	11:29	27-01-2026	14:25	2:56	0.001222	LT CIRCUIT MAINTENANCE
2237	28-01-2026	Part of : BLOCK B UTTAM NAGAR	2945	Other Outage	Unplanned Outage	28-01-2026	10:58	28-01-2026	12:30	1:32	0.000000	SAFEGUARDING OF CABLE
2238	28-01-2026	Part of : MAHINDRA PARK BINDAPUR	1465	Other Outage	Unplanned Outage	28-01-2026	13:35	28-01-2026	15:10	1:35	0.000792	CONNECTION OF NEW LT CABLE
2239	28-01-2026	Part of : UTTAM NAGAR EAST	1436	Other Outage	Unplanned Outage	28-01-2026	13:28	28-01-2026	15:09	1:41	0.001571	LT ACB LEAD REPLACEMENT
2240	28-01-2026	Part of : OLD JANKI PURI BINDAPUR	499	Other Outage	Planned Outage	28-01-2026	11:23	28-01-2026	14:04	2:41	0.001118	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
2241	29-01-2026	Part of : INDIRA PARK BINDAPUR,BLOCK F JEEVAN PARK BINDAPUR	3932	Other Outage	Unplanned Outage	29-01-2026	15:55	29-01-2026	16:48	0:53	0.000726	HT SYSTEM FAULT
2242	29-01-2026	Part of : OLD JANKI PURI BINDAPUR,BLOCK D 2 MAHINDRA PARK BINDAPUR,BLOCK C MAHINDRA PARK BINDAPUR,	5762	Other Outage	Unplanned Outage	29-01-2026	12:04	29-01-2026	13:30	1:26	0.000000	LAYING OF NEW LTAB
2243	29-01-2026	Part of : OLD JANKI PURI BINDAPUR,	555	Other Outage	Planned Outage	29-01-2026	11:12	29-01-2026	13:35	2:23	0.000874	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
2244	30-01-2026	Part of : BLOCK A 3 HARJAN COLONY SITAPURI PART 1 SITAPURI	1138	Other Outage	Planned Outage	30-01-2026	12:21	30-01-2026	15:20	2:59	0.001492	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
2245	01-01-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL,BLOCK A 2 UTTAM NAGAR,PHASE 2 OM VIHAR HASTSAL,HOSTAL VIHAR OM VIHAR HASTSAL	3148	Other Outage	Unplanned HASTSAL	01-01-2026	05:01	01-01-2026	05:34	0:33	0.000156	HT SYSTEM FAULT
2246	01-01-2026	Part of : BLOCK H SAMAJ KALYAN APARTMENT VIKAS PURI,	51	Other Outage	Planned Outage	01-01-2026	11:39	01-01-2026	13:53	2:14	0.000000	REPLACEMET OF HT BUSHING ROD
2247	02-01-2026	Part of : C&D BLOCK VIKAS NAGAR,PRESS ENCLAVE,SHIV VIHAR HASTSAL,VIKAS NAGAR EXTN.,SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK	3187	Other Outage	Unplanned Outage	02-01-2026	15:03	02-01-2026	15:32	0:29	0.000322	CABLE FAULT
2248	02-01-2026	Part of : PHASE 1 OM VIHAR NAWADA	1084	Other Outage	Planned Outage	02-01-2026	11:49	02-01-2026	13:52	2:03	0.000000	REPLACEMENT OF LT BUSHING ROD
2249	02-01-2026	Part of : BLOCK FG1 VIKAS PURI	567	Other Outage	Planned Outage	02-01-2026	11:13	02-01-2026	13:51	2:38	0.000000	REPLACEMENT OF HT BUSHING ROD
2250	02-01-2026	Part of : DEEP ENCLAVE	1336	Other Outage	Planned Outage	02-01-2026	11:15	02-01-2026	13:51	2:36	0.000000	REPLACEMENT OF HT BUSHING ROD
2251	03-01-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE,OM VIHAR PHASE 5 HASTSAL	1365	Other Outage	Unplanned Outage	03-01-2026	13:34	03-01-2026	14:17	0:43	0.001433	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						Remarks
						From		To		Duration	Unservd (MU) due to outage	
						Date	Time	Date	Time			
2252	03-01-2026	Part of : A,B&C-BLOCK MAHARANI ENCLAVE,BLOCK A PANCHVATI APPT VIKAS PURI	2090	Other Outage	Unplanned Outage	03-01-2026	12:48	03-01-2026	13:51	1:03	0.000000	REPAIRING OF RMU
2253	03-01-2026	Part of : YADAV ENCLAVE,VIKAS VIHAR,A&B BLOCK SAI ENCLAVE,C,SURKAKHA ENCLAVE,SAINIK ENCLAVE,PANCHSHEEL ENCLAVE	1524	Other Outage	Planned Outage	03-01-2026	12:04	03-01-2026	14:48	2:44	0.000000	3PH HT AB CABLE REPLACEMENT
2254	03-01-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE	414	Other Outage	Planned Outage	03-01-2026	11:15	03-01-2026	13:41	2:26	0.000000	REPLACEMENT OF HT BUSHING ROD
2255	03-01-2026	Part of : VIKAS KUNJ VIKAS PURI	92	Other Outage	Planned Outage	03-01-2026	10:42	03-01-2026	13:30	2:48	0.000000	LT CIRCUIT MAINTENANCE
2256	04-01-2026	Part of : F & S-BLOCK VIKAS NAGAR,SHIV VIHAR COLONY,D-BLOCK JJ COLONY	5432	Other Outage	Unplanned Outage	04-01-2026	16:58	04-01-2026	17:39	0:41	0.000296	HT SYSTEM FAULT
2257	04-01-2026	Part of : MANOHAR NAGAR VIKAS PURI,KESHOPUR VIKAS PURI,BLOCK GG 2 VIKAS PURI	3494	Other Outage	Unplanned Outage	04-01-2026	05:57	04-01-2026	06:42	0:45	0.000375	CABLE FAULT
2258	05-01-2026	Part of : DDA LIG FLATS HASTSAL	870	Other Outage	Unplanned Outage	05-01-2026	17:40	05-01-2026	18:46	1:06	0.000880	CABLE FAULT
2259	05-01-2026	Part of : VIKAS KUNJ AND VIKAS KUNJ EXTN.,	2251	Other Outage	Planned Outage	05-01-2026	13:50	05-01-2026	16:09	2:19	0.000000	MAINTENANCE OF LT TRANSFORMER
2260	05-01-2026	Part of : BLOCK A 3 UTTAM NAGAR,	979	Other Outage	Planned Outage	05-01-2026	11:56	05-01-2026	14:24	2:28	0.000000	MAINTENANCE OF LT CIRCUIT
2261	05-01-2026	Part of : PHASE 3 OM VIHAR HASTSAL,	1289	Other Outage	Planned Outage	05-01-2026	11:12	05-01-2026	13:51	2:39	0.000000	MAINTENANCE OF LT TRANSFORMER
2262	05-01-2026	Part of : VIKAS KUNJ VIKAS PURI,	114	Other Outage	Planned Outage	05-01-2026	10:54	05-01-2026	13:50	2:56	0.000000	MAINTENANCE OF LT TRANSFORMER
2263	06-01-2026	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK,VIKAS NAGAR EXTN.,SAINIK ENCLAVE,M-BLOCK VIKAS VIHAR COMMANDER CHOWK	1825	Other Outage	Planned Outage	06-01-2026	11:21	06-01-2026	13:50	2:29	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2264	06-01-2026	Part of : VIKAS KUNJ VIKAS PURI	173	Other Outage	Planned Outage	06-01-2026	10:37	06-01-2026	13:32	2:55	0.000000	REPLACEMENT OF HT BUSHING ROD
2265	06-01-2026	Part of : HOSTAL VIHAR OM VIHAR HASTSAL	664	Other Outage	Planned Outage	06-01-2026	11:19	06-01-2026	13:48	2:29	0.000000	REPLACEMENT OF LT BUSHING ROD
2266	07-01-2026	Part of : E-BLOCK PROMISE APARTMENT VIKAS PURI,BUDHELA VILLAGE,NAVYUG ADARSH APARTMENT VIKAS PURI	1997	Other Outage	Unplanned Outage	07-01-2026	09:49	07-01-2026	10:32	0:43	0.000717	FAULT IN HT CONSUMER PANEL (MANGALAM SCHOOL)
2267	07-01-2026	Part of : DEEPAK VIHAR,PRESS ENCLAVE,VIKAS ENCLAVE, B-BLOCK VIKAS NAGAR EXTN.,SURKAKHA ENCLAVE	1718	Other Outage	Planned Outage	07-01-2026	11:27	07-01-2026	13:55	2:28	0.000000	3PH HT AB CABLE REPLACEMENT
2268	07-01-2026	Part of : HASTSAL VIHAR & HASTSAL VILLAGE	141	Other Outage	Planned Outage	07-01-2026	11:08	07-01-2026	13:53	2:45	0.000000	LT CIRCUIT MAINTENANCE
2269	07-01-2026	Part of : KESHOPUR VIKAS PURI	328	Other Outage	Planned Outage	07-01-2026	10:45	07-01-2026	13:52	3:07	0.000000	LT CIRCUIT MAINTENANCE
2270	08-01-2026	Part of : SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE	3062	Other Outage	Planned Outage	08-01-2026	10:52	08-01-2026	13:30	2:38	0.000000	REPLACEMENT OF LT BUSHING ROD
2271	08-01-2026	Part of : KESHOPUR VILLAGE VIKAS PURI	229	Other Outage	Planned Outage	08-01-2026	10:33	08-01-2026	13:05	2:32	0.000000	REPLACEMENT OF LT BUSHING ROD
2272	09-01-2026	Part of : PHASE 3 OM VIHAR HASTSAL,	1289	Other Outage	Planned Outage	09-01-2026	11:22	09-01-2026	13:53	2:31	0.000000	MAINTENANCE OF LT TRANSFORMER
2273	09-01-2026	Part of : BLOCK C POLICE COLONY VIKAS PURI,	228	Other Outage	Planned Outage	09-01-2026	10:32	09-01-2026	12:39	2:07	0.000000	MAINTENANCE OF LT TRANSFORMER
2274	10-01-2026	PART OF : BLOCK M ZAILDAR ENCLAVE HASTSAL	458	Other Outage	Planned Outage	10-01-2026	12:17	10-01-2026	15:15	2:58	0.000000	REPLACEMENT OF LT BUSHING ROD
2275	10-01-2026	PART OF : PHASE 3 OM VIHAR HASTSAL	1301	Other Outage	Planned Outage	10-01-2026	11:06	10-01-2026	13:48	2:42	0.000000	REPLACEMENT OF LT BUSHING ROD
2276	10-01-2026	PART OF : BLOCK GG1 VIKAS PURI	466	Other Outage	Planned Outage	10-01-2026	10:21	10-01-2026	13:32	3:11	0.000000	REPLACEMENT OF LT BUSHING ROD
2277	12-01-2026	Part of : DDA LIG FLATS HASTSAL, VIKASPURI	870	Other Outage	Unplanned Outage	12-01-2026	04:46	12-01-2026	05:25	0:39	0.000249	CABLE FAULT
2278	12-01-2026	Part of : BLOCK K4,K7 & M ZAILDAR ENCLAVE HASTSAL,BLOCK L-2 MOHAN GARDEN,A&B-BLOCK SHAKTI VIHAR	5868	Other Outage	Unplanned Outage	12-01-2026	04:46	12-01-2026	05:24	0:38	0.000042	CABLE FAULT
2279	12-01-2026	Part of : DEEP ENCLAVE	2096	Other Outage	Planned Outage	12-01-2026	11:52	12-01-2026	14:30	2:38	0.000000	REPLACEMENT OF LT BUSHING ROD
2280	12-01-2026	Part of : BLOCK A 1 UTTAM NAGAR	795	Other Outage	Planned Outage	12-01-2026	11:40	12-01-2026	14:04	2:24	0.000000	REPLACEMENT OF LT BUSHING ROD
2281	12-01-2026	Part of : BLOCK H3 VIKAS PURI	35	Other Outage	Planned Outage	12-01-2026	11:07	12-01-2026	13:59	2:52	0.000000	REPLACEMENT OF LT BUSHING ROD
2282	13-01-2026	Part of : BLOCK A 3 UTTAM NAGAR,JJ COLONY UTTAM NAGAR,KRISHNA COLONY HASTSAL VILLAGE HASTSAL	4203	Other Outage	Planned Outage	13-01-2026	11:32	13-01-2026	14:01	2:29	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
2283	13-01-2026	Part of : HASTSAL VIHAR HASTSAL VILLAGE HASTSAL,KRISHNA COLONY HASTSAL VILLAGE HASTSAL	2690	Other Outage	Planned Outage	13-01-2026	11:34	13-01-2026	14:00	2:26	0.000000	GUARD WIRES SAGGING PER SPAN
2284	15-01-2026	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK	1824	Other Outage	Planned Outage	15-01-2026	12:26	15-01-2026	14:59	2:33	0.000000	LT CIRCUIT MAINTENANCE
2285	15-01-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE	185	Other Outage	Planned Outage	15-01-2026	11:51	15-01-2026	15:03	3:12	0.000000	LT CIRCUIT MAINTENANCE
2286	16-01-2026	Part of : BLOCK J 3 RAJOURI GARDEN EXTENSION	1301	Other Outage	Planned Outage	16-01-2026	11:34	16-01-2026	13:25	1:51	0.000000	REPLACEMENT OF LT BUSHING ROD
2287	16-01-2026	Part of : POCKET 1 SECTOR 3 MATIALA	3415	Other Outage	Planned Outage	16-01-2026	11:10	16-01-2026	13:28	2:18	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
2288	16-01-2026	Part of : GADAIPUR DLF FARMS,GADAIPUR JAUNAPUR	828	Other Outage	Planned Outage	16-01-2026	11:09	16-01-2026	13:31	2:22	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
2289	16-01-2026	Part of : BLOCK D,E & L BHAGWATI GARDEN NAWADA	4321	Other Outage	Planned Outage	16-01-2026	11:09	16-01-2026	13:29	2:20	0.000000	GUARD WIRES SAGGING PER SPAN
2290	16-01-2026	Part of : BLOCK H KESHOPUR INDUSTRIAL AREA VIKAS PURI	1	Other Outage	Planned Outage	16-01-2026	10:25	16-01-2026	13:18	2:53	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2291	17-01-2026	Part of : YADAV ENCLAVE AND VIKAS VIHAR,A&B BLOCK VIKAS VIHAR AND SAI ENCLAVE	1524	Other Outage	Planned Outage	17-01-2026	11:07	17-01-2026	13:54	2:47	0.000000	MAINTENANCE OF TRANSFORMER
2292	17-01-2026	Part of : PHASE 5 OM VIHAR HASTSAL	102	Other Outage	Planned Outage	17-01-2026	11:18	17-01-2026	13:58	2:40	0.000000	MAINTENANCE OF LT TRANSFORMER
2293	17-01-2026	Part of : PHASE 1 VIKAS PURI	38	Other Outage	Planned Outage	17-01-2026	10:52	17-01-2026	13:57	3:05	0.000000	MAINTENANCE OF LT TRANSFORMER
2294	19-01-2026	Part of : M-BLOCK VIKAS VIHAR,LIONS ENCLAVE,SAINIK ENCLAVE,SURKAKHA ENCLAVE,M-BLOCK COMMONDER CHOWK,VIKAS NAGAR EXTN.	3783	Other Outage	Unplanned Outage	19-01-2026	10:52	19-01-2026	12:28	1:36	0.000000	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
2295	19-01-2026	Part of : SAINIK ENCLAVE,PANCHSHEEL ENCLAVE,SURKAKHA ENCLAVE,M- BLOCK COMMONDER CHOWK,PRESS ENCLAVE	1542	Other Outage	Planned Outage	19-01-2026	11:24	19-01-2026	14:03	2:39	0.000000	REPLACEMET OF HT BUSHING ROD
2296	19-01-2026	Part of : OM VIHAR PHASE 3 HASTSAL	1289	Other Outage	Planned Outage	19-01-2026	11:09	19-01-2026	14:04	2:55	0.000000	LT CIRCUIT MAINTENANCE WORK
2297	20-01-2026	Part of : K5 & K6 & DEFENCE ENCLAVE PART-1 MOHAN GARDEN,PRESS ENCLAVE	1057	Other Outage	Planned Outage	20-01-2026	11:15	20-01-2026	13:42	2:27	0.000000	REPLACEMENT OF LT BUSHING ROD
2298	20-01-2026	Part of : BLOCK B JJ COLONY UTTAM NAGAR	947	Other Outage	Planned Outage	20-01-2026	11:22	20-01-2026	13:43	2:21	0.000000	REPLACEMENT OF LT BUSHING ROD
2299	20-01-2026	Part of : POORTI APARTMENTS VIKAS PURI	63	Other Outage	Planned Outage	20-01-2026	10:49	20-01-2026	13:41	2:52	0.000000	REPLACEMET OF HT BUSHING ROD
2300	21-01-2026	Part of : PHASE 1 OM VIHAR NAWADA,	1301	Other Outage	Planned Outage	21-01-2026	11:06	21-01-2026	13:41	2:35	0.000000	LT TRANSFORMER MAINTENANCE
2301	22-01-2026	Part of : SHIV VIHAR,VIKAS NAGAR EXTENSION,SURKAKSHA VIHAR VIKAS NAGAR A BLK	4559	Other Outage	Unplanned Outage	22-01-2026	22:28	22-01-2026	23:30	1:02	0.000000	BIRDAGE
2302	22-01-2026	Part of : SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,VIKRANT VIHAR,A&B BLOCK VIKAS VIHAR AND SAI ENCLAVE,SAINIK ENCLAVE	3062	Other Outage	Planned Outage	22-01-2026	11:19	22-01-2026	13:52	2:33	0.000000	REPLACEMENT OF HT BUSHING ROD
2303	22-01-2026	Part of : PHASE 1 VIKAS PURI	50	Other Outage	Planned Outage	22-01-2026	11:03	22-01-2026	13:51	2:48	0.000000	REPLACEMENT OF HT BUSHING ROD
2304	23-01-2026	Part of : H3 & JG 3-BLOCK JG 3 VIKAS PURI	1492	Other Outage	Unplanned Outage	23-01-2026	22:31	23-01-2026	23:05	0:34	0.000209	CABLE FAULT
2305	23-01-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE,HOSTAL VIHAR,OM VIHAR PHASE 2,A 2-BLOCK UTTAM NAGAR	3151	Other Outage	Unplanned Outage	23-01-2026	09:52	23-01-2026	10:35	0:43	0.000727	CABLE FAULT
2306	23-01-2026	Part of : MANOHAR NAGAR,JG 1, JG 2 & GG 2-BLOCK VIKAS PURI,KESHOPUR VILLAGE,GUJRANWALA VIKAS PURI	3491	Other Outage	Unplanned Outage	23-01-2026	08:15	23-01-2026	09:01	0:46	0.001112	HVDS FAULT
2307	24-01-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK N1 & P MOHAN GARDEN RAZAPUR KHURD	2827	Other Outage	Unplanned Outage	24-01-2026	13:52	24-01-2026	15:09	1:17	0.000000	REPAIRING OF HVDS CIRCUIT
2308	24-01-2026	Part of : D-BLOCK JJ COLONY	1075	Other Outage	Planned Outage	24-01-2026	13:49	24-01-2026	16:35	2:46	0.000000	REPLACEMET OF HT BUSHING ROD
2309	24-01-2026	Part of : ANAND KUNJ VIKAS PURI	60	Other Outage	Planned Outage	24-01-2026	10:45	24-01-2026	14:06	3:21	0.000000	REPLACEMET OF HT BUSHING ROD
2310	24-01-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE	16	Other Outage	Planned Outage	24-01-2026	11:33	24-01-2026	14:05	2:32	0.000000	REPLACEMET OF HT BUSHING ROD
2311	27-01-2026	Part of : B-BLK BOOSTER PUMP (HT CONSUMER)	0	Other Outage	Unplanned Outage	27-01-2026	03:49	27-01-2026	04:25	0:36	0.000025	CABLE FAULT
2312	27-01-2026	Part of : BUDHELA VILLAGE VIKAS PURI	67	Other Outage	Planned Outage	27-01-2026	10:42	27-01-2026	13:44	3:02	0.000000	LT CIRCUIT MAINTENANCE
2313	28-01-2026	Part of : K-5 EXTN. AND DEEPAK VIHAR	239	Other Outage	Planned Outage	28-01-2026	10:52	28-01-2026	14:03	3:11	0.000000	REPLACEMET OF HT BUSHING ROD
2314	28-01-2026	Part of : HOSTAL VIHAR OM VIHAR HASTSAL	664	Other Outage	Planned Outage	28-01-2026	10:49	28-01-2026	14:03	3:14	0.000000	REPLACEMENT OF LT BUSHING ROD
2315	28-01-2026	Part of : BLOCK H SAMAJ KALYAN APARTMENT VIKAS PURI	87	Other Outage	Planned Outage	28-01-2026	10:07	28-01-2026	13:01	2:54	0.000000	REPLACEMET OF HT BUSHING ROD
2316	29-01-2026	Part of : SAINIK ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,SURKAKHA ENCLAVE AND M-BLOCK COMMONDER CHOWK,PRESS ENCLAVE,	1542	Other Outage	Planned Outage	29-01-2026	12:16	29-01-2026	14:30	2:14	0.000000	REPLACEMET OF HT BUSHING ROD
2317	29-01-2026	Part of : BLOCK C JJ COLONY UTTAM NAGAR,	1023	Other Outage	Planned Outage	29-01-2026	12:14	29-01-2026	14:31	2:17	0.000000	REPLACEMENT OF LT BUSHING ROD
2318	30-01-2026	Part of : GUPTA ENCLAVE	2505	Other Outage	Planned Outage	30-01-2026	11:44	30-01-2026	14:35	2:51	0.000000	REPLACEMENT OF HT BUSHING ROD
2319	30-01-2026	Part of : PHASE 3 OM VIHAR HASTSAL	1289	Other Outage	Planned Outage	30-01-2026	11:43	30-01-2026	14:07	2:24	0.000000	REPLACEMENT OF LT BUSHING ROD
2320	31-01-2026	Part of : H 2 & JG 3-BLOCK VIKAS PURI,MANOHAR NAGAR,NAVYUG ADARSH APARTMENT	2205	Other Outage	Unplanned Outage	31-01-2026	10:10	31-01-2026	10:58	0:48	0.001078	CABLE FAULT