

Name of Distribution Licensee: BSES Rajdhani Power Limited												
Period of Outage: MARCH 2026												
Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1	01-03-2026	Part of : F-BLOCK OKHLA PHASE-1,F-79-80 DLF UNIVERSAL OKHLA PHASE-1	1381	Other Outage	Planned Outage	01-03-2026	11:02	01-03-2026	12:09	1:07	0.000000	MEASUREMET OF INSULATION RESISTANCE,REPLACEMENT OF SILICAGEL IN BREATHER
2	01-03-2026	Part of : F-BLOCK OKHLA PHASE-1	795	Other Outage	Planned Outage	01-03-2026	12:09	01-03-2026	14:36	2:27	0.002246	REPLACEMET OF HT BUSHING ROD
3	01-03-2026	Part of : DDA SHED OKHLA PHASE-1,B-BLOCK OKHLA PHASE-1	709	Other Outage	Planned Outage	01-03-2026	10:58	01-03-2026	13:50	2:52	0.001672	REPLACEMENT OF LT BUSHING ROD
4	03-03-2026	Part of : GANGOTRI ENCLAVE	512	Other Outage	Planned Outage	03-03-2026	11:10	03-03-2026	14:33	3:23	0.001974	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS,REPLACEMENT OF FAULTY END BOX
5	05-03-2026	Part of : TUGHLAKABAD	5	Other Outage	Planned Outage	05-03-2026	10:57	05-03-2026	14:49	3:52	0.005607	GUARD WIRES SAGGING PER SPAN
6	08-03-2026	Part of : A-BLOCK OKHLA INDUSTRIAL AREA PHASE-1	4	Other Outage	Unplanned Outage	08-03-2026	03:01	08-03-2026	03:46	0:45	0.000263	CABLE FAULT
7	08-03-2026	Part of : ESI HOSPITAL OKHLA INDUSTRIAL AREA PHASE-1	73	Other Outage	Planned Outage	08-03-2026	10:58	08-03-2026	13:41	2:43	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
8	09-03-2026	Part of : GOVINDPURI	919	Other Outage	Planned Outage	09-03-2026	11:05	09-03-2026	14:00	2:55	0.005833	INSTALLATION OF HT BOOTS,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
9	09-03-2026	Part of : E-BLOCK MASJID MOTH	241	Other Outage	Planned Outage	09-03-2026	10:53	09-03-2026	13:39	2:46	0.000000	3PH DB REPLACEMENT
10	10-03-2026	Part of : BLOCK A CHITTARANJAN PARK,	191	Other Outage	Planned Outage	10-03-2026	10:48	10-03-2026	12:24	1:36	0.000000	CONDUCTOR REPLACEMENT PER SPAN
11	11-03-2026	Part of : B-BLOCK CR PARK	397	Other Outage	Planned Outage	11-03-2026	10:07	11-03-2026	11:53	1:46	0.000000	LT CIRCUIT MAINTENANCE
12	12-03-2026	Part of : SAVITRI CINEMA	109	Other Outage	Planned Outage	12-03-2026	12:19	12-03-2026	14:45	2:26	0.000000	LT CIRCUIT MAINTENANCE
13	13-03-2026	Part of : TUGHLAQABAD FORT TUGHLAKABAD,TUGHLAQABAD VILLAGE TUGHLAKABAD,DDA PARK LAL KUAN,TUGHLAKABAD	2913	Other Outage	Unplanned Outage	13-03-2026	01:39	13-03-2026	02:37	0:58	0.000972	HT SYSTEM FAULT
14	13-03-2026	Part of : BLOCK A CHITTARANJAN PARK	153	Other Outage	Planned Outage	13-03-2026	11:25	13-03-2026	12:50	1:25	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
15	14-03-2026	Part of : MELA GROUND,	241	Other Outage	Planned Outage	14-03-2026	11:49	14-03-2026	12:37	0:48	0.000000	INSTALLATION OF PHASE SEPERATOR PER SPAN,INSULATOR REPLACEMENT PER POLE,LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
16	15-03-2026	Part of : B-BLOCK OKHLA PHASE-1,DDA SHED OKHLA PHASE-1	198	Other Outage	Planned Outage	15-03-2026	11:14	15-03-2026	12:40	1:26	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
17	15-03-2026	Part of : D-BLOCK OKHLA PHASE-1	44	Other Outage	Planned Outage	15-03-2026	11:53	15-03-2026	14:53	3:00	0.002000	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
18	16-03-2026	Part of : W-BLOCK GK-2	680	Other Outage	Unplanned Outage	16-03-2026	01:45	16-03-2026	02:37	0:52	0.000337	CABLE FAULT
19	17-03-2026	Part of : TUGHLAQABAD VILLAGE ,DUMPING YARD OKHLA PHASE-1	1986	Other Outage	Unplanned Outage	17-03-2026	00:39	17-03-2026	01:29	0:50	0.000861	CABLE FAULT
20	17-03-2026	Part of : H-BLOCK KALKA JI	1144	Other Outage	Planned Outage	17-03-2026	11:23	17-03-2026	13:52	2:29	0.006208	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
21	17-03-2026	Part of : W-BLOCK GK-2	121	Other Outage	Planned Outage	17-03-2026	11:24	17-03-2026	13:49	2:25	0.000000	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE
22	18-03-2026	Part of : C-BLOCK KALKA JI ,1-BLOCK KALKA JI,2-BLOCK KALKA JI,9-BLOCK KALKA JI,	1030	Other Outage	Planned Outage	18-03-2026	11:00	18-03-2026	12:43	1:43	0.004292	REPLACEMENT OF LT BUSHING ROD
23	18-03-2026	Part of : C-BLOCK CR PARK,	242	Other Outage	Planned Outage	18-03-2026	11:00	18-03-2026	13:31	2:31	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
24	19-03-2026	Part of : SHAHEED RAJIV GANDHI COLONY GOVINDPURI	3112	Other Outage	Unplanned Outage	19-03-2026	03:03	19-03-2026	03:44	0:41	0.000000	CABLE FAULT
25	19-03-2026	Part of : SHAHEED RAJIV GANDHI COLONY GOVINDPURI	1168	Other Outage	Unplanned Outage	19-03-2026	13:40	19-03-2026	14:39	0:59	0.000000	SAFEGUARDING OF CABLE
26	19-03-2026	Part of : E-BLOCK MASJID MOTH	258	Other Outage	Planned Outage	19-03-2026	11:53	19-03-2026	13:08	1:15	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
27	22-03-2026	Part of : C-BLOCK OKHLA PHASE-1,	20	Other Outage	Planned Outage	22-03-2026	10:57	22-03-2026	12:56	1:59	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER
28	22-03-2026	Part of : C-BLOCK OKHLA PHASE-1,	12	Other Outage	Planned Outage	22-03-2026	10:57	22-03-2026	12:57	2:00	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER
29	23-03-2026	Part of : D-BLOCK KALKA II	327	Other Outage	Planned Outage	23-03-2026	12:52	23-03-2026	15:12	2:20	0.002722	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
30	23-03-2026	Part of : A-BLOCK CHITTARANJAN PARK	191	Other Outage	Planned Outage	23-03-2026	12:07	23-03-2026	14:10	2:03	0.000000	LT CIRCUIT MAINTENANCE
31	24-03-2026	Part of : F-BLOCK OKHLA INDUSTRIAL AREA PHASE-1	731	Other Outage	Unplanned Outage	24-03-2026	00:18	24-03-2026	01:11	0:53	0.000349	HT SYSTEM FAULT
32	24-03-2026	Part of : E-BLOCK MASJID MOTH	199	Other Outage	Planned Outage	24-03-2026	10:56	24-03-2026	13:39	2:43	0.000000	LT CIRCUIT MAINTENANCE
33	24-03-2026	Part of : H-BLOCK MASJID MOTH	271	Other Outage	Planned Outage	24-03-2026	10:55	24-03-2026	13:38	2:43	0.000000	LT CIRCUIT MAINTENANCE
34	25-03-2026	Part of : W-BLOCK GK-2	119	Other Outage	Planned Outage	25-03-2026	11:07	25-03-2026	14:20	3:13	0.000000	INSTALLATION OF PHASE SEPERATOR PER SPAN
35	28-03-2026	Part of : M-BLOCK GK-2	224	Other Outage	Planned Outage	28-03-2026	11:04	28-03-2026	12:45	1:41	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
36	29-03-2026	Part of : F-BLOCK OKHLA PHASE-1	19	Other Outage	Planned Outage	29-03-2026	10:57	29-03-2026	12:42	1:45	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
37	29-03-2026	Part of : A-BLOCK OKHLA PHASE-1	23	Other Outage	Planned Outage	29-03-2026	10:57	29-03-2026	12:38	1:41	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
38	02-03-2026	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR,	1193	Other Outage	Planned Outage	02-03-2026	14:00	02-03-2026	14:42	0:42	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
39	02-03-2026	Part of : SULTANPUR,JAUNAPUR VILLAGE JAUNAPUR,RADHEY MOHAN DRIVE,DLF FARMS,GADAIPIR JAUNAPUR,	70	Other Outage	Planned Outage	02-03-2026	11:41	02-03-2026	14:02	2:21	0.000392	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
40	03-03-2026	Part of : G-BLOCK AYA NAGAR EXTENSION	1193	Other Outage	Planned Outage	03-03-2026	12:29	03-03-2026	13:38	1:09	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
41	05-03-2026	Part of : DLF FARMS,BLOCK C CHHATARPUR EXTENSION	386	Other Outage	Planned Outage	05-03-2026	12:48	05-03-2026	13:36	0:48	0.000000	REPLACEMET OF HT BUSHING ROD
42	05-03-2026	Part of : ASOLA	436	Other Outage	Planned Outage	05-03-2026	12:58	05-03-2026	14:26	1:28	0.000000	CONNECTING OF NEW EARTHING PER EARTHING
43	05-03-2026	Part of : BLOCK G AYA NAGAR EXTENSION	1193	Other Outage	Planned Outage	05-03-2026	11:25	05-03-2026	13:34	2:09	0.000000	INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT PER POLE
44	05-03-2026	Part of : RADHEY MOHAN DRIVE,JAUNAPUR VILLAGE,FATEHPUR BERI,CHANDAN HOLA	813	Other Outage	Planned Outage	05-03-2026	10:31	05-03-2026	13:30	2:59	0.000000	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN
45	05-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	25	Other Outage	Planned Outage	05-03-2026	13:53	05-03-2026	16:11	2:18	0.000000	REPLACEMENT OF LT BUSHING ROD
46	05-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	476	Other Outage	Planned Outage	05-03-2026	12:06	05-03-2026	14:45	2:39	0.000000	REPLACEMENT OF LT BUSHING ROD
47	05-03-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	652	Other Outage	Planned Outage	05-03-2026	12:22	05-03-2026	14:44	2:22	0.000000	REPLACEMET OF HT BUSHING ROD
48	06-03-2026	Part of : DERA VILLAGE,BHATI KALAN,NEW GAWALPAHARI VILLAGE,FATEHPUR BERI	2980	Other Outage	Unplanned Outage	06-03-2026	16:18	06-03-2026	17:37	1:19	0.001716	HT SYSTEM FAULT
49	06-03-2026	Part of : GADPUR FARM DLF FARMS,GADAIPIR DLF FARMS,GADAIPIR JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,SULTANPUR,	1487	Other Outage	Planned Outage	06-03-2026	12:28	06-03-2026	12:57	0:29	0.000081	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
50	06-03-2026	Part of : FATEHPUR BERI,	851	Other Outage	Planned Outage	06-03-2026	11:27	06-03-2026	13:23	1:56	0.000000	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
51	06-03-2026	Part of : MAIDAN GARHI VILLAGE CHHATARPUR,	2098	Other Outage	Planned Outage	06-03-2026	13:59	06-03-2026	16:20	2:21	0.000000	REPLACEMENT OF LT BUSHING ROD
52	06-03-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR,	605	Other Outage	Planned Outage	06-03-2026	11:39	06-03-2026	14:35	2:56	0.000000	REPLACEMENT OF HT BUSHING ROD
53	07-03-2026	Part of : A 1-BLOCK CHHATARPUR VILLAGE	968	Other Outage	Planned Outage	07-03-2026	12:36	07-03-2026	13:54	1:18	0.000000	REPLACEMENT OF HT BUSHING ROD
54	07-03-2026	Part of : SULTANPUR	252	Other Outage	Planned Outage	07-03-2026	11:36	07-03-2026	12:36	1:00	0.000000	LT CIRCUIT MAINTENANCE
55	07-03-2026	Part of : A1,D,G & F-BLOCK CHHATARPUR VILLAGE,C-BLOCK CHHATARPUR EXTENSION	4909	Other Outage	Planned Outage	07-03-2026	12:33	07-03-2026	14:35	2:02	0.000000	REPLACEMENT OF HT BUSHING ROD
56	07-03-2026	Part of : C-BLOCK CHHATARPUR EXTENSION	474	Other Outage	Planned Outage	07-03-2026	12:25	07-03-2026	14:36	2:11	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
57	09-03-2026	Part of : ASOLA,ASOLA WILD LIFE SANCTUARY ASOLA	1676	Other Outage	Unplanned Outage	09-03-2026	22:09	09-03-2026	22:42	0:33	0.000513	HT SYSTEM FAULT
58	09-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	637	Other Outage	Planned Outage	09-03-2026	14:10	09-03-2026	15:47	1:37	0.000000	REPLACEMENT OF HT BUSHING ROD
59	09-03-2026	Part of : SULTANPUR,JAUNAPUR VILLAGE JAUNAPUR,RADHEY MOHAN DRIVE	70	Other Outage	Planned Outage	09-03-2026	12:49	09-03-2026	13:52	1:03	0.000175	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
60	09-03-2026	Part of : ASOLA,BHATI KALAN,DERA VILLAGE,FATEHPUR BERI	8957	Other Outage	Planned Outage	09-03-2026	10:48	09-03-2026	13:55	3:07	0.000000	TAPPING OF JUMPERS ,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
61	09-03-2026	Part of : FATEHPUR BERI	851	Other Outage	Planned Outage	09-03-2026	11:21	09-03-2026	15:16	3:55	0.000000	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
62	09-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	1026	Other Outage	Planned Outage	09-03-2026	11:36	09-03-2026	14:17	2:41	0.000000	REPLACEMENT OF HT BUSHING ROD
63	09-03-2026	Part of : SULTANPUR	1385	Other Outage	Planned Outage	09-03-2026	12:41	09-03-2026	15:13	2:32	0.000422	REPLACEMENT OF HT BUSHING ROD
64	10-03-2026	Part of : CHANDAN HOLA,FATEHPUR BERI,ANSAL VILLAS SAT BARI,ASOLA,	1817	Other Outage	Planned Outage	10-03-2026	11:37	10-03-2026	14:00	2:23	0.000000	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF GAS KIT AND OIL SEAL
65	10-03-2026	Part of : CHANDAN HOLA,ANSAL VILLAS SAT BARI,DLF FARMS,SAT BARI,	486	Other Outage	Planned Outage	10-03-2026	11:42	10-03-2026	14:00	2:18	0.000000	REPLACEMET OF LUGS,SUB STATION CLEANING
66	10-03-2026	Part of : DERA VILLAGE,NEW GAWALPAHARI VILLAGE,GAWALPAHARI VILLAGE,	251	Other Outage	Planned Outage	10-03-2026	11:04	10-03-2026	13:05	2:01	0.001681	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
67	11-03-2026	Part of : ANSAL VILLAS SAT BARI,FATEHPUR BERI,CHANDAN HOLA,ASOLA	1826	Other Outage	Unplanned Outage	11-03-2026	06:51	11-03-2026	07:03	0:12	0.000244	BIRDAGE
68	11-03-2026	Part of : SULTANPUR	178	Other Outage	Planned Outage	11-03-2026	12:03	11-03-2026	13:30	1:27	0.000000	LT CIRCUIT MAINTENANCE
69	11-03-2026	Part of : JAUNAPUR VILLAGE	26	Other Outage	Planned Outage	11-03-2026	12:19	11-03-2026	14:37	2:18	0.000383	REPLACEMENT OF HT BUSHING ROD
70	11-03-2026	Part of : MANDI VILLAGE	282	Other Outage	Planned Outage	11-03-2026	12:05	11-03-2026	14:36	2:31	0.000419	REPLACEMENT OF HT BUSHING ROD
71	11-03-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	682	Other Outage	Planned Outage	11-03-2026	12:29	11-03-2026	15:03	2:34	0.000000	REPLACEMENT OF HT BUSHING ROD
72	11-03-2026	Part of : FATEHPUR BERI,RADHEY MOHAN DRIVE,CHANDAN HOLA	1821	Other Outage	Planned Outage	11-03-2026	11:15	11-03-2026	13:51	2:36	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
73	12-03-2026	Part of : DLF FARMS,C-BLOCK CHHATARPUR EXTENSION	431	Other Outage	Unplanned Outage	12-03-2026	22:39	12-03-2026	23:30	0:51	0.001166	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
74	12-03-2026	Part of : JAUNAPUR VILLAGE	1313	Other Outage	Unplanned Outage	12-03-2026	08:54	12-03-2026	09:28	0:34	0.000481	CABLE FAULT
75	12-03-2026	Part of : C-BLOCK CHHATARPUR EXTENSION,RAJPUR KHURD VILLAGE,A1-BLOCK CHHATARPUR VILLAGE	173	Other Outage	Unplanned Outage	12-03-2026	01:18	12-03-2026	02:13	0:55	0.000204	HT SYSTEM FAULT
76	12-03-2026	Part of : FATEHPUR BERI	850	Other Outage	Planned Outage	12-03-2026	14:27	12-03-2026	15:22	0:55	0.000000	REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
77	12-03-2026	Part of : GADPUR FARM DLF FARMS,JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,SULTANPUR	1487	Other Outage	Planned Outage	12-03-2026	12:23	12-03-2026	14:02	1:39	0.000825	REPLACEMET OF HT BUSHING ROD
78	12-03-2026	Part of : F-BLOCK AYA NAGAR EXTENSION	301	Other Outage	Planned Outage	12-03-2026	12:22	12-03-2026	14:01	1:39	0.000000	LT CIRCUIT MAINTENANCE
79	12-03-2026	Part of : CHHATARPUR ENCLAVE	173	Other Outage	Planned Outage	12-03-2026	11:26	12-03-2026	13:35	2:09	0.000000	REPLACEMET OF HT BUSHING ROD
80	13-03-2026	Part of : AYA NAGAR VILLAGE	3620	Other Outage	Unplanned Outage	13-03-2026	11:17	13-03-2026	12:23	1:06	0.000000	CONNECTION/DISCONNETION OF HT/LT CABLES
81	13-03-2026	Part of : BLOCK F AYA NAGAR EXTENSION	301	Other Outage	Planned Outage	13-03-2026	12:45	13-03-2026	13:27	0:42	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING
82	13-03-2026	Part of : AMBEDKAR COLONY MANDI	795	Other Outage	Planned Outage	13-03-2026	14:42	13-03-2026	16:01	1:19	0.000219	REPLACEMENT OF HT BUSHING ROD
83	13-03-2026	Part of : MANDI VILLAGE	461	Other Outage	Planned Outage	13-03-2026	11:24	13-03-2026	12:26	1:02	0.000000	3PH DB REPLACEMENT,PRC REPLACEMENT PER FEEDER
84	13-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,ANSAL VILLAS SAT BARI	2233	Other Outage	Planned Outage	13-03-2026	10:54	13-03-2026	13:31	2:37	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
85	13-03-2026	Part of : ASOLA	973	Other Outage	Planned Outage	13-03-2026	11:04	13-03-2026	14:28	3:24	0.000000	REPLACEMENT OF LUGS,SUB STATION CLEANING
86	14-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,	626	Other Outage	Planned Outage	14-03-2026	13:27	14-03-2026	14:15	0:48	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
87	14-03-2026	Part of : BLOCK F AYA NAGAR EXTENSION AYA NAGAR,	301	Other Outage	Planned Outage	14-03-2026	11:22	14-03-2026	13:17	1:55	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
88	14-03-2026	Part of : GADAI PUR JAUNAPUR,	45	Other Outage	Planned Outage	14-03-2026	11:23	14-03-2026	13:16	1:53	0.000000	INSTALLATION OF PHASE SEPERATOR PER SPAN,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
89	14-03-2026	Part of : BHATI KALAN,	1167	Other Outage	Planned Outage	14-03-2026	11:51	14-03-2026	13:59	2:08	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
90	14-03-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR,	42	Other Outage	Planned Outage	14-03-2026	10:56	14-03-2026	13:31	2:35	0.000000	REPLACEMENT OF LT BUSHING ROD
91	16-03-2026	Part of : SULTANPUR	1533	Other Outage	Unplanned Outage	16-03-2026	00:12	16-03-2026	00:42	0:30	0.000288	CABLE FAULT
92	16-03-2026	Part of : MANDI VILLAGE	282	Other Outage	Planned Outage	16-03-2026	14:11	16-03-2026	15:41	1:30	0.000250	REPLACEMENT OF HT BUSHING ROD
93	16-03-2026	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	4159	Other Outage	Planned Outage	16-03-2026	13:39	16-03-2026	15:28	1:49	0.000000	GUARD WIRES SAGGING
94	16-03-2026	Part of : AMBEDKAR COLONY MANDI	795	Other Outage	Planned Outage	16-03-2026	13:23	16-03-2026	15:11	1:48	0.000300	REPLACEMENT OF HT BUSHING ROD
95	16-03-2026	Part of : JAUNAPUR VILLAGE	26	Other Outage	Planned Outage	16-03-2026	12:29	16-03-2026	14:17	1:48	0.000300	REPLACEMENT OF HT BUSHING ROD
96	16-03-2026	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION	1141	Other Outage	Planned Outage	16-03-2026	11:15	16-03-2026	12:20	1:05	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
97	16-03-2026	Part of : ASOLA	1	Other Outage	Planned Outage	16-03-2026	11:51	16-03-2026	13:04	1:13	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
98	16-03-2026	Part of : JAUNAPUR VILLAGE	932	Other Outage	Planned Outage	16-03-2026	11:11	16-03-2026	12:19	1:08	0.000000	LT CIRCUIT MAINTENANCE
99	16-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	476	Other Outage	Planned Outage	16-03-2026	13:01	16-03-2026	15:27	2:26	0.000000	REPLACEMENT OF HT BUSHING ROD
100	17-03-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE	877	Other Outage	Planned Outage	17-03-2026	11:37	17-03-2026	11:58	0:21	0.000000	REPLACEMENT OF HT BUSHING ROD
101	17-03-2026	Part of : FATEHPUR BERI,RADHEY MOHAN DRIVE,CHANDAN HOLA	1848	Other Outage	Planned Outage	17-03-2026	14:08	17-03-2026	15:21	1:13	0.000608	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT PER SPAN
102	17-03-2026	Part of : JAUNAPUR VILLAGE JAUNAPUR,BHIM BASTI JUANAPUR,AMBEDKAR COLONY MANDI,MANDI VILLAGE	4037	Other Outage	Planned Outage	17-03-2026	11:11	17-03-2026	13:11	2:00	0.001000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
103	17-03-2026	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION	1141	Other Outage	Planned Outage	17-03-2026	15:01	17-03-2026	16:31	1:30	0.000000	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
104	18-03-2026	Part of : FATEHPUR BERI,ASOLA	1811	Other Outage	Unplanned Outage	18-03-2026	20:18	18-03-2026	20:23	0:05	0.000060	HT SYSTEM FAULT
105	18-03-2026	Part of : DLF FARMS,CHHATARPUR,SULTANPUR	166	Other Outage	Unplanned Outage	18-03-2026	20:06	18-03-2026	20:53	0:47	0.000260	TREE TOUCHING
106	18-03-2026	Part of : DERA VILLAGE,BHATI KALAN,NEW GAWALPAHARI VILLAGE,ASOLA,FATEHPUR BERI	3057	Other Outage	Unplanned Outage	18-03-2026	18:46	18-03-2026	19:25	0:39	0.001040	BIRDAGE
107	18-03-2026	Part of : SULTANPUR,	1263	Other Outage	Planned Outage	18-03-2026	11:54	18-03-2026	12:50	0:56	0.000000	3PH DB REVAMPING,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
108	18-03-2026	Part of : ASOLA,BHATI KALAN,ASOLA WILD LIFE SANCTUARY ASOLA,	1259	Other Outage	Planned Outage	18-03-2026	11:11	18-03-2026	12:38	1:27	0.000000	TAPPING OF JUMPERS ,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
109	18-03-2026	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION AYA NAGAR,	1141	Other Outage	Planned Outage	18-03-2026	10:53	18-03-2026	13:25	2:32	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
110	19-03-2026	Part of : AYA NAGAR VILLAGE	3625	Other Outage	Unplanned Outage	19-03-2026	15:01	19-03-2026	16:05	1:04	0.000533	REPAIRING OF RMU
111	19-03-2026	Part of : ASOLA,ANSAL VILLAS SAT BARI	809	Other Outage	Planned Outage	19-03-2026	13:12	19-03-2026	14:40	1:28	0.000000	JUMPER REPLACEMENT PER POLE,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
112	19-03-2026	Part of : ASOLA	439	Other Outage	Planned Outage	19-03-2026	12:25	19-03-2026	13:43	1:18	0.000000	CONDUCTOR REPLACEMENT PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING,GUARD WIRE LACS INSTALLTION
113	19-03-2026	Part of : JAUNAPUR VILLAGE	639	Other Outage	Planned Outage	19-03-2026	11:06	19-03-2026	12:41	1:35	0.000000	LT CIRCUIT MAINTENANCE
114	19-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	721	Other Outage	Planned Outage	19-03-2026	12:30	19-03-2026	14:53	2:23	0.000000	CONDUCTOR REPLACEMENT
115	20-03-2026	Part of : DR AMBEDKAR COLONY,CHHATARPUR PHASE-1 & 2,CHHATARPUR ENCLAVE,RAJPUR KHURD VILLAGE,CHHATARPUR ENCLAVE	2279	Other Outage	Unplanned Outage	20-03-2026	14:45	20-03-2026	15:37	0:52	0.000258	CABLE FAULT
116	20-03-2026	Part of : AYA NAGAR PHASE-1,ARJUN GARH,AYA NAGAR VILLAGE	2027	Other Outage	Unplanned Outage	20-03-2026	01:51	20-03-2026	02:25	0:34	0.000314	CABLE FAULT
117	20-03-2026	Part of : BHIM BASTI JUANAPUR	816	Other Outage	Planned Outage	20-03-2026	12:37	20-03-2026	13:18	0:41	0.000000	LT CIRCUIT MAINTENANCE
118	20-03-2026	Part of : F-BLOCK AYA NAGAR EXTENSION	344	Other Outage	Planned Outage	20-03-2026	12:13	20-03-2026	13:45	1:32	0.000000	1PH DB REVAMPING
119	23-03-2026	Part of : G-BLOCK AYA NAGAR EXTENSION	686	Other Outage	Planned Outage	23-03-2026	11:25	23-03-2026	12:15	0:50	0.000000	LT CIRCUIT MAINTENANCE
120	23-03-2026	Part of : SULTANPUR	42	Other Outage	Planned Outage	23-03-2026	11:29	23-03-2026	12:14	0:45	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
121	23-03-2026	Part of : SAT BARI	14	Other Outage	Planned Outage	23-03-2026	11:16	23-03-2026	12:15	0:59	0.000000	LT CIRCUIT MAINTENANCE
122	23-03-2026	Part of : CHHATARPUR	21	Other Outage	Planned Outage	23-03-2026	11:28	23-03-2026	12:53	1:25	0.000000	REPLACEMENT OF HT BUSHING ROD
123	24-03-2026	Part of : ANSAL VILLAS SAT BARI,FATEHPUR BERI,CHANDAN HOLA,ASOLA	1828	Other Outage	Unplanned Outage	24-03-2026	00:30	24-03-2026	00:48	0:18	0.000236	BIRDAGE
124	24-03-2026	Part of : AYA NAGAR VILLAGE	3626	Other Outage	Unplanned Outage	24-03-2026	15:50	24-03-2026	16:41	0:51	0.000142	REPAIRING OF RMU
125	24-03-2026	Part of : FATEHPUR BERI,RADHEY MOHAN DRIVE,CHANDAN HOLA	1936	Other Outage	Planned Outage	24-03-2026	11:47	24-03-2026	12:06	0:19	0.000000	HT CONDUCTOR REPLACEMENT
126	24-03-2026	Part of : G-BLOCK AYA NAGAR EXTENSION	686	Other Outage	Planned Outage	24-03-2026	11:19	24-03-2026	12:43	1:24	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
127	24-03-2026	Part of : SULTANPUR	36	Other Outage	Planned Outage	24-03-2026	10:56	24-03-2026	12:44	1:48	0.000000	LT CIRCUIT MAINTENANCE
128	24-03-2026	Part of : CHHATARPUR ENCLAVE	348	Other Outage	Planned Outage	24-03-2026	10:33	24-03-2026	13:20	2:47	0.000000	REPLACEMENT OF HT BUSHING ROD
129	25-03-2026	Part of : DLF FARMS, CHHATARPUR, SULTANPUR	168	Other Outage	Unplanned Outage	25-03-2026	10:58	25-03-2026	11:47	0:49	0.000216	TREE TOUCHING
130	25-03-2026	Part of : BLOCK G AYA NAGAR EXTENSION	686	Other Outage	Planned Outage	25-03-2026	13:34	25-03-2026	14:44	1:10	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING
131	25-03-2026	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	996	Other Outage	Planned Outage	25-03-2026	14:27	25-03-2026	16:50	2:23	0.000000	REPLACEMENT OF LT BUSHING ROD
132	26-03-2026	Part of : GADPUR FARM DLF FARMS,	522	Other Outage	Planned Outage	26-03-2026	11:01	26-03-2026	12:25	1:24	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
133	27-03-2026	Part of : AYA NAGAR VILLAGE	3639	Other Outage	Unplanned Outage	27-03-2026	16:53	27-03-2026	17:46	0:53	0.000147	REPAIRING OF RMU
134	27-03-2026	Part of : FATEHPUR BERI	1522	Other Outage	Planned Outage	27-03-2026	12:30	27-03-2026	13:47	1:17	0.000000	OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
135	27-03-2026	Part of : MANDI VILLAGE	132	Other Outage	Planned Outage	27-03-2026	11:33	27-03-2026	12:48	1:15	0.000000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
136	27-03-2026	Part of : POCKET A & B DR AMBEDKAR COLONY CHHATARPUR	1061	Other Outage	Planned Outage	27-03-2026	10:49	27-03-2026	13:30	2:41	0.000000	3PH HT AB CABLE REPLACEMENT
137	28-03-2026	Part of : CHHATARPUR VILLAGE, GHITORNI VILLAGE	3410	Other Outage	Unplanned Outage	28-03-2026	08:18	28-03-2026	08:51	0:33	0.000000	HT SYSTEM FAULT
138	28-03-2026	Part of : ASOLA	440	Other Outage	Unplanned Outage	28-03-2026	10:09	28-03-2026	11:55	1:46	0.000000	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
139	28-03-2026	Part of : ASOLA WILD LIFE SANCTUARY ASOLA,ASOLA,BHATI KALAN	1284	Other Outage	Planned Outage	28-03-2026	12:14	28-03-2026	12:52	0:38	0.000000	SUB STATION CLEANING
140	28-03-2026	Part of : BLOCK A1 CHHATARPUR VILLAGE,GHITORNI VILLAGE	3406	Other Outage	Planned Outage	28-03-2026	14:04	28-03-2026	15:37	1:33	0.000258	REPLACEMENT OF HT BUSHING ROD
141	28-03-2026	Part of : JAUNAPUR VILLAGE	676	Other Outage	Planned Outage	28-03-2026	11:02	28-03-2026	12:13	1:11	0.000000	3PH DB REPLACEMENT,PRC REPLACEMENT PER FEEDER
142	28-03-2026	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION	523	Other Outage	Planned Outage	28-03-2026	11:01	28-03-2026	13:24	2:23	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
143	30-03-2026	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION AYA NAGAR,	523	Other Outage	Planned Outage	30-03-2026	11:35	30-03-2026	12:55	1:20	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
144	30-03-2026	Part of : GADPUR FARM DLF FARMS,GADAIPUR DLF FARMS,GADAIPUR JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,SULTANPUR,	1487	Other Outage	Planned Outage	30-03-2026	10:46	30-03-2026	13:22	2:36	0.001300	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
145	31-03-2026	Part of : SAT BARI	244	Other Outage	Planned Outage	31-03-2026	11:10	31-03-2026	12:31	1:21	0.000000	REPLACEMENT OF LT BUSHING ROD
146	31-03-2026	Part of : AYA NAGAR PHASE 1	319	Other Outage	Planned Outage	31-03-2026	10:57	31-03-2026	13:14	2:17	0.000000	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS
147	02-03-2026	Part of : YUSUF SARAI,GAUTAM NAGAR,GULMOHAR ENCLAVE GULMOHAR PARK	3666	Other Outage	Unplanned Outage	02-03-2026	18:46	02-03-2026	19:42	0:56	0.001058	TRANSIENT FAULT
148	02-03-2026	Part of : HTC:L-5 GREEN PARK EXT	1	Other Outage	Planned Outage	02-03-2026	12:21	02-03-2026	12:47	0:26	0.000072	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
149	02-03-2026	Part of : MAYFAIR GARDEN HAUZ KHAS,BLOCK G HAUZ KHAS,SIRI FORT INSTITUTIONAL AREA SIRI FORT,	867	Other Outage	Planned Outage	02-03-2026	13:08	02-03-2026	14:42	1:34	0.000209	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
150	03-03-2026	Part of : ANDREWS GANJ EXTENSION ANDREWS GANJ	44	Other Outage	Unplanned Outage	03-03-2026	15:29	03-03-2026	15:34	0:05	0.000028	REPAIRING OF RMU
151	03-03-2026	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE	403	Other Outage	Unplanned Outage	03-03-2026	14:41	03-03-2026	15:13	0:32	0.000000	REPAIRING OF LT AB CIRCUIT
152	03-03-2026	Part of : S-BLOCK PANCHSHILA PARK SOUT	300	Other Outage	Planned Outage	03-03-2026	13:06	03-03-2026	13:38	0:32	0.000000	CONNECTING OF NEW EARTHING PER EARTHING,JUMPER REPLACEMENT PER POLE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
153	03-03-2026	Part of : GAUTAM NAGAR	539	Other Outage	Planned Outage	03-03-2026	11:07	03-03-2026	13:04	1:57	0.000163	APPLY OF INSULATION TAPE HT/LT BUSHINGS,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF HT/LT CLEATS
154	05-03-2026	Part of : MAYFAIR GARDEN HAUZ KHAS,SIRI FORT INSTITUTIONAL AREA,NORTH PANCHSHILA PARK,SHAHPUR JAT VILLAGE	1378	Other Outage	Planned Outage	05-03-2026	11:31	05-03-2026	13:21	1:50	0.000153	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
155	06-03-2026	Part of : BLOCK H GREEN PARK EXTENSION GREEN PARK,	247	Other Outage	Unplanned Outage	06-03-2026	15:43	06-03-2026	16:18	0:35	0.000000	CONNECTION OF NEW LT CABLE
156	06-03-2026	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE,	965	Other Outage	Unplanned Outage	06-03-2026	12:16	06-03-2026	14:13	1:57	0.000000	CONNECTION OF NEW LT CABLE
157	06-03-2026	Part of : BLOCK F GREEN PARK,	181	Other Outage	Planned Outage	06-03-2026	11:08	06-03-2026	12:59	1:51	0.000154	3PH DB REVAMPING
158	06-03-2026	Part of : BLOCK B KATWARIA SARAI,	1339	Other Outage	Planned Outage	06-03-2026	10:54	06-03-2026	13:30	2:36	0.000087	3PH DB REVAMPING
159	07-03-2026	Part of : IIT NO.3 (HTC)	0	Other Outage	Unplanned Outage	07-03-2026	18:00	07-03-2026	18:33	0:33	0.000614	HT SYSTEM FAULT
160	07-03-2026	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE	965	Other Outage	Unplanned Outage	07-03-2026	13:29	07-03-2026	14:23	0:54	0.000000	JOINTING OF NEW LT CABLE
161	07-03-2026	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE	540	Other Outage	Unplanned Outage	07-03-2026	11:50	07-03-2026	13:04	1:14	0.000000	LAYING OF NEW LTAB CABLE
162	07-03-2026	Part of : BHEL BUILDING (HT CONSUMER)	1	Other Outage	Planned Outage	07-03-2026	12:53	07-03-2026	14:07	1:14	0.000062	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
163	07-03-2026	Part of : ASSOCIATE OF OLYMPIC (HT CONSUMER)	1	Other Outage	Planned Outage	07-03-2026	11:16	07-03-2026	12:57	1:41	0.000140	PROPER SEALING RMU PER WAY,RELAY REPLACEMENT/VPI/FPI
164	07-03-2026	Part of : GAUTAM NAGAR	729	Other Outage	Planned Outage	07-03-2026	10:55	07-03-2026	13:25	2:30	0.000333	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
165	08-03-2026	Part of : ANDREWS GANJ,ANDREWS GANJ EXTENSION,M & E-BLOCK SOUTH EXTENSION-2	1218	Other Outage	Unplanned Outage	08-03-2026	10:21	08-03-2026	11:08	0:47	0.001548	CABLE FAULT
166	09-03-2026	Part of : ANDREWS GANJ EXTENSION	44	Other Outage	Planned Outage	09-03-2026	12:06	09-03-2026	12:39	0:33	0.000183	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
167	09-03-2026	Part of : BLOCK L KAUSALYA PARK PADMINI ENCLAVE HAUZ KHAS,BLOCK F POLICE COLONY HAUZ KHAS,BLOCK Q PADMINI ENCLAVE HAUZ KHAS	420	Other Outage	Planned Outage	09-03-2026	11:29	09-03-2026	13:07	1:38	0.000218	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
168	09-03-2026	Part of : POCKET B KATWARIA SARAI	674	Other Outage	Planned Outage	09-03-2026	11:39	09-03-2026	13:33	1:54	0.000158	3PH DB REVAMPING
169	09-03-2026	Part of : BLOCK D GULMOHAR PARK	294	Other Outage	Planned Outage	09-03-2026	10:54	09-03-2026	13:04	2:10	0.000325	REPLACEMENT OF GAS KIT AND OIL SEAL
170	09-03-2026	Part of : NISDOC (HT CONSUMER)	1	Other Outage	Planned Outage	09-03-2026	10:44	09-03-2026	13:11	2:27	0.000408	REPLACEMENT OF FAULTY END BOX
171	09-03-2026	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE	965	Other Outage	Planned Outage	09-03-2026	11:32	09-03-2026	14:10	2:38	0.000219	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
172	09-03-2026	Part of : BLOCK F GREEN PARK	183	Other Outage	Planned Outage	09-03-2026	11:46	09-03-2026	13:56	2:10	0.000361	3PH DB REVAMPING
173	10-03-2026	Part of : BLOCK N PANCHSHILA PARK NORTH PANCHSHILA PARK,	101	Other Outage	Planned Outage	10-03-2026	11:09	10-03-2026	12:29	1:20	0.000156	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING
174	10-03-2026	Part of : YUSUF SARAI,	557	Other Outage	Planned Outage	10-03-2026	11:08	10-03-2026	12:30	1:22	0.000137	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
175	10-03-2026	Part of : BLOCK V GREEN PARK,	421	Other Outage	Planned Outage	10-03-2026	10:59	10-03-2026	13:01	2:02	0.000678	3PH DB REVAMPING
176	11-03-2026	Part of : INSTITUTIONAL AREA HAUZ KHAS	19	Other Outage	Planned Outage	11-03-2026	11:11	11-03-2026	11:56	0:45	0.000063	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
177	11-03-2026	Part of : DEER PARK HAUZ KHAS	307	Other Outage	Planned Outage	11-03-2026	11:05	11-03-2026	13:21	2:16	0.000378	LT CIRCUIT MAINTENANCE
178	12-03-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE	566	Other Outage	Unplanned Outage	12-03-2026	12:21	12-03-2026	14:27	2:06	0.000000	REPAIR OF DAMAGED WIRE ON POLES
179	12-03-2026	Part of : S-BLOCK PANCHSHILA PARK SOUTH	164	Other Outage	Planned Outage	12-03-2026	11:11	12-03-2026	11:56	0:45	0.000088	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
180	13-03-2026	Part of : BLOCK C7 BHIM NAGAR HAUZ KHAS	264	Other Outage	Planned Outage	13-03-2026	11:03	13-03-2026	12:55	1:52	0.000311	3PH DB REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
181	13-03-2026	Part of : JIA SARAI HAUZ KHAS	227	Other Outage	Planned Outage	13-03-2026	13:19	13-03-2026	15:24	2:05	0.000347	DT REPLACEMENT
182	14-03-2026	Part of : SIRI FORT INSTITUTIONAL AREA SIRI FORT,	1	Other Outage	Planned Outage	14-03-2026	12:05	14-03-2026	13:17	1:12	0.000100	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
183	14-03-2026	Part of : HTC:M/S DIR OF WORKS MINE OF D,C-7 QLA	1	Other Outage	Planned Outage	14-03-2026	11:42	14-03-2026	13:03	1:21	0.000090	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
184	14-03-2026	Part of : BLOCK B KATWARIA SARAI,	439	Other Outage	Planned Outage	14-03-2026	11:36	14-03-2026	13:32	1:56	0.000387	3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
185	16-03-2026	Part of : B 4-BLOCK SAFDARJUNG ENCLAVE	358	Other Outage	Unplanned Outage	16-03-2026	13:44	16-03-2026	14:06	0:22	0.000061	LT CIRCUIT JUMPER REPLACEMENT
186	16-03-2026	Part of : ASIAN GAMES VILLAGE COMPLEX SIRI FORT	267	Other Outage	Planned Outage	16-03-2026	11:26	16-03-2026	12:30	1:04	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
187	16-03-2026	Part of : C 7-BLOCK BHIM NAGAR HAUZ KHAS	332	Other Outage	Planned Outage	16-03-2026	11:38	16-03-2026	13:24	1:46	0.000294	LT CIRCUIT MAINTENANCE
188	17-03-2026	Part of : BLOCK B 3 SAFDARJUNG ENCLAVE	2927	Other Outage	Unplanned Outage	17-03-2026	06:24	17-03-2026	07:23	0:59	0.000857	CABLE FAULT
189	17-03-2026	Part of : BLOCK B 3 SAFDARJUNG ENCLAVE	304	Other Outage	Unplanned Outage	17-03-2026	13:46	17-03-2026	15:11	1:25	0.000000	TREE TRIMMING
190	17-03-2026	Part of : TEL. EXCHANGE(HT CONSUMER) HAUZ KHAS	0	Other Outage	Unplanned Outage	17-03-2026	10:55	17-03-2026	13:04	2:09	0.000000	REPLACEMENT OF RMU
191	17-03-2026	Part of : BLOCK X HAUZ KHAS	162	Other Outage	Planned Outage	17-03-2026	11:16	17-03-2026	12:23	1:07	0.000130	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS
192	17-03-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE	1429	Other Outage	Planned Outage	17-03-2026	11:20	17-03-2026	12:58	1:38	0.000272	REPLACEMENT OF GAS KIT AND OIL SEAL
193	18-03-2026	Part of : SHAHPUR JAT VILLAGE SIRI FORT,	1133	Other Outage	Planned Outage	18-03-2026	11:03	18-03-2026	12:41	1:38	0.000136	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
194	18-03-2026	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE,	719	Other Outage	Planned Outage	18-03-2026	12:02	18-03-2026	15:26	3:24	0.000850	DT REPLACEMENT
195	18-03-2026	Part of : BLOCK A KATWARIA SARAI,	1271	Other Outage	Planned Outage	18-03-2026	11:15	18-03-2026	13:19	2:04	0.000344	3PH DB REVAMPING
196	19-03-2026	Part of : BLOCK A 1 NAUROJI NAGAR SAFDARJUNG ENCLAVE	312	Other Outage	Unplanned Outage	19-03-2026	13:39	19-03-2026	14:19	0:40	0.000000	TREE TRIMMING
197	19-03-2026	Part of : BLOCK C 3 SAFDARJUNG DEVELOPMENT AREA HAUZ KHAS	238	Other Outage	Unplanned Outage	19-03-2026	13:03	19-03-2026	15:45	2:42	0.000000	REPAIRING OF DB AND SERVICE LINE
198	19-03-2026	Part of : E-BLOCK HAUZ KHAS	852	Other Outage	Planned Outage	19-03-2026	11:12	19-03-2026	11:43	0:31	0.000026	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
199	19-03-2026	Part of : P-BLOCK SOUTH EXTENSION-2	534	Other Outage	Planned Outage	19-03-2026	10:26	19-03-2026	14:54	4:28	0.000074	LT CIRCUIT MAINTENANCE
200	20-03-2026	Part of : RAMAKRISHNA PURAM SECTOR 2,DEER PARK HAUZ KHAS	310	Other Outage	Unplanned Outage	20-03-2026	07:51	20-03-2026	08:39	0:48	0.000520	TREE TOUCHING
201	20-03-2026	Part of : YUSUF SARAI	955	Other Outage	Planned Outage	20-03-2026	11:52	20-03-2026	12:22	0:30	0.000267	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER
202	20-03-2026	Part of : B-BLOCK KATWARIA SARAI	439	Other Outage	Planned Outage	20-03-2026	11:38	20-03-2026	14:24	2:46	0.000000	LT CIRCUIT MAINTENANCE
203	22-03-2026	Part of : HTC:B-8, S.I.I.A., HTC:POWER GRID CORPORATION	0	Other Outage	Unplanned Outage	22-03-2026	21:03	22-03-2026	21:47	0:44	0.000180	CABLE FAULT
204	22-03-2026	Part of : BLOCK B QUTAB INSTITUTIONAL AREA,BLOCK C QUTAB INSTITUTIONAL AREA	180	Other Outage	Unplanned Outage	22-03-2026	04:06	22-03-2026	05:04	0:58	0.000292	CABLE FAULT
205	23-03-2026	Part of : BLOCK A GREEN PARK	1	Other Outage	Unplanned Outage	23-03-2026	14:36	23-03-2026	15:18	0:42	0.000000	REPAIRING OF LT CIRCUIT
206	23-03-2026	Part of : B 7-BLOCK ARJUN NAGAR SAFDARJUNG ENCLAVE	840	Other Outage	Planned Outage	23-03-2026	11:36	23-03-2026	14:19	2:43	0.000679	LT CIRCUIT MAINTENANCE
207	24-03-2026	Part of : MAYFAIR GARDEN HAUZ KHAS	269	Other Outage	Planned Outage	24-03-2026	11:29	24-03-2026	13:22	1:53	0.000220	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF SILICAGEL IN BREATHER
208	24-03-2026	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE	430	Other Outage	Planned Outage	24-03-2026	11:12	24-03-2026	12:49	1:37	0.000404	LT CIRCUIT MAINTENANCE
209	25-03-2026	Part of : BLOCK C GREEN PARK EXTENSION	781	Other Outage	Unplanned Outage	25-03-2026	11:54	25-03-2026	13:53	1:59	0.000000	REPAIR OF DAMAGED WIRE ON POLES
210	25-03-2026	Part of : ASIAN GAMES VILLAGE COMPLEX SIRI FORT	95	Other Outage	Planned Outage	25-03-2026	11:25	25-03-2026	13:21	1:56	0.000000	REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
211	25-03-2026	Part of : BLOCK A KATWARIA SARAI	635	Other Outage	Planned Outage	25-03-2026	11:25	25-03-2026	13:19	1:54	0.000158	3PH DB REVAMPING
212	27-03-2026	Part of : B 4-BLOCK SAFDARJUNG ENCLAVE	409	Other Outage	Planned Outage	27-03-2026	11:19	27-03-2026	13:13	1:54	0.000475	REPLACEMENT OF GAS KIT AND OIL SEAL
213	27-03-2026	Part of : BEER SARAI	350	Other Outage	Planned Outage	27-03-2026	11:42	27-03-2026	13:11	1:29	0.000074	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
214	28-03-2026	Part of : BLOCK A GREEN PARK EXTENSION	314	Other Outage	Unplanned Outage	28-03-2026	11:39	28-03-2026	12:26	0:47	0.000000	TREE TRIMMING
215	28-03-2026	Part of : GAUTAM NAGAR	279	Other Outage	Planned Outage	28-03-2026	11:22	28-03-2026	13:23	2:01	0.000168	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
216	28-03-2026	Part of : KENDRIYA(RASTRIYA) HINDI SANSTHAN (HTC)	1	Other Outage	Planned Outage	28-03-2026	10:59	28-03-2026	14:07	3:08	0.000313	REPLACEMENT OF FAULTY END BOX
217	30-03-2026	Part of : BLOCK C QUTAB INSTITUTIONAL AREA,BLOCK B QUTAB INSTITUTIONAL AREA,	216	Other Outage	Planned Outage	30-03-2026	12:58	30-03-2026	13:22	0:24	0.000200	CLEANING OF INSULATORS PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
218	30-03-2026	Part of : HTC:PURULATOR HAUZ KHAS	1	Other Outage	Planned Outage	30-03-2026	11:20	30-03-2026	11:57	0:37	0.000021	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
219	30-03-2026	Part of : SHAHPUR JAT VILLAGE SIRI FORT,	82	Other Outage	Planned Outage	30-03-2026	11:19	30-03-2026	13:52	2:33	0.000425	CONDUCTOR REPLACEMENT PER SPAN
220	31-03-2026	Part of : BLOCK C SOUTH EXTENSION II	517	Other Outage	Planned Outage	31-03-2026	10:55	31-03-2026	15:18	4:23	0.000365	LT AB SAGGING PER SPAN
221	02-03-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,	1159	Other Outage	Planned Outage	02-03-2026	11:37	02-03-2026	13:56	2:19	0.000425	3PH DB REPLACEMENT
222	02-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR,	2838	Other Outage	Planned Outage	02-03-2026	09:56	02-03-2026	12:55	2:59	0.000994	3PH HT AB CABLE REPLACEMENT PER SPAN
223	02-03-2026	Part of : BLOCK J 2 DEVLII SANGAM VIHAR,	2492	Other Outage	Planned Outage	02-03-2026	10:31	02-03-2026	12:54	2:23	0.000437	3PH HT AB CABLE REPLACEMENT PER SPAN
224	03-03-2026	Part of : VAYUSENA VIHAR VAYUSENABAD	2895	Other Outage	Planned Outage	03-03-2026	12:00	03-03-2026	13:32	1:32	0.000281	3PH DB REPLACEMENT
225	03-03-2026	Part of : J 2-BLOCK DEVLII SANGAM VIHAR	4120	Other Outage	Planned Outage	03-03-2026	11:19	03-03-2026	13:20	2:01	0.000370	3PH HT AB CABLE REPLACEMENT
226	03-03-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	1671	Other Outage	Planned Outage	03-03-2026	09:56	03-03-2026	12:56	3:00	0.000550	3PH HT AB CABLE REPLACEMENT
227	05-03-2026	Part of : DURGA VIHAR DEVLII SANGAM VIHAR	1056	Other Outage	Planned Outage	05-03-2026	14:59	05-03-2026	16:08	1:09	0.000211	3PH HT AB CABLE REPLACEMENT PER SPAN
228	06-03-2026	Part of : POCKET A JAWAHAR PARK KHANPUR,	1382	Other Outage	Planned Outage	06-03-2026	10:50	06-03-2026	12:39	1:49	0.000333	3PH HT AB CABLE REPLACEMENT PER SPAN
229	06-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR,	2839	Other Outage	Planned Outage	06-03-2026	09:56	06-03-2026	12:52	2:56	0.000538	3PH HT AB CABLE REPLACEMENT PER SPAN
230	06-03-2026	Part of : BLOCK J 2 DEVLII SANGAM VIHAR,	4120	Other Outage	Planned Outage	06-03-2026	10:32	06-03-2026	12:55	2:23	0.000437	3PH HT AB CABLE REPLACEMENT PER SPAN
231	07-03-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	864	Other Outage	Planned Outage	07-03-2026	11:31	07-03-2026	13:47	2:16	0.000416	3PH HT AB CABLE REPLACEMENT
232	07-03-2026	Part of : B,C & L-BLOCK DEVLII SANGAM VIHAR	3	Other Outage	Planned Outage	07-03-2026	11:07	07-03-2026	13:32	2:25	0.000443	3PH HT AB END TERMINATION REPLACEMENT
233	07-03-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	1671	Other Outage	Planned Outage	07-03-2026	10:03	07-03-2026	12:57	2:54	0.000532	3PH HT AB CABLE REPLACEMENT
234	08-03-2026	Part of : POCKET C DUGGAL COLONY & JJ COLONY DUGGAL COLONY KHANPUR	779	Other Outage	Unplanned Outage	08-03-2026	03:18	08-03-2026	03:57	0:39	0.000509	HVDS FAULT
235	09-03-2026	Part of : BLOCK D SANGAM VIHAR,BLOCK B TIGRI EXTENSION SANGAM VIHAR,BLOCK B, C & L DEVLII SANGAM VIHAR	6508	Other Outage	Unplanned Outage	09-03-2026	23:21	10-03-2026	00:00	0:39	0.000054	HT SYSTEM FAULT
236	09-03-2026	Part of : BLOCK 2 & 4 DAKSHINPURI EXTENSION SECTOR 6,BLOCK A SECTOR 5 DAKSHINPURI	1703	Other Outage	Planned Outage	09-03-2026	10:37	09-03-2026	12:30	1:53	0.000345	3PH DB REPLACEMENT
237	09-03-2026	Part of : BLOCK B TIGRI EXTENSION SANGAM VIHAR	1274	Other Outage	Planned Outage	09-03-2026	11:31	09-03-2026	12:46	1:15	0.000229	3PH DB REPLACEMENT
238	09-03-2026	Part of : BLOCK B, C & L DEVLII SANGAM VIHAR	3	Other Outage	Planned Outage	09-03-2026	12:32	09-03-2026	14:30	1:58	0.000361	3PH HT AB CABLE REPLACEMENT PER SPAN
239	09-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	2839	Other Outage	Planned Outage	09-03-2026	09:55	09-03-2026	12:54	2:59	0.000547	3PH HT AB CABLE REPLACEMENT PER SPAN
240	10-03-2026	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	838	Other Outage	Unplanned Outage	10-03-2026	14:34	10-03-2026	16:38	2:04	0.001033	MOBILE TRANSFORMER REPLACEMENT
241	10-03-2026	Part of : KHANPUR EXTENSION SANGAM VIHAR,KHANPUR VILLAGE KHANPUR,POCKET A DUGGAL COLONY KHANPUR,BLOCK G SECTOR 5 DAKSHINPURI,JAWAHAR PARK SANGAM VIHAR,	1305	Other Outage	Planned Outage	10-03-2026	13:07	10-03-2026	14:43	1:36	0.000293	3PH HT AB CABLE REPLACEMENT PER SPAN
242	10-03-2026	Part of : BLOCK F 2 SANGAM VIHAR,	1301	Other Outage	Planned Outage	10-03-2026	10:57	10-03-2026	13:40	2:43	0.000498	3PH HT AB CABLE REPLACEMENT PER SPAN
243	10-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR,	3447	Other Outage	Planned Outage	10-03-2026	10:09	10-03-2026	13:20	3:11	0.000584	3PH HT AB CABLE REPLACEMENT PER SPAN
244	10-03-2026	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,BLOCK A TIGRI EXTENSION SANGAM VIHAR,	1671	Other Outage	Planned Outage	10-03-2026	09:54	10-03-2026	12:34	2:40	0.000489	3PH HT AB CABLE REPLACEMENT PER SPAN
245	11-03-2026	Part of : RPS COLONY MADANGIR	1133	Other Outage	Unplanned Outage	11-03-2026	11:03	11-03-2026	13:07	2:04	0.000344	REPLACEMENT OF BURNT CABLE
246	11-03-2026	Part of : F-BLOCK KHANPUR COLONY KHANPUR	1382	Other Outage	Planned Outage	11-03-2026	11:50	11-03-2026	12:55	1:05	0.000199	3PH HT AB CABLE REPLACEMENT
247	11-03-2026	Part of : K, I 1 & G 2-BLOCK SANGAM VIHAR,ASOLA WILD LIFE SANCTUARY, TUGHLAKABAD	3639	Other Outage	Planned Outage	11-03-2026	10:23	11-03-2026	13:04	2:41	0.000492	3PH HT AB CABLE REPLACEMENT
248	11-03-2026	Part of : L 2-BLOCK DEVLII SANGAM VIHAR	2839	Other Outage	Planned Outage	11-03-2026	09:58	11-03-2026	12:57	2:59	0.000547	3PH HT AB CABLE REPLACEMENT
249	12-03-2026	Part of : G 2-BLOCK SANGAM VIHAR	215	Other Outage	Planned Outage	12-03-2026	10:42	12-03-2026	13:22	2:40	0.000489	3PH HT AB CABLE REPLACEMENT
250	12-03-2026	Part of : DURGA VIHAR DEVLII SANGAM VIHAR	1057	Other Outage	Planned Outage	12-03-2026	09:56	12-03-2026	12:58	3:02	0.000556	3PH HT AB CABLE REPLACEMENT
251	13-03-2026	Part of : BLOCK B TIGRI EXTENSION SANGAM VIHAR	1274	Other Outage	Planned Outage	13-03-2026	11:47	13-03-2026	13:57	2:10	0.000397	3PH DB REPLACEMENT
252	13-03-2026	Part of : BLOCK L DEVLII SANGAM VIHAR,BLOCK G DEVLII SANGAM VIHAR	3270	Other Outage	Planned Outage	13-03-2026	10:10	13-03-2026	12:52	2:42	0.000495	3PH HT AB CABLE REPLACEMENT PER SPAN
253	13-03-2026	Part of : BLOCK K SANGAM VIHAR	3639	Other Outage	Planned Outage	13-03-2026	10:03	13-03-2026	13:19	3:16	0.000599	3PH HT AB CABLE REPLACEMENT PER SPAN
254	14-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR,	2840	Other Outage	Planned Outage	14-03-2026	10:01	14-03-2026	13:07	3:06	0.000568	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
255	14-03-2026	Part of : BLOCK H SANGAM VIHAR,TALIMABAD SANGAM VIHAR,	2439	Other Outage	Planned Outage	14-03-2026	10:29	14-03-2026	12:56	2:27	0.000449	3PH HT AB CABLE REPLACEMENT PER SPAN
256	15-03-2026	Part of : MADANGIR VILLAGE MADANGIR,BLOCK 10 DAKSHINPURI	3782	Other Outage	Unplanned Outage	15-03-2026	08:06	15-03-2026	08:25	0:19	0.000232	CABLE FAULT
257	16-03-2026	Part of : RPS COLONY MADANGIR,J-BLOCK JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	2730	Other Outage	Unplanned Outage	16-03-2026	19:33	16-03-2026	20:09	0:36	0.000683	CABLE FAULT
258	16-03-2026	Part of : C,G 2, F 2 & F 3-BLOCK SANGAM VIHAR,VAYUSENA VIHAR	7982	Other Outage	Unplanned Outage	16-03-2026	14:57	16-03-2026	15:37	0:40	0.000394	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
259	16-03-2026	Part of : TIGRI COLONY SANGAM VIHAR	1314	Other Outage	Planned Outage	16-03-2026	15:07	16-03-2026	16:34	1:27	0.000266	DT REPLACEMENT
260	16-03-2026	Part of : JAWAHAR PARK SANGAM VIHAR	815	Other Outage	Planned Outage	16-03-2026	12:29	16-03-2026	14:15	1:46	0.000324	REPLACEMENT OF GAS KIT AND OIL SEAL
261	16-03-2026	Part of : J 2-BLOCK DEVL I SANGAM VIHAR	4120	Other Outage	Planned Outage	16-03-2026	10:57	16-03-2026	13:38	2:41	0.000492	3PH HT AB CABLE REPLACEMENT
262	16-03-2026	Part of : DURGA VIHAR DEVL I SANGAM VIHAR	1003	Other Outage	Planned Outage	16-03-2026	12:04	16-03-2026	14:24	2:20	0.001944	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
263	16-03-2026	Part of : L & L 2-BLOCK L 2 DEVL I SANGAM VIHAR	1982	Other Outage	Planned Outage	16-03-2026	09:55	16-03-2026	12:55	3:00	0.000550	3PH HT AB CABLE REPLACEMENT
264	17-03-2026	Part of : BLOCK D & E SANGAM VIHAR	4505	Other Outage	Unplanned Outage	17-03-2026	00:49	17-03-2026	01:02	0:13	0.000177	CABLE FAULT
265	17-03-2026	Part of : JAWAHAR PARK SANGAM VIHAR,DEOLI GAON NAI BASTI SANGAM VIHAR	1380	Other Outage	Planned Outage	17-03-2026	15:12	17-03-2026	16:01	0:49	0.000150	CONDUCTOR REPLACEMENT PER SPAN
266	17-03-2026	Part of : BLOCK J 1 DEVL I SANGAM VIHAR	2818	Other Outage	Planned Outage	17-03-2026	10:32	17-03-2026	12:57	2:25	0.000443	3PH HT AB CABLE REPLACEMENT PER SPAN
267	17-03-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	2840	Other Outage	Planned Outage	17-03-2026	10:04	17-03-2026	12:30	2:26	0.000446	3PH HT AB CABLE REPLACEMENT PER SPAN
268	17-03-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR	1503	Other Outage	Planned Outage	17-03-2026	10:03	17-03-2026	12:55	2:52	0.000526	3PH HT AB CABLE REPLACEMENT PER SPAN
269	18-03-2026	Part of : F-2 BLOCK SANGAM VIHAR	0	Other Outage	Unplanned Outage	18-03-2026	22:01	18-03-2026	22:57	0:56	0.000119	HVDS FAULT
270	18-03-2026	Part of : RPS COLONY MADANGIR,KHANPUR EXTENSION SANGAM VIHAR,POCKET A DUGGAL COLONY KHANPUR,KHANPUR VILLAGE KHANPUR,JAWAHAR PARK SANGAM VIHAR,BLOCK G SECTOR 5 DAKSHINPURI	1635	Other Outage	Unplanned Outage	18-03-2026	19:51	18-03-2026	20:47	0:56	0.000901	HT SYSTEM FAULT
271	18-03-2026	Part of : POCKET C RAJU PARK SANGAM VIHAR,	2184	Other Outage	Unplanned Outage	18-03-2026	11:25	18-03-2026	13:15	1:50	0.000000	REPAIRING OF JUMPER
272	18-03-2026	Part of : BLOCK B SECTOR 5 DAKSHINPURI,BLOCK A SECTOR 5 DAKSHINPURI,	2717	Other Outage	Planned Outage	18-03-2026	13:18	18-03-2026	15:56	2:38	0.000878	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
273	18-03-2026	Part of : DURGA VIHAR DEVL I SANGAM VIHAR,	1056	Other Outage	Planned Outage	18-03-2026	09:56	18-03-2026	12:59	3:03	0.000559	3PH HT AB CABLE REPLACEMENT PER SPAN
274	18-03-2026	Part of : BLOCK L 2 DEVL I SANGAM VIHAR,	3390	Other Outage	Planned Outage	18-03-2026	09:55	18-03-2026	13:01	3:06	0.000568	3PH HT AB CABLE REPLACEMENT PER SPAN
275	19-03-2026	Part of : BLOCK B SECTOR 5 DAKSHINPURI,BLOCK A SECTOR 5 DAKSHINPURI	2717	Other Outage	Unplanned Outage	19-03-2026	13:22	19-03-2026	15:58	2:36	0.001083	MOBILE TRANSFORMER REPLACEMENT
276	19-03-2026	Part of : TALIMABAD SANGAM VIHAR	720	Other Outage	Planned Outage	19-03-2026	12:10	19-03-2026	13:41	1:31	0.000278	DT OIL SAMPLING TO CHECK BDV VALUE
277	19-03-2026	Part of : B-BLOCK DEVL I SANGAM VIHAR	1196	Other Outage	Planned Outage	19-03-2026	12:20	19-03-2026	14:32	2:12	0.000403	DT OIL SAMPLING TO CHECK BDV VALUE
278	19-03-2026	Part of : J 1-BLOCK DEVL I SANGAM VIHAR	9	Other Outage	Planned Outage	19-03-2026	12:09	19-03-2026	14:51	2:42	0.000495	DT OIL SAMPLING TO CHECK BDV VALUE
279	19-03-2026	Part of : B-BLOCK DEVL I SANGAM VIHAR	1796	Other Outage	Planned Outage	19-03-2026	10:42	19-03-2026	13:40	2:58	0.000544	3PH HT AB CABLE REPLACEMENT
280	19-03-2026	Part of : L 2-BLOCK DEVL I SANGAM VIHAR	2840	Other Outage	Planned Outage	19-03-2026	10:18	19-03-2026	12:49	2:31	0.000461	3PH HT AB CABLE REPLACEMENT
281	19-03-2026	Part of : L 2-BLOCK DEVL I SANGAM VIHAR	1552	Other Outage	Planned Outage	19-03-2026	10:17	19-03-2026	12:50	2:33	0.000468	3PH HT AB CABLE REPLACEMENT
282	20-03-2026	Part of : DURGA VIHAR DEVL I SANGAM VIHAR	12	Other Outage	Planned Outage	20-03-2026	11:24	20-03-2026	13:03	1:39	0.000303	3PH HT AB CABLE REPLACEMENT
283	20-03-2026	Part of : B-BLOCK DEVL I SANGAM VIHAR	2351	Other Outage	Planned Outage	20-03-2026	11:50	20-03-2026	13:10	1:20	0.000244	3PH HT AB CABLE REPLACEMENT
284	21-03-2026	Part of : JJ COLONY DR AMBEDKAR NAGAR, DR AMBEDKAR NAGAR MADANGIR, MADANGIR CHUDI MARKET	5727	Other Outage	Unplanned Outage	21-03-2026	17:45	21-03-2026	18:33	0:48	0.000830	CABLE FAULT
285	21-03-2026	Part of : RPS COLONY MADANGIR, KHANPUR EXTENSION, POCKET A DUGGAL COLONY, KHANPUR VILLAGE	1634	Other Outage	Unplanned Outage	21-03-2026	12:42	21-03-2026	13:24	0:42	0.000561	CABLE DAMAGED BY OUTSIDE AGENCY (DMRC)
286	22-03-2026	Part of : D BLOCK JJ COLONY KHANPUR,BLOCK B JJ COLONY KHANPUR,KHANPUR VILLAGE KHANPUR	2997	Other Outage	Unplanned Outage	22-03-2026	22:17	22-03-2026	22:55	0:38	0.000739	HT SYSTEM FAULT
287	22-03-2026	Part of : BLOCK D JJ COLONY KHANPUR,BLOCK B JJ COLONY KHANPUR,KHANPUR VILLAGE KHANPUR	2997	Other Outage	Unplanned Outage	22-03-2026	18:54	22-03-2026	19:37	0:43	0.000922	CABLE FAULT
288	22-03-2026	Part of : DEVL I BANDH RMU NEW	0	Other Outage	Unplanned Outage	22-03-2026	10:24	22-03-2026	10:57	0:33	0.000283	HVDS FAULT
289	23-03-2026	Part of : JAWAHAR PARK SANGAM VIHAR	864	Other Outage	Planned Outage	23-03-2026	12:22	23-03-2026	14:26	2:04	0.000379	3PH HT AB CABLE REPLACEMENT
290	23-03-2026	Part of : B & C-BLOCK DEVL I SANGAM VIHAR,F-BLOCK SANGAM VIHAR	3623	Other Outage	Planned Outage	23-03-2026	10:44	23-03-2026	13:43	2:59	0.000547	3PH HT AB CABLE REPLACEMENT
291	24-03-2026	Part of : J 1-BLOCK DEVL I SANGAM VIHAR	2232	Other Outage	Planned Outage	24-03-2026	10:44	24-03-2026	13:41	2:57	0.000541	3PH HT AB CABLE REPLACEMENT
292	24-03-2026	Part of : L 2-BLOCK DEVL I SANGAM VIHAR,	1683	Other Outage	Planned Outage	24-03-2026	09:58	24-03-2026	13:00	3:02	0.000556	3PH HT AB CABLE REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
293	25-03-2026	Part of : DDA LIG FLATS PULPEHLADPUR, BLOCK C,F & G VISHWAKARMA COLONY PULPEHLADPUR	1916	Other Outage	Unplanned Outage	25-03-2026	09:54	25-03-2026	10:37	0:43	0.001072	HVDS FAULT
294	25-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	1552	Other Outage	Planned Outage	25-03-2026	11:14	25-03-2026	12:55	1:41	0.000309	3PH HT AB CABLE REPLACEMENT PER SPAN
295	25-03-2026	Part of : BLOCK K SANGAM VIHAR	3639	Other Outage	Planned Outage	25-03-2026	11:02	25-03-2026	13:22	2:20	0.000428	3PH HT AB CABLE REPLACEMENT PER SPAN
296	25-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	2840	Other Outage	Planned Outage	25-03-2026	10:02	25-03-2026	12:53	2:51	0.000523	3PH HT AB CABLE REPLACEMENT PER SPAN
297	26-03-2026	Part of : BLOCK C LAL KUAN,BLOCK A VISHWAKARMA COLONY PULPEHLADPUR,BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,BLOCK B VISHWAKARMA COLONY PULPEHLADPUR,BLOCK C VISHWAKARMA COLONY PULPEHLADPUR,BLOCK F VISHWAKARMA COLONY PULPEHLADPUR	3160	Other Outage	Unplanned Outage	26-03-2026	21:54	26-03-2026	22:13	0:19	0.000331	CABLE FAULT
298	27-03-2026	Part of : RPS COLONY MADANGIR,BLOCK I JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	2734	Other Outage	Unplanned Outage	27-03-2026	16:33	27-03-2026	17:10	0:37	0.000187	HVDS FAULT
299	27-03-2026	Part of : L & L 2-BLOCK L DEVLII SANGAM VIHAR	1982	Other Outage	Planned Outage	27-03-2026	10:26	27-03-2026	12:51	2:25	0.000443	3PH HT AB CABLE REPLACEMENT
300	27-03-2026	Part of : C-BLOCK DEVLII SANGAM VIHAR	3	Other Outage	Planned Outage	27-03-2026	10:07	27-03-2026	13:12	3:05	0.000565	3PH HT AB CABLE REPLACEMENT
301	28-03-2026	Part of : BLOCK A LAL KUAN	932	Other Outage	Planned Outage	28-03-2026	14:58	28-03-2026	15:31	0:33	0.000183	MEASUREMET OF INSULATION RESISTANCE
302	28-03-2026	Part of : BLOCK C PULPEHLADPUR	229	Other Outage	Planned Outage	28-03-2026	11:12	28-03-2026	13:06	1:54	0.000792	ACB REPLACEMENT PER ACB,PROPER LOOP EARTHING/STRUCTURE EARTHING PER ACB
303	28-03-2026	Part of : BLOCK J 2 DEVLII SANGAM VIHAR	2492	Other Outage	Planned Outage	28-03-2026	10:58	28-03-2026	13:28	2:30	0.000458	3PH HT AB CABLE REPLACEMENT PER SPAN
304	28-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	2840	Other Outage	Planned Outage	28-03-2026	10:00	28-03-2026	12:57	2:57	0.000541	3PH HT AB CABLE REPLACEMENT PER SPAN
305	30-03-2026	Part of : HTC BATRA HOSPITAL	0	Other Outage	Unplanned Outage	30-03-2026	23:00	30-03-2026	23:03	0:03	0.000000	CABLE FAULT
306	30-03-2026	Part of : BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,	45	Other Outage	Planned Outage	30-03-2026	11:38	30-03-2026	12:34	0:56	0.000156	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
307	30-03-2026	Part of : BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,	1	Other Outage	Planned Outage	30-03-2026	11:38	30-03-2026	12:32	0:54	0.000150	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
308	30-03-2026	Part of : BLOCK C VISHWAKARMA COLONY PULPEHLADPUR,	229	Other Outage	Planned Outage	30-03-2026	12:33	30-03-2026	13:45	1:12	0.000200	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
309	30-03-2026	Part of : BLOCK J 2 DEVLII SANGAM VIHAR,	4120	Other Outage	Planned Outage	30-03-2026	10:36	30-03-2026	12:56	2:20	0.000428	3PH HT AB CABLE REPLACEMENT PER SPAN
310	30-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR,DURGA VIHAR DEVLII SANGAM VIHAR,	4552	Other Outage	Planned Outage	30-03-2026	09:58	30-03-2026	12:56	2:58	0.000544	3PH HT AB CABLE REPLACEMENT PER SPAN
311	31-03-2026	Part of : TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD	10	Other Outage	Planned Outage	31-03-2026	11:16	31-03-2026	12:14	0:58	0.000403	REPLACEMENT OF FAULTY END BOX
312	31-03-2026	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	2531	Other Outage	Planned Outage	31-03-2026	10:48	31-03-2026	13:03	2:15	0.000413	3PH HT AB CABLE REPLACEMENT PER SPAN
313	02-03-2026	Part of : BLOCK H SHAHEEN BAGH JASOLA VIHAR,	302	Other Outage	Planned Outage	02-03-2026	10:38	02-03-2026	11:28	0:50	0.000583	REPLACEMENT OF LT BUSHING ROD
314	05-03-2026	Part of : JASOLA VIHAR	4	Other Outage	Planned Outage	05-03-2026	10:22	05-03-2026	11:33	1:11	0.000828	REPLACEMENT OF LT BUSHING ROD
315	05-03-2026	Part of : POCKET 10B JASOLA VIHAR	332	Other Outage	Planned Outage	05-03-2026	10:22	05-03-2026	11:32	1:10	0.000389	INSTALLATION OF BUS BAR
316	06-03-2026	Part of : BLOCK A TAIMOOR NAGAR NEW FRIENDS COLONY,	493	Other Outage	Planned Outage	06-03-2026	11:09	06-03-2026	13:31	2:22	0.001183	REPLACEMENT OF LT BUSHING ROD
317	07-03-2026	Part of : A-BLOCK SHAHEEN BAGH JASOLA VIHAR	970	Other Outage	Planned Outage	07-03-2026	13:15	07-03-2026	13:47	0:32	0.000356	INSTALLATION OF BUS BAR
318	07-03-2026	Part of : POCKET 1 JASOLA VIHAR	158	Other Outage	Planned Outage	07-03-2026	10:15	07-03-2026	12:13	1:58	0.000656	INSTALLATION OF BUS BAR
319	07-03-2026	Part of : M-BLOCK ABUL FAZAL ENCLAVE PART 1 JAMIA NAGAR OKHLA	739	Other Outage	Planned Outage	07-03-2026	10:09	07-03-2026	12:01	1:52	0.001307	REPLACEMENT OF HT BUSHING ROD
320	09-03-2026	Part of : BLOCK C JOGA BAI EXTENSION OKHLA	4090	Other Outage	Planned Outage	09-03-2026	10:05	09-03-2026	12:17	2:12	0.001283	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
321	10-03-2026	Part of : BLOCK G SRINIVAS PURI,	656	Other Outage	Planned Outage	10-03-2026	12:13	10-03-2026	14:31	2:18	0.001150	REPLACEMENT OF LT BUSHING ROD
322	10-03-2026	Part of : BLOCK N PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA,	490	Other Outage	Planned Outage	10-03-2026	10:31	10-03-2026	12:54	2:23	0.001668	REPLACEMENT OF LT BUSHING ROD
323	11-03-2026	Part of : ISWAR NAGAR NEW FRIENDS COLONY	313	Other Outage	Unplanned Outage	11-03-2026	01:45	11-03-2026	02:24	0:39	0.000428	CABLE FAULT
324	12-03-2026	Part of : F-BLOCK SHAHEEN BAGH JASOLA VIHAR	410	Other Outage	Planned Outage	12-03-2026	10:40	12-03-2026	12:18	1:38	0.001143	REPLACEMENT OF HT BUSHING ROD
325	13-03-2026	Part of : BLOCK N PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	1123	Other Outage	Planned Outage	13-03-2026	10:27	13-03-2026	11:21	0:54	0.000600	INSTALLATION OF BUS BAR
326	13-03-2026	Part of : BLOCK G SRINIVAS PURI	30	Other Outage	Planned Outage	13-03-2026	11:20	13-03-2026	13:34	2:14	0.001117	REPLACEMENT OF LT BUSHING ROD
327	14-03-2026	Part of : POCKET 7 JASOLA VIHAR,	107	Other Outage	Planned Outage	14-03-2026	10:23	14-03-2026	11:43	1:20	0.000933	REPLACEMENT OF LT BUSHING ROD
328	16-03-2026	Part of : SUKHDEV VIHAR OKHLA	674	Other Outage	Planned Outage	16-03-2026	13:02	16-03-2026	13:43	0:41	0.000000	REPLACEMENT OF HT BUSHING ROD
329	16-03-2026	Part of : B-BLOCK MAHARANI BAGH NEW FRIENDS COLONY	68	Other Outage	Planned Outage	16-03-2026	10:57	16-03-2026	11:51	0:54	0.000000	REPLACEMENT OF HT BUSHING ROD
330	16-03-2026	Part of : POCKET B SUKHDEV VIHAR OKHLA	143	Other Outage	Planned Outage	16-03-2026	10:58	16-03-2026	11:50	0:52	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
331	16-03-2026	Part of : S-BLOCK PRIVATE COLONY SRINIVAS PURI	318	Other Outage	Planned Outage	16-03-2026	10:57	16-03-2026	11:49	0:52	0.000433	REPLACEMENT OF HT BUSHING ROD
332	16-03-2026	Part of : POCKET 2 JASOLA VIHAR	166	Other Outage	Planned Outage	16-03-2026	11:02	16-03-2026	13:20	2:18	0.000767	INSTALLATION OF BUS BAR
333	17-03-2026	Part of : BLOCK A NEW FRIENDS COLONY WEST	31	Other Outage	Planned Outage	17-03-2026	11:09	17-03-2026	11:55	0:46	0.000000	REPLACEMENT OF LT BUSHING ROD
334	17-03-2026	Part of : BLOCK C NEW FRIENDS COLONY	129	Other Outage	Planned Outage	17-03-2026	11:09	17-03-2026	11:56	0:47	0.000000	REPLACEMENT OF LT BUSHING ROD
335	17-03-2026	Part of : POCKET 7 JASOLA VIHAR	87	Other Outage	Planned Outage	17-03-2026	10:34	17-03-2026	12:20	1:46	0.001237	REPLACEMENT OF LT BUSHING ROD
336	19-03-2026	Part of : POCKET 9A JASOLA VIHAR	89	Other Outage	Planned Outage	19-03-2026	10:34	19-03-2026	12:14	1:40	0.001167	REPLACEMENT OF HT BUSHING ROD
337	21-03-2026	Part of : MASSI GARH VILLAGE, SUKHDEV VIHAR OKHLA, C.R.R.I, DTC DEPO SUKHDEV VIHAR	1195	Other Outage	Unplanned Outage	21-03-2026	13:18	21-03-2026	13:42	0:24	0.000188	HT SYSTEM FAULT
338	23-03-2026	Part of : B-BLOCK NEW FRIENDS COLONY	117	Other Outage	Planned Outage	23-03-2026	11:01	23-03-2026	11:33	0:32	0.000000	REPLACEMENT OF HT BUSHING ROD
339	23-03-2026	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR	2	Other Outage	Planned Outage	23-03-2026	11:01	23-03-2026	11:34	0:33	0.000000	REPLACEMENT OF HT BUSHING ROD
340	23-03-2026	Part of : OKHLA VILLAGE,JAMIA NAGAR,CANAL COLONY	2228	Other Outage	Planned Outage	23-03-2026	12:56	23-03-2026	13:56	1:00	0.000750	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
341	23-03-2026	Part of : JAMIA NAGAR OKHLA	570	Other Outage	Planned Outage	23-03-2026	12:14	23-03-2026	13:56	1:42	0.001558	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,SUB STATION CLEANING
342	23-03-2026	Part of : ISWAR NAGAR NEW FRIENDS COLONY	47	Other Outage	Planned Outage	23-03-2026	12:18	23-03-2026	15:33	3:15	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
343	25-03-2026	Part of : POCKET 10B JASOLA VIHAR	196	Other Outage	Planned Outage	25-03-2026	11:10	25-03-2026	13:04	1:54	0.001330	REPLACEMENT OF LT BUSHING ROD
344	25-03-2026	Part of : MUJEEB BAGH JAMIA NAGAR OKHLA	1663	Other Outage	Planned Outage	25-03-2026	13:02	25-03-2026	15:19	2:17	0.002093	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
345	26-03-2026	Part of : NEW FRIENDS COLONY EAST NEW FRIENDS COLONY,	144	Other Outage	Planned Outage	26-03-2026	11:17	26-03-2026	13:38	2:21	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
346	27-03-2026	Part of : SUKHDEV VIHAR OKHLA	1197	Other Outage	Unplanned Outage	27-03-2026	07:48	27-03-2026	08:16	0:28	0.000448	HT SYSTEM FAULT
347	27-03-2026	Part of : BHARAT NAGAR NEW FRIENDS COLONY,BLOCK B, C & D NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	1376	Other Outage	Unplanned Outage	27-03-2026	00:21	27-03-2026	01:00	0:39	0.000510	CABLE FAULT
348	28-03-2026	Part of : SHAHEEN BAGH	3310	Other Outage	Unplanned Outage	28-03-2026	23:57	29-03-2026	00:31	0:34	0.000345	CABLE FAULT
349	28-03-2026	Part of : BLOCK C OKHLA VIHAR JAMIA NAGAR OKHLA	1351	Other Outage	Planned Outage	28-03-2026	13:06	28-03-2026	15:04	1:58	0.001475	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
350	28-03-2026	Part of : POCKET 2 JASOLA VIHAR	82	Other Outage	Planned Outage	28-03-2026	10:19	28-03-2026	11:20	1:01	0.000712	REPLACEMENT OF LT BUSHING ROD
351	29-03-2026	Part of : BLOCK H SHAHEEN BAGH JASOLA VIHAR,BLOCK B SHAHEEN BAGH JASOLA VIHAR	3741	Other Outage	Unplanned Outage	29-03-2026	00:00	29-03-2026	00:32	0:32	0.000430	CABLE FAULT
352	30-03-2026	Part of : NOOR NAGAR OKHLA,	482	Other Outage	Planned Outage	30-03-2026	13:30	30-03-2026	13:44	0:14	0.000156	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),SUB STATION CLEANING,TIGHTENING OF NUT BOLT
353	01-03-2026	Part of : POCKET B,D & W OKHLA PHASE II OKHLA INDUSTRIAL AREA	375	Other Outage	Unplanned Outage	01-03-2026	09:48	01-03-2026	10:41	0:53	0.000118	HT AB CABLE FAULT
354	01-03-2026	Part of : NEHRU PLACE	96	Other Outage	Planned Outage	01-03-2026	11:07	01-03-2026	12:10	1:03	0.000910	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
355	01-03-2026	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA	52	Other Outage	Planned Outage	01-03-2026	11:04	01-03-2026	14:08	3:04	0.002556	REPLACEMENT OF LT BUSHING ROD
356	02-03-2026	Part of : NEHRU PLACE,	129	Other Outage	Planned Outage	02-03-2026	11:41	02-03-2026	12:08	0:27	0.000390	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
357	02-03-2026	Part of : NEHRU PLACE,	6	Other Outage	Planned Outage	02-03-2026	11:02	02-03-2026	12:10	1:08	0.000982	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMET OF LUGS,SUB STATION CLEANING
358	02-03-2026	Part of : BLOCK E EAST OF KAILASH,	665	Other Outage	Planned Outage	02-03-2026	10:23	02-03-2026	13:00	2:37	0.002268	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
359	05-03-2026	Part of : NEHRU PLACE	1	Other Outage	Planned Outage	05-03-2026	11:14	05-03-2026	12:03	0:49	0.000708	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
360	07-03-2026	Part of : SHO R BLOCK GK-1	1	Other Outage	Planned Outage	07-03-2026	11:33	07-03-2026	12:01	0:28	0.000404	END TERMINATION COVER REPLACEMENT,PROPER SEALING RMU PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
361	07-03-2026	Part of : NEHRU PLACE	218	Other Outage	Planned Outage	07-03-2026	11:33	07-03-2026	11:58	0:25	0.000361	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
362	08-03-2026	Part of : POCKET D & W OKHLA INDUSTRIAL AREA PHASE-2	721	Other Outage	Unplanned Outage	08-03-2026	12:18	08-03-2026	13:24	1:06	0.000338	CABLE FAULT
363	08-03-2026	Part of : NEHRU PLACE	30	Other Outage	Planned Outage	08-03-2026	10:58	08-03-2026	11:51	0:53	0.000766	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
364	08-03-2026	Part of : OKHLA INDUSTRIAL AREA PHASE-3	5	Other Outage	Planned Outage	08-03-2026	10:58	08-03-2026	14:07	3:09	0.002888	REPLACEMET OF HT BUSHING ROD
365	09-03-2026	Part of : NEHRU PLACE	33	Other Outage	Planned Outage	09-03-2026	13:36	09-03-2026	13:45	0:09	0.000130	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
366	10-03-2026	Part of : HTC:RMU (TCIL) NR VSNL	0	Other Outage	Unplanned Outage	10-03-2026	21:48	10-03-2026	22:45	0:57	0.000000	CABLE FAULT
367	10-03-2026	Part of : HTC:PUMPING STATION, GK-1	0	Other Outage	Unplanned Outage	10-03-2026	09:15	10-03-2026	10:00	0:45	0.001097	FAULT IN HT CONSUMER PANEL (PUMPING STATION GK-1)
368	10-03-2026	Part of : HTC:PUMPING STATION, GK-1, HTC:DELHI JAL BOARD GK-1(NORTH)	2	Other Outage	Unplanned Outage	10-03-2026	02:33	10-03-2026	03:41	1:08	0.000000	FAULT IN HT CONSUMER PANEL (DELHI JAL BOARD)
369	10-03-2026	Part of : HTC:PUMPING STATION, GK-1	0	Other Outage	Unplanned Outage	10-03-2026	00:39	10-03-2026	02:22	1:43	0.002341	TRANSIENT FAULT
370	10-03-2026	Part of : BLOCK M GREATER KAILASH I GREATER KAILASH,	141	Other Outage	Planned Outage	10-03-2026	11:01	10-03-2026	11:56	0:55	0.000794	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
371	11-03-2026	Part of : NEHRU PLACE	286	Other Outage	Planned Outage	11-03-2026	11:12	11-03-2026	14:39	3:27	0.002990	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
372	12-03-2026	Part of : NEHRU PLACE	152	Other Outage	Planned Outage	12-03-2026	11:15	12-03-2026	11:40	0:25	0.000361	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
373	15-03-2026	Part of : KALASH ENCLAVE GREATER KAILASH,BLOCK N GREATER KAILASH I GREATER KAILASH,KAILASH COLONY GREATER KAILASH,BLOCK B ZAMRUPUR VILLAGE GREATER KAILASH	2245	Other Outage	Unplanned Outage	15-03-2026	01:12	15-03-2026	01:42	0:30	0.000392	CABLE FAULT
374	15-03-2026	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA	15	Other Outage	Planned Outage	15-03-2026	10:41	15-03-2026	14:11	3:30	0.001750	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE
375	18-03-2026	Part of : POCKET D OKHLA PHASE II OKHLA INDUSTRIAL AREA,SHYAM NAGAR OKHLA INDUSTRIAL AREA,POCKET T OKHLA PHASE II OKHLA INDUSTRIAL AREA	585	Other Outage	Unplanned Outage	18-03-2026	17:55	18-03-2026	18:45	0:50	0.000875	TRANSIENT FAULT
376	18-03-2026	Part of : CSP FLATS EAST OF KAILASH,	533	Other Outage	Unplanned Outage	18-03-2026	11:46	18-03-2026	12:26	0:40	0.000611	REPAIRING OF JUMPER
377	19-03-2026	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA,BLOCK G KAILASH HILL EAST OF KAILASH	245	Other Outage	Unplanned Outage	19-03-2026	23:48	20-03-2026	01:20	1:32	0.000499	HT SYSTEM FAULT
378	19-03-2026	Part of : CSP FLATS EAST OF KAILASH	532	Other Outage	Unplanned Outage	19-03-2026	12:54	19-03-2026	14:25	1:31	0.001390	REPAIRING OF RMU
379	20-03-2026	Part of : PUMPING STATION GK-1 (HT CONSUMER)	0	Other Outage	Unplanned Outage	20-03-2026	20:00	20-03-2026	20:46	0:46	0.001507	FAULT IN HT CONSUMER PANEL (PUMPING STATION GK-1)
380	22-03-2026	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA,	11	Other Outage	Planned Outage	22-03-2026	11:04	22-03-2026	13:35	2:31	0.001258	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF LT BUSHING ROD
381	24-03-2026	Part of : A-BLOCK & POCKET W-OKHLA INDUSTRIAL AREA PHASE-2	719	Other Outage	Unplanned Outage	24-03-2026	12:08	24-03-2026	13:17	1:09	0.000958	REPAIRING OF RMU
382	25-03-2026	Part of : POCKET A & W OKHLA PHASE II OKHLA INDUSTRIAL AREA	719	Other Outage	Unplanned Outage	25-03-2026	16:12	25-03-2026	16:36	0:24	0.000340	TREE TOUCHING
383	31-03-2026	Part of : NEHRU PLACE	546	Other Outage	Unplanned Outage	31-03-2026	05:21	31-03-2026	06:03	0:42	0.000095	HT SYSTEM FAULT
384	02-03-2026	Part of : NATIONAL ZOOLOGICAL PARK SUNDAR NAGAR,	23	Other Outage	Planned Outage	02-03-2026	11:51	02-03-2026	14:32	2:41	0.001342	REPLACEMET OF HT BUSHING ROD
385	02-03-2026	Part of : RISHI NAGAR SOUTH EXTENSION PART 1,	1668	Other Outage	Planned Outage	02-03-2026	11:42	02-03-2026	14:55	3:13	0.002144	REPLACEMET OF HT BUSHING ROD
386	02-03-2026	Part of : BLOCK I LAJPAT NAGAR II LAJPAT NAGAR,	431	Other Outage	Planned Outage	02-03-2026	10:56	02-03-2026	13:51	2:55	0.000972	REPLACEMENT OF LT BUSHING ROD
387	02-03-2026	Part of : BLOCK A DEFENCE COLONY,	140	Other Outage	Planned Outage	02-03-2026	11:13	02-03-2026	13:50	2:37	0.000872	REPLACEMET OF HT BUSHING ROD
388	03-03-2026	Part of : ISBT SARAI KALE KHAN SARAI KALE KHAN,BLOCK A GANGA VIHAR SARAI KALE KHAN	13	Other Outage	Unplanned Outage	03-03-2026	12:32	03-03-2026	13:20	0:48	0.001640	HT SYSTEM FAULT
389	05-03-2026	Part of : BLOCK E SOUTH EXTENSION PART 1	113	Other Outage	Planned Outage	05-03-2026	10:34	05-03-2026	13:15	2:41	0.000894	REPLACEMENT OF LT BUSHING ROD
390	06-03-2026	Part of : BLOCK D SARAI KALE KHAN VILLAGE SARAI KALE KHAN,BLOCK B SARAI KALE KHAN,BLOCK A GANGA VIHAR SARAI KALE KHAN	1772	Other Outage	Unplanned Outage	06-03-2026	15:27	06-03-2026	16:14	0:47	0.000221	HT SYSTEM FAULT
391	06-03-2026	Part of : BLOCK A GANGA VIHAR SARAI KALE KHAN,	5	Other Outage	Unplanned Outage	06-03-2026	12:37	06-03-2026	13:08	0:31	0.000103	REPAIR OF RMU
392	06-03-2026	Part of : BLOCK C JUNG PURA B JANG PURA,	731	Other Outage	Planned Outage	06-03-2026	11:31	06-03-2026	13:28	1:57	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
393	07-03-2026	Part of : INSTITUTIONAL AREA LODI COLONY	183	Other Outage	Planned Outage	07-03-2026	13:00	07-03-2026	15:56	2:56	0.002200	REPLACEMENT OF HT BUSHING ROD
394	07-03-2026	Part of : A-BLOCK DEFENCE COLONY	327	Other Outage	Planned Outage	07-03-2026	10:22	07-03-2026	14:24	4:02	0.001344	REPLACEMENT OF HT BUSHING ROD
395	09-03-2026	Part of : SUNDAR NAGAR	2	Other Outage	Planned Outage	09-03-2026	11:08	09-03-2026	13:19	2:11	0.001092	REPLACEMENT OF HT BUSHING ROD
396	09-03-2026	Part of : WAZIR NAGAR SOUTH EXTENSION PART 1	861	Other Outage	Planned Outage	09-03-2026	11:21	09-03-2026	14:55	3:34	0.001546	REPLACEMENT OF LT BUSHING ROD
397	10-03-2026	Part of : BLOCK 12 NEHRU NAGAR LAJPAT NAGAR,	1183	Other Outage	Planned Outage	10-03-2026	11:02	10-03-2026	14:50	3:48	0.000000	REPLACEMENT OF LT BUSHING ROD
398	11-03-2026	Part of : POCKET C SIDDHARTHA NAGAR,PHASE 1 SUNLIGHT COLONY	2975	Other Outage	Unplanned Outage	11-03-2026	11:57	11-03-2026	12:43	0:46	0.000000	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
399	11-03-2026	Part of : HARI NAGAR ASHRAM	772	Other Outage	Planned Outage	11-03-2026	12:01	11-03-2026	14:47	2:46	0.001891	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
400	11-03-2026	Part of : DEFENCE COLONY	143	Other Outage	Planned Outage	11-03-2026	10:45	11-03-2026	14:28	3:43	0.001239	REPLACEMENT OF HT BUSHING ROD
401	12-03-2026	Part of : JAWAHARLAL NEHRU STADIUM PRAGATI VIHAR	4	Other Outage	Planned Outage	12-03-2026	12:23	12-03-2026	15:05	2:42	0.000135	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
402	13-03-2026	Part of : BLOCK B SARAI KALE KHAN,BLOCK A SARAI KALE KHAN,BEHLOLPUR BANGAR SARAI KALE KHAN,NIZAMUDDIN EAST	3118	Other Outage	Planned Outage	13-03-2026	11:24	13-03-2026	12:20	0:56	0.000373	RELAY REPLACEMENT/VPI/FPI
403	14-03-2026	Part of : ISBT SARAI KALE KHAN SARAI KALE KHAN,BLOCK A GANGA VIHAR SARAI KALE KHAN,	12	Other Outage	Unplanned Outage	14-03-2026	12:00	14-03-2026	12:50	0:50	0.000250	REPAIR OF RMU
404	16-03-2026	Part of : L-BLOCK LAJPAT NAGAR-3	132	Other Outage	Planned Outage	16-03-2026	11:51	16-03-2026	15:19	3:28	0.000809	REPLACEMENT OF HT BUSHING ROD
405	16-03-2026	Part of : MEHARCHAND MARKET LODI COLONY	639	Other Outage	Planned Outage	16-03-2026	11:16	16-03-2026	14:10	2:54	0.001692	REPLACEMENT OF HT BUSHING ROD
406	17-03-2026	Part of : INA COLONY	117	Other Outage	Planned Outage	17-03-2026	11:34	17-03-2026	14:14	2:40	0.001556	REPLACEMENT OF HT BUSHING ROD
407	17-03-2026	Part of : BLOCK L LAJPAT NAGAR III	118	Other Outage	Planned Outage	17-03-2026	12:55	17-03-2026	15:32	2:37	0.000000	REPLACEMENT OF HT BUSHING ROD
408	18-03-2026	Part of : BEHLOLPUR BANGAR SARAI KALE KHAN,NIZAMUDDIN EAST,BLOCK B SARAI KALE KHAN,BLOCK A SARAI KALE KHAN,	3098	Other Outage	Unplanned Outage	18-03-2026	14:06	18-03-2026	15:13	1:07	0.000223	ATTENDING WEAK POINTS/HOT SPOT
409	19-03-2026	Part of : ISBT SARAI KALE KHAN SARAI KALE KHAN,BLOCK A GANGA VIHAR SARAI KALE KHAN	12	Other Outage	Unplanned Outage	19-03-2026	12:59	19-03-2026	13:42	0:43	0.001493	CABLE FAULT
410	19-03-2026	Part of : L-BLOCK LAJPAT NAGAR-3	499	Other Outage	Planned Outage	19-03-2026	12:07	19-03-2026	15:30	3:23	0.000000	REPLACEMENT OF HT BUSHING ROD
411	20-03-2026	Part of : KASTURBA NAGAR SEWA NAGAR	0	Other Outage	Unplanned Outage	20-03-2026	06:08	20-03-2026	06:25	0:17	0.000000	CABLE FAULT
412	20-03-2026	Part of : KASTURBA NAGAR SEWA NAGAR	0	Other Outage	Unplanned Outage	20-03-2026	04:14	20-03-2026	05:06	0:52	0.000000	TREE TOUCHING
413	23-03-2026	Part of : WAZIR NAGAR SOUTH EXTENSION PART-1	701	Other Outage	Planned Outage	23-03-2026	12:07	23-03-2026	15:17	3:10	0.001056	REPLACEMENT OF HT BUSHING ROD
414	23-03-2026	Part of : L-BLOCK LAJPAT NAGAR-2	169	Other Outage	Planned Outage	23-03-2026	10:58	23-03-2026	13:38	2:40	0.000533	REPLACEMENT OF HT BUSHING ROD
415	25-03-2026	Part of : BLOCK L LAJPAT NAGAR II	250	Other Outage	Planned Outage	25-03-2026	11:33	25-03-2026	14:27	2:54	0.001933	REPLACEMENT OF HT BUSHING ROD
416	26-03-2026	Part of : BLOCK D DEFENCE COLONY	377	Other Outage	Unplanned Outage	26-03-2026	05:00	26-03-2026	05:50	0:50	0.000000	HT SYSTEM FAULT
417	28-03-2026	Part of : SEWA NAGAR, KASTURBA NAGAR SEWA NAGAR, KOTLA MUBARAKPUR	2555	Other Outage	Unplanned Outage	28-03-2026	22:55	28-03-2026	23:30	0:35	0.001196	CABLE FAULT
418	28-03-2026	Part of : BLOCK A & H SOUTH EXTENSION PART 1, BLOCK B,J & K NDSE-1	2177	Other Outage	Unplanned Outage	28-03-2026	22:06	28-03-2026	22:44	0:38	0.000507	CABLE FAULT
419	30-03-2026	Part of : KILOKARI PHASE 1 SUNLIGHT COLONY,	971	Other Outage	Planned Outage	30-03-2026	12:23	30-03-2026	15:29	3:06	0.002325	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
420	02-03-2026	Part of : SUBROTO PARK,	1	Other Outage	Planned Outage	02-03-2026	11:07	02-03-2026	12:56	1:49	0.000091	GUARD WIRES SAGGING PER SPAN,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
421	02-03-2026	Part of : HTC:AJAY BIJLI,PLOT-9,PALAM MARG,V.VIHAR	1	Other Outage	Planned Outage	02-03-2026	10:46	02-03-2026	12:56	2:10	0.000722	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
422	03-03-2026	Part of : INDIAN AIR LINES AND AIR INDIA ESTATE VASANT VIHAR	1601	Other Outage	Planned Outage	03-03-2026	11:45	03-03-2026	12:39	0:54	0.000300	RELAY REPLACEMENT/VPI/FPI
423	03-03-2026	Part of : POCKET 2 SECTOR 2 DWARKA	6	Other Outage	Planned Outage	03-03-2026	12:27	03-03-2026	13:49	1:22	0.001253	JUMPER REPLACEMENT PER POLE
424	06-03-2026	Part of : HTC:PWD DHAULA KUAN FLYOVER	1	Other Outage	Planned Outage	06-03-2026	12:59	06-03-2026	15:27	2:28	0.000576	REPLACEMENT OF CROSS-ARMS AND POLES
425	06-03-2026	Part of : MUNIRKA,	1012	Other Outage	Planned Outage	06-03-2026	11:01	06-03-2026	13:52	2:51	0.000000	3PH DB REVAMPING,CONDUCTOR REPLACEMENT PER SPAN,INSTALLATION OF PHASE SEPARATOR PER SPAN,JUMPER REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER
426	06-03-2026	Part of : HTC:MCD CAR PARKING, MUNIRKA	1	Other Outage	Planned Outage	06-03-2026	10:41	06-03-2026	12:46	2:05	0.000694	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
427	07-03-2026	Part of : SRI RAM SCHOOL, D-3 VASANT VIHAR	1	Other Outage	Planned Outage	07-03-2026	11:07	07-03-2026	13:18	2:11	0.000546	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
428	08-03-2026	Part of : B-BLOCK ANAND NIKETAN,SECTOR 1,2,5 & 8 SHANTI NIKETAN	1095	Other Outage	Unplanned Outage	08-03-2026	13:03	08-03-2026	13:58	0:55	0.001073	CABLE FAULT
429	09-03-2026	Part of : MES B.I.LINES (HT CONSUMER)	1	Other Outage	Planned Outage	09-03-2026	11:49	09-03-2026	15:05	3:16	0.000327	GUARD WIRES SAGGING PER SPAN,TAPPING OF JUMPERS
430	09-03-2026	Part of : SAMAJWADI PARTY PLOT-1 (HT CONSUMER) VASANT VIHAR	1	Other Outage	Planned Outage	09-03-2026	10:33	09-03-2026	12:56	2:23	0.000794	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD
431	10-03-2026	Part of : HTC:CGHS WELLNESS CENTRE VASANT VIHAR	1	Other Outage	Planned Outage	10-03-2026	11:21	10-03-2026	13:09	1:48	0.000450	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
432	10-03-2026	Part of : BASANT GAON VASANT VIHAR,	190	Other Outage	Planned Outage	10-03-2026	10:30	10-03-2026	12:12	1:42	0.000000	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
433	10-03-2026	Part of : BLOCK B ANAND NIKETAN,	279	Other Outage	Planned Outage	10-03-2026	10:34	10-03-2026	13:39	3:05	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
434	11-03-2026	Part of : AIG SPG OLD JNU CAMPUS	1	Other Outage	Planned Outage	11-03-2026	14:11	11-03-2026	15:19	1:08	0.000283	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
435	11-03-2026	Part of : MUNIRKA VIHAR	278	Other Outage	Planned Outage	11-03-2026	14:09	11-03-2026	16:59	2:50	0.000000	LT CIRCUIT MAINTENANCE
436	11-03-2026	Part of : MUNIRKA ENCLAVE	632	Other Outage	Planned Outage	11-03-2026	10:57	11-03-2026	13:02	2:05	0.000000	LT CIRCUIT MAINTENANCE
437	12-03-2026	Part of : BA,BC & CA-BLOCK MUNIRKA	2702	Other Outage	Unplanned Outage	12-03-2026	04:51	12-03-2026	05:03	0:12	0.000140	CABLE FAULT
438	12-03-2026	Part of : D-BLOCK VASANT VIHAR	493	Other Outage	Planned Outage	12-03-2026	14:58	12-03-2026	16:31	1:33	0.000000	LT CIRCUIT MAINTENANCE
439	12-03-2026	Part of : NTRO OLD JNU CAMPUS	1	Other Outage	Planned Outage	12-03-2026	11:02	12-03-2026	13:14	2:12	0.000550	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
440	12-03-2026	Part of : C-BLOCK VASANT VIHAR	195	Other Outage	Planned Outage	12-03-2026	11:12	12-03-2026	14:12	3:00	0.000000	LT CIRCUIT MAINTENANCE
441	13-03-2026	Part of : MODERN SCH VASANT VIHAR (HTC)	1	Other Outage	Planned Outage	13-03-2026	14:06	13-03-2026	15:09	1:03	0.000210	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
442	13-03-2026	Part of : MUNIRKA ENCLAVE MUNIRKA	632	Other Outage	Planned Outage	13-03-2026	14:05	13-03-2026	15:09	1:04	0.000000	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
443	13-03-2026	Part of : MUNIRKA VIHAR	278	Other Outage	Planned Outage	13-03-2026	11:00	13-03-2026	12:25	1:25	0.000000	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
444	14-03-2026	Part of : BLOCK B VASANT VIHAR,	170	Other Outage	Planned Outage	14-03-2026	14:45	14-03-2026	16:05	1:20	0.000000	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
445	14-03-2026	Part of : BASANT LOK VASANT VIHAR,	50	Other Outage	Planned Outage	14-03-2026	12:02	14-03-2026	15:02	3:00	0.000750	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
446	14-03-2026	Part of : BLOCK B VASANT VIHAR,	129	Other Outage	Planned Outage	14-03-2026	10:13	14-03-2026	13:03	2:50	0.000000	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
447	16-03-2026	Part of : JAWAHAR LAL NEHRU UNIVERSITY OLD JNU CAMPUS MUNIRKA,MOTILAL NEHRU CAMP OLD JNU CAMPUS MUNIRKA	1002	Other Outage	Planned Outage	16-03-2026	13:59	16-03-2026	16:36	2:37	0.002181	REPLACEMENT OF FAULTY END BOX
448	16-03-2026	Part of : BC & BD-BLOCK MUNIRKA	539	Other Outage	Planned Outage	16-03-2026	10:54	16-03-2026	13:21	2:27	0.002042	CT REPLACEMENT,REPLACEMENT OF FAULTY END BOX
449	16-03-2026	Part of : E-BLOCK VASANT VIHAR	83	Other Outage	Planned Outage	16-03-2026	14:06	16-03-2026	16:51	2:45	0.000000	LT CIRCUIT MAINTENANCE
450	16-03-2026	Part of : D-BLOCK VASANT VIHAR	210	Other Outage	Planned Outage	16-03-2026	10:14	16-03-2026	13:13	2:59	0.000000	LT CIRCUIT MAINTENANCE
451	17-03-2026	Part of : CGHC COLONY VASANT VIHAR	571	Other Outage	Planned Outage	17-03-2026	11:15	17-03-2026	12:52	1:37	0.001347	REPLACEMENT OF FAULTY END BOX
452	19-03-2026	Part of : BLOCK B VASANT VIHAR	170	Other Outage	Unplanned Outage	19-03-2026	12:48	19-03-2026	14:51	2:03	0.002904	MOBILE TRANSFORMER REPLACEMENT
453	20-03-2026	Part of : POCKET 2 SECTOR 2 DWARKA	6	Other Outage	Planned Outage	20-03-2026	12:38	20-03-2026	13:24	0:46	0.000000	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF FAULTY END BOX
454	23-03-2026	Part of : SECTOR 5 RAMAKRISHNA PURAM	3	Other Outage	Planned Outage	23-03-2026	11:11	23-03-2026	12:25	1:14	0.000164	DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LUGS
455	24-03-2026	Part of : B-BLOCK VASANT VIHAR	170	Other Outage	Planned Outage	24-03-2026	13:02	24-03-2026	15:17	2:15	0.003188	REPLACEMENT OF GAS KIT AND OIL SEAL
456	27-03-2026	Part of : SECTOR 1 RAMAKRISHNA PURAM,SECTOR 5 RAMAKRISHNA PURAM,SECTOR 4 RAMAKRISHNA PURAM,EAST BLOCK ADARSH BASTI RAMAKRISHNA PURAM	1542	Other Outage	Unplanned Outage	27-03-2026	09:42	27-03-2026	10:12	0:30	0.000142	CABLE FAULT
457	27-03-2026	Part of : MUNIRKA	441	Other Outage	Planned Outage	27-03-2026	15:41	27-03-2026	16:45	1:04	0.000000	LT CIRCUIT MAINTENANCE
458	28-03-2026	Part of : CGHC COLONY VASANT VIHAR	134	Other Outage	Planned Outage	28-03-2026	11:32	28-03-2026	12:51	1:19	0.000439	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
459	30-03-2026	Part of : HTC:DTC DEPOT,VASANT VIHAR	1	Other Outage	Planned Outage	30-03-2026	12:03	30-03-2026	13:09	1:06	0.000367	SUB STATION CLEANING
460	30-03-2026	Part of : BLOCK C MOTI BAGH SOUTH MARKET MOTI BAGH SOUTH,	454	Other Outage	Planned Outage	30-03-2026	10:00	30-03-2026	13:27	3:27	0.000690	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
461	02-03-2026	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM	2151	Other Outage	Unplanned Outage	02-03-2026	12:33	02-03-2026	13:16	0:43	0.000447	ELECTROCUTION OF SQUIRREL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
462	02-03-2026	Part of : SECTOR 6 PUSHPA VIHAR,	86	Other Outage	Planned Outage	02-03-2026	15:15	02-03-2026	17:15	2:00	0.003333	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING TIGHTENEING OF NUT BOLT
463	02-03-2026	Part of : SECTOR 7 PUSHPA VIHAR,	103	Other Outage	Planned Outage	02-03-2026	12:24	02-03-2026	13:39	1:15	0.002083	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
464	02-03-2026	Part of : SECTOR 6 PUSHPA VIHAR,	241	Other Outage	Planned Outage	02-03-2026	11:00	02-03-2026	14:04	3:04	0.005111	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING TIGHTENEING OF NUT BOLT
465	02-03-2026	Part of : BLOCK G 11 MALVIYA NAGAR,	1285	Other Outage	Planned Outage	02-03-2026	10:57	02-03-2026	14:27	3:30	0.000000	REPLACEMET OF HT BUSHING ROD
466	03-03-2026	Part of : SECTOR 3 PUSHPA VIHAR	717	Other Outage	Unplanned Outage	03-03-2026	17:54	03-03-2026	18:37	0:43	0.000263	CABLE FAULT
467	03-03-2026	Part of : SECTOR 6 PUSHPA VIHAR	174	Other Outage	Planned Outage	03-03-2026	11:37	03-03-2026	12:25	0:48	0.001333	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
468	04-03-2026	Part of : E & J-BLOCK SAINIK FARM,BLOCK H NEB SARAI	411	Other Outage	Unplanned Outage	04-03-2026	08:48	04-03-2026	09:37	0:49	0.000146	HVDS FAULT
469	04-03-2026	Part of : E-BLOCK SAINIK FARM,H-BLOCK H NEB SARAI	392	Other Outage	Unplanned Outage	04-03-2026	15:00	04-03-2026	16:39	1:39	0.000332	TRANSIENT FAULT
470	05-03-2026	Part of : BEGUMPUR	1171	Other Outage	Planned Outage	05-03-2026	11:03	05-03-2026	14:01	2:58	0.000000	REPLACEMET OF HT BUSHING ROD
471	05-03-2026	Part of : POLICE TRAINING CENTRE NAVJIVAN VIHAR MALVIYA NAGAR	183	Other Outage	Planned Outage	05-03-2026	10:08	05-03-2026	12:32	2:24	0.000000	REPLACEMET OF HT BUSHING ROD
472	05-03-2026	Part of : BLOCK 7 SARVAPRIYA VIHAR	236	Other Outage	Planned Outage	05-03-2026	10:12	05-03-2026	12:36	2:24	0.000000	FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,JUMPER REPLACEMENT PER POLE
473	06-03-2026	Part of : SECTOR 6 PUSHPA VIHAR,	1	Other Outage	Planned Outage	06-03-2026	11:02	06-03-2026	13:44	2:42	0.004500	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
474	06-03-2026	Part of : SECTOR 6 PUSHPA VIHAR,	56	Other Outage	Planned Outage	06-03-2026	11:01	06-03-2026	13:42	2:41	0.004472	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
475	06-03-2026	Part of : SECTOR 6 PUSHPA VIHAR,	3	Other Outage	Planned Outage	06-03-2026	11:01	06-03-2026	13:43	2:42	0.004500	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,TIGHTENEING OF NUT BOLT
476	06-03-2026	Part of : BLOCK D DDA FLATE MALVIYA NAGAR,	827	Other Outage	Planned Outage	06-03-2026	10:55	06-03-2026	14:35	3:40	0.000000	REPLACEMENT OF HT BUSHING ROD
477	06-03-2026	Part of : SARVODYA ENCLAVE,	476	Other Outage	Planned Outage	06-03-2026	10:08	06-03-2026	12:34	2:26	0.000000	REPLACEMENT OF LT BUSHING ROD
478	07-03-2026	Part of : B-BLOCK NAVJIVAN VIHAR MALVIYA NAGAR	274	Other Outage	Planned Outage	07-03-2026	10:14	07-03-2026	11:38	1:24	0.000000	REPLACEMENT OF HT BUSHING ROD
479	07-03-2026	Part of : FREEDOM FIGHTER VIHAR,A,C,D & E-BLOCK PARYAVARAN COMPLEX SAINIK FARM	2501	Other Outage	Planned Outage	07-03-2026	11:44	07-03-2026	15:11	3:27	0.005750	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT,3PH HT AB END TERMINATION REPLACEMENT
480	07-03-2026	Part of : L-BLOCK MALVIYA NAGAR	959	Other Outage	Planned Outage	07-03-2026	10:45	07-03-2026	13:51	3:06	0.000000	REPLACEMENT OF HT BUSHING ROD
481	08-03-2026	Part of : MMT COLONY SARVODYA ENCLAVE	1	Other Outage	Planned Outage	08-03-2026	09:55	08-03-2026	11:37	1:42	0.000057	REPLACEMENT OF HT BUSHING ROD
482	09-03-2026	Part of : BLOCK E SAINIK FARM,BLOCK H NEB SARAI SAINIK FARM	392	Other Outage	Unplanned Outage	09-03-2026	10:33	09-03-2026	11:04	0:31	0.000861	REPAIRING OF RMU
483	09-03-2026	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	325	Other Outage	Planned Outage	09-03-2026	10:01	09-03-2026	11:56	1:55	0.000000	REPLACEMENT OF HT BUSHING ROD
484	09-03-2026	Part of : JAGDAMBA CAMP SHEIKH SARAI	1478	Other Outage	Planned Outage	09-03-2026	11:28	09-03-2026	14:02	2:34	0.000000	REPLACEMENT OF HT BUSHING ROD
485	09-03-2026	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	1130	Other Outage	Planned Outage	09-03-2026	13:29	09-03-2026	16:02	2:33	0.004250	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT
486	10-03-2026	Part of : NAI BASTI LADO SARAI,CHHATRI WALA KUNA LADO SARAI,	3260	Other Outage	Unplanned Outage	10-03-2026	10:14	10-03-2026	11:09	0:55	0.001528	REPLACEMENT OF SOCKETS
487	10-03-2026	Part of : KALU SARAI,	268	Other Outage	Planned Outage	10-03-2026	10:16	10-03-2026	12:04	1:48	0.000000	REPLACEMENT OF HT BUSHING ROD
488	10-03-2026	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI,	1144	Other Outage	Planned Outage	10-03-2026	11:10	10-03-2026	14:08	2:58	0.000000	REPLACEMENT OF HT BUSHING ROD
489	10-03-2026	Part of : BLOCK B FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK A 1 NEB SARAI SAINIK FARM,FREEDOM FIGHTER VIHAR SAINIK FARM,SAINIK FARM,BLOCK H NEB SARAI SAINIK FARM,BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM,	2437	Other Outage	Planned Outage	10-03-2026	11:16	10-03-2026	14:52	3:36	0.006000	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT,ST.TH JOINT ON 1PH HT AB,ST.TH JOINT ON 3PH HT AB
490	11-03-2026	Part of : MALVIYA NAGAR HOSPITAL	1	Other Outage	Planned Outage	11-03-2026	12:45	11-03-2026	13:35	0:50	0.000000	REPLACEMENT OF HT BUSHING ROD
491	11-03-2026	Part of : POCKET B & C SHEIKH SARAI PHASE-1	485	Other Outage	Planned Outage	11-03-2026	11:35	11-03-2026	12:50	1:15	0.000000	REPLACEMENT OF HT BUSHING ROD
492	11-03-2026	Part of : SECTOR 6 PUSHPA VIHAR	1	Other Outage	Planned Outage	11-03-2026	14:14	11-03-2026	16:43	2:29	0.004139	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
493	11-03-2026	Part of : THE PANCHSHIL RENDEZVOUS	1	Other Outage	Planned Outage	11-03-2026	10:29	11-03-2026	12:33	2:04	0.000000	REPLACEMENT OF HT BUSHING ROD
494	11-03-2026	Part of : B-BLOCK NAVJIVAN VIHAR MALVIYA NAGAR	139	Other Outage	Planned Outage	11-03-2026	10:11	11-03-2026	12:20	2:09	0.000000	REPLACEMENT OF HT BUSHING ROD
495	12-03-2026	Part of : D-BLOCK DDA FLATE MALVIYA NAGAR	267	Other Outage	Planned Outage	12-03-2026	11:17	12-03-2026	13:06	1:49	0.000303	HT CONDUCTOR REPLACEMENT
496	12-03-2026	Part of : A,A1 & B & H-BLOC FREEDOM FIGHTER VIHAR SAINIK FARM,A1-BLOCK NEB SARAI SAINIK FARM	2398	Other Outage	Planned Outage	12-03-2026	11:39	12-03-2026	13:56	2:17	0.003806	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
497	12-03-2026	Part of : MMT COLONY SARVODYA ENCLAVE	97	Other Outage	Planned Outage	12-03-2026	09:57	12-03-2026	13:00	3:03	0.000000	REPLACEMENT OF HT BUSHING ROD
498	13-03-2026	Part of : MALVIYA NAGAR,MMTC COLONY SARVODYA ENCLAVE,BLOCK F GITANJALI ENCLAVE MALVIYA NAGAR	1897	Other Outage	Unplanned Outage	13-03-2026	10:58	13-03-2026	11:20	0:22	0.000104	CABLE FAULT
499	13-03-2026	Part of : BLOCK D PARYAVARAN COMPLEX SAINIK FARM,BLOCK E SAKET	36	Other Outage	Unplanned Outage	13-03-2026	16:11	13-03-2026	17:12	1:01	0.001694	REPAIRING OF RMU
500	13-03-2026	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI	392	Other Outage	Planned Outage	13-03-2026	12:03	13-03-2026	13:31	1:28	0.000489	REPLACEMENT OF HT BUSHING ROD
501	13-03-2026	Part of : CHIRAG DELHI	1366	Other Outage	Planned Outage	13-03-2026	12:02	13-03-2026	13:30	1:28	0.000000	REPLACEMENT OF HT BUSHING ROD
502	13-03-2026	Part of : BLOCK A 1 NEB SARAI SAINIK FARM,POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	519	Other Outage	Planned Outage	13-03-2026	11:12	13-03-2026	14:01	2:49	0.004694	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
503	13-03-2026	Part of : BLOCK A GITANJALI ENCLAVE MALVIYA NAGAR	145	Other Outage	Planned Outage	13-03-2026	09:59	13-03-2026	10:30	3:31	0.000000	REPLACEMENT OF LT BUSHING ROD
504	14-03-2026	Part of : SECTOR 3 PUSHPA VIHAR,	76	Other Outage	Planned Outage	14-03-2026	14:27	14-03-2026	16:27	2:00	0.003333	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
505	14-03-2026	Part of : BLOCK D DDA FLATS SAKET,	524	Other Outage	Planned Outage	14-03-2026	10:19	14-03-2026	14:32	4:13	0.007028	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
506	14-03-2026	Part of : BLOCK L MALVIYA NAGAR,	525	Other Outage	Planned Outage	14-03-2026	10:44	14-03-2026	13:54	3:10	0.000000	3PH DB REPLACEMENT
507	15-03-2026	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI,BLOCK N MALVIYA NAGAR	1919	Other Outage	Unplanned Outage	15-03-2026	06:12	15-03-2026	07:02	0:50	0.000617	CABLE FAULT
508	16-03-2026	Part of : SECTOR 3 PUSHPA VIHAR	718	Other Outage	Unplanned Outage	16-03-2026	12:24	16-03-2026	13:22	0:58	0.000220	HVDS FAULT
509	16-03-2026	Part of : BLOCK B SHIVALIK MALVIYA NAGAR,	203	Other Outage	Planned Outage	16-03-2026	11:22	16-03-2026	13:02	1:40	0.000000	LT CIRCUIT MAINTENANCE
510	16-03-2026	Part of : F-BLOCK KHANPUR COLONY	39	Other Outage	Planned Outage	16-03-2026	10:55	16-03-2026	13:55	3:00	0.005000	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
511	16-03-2026	Part of : B-BLOCK SARVODYA ENCLAVE	188	Other Outage	Planned Outage	16-03-2026	10:02	16-03-2026	12:46	2:44	0.000000	REPLACEMENT OF HT BUSHING ROD
512	17-03-2026	Part of : MALVIYA NAGAR	601	Other Outage	Planned Outage	17-03-2026	10:15	17-03-2026	11:31	1:16	0.000000	CONDUCTOR REPLACEMENT PER SPAN
513	17-03-2026	Part of : FREEDOM FIGHTER VIHAR SAINIK FARM,SAINIK FARM,SAIYAD UL AJAB VILLAGE SAINIK FARM	5271	Other Outage	Planned Outage	17-03-2026	12:40	17-03-2026	15:19	2:39	0.004417	3PH HT AB CABLE REPLACEMENT PER SPAN,ST.TH JOINT ON 1PH HT AB
514	17-03-2026	Part of : GITANJALI ENCLAVE MALVIYA NAGAR	190	Other Outage	Planned Outage	17-03-2026	10:05	17-03-2026	12:37	2:32	0.000000	REPLACEMENT OF LT BUSHING ROD
515	18-03-2026	Part of : BLOCK A PARYAVARAN COMPLEX SAINIK FARM,	947	Other Outage	Planned Outage	18-03-2026	11:48	18-03-2026	15:02	3:14	0.000539	3PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER , JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
516	18-03-2026	Part of : BEGUMPUR,	390	Other Outage	Planned Outage	18-03-2026	10:07	18-03-2026	12:52	2:45	0.000000	REPLACEMENT OF LT BUSHING ROD
517	18-03-2026	Part of : BLOCK A SHIVALIK MALVIYA NAGAR,	1084	Other Outage	Planned Outage	18-03-2026	10:28	18-03-2026	13:34	3:06	0.000000	REPLACEMET OF HT BUSHING ROD
518	19-03-2026	Part of : G 6-BLOCK MALVIYA NAGAR	553	Other Outage	Planned Outage	19-03-2026	12:14	19-03-2026	13:37	1:23	0.000000	REPLACEMENT OF HT BUSHING ROD
519	19-03-2026	Part of : SECTOR 3 PUSHPA VIHAR	76	Other Outage	Planned Outage	19-03-2026	10:58	19-03-2026	14:08	3:10	0.005278	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
520	19-03-2026	Part of : MMT C COLONY SARVODYA ENCLAVE	127	Other Outage	Planned Outage	19-03-2026	09:58	19-03-2026	12:41	2:43	0.000000	REPLACEMENT OF HT BUSHING ROD
521	20-03-2026	Part of : B-BLOCK SHIVALIK MALVIYA NAGAR	794	Other Outage	Planned Outage	20-03-2026	13:17	20-03-2026	15:34	2:17	0.000000	REPLACEMENT OF HT BUSHING ROD
522	20-03-2026	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	1067	Other Outage	Planned Outage	20-03-2026	11:20	20-03-2026	14:07	2:47	0.004639	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
523	20-03-2026	Part of : F-BLOCK GITANJALI ENCLAVE MALVIYA NAGAR	169	Other Outage	Planned Outage	20-03-2026	10:15	20-03-2026	13:17	3:02	0.000000	REPLACEMENT OF HT BUSHING ROD
524	21-03-2026	Part of : DDA FLATS SAKET, PRESS ENCLAVE SAKET, BLOCK D SAKET, ANUPAM PVR (HTC)	1102	Other Outage	Unplanned Outage	21-03-2026	18:00	21-03-2026	18:54	0:54	0.001619	BIRDAGE
525	22-03-2026	Part of : BLOCK A 1 NEB SARAI SAINIK FARM,POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,BLOCK D FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK D PARYAVARAN COMPLEX SAINIK FARM,SAINIK FARM,BLOCK B FREEDOM FIGHTER VIHAR SAINIK FARM	748	Other Outage	Unplanned Outage	22-03-2026	12:24	22-03-2026	13:05	0:41	0.000016	CABLE FAULT
526	23-03-2026	Part of : G 6-BLOCK MALVIYA NAGAR	553	Other Outage	Planned Outage	23-03-2026	11:11	23-03-2026	14:02	2:51	0.000000	REPLACEMENT OF HT BUSHING ROD
527	23-03-2026	Part of : A-BLOCK GITANJALI ENCLAVE MALVIYA NAGAR	348	Other Outage	Planned Outage	23-03-2026	10:10	23-03-2026	12:48	2:38	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
528	23-03-2026	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	10	Other Outage	Planned Outage	23-03-2026	11:00	23-03-2026	14:00	3:00	0.000000	LT CIRCUIT MAINTENANCE
529	24-03-2026	Part of : POCKET B PHASE-1 SHEIKH SARAI	151	Other Outage	Planned Outage	24-03-2026	10:29	24-03-2026	11:22	0:53	0.000000	REPLACEMENT OF HT BUSHING ROD
530	24-03-2026	Part of : MPMC COLONY SARVODYA ENCLAVE	7	Other Outage	Planned Outage	24-03-2026	10:10	24-03-2026	11:55	1:45	0.000000	REPLACEMENT OF HT BUSHING ROD
531	24-03-2026	Part of : BUTTERFLY PARK QILA RAI PITHORA SAINIK FARM	1	Other Outage	Planned Outage	24-03-2026	11:04	24-03-2026	14:57	3:53	0.000000	LT CIRCUIT MAINTENANCE
532	25-03-2026	Part of : BLOCK E & J SAINIK FARM,BLOCK H NEB SARAI SAINIK FARM, BANDH ROAD WESTERN AVENUE SAINIK FARM	414	Other Outage	Unplanned Outage	25-03-2026	13:10	25-03-2026	13:52	0:42	0.000000	HTAB CABLE FAULT
533	25-03-2026	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	16	Other Outage	Planned Outage	25-03-2026	10:04	25-03-2026	12:28	2:24	0.000000	REPLACEMET OF HT BUSHING ROD
534	26-03-2026	Part of : BLOCK E SAINIK FARM,BLOCK H NEB SARAI SAINIK FARM	398	Other Outage	Unplanned Outage	26-03-2026	16:19	26-03-2026	16:41	0:22	0.000159	HT SYSTEM FAULT
535	26-03-2026	Part of : JAGDAMBA CAMP SHEIKH SARAI,POCKET C PHASE I SHEIKH SARAI	1917	Other Outage	Unplanned Outage	26-03-2026	00:17	26-03-2026	00:43	0:26	0.000339	CABLE FAULT
536	27-03-2026	Part of : SECTOR 1 PUSHPA VIHAR,BLOCK H SAKET,BLOCK N, J, L & G SAKET	1960	Other Outage	Unplanned Outage	27-03-2026	03:54	27-03-2026	04:47	0:53	0.001673	CABLE FAULT
537	27-03-2026	Part of : A 1-BLOCK NEB SARAI SAINIK FARM	1467	Other Outage	Planned Outage	27-03-2026	14:59	27-03-2026	17:13	2:14	0.003722	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB END TERMINATION REPLACEMENT
538	27-03-2026	Part of : B-BLOCK SARVODYA ENCLAVE	1	Other Outage	Planned Outage	27-03-2026	14:02	27-03-2026	16:02	2:00	0.000000	REPLACEMENT OF HT BUSHING ROD
539	28-03-2026	Part of : BEST VIEW INFRACON MALIVIYA NAGAR (HTC)	1	Other Outage	Planned Outage	28-03-2026	11:05	28-03-2026	11:57	0:52	0.000000	REPLACEMET OF FAULTY END BOX
540	28-03-2026	Part of : MADHUKAR HOSPITAL MALVIYA NAGAR (HTC)	1	Other Outage	Planned Outage	28-03-2026	11:59	28-03-2026	13:35	1:36	0.000107	CLEANING OF HT BUSHING PER WAY,REPLACEMET OF FAULTY END BOX
541	28-03-2026	Part of : NAI BASTI LADO SARAI,NEAR CHHATRI WALA KUNA LADO SARAI	3081	Other Outage	Planned Outage	28-03-2026	11:27	28-03-2026	13:56	2:29	0.004139	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER
542	29-03-2026	Part of : SECTOR 6 PUSHPA VIHAR	298	Other Outage	Planned Outage	29-03-2026	11:08	29-03-2026	14:10	3:02	0.005056	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
543	29-03-2026	Part of : SECTOR 6 PUSHPA VIHAR	325	Other Outage	Planned Outage	29-03-2026	11:07	29-03-2026	14:10	3:03	0.005083	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
544	30-03-2026	Part of : BLOCK B NAVJIVAN VIHAR MALVIYA NAGAR,	134	Other Outage	Planned Outage	30-03-2026	14:29	30-03-2026	16:20	1:51	0.000000	REPLACEMET OF HT BUSHING ROD
545	30-03-2026	Part of : FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK A PARYAVARAN COMPLEX SAINIK FARM,BLOCK D PARYAVARAN COMPLEX SAINIK FARM,BLOCK E PARYAVARAN COMPLEX SAINIK FARM,BLOCK C PARYAVARAN COMPLEX SAINIK FARM,	2482	Other Outage	Planned Outage	30-03-2026	11:06	30-03-2026	13:56	2:50	0.004722	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT,LT JUMPER REPLACEMENT,ST.TH JOINT ON 1PH HT AB,ST.TH JOINT ON 3PH HT AB
546	30-03-2026	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI,	1183	Other Outage	Planned Outage	30-03-2026	11:10	30-03-2026	13:52	2:42	0.000000	REPLACEMET OF HT BUSHING ROD
547	30-03-2026	Part of : BLOCK A GITANJALI ENCLAVE MALVIYA NAGAR,	348	Other Outage	Planned Outage	30-03-2026	10:01	30-03-2026	12:45	2:44	0.000000	CONDUCTOR REPLACEMENT PER SPAN
548	31-03-2026	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	526	Other Outage	Planned Outage	31-03-2026	10:52	31-03-2026	13:09	2:17	0.001903	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
549	01-03-2026	Part of : NEHRU MARKET, BADARPUR DDA FLAT, BADARPUR VILLAGE	4652	Other Outage	Unplanned Outage	01-03-2026	13:19	01-03-2026	13:56	0:37	0.001057	CABLE FAULT
550	02-03-2026	Part of : BLOCK D MOLARBAND EXTENSION BADARPUR,	850	Other Outage	Planned Outage	02-03-2026	11:43	02-03-2026	12:16	0:33	0.000092	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT BUSHING ROD
551	02-03-2026	Part of : RAJ NAGAR MADANPUR KHADAR,	686	Other Outage	Planned Outage	02-03-2026	10:55	02-03-2026	13:36	2:41	0.002147	REPLACEMENT OF LT BUSHING ROD
552	02-03-2026	Part of : J BLOCK SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND,K-BLOCK SAURABH VIHAR,D-BLOCK SAURABH,	1381	Other Outage	Planned Outage	02-03-2026	10:40	02-03-2026	13:16	2:36	0.003033	3PH HT AB CABLE REPLACEMENT PER SPAN
553	02-03-2026	Part of : ALI EXTENSION ALI,	236	Other Outage	Planned Outage	02-03-2026	10:56	02-03-2026	13:34	2:38	0.002194	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
554	02-03-2026	Part of : RAJ NAGAR MADANPUR KHADAR,	1665	Other Outage	Planned Outage	02-03-2026	10:55	02-03-2026	13:16	2:21	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
555	03-03-2026	Part of : GAYATRI KUNJ ALI,ALI VILLAGE ALI,ALI VIHAR ALI,LALU COLONY ALI	3081	Other Outage	Unplanned Outage	03-03-2026	13:31	03-03-2026	14:13	0:42	0.000000	CABLE FAULT
556	03-03-2026	Part of : F-BLOCK SAURABH VIHAR	19	Other Outage	Unplanned Outage	03-03-2026	10:54	03-03-2026	12:05	1:11	0.001578	CONNECTION/DISCONNETION OF HT/LT CABLES
557	03-03-2026	Part of : MADANPUR KHADAR	901	Other Outage	Planned Outage	03-03-2026	10:34	03-03-2026	11:11	0:37	0.000576	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
558	03-03-2026	Part of : POCKET F SARITA VIHAR	599	Other Outage	Planned Outage	03-03-2026	10:36	03-03-2026	12:10	1:34	0.002089	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
559	03-03-2026	Part of : H BLOCK SAURABH VIHAR,JAITPUR	1431	Other Outage	Planned Outage	03-03-2026	10:57	03-03-2026	12:07	1:10	0.001361	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
560	03-03-2026	Part of : KHADDA COLONY JAIPUR	184	Other Outage	Planned Outage	03-03-2026	10:35	03-03-2026	12:30	1:55	0.000000	REPLACEMENT OF HT BUSHING ROD
561	05-03-2026	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR	659	Other Outage	Planned Outage	05-03-2026	11:29	05-03-2026	13:43	2:14	0.000372	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF LT BUSHING ROD
562	05-03-2026	Part of : D,J & K-BLOCK SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND	1381	Other Outage	Planned Outage	05-03-2026	10:59	05-03-2026	13:01	2:02	0.002033	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
563	05-03-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1478	Other Outage	Planned Outage	05-03-2026	11:01	05-03-2026	13:11	2:10	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
564	06-03-2026	Part of : J BLOCK SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND,D-BLOCK SAURABH,K-BLOCK SAURABH VIHAR,	1381	Other Outage	Planned Outage	06-03-2026	12:06	06-03-2026	14:28	2:22	0.001972	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
565	06-03-2026	Part of : RAJ NAGAR MADANPUR KHADAR,	1504	Other Outage	Planned Outage	06-03-2026	11:10	06-03-2026	13:25	2:15	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
566	06-03-2026	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR,	720	Other Outage	Planned Outage	06-03-2026	11:09	06-03-2026	13:24	2:15	0.004125	REPLACEMENT OF HT BUSHING ROD
567	07-03-2026	Part of : N & O-BLOCK SAURABH VIHAR,E-BLOCK HARI NAGAR EXT PART-2	1366	Other Outage	Planned Outage	07-03-2026	11:08	07-03-2026	12:20	1:12	0.001200	3PH HT AB CABLE REPLACEMENT PER SPAN,ST.TH JOINT ON 1PH HT AB
568	07-03-2026	Part of : C-BLOCK MOLARBAND EXTENSION BADARPUR	433	Other Outage	Planned Outage	07-03-2026	11:07	07-03-2026	13:09	2:02	0.000339	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING
569	09-03-2026	Part of : BLOCK D MOLARBAND EXTENSION BADARPUR	612	Other Outage	Planned Outage	09-03-2026	11:53	09-03-2026	14:00	2:07	0.000353	SUB STATION CLEANING,TIGHTENING OF NUT BOLT
570	09-03-2026	Part of : H BLOCK SAURABH VIHAR,JAITPUR	1431	Other Outage	Planned Outage	09-03-2026	10:57	09-03-2026	13:48	2:51	0.002850	3PH HT AB CABLE REPLACEMENT PER SPAN,ST.TH JOINT ON 1PH HT AB
571	09-03-2026	Part of : KHADDA COLONY JAIPUR	2608	Other Outage	Planned Outage	09-03-2026	11:02	09-03-2026	13:37	2:35	0.006114	3PH HT AB CABLE REPLACEMENT PER SPAN
572	09-03-2026	Part of : MADANPUR KHADAR VILLAGE	774	Other Outage	Planned Outage	09-03-2026	11:03	09-03-2026	13:39	2:36	0.003467	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
573	10-03-2026	Part of : POCKET M SARITA VIHAR,	637	Other Outage	Planned Outage	10-03-2026	11:34	10-03-2026	12:55	1:21	0.001800	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
574	11-03-2026	Part of : D,K & J-BLOCK SAURABH VIHAR,ABC-BLOCK HARI NAGAR MOLARBAND	1381	Other Outage	Planned Outage	11-03-2026	12:32	11-03-2026	13:08	0:36	0.000600	3PH HT AB CABLE REPLACEMENT,INSULATOR REPLACEMENT
575	11-03-2026	Part of : ALI VILLAGE	1213	Other Outage	Planned Outage	11-03-2026	11:07	11-03-2026	13:43	2:36	0.004767	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
576	11-03-2026	Part of : KHADDA COLONY JAIPUR	3211	Other Outage	Planned Outage	11-03-2026	11:06	11-03-2026	13:40	2:34	0.003850	3PH HT AB END TERMINATION REPLACEMENT
577	12-03-2026	Part of : ALI VILLAGE	463	Other Outage	Unplanned Outage	12-03-2026	15:17	12-03-2026	17:05	1:48	0.001200	PREVENTIVE MAINTENANCE
578	12-03-2026	Part of : KHADDA COLONY JAIPUR	1796	Other Outage	Planned Outage	12-03-2026	11:02	12-03-2026	13:00	1:58	0.002622	3PH HT AB CABLE REPLACEMENT
579	12-03-2026	Part of : H BLOCK SAURABH VIHAR,JAITPUR	1431	Other Outage	Planned Outage	12-03-2026	11:09	12-03-2026	12:22	1:13	0.001419	HT BUSHING REPLACEMENT,ST.TH JOINT ON 1PH HT AB
580	13-03-2026	Part of : L-BLOCK SAURABH VIHAR,M-BLOCK SAURABH VIHAR,K-BLOCK SAURABH VIHAR,H BLOCK SAURABH VIHAR,JAITPUR,F-BLOCK SAURABH VIHAR	2239	Other Outage	Unplanned Outage	13-03-2026	23:54	14-03-2026	00:29	0:35	0.000000	CABLE FAULT
581	13-03-2026	Part of : MOLARBAND VILLAGE BADARPUR	378	Other Outage	Planned Outage	13-03-2026	10:42	13-03-2026	13:41	2:59	0.005469	REPLACEMENT OF FAULTY END BOX
582	13-03-2026	Part of : I-BLOCK HARI NAGAR EXTN,ABC BLOCK HARI NAGAR MOLARBAND,D2-BLOCK HARI NAGAR EXTN-III,ROOP NAGAR MOLARBAND,MOLARBAND	4298	Other Outage	Planned Outage	13-03-2026	11:01	13-03-2026	13:25	2:24	0.002800	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
583	13-03-2026	Part of : KHADDA COLONY JAIPUR	2608	Other Outage	Planned Outage	13-03-2026	11:06	13-03-2026	13:43	2:37	0.005015	3PH HT AB CABLE REPLACEMENT PER SPAN
584	14-03-2026	Part of : E-BLOCK HARI NAGAR EXT PART-2,	1366	Other Outage	Planned Outage	14-03-2026	11:37	14-03-2026	13:49	2:12	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
585	14-03-2026	Part of : KHADDA COLONY JAIPUR,	1959	Other Outage	Planned Outage	14-03-2026	11:04	14-03-2026	13:28	2:24	0.005000	3PH HT AB CABLE REPLACEMENT PER SPAN
586	16-03-2026	Part of : BADARPUR VILLAGE	4619	Other Outage	Unplanned Outage	16-03-2026	02:03	16-03-2026	02:42	0:39	0.000527	CABLE FAULT
587	16-03-2026	Part of : BADARPUR VILLAGE	922	Other Outage	Planned Outage	16-03-2026	11:36	16-03-2026	13:16	1:40	0.000278	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
588	16-03-2026	Part of : D2, E & F-BLOCK HARI NAGAR EXTN	1055	Other Outage	Planned Outage	16-03-2026	11:04	16-03-2026	12:17	1:13	0.000000	3PH HT AB CABLE REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
589	16-03-2026	Part of : BADARPUR EXTENSION TAJPUR	958	Other Outage	Planned Outage	16-03-2026	11:04	16-03-2026	13:47	2:43	0.000453	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
590	16-03-2026	Part of : MADANPUR KHADAR VILLAGE	306	Other Outage	Planned Outage	16-03-2026	10:56	16-03-2026	13:59	3:03	0.004575	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
591	16-03-2026	Part of : RAJ NAGAR MADANPUR KHADAR	671	Other Outage	Planned Outage	16-03-2026	10:57	16-03-2026	14:00	3:03	0.005592	REPLACEMENT OF HT BUSHING ROD
592	17-03-2026	Part of : I-BLOCK HARI NAGAR EXTN,ABC BLOCK HARI NAGAR MOLARBAND	2343	Other Outage	Planned Outage	17-03-2026	11:13	17-03-2026	12:45	1:32	0.001789	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
593	17-03-2026	Part of : ALI VIHAR ,PRIYANKA CAMP,ALI EXTENSION	1042	Other Outage	Planned Outage	17-03-2026	11:08	17-03-2026	13:27	2:19	0.004247	3PH HT AB END TERMINATION REPLACEMENT
594	17-03-2026	Part of : MOLARBAND VILLAGE BADARPUR	2076	Other Outage	Planned Outage	17-03-2026	10:53	17-03-2026	13:41	2:48	0.000467	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE
595	17-03-2026	Part of : RAJ NAGAR MADANPUR KHADAR	357	Other Outage	Planned Outage	17-03-2026	11:09	17-03-2026	13:30	2:21	0.004308	REPLACEMENT OF HT BUSHING ROD
596	18-03-2026	Part of : ABC BLOCK HARI NAGAR MOLARBAND,	1375	Other Outage	Planned Outage	18-03-2026	11:07	18-03-2026	12:16	1:09	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
597	18-03-2026	Part of : KHADDA COLONY JAIPUR,	2390	Other Outage	Planned Outage	18-03-2026	10:56	18-03-2026	13:26	2:30	0.003750	REPLACEMENT OF HT BUSHING ROD
598	18-03-2026	Part of : MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR,BADARPUR EXTENSION TAJPUR BADARPUR,BLOCK A BUDH BIHAR TAJPUR PAHARI VILLAGE BADARPUR,	2412	Other Outage	Planned Outage	18-03-2026	10:57	18-03-2026	13:47	2:50	0.000472	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
599	19-03-2026	Part of : H BLOCK SAURABH VIHAR,JAIPUR	1431	Other Outage	Planned Outage	19-03-2026	11:41	19-03-2026	12:01	0:20	0.000000	3PH HT AB END TERMINATION REPLACEMENT
600	19-03-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1460	Other Outage	Planned Outage	19-03-2026	11:01	19-03-2026	13:17	2:16	0.003022	3PH HT AB CABLE REPLACEMENT
601	20-03-2026	Part of : RAJ NAGAR MADANPUR KHADAR	1665	Other Outage	Planned Outage	20-03-2026	11:01	20-03-2026	12:53	1:52	0.003578	3PH HT AB CABLE REPLACEMENT
602	20-03-2026	Part of : D-BLOCK TAJPUR PAHARI VILLAGE BADARPUR	1168	Other Outage	Planned Outage	20-03-2026	11:33	20-03-2026	12:35	1:02	0.000172	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
603	20-03-2026	Part of : A,B,C & I-BLOCK HARI NAGAR EXTN MOLARBAND	2343	Other Outage	Planned Outage	20-03-2026	11:06	20-03-2026	13:18	2:12	0.002567	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
604	21-03-2026	Part of : BLOCK- A & C KANCHAN KUNJ, MADANPUR KHADAR	1712	Other Outage	Unplanned Outage	21-03-2026	06:00	21-03-2026	06:34	0:34	0.000000	HT SYSTEM FAULT
605	23-03-2026	Part of : BLOCK E MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	91	Other Outage	Unplanned Outage	23-03-2026	18:18	23-03-2026	18:59	0:41	0.000909	CABLE FAULT
606	23-03-2026	Part of : H BLOCK SAURABH VIHAR,JAIPUR	1431	Other Outage	Planned Outage	23-03-2026	11:02	23-03-2026	12:11	1:09	0.000000	3PH HT AB CABLE REPLACEMENT
607	23-03-2026	Part of : BADARPUR EXTENSION	629	Other Outage	Planned Outage	23-03-2026	12:12	23-03-2026	14:48	2:36	0.000433	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
608	23-03-2026	Part of : POCKET A SARITA VIHAR	211	Other Outage	Planned Outage	23-03-2026	11:07	23-03-2026	13:35	2:28	0.002878	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
609	23-03-2026	Part of : KHADDA COLONY JAIPUR	1959	Other Outage	Planned Outage	23-03-2026	11:06	23-03-2026	13:29	2:23	0.003972	3PH HT AB CABLE REPLACEMENT
610	24-03-2026	Part of : B-BLOCK MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	24	Other Outage	Unplanned Outage	24-03-2026	14:36	24-03-2026	15:08	0:32	0.000251	CABLE FAULT
611	24-03-2026	Part of : KHADDA COLONY JAIPUR	1459	Other Outage	Planned Outage	24-03-2026	11:32	24-03-2026	13:12	1:40	0.003889	3PH HT AB CABLE REPLACEMENT
612	24-03-2026	Part of : ABC,D2 & I-BLOCK HARI NAGAR EXTN,ROOP NAGAR MOLARBAND	4296	Other Outage	Planned Outage	24-03-2026	11:23	24-03-2026	13:08	1:45	0.002042	3PH HT AB END TERMINATION REPLACEMENT
613	25-03-2026	Part of : BADARPUR EXTENSION TAJPUR	1162	Other Outage	Planned Outage	25-03-2026	11:06	25-03-2026	13:46	2:40	0.000444	DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
614	25-03-2026	Part of : KHADDA COLONY JAIPUR	2608	Other Outage	Planned Outage	25-03-2026	11:01	25-03-2026	13:20	2:19	0.004324	3PH HT AB CABLE REPLACEMENT PER SPAN
615	25-03-2026	Part of : MADANPUR KHADAR VILLAGE	1062	Other Outage	Planned Outage	25-03-2026	11:02	25-03-2026	13:19	2:17	0.003806	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
616	25-03-2026	Part of : O-BLOCK SAURABH VIHAR	1174	Other Outage	Planned Outage	25-03-2026	11:54	25-03-2026	14:20	2:26	0.000000	3PH HT AB END TERMINATION REPLACEMENT
617	27-03-2026	Part of : A,B,C & I-BLOCK HARI NAGAR EXTN MOLARBAND	2343	Other Outage	Planned Outage	27-03-2026	11:12	27-03-2026	12:48	1:36	0.001867	3PH HT AB CABLE REPLACEMENT PER SPAN,ST.TH JOINT ON 1PH HT AB
618	27-03-2026	Part of : ALI VIHAR	310	Other Outage	Planned Outage	27-03-2026	11:09	27-03-2026	13:31	2:22	0.003156	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
619	27-03-2026	Part of : KHADDA COLONY JAIPUR	1459	Other Outage	Planned Outage	27-03-2026	11:08	27-03-2026	13:29	2:21	0.004700	3PH HT AB CABLE REPLACEMENT
620	27-03-2026	Part of : B-BLOCK MOLARBAND EXTENSION BADARPUR	499	Other Outage	Planned Outage	27-03-2026	11:01	27-03-2026	13:39	2:38	0.000439	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF LUGS,SUB STATION CLEANING
621	28-03-2026	Part of : SAURABH VIHAR, ABC BLOCK HARI NAGAR MOLARBAND, E-BLOCK HARI NAGAR EXT PART-2	4386	Other Outage	Unplanned Outage	28-03-2026	14:35	28-03-2026	15:10	0:35	0.000535	BIRDAGE
622	28-03-2026	Part of : N-BLOCK SAURABH VIHAR	1366	Other Outage	Planned Outage	28-03-2026	12:06	28-03-2026	14:12	2:06	0.000000	1PH HT AB END TERMINATION REPLACEMENT
623	28-03-2026	Part of : MADANPUR KHADAR VILLAGE	1786	Other Outage	Planned Outage	28-03-2026	10:59	28-03-2026	13:30	2:31	0.004614	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
624	28-03-2026	Part of : KHADDA COLONY JAIPUR	2608	Other Outage	Planned Outage	28-03-2026	10:58	28-03-2026	13:29	2:31	0.006292	3PH HT AB CABLE REPLACEMENT PER SPAN
625	29-03-2026	Part of : BLOCK E MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR,GAUTAMPURI AWAS BADARPUR	772	Other Outage	Planned Outage	29-03-2026	10:48	29-03-2026	12:54	2:06	0.000350	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN,GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
626	30-03-2026	Part of : GAUTAMPURI AWAS BADARPUR,	831	Other Outage	Planned Outage	30-03-2026	11:52	30-03-2026	14:28	2:36	0.002600	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
627	30-03-2026	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR,	1779	Other Outage	Planned Outage	30-03-2026	10:55	30-03-2026	13:26	2:31	0.005033	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
628	30-03-2026	Part of : KHADDA COLONY JAIPUR,	1796	Other Outage	Planned Outage	30-03-2026	10:55	30-03-2026	13:24	2:29	0.005174	3PH HT AB CABLE REPLACEMENT PER SPAN
629	30-03-2026	Part of : H BLOCK SAURABH VIHAR,	1431	Other Outage	Planned Outage	30-03-2026	10:28	30-03-2026	12:32	2:04	0.000000	3PH HT AB END TERMINATION REPLACEMENT
630	31-03-2026	Part of : GAUTAMPURI AWAS BADARPUR,BLOCK E MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	1094	Other Outage	Unplanned Outage	31-03-2026	09:35	31-03-2026	10:09	0:34	0.000406	BIRDAGE
631	31-03-2026	Part of : POCKET B SARITA VIHAR	243	Other Outage	Planned Outage	31-03-2026	11:57	31-03-2026	12:33	0:36	0.000900	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
632	31-03-2026	Part of : I-BLOCK HARI NAGAR EXTN,ABC BLOCK HARI NAGAR MOLARBAND	2343	Other Outage	Planned Outage	31-03-2026	11:48	31-03-2026	13:28	1:40	0.001944	3PH HT AB CABLE REPLACEMENT PER SPAN,LT JUMPER REPLACEMENT
633	02-03-2026	Part of : TEACHER COLONY MEHRAULI,	536	Other Outage	Planned Outage	02-03-2026	17:13	02-03-2026	17:20	0:07	0.000058	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE
634	02-03-2026	Part of : PALAM FARMS,	982	Other Outage	Planned Outage	02-03-2026	10:49	02-03-2026	12:04	1:15	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
635	02-03-2026	Part of : RANGPURI,	1370	Other Outage	Planned Outage	02-03-2026	11:08	02-03-2026	13:19	2:11	0.001819	REPLACEMENT OF LT BUSHING ROD
636	02-03-2026	Part of : ANAND GRAM GHITORNI,	60	Other Outage	Planned Outage	02-03-2026	10:58	02-03-2026	13:00	2:02	0.000678	GUARD WIRES SAGGING PER SPAN,HT SLEEVE INSTALLATION PER SPAN,JUMPER REPLACEMENT PER POLE
637	02-03-2026	Part of : DESU COLONY VASANT KUNJ,GANDHI COLONY MEHRAULI,KHANDSA COLONY MEHRAULI,	3660	Other Outage	Planned Outage	02-03-2026	10:12	02-03-2026	13:36	3:24	0.002833	BIRD SPIKES INSTALLATION PER POLE,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
638	02-03-2026	Part of : KAPAS HERA EXTENSION KAPAS HERA,	839	Other Outage	Planned Outage	02-03-2026	10:48	02-03-2026	13:04	2:16	0.000756	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD
639	03-03-2026	Part of : MAHIPALPUR EXTENSION	982	Other Outage	Planned Outage	03-03-2026	11:58	03-03-2026	13:05	1:07	0.001210	REPLACEMENT OF HT BUSHING ROD
640	03-03-2026	Part of : GHITORNI VILLAGE	1124	Other Outage	Planned Outage	03-03-2026	10:50	03-03-2026	12:25	1:35	0.002111	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
641	03-03-2026	Part of : SAMALKA	1049	Other Outage	Planned Outage	03-03-2026	10:36	03-03-2026	12:18	1:42	0.000567	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
642	03-03-2026	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	113	Other Outage	Planned Outage	03-03-2026	10:46	03-03-2026	12:09	1:23	0.000231	HT SLEEVE INSTALLATION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
643	05-03-2026	Part of : SLASH PUR VILLAGE PALAM FARMS,KAPAS HERA EXTENSION,SAMALKA	82	Other Outage	Unplanned Outage	05-03-2026	15:27	05-03-2026	15:49	0:22	0.000385	TREE FALLEN BRANCH ON HT LINE
644	05-03-2026	Part of : SAMALKA	1	Other Outage	Planned Outage	05-03-2026	11:01	05-03-2026	11:50	0:49	0.000272	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
645	05-03-2026	Part of : SAMALKA,KAPAS HERA ESTATE,RAJOKRI VILLAGE RAJOKRI,YAWANTIKA COLONY RANGPURI	914	Other Outage	Planned Outage	05-03-2026	11:04	05-03-2026	12:02	0:58	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
646	05-03-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	563	Other Outage	Planned Outage	05-03-2026	11:12	05-03-2026	11:53	0:41	0.000114	FEEDER PILLAR CLEANING,TAPPING OF MAIN CABLES
647	05-03-2026	Part of : LAKHI NATH KUTI MEHRAULI	557	Other Outage	Planned Outage	05-03-2026	11:39	05-03-2026	13:32	1:53	0.000345	DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
648	05-03-2026	Part of : GHITORNI VILLAGE	45	Other Outage	Planned Outage	05-03-2026	10:48	05-03-2026	12:48	2:00	0.000667	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
649	06-03-2026	Part of : HTC:MES, MARRIED ACOMODATION, RANGP	1	Other Outage	Unplanned Outage	06-03-2026	19:17	06-03-2026	19:49	0:32	0.000178	FAULT IN HT CONSUMER PANEL (MES)
650	06-03-2026	Part of : SAMALKA,KAPAS HERA ESTATE,RAJOKRI VILLAGE RAJOKRI,YAWANTIKA COLONY RANGPURI,AVENUE BOUGANVILLEA RANGPURI,	914	Other Outage	Planned Outage	06-03-2026	11:02	06-03-2026	11:31	0:29	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
651	06-03-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ,	336	Other Outage	Planned Outage	06-03-2026	14:34	06-03-2026	15:13	0:39	0.000108	FEEDER PILLAR CLEANING,TAPPING OF MAIN CABLES,TAPPING OF SERVICE CABLES
652	06-03-2026	Part of : GANDHI COLONY MEHRAULI,	1597	Other Outage	Planned Outage	06-03-2026	13:24	06-03-2026	15:22	1:58	0.000590	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
653	06-03-2026	Part of : POCKET D DR AMBEDKAR COLONY CHHATARPUR,	73	Other Outage	Planned Outage	06-03-2026	11:30	06-03-2026	13:16	1:46	0.000294	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT PER SPAN
654	06-03-2026	Part of : PALAM FARMS,PUSHPANJALI FARMS,DALMIA VIHAR BIJWASAN,	635	Other Outage	Planned Outage	06-03-2026	10:52	06-03-2026	12:08	1:16	0.000000	CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE,GUARD WIRE LACS INSTALLTION PER SPAN
655	07-03-2026	Part of : MAHIPALPUR VILLAGE	498	Other Outage	Unplanned Outage	07-03-2026	01:13	07-03-2026	01:49	0:36	0.000040	CABLE FAULT
656	07-03-2026	Part of : KAPAS HERA EXTENSION,KAPAS HERA ESTATE	2104	Other Outage	Planned Outage	07-03-2026	11:07	07-03-2026	11:44	0:37	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
657	07-03-2026	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	336	Other Outage	Planned Outage	07-03-2026	11:31	07-03-2026	12:25	0:54	0.000150	LT CIRCUIT MAINTENANCE
658	07-03-2026	Part of : POLICE COLONY MEHRAM NAGAR	5	Other Outage	Planned Outage	07-03-2026	12:43	07-03-2026	13:47	1:04	0.000622	REPLACEMENT OF HT BUSHING ROD
659	07-03-2026	Part of : PUSHPANJALI FARMS	269	Other Outage	Planned Outage	07-03-2026	09:57	07-03-2026	11:32	1:35	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT
660	07-03-2026	Part of : POCKET 4 SECTOR D VASANT KUNJ	186	Other Outage	Planned Outage	07-03-2026	10:09	07-03-2026	12:35	2:26	0.000811	GUARD WIRE LACS INSTALLTION PER SPAN,HT SLEEVE INSTALLATION PER SPAN,JUMPER REPLACEMENT PER POLE
661	09-03-2026	Part of : ISLAM COLONY MEHRAULI	586	Other Outage	Planned Outage	09-03-2026	16:06	09-03-2026	16:51	0:45	0.000125	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
662	09-03-2026	Part of : NAYAK PURA BIJWASAN	1303	Other Outage	Planned Outage	09-03-2026	09:41	09-03-2026	10:40	0:59	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,TIGHTENEING OF NUT BOLT
663	09-03-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	363	Other Outage	Planned Outage	09-03-2026	11:28	09-03-2026	12:08	0:40	0.000111	TAPPING OF MAIN CABLES,TAPPING OF SERVICE CABLES
664	09-03-2026	Part of : INSTITUTIONAL AREA VASANT KUNJ	7	Other Outage	Planned Outage	09-03-2026	10:17	09-03-2026	11:40	1:23	0.000231	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
665	09-03-2026	Part of : RAJOKRI VILLAGE,WEST END GREENS RANGPURI,AVENUE JHAKARANDA GOLDEN GRITERS	1661	Other Outage	Planned Outage	09-03-2026	10:29	09-03-2026	11:59	1:30	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
666	09-03-2026	Part of : SAMALKA,KAPAS HERA ESTATE,PUSHPANJALI FARMS,KAPAS HERA EXTENSION	3193	Other Outage	Planned Outage	09-03-2026	09:52	09-03-2026	11:18	1:26	0.000000	CONDUCTOR REPLACEMENT PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING
667	09-03-2026	Part of : ANAND GRAM GHITORNI	5	Other Outage	Planned Outage	09-03-2026	10:39	09-03-2026	12:54	2:15	0.000750	GUARD WIRES SAGGING PER SPAN,HT SLEEVE INSTALLATION PER SPAN
668	10-03-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ,	202	Other Outage	Planned Outage	10-03-2026	11:26	10-03-2026	12:06	0:40	0.000111	FEEDER PILLAR CLEANING,TAPPING OF MAIN CABLES,TAPPING OF SERVICE CABLES

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
669	10-03-2026	Part of : GHITORNI VILLAGE GHITORNI,	1227	Other Outage	Planned Outage	10-03-2026	11:16	10-03-2026	13:08	1:52	0.000622	INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
670	10-03-2026	Part of : RANGPURI NALLAPAR RANGPURI,	442	Other Outage	Planned Outage	10-03-2026	12:04	10-03-2026	13:06	1:02	0.000431	REPLACEMENT OF LT BUSHING ROD
671	10-03-2026	Part of : RAJOKRI VILLAGE RAJOKRI,	620	Other Outage	Planned Outage	10-03-2026	10:46	10-03-2026	11:50	1:04	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF GAS KIT AND OIL SEAL
672	11-03-2026	Part of : ANAND GRAM GHITORNI	33	Other Outage	Planned Outage	11-03-2026	15:54	11-03-2026	16:50	0:56	0.000311	GUARD WIRES SAGGING PER SPAN,HT SLEEVE INSTALLATION PER SPAN,JUMPER REPLACEMENT PER POLE
673	11-03-2026	Part of : TEACHER COLONY MEHRAULI	898	Other Outage	Planned Outage	11-03-2026	14:09	11-03-2026	15:00	0:51	0.000156	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
674	11-03-2026	Part of : NAYAK PURA BIJWASAN	340	Other Outage	Planned Outage	11-03-2026	11:01	11-03-2026	12:34	1:33	0.000000	DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR
675	11-03-2026	Part of : JAWAHAR LAL NEHRU UNIVERSITY	1	Other Outage	Planned Outage	11-03-2026	10:15	11-03-2026	11:45	1:30	0.000250	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS,TAPPING OF JUMPERS
676	11-03-2026	Part of : HARIJAN BASTI RAJOKRI	365	Other Outage	Planned Outage	11-03-2026	10:52	11-03-2026	11:58	1:06	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
677	11-03-2026	Part of : MAHIPALPUR EXTENSION,POCKET 3 & 8 SECTOR C VASANT KUNJ	1422	Other Outage	Planned Outage	11-03-2026	10:26	11-03-2026	13:10	2:44	0.002278	REPLACEMENT OF HT BUSHING ROD
678	12-03-2026	Part of : INDIRA GANDHI INTERNATIONAL AIRPORT,AVENUE BOUGANVILLEA RANGPURI,R-BLOCK R MAHIPALPUR VILLAGE	2461	Other Outage	Planned Outage	12-03-2026	11:44	12-03-2026	12:34	0:50	0.000486	REPLACEMET OF FAULTY END BOX
679	12-03-2026	Part of : KAPAS HERA EXTENSION	343	Other Outage	Planned Outage	12-03-2026	10:59	12-03-2026	11:36	0:37	0.000206	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACMET OF HT BUSHING ROD
680	12-03-2026	Part of : RZ-BLOCK MAHIPALPUR VILLAGE	287	Other Outage	Planned Outage	12-03-2026	11:48	12-03-2026	12:40	0:52	0.000578	REPLACMET OF HT BUSHING ROD
681	12-03-2026	Part of : GHITORNI VILLAGE	390	Other Outage	Planned Outage	12-03-2026	11:14	12-03-2026	13:08	1:54	0.000633	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS
682	12-03-2026	Part of : PUSHPANJALI FARMS	269	Other Outage	Planned Outage	12-03-2026	10:48	12-03-2026	12:10	1:22	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACMET
683	12-03-2026	Part of : R-BLOCK MAHIPALPUR VILLAGE	54	Other Outage	Planned Outage	12-03-2026	10:25	12-03-2026	12:43	2:18	0.001150	REPLACMET OF HT BUSHING ROD
684	12-03-2026	Part of : BADIWALA KUA,TEACHER COLONY,ISLAM COLONY,KALKA DASS MEHRAULI,POCKET 4 SECTOR B VASANT KUNJ	3801	Other Outage	Planned Outage	12-03-2026	12:11	12-03-2026	14:43	2:32	0.000633	1PH HT AB CABLE REPLACEMENT PER SPAN,ST.TH JOINT ON 1PH HT AB
685	13-03-2026	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	557	Other Outage	Planned Outage	13-03-2026	10:38	13-03-2026	11:37	0:59	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
686	13-03-2026	Part of : SAMALKA,KAPAS HERA ESTATE,PUSHPANJALI FARMS,KAPAS HERA EXTENSION KAPAS HERA	3193	Other Outage	Planned Outage	13-03-2026	11:07	13-03-2026	11:56	0:49	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
687	13-03-2026	Part of : RUCHI VIHAR VASANT KUNJ	396	Other Outage	Planned Outage	13-03-2026	11:37	13-03-2026	13:13	1:36	0.000267	3PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,PRC REPLACEMENT PER FEEDER
688	13-03-2026	Part of : ANAND GRAM GHITORNI	204	Other Outage	Planned Outage	13-03-2026	10:52	13-03-2026	12:59	2:07	0.003881	BIRD SPIKES INSTALLATION PER POLE,GUARD WIRES SAGGING PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD
689	13-03-2026	Part of : POCKET A SECTOR A VASANT KUNJ	758	Other Outage	Planned Outage	13-03-2026	12:04	13-03-2026	14:23	2:19	0.000579	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
690	14-03-2026	Part of : POCKET A SECTOR A VASANT KUNJ,	911	Other Outage	Planned Outage	14-03-2026	13:05	14-03-2026	13:25	0:20	0.000011	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
691	14-03-2026	Part of : TEACHER COLONY MEHRAULI,	539	Other Outage	Planned Outage	14-03-2026	12:18	14-03-2026	13:43	1:25	0.000472	INSTALLATION OF BUS BAR
692	14-03-2026	Part of : KAPAS HERA EXTENSION KAPAS HERA,PALAM FARMS,	3350	Other Outage	Planned Outage	14-03-2026	11:00	14-03-2026	12:18	1:18	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
693	14-03-2026	Part of : GHITORNI VILLAGE GHITORNI,	53	Other Outage	Planned Outage	14-03-2026	10:33	14-03-2026	12:31	1:58	0.003606	BIRD SPIKES INSTALLATION PER POLE,GUARD WIRE LACS INSTALLTION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
694	14-03-2026	Part of : RANGPURI,	1059	Other Outage	Planned Outage	14-03-2026	10:37	14-03-2026	13:30	2:53	0.002163	REPLACEMENT OF LT BUSHING ROD
695	16-03-2026	Part of : POCKET 4 SECTOR B VASANT KUNJ	1047	Other Outage	Planned Outage	16-03-2026	14:27	16-03-2026	14:55	0:28	0.000117	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
696	16-03-2026	Part of : RUCHI VIHAR VASANT KUNJ	342	Other Outage	Planned Outage	16-03-2026	12:22	16-03-2026	13:14	0:52	0.000144	LT CIRCUIT MAINTENANCE
697	16-03-2026	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	642	Other Outage	Planned Outage	16-03-2026	10:39	16-03-2026	12:04	1:25	0.000236	ACB REPLACEMENT PER ACB,TAPPING/SPRAY OF ALL BUS BARS IN LT ACB PER ACB,TAPPING/SPRAY OF ALL BUS BARS IN LT MAINACB AFTER OPENING CABLES
698	16-03-2026	Part of : GHITORNI VILLAGE	526	Other Outage	Planned Outage	16-03-2026	10:57	16-03-2026	12:46	1:49	0.003331	BIRD SPIKES INSTALLATION PER POLE,GUARD WIRES SAGGING PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES
699	16-03-2026	Part of : KAPAS HERA EXTENSION	466	Other Outage	Planned Outage	16-03-2026	10:50	16-03-2026	12:28	1:38	0.000544	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
700	16-03-2026	Part of : PALAM FARMS	8	Other Outage	Planned Outage	16-03-2026	10:43	16-03-2026	12:29	1:46	0.000000	1PH DB REVAMPING,3PH DB REPLACEMENT
701	17-03-2026	Part of : DESU COLONY VASANT KUNJ,AHINSHA ENCLAVE MEHRAULI	3497	Other Outage	Planned Outage	17-03-2026	14:18	17-03-2026	14:37	0:19	0.000079	BIRD SPIKES INSTALLATION PER POLE,HT SLEEVE INSTALLATION PER SPAN
702	17-03-2026	Part of : DESU COLONY VASANT KUNJ,GANDHI COLONY MEHRAULI,KHANDSA COLONY MEHRAULI	3658	Other Outage	Planned Outage	17-03-2026	14:18	17-03-2026	14:38	0:20	0.000167	BIRD SPIKES INSTALLATION PER POLE,GUARD WIRES SAGGING PER SPAN
703	17-03-2026	Part of : GHITORNI VILLAGE	306	Other Outage	Planned Outage	17-03-2026	11:18	17-03-2026	12:59	1:41	0.003086	REPLACEMENT OF HT BUSHING INULATOR,SUB STATION CLEANING
704	17-03-2026	Part of : RAJOKRI VILLAGE	395	Other Outage	Planned Outage	17-03-2026	10:49	17-03-2026	12:22	1:33	0.000517	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD
705	17-03-2026	Part of : RANGPURI	1370	Other Outage	Planned Outage	17-03-2026	14:21	17-03-2026	16:01	1:40	0.001667	REPLACEMENT OF LT BUSHING ROD
706	18-03-2026	Part of : AVENUE BOUGANVILLEA RANGPURI,HARIJAN BASTI RAJOKRI,WEST END GREENS RANGPURI,AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	218	Other Outage	Unplanned Outage	18-03-2026	21:33	18-03-2026	22:04	0:31	0.000632	CABLE FAULT
707	18-03-2026	Part of : GHITORNI VILLAGE GHITORNI,	842	Other Outage	Planned Outage	18-03-2026	16:23	18-03-2026	17:13	0:50	0.001528	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER , REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
708	18-03-2026	Part of : BRIJBASI COLONY MEHRAULI,	1096	Other Outage	Planned Outage	18-03-2026	14:43	18-03-2026	15:29	0:46	0.000153	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
709	18-03-2026	Part of : TEACHER COLONY MEHRAULI,	538	Other Outage	Planned Outage	18-03-2026	14:16	18-03-2026	16:05	1:49	0.000606	INSTALLATION OF PHASE SEPERATOR PER SPAN
710	18-03-2026	Part of : MEHRAULI VILLAGE MEHRAULI,	287	Other Outage	Planned Outage	18-03-2026	13:07	18-03-2026	14:44	1:37	0.000323	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
711	18-03-2026	Part of : PUSHANJALI FARMS,	269	Other Outage	Planned Outage	18-03-2026	12:05	18-03-2026	13:18	1:13	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN
712	18-03-2026	Part of : RANGPURI,	1511	Other Outage	Planned Outage	18-03-2026	11:05	18-03-2026	13:00	1:55	0.002076	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
713	18-03-2026	Part of : HARIJAN BASTI RAJOKRI,	324	Other Outage	Planned Outage	18-03-2026	10:45	18-03-2026	11:51	1:06	0.000367	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
714	18-03-2026	Part of : HARIJAN BASTI SECTOR B VASANT KUNJ,	187	Other Outage	Planned Outage	18-03-2026	11:05	18-03-2026	12:33	1:28	0.000244	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER,JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
715	19-03-2026	Part of : IAA COLONY SECTOR D VASANT KUNJ	229	Other Outage	Planned Outage	19-03-2026	11:33	19-03-2026	12:07	0:34	0.000094	CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
716	19-03-2026	Part of : SAMALKA	497	Other Outage	Planned Outage	19-03-2026	10:56	19-03-2026	11:44	0:48	0.000267	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD
717	19-03-2026	Part of : GHITORNI VILLAGE	679	Other Outage	Planned Outage	19-03-2026	14:45	19-03-2026	15:49	1:04	0.001956	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS
718	19-03-2026	Part of : MEHRAM NAGAR WEST	258	Other Outage	Planned Outage	19-03-2026	14:17	19-03-2026	15:45	1:28	0.001100	REPLACEMENT OF HT BUSHING ROD
719	19-03-2026	Part of : R-BLOCK MAHIPALPUR VILLAGE	1398	Other Outage	Planned Outage	19-03-2026	11:51	19-03-2026	13:10	1:19	0.000768	REPLACEMENT OF HT BUSHING ROD
720	19-03-2026	Part of : PALAM FARMS,PUSHPANJALI FARMS,DALMIA VIHAR BIJWASAN	635	Other Outage	Planned Outage	19-03-2026	10:52	19-03-2026	12:17	1:25	0.000000	CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT,CONNECTING OF NEW EARTHING PER EARTHING
721	20-03-2026	Part of : R & F-BLOCK F MAHIPALPUR VILLAGE	953	Other Outage	Unplanned Outage	20-03-2026	19:10	20-03-2026	19:47	0:37	0.000493	CABLE FAULT
722	20-03-2026	Part of : GHITORNI VILLAGE	738	Other Outage	Planned Outage	20-03-2026	14:12	20-03-2026	15:10	0:58	0.001772	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR
723	20-03-2026	Part of : WEST END GREENS RANGPURI,AVENUE BOUGANVILLEA RANGPURI,HARIJAN BASTI RAJOKRI,AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	223	Other Outage	Planned Outage	20-03-2026	11:35	20-03-2026	12:23	0:48	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
724	20-03-2026	Part of : PALAM FARMS	237	Other Outage	Planned Outage	20-03-2026	10:39	20-03-2026	11:40	1:01	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER
725	20-03-2026	Part of : POCKET C SECTOR A VASANT KUNJ	315	Other Outage	Planned Outage	20-03-2026	13:43	20-03-2026	15:08	1:25	0.000236	SUB STATION CLEANING
726	20-03-2026	Part of : CHRISTIAN COLONY MEHRAULI	201	Other Outage	Planned Outage	20-03-2026	12:15	20-03-2026	13:35	1:20	0.000333	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
727	22-03-2026	Part of : POCKET 2 SECTOR C VASANT KUNJ,POCKET 6 SECTOR C VASANT KUNJ	856	Other Outage	Unplanned Outage	22-03-2026	15:24	22-03-2026	16:07	0:43	0.000318	CABLE FAULT
728	23-03-2026	Part of : ANAND GRAM GHITORNI	95	Other Outage	Planned Outage	23-03-2026	15:56	23-03-2026	16:26	0:30	0.000167	CONDUCTOR REPLACEMENT PER SPAN,GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
729	23-03-2026	Part of : SECTOR D VASANT KUNJ	77	Other Outage	Planned Outage	23-03-2026	11:48	23-03-2026	12:28	0:40	0.000111	CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY
730	23-03-2026	Part of : KHANDSA COLONY MEHRAULI	781	Other Outage	Planned Outage	23-03-2026	14:23	23-03-2026	15:34	1:11	0.000256	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
731	23-03-2026	Part of : PALAM FARMS	1	Other Outage	Planned Outage	23-03-2026	10:47	23-03-2026	12:16	1:29	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
732	23-03-2026	Part of : R-BLOCK MAHIPALPUR VILLAGE	54	Other Outage	Planned Outage	23-03-2026	10:31	23-03-2026	13:22	2:51	0.002138	REPLACEMENT OF HT BUSHING ROD
733	23-03-2026	Part of : SECTOR D VASANT KUNJ	203	Other Outage	Planned Outage	23-03-2026	10:37	23-03-2026	13:24	2:47	0.005103	INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
734	24-03-2026	Part of : POCKET C SECTOR A VASANT KUNJ	37	Other Outage	Planned Outage	24-03-2026	15:56	24-03-2026	16:55	0:59	0.000492	REPLACEMENT OF HT BUSHING INULATOR,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
735	24-03-2026	Part of : B-BLOCK NANGAL DEWAT SECTOR D VASANT KUNJ,RUCHI VIHAR VASANT KUNJ	1643	Other Outage	Planned Outage	24-03-2026	12:24	24-03-2026	13:02	0:38	0.000106	CLEANING OF HT BUSHING PER WAY,PROPER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
736	24-03-2026	Part of : DALMIA VIHAR BIJWASAN	626	Other Outage	Planned Outage	24-03-2026	11:00	24-03-2026	11:44	0:44	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
737	24-03-2026	Part of : BADIWALA KUA MEHRAULI,TEACHER COLONY MEHRAULI,ISLAM COLONY MEHRAULI,KALKA DASS MEHRAULI,POCKET 4 SECTOR B VASANT KUNJ	3801	Other Outage	Planned Outage	24-03-2026	14:34	24-03-2026	16:19	1:45	0.000729	1PH HT AB CABLE REPLACEMENT PER SPAN,ST.TH JOINT ON 1PH HT AB
738	24-03-2026	Part of : KAPAS HERA EXTENSION & KAPAS HERA ESTATE	2104	Other Outage	Planned Outage	24-03-2026	10:48	24-03-2026	12:44	1:56	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
739	24-03-2026	Part of : GHITORNI VILLAGE	1227	Other Outage	Planned Outage	24-03-2026	10:57	24-03-2026	12:40	1:43	0.003147	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
740	24-03-2026	Part of : TEACHER COLONY MEHRAULI,LAKHI NATH KUTI MEHRAULI,BRAHMAN MOHALLA MEHRAULI,POCKET 4,5 & 6 SECTOR B VASANT KUNJ,KISHANGARH VILLAGE	2400	Other Outage	Planned Outage	24-03-2026	11:23	24-03-2026	13:28	2:05	0.001215	1PH HT AB END TERMINATION REPLACEMENT,ST.TH JOINT ON 3PH HT AB
741	25-03-2026	Part of : PALAM FARMS,PUSHPANJALI FARMS,DALMIA VIHAR BIJWASAN	635	Other Outage	Planned Outage	25-03-2026	10:46	25-03-2026	12:14	1:28	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT PER SPAN
742	25-03-2026	Part of : SAMALKA,PUSHPANJALI FARMS	2636	Other Outage	Planned Outage	25-03-2026	10:55	25-03-2026	12:02	1:07	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
743	25-03-2026	Part of : GHITORNI VILLAGE	2	Other Outage	Planned Outage	25-03-2026	11:41	25-03-2026	13:45	2:04	0.003789	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
744	25-03-2026	Part of : TEACHER COLONY MEHRAULI	1093	Other Outage	Planned Outage	25-03-2026	12:01	25-03-2026	14:51	2:50	0.000708	DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
745	27-03-2026	Part of : MEHRAULI VILLAGE	287	Other Outage	Planned Outage	27-03-2026	15:14	27-03-2026	16:05	0:51	0.000142	INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
746	27-03-2026	Part of : RANGPURI NALLAPAR	408	Other Outage	Planned Outage	27-03-2026	12:14	27-03-2026	13:01	0:47	0.000392	REPLACEMENT OF HT BUSHING ROD
747	27-03-2026	Part of : B-BLOCK NANGAL DEWAT SECTOR D VASANT KUNJ	819	Other Outage	Planned Outage	27-03-2026	11:38	27-03-2026	12:21	0:43	0.000119	CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
748	27-03-2026	Part of : SAMALKA,KAPAS HERA ESTATE,PUSHPANJALI FARMS,KAPAS HERA EXTENSION	3193	Other Outage	Planned Outage	27-03-2026	11:20	27-03-2026	12:05	0:45	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING
749	27-03-2026	Part of : KAPAS HERA EXTENSION	479	Other Outage	Planned Outage	27-03-2026	11:01	27-03-2026	11:38	0:37	0.000206	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
750	27-03-2026	Part of : GHITORNI VILLAGE	679	Other Outage	Planned Outage	27-03-2026	11:40	27-03-2026	12:56	1:16	0.002322	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
751	28-03-2026	Part of : TEACHER COLONY MEHRAULI	452	Other Outage	Planned Outage	28-03-2026	14:00	28-03-2026	14:07	0:07	0.000039	DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER,SUB STATION CLEANING
752	28-03-2026	Part of : KAPAS HERA EXTENSION,PUSHPANJALI FARMS,PALAM FARMS	2198	Other Outage	Planned Outage	28-03-2026	11:00	28-03-2026	11:35	0:35	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
753	28-03-2026	Part of : RUCHI VIHAR VASANT KUNJ,IAA COLONY SECTOR D VASANT KUNJ	469	Other Outage	Planned Outage	28-03-2026	10:34	28-03-2026	12:00	1:26	0.000478	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
754	28-03-2026	Part of : GHITORNI VILLAGE	390	Other Outage	Planned Outage	28-03-2026	11:33	28-03-2026	13:37	2:04	0.003789	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
755	29-03-2026	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS	3409	Other Outage	Unplanned Outage	29-03-2026	07:55	29-03-2026	08:15	0:20	0.000639	TREE TOUCHING
756	30-03-2026	Part of : RANGPURI PAHARI RANGPURI,IAA COLONY SECTOR D VASANT KUNJ	1164	Other Outage	Unplanned Outage	30-03-2026	04:15	30-03-2026	04:47	0:32	0.000304	TREE TOUCHING
757	30-03-2026	Part of : POCKET C SECTOR A VASANT KUNJ,	284	Other Outage	Planned Outage	30-03-2026	14:16	30-03-2026	15:06	0:50	0.000417	INSTALLATION OF BUS BAR

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
758	30-03-2026	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ,	689	Other Outage	Planned Outage	30-03-2026	14:17	30-03-2026	15:02	0:45	0.000138	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
759	30-03-2026	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ,	562	Other Outage	Planned Outage	30-03-2026	11:12	30-03-2026	11:48	0:36	0.000100	FEEDER PILLAR CLEANING,TAPPING OF MAIN CABLES,TAPPING OF SERVICE CABLES
760	30-03-2026	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS,	3528	Other Outage	Planned Outage	30-03-2026	10:51	30-03-2026	12:15	1:24	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN
761	30-03-2026	Part of : KAPAS HERA EXTENSION KAPAS HERA,	252	Other Outage	Planned Outage	30-03-2026	10:51	30-03-2026	12:04	1:13	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
762	31-03-2026	Part of : RANGPURI PAHARI RANGPURI,IAA COLONY SECTOR D VASANT KUNJ	1164	Other Outage	Unplanned Outage	31-03-2026	08:39	31-03-2026	09:03	0:24	0.000228	TREE TOUCHING
763	02-03-2026	Part of : POCKET D SECTOR 17 DWARKA,	8	Other Outage	Planned Outage	02-03-2026	13:00	02-03-2026	14:12	1:12	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
764	03-03-2026	Part of : POCKET 3 SECTOR 11 DWARKA,SECTOR 12 DWARKA,POCKET 4 SECTOR 11 DWARKA,POCKET 2 SECTOR 11 DWARKA	1495	Other Outage	Unplanned Outage	03-03-2026	13:18	03-03-2026	13:58	0:40	0.000700	TREEE BRANCH FALLEN
765	03-03-2026	Part of : SUBHASH PARK MATIALA	328	Other Outage	Unplanned Outage	03-03-2026	12:10	03-03-2026	14:06	1:56	0.000000	REPAIR OF DAMAGED WIRE ON POLES
766	04-03-2026	Part of : TRANSIT CAMP DWARKA,BHARAT VIHAR DWARKA,POCKET 1 SECTOR 14 DWARKA	2282	Other Outage	Unplanned Outage	04-03-2026	12:39	04-03-2026	13:08	0:29	0.000235	BIRDAGE
767	04-03-2026	Part of : SECTOR 6 & 11 DWARKA	1294	Other Outage	Unplanned Outage	04-03-2026	15:08	04-03-2026	15:47	0:39	0.000390	CABLE FAULT
768	05-03-2026	Part of : BLOCK D & A3 UTTAM VIHAR BINDAPUR,BLOCK A BHARAT NAGAR MADHU VIHAR	1668	Other Outage	Unplanned Outage	05-03-2026	12:47	05-03-2026	14:40	1:53	0.000000	REPLACEMENT OF HVDS TRANSFORMER
769	05-03-2026	Part of : BLOCK D MANSAMAN RAM PARK UTTAM NAGAR	2282	Other Outage	Planned Outage	05-03-2026	11:29	05-03-2026	12:46	1:17	0.000000	REPLACEMENT OF HT BUSHING ROD
770	05-03-2026	Part of : POCKET C SECTOR 17 DWARKA	40	Other Outage	Planned Outage	05-03-2026	12:49	05-03-2026	15:45	2:56	0.000000	REPLACEMENT OF HT BUSHING ROD
771	05-03-2026	Part of : SECTOR 18B DWARKA	95	Other Outage	Planned Outage	05-03-2026	10:01	05-03-2026	12:47	2:46	0.000000	REPLACEMENT OF HT BUSHING ROD
772	06-03-2026	Part of : HTC: PNB PLOT-4 SEC-10	0	Other Outage	Unplanned Outage	06-03-2026	17:06	06-03-2026	18:03	0:57	0.000940	FAULT IN HT CONSUMER PANEL (PNB)
773	06-03-2026	Part of : HAR NAGAR SECTOR 16 DWARKA,	238	Other Outage	Unplanned Outage	06-03-2026	11:03	06-03-2026	12:47	1:44	0.000000	LT ACB INSTALLATION,TRANSFORMER REPLACEMENT
774	06-03-2026	Part of : SECTOR 3 DWARKA,	186	Other Outage	Planned Outage	06-03-2026	12:34	06-03-2026	13:39	1:05	0.000000	REPLACEMENT OF HT BUSHING ROD
775	06-03-2026	Part of : SECTOR 18B DWARKA,	84	Other Outage	Planned Outage	06-03-2026	14:41	06-03-2026	16:43	2:02	0.000000	REPLACEMENT OF HT BUSHING ROD
776	06-03-2026	Part of : SECTOR 3 DWARKA,	209	Other Outage	Planned Outage	06-03-2026	12:33	06-03-2026	14:42	2:09	0.000000	REPLACEMENT OF HT BUSHING ROD
777	06-03-2026	Part of : POCKET B SECTOR 13 DWARKA,	210	Other Outage	Planned Outage	06-03-2026	12:30	06-03-2026	14:40	2:10	0.000000	REPLACEMENT OF FAULTY END BOX
778	07-03-2026	Part of : POCKET B SECTOR 13 DWARKA	210	Other Outage	Unplanned Outage	07-03-2026	11:52	07-03-2026	13:41	1:49	0.000000	REPAIRING OF RMU
779	07-03-2026	Part of : D-BLOCK MANSAMAN RAM PARK UTTAM NAGAR	904	Other Outage	Planned Outage	07-03-2026	11:33	07-03-2026	13:28	1:55	0.000000	LT CIRCUIT MAINTENANCE
780	07-03-2026	Part of : SECTOR 18B DWARKA	99	Other Outage	Planned Outage	07-03-2026	13:27	07-03-2026	15:36	2:09	0.000000	REPLACEMENT OF HT BUSHING ROD
781	09-03-2026	Part of : POCKET 2 SECTOR 19 DWARKA	751	Other Outage	Planned Outage	09-03-2026	11:26	09-03-2026	13:51	2:25	0.000000	ACB REPLACEMENT PER ACB
782	09-03-2026	Part of : SECTOR 18B DWARKA	73	Other Outage	Planned Outage	09-03-2026	10:56	09-03-2026	13:50	2:54	0.000000	REPLACEMENT OF HT BUSHING ROD
783	09-03-2026	Part of : SUBHASH PARK MATIALA	2011	Other Outage	Planned Outage	09-03-2026	14:01	09-03-2026	16:54	2:53	0.000000	REPLACEMENT OF HT BUSHING ROD
784	10-03-2026	Part of : BLOCK D MANSAMAN RAM PARK UTTAM NAGAR,	648	Other Outage	Unplanned Outage	10-03-2026	11:48	10-03-2026	13:38	1:50	0.000000	REPAIR OF RMU
785	10-03-2026	Part of : SECTOR 6 DWARKA,SECTOR 11 DWARKA,	1294	Other Outage	Unplanned Outage	10-03-2026	10:59	10-03-2026	12:50	1:51	0.000000	REPAIR OF RMU
786	10-03-2026	Part of : POCKET 3 SECTOR 11 DWARKA,SECTOR 12 DWARKA,POCKET 4 SECTOR 11 DWARKA,POCKET 2 SECTOR 11 DWARKA,	1498	Other Outage	Planned Outage	10-03-2026	14:45	10-03-2026	16:19	1:34	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
787	10-03-2026	Part of : SECTOR 18B DWARKA,	2090	Other Outage	Planned Outage	10-03-2026	10:24	10-03-2026	12:35	2:11	0.000000	REPLACEMENT OF HT BUSHING ROD
788	11-03-2026	Part of : SECTOR 18B DWARKA	103	Other Outage	Planned Outage	11-03-2026	11:40	11-03-2026	12:39	0:59	0.000000	REPLACEMENT OF HT BUSHING ROD
789	11-03-2026	Part of : POCKET 3 SECTOR 19 DWARKA	400	Other Outage	Planned Outage	11-03-2026	13:11	11-03-2026	15:37	2:26	0.000000	ACB REPLACEMENT
790	12-03-2026	Part of : POCKET 3 SECTOR 19 DWARKA	107	Other Outage	Unplanned Outage	12-03-2026	11:18	12-03-2026	12:14	0:56	0.000053	CABLE FAULT
791	12-03-2026	Part of : HAR NAGAR SECTOR 16 DWARKA	238	Other Outage	Planned Outage	12-03-2026	13:48	12-03-2026	15:51	2:03	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
792	12-03-2026	Part of : SECTOR 18B DWARKA	90	Other Outage	Planned Outage	12-03-2026	10:28	12-03-2026	13:03	2:35	0.000000	REPLACEMENT OF HT BUSHING ROD
793	13-03-2026	Part of : SECTOR 18B DWARKA	97	Other Outage	Planned Outage	13-03-2026	11:41	13-03-2026	13:32	1:51	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
794	13-03-2026	Part of : BLOCK D MANSA RAM PARK UTTAM NAGAR	905	Other Outage	Planned Outage	13-03-2026	10:59	13-03-2026	13:29	2:30	0.000000	REPLACEMENT OF LT BUSHING ROD
795	14-03-2026	Part of : SECTOR 16C DWARKA,	46	Other Outage	Unplanned Outage	14-03-2026	10:07	14-03-2026	11:53	1:46	0.000000	ATTENDING WEAK POINTS/HOT SPOT
796	14-03-2026	Part of : SECTOR 18B DWARKA,	124	Other Outage	Planned Outage	14-03-2026	12:03	14-03-2026	13:54	1:51	0.000000	REPLACEMENT OF HT BUSHING ROD
797	15-03-2026	Part of : SECTOR 19 DWARKA	2209	Other Outage	Unplanned Outage	15-03-2026	16:54	15-03-2026	17:42	0:48	0.000066	CABLE FAULT
798	15-03-2026	Part of : RAJU ENCLAVE SECTOR 15 DWARKA,HARI VIHAR SECTOR 15 DWARKA,CHANDAN PARK DWARKA,HARI VIHAR SECTOR 16A DWARKA	4670	Other Outage	Unplanned Outage	15-03-2026	05:42	15-03-2026	06:42	1:00	0.000397	CABLE FAULT
799	16-03-2026	Part of : SECTOR 18B DWARKA	372	Other Outage	Planned Outage	16-03-2026	11:36	16-03-2026	13:31	1:55	0.000000	REPLACEMENT OF HT BUSHING ROD
800	17-03-2026	Part of : BLOCK G RAJAPURI MATIALA,BLOCK G JAIN COLONY MATIALA,BLOCK B SUBHASH PARK MATIALA	5589	Other Outage	Unplanned Outage	17-03-2026	00:48	17-03-2026	01:25	0:37	0.000426	HT SYSTEM FAULT
801	17-03-2026	Part of : SUBHASH PARK MATIALA	1492	Other Outage	Unplanned Outage	17-03-2026	11:34	17-03-2026	13:23	1:49	0.000000	LT ACB INSTALLATION
802	17-03-2026	Part of : RAJU ENCLAVE SECTOR 15 DWARKA,HARI VIHAR SECTOR 15 DWARKA,BAJAJ ENCLAVE SECTOR 15 DWARKA	6170	Other Outage	Unplanned Outage	17-03-2026	10:47	17-03-2026	12:36	1:49	0.000000	BUSHING REPLACEMENT
803	17-03-2026	Part of : POCKET 3 SECTOR 19 DWARKA	1006	Other Outage	Planned Outage	17-03-2026	13:23	17-03-2026	14:21	0:58	0.000000	ACB REPLACEMENT PER ACB
804	17-03-2026	Part of : POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA,POCKET 3 SECTOR 19 DWARKA,SECTOR 19 DWARKA	2572	Other Outage	Planned Outage	17-03-2026	14:18	17-03-2026	15:39	1:21	0.000000	ACB REPLACEMENT PER ACB
805	17-03-2026	Part of : SECTOR 18B DWARKA	239	Other Outage	Planned Outage	17-03-2026	11:43	17-03-2026	13:40	1:57	0.000000	REPLACEMENT OF HT BUSHING ROD
806	18-03-2026	Part of : SECTOR 3 DWARKA	1825	Other Outage	Unplanned Outage	18-03-2026	18:58	18-03-2026	19:28	0:30	0.000321	TRANSIENT FAULT
807	18-03-2026	Part of : BLOCK D UTTAM VIHAR BINDAPUR,BLOCK RZ MADHU VIHAR,BLOCK A3 UTTAM VIHAR BINDAPUR	4592	Other Outage	Unplanned Outage	18-03-2026	11:03	18-03-2026	12:03	1:00	0.000736	TRANSIENT FAULT
808	18-03-2026	Part of : NAND VIHAR SECTOR 16A DWARKA,	1187	Other Outage	Planned Outage	18-03-2026	11:27	18-03-2026	12:22	0:55	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
809	18-03-2026	Part of : SECTOR 18B DWARKA,	2090	Other Outage	Planned Outage	18-03-2026	11:27	18-03-2026	13:30	2:03	0.000000	REPLACEMENT OF HT BUSHING ROD
810	19-03-2026	Part of : SEWAGE TREAT PLANT 20 MGD SEC-16D (HTC)	0	Other Outage	Unplanned Outage	19-03-2026	14:57	19-03-2026	15:47	0:50	0.001473	CABLE FAULT
811	19-03-2026	Part of : SECTOR 11 DWARKA	5	Other Outage	Planned Outage	19-03-2026	11:11	19-03-2026	13:27	2:16	0.000378	REPLACEMENT OF HT BUSHING ROD
812	19-03-2026	Part of : KAKRAULA VILLAGE DWARKA	595	Other Outage	Planned Outage	19-03-2026	11:27	19-03-2026	13:29	2:02	0.000000	REPLACEMENT OF HT BUSHING ROD
813	23-03-2026	Part of : BHARAT VIHAR DWARKA	311	Other Outage	Planned Outage	23-03-2026	10:26	23-03-2026	12:46	2:20	0.000000	REPLACEMENT OF HT BUSHING ROD
814	24-03-2026	Part of : BHARAT VIHAR DWARKA	1	Other Outage	Planned Outage	24-03-2026	09:54	24-03-2026	12:30	2:36	0.000000	REPLACEMENT OF HT BUSHING ROD
815	25-03-2026	Part of : POCKET 1 SECTOR 14 DWARKA,POCKET B SECTOR 13 DWARKA	3848	Other Outage	Unplanned Outage	25-03-2026	16:02	25-03-2026	17:42	1:40	0.000000	REPAIRING OF RMU
816	25-03-2026	Part of : POCKET C,D & E SECTOR 17 DWARKA,POCKET B SECTOR 13 DWARKA	2063	Other Outage	Unplanned Outage	25-03-2026	16:01	25-03-2026	17:41	1:40	0.000000	REPAIRING OF RMU
817	25-03-2026	Part of : BHARAT VIHAR DWARKA	70	Other Outage	Planned Outage	25-03-2026	13:57	25-03-2026	16:21	2:24	0.000000	REPLACEMENT OF HT BUSHING ROD
818	25-03-2026	Part of : SECTOR 10 DWARKA	83	Other Outage	Planned Outage	25-03-2026	13:54	25-03-2026	16:20	2:26	0.000000	REPLACEMENT OF HT BUSHING ROD
819	26-03-2026	Part of : SECTOR 18A DWARKA,POCKET C SECTOR 17 DWARKA,SECTOR 18B DWARKA,POCKET B SECTOR 17 DWARKA	2652	Other Outage	Unplanned Outage	26-03-2026	15:06	26-03-2026	15:52	0:46	0.000526	ELECTROCUTION OF SQUIRREL
820	27-03-2026	Part of : BHARAT VIHAR DWARKA	439	Other Outage	Planned Outage	27-03-2026	12:05	27-03-2026	14:11	2:06	0.000000	REPLACEMENT OF HT BUSHING ROD
821	28-03-2026	Part of : BHARAT VIHAR DWARKA	439	Other Outage	Planned Outage	28-03-2026	11:54	28-03-2026	14:16	2:22	0.000000	REPLACEMENT OF HT BUSHING ROD
822	30-03-2026	Part of : SECTOR 19 DWARKA,	84	Other Outage	Planned Outage	30-03-2026	12:18	30-03-2026	14:19	2:01	0.000000	REPLACEMENT OF HT BUSHING ROD
823	31-03-2026	Part of : SECTOR 18A DWARKA	4	Other Outage	Planned Outage	31-03-2026	13:19	31-03-2026	14:38	1:19	0.000000	REPLACEMENT OF HT BUSHING ROD
824	31-03-2026	Part of : NAND VIHAR SECTOR 16A DWARKA	1187	Other Outage	Planned Outage	31-03-2026	10:05	31-03-2026	11:14	1:09	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
825	02-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	3925	Other Outage	Unplanned Outage	02-03-2026	13:48	02-03-2026	14:16	0:28	0.000388	CABLE FAULT
826	02-03-2026	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE,	1470	Other Outage	Planned Outage	02-03-2026	15:49	02-03-2026	16:11	0:22	0.000367	REPLACEMENT OF HT BUSHING ROD
827	02-03-2026	Part of : NANU RAM PARK NAJAFGARH,	29	Other Outage	Planned Outage	02-03-2026	14:06	02-03-2026	15:06	1:00	0.001000	REPLACEMENT OF HT BUSHING ROD
828	02-03-2026	Part of : KHERA DABAS VILLAGE,SUREHRA VILLAGE,KHARKHARI ROND VILLAGE,	1591	Other Outage	Planned Outage	02-03-2026	14:28	02-03-2026	16:09	1:41	0.001403	GUARD WIRES SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
829	02-03-2026	Part of : BADHOSRA,	318	Other Outage	Planned Outage	02-03-2026	14:14	02-03-2026	15:31	1:17	0.001069	REPLACEMET OF HT BUSHING ROD
830	02-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	2355	Other Outage	Planned Outage	02-03-2026	11:29	02-03-2026	13:29	2:00	0.002000	REPLACEMET OF HT BUSHING ROD
831	02-03-2026	Part of : SARANGPUR VILLAGE,	14	Other Outage	Planned Outage	02-03-2026	12:52	02-03-2026	15:32	2:40	0.002667	REPLACEMET OF HT BUSHING ROD
832	02-03-2026	Part of : MALIKPUR ZER VILLAGE,	401	Other Outage	Planned Outage	02-03-2026	11:11	02-03-2026	13:16	2:05	0.002083	REPLACEMENT OF LT BUSHING ROD
833	03-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1434	Other Outage	Planned Outage	03-03-2026	16:02	03-03-2026	16:53	0:51	0.000567	REPLACEMENT OF HT BUSHING ROD
834	03-03-2026	Part of : KHERA DABAS VILLAGE	254	Other Outage	Planned Outage	03-03-2026	12:00	03-03-2026	14:17	2:17	0.003044	REPLACEMENT OF HT BUSHING ROD
835	05-03-2026	Part of : MANDHELA KALAN VILLAGE	12	Other Outage	Planned Outage	05-03-2026	16:08	05-03-2026	16:49	0:41	0.000569	REPLACEMET OF HT BUSHING ROD
836	05-03-2026	Part of : MITRAON VILLAGE NAJAFGARH	242	Other Outage	Planned Outage	05-03-2026	15:11	05-03-2026	16:39	1:28	0.001467	REPLACEMET OF HT BUSHING ROD
837	05-03-2026	Part of : SRI HANS NAGAR	529	Other Outage	Planned Outage	05-03-2026	15:20	05-03-2026	16:40	1:20	0.001333	REPLACEMENT OF LT BUSHING ROD
838	05-03-2026	Part of : GOPAL NAGAR NAJAFGARH	2	Other Outage	Planned Outage	05-03-2026	14:22	05-03-2026	16:35	2:13	0.001847	REPLACEMENT OF HT BUSHING ROD
839	06-03-2026	Part of : MITRAON VILLAGE NAJAFGARH,	242	Other Outage	Planned Outage	06-03-2026	16:08	06-03-2026	16:48	0:40	0.000444	REPLACEMET OF HT BUSHING ROD
840	06-03-2026	Part of : SAMAZPUR KHALSA,	171	Other Outage	Planned Outage	06-03-2026	16:09	06-03-2026	16:41	0:32	0.000533	REPLACEMENT OF LT BUSHING ROD
841	06-03-2026	Part of : MANDHELA KHURD VILLAGE,	3	Other Outage	Planned Outage	06-03-2026	11:54	06-03-2026	14:06	2:12	0.002200	TAPPING OF UG CABLE TO OH JUMPER CONNECTION
842	07-03-2026	Part of : SHYAM ENCAVE NAJAFGARH,KRISHAN VIHAR NAJAFGARH,BASCO COLONY ARYA NAGAR NAJAFGARH,GOPAL NAGAR NAJAFGARH,MITRAON VILLAGE NAJAFGARH	3130	Other Outage	Unplanned Outage	07-03-2026	13:19	07-03-2026	13:47	0:28	0.000117	HVDS FAULT
843	07-03-2026	Part of : JAFARPUR KALAN VILLAGE	1	Other Outage	Planned Outage	07-03-2026	14:32	07-03-2026	15:04	0:32	0.000533	REPLACEMENT OF HT BUSHING ROD
844	07-03-2026	Part of : KAIR VILLAGE	1	Other Outage	Planned Outage	07-03-2026	14:32	07-03-2026	15:03	0:31	0.000431	REPLACEMENT OF HT BUSHING ROD
845	07-03-2026	Part of : NEHA COLONY,B-BLOCK NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	320	Other Outage	Planned Outage	07-03-2026	14:30	07-03-2026	15:41	1:11	0.001183	REPLACEMENT OF HT BUSHING ROD
846	07-03-2026	Part of : HAIBUTPURA EXTENSION	439	Other Outage	Planned Outage	07-03-2026	13:09	07-03-2026	15:06	1:57	0.001950	REPLACEMENT OF HT BUSHING ROD
847	09-03-2026	Part of : BABA HARI DAS ENCLAVE JHARODA KALAN	455	Other Outage	Planned Outage	09-03-2026	14:42	09-03-2026	16:04	1:22	0.001139	REPLACEMENT OF HT BUSHING ROD
848	09-03-2026	Part of : KHERA DABAS VILLAGE	20	Other Outage	Planned Outage	09-03-2026	14:42	09-03-2026	16:08	1:26	0.001911	REPLACEMENT OF HT BUSHING ROD
849	09-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	320	Other Outage	Planned Outage	09-03-2026	14:43	09-03-2026	16:07	1:24	0.001167	REPLACEMENT OF HT BUSHING ROD
850	09-03-2026	Part of : SARANGPUR VILLAGE	16	Other Outage	Planned Outage	09-03-2026	12:28	09-03-2026	14:25	1:57	0.001950	REPLACEMENT OF LT BUSHING ROD
851	09-03-2026	Part of : MANDHELA KHURD VILLAGE	2	Other Outage	Planned Outage	09-03-2026	10:58	09-03-2026	13:01	2:03	0.000000	REPLACEMENT OF LT BUSHING ROD
852	10-03-2026	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE,	1470	Other Outage	Planned Outage	10-03-2026	15:08	10-03-2026	16:25	1:17	0.001069	REPLACEMET OF HT BUSHING ROD
853	10-03-2026	Part of : DHANSA VILLAGE,	355	Other Outage	Planned Outage	10-03-2026	11:51	10-03-2026	13:40	1:49	0.001514	REPLACEMET OF HT BUSHING ROD
854	10-03-2026	Part of : GOPAL EXTENSION II NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	5	Other Outage	Planned Outage	10-03-2026	13:58	10-03-2026	16:26	2:28	0.002467	REPLACEMET OF HT BUSHING ROD
855	10-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	5117	Other Outage	Planned Outage	10-03-2026	13:58	10-03-2026	16:24	2:26	0.002028	GUARD WIRE LACS INSTALLTION PER SPAN
856	10-03-2026	Part of : KHERA DABAS VILLAGE,	20	Other Outage	Planned Outage	10-03-2026	13:56	10-03-2026	16:24	2:28	0.002467	REPLACEMET OF HT BUSHING ROD
857	11-03-2026	Part of : GOPAL EXTENSION-2 NAJAFGARH,Z-BLOCK CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	5	Other Outage	Planned Outage	11-03-2026	14:48	11-03-2026	16:44	1:56	0.001289	REPLACEMENT OF HT BUSHING ROD
858	11-03-2026	Part of : A 1-BLOCK VINOBHA ENCLAVE,CRPF COLONY JHARODA KALAN,D-BLOCK BANGALI COLONY NAVEEN PALACE JHARODA KALAN	280	Other Outage	Planned Outage	11-03-2026	14:47	11-03-2026	16:43	1:56	0.001611	REPLACEMENT OF HT BUSHING ROD
859	11-03-2026	Part of : GHALLBPUR VILLAGE	138	Other Outage	Planned Outage	11-03-2026	14:02	11-03-2026	15:28	1:26	0.001433	REPLACEMENT OF HT BUSHING ROD
860	11-03-2026	Part of : SAMAZPUR KHALSA	190	Other Outage	Planned Outage	11-03-2026	12:11	11-03-2026	14:40	2:29	0.002483	REPLACEMENT OF HT BUSHING ROD
861	11-03-2026	Part of : BADHOSRA	458	Other Outage	Planned Outage	11-03-2026	12:03	11-03-2026	14:39	2:36	0.002167	REPLACEMENT OF HT BUSHING ROD
862	11-03-2026	Part of : MANDHELA KHURD & KALAN VILLAGE,KAIR VILLAGE,MITRAON VILLAGE NAJAFGARH,RAWTA JAFARPUR KALAN VILLAGE	834	Other Outage	Planned Outage	11-03-2026	12:21	11-03-2026	14:40	2:19	0.001931	REPLACEMENT OF HT BUSHING ROD
863	12-03-2026	Part of : HAIBUTPUR	377	Other Outage	Planned Outage	12-03-2026	15:12	12-03-2026	16:33	1:21	0.001350	REPLACEMET OF HT BUSHING ROD
864	12-03-2026	Part of : MANDHELA KHURD & KALAN VILLAGE,KAIR VILLAGE	834	Other Outage	Planned Outage	12-03-2026	12:40	12-03-2026	14:13	1:33	0.001292	REPLACEMET OF HT BUSHING ROD
865	12-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR,B-BLOCK NANDA ENCLAVE NAJAFGARH	1053	Other Outage	Planned Outage	12-03-2026	13:58	12-03-2026	16:30	2:32	0.002111	REPLACEMET OF HT BUSHING ROD
866	12-03-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	1005	Other Outage	Planned Outage	12-03-2026	11:12	12-03-2026	13:37	2:25	0.002417	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
867	13-03-2026	Part of : ASALATPUR KHAWAD	7	Other Outage	Planned Outage	13-03-2026	15:05	13-03-2026	16:42	1:37	0.001617	REPLACEMENT OF HT BUSHING ROD
868	13-03-2026	Part of : KHERA DABAS VILLAGE	698	Other Outage	Planned Outage	13-03-2026	15:04	13-03-2026	16:23	1:19	0.001317	REPLACEMENT OF LT BUSHING ROD
869	13-03-2026	Part of : GOPAL NAGAR NAJAFGARH	434	Other Outage	Planned Outage	13-03-2026	15:00	13-03-2026	16:42	1:42	0.001700	REPLACEMENT OF HT BUSHING ROD
870	13-03-2026	Part of : ISSAPUR VILLAGE	454	Other Outage	Planned Outage	13-03-2026	12:21	13-03-2026	13:54	1:33	0.001292	REPLACEMENT OF HT BUSHING ROD
871	13-03-2026	Part of : QAZIPUR VILLAGE	2	Other Outage	Planned Outage	13-03-2026	12:11	13-03-2026	14:38	2:27	0.002450	REPLACEMENT OF LT BUSHING ROD
872	13-03-2026	Part of : MANDHELA KHURD VILLAGE	1	Other Outage	Planned Outage	13-03-2026	10:59	13-03-2026	13:05	2:06	0.001750	REPLACEMENT OF HT BUSHING ROD
873	14-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	2355	Other Outage	Planned Outage	14-03-2026	15:12	14-03-2026	16:24	1:12	0.001200	REPLACEMENT OF HT BUSHING ROD
874	14-03-2026	Part of : BASCO COLONY ARYA NAGAR NAJAFGARH,	45	Other Outage	Planned Outage	14-03-2026	15:11	14-03-2026	16:22	1:11	0.001183	REPLACEMENT OF HT BUSHING ROD
875	16-03-2026	Part of : MITRAON VILLAGE NAJAFGARH,SUREHRA VILLAGE	467	Other Outage	Unplanned Outage	16-03-2026	05:17	16-03-2026	06:03	0:46	0.000026	BIRDAGE
876	16-03-2026	Part of : MITRAON VILLAGE NAJAFGARH,SUREHRA VILLAGE	467	Other Outage	Unplanned Outage	16-03-2026	03:38	16-03-2026	04:30	0:52	0.000072	BIRDAGE
877	16-03-2026	Part of : MANDHELA KHURD & KALAN VILLAGE,KAIR VILLAGE,MITRAON VILLAGE NAJAFGARH,RAWTA JAFARPUR KALAN VILLAGE	834	Other Outage	Planned Outage	16-03-2026	15:02	16-03-2026	16:31	1:29	0.001236	REPLACEMENT OF HT BUSHING ROD
878	16-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1434	Other Outage	Planned Outage	16-03-2026	15:01	16-03-2026	16:31	1:30	0.001500	REPLACEMENT OF HT BUSHING ROD
879	16-03-2026	Part of : A1-BLOCK VINOBHA ENCLAVE,CRPF COLONY JHARODA KALAN,D-BLOCK BANGALI COLONY NAVEEN PALACE JHARODA KALAN	280	Other Outage	Planned Outage	16-03-2026	12:52	16-03-2026	15:19	2:27	0.002450	REPLACEMENT OF HT BUSHING ROD
880	16-03-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	732	Other Outage	Planned Outage	16-03-2026	12:12	16-03-2026	14:39	2:27	0.002450	REPLACEMENT OF HT BUSHING ROD
881	16-03-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	16	Other Outage	Planned Outage	16-03-2026	11:55	16-03-2026	14:38	2:43	0.002717	REPLACEMENT OF HT BUSHING ROD
882	17-03-2026	Part of : MITRAON VILLAGE NAJAFGARH,KAIR VILLAGE,SUREHRA VILLAGE	1618	Other Outage	Unplanned Outage	17-03-2026	14:36	17-03-2026	15:05	0:29	0.000216	HT SYSTEM FAULT
883	17-03-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE	3	Other Outage	Planned Outage	17-03-2026	15:40	17-03-2026	16:32	0:52	0.000722	REPLACEMENT OF HT BUSHING ROD
884	17-03-2026	Part of : ISSAPUR VILLAGE	268	Other Outage	Planned Outage	17-03-2026	12:23	17-03-2026	14:02	1:39	0.001375	REPLACEMENT OF HT BUSHING ROD
885	17-03-2026	Part of : HAIBUTPUR,BABA HARI DAS ENCLAVE JHARODA KALAN	3	Other Outage	Planned Outage	17-03-2026	14:18	17-03-2026	16:31	2:13	0.002217	REPLACEMENT OF HT BUSHING ROD
886	17-03-2026	Part of : MANDHELA KHURD VILLAGE	5	Other Outage	Planned Outage	17-03-2026	14:27	17-03-2026	16:32	2:05	0.001736	REPLACEMENT OF LT BUSHING ROD
887	18-03-2026	Part of : BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN,BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN,	280	Other Outage	Planned Outage	18-03-2026	15:37	18-03-2026	16:41	1:04	0.001067	REPLACEMENT OF HT BUSHING ROD
888	18-03-2026	Part of : KHERA DABAS VILLAGE,	256	Other Outage	Planned Outage	18-03-2026	15:16	18-03-2026	16:48	1:32	0.001533	REPLACEMENT OF HT BUSHING ROD
889	18-03-2026	Part of : MALIKPUR ZER VILLAGE,JAFARPUR KALAN VILLAGE,SAMAZPUR KHALSA,	1708	Other Outage	Planned Outage	18-03-2026	11:37	18-03-2026	13:57	2:20	0.001944	GUARD WIRE LACS INSTALLTION PER SPAN
890	19-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	4416	Other Outage	Unplanned Outage	19-03-2026	14:21	19-03-2026	15:04	0:43	0.000509	CABLE FAULT
891	19-03-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	1337	Other Outage	Planned Outage	19-03-2026	15:44	19-03-2026	16:46	1:02	0.000861	REPLACEMENT OF HT BUSHING ROD
892	19-03-2026	Part of : SRI HANS NAGAR	529	Other Outage	Planned Outage	19-03-2026	15:40	19-03-2026	16:43	1:03	0.001050	REPLACEMENT OF HT BUSHING ROD
893	19-03-2026	Part of : HAIBUTPUR	1058	Other Outage	Planned Outage	19-03-2026	14:21	19-03-2026	16:45	2:24	0.002400	REPLACEMENT OF HT BUSHING ROD
894	20-03-2026	Part of : BPS UJWA VILLAGE (HT CONSUMER)	1	Other Outage	Planned Outage	20-03-2026	16:11	20-03-2026	16:59	0:48	0.000667	REPLACEMENT OF HT BUSHING ROD
895	20-03-2026	Part of : ZOBLOCK CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	704	Other Outage	Planned Outage	20-03-2026	16:07	20-03-2026	17:00	0:53	0.000883	REPLACEMENT OF HT BUSHING ROD
896	20-03-2026	Part of : GOPAL NAGAR NAJAFGARH	434	Other Outage	Planned Outage	20-03-2026	16:01	20-03-2026	17:04	1:03	0.001400	REPLACEMENT OF HT BUSHING ROD
897	20-03-2026	Part of : DHANSA VILLAGE	384	Other Outage	Planned Outage	20-03-2026	11:12	20-03-2026	13:32	2:20	0.001944	REPLACEMENT OF HT BUSHING ROD
898	23-03-2026	Part of : JAFARPUR KALAN VILLAGE	428	Other Outage	Planned Outage	23-03-2026	15:57	23-03-2026	16:51	0:54	0.000750	REPLACEMENT OF HT BUSHING ROD
899	23-03-2026	Part of : BASCO COLONY ARYA NAGAR NAJAFGARH	45	Other Outage	Planned Outage	23-03-2026	15:01	23-03-2026	16:39	1:38	0.001361	REPLACEMENT OF HT BUSHING ROD
900	23-03-2026	Part of : MANDHELA KALAN VILLAGE	281	Other Outage	Planned Outage	23-03-2026	15:04	23-03-2026	16:39	1:35	0.001319	REPLACEMENT OF HT BUSHING ROD
901	23-03-2026	Part of : RAWTA VILLAGE	280	Other Outage	Planned Outage	23-03-2026	14:04	23-03-2026	16:19	2:15	0.001875	REPLACEMENT OF HT BUSHING ROD
902	23-03-2026	Part of : ISSAPUR VILLAGE	16	Other Outage	Planned Outage	23-03-2026	11:08	23-03-2026	13:12	2:04	0.001722	REPLACEMENT OF HT BUSHING ROD
903	24-03-2026	Part of : MITRAON VILLAGE,KAIR VILLAGE,SUREHRA VILLAGE	1619	Other Outage	Unplanned Outage	24-03-2026	15:27	24-03-2026	15:54	0:27	0.000150	BIRDAGE
904	24-03-2026	Part of : NEHA COLONY & Z-BLOCK CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	2355	Other Outage	Planned Outage	24-03-2026	15:48	24-03-2026	16:44	0:56	0.000933	REPLACEMENT OF HT BUSHING ROD
905	24-03-2026	Part of : JHULJHULI VILLAGE	6	Other Outage	Planned Outage	24-03-2026	15:49	24-03-2026	16:47	0:58	0.000967	REPLACEMENT OF HT BUSHING ROD
906	24-03-2026	Part of : MANDHELA KALAN VILLAGE	518	Other Outage	Planned Outage	24-03-2026	15:53	24-03-2026	16:30	0:37	0.000514	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
907	24-03-2026	Part of : SARSWATI ENCLAVE GOPAL NAGAR NAJAFGARH, HAIBUTPUR, KRISHAN VIHAR NAJAFGARH	1660	Other Outage	Planned Outage	24-03-2026	15:14	24-03-2026	16:46	1:32	0.001533	REPLACEMENT OF HT BUSHING ROD
908	24-03-2026	Part of : UJWA VILLAGE	468	Other Outage	Planned Outage	24-03-2026	13:04	24-03-2026	14:42	1:38	0.001633	REPLACEMENT OF HT BUSHING ROD
909	24-03-2026	Part of : QAZIPUR VILLAGE	330	Other Outage	Planned Outage	24-03-2026	11:59	24-03-2026	14:07	2:08	0.001778	REPLACEMENT OF HT BUSHING ROD
910	25-03-2026	Part of : MANDHELA KALAN VILLAGE	335	Other Outage	Planned Outage	25-03-2026	13:36	25-03-2026	15:28	1:52	0.001556	REPLACEMENT OF HT BUSHING ROD
911	25-03-2026	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1434	Other Outage	Planned Outage	25-03-2026	14:52	25-03-2026	16:19	1:27	0.001208	REPLACEMENT OF LT BUSHING ROD
912	25-03-2026	Part of : HAIBUTPUR, BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN	3	Other Outage	Planned Outage	25-03-2026	13:58	25-03-2026	16:20	2:22	0.003156	REPLACEMENT OF HT BUSHING ROD
913	25-03-2026	Part of : SARANGPUR VILLAGE	181	Other Outage	Planned Outage	25-03-2026	12:51	25-03-2026	14:54	2:03	0.001708	REPLACEMENT OF HT BUSHING ROD
914	27-03-2026	Part of : DARYAPUR KHURD VILLAGE	2	Other Outage	Planned Outage	27-03-2026	15:35	27-03-2026	16:35	1:00	0.000833	REPLACEMENT OF HT BUSHING ROD
915	27-03-2026	Part of : SRI HANS NAGAR	529	Other Outage	Planned Outage	27-03-2026	15:01	27-03-2026	16:35	1:34	0.001567	REPLACEMENT OF HT BUSHING ROD
916	27-03-2026	Part of : KAIR VILLAGE, MANDHELA KHURD VILLAGE	1487	Other Outage	Planned Outage	27-03-2026	13:13	27-03-2026	15:02	1:49	0.001817	REPLACEMENT OF HT BUSHING ROD
917	27-03-2026	Part of : BADHOSRA	842	Other Outage	Planned Outage	27-03-2026	11:51	27-03-2026	13:16	1:25	0.001181	REPLACEMENT OF HT BUSHING ROD
918	28-03-2026	Part of : MALIKPUR ZER VILLAGE, JAFARPUR KALAN VILLAGE, SAMAZPUR KHALSA	1958	Other Outage	Unplanned Outage	28-03-2026	03:33	28-03-2026	04:29	0:56	0.000578	CABLE FAULT
919	28-03-2026	Part of : GHUMAN HERA JAINPUR VILLAGE	394	Other Outage	Planned Outage	28-03-2026	15:32	28-03-2026	16:22	0:50	0.000694	REPLACEMENT OF HT BUSHING ROD
920	28-03-2026	Part of : NEHA COLONY, BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	1053	Other Outage	Planned Outage	28-03-2026	14:32	28-03-2026	15:38	1:06	0.001100	REPLACEMENT OF HT BUSHING ROD
921	28-03-2026	Part of : BLOCK A1 VINOBHA ENCLAVE, BLOCK D BANGALI COLONY NAVEEN PALACE, BABA HARI DAS ENCLAVE JHARODA KALAN	1289	Other Outage	Planned Outage	28-03-2026	14:33	28-03-2026	15:37	1:04	0.001067	REPLACEMENT OF HT BUSHING ROD
922	28-03-2026	Part of : DHANSA VILLAGE	148	Other Outage	Planned Outage	28-03-2026	11:46	28-03-2026	13:30	1:44	0.001444	REPLACEMENT OF HT BUSHING ROD
923	30-03-2026	Part of : SUREHRA VILLAGE,	471	Other Outage	Planned Outage	30-03-2026	14:45	30-03-2026	16:11	1:26	0.000956	REPLACEMENT OF HT BUSHING ROD
924	30-03-2026	Part of : NAJAFGARH VILLAGE NAJAFGARH, PREM NAGAR GOPAL NAGAR NAJAFGARH, SHIV VIHAR COLONY GOPAL NAGAR NAJAFGARH,	445	Other Outage	Planned Outage	30-03-2026	14:44	30-03-2026	16:12	1:28	0.001467	REPLACEMENT OF HT BUSHING ROD
925	30-03-2026	Part of : RAWTA JAFARPUR KALAN VILLAGE,	1005	Other Outage	Planned Outage	30-03-2026	12:00	30-03-2026	13:59	1:59	0.001983	REPLACEMENT OF HT BUSHING ROD
926	30-03-2026	Part of : BADHOSRA,	190	Other Outage	Planned Outage	30-03-2026	11:35	30-03-2026	13:32	1:57	0.001625	REPLACEMENT OF HT BUSHING ROD
927	01-03-2026	Part of : DISTRICT CENTRE JANAK PURI	110	Other Outage	Planned Outage	01-03-2026	12:18	01-03-2026	15:08	2:50	0.000944	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT), REPLACEMENT OF LT BUSHING ROD
928	02-03-2026	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI	1204	Other Outage	Unplanned Outage	02-03-2026	11:16	02-03-2026	11:42	0:26	0.000318	CABLE FAULT
929	02-03-2026	Part of : BLOCK C3 JANAK PURI,	721	Other Outage	Planned Outage	02-03-2026	12:39	02-03-2026	14:18	1:39	0.000000	RELAY REPLACEMENT/VPI/FPI, REPLACEMENT OF FAULTY END BOX
930	02-03-2026	Part of : BLOCK A KARAN MARKET NANGAL RAYA JANAK PURI,	133	Other Outage	Planned Outage	02-03-2026	11:47	02-03-2026	13:26	1:39	0.000000	1PH DB REVAMPING, 3PH DB REVAMPING, OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE, PRC REPLACEMENT PER FEEDER
931	02-03-2026	Part of : BLOCK C1 JANAK PURI,	182	Other Outage	Planned Outage	02-03-2026	12:04	02-03-2026	14:14	2:10	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS, OIL TOP UP IN TRANSFORMER, OIL TOP UP IN TRANSFORMER, REPLACEMENT OF GAS KIT AND OIL SEAL, SUB STATION CLEANING
932	02-03-2026	Part of : HTC: BX METAL FORGING	1	Other Outage	Planned Outage	02-03-2026	12:03	02-03-2026	14:36	2:33	0.000425	AUXILIARY SUPPLY FOR RELAYS, CLEANING OF HT BUSHING PER WAY, SF6 GAS FILLING
933	02-03-2026	Part of : BLOCK J RAJOURI GARDEN EXTENSION RAJOURI GARDEN,	420	Other Outage	Planned Outage	02-03-2026	11:29	02-03-2026	14:13	2:44	0.000000	REPLACEMENT OF HT BUSHING ROD
934	02-03-2026	Part of : BLOCK G RAJOURI GARDEN,	330	Other Outage	Planned Outage	02-03-2026	11:44	02-03-2026	14:11	2:27	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL, REPLACEMENT OF HT BUSHING ROD
935	03-03-2026	Part of : M/S HARDWYN B-35 PH-I MAYAPURI (HT CONSUMER)	1	Other Outage	Planned Outage	03-03-2026	11:19	03-03-2026	12:17	0:58	0.000161	AUXILIARY SUPPLY FOR RELAYS, CLEANING OF HT BUSHING PER WAY, PROPER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
936	03-03-2026	Part of : TIHAR CENTRAL JAIL JANAK PURI	9	Other Outage	Planned Outage	03-03-2026	11:38	03-03-2026	13:02	1:24	0.000000	LT CIRCUIT MAINTENANCE
937	03-03-2026	Part of : BLOCK 1 ASHOK NAGAR	512	Other Outage	Planned Outage	03-03-2026	10:53	03-03-2026	12:13	1:20	0.000000	LT CIRCUIT MAINTENANCE
938	05-03-2026	Part of : PUNJAB STEEL (HT CONSUMER)	1	Other Outage	Planned Outage	05-03-2026	11:03	05-03-2026	12:05	1:02	0.000172	AUXILIARY SUPPLY FOR RELAYS, CLEANING OF HT BUSHING PER WAY, PROPER SEALING RMU PER WAY
939	05-03-2026	Part of : BLOCK A 4C P AND T COLONY JANAK PURI	720	Other Outage	Planned Outage	05-03-2026	11:54	05-03-2026	13:04	1:10	0.000389	REPLACEMENT OF LT BUSHING ROD, SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
940	05-03-2026	Part of : BLOCK A KARAN MARKET NANGAL RAYA JANAK PURI	936	Other Outage	Planned Outage	05-03-2026	13:00	05-03-2026	14:16	1:16	0.000422	1PH DB REVAMPING,PRC REPLACEMET PER FEEDER
941	05-03-2026	Part of : BLOCK G RAJOURI GARDEN	225	Other Outage	Planned Outage	05-03-2026	10:57	05-03-2026	13:12	2:15	0.000750	REPLACEMENT OF LT BUSHING ROD
942	06-03-2026	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI,BLOCK C 5B JANAK PURI,BLOCK C 6B JANAK PURI,BLOCK C4H JANAK PURI	2931	Other Outage	Unplanned Outage	06-03-2026	15:15	06-03-2026	16:20	1:05	0.000375	CABLE FAULT
943	06-03-2026	Part of : BLOCK S RAJOURI GARDEN,	433	Other Outage	Unplanned Outage	06-03-2026	12:48	06-03-2026	14:47	1:59	0.000331	MOBILE TRANSFORMER REPLACEMENT
944	06-03-2026	Part of : TIHAR CENTRAL JAIL JANAK PURI,	153	Other Outage	Planned Outage	06-03-2026	13:13	06-03-2026	14:45	1:32	0.000000	DT REPLACEMENT
945	06-03-2026	Part of : HTC:PLOT NO.:A-41 SSTN, PH-1, MAYAPURI	1	Other Outage	Planned Outage	06-03-2026	10:55	06-03-2026	12:33	1:38	0.000272	AUXILIARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY,SF6 GAS FILLING
946	06-03-2026	Part of : BLOCK G RAJOURI GARDEN,	267	Other Outage	Planned Outage	06-03-2026	13:14	06-03-2026	15:36	2:22	0.000000	REPLACEMENT OF LT BUSHING ROD
947	06-03-2026	Part of : BLOCK WZ PADAM BASTI NANGAL RAYA JANAK PURI,	305	Other Outage	Planned Outage	06-03-2026	12:59	06-03-2026	16:14	3:15	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
948	06-03-2026	Part of : C-4 BLOCK JANAK PURI,	314	Other Outage	Planned Outage	06-03-2026	12:07	06-03-2026	14:09	2:02	0.000000	DT REPLACEMENT
949	07-03-2026	Part of : BLOCK 4 SUBHASH NAGAR	459	Other Outage	Planned Outage	07-03-2026	15:42	07-03-2026	16:36	0:54	0.000000	LT CIRCUIT MAINTENANCE
950	07-03-2026	Part of : DTC DEPOT MAYAPURI (HT CONSUMER)	1	Other Outage	Planned Outage	07-03-2026	15:02	07-03-2026	16:28	1:26	0.000239	AUXILIARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,SF6 GAS FILLING
951	07-03-2026	Part of : DDU HOSPITAL (HT CONSUMER)	2	Other Outage	Planned Outage	07-03-2026	11:18	07-03-2026	13:30	2:12	0.000367	AUXILIARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY
952	07-03-2026	Part of : A 3-BLOCK ASALATPUR VILLAGE JANAK PURI	245	Other Outage	Planned Outage	07-03-2026	11:27	07-03-2026	13:36	2:09	0.000000	LT CIRCUIT MAINTENANCE
953	08-03-2026	Part of : S-BLOCK RAJOURI GARDEN	632	Other Outage	Unplanned Outage	08-03-2026	12:35	08-03-2026	15:38	3:03	0.001017	MOBILE TRANSFORMER REPLACEMENT
954	09-03-2026	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI,BLOCK C 5B, C4H & C6B JANAK PURI	2931	Other Outage	Unplanned Outage	09-03-2026	02:51	09-03-2026	03:50	0:59	0.000302	CABLE FAULT
955	09-03-2026	Part of : BLOCK C1 RAJOURI GARDEN	139	Other Outage	Planned Outage	09-03-2026	13:55	09-03-2026	15:51	1:56	0.000000	REPLACEMENT OF HT BUSHING ROD
956	09-03-2026	Part of : BLOCK B FATEH NAGAR	547	Other Outage	Planned Outage	09-03-2026	13:06	09-03-2026	16:39	3:33	0.001775	DT REPLACEMENT
957	10-03-2026	Part of : NANGAL VILLAGE DELHI CANTONMENT	1483	Other Outage	Unplanned Outage	10-03-2026	00:08	10-03-2026	00:36	0:28	0.000311	CABLE FAULT
958	10-03-2026	Part of : MEENAKSHI GARDEN ASHOK NAGAR,BLOCK 1 SUBHASH NAGAR,BLOCK 1 ASHOK NAGAR	2711	Other Outage	Unplanned Outage	10-03-2026	12:24	10-03-2026	13:36	1:12	0.001438	CABLE FAULT
959	10-03-2026	Part of : BLOCK B PATEL BLOCK RAGHU NAGAR DABRI,	965	Other Outage	Planned Outage	10-03-2026	12:58	10-03-2026	14:52	1:54	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
960	10-03-2026	Part of : BLOCK C4F JANAK PURI,	560	Other Outage	Planned Outage	10-03-2026	11:58	10-03-2026	13:56	1:58	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
961	10-03-2026	Part of : BLOCK S RAJOURI GARDEN,	432	Other Outage	Planned Outage	10-03-2026	12:30	10-03-2026	16:04	3:34	0.001783	DT REPLACEMENT
962	10-03-2026	Part of : BLOCK J RAJOURI GARDEN,	128	Other Outage	Planned Outage	10-03-2026	10:57	10-03-2026	13:41	2:44	0.000000	REPLACEMET OF HT BUSHING ROD
963	11-03-2026	Part of : C 5 D-BLOCK JANAK PURI	404	Other Outage	Planned Outage	11-03-2026	12:17	11-03-2026	13:35	1:18	0.000000	LT CIRCUIT MAINTENANCE
964	11-03-2026	Part of : WZ-BLOCK LAJWANTI GARDEN JANAK PURI	724	Other Outage	Planned Outage	11-03-2026	12:15	11-03-2026	17:57	5:42	0.002850	DT REPLACEMENT
965	11-03-2026	Part of : A-BLOCK RAJOURI GARDEN	230	Other Outage	Planned Outage	11-03-2026	11:15	11-03-2026	13:41	2:26	0.000000	LT CIRCUIT MAINTENANCE
966	11-03-2026	Part of : VB-BLOCK VIRENDRA NAGAR JANAK PURI	700	Other Outage	Planned Outage	11-03-2026	11:16	11-03-2026	13:33	2:17	0.000000	LT CIRCUIT MAINTENANCE
967	11-03-2026	Part of : RZ-BLOCK MOHAN NAGAR SAGARPUR MAIN	678	Other Outage	Planned Outage	11-03-2026	11:19	11-03-2026	14:24	3:05	0.000000	LT CIRCUIT MAINTENANCE
968	12-03-2026	Part of : POCKET D 1C LAJWANTI GARDEN JANAK PURI	379	Other Outage	Planned Outage	12-03-2026	13:53	12-03-2026	15:14	1:21	0.000450	LT CIRCUIT MAINTENANCE
969	12-03-2026	Part of : SWARGASHRAM HARI,BOOSTERPUMP (HT CONSUMER)	1	Other Outage	Planned Outage	12-03-2026	10:43	12-03-2026	13:08	2:25	0.000403	AUXILIARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY,SF6 GAS FILLING
970	12-03-2026	Part of : POCKET G HARI NAGAR JANAK PURI	442	Other Outage	Planned Outage	12-03-2026	12:00	12-03-2026	14:31	2:31	0.000839	LT CIRCUIT MAINTENANCE
971	12-03-2026	Part of : BLOCK 3 SUBHASH NAGAR	678	Other Outage	Planned Outage	12-03-2026	10:42	12-03-2026	13:37	2:55	0.000972	LT CIRCUIT MAINTENANCE
972	12-03-2026	Part of : C 2C-BLOCK JANAK PURI	233	Other Outage	Planned Outage	12-03-2026	11:40	12-03-2026	13:51	2:11	0.000728	LT CIRCUIT MAINTENANCE
973	13-03-2026	Part of : Q BLK RAJOURI GARDEN	0	Other Outage	Unplanned Outage	13-03-2026	11:10	13-03-2026	12:03	0:53	0.000000	CABLE FAULT
974	13-03-2026	Part of : MCD RAJOURI GARDEN	0	Other Outage	Unplanned Outage	13-03-2026	10:57	13-03-2026	12:39	1:42	0.000708	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
975	13-03-2026	Part of : F BLK RAJOURI GARDEN	0	Other Outage	Unplanned Outage	13-03-2026	10:56	13-03-2026	12:03	1:07	0.000372	CABLE FAULT
976	13-03-2026	Part of : BLOCK C3 JANAK PURI	7	Other Outage	Planned Outage	13-03-2026	12:52	13-03-2026	14:45	1:53	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
977	13-03-2026	Part of : BLOCK 3 ASHOK NAGAR	1271	Other Outage	Planned Outage	13-03-2026	10:15	13-03-2026	12:31	2:16	0.000756	1PH DB REPLACEMENT,3PH DB REVAMPING,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER
978	14-03-2026	Part of : Q BLK RAJOURI GARDEN	0	Other Outage	Unplanned Outage	14-03-2026	21:21	14-03-2026	22:15	0:54	0.000000	CABLE FAULT
979	14-03-2026	Part of : BLOCK WZ LAJWANTI GARDEN JANAK PURI,	559	Other Outage	Planned Outage	14-03-2026	13:27	14-03-2026	14:14	0:47	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
980	14-03-2026	Part of : HTC:PLOT NO.:B-90 SSTN, PH-1, MAYAPURI	1	Other Outage	Planned Outage	14-03-2026	11:03	14-03-2026	12:43	1:40	0.000278	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY,SF6 GAS FILLING
981	14-03-2026	Part of : BLOCK A 3 ASALATPUR VILLAGE JANAK PURI,	402	Other Outage	Planned Outage	14-03-2026	12:17	14-03-2026	14:39	2:22	0.000000	CONDUCTOR REPLACEMENT PER SPAN
982	14-03-2026	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI,	587	Other Outage	Planned Outage	14-03-2026	12:00	14-03-2026	15:06	3:06	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
983	14-03-2026	Part of : BLOCK 16 PRESS COLONY MAYAPURI,	302	Other Outage	Planned Outage	14-03-2026	09:44	14-03-2026	12:01	2:17	0.000000	1PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER
984	14-03-2026	Part of : BLOCK L RAJOURI GARDEN,	234	Other Outage	Planned Outage	14-03-2026	09:52	14-03-2026	12:00	2:08	0.000000	REPLACEMET OF HT BUSHING ROD
985	15-03-2026	Part of : BLOCK BB JANAK PURI,SHIV NAGAR EXTENSION JANAK PURI,BLOCK BD GURUNANAK PURA JANAK PURI	1581	Other Outage	Unplanned Outage	15-03-2026	05:57	15-03-2026	06:56	0:59	0.000524	HT SYSTEM FAULT
986	15-03-2026	Part of : BLOCK C3 RAJOURI GARDEN	178	Other Outage	Unplanned Outage	15-03-2026	10:32	15-03-2026	11:30	0:58	0.000322	TRANSFORMER REPLACEMENT
987	15-03-2026	Part of : DISTRICT CENTRE JANAK PURI	39	Other Outage	Planned Outage	15-03-2026	12:06	15-03-2026	13:51	1:45	0.000000	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
988	15-03-2026	Part of : BLOCK WZ LAJWANTI GARDEN JANAK PURI	724	Other Outage	Planned Outage	15-03-2026	12:56	15-03-2026	16:52	3:56	0.001967	DT REPLACEMENT
989	16-03-2026	Part of : N-BLOCK RAJOURI GARDEN	324	Other Outage	Planned Outage	16-03-2026	10:19	16-03-2026	11:37	1:18	0.000433	LT CIRCUIT MAINTENANCE
990	16-03-2026	Part of : G-BLOCK RAJOURI GARDEN	267	Other Outage	Planned Outage	16-03-2026	13:37	16-03-2026	17:19	3:42	0.001850	DT REPLACEMENT
991	16-03-2026	Part of : B-BLOCK FATEH NAGAR	547	Other Outage	Planned Outage	16-03-2026	12:51	16-03-2026	16:35	3:44	0.001867	DT REPLACEMENT
992	16-03-2026	Part of : POCKET B 1 B 1 MARKET SUPER BAZAR JANAK PURI	465	Other Outage	Planned Outage	16-03-2026	11:42	16-03-2026	14:32	2:50	0.000944	LT CIRCUIT MAINTENANCE
993	16-03-2026	Part of : C 4H-BLOCK JANAK PURI	226	Other Outage	Planned Outage	16-03-2026	11:33	16-03-2026	13:41	2:08	0.000711	LT CIRCUIT MAINTENANCE
994	17-03-2026	Part of : BLOCK- 15 & 16 PRESS COLONY MAYAPURI	2287	Other Outage	Unplanned Outage	17-03-2026	13:00	17-03-2026	14:23	1:23	0.001228	CABLE FAULT
995	17-03-2026	Part of : NARANG COLONY CHANDAR NAGAR JANAK PURI,BLOCK A 3 ASALATPUR VILLAGE JANAK PURI,BLOCK A 4C AND T COLONY JANAK PURI	761	Other Outage	Unplanned Outage	17-03-2026	04:21	17-03-2026	05:35	1:14	0.000449	CABLE FAULT
996	17-03-2026	Part of : BLOCK WZ NANGAL RAYA JANAK PURI	786	Other Outage	Planned Outage	17-03-2026	13:45	17-03-2026	14:45	1:00	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
997	17-03-2026	Part of : DELHI HOSPITALITY (HT CONSUMER)	1	Other Outage	Planned Outage	17-03-2026	10:44	17-03-2026	12:27	1:43	0.000286	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY
998	17-03-2026	Part of : BLOCK G RAJOURI GARDEN	321	Other Outage	Planned Outage	17-03-2026	12:21	17-03-2026	16:11	3:50	0.001917	DT REPLACEMENT
999	17-03-2026	Part of : BLOCK C 6A JANAK PURI	168	Other Outage	Planned Outage	17-03-2026	11:52	17-03-2026	14:29	2:37	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
1000	17-03-2026	Part of : BLOCK R RAJOURI GARDEN	427	Other Outage	Planned Outage	17-03-2026	10:26	17-03-2026	13:01	2:35	0.000000	REPLACEMENT OF HT BUSHING ROD
1001	18-03-2026	Part of : BLOCK A 2B ASALATPUR VILLAGE JANAK PURI,BLOCK A 3 ASALATPUR VILLAGE JANAK PURI,CHANDAR NAGAR JANAK PURI,BLOCK A 2 ASALATPUR VILLAGE JANAK PURI	3009	Other Outage	Unplanned Outage	18-03-2026	20:36	18-03-2026	21:28	0:52	0.001242	CABLE FAULT
1002	18-03-2026	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	451	Other Outage	Unplanned Outage	18-03-2026	19:15	18-03-2026	21:16	2:01	0.002571	CABLE FAULT
1003	18-03-2026	Part of : BLOCK J RAJOURI GARDEN,	280	Other Outage	Unplanned Outage	18-03-2026	11:00	18-03-2026	13:01	2:01	0.001008	LAYING OF NEW LTAB
1004	18-03-2026	Part of : BLOCK S RAJOURI GARDEN,	430	Other Outage	Planned Outage	18-03-2026	10:18	18-03-2026	12:08	1:50	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1005	18-03-2026	Part of : HTC:MTNL HARINAGAR	1	Other Outage	Planned Outage	18-03-2026	11:02	18-03-2026	15:14	4:12	0.000700	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY,SF6 GAS FILLING
1006	18-03-2026	Part of : BLOCK D MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	728	Other Outage	Planned Outage	18-03-2026	11:34	18-03-2026	14:18	2:44	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1007	18-03-2026	Part of : BLOCK C 6B JANAK PURI,	700	Other Outage	Planned Outage	18-03-2026	12:04	18-03-2026	14:11	2:07	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1008	19-03-2026	Part of : POCKET G HARI NAGAR JANAK PURI	259	Other Outage	Planned Outage	19-03-2026	13:07	19-03-2026	14:17	1:10	0.000000	LT CIRCUIT MAINTENANCE
1009	19-03-2026	Part of : WZ-BLOCK RC BASTI NANGAL RAYA JANAK PURI	843	Other Outage	Planned Outage	19-03-2026	12:00	19-03-2026	13:46	1:46	0.000000	LT CIRCUIT MAINTENANCE
1010	19-03-2026	Part of : C 1A-BLOCK JANAK PURI	365	Other Outage	Planned Outage	19-03-2026	11:51	19-03-2026	13:50	1:59	0.000000	LT CIRCUIT MAINTENANCE
1011	20-03-2026	Part of : BLOCK 4,5,6 SUBHASH NAGAR,J & J 9-BLOCK RAJOURI GARDEN EXTENSION	3386	Other Outage	Planned Outage	20-03-2026	10:55	20-03-2026	13:00	2:05	0.000694	LT CIRCUIT MAINTENANCE
1012	21-03-2026	Part of : BLOCK G,J,R & S RAJOURI GARDEN	1452	Other Outage	Unplanned Outage	21-03-2026	15:33	21-03-2026	16:13	0:40	0.000341	CABLE FAULT
1013	21-03-2026	Part of : SUBHASH NAGAR JANAKPURI	1743	Other Outage	Unplanned Outage	21-03-2026	01:03	21-03-2026	01:59	0:56	0.000239	CABLE FAULT
1014	22-03-2026	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	410	Other Outage	Unplanned Outage	22-03-2026	08:03	22-03-2026	08:53	0:50	0.000315	BIRDAGE
1015	23-03-2026	Part of : HOMTEL H.NGR (HT CONSUMER)	1	Other Outage	Planned Outage	23-03-2026	12:50	23-03-2026	14:22	1:32	0.000256	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY,SF6 GAS FILLING
1016	23-03-2026	Part of : POCKET D2A NANGAL RAYA JANAK PURI	451	Other Outage	Planned Outage	23-03-2026	14:58	23-03-2026	16:46	1:48	0.000000	LT CIRCUIT MAINTENANCE
1017	23-03-2026	Part of : C 2C-BLOCK JANAK PURI	85	Other Outage	Planned Outage	23-03-2026	11:48	23-03-2026	14:07	2:19	0.000000	LT CIRCUIT MAINTENANCE
1018	24-03-2026	Part of : A & B-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-1	452	Other Outage	Unplanned Outage	24-03-2026	15:54	24-03-2026	16:21	0:27	0.000375	HT SYSTEM FAULT
1019	24-03-2026	Part of : G-BLOCK RAJOURI GARDEN	276	Other Outage	Unplanned Outage	24-03-2026	09:46	24-03-2026	11:42	1:56	0.000644	INSTALLATION OF TRANSFORMER
1020	24-03-2026	Part of : SWGR A-42 MAYAPURI PH-2 (HT CONSUMER)	1	Other Outage	Planned Outage	24-03-2026	11:28	24-03-2026	12:31	1:03	0.000175	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,PROPER SEALING RMU PER WAY,SF6 GAS FILLING
1021	24-03-2026	Part of : RZ-BLOCK MOHAN NAGAR SAGARPUR MAIN	1082	Other Outage	Planned Outage	24-03-2026	13:02	24-03-2026	14:55	1:53	0.000628	LT CIRCUIT MAINTENANCE
1022	24-03-2026	Part of : SHIV NAGAR JANAK PURI	442	Other Outage	Planned Outage	24-03-2026	12:52	24-03-2026	15:03	2:11	0.000728	LT CIRCUIT MAINTENANCE
1023	24-03-2026	Part of : TIHAR CENTRAL JAIL JANAK PURI	154	Other Outage	Planned Outage	24-03-2026	11:30	24-03-2026	13:51	2:21	0.000783	LT CIRCUIT MAINTENANCE
1024	25-03-2026	Part of : SWGR C-7 (HT CONSUMER) MAYAPURI PH-2	1	Other Outage	Planned Outage	25-03-2026	10:17	25-03-2026	12:27	2:10	0.000361	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY
1025	26-03-2026	Part of : NARANG COLONY CHANDAR NAGAR JANAK PURI,BLOCK A 3 ASALATPUR VILLAGE JANAK PURI,BLOCK A 4C P AND T COLONY JANAK PURI	761	Other Outage	Unplanned Outage	26-03-2026	04:51	26-03-2026	05:45	0:54	0.000190	CABLE FAULT
1026	27-03-2026	Part of : A 3-BLOCK ASALATPUR VILLAGE JANAK PURI	251	Other Outage	Planned Outage	27-03-2026	13:34	27-03-2026	14:54	1:20	0.000000	RELAY REPLACEMENT/VPI/FPI
1027	27-03-2026	Part of : POSSANGIPUR VILLAGE JANAK PURI	424	Other Outage	Planned Outage	27-03-2026	12:42	27-03-2026	16:27	3:45	0.000000	DT REPLACEMENT
1028	27-03-2026	Part of : C 3-BLOCK ANAK PURI	169	Other Outage	Planned Outage	27-03-2026	11:54	27-03-2026	14:04	2:10	0.000000	LT CIRCUIT MAINTENANCE
1029	28-03-2026	Part of : KHAJAN BASTI, PUMPING STATION DELHI CANT (HTC)	0	Other Outage	Unplanned Outage	28-03-2026	10:14	28-03-2026	10:41	0:27	0.000203	CABLE FAULT
1030	28-03-2026	Part of : BLOCK A 2B ASALATPUR VILLAGE, DISTRICT CENTRE JANAK PURI,BLOCK A-1 & A1/A JANAK PURI	2097	Other Outage	Unplanned Outage	28-03-2026	13:30	28-03-2026	14:22	0:52	0.000367	CABLE FAULT
1031	28-03-2026	Part of : MCKENZIE PHILIP C-97 MAYAPURI PH-II (HTC)	1	Other Outage	Planned Outage	28-03-2026	14:47	28-03-2026	16:18	1:31	0.000253	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,SF6 GAS FILLING
1032	28-03-2026	Part of : BLOCK C 2D JANAK PURI	96	Other Outage	Planned Outage	28-03-2026	12:05	28-03-2026	14:08	2:03	0.000683	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
1033	30-03-2026	Part of : ADITI APARTMENTS JANAK PURI,	349	Other Outage	Planned Outage	30-03-2026	13:08	30-03-2026	14:26	1:18	0.000000	1PH DB REVAMPING,3PH DB REVAMPING
1034	30-03-2026	Part of : BLOCK WZ LAJWANTI GARDEN JANAK PURI,	730	Other Outage	Planned Outage	30-03-2026	12:56	30-03-2026	16:07	3:11	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1035	31-03-2026	Part of : BLOCK B 2B JANAK PURI,PREM NAGAR JANAK PURI,HARI NAGAR PARK HARI NAGAR,BLOCK C MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	1401	Other Outage	Unplanned Outage	31-03-2026	19:54	31-03-2026	20:41	0:47	0.000899	CABLE FAULT
1036	31-03-2026	Part of : TRANSPORT DEPARTMENT HARI NAGAR (HTC)	1	Other Outage	Planned Outage	31-03-2026	13:01	31-03-2026	14:07	1:06	0.000183	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,SF6 GAS FILLING
1037	01-03-2026	Part of : MUNDKA INDUSTRIAL AREA	110	Other Outage	Planned Outage	01-03-2026	13:51	01-03-2026	16:12	2:21	0.002350	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1038	01-03-2026	Part of : LAXMI PARK COLONY,MUNDKA EXTENSION,AMAR COLONY,JAI VIHAR KAMARUDDIN NAGAR	6041	Other Outage	Planned Outage	01-03-2026	10:29	01-03-2026	13:23	2:54	0.001450	REPLACEMET OF HT BUSHING ROD
1039	01-03-2026	Part of : MUNDKA EXTENSION	8	Other Outage	Planned Outage	01-03-2026	10:30	01-03-2026	13:25	2:55	0.001458	REPLACEMENT OF GAS KIT AND OIL SEAL
1040	02-03-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,RANHOLLA,	4718	Other Outage	Unplanned Outage	02-03-2026	10:22	02-03-2026	12:08	1:46	0.000000	REPLACEMENT OF DAMAGE POLE
1041	02-03-2026	Part of : RATAN BAGH NANGLOI,	1194	Other Outage	Planned Outage	02-03-2026	11:28	02-03-2026	14:11	2:43	0.001358	REPLACEMET OF HT BUSHING ROD
1042	02-03-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,	659	Other Outage	Planned Outage	02-03-2026	11:13	02-03-2026	13:40	2:27	0.000817	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1043	03-03-2026	Part of : MUNDKA EXTENSION	8	Other Outage	Planned Outage	03-03-2026	17:03	03-03-2026	17:39	0:36	0.000100	REPLACEMENT OF GAS KIT AND OIL SEAL
1044	03-03-2026	Part of : VEENA ENCLAVE MUNDKA	63	Other Outage	Planned Outage	03-03-2026	13:43	03-03-2026	15:36	1:53	0.000471	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1045	03-03-2026	Part of : SAVITA VIHAR,C-BLOCK MUNDKA,FRIENDS COLONY	2861	Other Outage	Planned Outage	03-03-2026	13:44	03-03-2026	15:35	1:51	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1046	03-03-2026	Part of : AAKASH VIHAR	860	Other Outage	Planned Outage	03-03-2026	12:09	03-03-2026	13:38	1:29	0.000494	REPLACEMENT OF GAS KIT AND OIL SEAL
1047	05-03-2026	Part of : BABA HARIDAS NAGAR TIKRI KALAN	53	Other Outage	Planned Outage	05-03-2026	11:54	05-03-2026	13:34	1:40	0.000417	REPLACEMENT OF GAS KIT AND OIL SEAL
1048	06-03-2026	Part of : TYAGI COLONY NANGLOI EXTENSION NANGLOI,RAJENDRA PARK EXTENSION NANGLOI EXTENSION NANGLOI,RAJENDRA PARK NANGLOI EXTENSION NANGLOI,BLOCK A 1 NANGLOI EXTENSION NANGLOI,JOHAR VILLAGE NANGLOI EXTENSION NANGLOI,	1091	Other Outage	Planned Outage	06-03-2026	13:43	06-03-2026	16:32	2:49	0.000939	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1049	06-03-2026	Part of : HTC:BPS, DJB, SWARNPARK,MUNDKA	1	Other Outage	Planned Outage	06-03-2026	11:18	06-03-2026	13:42	2:24	0.000400	SUB STATION CLEANING
1050	06-03-2026	Part of : LOKNAYAK PURAM BAKARWALA,POCKET A LOKNAYAK PURAM BAKARWALA,POCKET B1 LOKNAYAK PURAM BAKARWALA,POCKET D LOKNAYAK PURAM BAKARWALA,POCKET C LOKNAYAK PURAM BAKARWALA,TILANGPUR KOTLA,POCKET B2 LOKNAYAK PURAM BAKARWALA,JJ COLONY BAKARWALA,HIRAN KUDNA,	4379	Other Outage	Planned Outage	06-03-2026	10:52	06-03-2026	13:40	2:48	0.000933	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1051	07-03-2026	Part of : RANHOLLA RADAR	1	Other Outage	Planned Outage	07-03-2026	14:00	07-03-2026	15:10	1:10	0.000389	REPLACEMENT OF GAS KIT AND OIL SEAL
1052	07-03-2026	Part of : AMAR COLONY NANGLOI EXTENSION	893	Other Outage	Planned Outage	07-03-2026	13:30	07-03-2026	15:09	1:39	0.000550	REPLACEMENT OF GAS KIT AND OIL SEAL
1053	08-03-2026	Part of : MUNDKA INDUSTRIAL AREA	31	Other Outage	Planned Outage	08-03-2026	16:33	08-03-2026	17:27	0:54	0.000450	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1054	09-03-2026	Part of : JAI VIHAR KAMARUDDIN NAGAR	329	Other Outage	Planned Outage	09-03-2026	10:20	09-03-2026	12:00	1:40	0.000833	REPLACEMENT OF LT BUSHING ROD
1055	09-03-2026	Part of : JOHAR VILLAGE NANGLOI EXTENSION	251	Other Outage	Planned Outage	09-03-2026	12:54	09-03-2026	15:07	2:13	0.002586	REPLACEMENT OF GAS KIT AND OIL SEAL
1056	09-03-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	657	Other Outage	Planned Outage	09-03-2026	12:55	09-03-2026	15:08	2:13	0.003325	REPLACEMENT OF LT BUSHING ROD
1057	10-03-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	7	Other Outage	Planned Outage	10-03-2026	10:51	10-03-2026	12:38	1:47	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1058	11-03-2026	Part of : 2A,2B,2D & D-BLOCK NANGLOI EXTENSION,RAJENDRA PARK EXTENSION	2565	Other Outage	Planned Outage	11-03-2026	12:19	11-03-2026	14:00	1:41	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1059	12-03-2026	Part of : MUNDKA EXTENSION	2	Other Outage	Planned Outage	12-03-2026	15:27	12-03-2026	16:59	1:32	0.000511	REPLACEMENT OF GAS KIT AND OIL SEAL
1060	13-03-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA	25	Other Outage	Planned Outage	13-03-2026	15:22	13-03-2026	16:40	1:18	0.000217	REPLACEMENT OF HT BUSHING ROD
1061	13-03-2026	Part of : SAVITA VIHAR MUNDKA	816	Other Outage	Planned Outage	13-03-2026	13:23	13-03-2026	15:37	2:14	0.000744	REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						Remarks
						From		To		Duration	Unservd (MU) due to outage	
						Date	Time	Date	Time			
1062	13-03-2026	Part of : MUNDKA EXTENSION	842	Other Outage	Planned Outage	13-03-2026	13:24	13-03-2026	15:38	2:14	0.002047	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
1063	13-03-2026	Part of : RANHOLLA RADAR	1	Other Outage	Planned Outage	13-03-2026	11:34	13-03-2026	14:03	2:29	0.002690	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1064	13-03-2026	Part of : BLOCK A NANGLOI EXTENSION NANGLOI,BLOCK N AMAR COLONY NANGLOI EXTENSION NANGLOI,AMAR COLONY NANGLOI EXTENSION NANGLOI	5352	Other Outage	Planned Outage	13-03-2026	11:19	13-03-2026	13:25	2:06	0.001750	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
1065	14-03-2026	Part of : BAKKARWALA VILLAGE BAKARWALA,	567	Other Outage	Unplanned Outage	14-03-2026	15:04	14-03-2026	16:03	0:59	0.000000	ATTENDING WEAK POINTS/HOT SPOT
1066	14-03-2026	Part of : BAKKARWALA VILLAGE BAKARWALA,	567	Other Outage	Unplanned Outage	14-03-2026	14:24	14-03-2026	15:02	0:38	0.000000	ATTENDING WEAK POINTS/HOT SPOT
1067	14-03-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	32	Other Outage	Planned Outage	14-03-2026	15:24	14-03-2026	16:59	1:35	0.000528	REPLACEMENT OF GAS KIT AND OIL SEAL
1068	14-03-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,BLOCK A NANGLOI EXTENSION NANGLOI,MUNDKA EXTENSION MUNDKA,AMAR COLONY NANGLOI EXTENSION NANGLOI,BLOCK N AMAR COLONY NANGLOI EXTENSION NANGLOI,JAI VIHAR KAMARUDDIN NAGAR,	6056	Other Outage	Planned Outage	14-03-2026	15:23	14-03-2026	17:00	1:37	0.000539	REPLACEMET OF FAULTY END BOX
1069	15-03-2026	Part of : DJB, NAJAFGARH ROAD	0	Other Outage	Unplanned Outage	15-03-2026	06:39	15-03-2026	07:18	0:39	0.000022	CABLE FAULT
1070	15-03-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,MUNDKA EXTENSION MUNDKA,BLOCK C MUNDKA,MUNDKA VILLAGE MUNDKA,FRIENDS COLONY MUNDKA	2985	Other Outage	Unplanned Outage	15-03-2026	06:18	15-03-2026	06:59	0:41	0.000496	CABLE FAULT
1071	15-03-2026	Part of : VEENA ENCLAVE MUNDKA	72	Other Outage	Unplanned Outage	15-03-2026	06:06	15-03-2026	06:44	0:38	0.000019	CABLE FAULT
1072	15-03-2026	Part of : BLOCK B MUNDKA,SAVITA VIHAR MUNDKA,FRIENDS COLONY MUNDKA,BLOCK C MUNDKA,BLOCK D MUNDKA	4634	Other Outage	Unplanned Outage	15-03-2026	06:06	15-03-2026	06:42	0:36	0.000014	CABLE FAULT
1073	15-03-2026	Part of : WEST CABIN BLOCK MUNDKA,GULSHAN PARK WEST CABIN BLOCK MUNDKA	842	Other Outage	Planned Outage	15-03-2026	13:02	15-03-2026	14:17	1:15	0.000208	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1074	15-03-2026	Part of : WEST CABIN BLOCK MUNDKA,VEENA ENCLAVE WEST CABIN BLOCK MUNDKA,GULSHAN PARK WEST CABIN BLOCK MUNDKA	4547	Other Outage	Planned Outage	15-03-2026	12:59	15-03-2026	14:18	1:19	0.000219	REPLACEMENT OF FAULTY END BOX
1075	15-03-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,NETAJI SUBHASH VIHAR MUNDKA,HIRAN KUDNA	342	Other Outage	Planned Outage	15-03-2026	10:39	15-03-2026	12:35	1:56	0.000322	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1076	17-03-2026	Part of : TYAGI VIHAR MUNDKA	1	Other Outage	Planned Outage	17-03-2026	10:43	17-03-2026	12:13	1:30	0.000250	REPLACEMENT OF GAS KIT AND OIL SEAL
1077	17-03-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,MUNDKA VILLAGE	2319	Other Outage	Planned Outage	17-03-2026	12:09	17-03-2026	15:41	3:32	0.002356	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1078	18-03-2026	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	1147	Other Outage	Unplanned Outage	18-03-2026	21:03	18-03-2026	21:44	0:41	0.000389	CABLE FAULT
1079	18-03-2026	Part of : TIKRI KALAN,NEELWAL VILLAGE	1489	Other Outage	Unplanned Outage	18-03-2026	18:51	18-03-2026	19:27	0:36	0.000329	TRANSIENT FAULT
1080	18-03-2026	Part of : MUNDKA EXTENSION MUNDKA,	88	Other Outage	Planned Outage	18-03-2026	12:18	18-03-2026	14:10	1:52	0.000622	GUARD WIRE LACS INSTALLTION PER SPAN
1081	18-03-2026	Part of : TYAGI COLONY NANGLOI EXTENSION NANGLOI,RAJENDRA PARK EXTENSION NANGLOI EXTENSION NANGLOI,RAJENDRA PARK NANGLOI EXTENSION NANGLOI,BLOCK A 1 NANGLOI EXTENSION NANGLOI,JOHAR VILLAGE NANGLOI EXTENSION NANGLOI,	1091	Other Outage	Planned Outage	18-03-2026	12:22	18-03-2026	13:52	1:30	0.000750	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1082	19-03-2026	Part of : POCKET A & D LOKNAYAK PURAM BAKARWALA,MUNDKA INDUSTRIAL AREA MUNDKA,HIRAN KUDNA	962	Other Outage	Unplanned Outage	19-03-2026	16:31	19-03-2026	16:56	0:25	0.000079	HVDS FAULT
1083	19-03-2026	Part of : A-BLOCK JJ COLONY 2 NANGLOI	1510	Other Outage	Planned Outage	19-03-2026	14:24	19-03-2026	15:37	1:13	0.000304	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
1084	20-03-2026	Part of : NEW PVC MARKET TIKRI KALAN,NETAJI SUBHASH VIHAR MUNDKA	340	Other Outage	Planned Outage	20-03-2026	16:13	20-03-2026	17:31	1:18	0.000433	REPLACEMENT OF GAS KIT AND OIL SEAL
1085	20-03-2026	Part of : 2A,2B,D,2D & 4ABC-BLOCK NANGLOI EXTENSION,RAJENDRA PARK EXTENSION,C & D-BLOCK JJ COLONY 2 NANGLOI	7172	Other Outage	Planned Outage	20-03-2026	13:10	20-03-2026	15:10	2:00	0.000667	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1086	21-03-2026	Part of : POCKET A LOKNAYAK PURAM BAKARWALA	221	Other Outage	Planned Outage	21-03-2026	15:14	21-03-2026	16:11	0:57	0.000158	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1087	22-03-2026	Part of : BLOCK C MUNDKA,MUNDKA EXTENSION MUNDKA,SAVITA VIHAR MUNDKA,	886	Other Outage	Planned Outage	22-03-2026	12:40	22-03-2026	15:34	2:54	0.000483	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1088	22-03-2026	Part of : BLOCK C TYAGI VIHAR MUNDKA,VEENA ENCLAVE MUNDKA,MUNDKA INDUSTRIAL AREA MUNDKA,WEST CABIN BLOCK MUNDKA,BLOCK B TYAGI VIHAR MUNDKA,BLOCK A TYAGI VIHAR MUNDKA,TYAGI VIHAR MUNDKA,NETAJI SUBHASH VIHAR MUNDKA.	3048	Other Outage	Planned Outage	22-03-2026	11:27	22-03-2026	13:59	2:32	0.001689	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1089	23-03-2026	Part of : RANHOLLA	241	Other Outage	Planned Outage	23-03-2026	12:34	23-03-2026	15:24	2:50	0.001417	REPLACEMENT OF GAS KIT AND OIL SEAL
1090	24-03-2026	Part of : A,B & C-BLOCK TYAGI VIHAR,VEENA ENCLAVE,MUNDKA INDUSTRIAL AREA,WEST CABIN BLOCK MUNDKA,NETAJI SUBHASH VIHAR	2964	Other Outage	Unplanned Outage	24-03-2026	21:00	24-03-2026	21:32	0:32	0.000000	CABLE FAULT
1091	24-03-2026	Part of : BLOCK A1,2D & 1B NANGLOI EXTENSION,RAJENDRA PARK,TYAGI COLONY,RAJENDRA PARK EXTENSION,B-BLOCK YADAV PARK,RATAN BAGH NANGLOI,JOHAR VILLAGE	5083	Other Outage	Unplanned Outage	24-03-2026	07:51	24-03-2026	08:37	0:46	0.000993	CABLE FAULT
1092	24-03-2026	Part of : BANI AIR FORCE CAMP JAI VIHAR BAPROLA	755	Other Outage	Planned Outage	24-03-2026	12:33	24-03-2026	14:23	1:50	0.000611	REPLACEMENT OF GAS KIT AND OIL SEAL
1093	24-03-2026	Part of : MUNDKA INDUSTRIAL AREA	19	Other Outage	Planned Outage	24-03-2026	11:28	24-03-2026	14:07	2:39	0.000883	REPLACEMENT OF GAS KIT AND OIL SEAL
1094	25-03-2026	Part of : BLOCK B,C & D MUNDKA,FRIENDS COLONY MUNDKA	4646	Other Outage	Unplanned Outage	25-03-2026	10:54	25-03-2026	12:27	1:33	0.000000	ATTENDING WEAK POINTS/HOT SPOT
1095	25-03-2026	Part of : BLOCK 2C NANGLOI EXTENSION	215	Other Outage	Planned Outage	25-03-2026	12:21	25-03-2026	14:41	2:20	0.001556	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1096	26-03-2026	Part of : VEENA ENCLAVE MUNDKA,	306	Other Outage	Planned Outage	26-03-2026	15:12	26-03-2026	15:52	0:40	0.000333	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1097	26-03-2026	Part of : SAVITA VIHAR MUNDKA,	40	Other Outage	Planned Outage	26-03-2026	14:26	26-03-2026	15:51	1:25	0.000236	REPLACEMENT OF HT BUSHING ROD
1098	26-03-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,MUNDKA VILLAGE MUNDKA,	2319	Other Outage	Planned Outage	26-03-2026	13:12	26-03-2026	14:30	1:18	0.000867	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1099	27-03-2026	Part of : MUNDKA EXTENSION	347	Other Outage	Planned Outage	27-03-2026	15:48	27-03-2026	16:39	0:51	0.000213	REPLACEMENT OF GAS KIT AND OIL SEAL
1100	27-03-2026	Part of : TILANGPUR KOTLA	1330	Other Outage	Planned Outage	27-03-2026	11:43	27-03-2026	12:48	1:05	0.000271	REPLACEMENT OF GAS KIT AND OIL SEAL
1101	27-03-2026	Part of : MUNDKA INDUSTRIAL AREA,NETAJI SUBHASH VIHAR	216	Other Outage	Planned Outage	27-03-2026	10:49	27-03-2026	12:48	1:59	0.000496	REPLACEMENT OF GAS KIT AND OIL SEAL
1102	27-03-2026	Part of : 4 ABC-BLOCK NANGLOI EXTENSION	2137	Other Outage	Planned Outage	27-03-2026	12:46	27-03-2026	15:47	3:01	0.001006	REPLACEMENT OF GAS KIT AND OIL SEAL
1103	28-03-2026	Part of : NETAJI SUBHASH VIHAR MUNDKA	1	Other Outage	Planned Outage	28-03-2026	12:34	28-03-2026	14:37	2:03	0.000683	GUARD WIRE LACS INSTALLTION PER SPAN
1104	29-03-2026	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,NETAJI SUBHASH VIHAR MUNDKA	216	Other Outage	Planned Outage	29-03-2026	10:23	29-03-2026	12:08	1:45	0.000875	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1105	31-03-2026	Part of : MUNDKA EXTENSION	37	Other Outage	Unplanned Outage	31-03-2026	20:55	31-03-2026	21:36	0:41	0.001082	CABLE FAULT
1106	31-03-2026	Part of : NAJAFGARH ROAD MUNDKA	0	Other Outage	Unplanned Outage	31-03-2026	17:18	31-03-2026	18:10	0:52	0.000000	CABLE FAULT
1107	31-03-2026	Part of : HIRAN KUDNA	492	Other Outage	Planned Outage	31-03-2026	13:14	31-03-2026	14:24	1:10	0.000389	REPLACEMENT OF HT BUSHING ROD
1108	02-03-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,NAWADA EXTENSION NAWADA,BLOCK A MAHAVIR ENCLAVE NAWADA,BLOCK K 5 ZAILDAR ENCLAVE HASTSAL,BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK B BHAGWATI GARDEN NAWADA	5934	Other Outage	Unplanned Outage	02-03-2026	15:01	02-03-2026	15:54	0:53	0.000000	BIRDAGE
1109	02-03-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	55	Other Outage	Planned Outage	02-03-2026	15:25	02-03-2026	16:29	1:04	0.000000	3PH DB REPLACEMENT
1110	02-03-2026	Part of : JAI BHARAT ENCLAVE BHAGWATI GARDEN NAWADA,	909	Other Outage	Planned Outage	02-03-2026	15:30	02-03-2026	16:30	1:00	0.000000	DT REPLACEMENT PER DT
1111	02-03-2026	Part of : PHASE 2 OM VIHAR NAWADA,	980	Other Outage	Planned Outage	02-03-2026	12:14	02-03-2026	14:32	2:18	0.000767	REPLACEMENT OF LT BUSHING ROD
1112	03-03-2026	Part of : H-BLOCK BHAGWATI GARDEN,LAXMI VIHAR NAWADA	1484	Other Outage	Planned Outage	03-03-2026	11:28	03-03-2026	14:01	2:33	0.000000	DT REPLACEMENT PER DT
1113	03-03-2026	Part of : S,R & R1-BLOCK MOHAN GARDEN RAZAPUR KHURD	2101	Other Outage	Planned Outage	03-03-2026	11:17	03-03-2026	13:59	2:42	0.000450	3PH HT AB CABLE REPLACEMENT
1114	03-03-2026	Part of : NAWADA EXTENSION	659	Other Outage	Planned Outage	03-03-2026	11:34	03-03-2026	13:49	2:15	0.000000	LT CIRCUIT MAINTENANCE
1115	05-03-2026	Part of : BHAGWATI GARDEN EXTENSION NAWADA	1771	Other Outage	Planned Outage	05-03-2026	11:02	05-03-2026	13:55	2:53	0.000000	DT REPLACEMENT PER DT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1116	05-03-2026	Part of : BLOCK R 1 & N 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK S MOHAN GARDEN RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL	2927	Other Outage	Planned Outage	05-03-2026	11:07	05-03-2026	13:46	2:39	0.000442	3PH HT AB CABLE REPLACEMENT PER SPAN
1117	06-03-2026	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,	2278	Other Outage	Planned Outage	06-03-2026	15:43	06-03-2026	16:45	1:02	0.000689	3PH HT AB CABLE REPLACEMENT PER SPAN
1118	06-03-2026	Part of : PHASE 1 OM VIHAR NAWADA,	2027	Other Outage	Planned Outage	06-03-2026	12:06	06-03-2026	13:58	1:52	0.000000	REPLACEMET OF FAULTY END BOX
1119	06-03-2026	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD,	836	Other Outage	Planned Outage	06-03-2026	12:25	06-03-2026	13:59	1:34	0.000522	REPLACEMENT OF LT BUSHING ROD
1120	06-03-2026	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA,	1141	Other Outage	Planned Outage	06-03-2026	11:45	06-03-2026	14:00	2:15	0.000000	3PH DB REPLACEMENT
1121	07-03-2026	Part of : R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	906	Other Outage	Planned Outage	07-03-2026	16:23	07-03-2026	17:43	1:20	0.000222	3PH HT AB CABLE REPLACEMENT
1122	07-03-2026	Part of : NAWADA EXTENSION	2147	Other Outage	Planned Outage	07-03-2026	11:47	07-03-2026	14:24	2:37	0.000872	3PH HT AB CABLE REPLACEMENT
1123	07-03-2026	Part of : RAZAPUR KHURD	1064	Other Outage	Planned Outage	07-03-2026	12:10	07-03-2026	14:23	2:13	0.000369	3PH DB REPLACEMENT
1124	07-03-2026	Part of : D & H-BLOCK BHAGWATI GARDEN NAWADA	1575	Other Outage	Planned Outage	07-03-2026	11:26	07-03-2026	13:32	2:06	0.001400	3PH HT AB CABLE REPLACEMENT
1125	09-03-2026	Part of : RAZA PUR KHURD VIKAS NAGAR,BLOCK WE & RK MOHAN GARDEN RAZAPUR KHURD	2321	Other Outage	Unplanned Outage	09-03-2026	12:54	09-03-2026	14:03	1:09	0.000958	REPAIRING OF RMU
1126	09-03-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL	542	Other Outage	Planned Outage	09-03-2026	15:20	09-03-2026	16:00	0:40	0.000000	3PH DB REPLACEMENT
1127	09-03-2026	Part of : BLOCK H BHAGWATI GARDEN NAWADA,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	8	Other Outage	Planned Outage	09-03-2026	12:17	09-03-2026	14:54	2:37	0.000000	DT REPLACEMENT PER DT
1128	09-03-2026	Part of : RAZAPUR KHURD,BLOCK N 2 & N 3 MOHAN GARDEN RAZAPUR KHURD	920	Other Outage	Planned Outage	09-03-2026	11:43	09-03-2026	13:57	2:14	0.000372	3PH HT AB CABLE REPLACEMENT PER SPAN
1129	09-03-2026	Part of : PHASE 5 OM VIHAR HASTSAL	752	Other Outage	Planned Outage	09-03-2026	11:29	09-03-2026	13:48	2:19	0.000000	REPLACEMENT OF FAULTY END BOX
1130	10-03-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA,JAI BHARAT ENCLAVE BHAGWATI GARDEN NAWADA,ROSHAN GARDEN BHAGWATI GARDEN NAWADA,	3041	Other Outage	Unplanned Outage	10-03-2026	13:50	10-03-2026	15:31	1:41	0.000000	REPAIR OF LT CIRCUIT
1131	10-03-2026	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,RAZAPUR KHURD,	1776	Other Outage	Planned Outage	10-03-2026	15:17	10-03-2026	16:07	0:50	0.000139	3PH HT AB CABLE REPLACEMENT PER SPAN
1132	10-03-2026	Part of : NAWADA EXTENSION NAWADA,	1345	Other Outage	Planned Outage	10-03-2026	14:32	10-03-2026	16:05	1:33	0.000000	REPLACEMENT OF LT BUSHING ROD
1133	10-03-2026	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,	2274	Other Outage	Planned Outage	10-03-2026	11:39	10-03-2026	16:04	4:25	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1134	10-03-2026	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD,	836	Other Outage	Planned Outage	10-03-2026	11:36	10-03-2026	13:48	2:12	0.000733	REPLACEMET OF HT BUSHING ROD
1135	11-03-2026	Part of : PHASE 1 OM VIHAR NAWADA	45	Other Outage	Unplanned Outage	11-03-2026	15:04	11-03-2026	15:12	0:08	0.000044	REPAIRING OF RMU
1136	11-03-2026	Part of : SAINIK ENCLAVE VIPIN GARDEN NAWADA,VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA	4411	Other Outage	Unplanned Outage	11-03-2026	17:34	11-03-2026	18:37	1:03	0.000000	REPAIRING OF HT CIRCUIT
1137	11-03-2026	Part of : OM VIHAR PHASE 2 NAWADA	475	Other Outage	Planned Outage	11-03-2026	15:45	11-03-2026	16:40	0:55	0.000000	LT CIRCUIT MAINTENANCE
1138	11-03-2026	Part of : D & H-BLOCK BHAGWATI GARDEN NAWADA	1577	Other Outage	Planned Outage	11-03-2026	11:46	11-03-2026	14:46	3:00	0.000000	3PH HT AB CABLE REPLACEMENT
1139	11-03-2026	Part of : A-BLOCK RAMA PARK,E & L-BLOCK BHAGWATI GARDEN NAWADA	1541	Other Outage	Planned Outage	11-03-2026	11:45	11-03-2026	13:47	2:02	0.000678	3PH HT AB CABLE REPLACEMENT
1140	11-03-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	729	Other Outage	Planned Outage	11-03-2026	11:30	11-03-2026	13:45	2:15	0.000375	3PH HT AB CABLE REPLACEMENT
1141	12-03-2026	Part of : F-BLOCK ZAILDAR ENCLAVE NAWADA	738	Other Outage	Planned Outage	12-03-2026	14:57	12-03-2026	15:55	0:58	0.000000	3PH DB REVAMPING
1142	12-03-2026	Part of : B & F-BLOCK MAHAVIR ENCLAVE,ZAILDAR ENCLAVE NAWADA	1496	Other Outage	Planned Outage	12-03-2026	11:11	12-03-2026	13:57	2:46	0.000922	3PH HT AB CABLE REPLACEMENT
1143	12-03-2026	Part of : NAWADA EXTENSION	1346	Other Outage	Planned Outage	12-03-2026	11:03	12-03-2026	13:54	2:51	0.001188	REPLACEMET OF HT BUSHING ROD
1144	12-03-2026	Part of : RK & WE-BLOCK MOHAN GARDEN RAZAPUR KHURD	1052	Other Outage	Planned Outage	12-03-2026	11:18	12-03-2026	13:56	2:38	0.000439	3PH HT AB CABLE REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1145	12-03-2026	Part of : A,B,D & H-BLOCK BHAGWATI GARDEN,LAXMI VIHAR NAWADA	5244	Other Outage	Planned Outage	12-03-2026	11:02	12-03-2026	13:57	2:55	0.001215	GUARD WIRES SAGGING
1146	13-03-2026	Part of : BLOCK RK MOHAN GARDEN RAZAPUR KHURD,BLOCK WE MOHAN GARDEN RAZAPUR KHURD	837	Other Outage	Unplanned Outage	13-03-2026	12:29	13-03-2026	13:44	1:15	0.001042	CONNECTION/DISCONNETION OF HT/LT CABLES
1147	13-03-2026	Part of : NAWADA EXTENSION	2147	Other Outage	Planned Outage	13-03-2026	11:59	13-03-2026	14:39	2:40	0.000889	REPLACEMENT OF FAULTY END BOX
1148	13-03-2026	Part of : PHASE 2 OM VIHAR NAWADA	981	Other Outage	Planned Outage	13-03-2026	12:25	13-03-2026	14:39	2:14	0.000744	REPLACEMENT OF GAS KIT AND OIL SEAL
1149	13-03-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	2627	Other Outage	Planned Outage	13-03-2026	11:07	13-03-2026	13:50	2:43	0.000453	3PH HT AB CABLE REPLACEMENT PER SPAN
1150	14-03-2026	Part of : PHASE 4 OM VIHAR HASTSAL	1548	Other Outage	Unplanned Outage	14-03-2026	09:30	14-03-2026	10:18	0:48	0.000280	CABLE FAULT
1151	14-03-2026	Part of : PHASE 2 OM VIHAR NAWADA,	795	Other Outage	Planned Outage	14-03-2026	12:44	14-03-2026	15:01	2:17	0.000000	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF LUGS
1152	14-03-2026	Part of : PHASE 2 OM VIHAR NAWADA,	981	Other Outage	Planned Outage	14-03-2026	11:10	14-03-2026	13:36	2:26	0.000811	REPLACEMENT OF GAS KIT AND OIL SEAL
1153	14-03-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA,	1861	Other Outage	Planned Outage	14-03-2026	11:22	14-03-2026	13:36	2:14	0.000000	REPLACEMENT OF LT BUSHING ROD
1154	14-03-2026	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	1	Other Outage	Planned Outage	14-03-2026	11:15	14-03-2026	13:39	2:24	0.000000	REPLACEMENT OF LT BUSHING ROD
1155	15-03-2026	Part of : BLOCK B1 SEWAK PARK DWARKA,NAWADA EXTENSION NAWADA,BLOCK B SEWAK PARK DWARKA	2632	Other Outage	Unplanned Outage	15-03-2026	11:53	15-03-2026	13:07	1:14	0.001028	LAYING OF NEW LTAB
1156	16-03-2026	Part of : NAWADA EXTENSION	2147	Other Outage	Planned Outage	16-03-2026	12:13	16-03-2026	14:11	1:58	0.000656	3PH HT AB CABLE REPLACEMENT
1157	16-03-2026	Part of : A,B,D & H-BLOCK BHAGWATI GARDEN NAWADA,LAXMI VIHAR,ROSHAN GARDEN	5230	Other Outage	Planned Outage	16-03-2026	11:40	16-03-2026	13:41	2:01	0.000000	3PH HT AB CABLE REPLACEMENT
1158	16-03-2026	Part of : P,P 2, H, R 5, & L-BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD	1981	Other Outage	Planned Outage	16-03-2026	12:03	16-03-2026	14:12	2:09	0.000358	3PH HT AB CABLE REPLACEMENT
1159	17-03-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	1296	Other Outage	Unplanned Outage	17-03-2026	16:10	17-03-2026	17:40	1:30	0.000250	REPAIR OF HVDS CIRCUIT
1160	17-03-2026	Part of : BLOCK B1 SEWAK PARK DWARKA	557	Other Outage	Planned Outage	17-03-2026	11:52	17-03-2026	13:54	2:02	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1161	17-03-2026	Part of : BLOCK N 1, R 1, & R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL	2927	Other Outage	Planned Outage	17-03-2026	11:23	17-03-2026	13:46	2:23	0.000397	3PH HT AB CABLE REPLACEMENT PER SPAN
1162	17-03-2026	Part of : PHASE 2 OM VIHAR NAWADA	1319	Other Outage	Planned Outage	17-03-2026	11:33	17-03-2026	13:43	2:10	0.000000	REPLACEMENT OF HT BUSHING ROD
1163	18-03-2026	Part of : ROSHAN GARDEN BHAGWATI GARDEN NAWADA	1494	Other Outage	Unplanned Outage	18-03-2026	18:55	18-03-2026	19:32	0:37	0.000493	CABLE FAULT
1164	18-03-2026	Part of : BLOCK B1 SEWAK PARK DWARKA,BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	294	Other Outage	Unplanned Outage	18-03-2026	17:26	18-03-2026	18:36	1:10	0.000389	ATTENDING WEAK POINTS/HOT SPOT
1165	18-03-2026	Part of : BLOCK K 6 ZAILDAR ENCLAVE HASTSAL,	1622	Other Outage	Planned Outage	18-03-2026	15:05	18-03-2026	16:07	1:02	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS
1166	18-03-2026	Part of : BLOCK L BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,	2661	Other Outage	Planned Outage	18-03-2026	13:47	18-03-2026	15:20	1:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1167	18-03-2026	Part of : RAZA PUR KHURD VIKAS NAGAR,	1274	Other Outage	Planned Outage	18-03-2026	11:56	18-03-2026	14:00	2:04	0.000344	3PH HT AB CABLE REPLACEMENT PER SPAN
1168	18-03-2026	Part of : BLOCK F ZAILDAR ENCLAVE NAWADA,	1680	Other Outage	Planned Outage	18-03-2026	11:24	18-03-2026	13:59	2:35	0.000861	REPLACEMET OF HT BUSHING ROD
1169	19-03-2026	Part of : OM VIHAR PHASE 2 NAWADA	799	Other Outage	Planned Outage	19-03-2026	14:03	19-03-2026	15:12	1:09	0.000383	REPLACEMENT OF HT BUSHING ROD
1170	19-03-2026	Part of : R,RK & WE-BLOCK MOHAN GARDEN RAZAPUR KHURD	1056	Other Outage	Planned Outage	19-03-2026	13:25	19-03-2026	14:31	1:06	0.000458	DT REPLACEMENT PER DT
1171	19-03-2026	Part of : B-BLOCK SEWAK PARK DWARKA	1388	Other Outage	Planned Outage	19-03-2026	11:32	19-03-2026	13:37	2:05	0.000000	LT CIRCUIT MAINTENANCE
1172	20-03-2026	Part of : E-BLOCK BHAGWATI GARDEN,A & B-BLOCK MAHAVIR ENCLAVE,M & F-BLOCK ZAILDAR ENCLAVE,NAWADA EXTENSION	4190	Other Outage	Unplanned Outage	20-03-2026	10:36	20-03-2026	11:13	0:37	0.000462	HT SYSTEM FAULT
1173	20-03-2026	Part of : RAZA PUR KHURD VIKAS NAGAR	1090	Other Outage	Planned Outage	20-03-2026	12:32	20-03-2026	14:51	2:19	0.000386	3PH HT AB CABLE REPLACEMENT
1174	20-03-2026	Part of : OM VIHAR PHASE 4 HASTSAL	1548	Other Outage	Planned Outage	20-03-2026	11:45	20-03-2026	14:51	3:06	0.000103	REPLACEMENT OF FAULTY END BOX
1175	20-03-2026	Part of : H-BLOCK BHAGWATI GARDEN NAWADA	8	Other Outage	Planned Outage	20-03-2026	12:59	20-03-2026	15:48	2:49	0.000000	LT CIRCUIT MAINTENANCE
1176	21-03-2026	Part of : PHASE 2 OM VIHAR NAWADA	799	Other Outage	Planned Outage	21-03-2026	10:32	21-03-2026	13:44	3:12	0.001067	REPLACEMENT OF LT BUSHING ROD
1177	23-03-2026	Part of : BLOCK C VIPIN GARDEN NAWADA,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,SAINIK ENCLAVE VIPIN GARDEN NAWADA	4295	Other Outage	Unplanned Outage	23-03-2026	12:05	23-03-2026	12:27	0:22	0.000183	CABLE FAULT
1178	23-03-2026	Part of : PHASE 2 OM VIHAR NAWADA	799	Other Outage	Unplanned Outage	23-03-2026	11:21	23-03-2026	12:31	1:10	0.000389	JUMPER REPLACEMENT
1179	23-03-2026	Part of : D-BLOCK MANSA RAM PARK UTTAM NAGAR	230	Other Outage	Planned Outage	23-03-2026	12:36	23-03-2026	13:51	1:15	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1180	23-03-2026	Part of : R-BLOCK MOHAN GARDEN RAZAPUR KHURD	1441	Other Outage	Planned Outage	23-03-2026	12:06	23-03-2026	15:18	3:12	0.000533	3PH HT AB CABLE REPLACEMENT
1181	23-03-2026	Part of : B-BLOCK MAHAVIR ENCLAVE,F-BLOCK ZAILDAR ENCLAVE,NAWADA EXTENSION	1680	Other Outage	Planned Outage	23-03-2026	12:29	23-03-2026	15:17	2:48	0.000933	3PH HT AB CABLE REPLACEMENT
1182	24-03-2026	Part of : R, R1 & RK-BLOCK MOHAN GARDEN RAZAPUR KHURD	584	Other Outage	Planned Outage	24-03-2026	15:39	24-03-2026	16:11	0:32	0.000089	3PH HT AB CABLE REPLACEMENT
1183	24-03-2026	Part of : A-BLOCK MAHAVIR ENCLAVE NAWADA	1607	Other Outage	Planned Outage	24-03-2026	11:26	24-03-2026	13:24	1:58	0.000066	REPLACEMENT OF FAULTY END BOX
1184	25-03-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK B, D & E BHAGWATI GARDEN NAWADA	3503	Other Outage	Planned Outage	25-03-2026	13:28	25-03-2026	16:25	2:57	0.000000	REPLACEMET OF HT BUSHING ROD
1185	25-03-2026	Part of : BLOCK B MAHAVIR ENCLAVE NAWADA,BLOCK F ZAILDAR ENCLAVE NAWADA	1680	Other Outage	Planned Outage	25-03-2026	11:23	25-03-2026	13:28	2:05	0.000694	3PH DB REPLACEMENT
1186	25-03-2026	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,RAZAPUR KHURD	1776	Other Outage	Planned Outage	25-03-2026	11:13	25-03-2026	13:27	2:14	0.000372	3PH HT AB CABLE REPLACEMENT PER SPAN
1187	26-03-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA,	1527	Other Outage	Planned Outage	26-03-2026	12:11	26-03-2026	15:16	3:05	0.001028	REPLACEMENT OF GAS KIT AND OIL SEAL
1188	26-03-2026	Part of : RAZAPUR KHURD,VIKAS KUNJ AND VIKAS KUNJ EXTN.,	871	Other Outage	Planned Outage	26-03-2026	12:26	26-03-2026	15:17	2:51	0.000475	3PH HT AB CABLE REPLACEMENT PER SPAN
1189	27-03-2026	Part of : BHAGWATI GARDEN EXTENSION NAWADA,LAXMI VIHAR NAWADA	5487	Other Outage	Unplanned Outage	27-03-2026	15:13	27-03-2026	16:14	1:01	0.001101	REPAIRING OF HVDS CIRCUIT
1190	27-03-2026	Part of : RAZAPUR KHURD,SAI& SETHI ENCLAVE,SAINIK ENCLAVE,PANCHSHEEL ENCLAVE	873	Other Outage	Planned Outage	27-03-2026	11:59	27-03-2026	14:39	2:40	0.000444	3PH HT AB CABLE REPLACEMENT
1191	27-03-2026	Part of : B-BLOCK MAHAVIR ENCLAVE NAWADA	711	Other Outage	Planned Outage	27-03-2026	12:16	27-03-2026	14:40	2:24	0.000800	REPLACEMENT OF HT BUSHING ROD
1192	27-03-2026	Part of : OM VIHAR NAWADA PHASE-1	2027	Other Outage	Planned Outage	27-03-2026	10:56	27-03-2026	14:37	3:41	0.001228	REPLACEMENT OF HT BUSHING ROD
1193	28-03-2026	Part of : BLOCK E BHAGWATI GARDEN NAWADA,BLOCK A & B MAHAVIR ENCLAVE NAWADA,BLOCK F ZAILDAR ENCLAVE NAWADA	525	Other Outage	Planned Outage	28-03-2026	11:52	28-03-2026	14:41	2:49	0.000939	REPLACEMET OF FAULTY END BOX
1194	28-03-2026	Part of : BLOCK B BHAGWATI GARDEN NAWADA	1940	Other Outage	Planned Outage	28-03-2026	11:56	28-03-2026	14:42	2:46	0.000000	REPLACEMET OF HT BUSHING ROD
1195	28-03-2026	Part of : BLOCK N2 & N3 MOHAN GARDEN RAZAPUR KHURD, DEFENCE ENCLAVE PART-1 MOHAN GARDEN	920	Other Outage	Planned Outage	28-03-2026	12:10	28-03-2026	14:41	2:31	0.000419	3PH HT AB CABLE REPLACEMENT PER SPAN
1196	28-03-2026	Part of : PHASE 4 OM VIHAR HASTSAL	1241	Other Outage	Planned Outage	28-03-2026	10:53	28-03-2026	13:28	2:35	0.000000	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF LUGS
1197	30-03-2026	Part of : SHYAM PARK NAWADA MAJRA VILLAGE NAWADA,	595	Other Outage	Unplanned Outage	30-03-2026	12:03	30-03-2026	12:54	0:51	0.000283	REPAIR OF DAMAGED WIRE ON POLES
1198	30-03-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,	96	Other Outage	Unplanned Outage	30-03-2026	13:00	30-03-2026	14:06	1:06	0.000367	JUMPER REPLACEMENT
1199	30-03-2026	Part of : BLOCK B MAHAVIR ENCLAVE NAWADA,	711	Other Outage	Planned Outage	30-03-2026	15:31	30-03-2026	16:38	1:07	0.000372	3PH HT AB CABLE REPLACEMENT PER SPAN
1200	30-03-2026	Part of : BLOCK S MOHAN GARDEN RAZAPUR KHURD,	242	Other Outage	Planned Outage	30-03-2026	14:41	30-03-2026	15:58	1:17	0.000214	3PH DB REPLACEMENT
1201	30-03-2026	Part of : BLOCK D BHAGWATI GARDEN NAWADA,	1811	Other Outage	Planned Outage	30-03-2026	11:54	30-03-2026	15:11	3:17	0.000000	REPLACEMET OF HT BUSHING ROD
1202	30-03-2026	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK L BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA,BLOCK P MOHAN GARDEN RAZAPUR KHURD,	1981	Other Outage	Planned Outage	30-03-2026	11:35	30-03-2026	13:53	2:18	0.000383	3PH HT AB CABLE REPLACEMENT PER SPAN
1203	31-03-2026	Part of : BLOCK N1,P2,R1 & R5 MOHAN GARDEN RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL	2927	Other Outage	Planned Outage	31-03-2026	15:10	31-03-2026	16:26	1:16	0.000211	3PH HT AB CABLE REPLACEMENT PER SPAN
1204	31-03-2026	Part of : BLOCK B SEWAK PARK DWARKA	1389	Other Outage	Planned Outage	31-03-2026	12:53	31-03-2026	14:00	1:07	0.000000	REPLACEMENT OF HT BUSHING ROD
1205	31-03-2026	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E & L BHAGWATI GARDEN NAWADA	1527	Other Outage	Planned Outage	31-03-2026	12:16	31-03-2026	13:59	1:43	0.001431	3PH HT AB CABLE REPLACEMENT PER SPAN
1206	02-03-2026	Part of : VIKASPURI EXTN,TEACHER VIHAR,GURUNANAK VIHAR,GRAM SABHA COLONY,	3284	Other Outage	Planned Outage	02-03-2026	11:08	02-03-2026	13:05	1:57	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1207	02-03-2026	Part of : BLOCK A NARESH PARK EXTENSION NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,NANGLOI JAT NANGLOI,BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI,POCKET A NARESH PARK NANGLOI,NARESH PARK NANGLOI,BLOCK B NARESH PARK EXTENSION NANGLOI,	4329	Other Outage	Planned Outage	02-03-2026	11:55	02-03-2026	14:23	2:28	0.000000	GUARD WIRES SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1208	02-03-2026	Part of : NARESH PARK NANGLOI,NANGLOI JAT NANGLOI,POCKET A NARESH PARK NANGLOI,	480	Other Outage	Planned Outage	02-03-2026	11:53	02-03-2026	14:24	2:31	0.000000	GUARD WIRES SAGGING PER SPAN
1209	02-03-2026	Part of : BLOCK GH 13 PASCHIM VIHAR,	147	Other Outage	Planned Outage	02-03-2026	11:06	02-03-2026	13:13	2:07	0.000353	REPLACEMENT OF HT BUSHING ROD
1210	05-03-2026	Part of : RANHOLLA	2	Other Outage	Planned Outage	05-03-2026	11:49	05-03-2026	12:51	1:02	0.000000	GUARD WIRES SAGGING PER SPAN
1211	05-03-2026	Part of : ADHYAPAK NAGAR NANGLOI	407	Other Outage	Planned Outage	05-03-2026	10:50	05-03-2026	12:50	2:00	0.000667	REPLACEMENT OF HT BUSHING ROD
1212	05-03-2026	Part of : INDER ENCLAVE PASCHIM VIHAR	228	Other Outage	Planned Outage	05-03-2026	11:34	05-03-2026	12:51	1:17	0.000000	REPLACEMENT OF LT BUSHING ROD
1213	06-03-2026	Part of : DASS GARDEN,	603	Other Outage	Planned Outage	06-03-2026	14:35	06-03-2026	16:14	1:39	0.000275	REPLACEMENT OF HT BUSHING ROD
1214	06-03-2026	Part of : RISHAL GARDEN,	1377	Other Outage	Planned Outage	06-03-2026	13:50	06-03-2026	16:12	2:22	0.000394	REPLACEMENT OF LT BUSHING ROD
1215	06-03-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR,	107	Other Outage	Planned Outage	06-03-2026	11:28	06-03-2026	13:33	2:05	0.000347	REPLACEMENT OF HT BUSHING ROD
1216	06-03-2026	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,	275	Other Outage	Planned Outage	06-03-2026	10:54	06-03-2026	13:33	2:39	0.000442	REPLACEMENT OF HT BUSHING ROD
1217	07-03-2026	Part of : A-BLOCK MIRA BAGH PASCHIM VIHAR	1219	Other Outage	Planned Outage	07-03-2026	14:37	07-03-2026	16:34	1:57	0.000000	REPLACEMENT OF FAULTY END BOX
1218	07-03-2026	Part of : GH 10-BLOCK SUNDER VIHAR PASCHIM VIHAR	425	Other Outage	Planned Outage	07-03-2026	10:56	07-03-2026	13:02	2:06	0.000000	REPLACEMENT OF FAULTY END BOX
1219	07-03-2026	Part of : DASS GARDEN	616	Other Outage	Planned Outage	07-03-2026	14:14	07-03-2026	16:35	2:21	0.000000	LT CIRCUIT MAINTENANCE
1220	07-03-2026	Part of : G-BLOCK UDAY VIHAR-2 ADHYAPAK NAGAR NANGLOI	115	Other Outage	Planned Outage	07-03-2026	10:58	07-03-2026	13:33	2:35	0.000000	LT CIRCUIT MAINTENANCE
1221	07-03-2026	Part of : RISHAL GARDEN	1381	Other Outage	Planned Outage	07-03-2026	11:04	07-03-2026	13:37	2:33	0.000000	LT CIRCUIT MAINTENANCE
1222	07-03-2026	Part of : TILANGPUR KOTLA VILLAGE	1187	Other Outage	Planned Outage	07-03-2026	11:27	07-03-2026	13:36	2:09	0.000000	LT CIRCUIT MAINTENANCE
1223	08-03-2026	Part of : UDYOG NAGAR MANGOLPURI	8	Other Outage	Planned Outage	08-03-2026	11:24	08-03-2026	13:35	2:11	0.000182	LT CIRCUIT MAINTENANCE
1224	09-03-2026	Part of : BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,BLOCK A,B & I NARESH PARK EXTENSION NANGLOI	271	Other Outage	Planned Outage	09-03-2026	13:16	09-03-2026	15:00	1:44	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1225	09-03-2026	Part of : CHANDER VIHAR,RISALA GARDEN NILOTHI,NILOTHI VILLAGE	1810	Other Outage	Planned Outage	09-03-2026	11:19	09-03-2026	13:07	1:48	0.000000	GUARD WIRES SAGGING PER SPAN
1226	09-03-2026	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	334	Other Outage	Planned Outage	09-03-2026	11:23	09-03-2026	13:02	1:39	0.000000	REPLACEMENT OF HT BUSHING ROD
1227	09-03-2026	Part of : BLOCK GH 13 PASCHIM VIHAR	113	Other Outage	Planned Outage	09-03-2026	11:08	09-03-2026	13:05	1:57	0.000000	REPLACEMENT OF HT BUSHING ROD
1228	09-03-2026	Part of : JAI VIHAR PH-1 & PH-3	718	Other Outage	Planned Outage	09-03-2026	13:17	09-03-2026	14:59	1:42	0.000000	REPLACEMENT OF HT BUSHING ROD
1229	09-03-2026	Part of : RAJIV RATAN AWAS FLATS	409	Other Outage	Planned Outage	09-03-2026	15:44	09-03-2026	16:54	1:10	0.000000	REPLACEMENT OF HT BUSHING ROD
1230	10-03-2026	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR,	337	Other Outage	Planned Outage	10-03-2026	14:05	10-03-2026	15:33	1:28	0.000244	REPLACEMENT OF FAULTY END BOX
1231	10-03-2026	Part of : BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,	416	Other Outage	Planned Outage	10-03-2026	13:43	10-03-2026	15:32	1:49	0.000303	REPLACEMENT OF HT BUSHING ROD
1232	10-03-2026	Part of : BLOCK GH 14 PASCHIM VIHAR,	417	Other Outage	Planned Outage	10-03-2026	10:46	10-03-2026	11:57	1:11	0.000197	REPLACEMENT OF FAULTY END BOX
1233	10-03-2026	Part of : DASS GARDEN,	687	Other Outage	Planned Outage	10-03-2026	11:53	10-03-2026	13:31	1:38	0.000272	REPLACEMENT OF HT BUSHING ROD
1234	10-03-2026	Part of : JAI VIHAR PH-1, PH-3,	73	Other Outage	Planned Outage	10-03-2026	11:05	10-03-2026	13:01	1:56	0.000322	REPLACEMENT OF HT BUSHING ROD
1235	11-03-2026	Part of : H-BLOCK VANDANA VIHAR NANGLOI	804	Other Outage	Planned Outage	11-03-2026	11:09	11-03-2026	13:08	1:59	0.000000	REPLACEMENT OF HT BUSHING ROD
1236	11-03-2026	Part of : BHERA ENCLAVE PASCHIM VIHAR	135	Other Outage	Planned Outage	11-03-2026	11:01	11-03-2026	12:46	1:45	0.000000	REPLACEMENT OF FAULTY END BOX
1237	11-03-2026	Part of : TILANGPUR KOTLA	382	Other Outage	Planned Outage	11-03-2026	11:00	11-03-2026	12:48	1:48	0.000000	LT CIRCUIT MAINTENANCE
1238	11-03-2026	Part of : H-BLOCK VANDANA VIHAR NANGLOI	835	Other Outage	Planned Outage	11-03-2026	11:08	11-03-2026	13:40	2:32	0.000000	REPLACEMENT OF HT BUSHING ROD
1239	11-03-2026	Part of : JAI VIHAR BAPROLA	205	Other Outage	Planned Outage	11-03-2026	13:47	11-03-2026	16:35	2:48	0.000000	LT CIRCUIT MAINTENANCE
1240	11-03-2026	Part of : DASS GARDEN	956	Other Outage	Planned Outage	11-03-2026	13:47	11-03-2026	16:34	2:47	0.000000	LT CIRCUIT MAINTENANCE
1241	11-03-2026	Part of : NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	199	Other Outage	Planned Outage	11-03-2026	13:51	11-03-2026	16:33	2:42	0.000000	LT CIRCUIT MAINTENANCE
1242	11-03-2026	Part of : NANGLI VIHAR	568	Other Outage	Planned Outage	11-03-2026	12:00	11-03-2026	14:41	2:41	0.000000	LT CIRCUIT MAINTENANCE
1243	12-03-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI	4452	Other Outage	Unplanned Outage	12-03-2026	13:21	12-03-2026	14:10	0:49	0.001433	BIRDAGE
1244	12-03-2026	Part of : RAJIV RATAN AWAS FLATS	179	Other Outage	Planned Outage	12-03-2026	14:11	12-03-2026	16:36	2:25	0.000403	LT CIRCUIT MAINTENANCE
1245	12-03-2026	Part of : NANGLI VIHAR	1964	Other Outage	Planned Outage	12-03-2026	12:21	12-03-2026	15:06	2:45	0.000458	LT CIRCUIT MAINTENANCE
1246	12-03-2026	Part of : HARPHOOL VIHAR	3355	Other Outage	Planned Outage	12-03-2026	11:42	12-03-2026	14:02	2:20	0.000194	LT CIRCUIT MAINTENANCE
1247	12-03-2026	Part of : NILOTHI VILLAGE	473	Other Outage	Planned Outage	12-03-2026	10:58	12-03-2026	14:01	3:03	0.002033	LT CIRCUIT MAINTENANCE
1248	13-03-2026	Part of : RANHOLLA,JAI VIHAR PH-1, PH-3,PRATAP VIHAR,TILANGPUR KOTLA VILLAGE	1512	Other Outage	Unplanned Outage	13-03-2026	01:57	13-03-2026	02:28	0:31	0.000403	CABLE DAMAGED BY OUT SIDE AGENCY (DJB)
1249	13-03-2026	Part of : GH 6 PASCHIM VIHAR,GH 6 WHITE APPARTMENTS PASCHIM VIHAR,BLOCK A MIRA BAGH PASCHIM VIHAR,BLOCK GH 7 PASCHIM VIHAR,BLOCK GH5 PASCHIM VIHAR	2684	Other Outage	Unplanned Outage	13-03-2026	17:33	13-03-2026	18:12	0:39	0.000343	CABLE FAULT
1250	13-03-2026	Part of : RANHOLLA,RISALA GARDEN NILOTHI	219	Other Outage	Planned Outage	13-03-2026	14:01	13-03-2026	15:03	1:02	0.000000	GUARD WIRES SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1251	13-03-2026	Part of : NANGLI VIHAR	568	Other Outage	Planned Outage	13-03-2026	12:44	13-03-2026	14:33	1:49	0.000000	REPLACEMENT OF LT BUSHING ROD
1252	13-03-2026	Part of : RISALA GARDEN NILOTHI	329	Other Outage	Planned Outage	13-03-2026	12:24	13-03-2026	13:36	1:12	0.000000	REPLACEMENT OF LT BUSHING ROD
1253	13-03-2026	Part of : RISHAL GARDEN	1381	Other Outage	Planned Outage	13-03-2026	13:56	13-03-2026	16:20	2:24	0.000000	REPLACEMENT OF HT BUSHING ROD
1254	13-03-2026	Part of : BLOCK D VANDANA VIHAR NANGLOI	1186	Other Outage	Planned Outage	13-03-2026	10:56	13-03-2026	13:33	2:37	0.000872	REPLACEMENT OF LT BUSHING ROD
1255	13-03-2026	Part of : BLOCK GH 13 PASCHIM VIHAR	103	Other Outage	Planned Outage	13-03-2026	11:01	13-03-2026	13:34	2:33	0.000000	REPLACEMENT OF HT BUSHING ROD
1256	14-03-2026	Part of : BLOCK NS MIYANWALI NAGAR PASCHIM VIHAR,	801	Other Outage	Planned Outage	14-03-2026	12:52	14-03-2026	14:28	1:36	0.000800	REPLACEMENT OF FAULTY END BOX
1257	14-03-2026	Part of : CHANDER VIHAR,VIKASPURI EXTN,	4234	Other Outage	Planned Outage	14-03-2026	14:24	14-03-2026	16:30	2:06	0.001400	GUARD WIRES SAGGING PER SPAN
1258	14-03-2026	Part of : NANGLI VIHAR,	2329	Other Outage	Planned Outage	14-03-2026	14:26	14-03-2026	16:31	2:05	0.000347	REPLACEMENT OF HT BUSHING ROD
1259	14-03-2026	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR,	30	Other Outage	Planned Outage	14-03-2026	11:00	14-03-2026	13:56	2:56	0.000733	REPLACEMENT OF HT BUSHING ROD
1260	15-03-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,BLOCK C KAMRUDDIN NAGAR NANGLOI,BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,ADHYAPAK NAGAR NANGLOI	6094	Other Outage	Unplanned Outage	15-03-2026	12:09	15-03-2026	12:54	0:45	0.000525	CABLE FAULT
1261	15-03-2026	Part of : NANGLI VIHAR,JAI VIHAR BAPROLA,RANHOLLA	9303	Other Outage	Unplanned Outage	15-03-2026	07:36	15-03-2026	08:30	0:54	0.001888	HT SYSTEM FAULT
1262	15-03-2026	Part of : VANDANA VIHAR,CHANDAN VIHAR C BLK,RAO VIHAR	7983	Other Outage	Unplanned Outage	15-03-2026	05:44	15-03-2026	06:44	1:00	0.000000	BIRDAGE
1263	15-03-2026	Part of : VIKASPURI EXTN,TEACHER VIHAR,GURUNANAK VIHAR,GRAM SABHA COLONY	5721	Other Outage	Unplanned Outage	15-03-2026	05:42	15-03-2026	06:40	0:58	0.000547	HVDS FAULT
1264	16-03-2026	Part of : PRASHANT ENCLAVE	1001	Other Outage	Planned Outage	16-03-2026	13:10	16-03-2026	15:03	1:53	0.001099	LT CIRCUIT MAINTENANCE
1265	16-03-2026	Part of : RISALA GARDEN NILOTHI	173	Other Outage	Planned Outage	16-03-2026	13:45	16-03-2026	16:37	2:52	0.001911	LT CIRCUIT MAINTENANCE
1266	16-03-2026	Part of : NANGLI VIHAR	2329	Other Outage	Planned Outage	16-03-2026	13:01	16-03-2026	16:00	2:59	0.000746	LT CIRCUIT MAINTENANCE
1267	16-03-2026	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR	328	Other Outage	Planned Outage	16-03-2026	10:58	16-03-2026	14:01	3:03	0.000915	LT CIRCUIT MAINTENANCE
1268	16-03-2026	Part of : M-BLOCK JJ COLONY 3 NANGLOI	1019	Other Outage	Planned Outage	16-03-2026	11:21	16-03-2026	14:01	2:40	0.000889	LT CIRCUIT MAINTENANCE
1269	17-03-2026	Part of : NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR,BHERA ENCLAVE PASCHIM VIHAR,PIRA GARHI VILLAGE	1111	Other Outage	Unplanned Outage	17-03-2026	11:15	17-03-2026	11:38	0:23	0.000405	CABLE FAULT
1270	17-03-2026	Part of : CHANDER VIHAR,UDAI VIHAR,RANJEET VIHAR	3333	Other Outage	Planned Outage	17-03-2026	11:13	17-03-2026	13:33	2:20	0.000000	GUARD WIRES SAGGING PER SPAN
1271	17-03-2026	Part of : BLOCK S JAWALAPURI EXTENSION PASCHIM VIHAR	649	Other Outage	Planned Outage	17-03-2026	11:11	17-03-2026	13:33	2:22	0.000394	REPLACEMENT OF HT BUSHING ROD
1272	17-03-2026	Part of : SHIV VIHAR NANGLOI	731	Other Outage	Planned Outage	17-03-2026	11:14	17-03-2026	13:32	2:18	0.000575	REPLACEMENT OF HT BUSHING ROD
1273	18-03-2026	Part of : RAJIV RATAN AWAS FLATS,BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	38	Other Outage	Unplanned Outage	18-03-2026	20:25	18-03-2026	21:08	0:43	0.001403	TREE TOUCHING
1274	18-03-2026	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,BLOCK A VANDANA VIHAR NANGLOI,RAO VIHAR NANGLOI,HANUMAN ENCLAVE NANGLOI,SHIV VIHAR NANGLOI	4709	Other Outage	Unplanned Outage	18-03-2026	18:48	18-03-2026	19:36	0:48	0.000977	TRANSIENT FAULT
1275	18-03-2026	Part of : RANHOLLA,	214	Other Outage	Planned Outage	18-03-2026	12:45	18-03-2026	14:51	2:06	0.001225	REPLACEMENT OF HT BUSHING ROD
1276	18-03-2026	Part of : CHANDER VIHAR,	1013	Other Outage	Planned Outage	18-03-2026	10:54	18-03-2026	13:33	2:39	0.001767	REPLACEMENT OF LT BUSHING ROD
1277	18-03-2026	Part of : BLOCK GH 13 PASCHIM VIHAR,	171	Other Outage	Planned Outage	18-03-2026	11:11	18-03-2026	13:58	2:47	0.000928	REPLACEMENT OF HT BUSHING ROD
1278	19-03-2026	Part of : RAIL NEER PLANT NANGLOI	1	Other Outage	Unplanned Outage	19-03-2026	03:52	19-03-2026	04:48	0:56	0.001416	HT SYSTEM FAULT
1279	19-03-2026	Part of : UDAI VIHAR,RANJEET VIHAR	2092	Other Outage	Planned Outage	19-03-2026	11:46	19-03-2026	14:38	2:52	0.000000	GUARD WIRES SAGGING
1280	19-03-2026	Part of : G-BLOCK NIHAL VIHAR,NAMDHARI COLONY,DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	10658	Other Outage	Planned Outage	19-03-2026	10:52	19-03-2026	13:41	2:49	0.000000	GUARD WIRES SAGGING
1281	19-03-2026	Part of : EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR	431	Other Outage	Planned Outage	19-03-2026	12:16	19-03-2026	14:36	2:20	0.000000	LT CIRCUIT MAINTENANCE
1282	20-03-2026	Part of : GH 8-BLOCK PASCHIM VIHAR,NANGLOI SAIYED VILLAGE PASCHIM VIHAR	1615	Other Outage	Unplanned Outage	20-03-2026	14:03	20-03-2026	14:43	0:40	0.001096	HT SYSTEM FAULT
1283	22-03-2026	Part of : BLOCK A NARESH PARK EXTENSION NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,NANGLOI JAT NANGLOI,BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI,POCKET A NARESH PARK NANGLOI,NARESH PARK NANGLOI,BLOCK B NARESH PARK EXTENSION NANGLOI,	2033	Other Outage	Planned Outage	22-03-2026	10:48	22-03-2026	11:03	0:15	0.000000	GUARD WIRES SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1284	22-03-2026	Part of : NARESH PARK NANGLOI,NANGLOI JAT NANGLOI,POCKET A NARESH PARK NANGLOI,	480	Other Outage	Planned Outage	22-03-2026	10:52	22-03-2026	12:59	2:07	0.000706	GUARD WIRES SAGGING PER SPAN
1285	23-03-2026	Part of : BLOCK A & B JAWALAPURI PASCHIM VIHAR	4553	Other Outage	Unplanned Outage	23-03-2026	23:39	24-03-2026	00:14	0:35	0.000335	TREE TOUCHING
1286	23-03-2026	Part of : JAI VIHAR BAPROLA	1028	Other Outage	Planned Outage	23-03-2026	15:23	23-03-2026	16:41	1:18	0.000217	LT CIRCUIT MAINTENANCE
1287	23-03-2026	Part of : BHERA ENCLAVE PASCHIM VIHAR	319	Other Outage	Planned Outage	23-03-2026	14:54	23-03-2026	16:46	1:52	0.000373	LT CIRCUIT MAINTENANCE
1288	23-03-2026	Part of : NANGLI VIHAR	1084	Other Outage	Planned Outage	23-03-2026	12:33	23-03-2026	14:04	1:31	0.000506	LT CIRCUIT MAINTENANCE
1289	23-03-2026	Part of : A-BLOCK MIRA BAGH PASCHIM VIHAR	806	Other Outage	Planned Outage	23-03-2026	11:33	23-03-2026	14:03	2:30	0.000625	LT CIRCUIT MAINTENANCE
1290	23-03-2026	Part of : RAIL NEER PLANT NANGLOI	1210	Other Outage	Planned Outage	23-03-2026	11:32	23-03-2026	14:00	2:28	0.000493	LT CIRCUIT MAINTENANCE
1291	23-03-2026	Part of : RAIL NEER PLANT NANGLOI	911	Other Outage	Planned Outage	23-03-2026	11:43	23-03-2026	13:59	2:16	0.000378	LT CIRCUIT MAINTENANCE
1292	23-03-2026	Part of : DASS GARDEN	1115	Other Outage	Planned Outage	23-03-2026	11:10	23-03-2026	14:01	2:51	0.000475	LT CIRCUIT MAINTENANCE
1293	24-03-2026	Part of : TILANGPUR KOTLA VILLAGE	1041	Other Outage	Planned Outage	24-03-2026	11:09	24-03-2026	13:40	2:31	0.001678	RELAY REPLACEMENT/VPI/FPI,REPLACEMENT OF FAULTY END BOX
1294	24-03-2026	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,C-BLOCK KAMRUDDIN NAGAR NANGLOI,G-BLOCK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	4228	Other Outage	Planned Outage	24-03-2026	10:34	24-03-2026	14:08	3:34	0.000892	3PH HT AB CABLE REPLACEMENT
1295	24-03-2026	Part of : PRADHAN ENCLAVE	364	Other Outage	Planned Outage	24-03-2026	13:37	24-03-2026	16:06	2:29	0.001449	LT CIRCUIT MAINTENANCE
1296	24-03-2026	Part of : A-BLOCK MIRA BAGH PASCHIM VIHAR	806	Other Outage	Planned Outage	24-03-2026	13:03	24-03-2026	15:15	2:12	0.000733	LT CIRCUIT MAINTENANCE
1297	24-03-2026	Part of : VIRAT APARTMENT PASCHIM VIHAR	85	Other Outage	Planned Outage	24-03-2026	11:51	24-03-2026	14:07	2:16	0.000189	LT CIRCUIT MAINTENANCE
1298	25-03-2026	Part of : BLOCK D NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	949	Other Outage	Planned Outage	25-03-2026	11:21	25-03-2026	13:07	1:46	0.000589	REPLACEMET OF HT BUSHING ROD
1299	25-03-2026	Part of : JAI VIHAR PH-1 & PH-3	1534	Other Outage	Planned Outage	25-03-2026	14:14	25-03-2026	15:53	1:39	0.000000	REPLACEMENT OF LT BUSHING ROD
1300	25-03-2026	Part of : RAJIV RATAN AWAS FLATS	159	Other Outage	Planned Outage	25-03-2026	14:15	25-03-2026	15:53	1:38	0.000000	REPLACEMET OF HT BUSHING ROD
1301	25-03-2026	Part of : BLOCK D NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1066	Other Outage	Planned Outage	25-03-2026	11:20	25-03-2026	13:27	2:07	0.000706	REPLACEMET OF HT BUSHING ROD
1302	25-03-2026	Part of : BLOCK GH 13 PASCHIM VIHAR	80	Other Outage	Planned Outage	25-03-2026	11:56	25-03-2026	14:11	2:15	0.000000	REPLACEMET OF HT BUSHING ROD
1303	25-03-2026	Part of : JAI VIHAR PH-1 & PH-3	660	Other Outage	Planned Outage	25-03-2026	11:08	25-03-2026	13:26	2:18	0.000000	REPLACEMET OF HT BUSHING ROD
1304	27-03-2026	Part of : VIKASPURI EXTN,TEACHER VIHAR,GURUNANAK VIHAR,GRAM SABHA COLONY	3263	Other Outage	Planned Outage	27-03-2026	11:12	27-03-2026	14:03	2:51	0.001900	GUARD WIRES SAGGING
1305	27-03-2026	Part of : B-BLOCK LAXMI PARK VANDANA VIHAR NANGLOI	923	Other Outage	Planned Outage	27-03-2026	14:12	27-03-2026	16:14	2:02	0.000678	LT CIRCUIT MAINTENANCE
1306	27-03-2026	Part of : PRADHAN ENCLAVE	1387	Other Outage	Planned Outage	27-03-2026	11:14	27-03-2026	14:01	2:47	0.001392	LT CIRCUIT MAINTENANCE
1307	27-03-2026	Part of : A-BLOCK MIRA BAGH PASCHIM VIHAR	313	Other Outage	Planned Outage	27-03-2026	11:07	27-03-2026	13:59	2:52	0.001433	LT CIRCUIT MAINTENANCE
1308	28-03-2026	Part of : SHRI RAM COLONY,BLOCK A & B SHIV VIHAR ,TEK CHAND COLONY,CHANDER VIHAR	2699	Other Outage	Planned Outage	28-03-2026	10:29	28-03-2026	12:12	1:43	0.000000	GUARD WIRES SAGGING PER SPAN
1309	28-03-2026	Part of : EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR	436	Other Outage	Planned Outage	28-03-2026	11:17	28-03-2026	12:57	1:40	0.000556	REPLACEMET OF FAULTY END BOX
1310	28-03-2026	Part of : JAI VIHAR PH-1	975	Other Outage	Planned Outage	28-03-2026	14:51	28-03-2026	16:50	1:59	0.000331	REPLACEMET OF HT BUSHING ROD
1311	28-03-2026	Part of : GURU HARKISHAN NAGAR PASCHIM VIHAR	309	Other Outage	Planned Outage	28-03-2026	14:52	28-03-2026	16:50	1:58	0.000328	REPLACEMET OF HT BUSHING ROD
1312	28-03-2026	Part of : BLOCK X JJ COLONY 3 NANGLOI	912	Other Outage	Planned Outage	28-03-2026	10:53	28-03-2026	13:33	2:40	0.000444	REPLACEMENT OF LT BUSHING ROD
1313	28-03-2026	Part of : CHANDER VIHAR	1262	Other Outage	Planned Outage	28-03-2026	11:12	28-03-2026	13:33	2:21	0.000392	REPLACEMENT OF LT BUSHING ROD
1314	29-03-2026	Part of : BLOCK A NARESH PARK EXTENSION NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,NANGLOI JAT	4329	Other Outage	Planned Outage	29-03-2026	10:40	29-03-2026	13:33	2:53	0.001201	GUARD WIRES SAGGING PER SPAN
1315	29-03-2026	Part of : NARESH PARK NANGLOI	96	Other Outage	Planned Outage	29-03-2026	10:41	29-03-2026	13:28	2:47	0.000928	REPLACEMENT OF LT BUSHING ROD
1316	30-03-2026	Part of : BLOCK GH5 PASCHIM VIHAR,	609	Other Outage	Planned Outage	30-03-2026	11:16	30-03-2026	11:47	0:31	0.000086	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,SF6 GAS FILLING
1317	30-03-2026	Part of : EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR,	98	Other Outage	Planned Outage	30-03-2026	12:43	30-03-2026	13:34	0:51	0.000142	SF6 GAS FILLING
1318	30-03-2026	Part of : JAI VIHAR BAPROLA,	1266	Other Outage	Planned Outage	30-03-2026	13:32	30-03-2026	14:59	1:27	0.000242	REPLACEMENT OF LT BUSHING ROD
1319	30-03-2026	Part of : RAO VIHAR NANGLOI,HANUMAN ENCLAVE NANGLOI,SHIV VIHAR NANGLOI,	1075	Other Outage	Planned Outage	30-03-2026	11:05	30-03-2026	12:42	1:37	0.000539	3PH HT AB CABLE REPLACEMENT PER SPAN
1320	30-03-2026	Part of : BLOCK H VANDANA VIHAR NANGLOI,	829	Other Outage	Planned Outage	30-03-2026	10:45	30-03-2026	12:48	2:03	0.000342	REPLACEMENT OF LT BUSHING ROD
1321	30-03-2026	Part of : BLOCK GH10 SUNDER VIHAR PASCHIM VIHAR,	339	Other Outage	Planned Outage	30-03-2026	11:06	30-03-2026	13:34	2:28	0.000411	REPLACEMET OF HT BUSHING ROD
1322	02-03-2026	Part of : POCHANPUR DWARKA,	621	Other Outage	Planned Outage	02-03-2026	14:51	02-03-2026	15:37	0:46	0.000192	REPLACEMET OF HT BUSHING ROD
1323	02-03-2026	Part of : ROSHAN VIHAR NAJAFGARH,	362	Other Outage	Planned Outage	02-03-2026	15:56	02-03-2026	17:04	1:08	0.000283	REPLACEMET OF HT BUSHING ROD
1324	02-03-2026	Part of : NAJAFGARH EXTENSION NAJAFGARH,	196	Other Outage	Planned Outage	02-03-2026	14:12	02-03-2026	16:56	2:44	0.001139	DT REPLACEMET PER DT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1325	02-03-2026	Part of : SARIKA VIHAR DINPUR,	8	Other Outage	Planned Outage	02-03-2026	11:02	02-03-2026	13:03	2:01	0.003025	REPLACEMET OF HT BUSHING ROD
1326	03-03-2026	Part of : SAI BABA ENCLAVE MASUDABAD NAJAFGARH,NAJAFGARH VILLAGE,DHARAMPURA NAJAFGARH,NATHU RAM PARK MASUDABAD NAJAFGARH	4998	Other Outage	Unplanned Outage	03-03-2026	08:07	03-03-2026	08:32	0:25	0.000556	BIRDAGE
1327	03-03-2026	Part of : GOYLA DAIRY,CHATWAL FARM	0	Other Outage	Unplanned Outage	03-03-2026	17:27	03-03-2026	18:12	0:45	0.000312	BIRDAGE
1328	03-03-2026	Part of : BLOCK A, B & E INDRA PARK MASUDABAD NAJAFGARH,NANGLI SANKRANTI NANGLI SAKRAWATI	2871	Other Outage	Unplanned Outage	03-03-2026	06:18	03-03-2026	07:03	0:45	0.000000	CABLE FAULT
1329	03-03-2026	Part of : SULTAN GARDEN,SHIV ENCLAVE,SAINIK NIKETAN,NEW HEERA PARK,NEW HIRA NAGAR,SHIV NAGAR,DICHAON ENCLAVE,NATHU RAM PARK,NEELWAL VILLAGE,KRISHNA ENCLAVE SP ROAD AREA,BANI AIR FORCE CAMP,DICHAON KALAN VILLAGE	2542	Other Outage	Planned Outage	03-03-2026	11:49	03-03-2026	13:39	1:50	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1330	03-03-2026	Part of : KHAIRA VILLAGE	43	Other Outage	Planned Outage	03-03-2026	11:11	03-03-2026	13:04	1:53	0.002825	REPLACEMENT OF HT BUSHING ROD
1331	03-03-2026	Part of : NAJAFGARH EXTENSION	725	Other Outage	Planned Outage	03-03-2026	14:10	03-03-2026	16:12	2:02	0.000678	DT REPLACEMENT
1332	03-03-2026	Part of : REWLA KHANPUR VILLAGE	506	Other Outage	Planned Outage	03-03-2026	11:40	03-03-2026	15:03	3:23	0.000846	REPLACEMENT OF HT BUSHING ROD
1333	03-03-2026	Part of : SECTOR 27 DWARKA,NANAK HERI VILLAGE	1851	Other Outage	Planned Outage	03-03-2026	11:44	03-03-2026	14:32	2:48	0.003267	REPLACEMENT OF HT BUSHING ROD
1334	05-03-2026	Part of : GOYALA DAIRY QUTUB VIHAR,BLOCK A GOYLA VIHAR GOYLA KHURD,BLOCK A QUTUB VIHAR PHASE 1,TAJPUR KHURD	2952	Other Outage	Unplanned Outage	05-03-2026	10:40	05-03-2026	11:15	0:35	0.000501	HVDS FAULT
1335	05-03-2026	Part of : SECTOR 29 DWARKA	438	Other Outage	Planned Outage	05-03-2026	14:04	05-03-2026	15:02	0:58	0.000322	REPLACEMET OF HT BUSHING ROD
1336	05-03-2026	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI	137	Other Outage	Planned Outage	05-03-2026	10:43	05-03-2026	13:44	3:01	0.000754	DT REPLACEMENT PER DT
1337	05-03-2026	Part of : LOKESH PARK NAJAFGARH,INDRA MARKET	683	Other Outage	Planned Outage	05-03-2026	10:54	05-03-2026	13:45	2:51	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1338	05-03-2026	Part of : ROSHAN PURA NAJAFGARH,PREM NAGAR NAJAFGARH	850	Other Outage	Planned Outage	05-03-2026	11:00	05-03-2026	13:05	2:05	0.003125	REPLACEMET OF HT BUSHING ROD
1339	05-03-2026	Part of : SHYAM VIHAR I NAJAFGARH,BLOCK E SHYAM VIHAR I NAJAFGARH,BLOCK X NEW ROSHAN PURA NAJAFGARH	1473	Other Outage	Planned Outage	05-03-2026	10:13	05-03-2026	12:48	2:35	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1340	06-03-2026	Part of : SHYAM VIHAR STN 2, VILL GOELA STN 1	0	Other Outage	Unplanned Outage	06-03-2026	23:15	07-03-2026	00:00	0:45	0.000018	CABLE FAULT
1341	06-03-2026	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH EXTENSION NAJAFGARH,	847	Other Outage	Planned Outage	06-03-2026	11:28	06-03-2026	13:28	2:00	0.000500	DT REPLACEMENT PER DT
1342	06-03-2026	Part of : DHULSIRAS VILLAGE DWARKA,	672	Other Outage	Planned Outage	06-03-2026	10:46	06-03-2026	13:19	2:33	0.000850	REPLACEMET OF HT BUSHING ROD
1343	06-03-2026	Part of : CHAWLA,	449	Other Outage	Planned Outage	06-03-2026	10:22	06-03-2026	12:54	2:32	0.000633	REPLACEMET OF HT BUSHING ROD
1344	06-03-2026	Part of : ROSHAN PURA NAJAFGARH,PREM NAGAR NAJAFGARH,	219	Other Outage	Planned Outage	06-03-2026	10:58	06-03-2026	13:13	2:15	0.003000	REPLACEMET OF HT BUSHING ROD
1345	06-03-2026	Part of : DHARAMPURA NAJAFGARH,	1372	Other Outage	Planned Outage	06-03-2026	10:22	06-03-2026	12:56	2:34	0.001497	REPLACEMENT OF HT BUSHING ROD
1346	07-03-2026	Part of : INDRA MARKET,SAINIK ENCLAVE,SULTAN GARDEN,NIRMAL VIHAR DICHAON KALAN,MAHESH GARDEN NANU RAM PARK NAJAFGARH	7785	Other Outage	Unplanned Outage	07-03-2026	07:18	07-03-2026	07:50	0:32	0.001200	CABLE FAULT
1347	07-03-2026	Part of : BABA HARIDAS ENCLAVE,JHARODA KALAN,SHIV NAGAR,DICHAON KALAN,TIKRI KALAN,A-BLOCK NAVEEN PALACE JHARODA KALAN	2065	Other Outage	Planned Outage	07-03-2026	11:56	07-03-2026	12:03	0:07	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1348	07-03-2026	Part of : SECTOR 29 DWARKA	255	Other Outage	Planned Outage	07-03-2026	10:49	07-03-2026	12:00	1:11	0.001183	REPLACEMENT OF HT BUSHING ROD
1349	07-03-2026	Part of : DURGA VIHAR-II DINPUR	442	Other Outage	Planned Outage	07-03-2026	11:35	07-03-2026	14:13	2:38	0.000658	REPLACEMENT OF HT BUSHING ROD
1350	07-03-2026	Part of : NEW DHARAMPURA EXTENSION MASUDABAD NAJAFGARH	897	Other Outage	Planned Outage	07-03-2026	10:43	07-03-2026	13:21	2:38	0.000000	REPLACEMENT OF HT BUSHING ROD
1351	07-03-2026	Part of : NAJAFGARH VILLAGE	961	Other Outage	Planned Outage	07-03-2026	08:13	07-03-2026	10:34	2:21	0.002350	REPLACEMENT OF HT BUSHING ROD
1352	08-03-2026	Part of : D-BLOCK LAXMI VIHAR COLONY NANGLI SAKRAWATI	4	Other Outage	Planned Outage	08-03-2026	12:02	08-03-2026	14:41	2:39	0.000883	REPLACEMET OF HT BUSHING ROD
1353	09-03-2026	Part of : SECTOR 27 DWARKA	25	Other Outage	Planned Outage	09-03-2026	12:07	09-03-2026	13:58	1:51	0.000463	REPLACEMENT OF HT BUSHING ROD
1354	09-03-2026	Part of : GANDHI PARK DINPUR,SHIV PURI II DINPUR	2207	Other Outage	Planned Outage	09-03-2026	10:17	09-03-2026	12:50	2:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1355	09-03-2026	Part of : NAJAFGARH EXTENSION ,AJAY PARK MASUDABAD NAJAFGARH	1980	Other Outage	Planned Outage	09-03-2026	13:54	09-03-2026	17:16	3:22	0.000842	DT REPLACEMENT PER DT
1356	09-03-2026	Part of : NAJAFGARH VILLAGE,LOKESH PARK NAJAFGARH	2600	Other Outage	Planned Outage	09-03-2026	10:20	09-03-2026	13:58	3:38	0.001211	REPLACEMENT OF HT BUSHING ROD
1357	09-03-2026	Part of : ROSHAN PURA NAJAFGARH	59	Other Outage	Planned Outage	09-03-2026	10:59	09-03-2026	13:09	2:10	0.002889	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1358	09-03-2026	Part of : JANTA VIHAR HAIBUTPUR,AGARWAL COLONY HAIBUTPUR,BABA HARIDAS NAGAR	4529	Other Outage	Planned Outage	09-03-2026	11:32	09-03-2026	14:06	2:34	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1359	09-03-2026	Part of : SULTAN GARDEN,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,SAINIK ENCLAVE,NAJAFGARH VILLAGE	5166	Other Outage	Planned Outage	09-03-2026	11:27	09-03-2026	14:07	2:40	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1360	10-03-2026	Part of : NAJAFGARH EXTENSION NAJAFGARH,NATHU RAM PARK MASUDABAD NAJAFGARH,AJAY PARK MASUDABAD NAJAFGARH,	1978	Other Outage	Planned Outage	10-03-2026	14:22	10-03-2026	15:33	1:11	0.000296	DT REPLACEMET PER DT
1361	10-03-2026	Part of : ROSHAN PURA NAJAFGARH,	170	Other Outage	Planned Outage	10-03-2026	10:57	10-03-2026	12:55	1:58	0.002622	REPLACEMET OF HT BUSHING ROD
1362	10-03-2026	Part of : QUTUB VIHAR PHASE 2 QUTUB VIHAR,	427	Other Outage	Planned Outage	10-03-2026	12:24	10-03-2026	17:02	4:38	0.001544	REPLACEMET OF HT BUSHING ROD
1363	10-03-2026	Part of : RANAJI ENCLAVE MASUDABAD NAJAFGARH,JAI VIHAR COLONY MASUDABAD NAJAFGARH,	2422	Other Outage	Planned Outage	10-03-2026	10:47	10-03-2026	13:45	2:58	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1364	10-03-2026	Part of : DURGA VIHAR II DINPUR,	442	Other Outage	Planned Outage	10-03-2026	10:51	10-03-2026	12:54	2:03	0.000513	REPLACEMET OF HT BUSHING ROD
1365	10-03-2026	Part of : SHIV NAGAR NAJAFGARH,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,LOKESH PARK NAJAFGARH,	1296	Other Outage	Planned Outage	10-03-2026	11:37	10-03-2026	13:58	2:21	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1366	11-03-2026	Part of : ROSHAN PURA NAJAFGARH	339	Other Outage	Planned Outage	11-03-2026	11:14	11-03-2026	13:02	1:48	0.002400	REPLACEMENT OF HT BUSHING ROD
1367	11-03-2026	Part of : B-BLOCK INDRA PARK MASUDABAD NAJAFGARH	1406	Other Outage	Planned Outage	11-03-2026	11:34	11-03-2026	13:20	1:46	0.000589	3PH HT AB CABLE REPLACEMENT
1368	11-03-2026	Part of : SATYAMPURAM,JHARODA KALAN	895	Other Outage	Planned Outage	11-03-2026	13:31	11-03-2026	15:59	2:28	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1369	11-03-2026	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	677	Other Outage	Planned Outage	11-03-2026	10:35	11-03-2026	12:45	2:10	0.000000	3PH HT AB CABLE REPLACEMENT
1370	12-03-2026	Part of : ANAND VIHAR NANGLI SAKRAWATI	675	Other Outage	Planned Outage	12-03-2026	14:11	12-03-2026	16:05	1:54	0.000633	DT REPLACEMET
1371	12-03-2026	Part of : SECTOR 27 DWARKA	32	Other Outage	Planned Outage	12-03-2026	14:00	12-03-2026	15:36	1:36	0.001600	REPLACEMET OF HT BUSHING ROD
1372	12-03-2026	Part of : ROSHAN PURA NAJAFGARH,PREM NAGAR	850	Other Outage	Planned Outage	12-03-2026	11:42	12-03-2026	15:49	4:07	0.006175	REPLACEMENT OF HT BUSHING ROD
1373	12-03-2026	Part of : ASALETPUR KHAWAD VILLAGE	535	Other Outage	Planned Outage	12-03-2026	11:10	12-03-2026	13:18	2:08	0.001778	REPLACEMENT OF HT BUSHING ROD
1374	12-03-2026	Part of : SULTAN GARDEN,LOKESH PARK EXTN,INDRA MARKET,SAINIK ENCLAVE,NIRMAL VIHAR,MAHESH GARDEN,NANU RAM PARK,VIRENDRA MARKET,AGARWAL COLONY,NEW HIRA NAGAR,B-BLOCKLAXMI VIHAR COLONY,NAJAFGARH VILLAGE	5166	Other Outage	Planned Outage	12-03-2026	11:31	12-03-2026	14:15	2:44	0.000000	3PH HT AB CABLE REPLACEMENT
1375	12-03-2026	Part of : A-BLOCK QUTUB VIHAR PHASE-1	118	Other Outage	Planned Outage	12-03-2026	14:10	12-03-2026	16:39	2:29	0.000000	LT CIRCUIT MAINTENANCE
1376	13-03-2026	Part of : SHYAM VIHAR I NAJAFGARH,SHYAM KUNJ DINPUR	573	Other Outage	Planned Outage	13-03-2026	12:35	13-03-2026	14:49	2:14	0.000744	REPLACEMENT OF HT BUSHING ROD
1377	13-03-2026	Part of : BLOCK E & Q NEW ROSHAN PURA NAJAFGARH,DHARAMPURA NAJAFGARH	949	Other Outage	Planned Outage	13-03-2026	10:47	13-03-2026	13:43	2:56	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1378	13-03-2026	Part of : ROSHAN PURA NAJAFGARH,PREM NAGAR NAJAFGARH	219	Other Outage	Planned Outage	13-03-2026	11:08	13-03-2026	13:11	2:03	0.002733	REPLACEMENT OF HT BUSHING ROD
1379	13-03-2026	Part of : SULTAN GARDEN,SAINIK NIKETAN NAJAFGARH,NEW HEERA PARK NAJAFGARH,SHIV NAGAR NAJAFGARH,INDRA MARKET	1531	Other Outage	Planned Outage	13-03-2026	10:38	13-03-2026	13:20	2:42	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1380	13-03-2026	Part of : SULTAN GARDEN,SHIV ENCLAVE NAJAFGARH,SAINIK NIKETAN NAJAFGARH,NEW HEERA PARK NAJAFGARH,NEW HIRA NAGAR DICHAON KALAN	2542	Other Outage	Planned Outage	13-03-2026	10:39	13-03-2026	13:18	2:39	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1381	13-03-2026	Part of : GOYALA DAIRY QUTUB VIHAR	684	Other Outage	Planned Outage	13-03-2026	14:51	13-03-2026	17:02	2:11	0.000000	REPLACEMENT OF LT BUSHING ROD
1382	14-03-2026	Part of : BLOCK B POCHANPUR DWARKA,	856	Other Outage	Unplanned Outage	14-03-2026	13:43	14-03-2026	14:34	0:51	0.000283	REPAIR OF RMU
1383	14-03-2026	Part of : ARJUN PARK NANGLI SAKRAWATI,ANAND VIHAR NANGLI SAKRAWATI,	1006	Other Outage	Planned Outage	14-03-2026	14:42	14-03-2026	16:02	1:20	0.000444	DT REPLACEMET PER DT
1384	14-03-2026	Part of : TAJPUR KHURD,	283	Other Outage	Planned Outage	14-03-2026	13:46	14-03-2026	16:05	2:19	0.000000	REPLACEMENT OF LT BUSHING ROD
1385	14-03-2026	Part of : BABA HARIDAS ENCLAVE,JHARODA KALAN,SHIV NAGAR DICHAON KALAN,BABA HARI DAS ENCLAVE JHARODA KALAN,TIKRI KALAN,BLOCK A NAVEEN PALACE JHARODA KALAN,	3034	Other Outage	Planned Outage	14-03-2026	11:26	14-03-2026	14:16	2:50	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1386	14-03-2026	Part of : BHARTHAL VILLAGE DWARKA,	620	Other Outage	Planned Outage	14-03-2026	11:08	14-03-2026	13:27	2:19	0.000579	REPLACEMET OF HT BUSHING ROD
1387	14-03-2026	Part of : BADUSARAI,	408	Other Outage	Planned Outage	14-03-2026	11:01	14-03-2026	13:28	2:27	0.003675	REPLACEMET OF HT BUSHING ROD
1388	14-03-2026	Part of : NAJAFGARH VILLAGE,	957	Other Outage	Planned Outage	14-03-2026	07:21	14-03-2026	09:56	2:35	0.003444	REPLACEMET OF HT BUSHING ROD
1389	15-03-2026	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI	4	Other Outage	Planned Outage	15-03-2026	15:18	15-03-2026	17:11	1:53	0.000471	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1390	16-03-2026	Part of : B-BLOCK NAVEEN PALACE & SARASWATI KUNJ JHARODA KALAN	1291	Other Outage	Planned Outage	16-03-2026	15:53	16-03-2026	16:40	0:47	0.000000	3PH HT AB CABLE REPLACEMENT
1391	16-03-2026	Part of : ANAND VIHAR NANGLI & ARJUN PARK NANGLI SAKRAWATI	962	Other Outage	Planned Outage	16-03-2026	13:18	16-03-2026	14:37	1:19	0.000439	DT REPLACEMENT PER DT
1392	16-03-2026	Part of : NAJAFGARH VILLAGE	1	Other Outage	Planned Outage	16-03-2026	11:03	16-03-2026	13:09	2:06	0.002100	REPLACEMENT OF HT BUSHING ROD
1393	16-03-2026	Part of : SHYAM VIHAR-1 NAJAFGARH,SHYAM KUNJ DINPUR	571	Other Outage	Planned Outage	16-03-2026	11:05	16-03-2026	13:53	2:48	0.002800	REPLACEMENT OF HT BUSHING ROD
1394	16-03-2026	Part of : SANGAM VIHAR DHARAMPURA NAJAFGARH	525	Other Outage	Planned Outage	16-03-2026	10:23	16-03-2026	12:53	2:30	0.000000	3PH HT AB CABLE REPLACEMENT
1395	17-03-2026	Part of : PREM NAGAR NAJAFGARH,ROSHAN PURA NAJAFGARH	730	Other Outage	Planned Outage	17-03-2026	11:25	17-03-2026	13:23	1:58	0.001967	REPLACEMENT OF HT BUSHING ROD
1396	17-03-2026	Part of : GHASIPURA	1160	Other Outage	Planned Outage	17-03-2026	11:10	17-03-2026	14:00	2:50	0.000708	DT REPLACEMENT PER DT
1397	17-03-2026	Part of : KANGANHERI VILLAGE	637	Other Outage	Planned Outage	17-03-2026	13:54	17-03-2026	16:29	2:35	0.000431	REPLACEMENT OF HT BUSHING ROD
1398	17-03-2026	Part of : NAJAFGARH VILLAGE	957	Other Outage	Planned Outage	17-03-2026	08:03	17-03-2026	10:47	2:44	0.003644	REPLACEMENT OF HT BUSHING ROD
1399	17-03-2026	Part of : QUTUB VIHAR PHASE 2	431	Other Outage	Planned Outage	17-03-2026	11:47	17-03-2026	14:16	2:29	0.002483	REPLACEMENT OF HT BUSHING ROD
1400	17-03-2026	Part of : SULTAN GARDEN,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,SAINIK ENCLAVE	5166	Other Outage	Planned Outage	17-03-2026	11:08	17-03-2026	14:15	3:07	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1401	18-03-2026	Part of : HTC:40-MGD WATER TREATMENT PLANT-DJ, GOVT BOYS SCHOOL , DICHAO VILLAGE	4	Other Outage	Unplanned Outage	18-03-2026	00:09	18-03-2026	00:50	0:41	0.000770	BIRDAGE
1402	18-03-2026	Part of : BLOCK B POCHANPUR DWARKA,	857	Other Outage	Unplanned Outage	18-03-2026	11:49	18-03-2026	13:23	1:34	0.000131	RMU BYPASS
1403	18-03-2026	Part of : BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI,	818	Other Outage	Planned Outage	18-03-2026	14:04	18-03-2026	16:08	2:04	0.000689	REPLACEMET OF HT BUSHING ROD
1404	18-03-2026	Part of : NAJAFGARH VILLAGE,	957	Other Outage	Planned Outage	18-03-2026	11:48	18-03-2026	14:45	2:57	0.003933	REPLACEMET OF HT BUSHING ROD
1405	18-03-2026	Part of : DHARAMPURA NAJAFGARH,	1179	Other Outage	Planned Outage	18-03-2026	11:07	18-03-2026	13:48	2:41	0.000000	REPLACEMENT OF LT BUSHING ROD
1406	18-03-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR,	525	Other Outage	Planned Outage	18-03-2026	11:01	18-03-2026	13:28	2:27	0.003267	REPLACEMET OF HT BUSHING ROD
1407	18-03-2026	Part of : D K FLORICULTURE PVT LTD & 57/4	1	Other Outage	Planned Outage	18-03-2026	11:29	18-03-2026	17:14	5:45	0.005750	REPLACEMET OF HT BUSHING ROD
1408	18-03-2026	Part of : SULTAN GARDEN,SHIV ENCLAVE NAJAFGARH,SAINIK NIKETAN NAJAFGARH,NEW HEERA PARK NAJAFGARH,NEW HIRA NAGAR DICHAON KALAN,SHIV NAGAR DICHAON KALAN,DICHAON ENCLAVE DICHAON KALAN,NATHU RAM PARK MASUDABAD NAJAFGARH,NEELWAL VILLAGE,KRISHNA ENCLAVE SP ROAD AREA NAJAFGARH,BANI AIR FORCE CAMP JAI VIHAR BAPROLA,DICHAON KALAN VILLAGE DICHAON KALAN,NIRMAL VIHAR DICHAON KALAN,	2542	Other Outage	Planned Outage	18-03-2026	11:16	18-03-2026	14:25	3:09	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1409	19-03-2026	Part of : SECTOR 27 DWARKA	27	Other Outage	Planned Outage	19-03-2026	13:58	19-03-2026	15:01	1:03	0.001050	REPLACEMENT OF HT BUSHING ROD
1410	19-03-2026	Part of : DURGA VIHAR-1 & 2 DINPUR,DATA RAM PARK,MUNIRKA KUNJ,SHANTI VIHAR	1009	Other Outage	Planned Outage	19-03-2026	11:12	19-03-2026	13:29	2:17	0.003044	REPLACEMENT OF HT BUSHING ROD
1411	20-03-2026	Part of : DHULSIRAS VILLAGE DWARKA	244	Other Outage	Planned Outage	20-03-2026	16:05	20-03-2026	16:50	0:45	0.000625	REPLACEMENT OF HT BUSHING ROD
1412	20-03-2026	Part of : CHAWLA	705	Other Outage	Planned Outage	20-03-2026	14:43	20-03-2026	15:33	0:50	0.001667	SUB STATION CLEANING
1413	20-03-2026	Part of : NAJAFGARH VILLAGE	957	Other Outage	Planned Outage	20-03-2026	14:03	20-03-2026	15:08	1:05	0.000271	REPLACEMENT OF HT BUSHING ROD
1414	20-03-2026	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	174	Other Outage	Planned Outage	20-03-2026	14:13	20-03-2026	15:52	1:39	0.000000	3PH HT AB CABLE REPLACEMENT
1415	20-03-2026	Part of : SHIV ENCLAVE,SAINIK NIKETAN,SULTAN GARDEN,NEW HEERA PARK NAJAFGARH	450	Other Outage	Planned Outage	20-03-2026	12:46	20-03-2026	15:16	2:30	0.000000	3PH HT AB CABLE REPLACEMENT
1416	21-03-2026	Part of : SHYAM KUNJ DINPUR,SHYAM VIHAR I NAJAFGARH	2253	Other Outage	Unplanned Outage	21-03-2026	11:16	21-03-2026	13:03	1:47	0.000892	CONNECTION/DISCONNECTION OF LT CABLE
1417	22-03-2026	Part of : QUTUB VIHAR PHASE 2 QUTUB VIHAR,	431	Other Outage	Planned Outage	22-03-2026	11:44	22-03-2026	14:22	2:38	0.000439	REPLACEMET OF HT BUSHING ROD
1418	23-03-2026	Part of : BABA HARIDAS ENCLAVE,JHARODA KALAN,SHIV NAGAR DICHAON KALAN,BABA HARI DAS ENCLAVE JHARODA KALAN,TIKRI KALAN,A-BLOCK NAVEEN PALACE JHARODA KALAN	3034	Other Outage	Planned Outage	23-03-2026	15:13	23-03-2026	15:43	0:30	0.000000	GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE
1419	23-03-2026	Part of : SECTOR 27 DWARKA	268	Other Outage	Planned Outage	23-03-2026	13:35	23-03-2026	14:16	0:41	0.000569	REPLACEMENT OF HT BUSHING ROD
1420	23-03-2026	Part of : QUTUB VIHAR PHASE-2	431	Other Outage	Planned Outage	23-03-2026	14:14	23-03-2026	16:33	2:19	0.000386	REPLACEMENT OF HT BUSHING ROD
1421	23-03-2026	Part of : DHARAMPURA NAJAFGARH,E-BLOCK NEW ROSHAN PURA NAJAFGARH	954	Other Outage	Planned Outage	23-03-2026	13:08	23-03-2026	15:59	2:51	0.001188	3PH HT AB CABLE REPLACEMENT
1422	23-03-2026	Part of : CHAWLA	540	Other Outage	Planned Outage	23-03-2026	11:48	23-03-2026	14:39	2:51	0.003800	REPLACEMENT OF HT BUSHING ROD
1423	23-03-2026	Part of : SHYAM VIHAR-1 NAJAFGARH,SHYAM KUNJ DINPUR	571	Other Outage	Planned Outage	23-03-2026	11:21	23-03-2026	14:04	2:43	0.003622	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1424	23-03-2026	Part of : NAJAFGARH VILLAGE	1	Other Outage	Planned Outage	23-03-2026	11:02	23-03-2026	13:03	2:01	0.002689	REPLACEMENT OF HT BUSHING ROD
1425	23-03-2026	Part of : A-BLOCK QUTUB VIHAR PHASE-1	475	Other Outage	Planned Outage	23-03-2026	14:15	23-03-2026	16:34	2:19	0.000000	LT CIRCUIT MAINTENANCE
1426	24-03-2026	Part of : SHIV PURI-2,SHYAM VIHAR-2,GANDHI PARK DINPUR	2293	Other Outage	Unplanned Outage	24-03-2026	15:38	24-03-2026	16:29	0:51	0.000567	REPAIRING OF RMU
1427	24-03-2026	Part of : NAJAFGARH VILLAGE	957	Other Outage	Unplanned Outage	24-03-2026	14:21	24-03-2026	15:21	1:00	0.000333	CONNECTION/DISCONNECTION OF LT CABLE
1428	24-03-2026	Part of : NANGLI SANKRANTI & NANGLI SAKRAWATI	243	Other Outage	Planned Outage	24-03-2026	15:54	24-03-2026	17:29	1:35	0.000660	REPLACEMENT OF HT BUSHING ROD
1429	24-03-2026	Part of : SAMTA ENCLAVE QUTUB VIHAR	981	Other Outage	Planned Outage	24-03-2026	12:08	24-03-2026	14:54	2:46	0.005533	3PH HT AB CABLE REPLACEMENT
1430	24-03-2026	Part of : SHYAM VIHAR-1 NAJAFGARH,SHYAM KUNJ DINPUR	571	Other Outage	Planned Outage	24-03-2026	12:06	24-03-2026	14:57	2:51	0.001900	REPLACEMENT OF HT BUSHING ROD
1431	24-03-2026	Part of : PREM NAGAR & ROSHAN PURA NAJAFGARH	730	Other Outage	Planned Outage	24-03-2026	11:08	24-03-2026	13:16	2:08	0.002844	REPLACEMENT OF HT BUSHING ROD
1432	24-03-2026	Part of : SHYAM ENCLAVE DINPUR,E-BLOCK SHYAM VIHAR-1 NAJAFGARH	763	Other Outage	Planned Outage	24-03-2026	10:19	24-03-2026	12:56	2:37	0.000000	3PH HT AB CABLE REPLACEMENT
1433	25-03-2026	Part of : NAJAFGARH VILLAGE,SHIV ENCLAVE NAJAFGARH	5166	Other Outage	Planned Outage	25-03-2026	14:41	25-03-2026	15:39	0:58	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1434	25-03-2026	Part of : ROSHAN PURA NAJAFGARH,PREM NAGAR NAJAFGARH	850	Other Outage	Planned Outage	25-03-2026	11:26	25-03-2026	12:59	1:33	0.002067	REPLACEMENT OF HT BUSHING ROD
1435	25-03-2026	Part of : QUTUB VIHAR PHASE 2	622	Other Outage	Planned Outage	25-03-2026	15:55	25-03-2026	17:02	1:07	0.000000	REPLACEMENT OF LT BUSHING ROD
1436	25-03-2026	Part of : SHYAM ENCLAVE DINPUR,BLOCK E SHYAM VIHAR I NAJAFGARH	563	Other Outage	Planned Outage	25-03-2026	10:45	25-03-2026	13:45	3:00	0.000000	REPLACEMENT OF LT BUSHING ROD
1437	26-03-2026	Part of : INDRAN MARKET,SAINIK ENCLAVE,SULTAN GARDEN,NIRMAL VIHAR DICHAON KALAN,MAHESH GARDEN NANU RAM PARK NAJAFGARH,VIRENDRA MARKET,AGARWAL COLONY HAIBUTPUR,NEW HIRA NAGAR DICHAON KALAN,BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH VILLAGE,NAJAFGARH VILLAGE NAJAFGARH,LOKESH PARK NAJAFGARH,LOKESH PARK EXTN NAJAFGARH,SHIV ENCLAVE NAJAFGARH	8059	Other Outage	Unplanned Outage	26-03-2026	09:42	26-03-2026	09:59	0:17	0.000269	HT SYSTEM FAULT
1438	26-03-2026	Part of : VNM TALF SOLAR JHTIKRA VILLAGE	0	Other Outage	Unplanned Outage	26-03-2026	10:13	26-03-2026	10:59	0:46	0.000089	CABLE FAULT
1439	27-03-2026	Part of : CT-06 , DWARKA SEC-26 (HTC)	0	Other Outage	Unplanned Outage	27-03-2026	14:09	27-03-2026	14:59	0:50	0.000220	CABLE DAMAGED BY OUTSIDE AGENCY (MCD)
1440	27-03-2026	Part of : A & B-BLOCK POCHANPUR DWARKA	5839	Other Outage	Planned Outage	27-03-2026	15:44	27-03-2026	15:59	0:15	0.000021	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE
1441	27-03-2026	Part of : QUTUB VIHAR PHASE-2	27	Other Outage	Planned Outage	27-03-2026	12:32	27-03-2026	14:12	1:40	0.000000	LT CIRCUIT MAINTENANCE
1442	27-03-2026	Part of : SULTAN GARDEN,SHIV ENCLAVE,SAINIK NIKETAN,NEW HEERA PARK,NEW HIRA NAGAR,SHIV NAGAR,DICHAON ENCLAVE,NATHU RAM PARK,NEELWAL VILLAGE,KRISHNA ENCLAVE SP ROAD AREA,BANI AIR FORCE CAMP JAI VIHAR	2542	Other Outage	Planned Outage	27-03-2026	13:47	27-03-2026	16:28	2:41	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1443	27-03-2026	Part of : E-BLOCK SHYAM VIHAR-1,X-BLOCK NEW ROSHAN PURA NAJAFGARH	1303	Other Outage	Planned Outage	27-03-2026	11:50	27-03-2026	14:48	2:58	0.001236	REPLACEMENT OF HT BUSHING ROD
1444	27-03-2026	Part of : ROSHAN VIHAR-1 NAJAFGARH,DURGA VIHAR-1 DINPUR	525	Other Outage	Planned Outage	27-03-2026	11:05	27-03-2026	13:38	2:33	0.003400	REPLACEMENT OF HT BUSHING ROD
1445	28-03-2026	Part of : NEW HIRA NAGAR DICHAON KALAN,SHIV NAGAR DICHAON KALAN,DICHAON ENCLAVE DICHAON KALAN	3821	Other Outage	Unplanned Outage	28-03-2026	11:37	28-03-2026	12:28	0:51	0.000850	MAINTENANCE/REPAIR OF RMU
1446	28-03-2026	Part of : SECTOR 28 DWARKA	293	Other Outage	Planned Outage	28-03-2026	13:19	28-03-2026	14:06	0:47	0.000065	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE
1447	28-03-2026	Part of : NAJAFGARH EXTENSION	725	Other Outage	Planned Outage	28-03-2026	11:35	28-03-2026	13:06	1:31	0.000506	REPLACEMENT OF HT BUSHING ROD
1448	28-03-2026	Part of : PREM NAGAR NAJAFGARH,NAJAFGARH VILLAGE,ROSHAN PURA NAJAFGARH	364	Other Outage	Planned Outage	28-03-2026	11:24	28-03-2026	13:24	2:00	0.002000	REPLACEMENT OF HT BUSHING ROD
1449	30-03-2026	Part of : SECTOR 27 DWARKA,	240	Other Outage	Planned Outage	30-03-2026	15:33	30-03-2026	17:00	1:27	0.000121	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
1450	30-03-2026	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH,DHARAMPURA NAJAFGARH,BLOCK Q NEW ROSHAN PURA NAJAFGARH,	941	Other Outage	Planned Outage	30-03-2026	12:04	30-03-2026	15:01	2:57	0.001229	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1451	30-03-2026	Part of : DHARAMPURA NAJAFGARH,BLOCK E NEW ROSHAN PURA NAJAFGARH,	954	Other Outage	Planned Outage	30-03-2026	12:02	30-03-2026	15:00	2:58	0.001236	REPLACEMENT OF LT BUSHING ROD
1452	30-03-2026	Part of : CHAWLA,	540	Other Outage	Planned Outage	30-03-2026	10:10	30-03-2026	12:18	2:08	0.002844	REPLACEMENT OF LT BUSHING ROD
1453	30-03-2026	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI,	243	Other Outage	Planned Outage	30-03-2026	11:22	30-03-2026	13:29	2:07	0.000706	REPLACEMENT OF LT BUSHING ROD
1454	30-03-2026	Part of : DHARAMPURA NAJAFGARH,	838	Other Outage	Planned Outage	30-03-2026	11:01	30-03-2026	13:49	2:48	0.001167	REPLACEMENT OF HT BUSHING ROD
1455	30-03-2026	Part of : SARASWATI KUNJ JHARODA KALAN,LOKESH PARK EXTN NAJAFGARH,BLOCK B NAVEEN PALACE JHARODA KALAN,SURYA KUNJ HAIBUTPUR,LOKESH PARK NAJAFGARH,DHANAK MOHALLA HAIBUTPUR,INDRA MARKET,BABA HARIDAS ENCLAVE,KRISHNA ENCLAVE SP ROAD AREA NAJAFGARH,NEW VISION COLONY DICHAN KALAN,SARASWATI ENCLAVE HAIBUTPUR,JANTA VIHAR HAIBUTPUR,AGARWAL COLONY HAIBUTPUR,BABA HARIDAS NAGAR,EKTA VIHAR & RAJIV VIHAR,DICHAN ENCLAVE DICHAN KALAN,BABA HARIDAS ENCLAVE JHARODA KALAN	4529	Other Outage	Planned Outage	30-03-2026	11:16	30-03-2026	13:31	2:15	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1456	30-03-2026	Part of : DURGA VIHAR I DINPUR,	821	Other Outage	Planned Outage	30-03-2026	11:05	30-03-2026	13:25	2:20	0.003111	REPLACEMENT OF HT BUSHING ROD
1457	30-03-2026	Part of : SULTAN GARDEN,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,SAINIK ENCLAVE,LOKESH PARK NAJAFGARH,NIRMAL VIHAR DICHAN KALAN,MAHESH GARDEN NANU RAM PARK NAJAFGARH,VIRENDRA MARKET,AGARWAL COLONY HAIBUTPUR,NEW HIRA NAGAR DICHAN KALAN,BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH VILLAGE,NAJAFGARH VILLAGE NAJAFGARH SHIV ENCLAVE NAJAFGARH	5166	Other Outage	Planned Outage	30-03-2026	11:04	30-03-2026	13:34	2:30	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN,JUMPER REPLACEMENT PER POLE
1458	31-03-2026	Part of : ROSHAN VIHAR 1 NAJAFGARH,DURGA VIHAR I DINPUR,DURGA PARK NAJAFGARH	690	Other Outage	Planned Outage	31-03-2026	10:52	31-03-2026	13:31	2:39	0.003533	REPLACEMENT OF HT BUSHING ROD
1459	02-03-2026	Part of : WEST PUNJABI BAGH PUNJABI BAGH	861	Other Outage	Unplanned Outage	02-03-2026	08:54	02-03-2026	09:37	0:43	0.000611	ELECTROCUTION OF SQUIRREL
1460	04-03-2026	Part of : INDIRA COLONY TRI NAGAR	437	Other Outage	Unplanned Outage	04-03-2026	09:13	04-03-2026	09:57	0:44	0.000232	BIRDAGE
1461	08-03-2026	Part of : STATE BANK COLONY PASCHIM VIHAR	1920	Other Outage	Unplanned Outage	08-03-2026	05:55	08-03-2026	06:11	0:16	0.000200	CABLE DAMAGE BY OUTSIDE AGENCY (PWD)
1462	08-03-2026	Part of : JWALAHARI VILLAGE,IFCI COLONY,B 3-BLOCK PASCHIM VIHAR	1800	Other Outage	Unplanned Outage	08-03-2026	03:30	08-03-2026	04:20	0:50	0.000283	CABLE DAMAGE BY OUTSIDE AGENCY (PWD)
1463	09-03-2026	Part of : BLOCK B 1 PASCHIM VIHAR	314	Other Outage	Unplanned Outage	09-03-2026	14:50	09-03-2026	16:55	2:05	0.000347	MOBILE TRANSFORMER REPLACEMENT
1464	11-03-2026	Part of : BLOCK A 2B PASCHIM VIHAR,BLOCK A 3 CA APARTMENTS PASCHIM VIHAR,BLOCK A 2 PASCHIM VIHAR	1415	Other Outage	Unplanned Outage	11-03-2026	05:21	11-03-2026	06:11	0:50	0.000401	CABLE FAULT
1465	12-03-2026	Part of : C,E-BLOCK NEW MULTAN NAGAR SHAKURBASTI,A-BLOCK PASCHIM VIHAR,POCKET GH1 PASCHIM VIHAR,POCKET GH2 DISTRICT PARK PASCHIM VIHAR	2595	Other Outage	Unplanned Outage	12-03-2026	14:24	12-03-2026	15:15	0:51	0.000188	BIRDAGE
1466	14-03-2026	Part of : PUNJABI BAGH EXTENSION PUNJABI BAGH	870	Other Outage	Unplanned Outage	14-03-2026	18:48	14-03-2026	19:33	0:45	0.000746	HT SYSTEM FAULT
1467	16-03-2026	Part of : C-BLOCK SHIVAJI PARK PUNJABI BAGH	701	Other Outage	Planned Outage	16-03-2026	12:02	16-03-2026	15:58	3:56	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
1468	18-03-2026	Part of : BLOCK B 1 PASCHIM VIHAR,	399	Other Outage	Planned Outage	18-03-2026	11:28	18-03-2026	14:00	2:32	0.000000	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,LT AB SAGGING PER SPAN
1469	20-03-2026	Part of : STATE BANK COLONY PASCHIM VIHAR	1821	Other Outage	Unplanned Outage	20-03-2026	10:16	20-03-2026	10:58	0:42	0.000817	HT SYSTEM FAULT
1470	23-03-2026	Part of : B 1-BLOCK PASCHIM VIHAR	399	Other Outage	Planned Outage	23-03-2026	11:42	23-03-2026	14:48	3:06	0.000000	LT CIRCUIT MAINTENANCE
1471	02-03-2026	Part of : BLOCK J SAGARPUR WEST SAGARPUR,	872	Other Outage	Planned Outage	02-03-2026	14:06	02-03-2026	16:19	2:13	0.000000	REPLACEMENT OF LT BUSHING ROD
1472	02-03-2026	Part of : BLOCK J SAGARPUR WEST SAGARPUR,JAGDAMBA VIHAR SAGARPUR WEST SAGARPUR,DURGA PARK COLONY DASRATHPURI,POCKET 10 SECTOR I DASRATHPURI,BLOCK B 2 DASRATHPURI,	4856	Other Outage	Planned Outage	02-03-2026	12:12	02-03-2026	14:19	2:07	0.004233	GUARD WIRES SAGGING PER SPAN
1473	02-03-2026	Part of : SHANKAR PARK SAGARPUR EAST SAGARPUR,	634	Other Outage	Planned Outage	02-03-2026	12:25	02-03-2026	14:43	2:18	0.000767	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1474	02-03-2026	Part of : BLOCK G RAJ NAGAR 2 RAJ NAGAR,	949	Other Outage	Planned Outage	02-03-2026	11:48	02-03-2026	14:09	2:21	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1475	02-03-2026	Part of : POCKET 13 MANGALPURI II PALAM,	442	Other Outage	Planned Outage	02-03-2026	11:20	02-03-2026	13:45	2:25	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1476	02-03-2026	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,BLOCK I MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	1594	Other Outage	Planned Outage	02-03-2026	11:19	02-03-2026	13:43	2:24	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1477	03-03-2026	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM	8748	Other Outage	Unplanned Outage	03-03-2026	04:19	03-03-2026	05:03	0:44	0.000293	HVDS FAULT
1478	03-03-2026	Part of : PALAM VILLAGE	1	Other Outage	Planned Outage	03-03-2026	13:07	03-03-2026	14:21	1:14	0.000411	LT CIRCUIT MAINTENANCE
1479	03-03-2026	Part of : E-BLOCK PALAM EXTENSION	320	Other Outage	Planned Outage	03-03-2026	12:34	03-03-2026	14:12	1:38	0.000544	LT CIRCUIT MAINTENANCE
1480	03-03-2026	Part of : SECTOR 9 DWARKA	56	Other Outage	Planned Outage	03-03-2026	12:26	03-03-2026	14:10	1:44	0.000578	LT CIRCUIT MAINTENANCE
1481	05-03-2026	Part of : BLOCK A RAJ NAGAR 1	881	Other Outage	Planned Outage	05-03-2026	13:33	05-03-2026	14:44	1:11	0.000197	REPLACEMENT OF LT BUSHING ROD
1482	05-03-2026	Part of : BLOCK RZ SHIV PURI SAGARPUR WEST	1022	Other Outage	Planned Outage	05-03-2026	10:41	05-03-2026	13:15	2:34	0.000856	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1483	05-03-2026	Part of : PALAM COLONY SADH NAGAR 1	320	Other Outage	Planned Outage	05-03-2026	11:15	05-03-2026	13:57	2:42	0.000900	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1484	06-03-2026	Part of : BLOCK T GANDHI MARKET SAGARPUR,SANT MOHALLA SAGARPUR MAIN SAGARPUR,	4553	Other Outage	Unplanned Outage	06-03-2026	13:32	06-03-2026	13:41	0:09	0.000000	REPAIR OF RMU
1485	06-03-2026	Part of : POCKET 2 SECTOR 9 DWARKA,	33	Other Outage	Planned Outage	06-03-2026	14:35	06-03-2026	16:23	1:48	0.000600	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1486	06-03-2026	Part of : BLOCK A 1 VIJAY ENCLAVE MAHAVIR ENCLAVE,	818	Other Outage	Planned Outage	06-03-2026	12:26	06-03-2026	14:16	1:50	0.000611	REPLACEMENT OF LT BUSHING ROD
1487	06-03-2026	Part of : BLOCK RZ SAGARPUR,BLOCK E RAGHU NAGAR DABRI,	3787	Other Outage	Planned Outage	06-03-2026	13:32	06-03-2026	16:12	2:40	0.003556	GUARD WIRE LACS INSTALLTION PER SPAN
1488	06-03-2026	Part of : PALAM VILLAGE PALAM,	40	Other Outage	Planned Outage	06-03-2026	12:18	06-03-2026	14:37	2:19	0.000772	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1489	06-03-2026	Part of : SHANKAR PARK SAGARPUR EAST SAGARPUR,	634	Other Outage	Planned Outage	06-03-2026	12:29	06-03-2026	15:21	2:52	0.000956	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1490	06-03-2026	Part of : PALAM VILLAGE PALAM,	494	Other Outage	Planned Outage	06-03-2026	11:45	06-03-2026	14:36	2:51	0.000950	REPLACEMENT OF LT BUSHING ROD
1491	06-03-2026	Part of : SECTOR 9 DWARKA,	116	Other Outage	Planned Outage	06-03-2026	11:07	06-03-2026	13:49	2:42	0.000900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1492	06-03-2026	Part of : BLOCK T GANDHI MARKET SAGARPUR,	753	Other Outage	Planned Outage	06-03-2026	10:36	06-03-2026	13:28	2:52	0.000956	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF LT BUSHING ROD
1493	07-03-2026	Part of : PALAM VIHAR SADH NAGAR-1	739	Other Outage	Planned Outage	07-03-2026	13:06	07-03-2026	14:43	1:37	0.000539	LT CIRCUIT MAINTENANCE
1494	07-03-2026	Part of : POCKET 2 SECTOR 9 DWARKA	43	Other Outage	Planned Outage	07-03-2026	13:03	07-03-2026	14:44	1:41	0.000561	LT CIRCUIT MAINTENANCE
1495	07-03-2026	Part of : BALMIKI VIHAR SADH NAGAR-2 PALAM	1187	Other Outage	Planned Outage	07-03-2026	10:25	07-03-2026	11:54	1:29	0.000494	LT CIRCUIT MAINTENANCE
1496	08-03-2026	Part of : F-BLOCK RAJ NAGAR EXTENSION,A & B-BLOCK SECTOR 8 DWARKA,BAGDAULA VILLAGE,POCKET 2 SECTOR 9 DWARKA	6069	Other Outage	Unplanned Outage	08-03-2026	13:05	08-03-2026	13:42	0:37	0.000288	TREE TOUCHING
1497	09-03-2026	Part of : BLOCK RZ SAGARPUR,BLOCK G SAGARPUR WEST SAGARPUR	3295	Other Outage	Unplanned Outage	09-03-2026	12:54	09-03-2026	13:32	0:38	0.000274	BIRDAGE
1498	09-03-2026	Part of : SADH NAGAR II PALAM	561	Other Outage	Planned Outage	09-03-2026	13:55	09-03-2026	14:52	0:57	0.000158	REPLACEMENT OF HT BUSHING ROD
1499	09-03-2026	Part of : BLOCK A SADH NAGAR II PALAM	634	Other Outage	Planned Outage	09-03-2026	10:29	09-03-2026	13:01	2:32	0.000844	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1500	09-03-2026	Part of : BLOCK B RAJ NAGAR 2	181	Other Outage	Planned Outage	09-03-2026	11:19	09-03-2026	14:10	2:51	0.000950	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1501	09-03-2026	Part of : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE	668	Other Outage	Planned Outage	09-03-2026	11:58	09-03-2026	14:35	2:37	0.001308	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
1502	09-03-2026	Part of : BLOCK J PALAM	1473	Other Outage	Planned Outage	09-03-2026	11:07	09-03-2026	13:54	2:47	0.000928	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1503	09-03-2026	Part of : BLOCK J SAGARPUR WEST	872	Other Outage	Planned Outage	09-03-2026	10:57	09-03-2026	13:50	2:53	0.000961	REPLACEMENT OF LT BUSHING ROD
1504	09-03-2026	Part of : SHANKAR PARK SAGARPUR EAST	635	Other Outage	Planned Outage	09-03-2026	12:23	09-03-2026	14:50	2:27	0.000817	REPLACEMENT OF LT BUSHING ROD
1505	10-03-2026	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1372	Other Outage	Planned Outage	10-03-2026	15:20	10-03-2026	16:21	1:01	0.000169	REPLACEMENT OF FAULTY END BOX
1506	10-03-2026	Part of : POCKET 2 SECTOR 9 DWARKA,	109	Other Outage	Planned Outage	10-03-2026	14:05	10-03-2026	15:21	1:16	0.000211	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1507	10-03-2026	Part of : DABRI EXTENSION EAST DABRI,	58	Other Outage	Planned Outage	10-03-2026	12:11	10-03-2026	15:01	2:50	0.000944	REPLACEMENT OF LT BUSHING ROD
1508	10-03-2026	Part of : BAGDAULA VILLAGE SECTOR 8 DWARKA,	480	Other Outage	Planned Outage	10-03-2026	11:04	10-03-2026	13:57	2:53	0.000961	REPLACEMENT OF LT BUSHING ROD
1509	10-03-2026	Part of : DABRI EXTENSION EAST DABRI,	1081	Other Outage	Planned Outage	10-03-2026	11:34	10-03-2026	14:28	2:54	0.000967	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1510	10-03-2026	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,BLOCK RZ KAMAL PARK KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM,	2618	Other Outage	Planned Outage	10-03-2026	10:41	10-03-2026	12:43	2:02	0.000678	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,LT BUSHING REPLACEMENT
1511	11-03-2026	Part of : DABRI EXTENSION EAST	58	Other Outage	Planned Outage	11-03-2026	12:58	11-03-2026	15:48	2:50	0.000944	LT CIRCUIT MAINTENANCE
1512	11-03-2026	Part of : JAGDAMBA VIHAR SAGARPUR WEST	1396	Other Outage	Planned Outage	11-03-2026	13:13	11-03-2026	15:17	2:04	0.000689	LT CIRCUIT MAINTENANCE
1513	11-03-2026	Part of : RZB-BLOCK SABZI MANDI SAGARPUR MAIN	354	Other Outage	Planned Outage	11-03-2026	13:22	11-03-2026	16:02	2:40	0.000889	LT CIRCUIT MAINTENANCE
1514	11-03-2026	Part of : B-BLOCK RAJ NAGAR-2	593	Other Outage	Planned Outage	11-03-2026	11:03	11-03-2026	13:54	2:51	0.000950	LT CIRCUIT MAINTENANCE
1515	11-03-2026	Part of : SECTOR 9 DWARKA	18	Other Outage	Planned Outage	11-03-2026	11:02	11-03-2026	13:23	2:21	0.000783	LT CIRCUIT MAINTENANCE
1516	11-03-2026	Part of : B 3-BLOCK MAHAVIR ENCLAVE PART 1	1326	Other Outage	Planned Outage	11-03-2026	11:42	11-03-2026	14:09	2:27	0.000817	LT CIRCUIT MAINTENANCE
1517	11-03-2026	Part of : VAISHALI EXTENSION DASRATHPURI	355	Other Outage	Planned Outage	11-03-2026	11:54	11-03-2026	14:41	2:47	0.000928	LT CIRCUIT MAINTENANCE
1518	12-03-2026	Part of : A,H & R-BLOCK DABRI EXTENSION EAST,SYNDICATE ENCLAVE	7733	Other Outage	Planned Outage	12-03-2026	14:10	12-03-2026	16:04	1:54	0.000633	GUARD WIRES SAGGING P
1519	12-03-2026	Part of : SECTOR 9 DWARKA	50	Other Outage	Planned Outage	12-03-2026	11:47	12-03-2026	13:11	1:24	0.000233	LT CIRCUIT MAINTENANCE
1520	12-03-2026	Part of : SHANKAR PARK SAGARPUR EAST	635	Other Outage	Planned Outage	12-03-2026	13:13	12-03-2026	16:05	2:52	0.000956	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1521	12-03-2026	Part of : J-BLOCK SAGARPUR WEST	872	Other Outage	Planned Outage	12-03-2026	12:28	12-03-2026	15:21	2:53	0.000961	LT CIRCUIT MAINTENANCE
1522	12-03-2026	Part of : T-BLOCK GANDHI MARKET SAGARPUR	1694	Other Outage	Planned Outage	12-03-2026	11:08	12-03-2026	14:04	2:56	0.000978	LT CIRCUIT MAINTENANCE
1523	12-03-2026	Part of : G 1-BLOCK MAHAVIR ENCLAVE PART-1	1797	Other Outage	Planned Outage	12-03-2026	11:34	12-03-2026	14:22	2:48	0.000933	LT CIRCUIT MAINTENANCE
1524	12-03-2026	Part of : J-BLOCK RAJ NAGAR-2	1410	Other Outage	Planned Outage	12-03-2026	11:33	12-03-2026	14:26	2:53	0.000961	LT CIRCUIT MAINTENANCE
1525	13-03-2026	Part of : MANGALPURI I PALAM,BLOCK D RAJ NAGAR 1 RAJ NAGAR	3940	Other Outage	Unplanned Outage	13-03-2026	01:06	13-03-2026	01:41	0:35	0.000476	CABLE DAMAGED BY OUT SIDE AGENCY (DJB)
1526	13-03-2026	Part of : SECTOR 9 DWARKA	15	Other Outage	Planned Outage	13-03-2026	15:36	13-03-2026	16:05	0:29	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1527	13-03-2026	Part of : BLOCK J SAGARPUR WEST	818	Other Outage	Planned Outage	13-03-2026	11:13	13-03-2026	12:07	0:54	0.000450	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1528	13-03-2026	Part of : ITL PUBLIC SCHOOL (HTC), SEC-9, DWK	1	Other Outage	Planned Outage	13-03-2026	14:01	13-03-2026	15:09	1:08	0.000000	REPLACEMENT OF FAULTY END BOX
1529	13-03-2026	Part of : BLOCK B RAJ NAGAR 2 RAJ NAGAR	1496	Other Outage	Planned Outage	13-03-2026	13:49	13-03-2026	15:39	1:50	0.000000	REPLACEMENT OF LT BUSHING ROD
1530	13-03-2026	Part of : BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR	637	Other Outage	Planned Outage	13-03-2026	10:55	13-03-2026	12:38	1:43	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1531	13-03-2026	Part of : SECTOR 9 DWARKA	104	Other Outage	Planned Outage	13-03-2026	10:57	13-03-2026	12:46	1:49	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1532	13-03-2026	Part of : SADH NAGAR II PALAM	561	Other Outage	Planned Outage	13-03-2026	13:57	13-03-2026	16:16	2:19	0.000000	REPLACEMENT OF LT BUSHING ROD
1533	13-03-2026	Part of : BLOCK C MAHAVIR ENCLAVE PART 1	997	Other Outage	Planned Outage	13-03-2026	12:03	13-03-2026	14:49	2:46	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1534	13-03-2026	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN SAGARPUR	354	Other Outage	Planned Outage	13-03-2026	11:49	13-03-2026	14:56	3:07	0.000000	REPLACEMENT OF LT BUSHING ROD
1535	13-03-2026	Part of : BLOCK F RAJ NAGAR EXTENSION	1326	Other Outage	Planned Outage	13-03-2026	10:56	13-03-2026	12:57	2:01	0.000000	REPLACEMENT OF LT BUSHING ROD
1536	14-03-2026	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR,NAVEEN KUNJ SOCIETY NARSIRPUR	3868	Other Outage	Unplanned Outage	14-03-2026	16:24	14-03-2026	16:56	0:32	0.000147	HVDS FAULT
1537	14-03-2026	Part of : SADH NAGAR II PALAM,	256	Other Outage	Planned Outage	14-03-2026	15:38	14-03-2026	16:53	1:15	0.000417	REPLACEMENT OF LT BUSHING ROD
1538	14-03-2026	Part of : BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR,	8	Other Outage	Planned Outage	14-03-2026	13:41	14-03-2026	14:49	1:08	0.000189	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1539	14-03-2026	Part of : HTC:SEC-7 BHARMA APPTT	1	Other Outage	Planned Outage	14-03-2026	11:19	14-03-2026	13:00	1:41	0.000561	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF FAULTY END BOX
1540	14-03-2026	Part of : DABRI EXTENSION EAST DABRI,	58	Other Outage	Planned Outage	14-03-2026	14:00	14-03-2026	16:52	2:52	0.000956	REPLACEMENT OF LT BUSHING ROD
1541	14-03-2026	Part of : POCKET 13 MANGALPURI II PALAM,	442	Other Outage	Planned Outage	14-03-2026	11:18	14-03-2026	13:40	2:22	0.000789	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1542	14-03-2026	Part of : BLOCK A SITAPURI PART 1 SITAPURI,	965	Other Outage	Planned Outage	14-03-2026	11:54	14-03-2026	14:48	2:54	0.000967	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1543	14-03-2026	Part of : BLOCK D RAJ NAGAR 1 RAJ NAGAR,	900	Other Outage	Planned Outage	14-03-2026	11:41	14-03-2026	14:35	2:54	0.000967	REPLACEMENT OF LT BUSHING ROD
1544	15-03-2026	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN SAGARPUR	530	Other Outage	Planned Outage	15-03-2026	14:01	15-03-2026	16:33	2:32	0.000844	REPLACEMENT OF LT BUSHING ROD
1545	16-03-2026	Part of : DABRI EXTENSION EAST,H-BLOCK RAGHU NAGAR,SYNDICATE ENCLAVE	8214	Other Outage	Unplanned Outage	16-03-2026	15:09	16-03-2026	15:39	0:30	0.000472	CABLE DAMAGE BY OUTSIDE AGENCY (PWD)
1546	16-03-2026	Part of : POCKET 6 SECTOR 1 NARSIRPUR	246	Other Outage	Planned Outage	16-03-2026	13:56	16-03-2026	15:07	1:11	0.000197	LT CIRCUIT MAINTENANCE
1547	16-03-2026	Part of : R-BLOCK INDRA PARK PALEM KAILASHPURI MAIN	1598	Other Outage	Planned Outage	16-03-2026	11:39	16-03-2026	13:38	1:59	0.000661	LT CIRCUIT MAINTENANCE
1548	16-03-2026	Part of : G-BLOCK PALAM EXTENSION	476	Other Outage	Planned Outage	16-03-2026	11:48	16-03-2026	13:39	1:51	0.000617	LT CIRCUIT MAINTENANCE
1549	16-03-2026	Part of : SHANKAR PARK SAGARPUR EAST	635	Other Outage	Planned Outage	16-03-2026	13:59	16-03-2026	16:49	2:50	0.000944	LT CIRCUIT MAINTENANCE
1550	16-03-2026	Part of : SADH NAGAR 2 PALAM	187	Other Outage	Planned Outage	16-03-2026	13:52	16-03-2026	16:47	2:55	0.000972	LT CIRCUIT MAINTENANCE
1551	16-03-2026	Part of : BAGDAULA VILLAGE SECTOR 8 DWARKA	416	Other Outage	Planned Outage	16-03-2026	12:24	16-03-2026	15:14	2:50	0.000944	LT CIRCUIT MAINTENANCE
1552	16-03-2026	Part of : A-BLOCK SITAPURI PART-1	991	Other Outage	Planned Outage	16-03-2026	12:13	16-03-2026	15:06	2:53	0.000961	LT CIRCUIT MAINTENANCE
1553	16-03-2026	Part of : A-BLOCK RAJ NAGAR-1	879	Other Outage	Planned Outage	16-03-2026	11:05	16-03-2026	14:01	2:56	0.000978	LT CIRCUIT MAINTENANCE
1554	16-03-2026	Part of : E-BLOCK SITAPURI PART-1	716	Other Outage	Planned Outage	16-03-2026	11:25	16-03-2026	14:18	2:53	0.000961	LT CIRCUIT MAINTENANCE
1555	17-03-2026	Part of : PALAM VIHAR SADH NAGAR 1	2747	Other Outage	Unplanned Outage	17-03-2026	02:27	17-03-2026	03:02	0:35	0.000205	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1556	17-03-2026	Part of : BLOCK D RAJ NAGAR 1	1805	Other Outage	Unplanned Outage	17-03-2026	01:36	17-03-2026	02:12	0:36	0.000196	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1557	17-03-2026	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	780	Other Outage	Planned Outage	17-03-2026	13:32	17-03-2026	14:40	1:08	0.000378	REPLACEMENT OF LT BUSHING ROD
1558	17-03-2026	Part of : BLOCK B RAJ NAGAR 2	594	Other Outage	Planned Outage	17-03-2026	11:51	17-03-2026	13:20	1:29	0.000247	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF LT BUSHING ROD
1559	17-03-2026	Part of : BLOCK E PALAM EXTENSION	320	Other Outage	Planned Outage	17-03-2026	11:42	17-03-2026	13:20	1:38	0.000544	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
1560	17-03-2026	Part of : BLOCK E SITAPURI PART 1	716	Other Outage	Planned Outage	17-03-2026	13:42	17-03-2026	14:59	1:17	0.000214	REPLACEMENT OF LT BUSHING ROD
1561	17-03-2026	Part of : SECTOR 8 DWARKA	316	Other Outage	Planned Outage	17-03-2026	10:42	17-03-2026	12:02	1:20	0.000222	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
1562	17-03-2026	Part of : BLOCK A MAHAVIR ENCLAVE,VAISHALI COLONY DASRATHPURI	3473	Other Outage	Planned Outage	17-03-2026	12:27	17-03-2026	15:01	2:34	0.001283	GUARD WIRE LACS INSTALLTION PER SPAN
1563	17-03-2026	Part of : BLOCK A SITAPURI PART 1	965	Other Outage	Planned Outage	17-03-2026	13:41	17-03-2026	16:38	2:57	0.000492	REPLACEMENT OF LT BUSHING ROD
1564	17-03-2026	Part of : BLOCK B RAJ NAGAR 2	182	Other Outage	Planned Outage	17-03-2026	11:15	17-03-2026	14:09	2:54	0.000967	REPLACEMENT OF LT BUSHING ROD
1565	17-03-2026	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN	530	Other Outage	Planned Outage	17-03-2026	12:10	17-03-2026	15:00	2:50	0.000944	REPLACEMENT OF LT BUSHING ROD
1566	17-03-2026	Part of : SADH NAGAR II PALAM	547	Other Outage	Planned Outage	17-03-2026	13:05	17-03-2026	15:59	2:54	0.000967	REPLACEMENT OF LT BUSHING ROD
1567	17-03-2026	Part of : VEER NAGAR SAGARPUR WEST	1279	Other Outage	Planned Outage	17-03-2026	10:49	17-03-2026	13:19	2:30	0.000833	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
1568	18-03-2026	Part of : SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR	2935	Other Outage	Unplanned Outage	18-03-2026	19:03	18-03-2026	19:29	0:26	0.000542	HVDS FAULT
1569	18-03-2026	Part of : PALAM COLONY SADH NAGAR 1 PALAM,SADH NAGAR II PALAM,KHERA VILLAGE SADH NAGAR 1 PALAM,BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM	3953	Other Outage	Unplanned Outage	18-03-2026	10:24	18-03-2026	10:59	0:35	0.000481	BIRDAGE
1570	18-03-2026	Part of : BLOCK B RAJ NAGAR 2 RAJ NAGAR,	769	Other Outage	Planned Outage	18-03-2026	15:01	18-03-2026	16:17	1:16	0.000211	REPLACEMENT OF LT BUSHING ROD
1571	18-03-2026	Part of : BLOCK A MAHAVIR ENCLAVE,VAISHALI COLONY DASRATHPURI,BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE,	3473	Other Outage	Planned Outage	18-03-2026	14:04	18-03-2026	15:14	1:10	0.000389	GUARD WIRES SAGGING PER SPAN
1572	18-03-2026	Part of : BLOCK A MAHAVIR ENCLAVE,BLOCK B 2 DASRATHPURI,VAISHALI COLONY DASRATHPURI,DURGA PARK COLONY DASRATHPURI,DABRI VILLAGE DABRI,POCKET 10 SECTOR I DASRATHPURI,BLOCK C DASRATHPURI,BLOCK F DASRATHPURI,	4945	Other Outage	Planned Outage	18-03-2026	14:12	18-03-2026	15:15	1:03	0.000350	GUARD WIRES SAGGING PER SPAN
1573	18-03-2026	Part of : BLOCK RZ PALAM,	6	Other Outage	Planned Outage	18-03-2026	12:17	18-03-2026	14:04	1:47	0.000297	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD.SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1574	18-03-2026	Part of : POCKET 2 SECTOR 9 DWARKA,	48	Other Outage	Planned Outage	18-03-2026	11:25	18-03-2026	12:51	1:26	0.000239	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1575	18-03-2026	Part of : POCKET 2 SECTOR 9 DWARKA,	43	Other Outage	Planned Outage	18-03-2026	11:26	18-03-2026	12:53	1:27	0.000242	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1576	18-03-2026	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN SAGARPUR,	530	Other Outage	Planned Outage	18-03-2026	13:59	18-03-2026	16:56	2:57	0.000983	REPLACEMENT OF LT BUSHING ROD
1577	18-03-2026	Part of : BLOCK A SITAPURI PART 1 SITAPURI,	991	Other Outage	Planned Outage	18-03-2026	11:23	18-03-2026	14:11	2:48	0.000933	REPLACEMENT OF LT BUSHING ROD
1578	18-03-2026	Part of : BLOCK G RAJ NAGAR 2 RAJ NAGAR,	728	Other Outage	Planned Outage	18-03-2026	11:17	18-03-2026	14:10	2:53	0.000961	REPLACEMENT OF LT BUSHING ROD
1579	18-03-2026	Part of : BLOCK C SADH NAGAR II PALAM,	1855	Other Outage	Planned Outage	18-03-2026	10:36	18-03-2026	13:33	2:57	0.000983	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1580	19-03-2026	Part of : SECTOR 8 DWARKA,BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR	2935	Other Outage	Unplanned Outage	19-03-2026	20:36	19-03-2026	21:13	0:37	0.000658	HVDS FAULT
1581	19-03-2026	Part of : PALAM EXTENSION	58	Other Outage	Planned Outage	19-03-2026	12:07	19-03-2026	13:47	1:40	0.000278	AUXILARY SUPPLY FOR RELAYS,CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF FAULTY END BOX
1582	19-03-2026	Part of : A-BLOCK SITAPURI PART-1	837	Other Outage	Planned Outage	19-03-2026	14:08	19-03-2026	15:53	1:45	0.000583	LT CIRCUIT MAINTENANCE
1583	19-03-2026	Part of : A-BLOCK SADH NAGAR-2 PALAM	634	Other Outage	Planned Outage	19-03-2026	12:33	19-03-2026	14:17	1:44	0.000578	LT CIRCUIT MAINTENANCE
1584	19-03-2026	Part of : SECTOR 21 DWARKA	3	Other Outage	Planned Outage	19-03-2026	12:03	19-03-2026	13:46	1:43	0.000286	LT CIRCUIT MAINTENANCE
1585	19-03-2026	Part of : SADH NAGAR-2 PALAM	563	Other Outage	Planned Outage	19-03-2026	13:14	19-03-2026	16:01	2:47	0.000928	LT CIRCUIT MAINTENANCE
1586	19-03-2026	Part of : RZB-BLOCK SABZI MANDI SAGARPUR MAIN	354	Other Outage	Planned Outage	19-03-2026	12:48	19-03-2026	15:38	2:50	0.000944	LT CIRCUIT MAINTENANCE
1587	19-03-2026	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST	1667	Other Outage	Planned Outage	19-03-2026	12:43	19-03-2026	15:37	2:54	0.000967	LT CIRCUIT MAINTENANCE
1588	19-03-2026	Part of : B-BLOCK RAJ NAGAR-2	594	Other Outage	Planned Outage	19-03-2026	11:42	19-03-2026	14:38	2:56	0.000978	LT CIRCUIT MAINTENANCE
1589	19-03-2026	Part of : F-BLOCK RAJ NAGAR EXTENSION	1326	Other Outage	Planned Outage	19-03-2026	11:43	19-03-2026	14:35	2:52	0.000956	LT CIRCUIT MAINTENANCE
1590	20-03-2026	Part of : I-BLOCK RAGHU ENCLAVE DABRI EXTENSION EAST	2043	Other Outage	Unplanned Outage	20-03-2026	16:22	20-03-2026	17:00	0:38	0.000232	CABLE FAULT
1591	21-03-2026	Part of : BLOCK A,B & E SITAPURI PART 1	1768	Other Outage	Unplanned Outage	21-03-2026	04:48	21-03-2026	05:26	0:38	0.000202	CABLE FAULT
1592	21-03-2026	Part of : PALAM COLONY SADH NAGAR 1 PALAM,KHERA VILLAGE SADH NAGAR 1 PALAM	2164	Other Outage	Planned Outage	21-03-2026	10:45	21-03-2026	12:25	1:40	0.000556	GUARD WIRES SAGGING PER SPAN
1593	21-03-2026	Part of : SADH NAGAR II PALAM	196	Other Outage	Planned Outage	21-03-2026	12:51	21-03-2026	15:40	2:49	0.000939	REPLACEMENT OF LT BUSHING ROD
1594	21-03-2026	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN	354	Other Outage	Planned Outage	21-03-2026	11:48	21-03-2026	14:56	3:08	0.001044	REPLACEMENT OF LT BUSHING ROD
1595	23-03-2026	Part of : F-BLOCK RAJ NAGAR EXTENSION	1263	Other Outage	Planned Outage	23-03-2026	14:38	23-03-2026	16:22	1:44	0.000289	REPLACEMENT OF FAULTY END BOX
1596	23-03-2026	Part of : SADH NAGAR-2 PALAM	549	Other Outage	Planned Outage	23-03-2026	13:15	23-03-2026	14:22	1:07	0.000186	LT CIRCUIT MAINTENANCE
1597	23-03-2026	Part of : BAGDAULA VILLAGE SECTOR 8 DWARKA	416	Other Outage	Planned Outage	23-03-2026	13:52	23-03-2026	15:30	1:38	0.000544	LT CIRCUIT MAINTENANCE
1598	23-03-2026	Part of : RZB-BLOCK SABZI MANDI SAGARPUR MAIN	531	Other Outage	Planned Outage	23-03-2026	12:13	23-03-2026	15:04	2:51	0.000950	LT CIRCUIT MAINTENANCE
1599	23-03-2026	Part of : D-BLOCK RAJ NAGAR-1	881	Other Outage	Planned Outage	23-03-2026	11:01	23-03-2026	13:51	2:50	0.000944	LT CIRCUIT MAINTENANCE
1600	24-03-2026	Part of : SANT MOHALLA SAGARPUR MAIN	1614	Other Outage	Planned Outage	24-03-2026	11:33	24-03-2026	12:55	1:22	0.000456	REPLACEMENT OF FAULTY END BOX
1601	24-03-2026	Part of : SECTOR 9 DWARKA	52	Other Outage	Planned Outage	24-03-2026	13:01	24-03-2026	14:24	1:23	0.000231	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1602	24-03-2026	Part of : J-BLOCK PALAM	86	Other Outage	Planned Outage	24-03-2026	11:42	24-03-2026	13:22	1:40	0.000556	LT CIRCUIT MAINTENANCE
1603	24-03-2026	Part of : POCKET B KAILASHPURI EAST,INDIRA PARK EXTENSION	1802	Other Outage	Planned Outage	24-03-2026	11:27	24-03-2026	14:21	2:54	0.000967	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING
1604	24-03-2026	Part of : RZB-BLOCK SABZI MANDI SAGARPUR MAIN	531	Other Outage	Planned Outage	24-03-2026	13:35	24-03-2026	16:25	2:50	0.000944	LT CIRCUIT MAINTENANCE
1605	24-03-2026	Part of : B-BLOCK RAJ NAGAR-2	1323	Other Outage	Planned Outage	24-03-2026	11:29	24-03-2026	14:23	2:54	0.000967	LT CIRCUIT MAINTENANCE
1606	24-03-2026	Part of : C-BLOCK DASRATHPURI	39	Other Outage	Planned Outage	24-03-2026	11:42	24-03-2026	14:32	2:50	0.000944	LT CIRCUIT MAINTENANCE
1607	25-03-2026	Part of : SECTOR 8 DWARKA	1	Other Outage	Planned Outage	25-03-2026	13:02	25-03-2026	13:37	0:35	0.000194	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1608	25-03-2026	Part of : BLOCK A RAJ NAGAR 1	881	Other Outage	Planned Outage	25-03-2026	12:14	25-03-2026	13:46	1:32	0.000511	REPLACEMENT OF LT BUSHING ROD
1609	25-03-2026	Part of : SECTOR 8 DWARKA	2	Other Outage	Planned Outage	25-03-2026	11:57	25-03-2026	13:07	1:10	0.000389	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1610	25-03-2026	Part of : BLOCK C SADH NAGAR II PALAM	924	Other Outage	Planned Outage	25-03-2026	13:07	25-03-2026	15:53	2:46	0.000922	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1611	25-03-2026	Part of : BLOCK E SITAPURI PART 1	1113	Other Outage	Planned Outage	25-03-2026	11:28	25-03-2026	14:02	2:34	0.000856	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
1612	25-03-2026	Part of : BLOCK WZ RAJ NAGAR 2	479	Other Outage	Planned Outage	25-03-2026	11:27	25-03-2026	14:38	3:11	0.001061	REPLACEMENT OF LT BUSHING ROD
1613	26-03-2026	Part of : KAILASHPURI WEST PALAM,KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION KAILASHPURI MAIN PALAM,	2053	Other Outage	Planned Outage	26-03-2026	11:31	26-03-2026	13:34	2:03	0.000683	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,LT BUSHING REPLACEMENT
1614	27-03-2026	Part of : BLOCK B RAJ NAGAR 2 RAJ NAGAR,SECTOR 20 DWARKA	1325	Other Outage	Unplanned Outage	27-03-2026	14:15	27-03-2026	14:55	0:40	0.000551	CABLE DAMAGED BY OUTSIDE AGENCY (MCD)
1615	27-03-2026	Part of : BLOCK RZ SAINIPURA RAJ NAGAR 1 RAJ NAGAR	164	Other Outage	Unplanned Outage	27-03-2026	14:12	27-03-2026	14:54	0:42	0.000050	CABLE DAMAGED BY OUTSIDE AGENCY (MCD)
1616	27-03-2026	Part of : SPG COMPLEX SECT-21 DWARKA	0	Other Outage	Unplanned Outage	27-03-2026	14:10	27-03-2026	14:53	0:43	0.000024	CABLE DAMAGED BY OUTSIDE AGENCY (MCD)
1617	27-03-2026	Part of : PALAM VILLAGE PALAM	745	Other Outage	Unplanned Outage	27-03-2026	04:30	27-03-2026	05:15	0:45	0.001175	CABLE DAMAGED BY OUTSIDE AGENCY (PWD)
1618	27-03-2026	Part of : RZ-BLOCK GEETANJALI PARK SAGARPUR WEST	1779	Other Outage	Planned Outage	27-03-2026	12:54	27-03-2026	13:53	0:59	0.000164	REPLACEMENT OF FAULTY END BOX
1619	27-03-2026	Part of : SECTOR 9 DWARKA	83	Other Outage	Planned Outage	27-03-2026	15:10	27-03-2026	16:34	1:24	0.000233	LT CIRCUIT MAINTENANCE
1620	27-03-2026	Part of : PALAM VILLAGE	979	Other Outage	Planned Outage	27-03-2026	12:59	27-03-2026	14:39	1:40	0.000278	LT CIRCUIT MAINTENANCE
1621	27-03-2026	Part of : B-BLOCK RAJ NAGAR-2	1913	Other Outage	Planned Outage	27-03-2026	11:29	27-03-2026	14:38	3:09	0.001050	LT CIRCUIT MAINTENANCE
1622	28-03-2026	Part of : MAHAVIR ENCLAVE PART 2, PALAM COLONY MAHAVIR ENCLAVE PART 2	5244	Other Outage	Unplanned Outage	28-03-2026	20:11	28-03-2026	20:35	0:24	0.000267	HVDS FAULT
1623	28-03-2026	Part of : BLOCK A1 & B VIJAY ENCLAVE MAHAVIR ENCLAVE,BLOCK A MAHAVIR ENCLAVE PART 1	749	Other Outage	Planned Outage	28-03-2026	11:45	28-03-2026	13:34	1:49	0.000303	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN
1624	28-03-2026	Part of : TAMILAR ENCLAVE VIJAY ENCLAVE MAHAVIR ENCLAVE	442	Other Outage	Planned Outage	28-03-2026	11:44	28-03-2026	13:33	1:49	0.000606	CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD
1625	28-03-2026	Part of : BLOCK F RAJ NAGAR EXTENSION	1267	Other Outage	Planned Outage	28-03-2026	11:00	28-03-2026	13:57	2:57	0.000983	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
1626	28-03-2026	Part of : BLOCK RZ SAGARPUR	1478	Other Outage	Planned Outage	28-03-2026	11:09	28-03-2026	14:06	2:57	0.000983	REPLACEMET OF HT BUSHING ROD
1627	30-03-2026	Part of : BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	578	Other Outage	Planned Outage	30-03-2026	13:04	30-03-2026	14:19	1:15	0.000208	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD
1628	30-03-2026	Part of : BLOCK H RAGHU NAGAR DABRI,	1282	Other Outage	Planned Outage	30-03-2026	12:11	30-03-2026	15:05	2:54	0.000967	REPLACEMENT OF LT BUSHING ROD
1629	30-03-2026	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1362	Other Outage	Planned Outage	30-03-2026	11:02	30-03-2026	14:18	3:16	0.001089	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1630	30-03-2026	Part of : POCKET 13 MANGALPURI II PALAM,	442	Other Outage	Planned Outage	30-03-2026	10:24	30-03-2026	13:06	2:42	0.000900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1631	31-03-2026	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,BLOCK RZ KAMAL PARK KAILASHPURI MAIN PALAM	4452	Other Outage	Unplanned Outage	31-03-2026	22:09	31-03-2026	23:03	0:54	0.000692	CABLE FAULT
1632	01-03-2026	Part of : BLOCK 4A TILAK NAGAR,BLOCK 2 TILAK NAGAR	433	Other Outage	Unplanned Outage	01-03-2026	12:12	01-03-2026	12:23	0:11	0.000031	SHIFTING OF CABLE
1633	01-03-2026	Part of : BLOCK 4A,6,7 & 8 TILAK NAGAR,BLOCK 9 NURSERY TILAK NAGAR	1586	Other Outage	Unplanned Outage	01-03-2026	12:17	01-03-2026	13:39	1:22	0.000228	SHIFTING OF CABLE
1634	01-03-2026	Part of : BLOCK S & WZ KHAYALA VISHNU GARDEN,BLOCK I KHAYALA VILLAGE KHAYALA	3202	Other Outage	Unplanned Outage	01-03-2026	11:43	01-03-2026	13:18	1:35	0.000264	SHIFTING OF CABLE
1635	01-03-2026	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN	79	Other Outage	Planned Outage	01-03-2026	12:30	01-03-2026	14:24	1:54	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1636	01-03-2026	Part of : BLOCK J KHAYALA VISHNU GARDEN	525	Other Outage	Planned Outage	01-03-2026	12:44	01-03-2026	13:57	1:13	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1637	02-03-2026	Part of : BLOCK D TAGORE GARDEN TAGORE GARDEN EXTENSION,POCKET AD TAGORE GARDEN TAGORE GARDEN EXTENSION,BLOCK 6 TILAK NAGAR,BLOCK N JJ COLONY TAGORE GARDEN TAGORE GARDEN EXTENSION,BLOCK FA TAGORE GARDEN TAGORE GARDEN EXTENSION.	5950	Other Outage	Unplanned Outage	02-03-2026	11:52	02-03-2026	13:51	1:59	0.000331	CONNECTION/DISCONNITION OF HT/LT CABLES
1638	02-03-2026	Part of : BLOCK I KHAYALA VILLAGE KHAYALA VISHNU GARDEN,	537	Other Outage	Planned Outage	02-03-2026	13:55	02-03-2026	15:13	1:18	0.000217	REPLACEMET OF HT BUSHING ROD
1639	02-03-2026	Part of : BLOCK K SHAM NAGAR VISHNU GARDEN,	428	Other Outage	Planned Outage	02-03-2026	10:55	02-03-2026	12:53	1:58	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1640	02-03-2026	Part of : BLOCK A VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	168	Other Outage	Planned Outage	02-03-2026	10:52	02-03-2026	13:55	3:03	0.000508	REPLACEMET OF HT BUSHING ROD
1641	02-03-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION,	1329	Other Outage	Planned Outage	02-03-2026	10:46	02-03-2026	12:50	2:04	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1642	03-03-2026	Part of : BLOCK EC & EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION	1870	Other Outage	Unplanned Outage	03-03-2026	10:42	03-03-2026	11:36	0:54	0.000627	BIRDAGE
1643	05-03-2026	Part of : BLOCK BA TAGORE GARDEN EXTENSION	174	Other Outage	Planned Outage	05-03-2026	10:56	05-03-2026	14:21	3:25	0.000569	REPLACEMET OF HT BUSHING ROD
1644	05-03-2026	Part of : BLOCK WZ KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	436	Other Outage	Planned Outage	05-03-2026	10:54	05-03-2026	14:23	3:29	0.000581	REPLACEMET OF HT BUSHING ROD
1645	06-03-2026	Part of : POCKET A SHAM NAGAR VISHNU GARDEN,BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN,	2697	Other Outage	Unplanned Outage	06-03-2026	12:54	06-03-2026	14:35	1:41	0.000421	REPAIRING OF HTAB
1646	06-03-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION,	1329	Other Outage	Planned Outage	06-03-2026	13:18	06-03-2026	15:00	1:42	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1647	06-03-2026	Part of : BLOCK N SHAM NAGAR VISHNU GARDEN,	1264	Other Outage	Planned Outage	06-03-2026	12:31	06-03-2026	14:33	2:02	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1648	06-03-2026	Part of : BLOCK B PRITHVI PARK TILAK NAGAR,	1088	Other Outage	Planned Outage	06-03-2026	10:26	06-03-2026	13:07	2:41	0.000447	REPLACEMET OF HT BUSHING ROD
1649	06-03-2026	Part of : BLOCK F TAGORE GARDEN TAGORE GARDEN EXTENSION,	1182	Other Outage	Planned Outage	06-03-2026	10:27	06-03-2026	13:05	2:38	0.000439	REPLACEMET OF HT BUSHING ROD
1650	07-03-2026	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN,POCKET A SHAM NAGAR VISHNU GARDEN	1261	Other Outage	Unplanned Outage	07-03-2026	23:09	08-03-2026	00:22	1:13	0.000459	CABLE FAULT
1651	07-03-2026	Part of : CHAUKHANDI VISHNU GARDEN	2479	Other Outage	Unplanned Outage	07-03-2026	12:10	07-03-2026	13:52	1:42	0.000283	LAYING OF HT CABLE
1652	07-03-2026	Part of : WZ-BLOCK MBS NAGAR CHAUKHANDI VISHNU GARDEN	1458	Other Outage	Planned Outage	07-03-2026	10:51	07-03-2026	13:29	2:38	0.000439	REPLACEMENT OF HT BUSHING ROD
1653	07-03-2026	Part of : G & J-BLOCK KHAYALA VISHNU GARDEN	1661	Other Outage	Planned Outage	07-03-2026	11:44	07-03-2026	13:46	2:02	0.003050	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INSULATOR
1654	07-03-2026	Part of : N-BLOCK RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	542	Other Outage	Planned Outage	07-03-2026	10:17	07-03-2026	12:31	2:14	0.000000	LT CIRCUIT MAINTENANCE
1655	08-03-2026	Part of : POCKET A,C & K-BLOCK SHAM NAGAR VISHNU GARDEN	2499	Other Outage	Unplanned Outage	08-03-2026	01:15	08-03-2026	02:15	1:00	0.000325	CABLE FAULT
1656	08-03-2026	Part of : G-BLOCK TILAK NAGAR	380	Other Outage	Planned Outage	08-03-2026	12:51	08-03-2026	15:01	2:10	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1657	08-03-2026	Part of : AE-BLOCK TAGORE GARDEN EXTENSION	279	Other Outage	Planned Outage	08-03-2026	10:44	08-03-2026	12:50	2:06	0.000000	LT CIRCUIT MAINTENANCE
1658	09-03-2026	Part of : BLOCK NA KHAYALA VISHNU GARDEN	2123	Other Outage	Planned Outage	09-03-2026	11:21	09-03-2026	14:00	2:39	0.000442	REPLACEMENT OF HT BUSHING ROD
1659	09-03-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	189	Other Outage	Planned Outage	09-03-2026	10:08	09-03-2026	13:05	2:57	0.000492	REPLACEMENT OF HT BUSHING ROD
1660	09-03-2026	Part of : BLOCK S KHAYALA VISHNU GARDEN	1088	Other Outage	Planned Outage	09-03-2026	09:51	09-03-2026	11:51	2:00	0.000000	CONDUCTOR REPLACEMENT PER SPAN,LT AB SAGGING PER SPAN
1661	10-03-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION,	1333	Other Outage	Unplanned Outage	10-03-2026	12:46	10-03-2026	13:04	0:18	0.000050	LAYING OF NEW LTAB
1662	10-03-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION,	18	Other Outage	Planned Outage	10-03-2026	11:01	10-03-2026	13:57	2:56	0.000489	REPLACEMENT OF HT BUSHING ROD
1663	10-03-2026	Part of : BLOCK J SHAM NAGAR VISHNU GARDEN,	1661	Other Outage	Planned Outage	10-03-2026	11:42	10-03-2026	14:02	2:20	0.000389	REPLACEMENT OF HT BUSHING ROD
1664	10-03-2026	Part of : BLOCK 4A TILAK NAGAR,	109	Other Outage	Planned Outage	10-03-2026	11:12	10-03-2026	14:05	2:53	0.000481	REPLACEMENT OF HT BUSHING ROD
1665	11-03-2026	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	848	Other Outage	Planned Outage	11-03-2026	11:31	11-03-2026	12:32	1:01	0.000169	REPLACEMENT OF HT BUSHING ROD
1666	11-03-2026	Part of : S4-BLOCK MAHAVIR NAGAR NEW TILAK NAGAR	550	Other Outage	Planned Outage	11-03-2026	10:33	11-03-2026	12:31	1:58	0.000328	REPLACEMENT OF HT BUSHING ROD
1667	11-03-2026	Part of : R-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	1358	Other Outage	Planned Outage	11-03-2026	10:31	11-03-2026	13:34	3:03	0.000508	REPLACEMENT OF HT BUSHING ROD
1668	11-03-2026	Part of : 4A-BLOCK TILAK NAGAR	196	Other Outage	Planned Outage	11-03-2026	10:21	11-03-2026	12:35	2:14	0.000000	LT CIRCUIT MAINTENANCE
1669	12-03-2026	Part of : POCKET A RAGHUBIR NAGA,C & K-BLOCK VISHAL ENCLAVE TAGORE GARDEN EXTENSION	2566	Other Outage	Unplanned Outage	12-03-2026	15:36	12-03-2026	16:31	0:55	0.000860	CABLE FAULT
1670	12-03-2026	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	793	Other Outage	Planned Outage	12-03-2026	11:11	12-03-2026	13:17	2:06	0.000525	INSTALLATION OF PHASE SEPERATOR PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1671	12-03-2026	Part of : D-BLOCK TAGORE GARDEN	386	Other Outage	Planned Outage	12-03-2026	11:16	12-03-2026	14:08	2:52	0.000478	REPLACEMENT OF HT BUSHING ROD
1672	12-03-2026	Part of : G-BLOCK TILAK NAGAR	380	Other Outage	Planned Outage	12-03-2026	10:16	12-03-2026	13:17	3:01	0.000503	REPLACEMENT OF HT BUSHING ROD
1673	13-03-2026	Part of : BLOCK S KHAYALA VISHNU GARDEN	1967	Other Outage	Planned Outage	13-03-2026	11:50	13-03-2026	13:15	1:25	0.001653	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1674	13-03-2026	Part of : BLOCK WZ KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	126	Other Outage	Planned Outage	13-03-2026	10:59	13-03-2026	14:11	3:12	0.000533	REPLACEMENT OF HT BUSHING ROD
1675	13-03-2026	Part of : BLOCK D TAGORE GARDEN TAGORE GARDEN EXTENSION	1075	Other Outage	Planned Outage	13-03-2026	10:03	13-03-2026	12:57	2:54	0.000483	REPLACEMENT OF HT BUSHING ROD
1676	13-03-2026	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	1333	Other Outage	Planned Outage	13-03-2026	13:11	13-03-2026	15:14	2:03	0.000342	3PH DB REPLACEMENT
1677	13-03-2026	Part of : BLOCK S KHAYALA VISHNU GARDEN	1091	Other Outage	Planned Outage	13-03-2026	10:05	13-03-2026	12:11	2:06	0.000000	CONDUCTOR REPLACEMENT PER SPAN,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,LT AB SAGGING PER SPAN
1678	14-03-2026	Part of : KRISHNA PARK EXTENSION TILAK NAGAR,BLOCK WZ MAHAVIR NAGAR NEW TILAK NAGAR,	2663	Other Outage	Planned Outage	14-03-2026	10:53	14-03-2026	13:33	2:40	0.000444	REPLACEMENT OF HT BUSHING ROD
1679	14-03-2026	Part of : RAVI NAGAR VISHNU GARDEN,	320	Other Outage	Planned Outage	14-03-2026	11:03	14-03-2026	13:38	2:35	0.003014	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF GAS KIT AND OIL SEAL
1680	14-03-2026	Part of : BLOCK CA TAGORE GARDEN TAGORE GARDEN EXTENSION,	254	Other Outage	Planned Outage	14-03-2026	10:50	14-03-2026	13:27	2:37	0.000436	REPLACEMENT OF HT BUSHING ROD
1681	15-03-2026	Part of : BLOCK J SHAM NAGAR VISHNU GARDEN,BLOCK S KHAYALA VISHNU GARDEN	3999	Other Outage	Unplanned Outage	15-03-2026	05:55	15-03-2026	06:43	0:48	0.002067	CABLE FAULT
1682	15-03-2026	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN,KHAYALA VISHNU GARDEN,BLOCK J KHAYALA VISHNU GARDEN	3255	Other Outage	Planned Outage	15-03-2026	10:23	15-03-2026	12:25	2:02	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1683	16-03-2026	Part of : MUKHERJI PARK & MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	1685	Other Outage	Unplanned Outage	16-03-2026	06:15	16-03-2026	07:16	1:01	0.000458	BIRDAGE
1684	16-03-2026	Part of : WZ-BLOCK KHAYALA VISHNU GARDEN	672	Other Outage	Unplanned Outage	16-03-2026	10:27	16-03-2026	12:54	2:27	0.000408	REPAIRING OF RMU
1685	16-03-2026	Part of : R-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	1333	Other Outage	Planned Outage	16-03-2026	12:39	16-03-2026	14:13	1:34	0.000000	LT CIRCUIT MAINTENANCE
1686	16-03-2026	Part of : CHAUKHANDI VISHNU GARDEN	1219	Other Outage	Planned Outage	16-03-2026	11:42	16-03-2026	13:45	2:03	0.000342	REPLACEMENT OF HT BUSHING ROD
1687	16-03-2026	Part of : EC-BLOCK VISHAL ENCLAVE TAGORE GARDEN EXTENSION	542	Other Outage	Planned Outage	16-03-2026	10:20	16-03-2026	13:23	3:03	0.000508	REPLACEMENT OF HT BUSHING ROD
1688	17-03-2026	Part of : BLOCK 4B TILAK NAGAR	89	Other Outage	Planned Outage	17-03-2026	10:12	17-03-2026	13:11	2:59	0.000497	REPLACEMENT OF HT BUSHING ROD
1689	17-03-2026	Part of : BLOCK N JJ COLONY TAGORE GARDEN EXTENSION	1328	Other Outage	Planned Outage	17-03-2026	10:09	17-03-2026	13:10	3:01	0.000503	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1690	18-03-2026	Part of : BLOCK 6 TILAK NAGAR,BLOCK 7 TILAK NAGAR,BLOCK 4B TILAK NAGAR,BLOCK 9 NURSERY TILAK NAGAR,BLOCK 8 TILAK NAGAR,BLOCK 5A TILAK NAGAR,BLOCK 4A TILAK NAGAR	1585	Other Outage	Unplanned Outage	18-03-2026	18:37	18-03-2026	19:39	1:02	0.002045	TREE TOUCHING
1691	18-03-2026	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN,	493	Other Outage	Planned Outage	18-03-2026	10:28	18-03-2026	13:33	3:05	0.000514	REPLACEMENT OF HT BUSHING ROD
1692	18-03-2026	Part of : BLOCK 6 TILAK NAGAR,	255	Other Outage	Planned Outage	18-03-2026	10:16	18-03-2026	12:46	2:30	0.000417	REPLACEMENT OF HT BUSHING ROD
1693	18-03-2026	Part of : BLOCK FA TAGORE GARDEN TAGORE GARDEN EXTENSION,	649	Other Outage	Planned Outage	18-03-2026	09:42	18-03-2026	12:43	3:01	0.000503	REPLACEMENT OF HT BUSHING ROD
1694	19-03-2026	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	793	Other Outage	Planned Outage	19-03-2026	15:31	19-03-2026	16:56	1:25	0.000000	LT CIRCUIT MAINTENANCE
1695	19-03-2026	Part of : EA-BLOCK TAGORE GARDEN EXTENSION	656	Other Outage	Planned Outage	19-03-2026	11:13	19-03-2026	13:29	2:16	0.000378	REPLACEMENT OF HT BUSHING ROD
1696	20-03-2026	Part of : MANOHAR NAGAR VIKASHPURI EXTENSION,A-BLOCK WIDOW COLONY,KRISHNA PARK EXTENSION,G-BLOCK TILAK NAGAR	2934	Other Outage	Unplanned Outage	20-03-2026	06:06	20-03-2026	06:52	0:46	0.000192	CABLE FAULT
1697	20-03-2026	Part of : FB-BLOCK TAGORE GARDEN EXTENSION	407	Other Outage	Planned Outage	20-03-2026	11:32	20-03-2026	13:39	2:07	0.000353	REPLACEMENT OF HT BUSHING ROD
1698	20-03-2026	Part of : ESI HOSPITAL TILAK NAGAR	1	Other Outage	Planned Outage	20-03-2026	11:26	20-03-2026	13:41	2:15	0.000375	REPLACEMENT OF HT BUSHING INULATOR
1699	20-03-2026	Part of : POCKET C CHAND NAGAR VISHNU GARDEN	2432	Other Outage	Planned Outage	20-03-2026	11:33	20-03-2026	13:38	2:05	0.000347	REPLACEMENT OF HT BUSHING ROD
1700	21-03-2026	Part of : POCKET C CHAND NAGAR VISHNU GARDEN,POCKET A SHAM NAGAR VISHNU GARDEN,BLOCK K SHAM NAGAR VISHNU GARDEN	2498	Other Outage	Unplanned Outage	21-03-2026	22:18	21-03-2026	22:57	0:39	0.000099	CABLE FAULT
1701	23-03-2026	Part of : NEW CHAUKHANDI VISHNU GARDEN,SANT NAGAR CHAUKHANDI VISHNU GARDEN,CHAUKHANDI VISHNU GARDEN	2241	Other Outage	Unplanned Outage	23-03-2026	03:12	23-03-2026	04:06	0:54	0.000463	CABLE FAULT
1702	23-03-2026	Part of : BLOCK 21 TILAK NAGAR	712	Other Outage	Planned Outage	23-03-2026	11:12	23-03-2026	14:09	2:57	0.000492	REPLACEMENT OF HT BUSHING ROD
1703	23-03-2026	Part of : FD-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	734	Other Outage	Planned Outage	23-03-2026	11:21	23-03-2026	14:06	2:45	0.000458	REPLACEMENT OF HT BUSHING ROD
1704	24-03-2026	Part of : POCKET A RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	2147	Other Outage	Planned Outage	24-03-2026	11:14	24-03-2026	13:17	2:03	0.000342	REPLACEMENT OF HT BUSHING ROD
1705	24-03-2026	Part of : BLOCK 15 TILAK NAGAR	43	Other Outage	Planned Outage	24-03-2026	11:15	24-03-2026	13:15	2:00	0.000333	REPLACEMENT OF HT BUSHING ROD
1706	25-03-2026	Part of : BLOCK 21 TILAK NAGAR	1099	Other Outage	Planned Outage	25-03-2026	11:08	25-03-2026	13:57	2:49	0.000469	REPLACEMENT OF HT BUSHING ROD
1707	25-03-2026	Part of : BLOCK M SHAM NAGAR VISHNU GARDEN	878	Other Outage	Planned Outage	25-03-2026	10:14	25-03-2026	13:06	2:52	0.000478	REPLACEMENT OF HT BUSHING ROD
1708	27-03-2026	Part of : SHIVAJI PALACE VISHAL ENCLAVE TAGORE GARDEN EXTENSION	57	Other Outage	Planned Outage	27-03-2026	10:12	27-03-2026	13:28	3:16	0.000544	REPLACEMENT OF HT BUSHING ROD
1709	27-03-2026	Part of : BLOCK 9 NURSERY TILAK NAGAR	169	Other Outage	Planned Outage	27-03-2026	10:44	27-03-2026	13:37	2:53	0.000481	REPLACEMENT OF HT BUSHING ROD
1710	30-03-2026	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN,	937	Other Outage	Planned Outage	30-03-2026	11:29	30-03-2026	14:07	2:38	0.000439	REPLACEMENT OF HT BUSHING ROD
1711	30-03-2026	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION,	1	Other Outage	Planned Outage	30-03-2026	11:26	30-03-2026	14:08	2:42	0.000450	REPLACEMENT OF HT BUSHING ROD
1712	30-03-2026	Part of : HTC:CRPF CAMP	1	Other Outage	Planned Outage	30-03-2026	11:02	30-03-2026	14:12	3:10	0.000528	REPLACEMENT OF HT BUSHING ROD
1713	31-03-2026	Part of : BLOCK C GANESH NAGAR TILAK NAGAR,BLOCK WZ MBS NAGAR CHAUKHANDI VISHNU GARDEN,BLOCK C HARJAN COLONY TILAK NAGAR	583	Other Outage	Unplanned Outage	31-03-2026	02:12	31-03-2026	02:53	0:41	0.000242	CABLE FAULT
1714	02-03-2026	Part of : PARAM PURI UTTAM NAGAR,NANHEY PARK OM VIHAR UTTAM NAGAR	2966	Other Outage	Unplanned Outage	02-03-2026	09:20	02-03-2026	10:13	0:53	0.000677	CABLE FAULT
1715	02-03-2026	Part of : BHAGAT ENCLAVE BINDAPUR,	1025	Other Outage	Planned Outage	02-03-2026	11:16	02-03-2026	13:38	2:22	0.000000	REPLACEMENT OF LT BUSHING ROD
1716	05-03-2026	Part of : PARJAPAT COLONY BINDAPUR	1355	Other Outage	Planned Outage	05-03-2026	12:25	05-03-2026	13:49	1:24	0.000000	REPLACEMENT OF LT BUSHING ROD
1717	05-03-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	881	Other Outage	Planned Outage	05-03-2026	10:59	05-03-2026	13:57	2:58	0.000000	REPLACEMENT OF LT BUSHING ROD
1718	05-03-2026	Part of : MAHAVIR ENCLAVE PART 3	1220	Other Outage	Planned Outage	05-03-2026	11:02	05-03-2026	13:45	2:43	0.000000	REPLACEMENT OF LT BUSHING ROD
1719	06-03-2026	Part of : INDIRA PARK BINDAPUR,	629	Other Outage	Planned Outage	06-03-2026	13:55	06-03-2026	16:43	2:48	0.000700	ACB REPLACEMENT PER ACB,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER LT ACB
1720	06-03-2026	Part of : BLOCK E PARAM PURI UTTAM NAGAR,	829	Other Outage	Planned Outage	06-03-2026	14:19	06-03-2026	16:44	2:25	0.000806	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1721	06-03-2026	Part of : BLOCK D 2 MAHINDRA PARK BINDAPUR,BLOCK C MAHINDRA PARK BINDAPUR,	2451	Other Outage	Planned Outage	06-03-2026	11:02	06-03-2026	13:55	2:53	0.000000	REPLACEMENT OF LT BUSHING ROD
1722	07-03-2026	Part of : INDIRA PARK BINDAPUR	464	Other Outage	Planned Outage	07-03-2026	10:58	07-03-2026	13:35	2:37	0.000000	LT CIRCUIT MAINTENANCE
1723	09-03-2026	Part of : INDIRA PARK BINDAPUR	955	Other Outage	Planned Outage	09-03-2026	12:11	09-03-2026	13:56	1:45	0.000000	REPLACEMENT OF LT BUSHING ROD
1724	09-03-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	382	Other Outage	Planned Outage	09-03-2026	12:41	09-03-2026	13:55	1:14	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1725	10-03-2026	Part of : SANTOSH PARK UTTAM NAGAR,	1432	Other Outage	Planned Outage	10-03-2026	13:21	10-03-2026	15:39	2:18	0.000000	REPLACEMENT OF LT BUSHING ROD
1726	10-03-2026	Part of : BLOCK A UTTAM VIHAR BINDAPUR,	462	Other Outage	Planned Outage	10-03-2026	11:01	10-03-2026	13:47	2:46	0.000000	REPLACEMENT OF LT BUSHING ROD
1727	10-03-2026	Part of : BLOCK H SITAPURI PART 2 SITAPURI,BLOCK A SITAPURI PART 2 SITAPURI,ANUP NAGAR ADARSH NAGAR BINDAPUR,	720	Other Outage	Planned Outage	10-03-2026	11:23	10-03-2026	13:48	2:25	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1728	11-03-2026	Part of : JAIN COLONY MATIALA,PARAM PURI UTTAM NAGAR,SANTOSH PARK UTTAM NAGAR,BHAGWATI VIHAR BINDAPUR,BLOCK C UTTAM VIHAR BINDAPUR	4156	Other Outage	Unplanned Outage	11-03-2026	12:51	11-03-2026	13:33	0:42	0.000015	CABLE FAULT
1729	11-03-2026	Part of : F-BLOCK UTTAM VIHAR BINDAPUR	1175	Other Outage	Planned Outage	11-03-2026	11:53	11-03-2026	13:43	1:50	0.000000	REPLACEMENT OF HT BUSHING ROD
1730	11-03-2026	Part of : OLD JANKI PURI BINDAPUR	418	Other Outage	Planned Outage	11-03-2026	11:31	11-03-2026	13:42	2:11	0.000000	LT CIRCUIT MAINTENANCE
1731	12-03-2026	Part of : C-BLOCK UTTAM VIHAR BINDAPUR	1247	Other Outage	Planned Outage	12-03-2026	11:29	12-03-2026	13:57	2:28	0.000000	REPLACEMENT OF HT BUSHING ROD
1732	12-03-2026	Part of : E-BLOCK SITAPURI PART-2	392	Other Outage	Planned Outage	12-03-2026	10:32	12-03-2026	13:55	3:23	0.000000	LT CIRCUIT MAINTENANCE
1733	12-03-2026	Part of : E-BLOCK PARAM PURI UTTAM NAGAR	1146	Other Outage	Planned Outage	12-03-2026	10:22	12-03-2026	13:00	2:38	0.000000	LT CIRCUIT MAINTENANCE
1734	13-03-2026	Part of : BLOCK A RAM DATT ENCLAVE UTTAM NAGAR	1222	Other Outage	Planned Outage	13-03-2026	15:50	13-03-2026	16:22	0:32	0.000000	REPLACEMENT OF HT BUSHING ROD
1735	13-03-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	669	Other Outage	Planned Outage	13-03-2026	13:17	13-03-2026	13:50	0:33	0.000000	REPLACEMENT OF LT BUSHING ROD
1736	13-03-2026	Part of : OLD JANKI PURI BINDAPUR	788	Other Outage	Planned Outage	13-03-2026	11:14	13-03-2026	13:49	2:35	0.000000	REPLACEMENT OF LT BUSHING ROD
1737	14-03-2026	Part of : MAHINDRA PARK BINDAPUR,POCKET 4 CHANAKYA PLACE I SITAPURI,BLOCK A 3 HARIJAN COLONY SITAPURI PART 1 SITAPURI,BLOCK C CHANAKYA PLACE I SITAPURI	4819	Other Outage	Unplanned Outage	14-03-2026	02:18	14-03-2026	02:31	0:13	0.000064	HVDS FAULT
1738	14-03-2026	Part of : BLOCK D JJ COLONY UTTAM NAGAR,	176	Other Outage	Planned Outage	14-03-2026	10:52	14-03-2026	13:35	2:43	0.000000	REPLACEMENT OF LT BUSHING ROD
1739	14-03-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,	804	Other Outage	Planned Outage	14-03-2026	10:51	14-03-2026	13:37	2:46	0.000000	REPLACEMENT OF LT BUSHING ROD
1740	16-03-2026	Part of : OLD JANKI PURI BINDAPUR,C & D 2-BLOCK MAHINDRA PARK BINDAPUR	3434	Other Outage	Unplanned Outage	16-03-2026	14:39	16-03-2026	15:24	0:45	0.000532	CABLE FAULT
1741	16-03-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,MAHAVIR ENCLAVE PART-3	266	Other Outage	Planned Outage	16-03-2026	11:19	16-03-2026	13:40	2:21	0.000000	3PH HT AB CABLE REPLACEMENT
1742	16-03-2026	Part of : PARAM PURI UTTAM NAGAR	831	Other Outage	Planned Outage	16-03-2026	11:37	16-03-2026	13:40	2:03	0.000000	LT CIRCUIT MAINTENANCE
1743	17-03-2026	Part of : BHAGWATI VIHAR BINDAPUR	1837	Other Outage	Planned Outage	17-03-2026	11:09	17-03-2026	13:43	2:34	0.000000	REPLACEMENT OF HT BUSHING ROD
1744	17-03-2026	Part of : INDIRA PARK BINDAPUR	539	Other Outage	Planned Outage	17-03-2026	11:08	17-03-2026	13:47	2:39	0.000000	REPLACEMENT OF LT BUSHING ROD
1745	17-03-2026	Part of : NEW UTTAM NAGAR	1461	Other Outage	Planned Outage	17-03-2026	13:29	17-03-2026	16:17	2:48	0.000000	REPLACEMENT OF LT BUSHING ROD
1746	18-03-2026	Part of : OLD JANKI PURI BINDAPUR,BLOCK E SITAPURI PART 2 SITAPURI	2621	Other Outage	Unplanned Outage	18-03-2026	18:57	18-03-2026	19:33	0:36	0.000958	HVDS FAULT
1747	18-03-2026	Part of : BLOCK B UTTAM NAGAR	2993	Other Outage	Unplanned Outage	18-03-2026	18:33	18-03-2026	19:11	0:38	0.000037	TRANSIENT FAULT
1748	18-03-2026	Part of : BLOCK D JJ COLONY UTTAM NAGAR,BLOCK G UTTAM NAGAR,BLOCK C MILAP NAGAR UTTAM NAGAR	5267	Other Outage	Unplanned Outage	18-03-2026	10:31	18-03-2026	11:12	0:41	0.000032	CABLE FAULT
1749	18-03-2026	Part of : BLOCK D JJ COLONY UTTAM NAGAR,	1292	Other Outage	Unplanned Outage	18-03-2026	13:13	18-03-2026	14:55	1:42	0.000000	ATTENDING WEAK POINTS/HOT SPOT
1750	18-03-2026	Part of : SANTOSH PARK UTTAM NAGAR,	1506	Other Outage	Planned Outage	18-03-2026	12:22	18-03-2026	13:59	1:37	0.000000	REPLACEMENT OF LT BUSHING ROD
1751	18-03-2026	Part of : BLOCK C MAHINDRA PARK BINDAPUR,	830	Other Outage	Planned Outage	18-03-2026	12:24	18-03-2026	13:55	1:31	0.000000	REPLACEMENT OF LT BUSHING ROD
1752	18-03-2026	Part of : BLOCK C UTTAM VIHAR BINDAPUR,	1598	Other Outage	Planned Outage	18-03-2026	11:25	18-03-2026	13:54	2:29	0.000000	REPLACEMENT OF LT BUSHING ROD
1753	19-03-2026	Part of : A & H-BLOCK SITAPURI PART 2 SITAPURI,ANUP NAGAR ADARSH NAGAR BINDAPUR	722	Other Outage	Planned Outage	19-03-2026	11:10	19-03-2026	13:34	2:24	0.000000	3PH HT AB CABLE REPLACEMENT
1754	20-03-2026	Part of : A 3-BLOCK HARIJAN COLONY SITAPURI PART-1	618	Other Outage	Planned Outage	20-03-2026	11:19	20-03-2026	14:02	2:43	0.000000	LT CIRCUIT MAINTENANCE
1755	21-03-2026	Part of : BLOCK B UTTAM NAGAR	2993	Other Outage	Unplanned Outage	21-03-2026	11:42	21-03-2026	12:24	0:42	0.000613	HT SYSTEM FAULT
1756	22-03-2026	Part of : BLOCK E PARAM PURI UTTAM NAGAR,	327	Other Outage	Unplanned Outage	22-03-2026	14:55	22-03-2026	16:26	1:31	0.000506	CONNECTION OF NEW LT CABLE
1757	23-03-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,MAHAVIR ENCLAVE PART 3	1398	Other Outage	Unplanned Outage	23-03-2026	10:59	23-03-2026	12:22	1:23	0.000807	REPAIRING OF HVDS CIRCUIT
1758	24-03-2026	Part of : PARJAPAT COLONY BINDAPUR	1371	Other Outage	Unplanned Outage	24-03-2026	12:20	24-03-2026	13:29	1:09	0.000192	CONNECTION OF NEW LT CABLE
1759	24-03-2026	Part of : E-BLOCK UTTAM VIHAR BINDAPUR	326	Other Outage	Planned Outage	24-03-2026	13:31	24-03-2026	14:58	1:27	0.000000	LT CIRCUIT MAINTENANCE
1760	24-03-2026	Part of : OLD JANKI PURI BINDAPUR	492	Other Outage	Planned Outage	24-03-2026	11:03	24-03-2026	13:21	2:18	0.000000	LT CIRCUIT MAINTENANCE
1761	25-03-2026	Part of : BLOCK O UTTAM NAGAR	432	Other Outage	Planned Outage	25-03-2026	11:00	25-03-2026	13:29	2:29	0.000000	REPLACEMENT OF LT BUSHING ROD
1762	27-03-2026	Part of : B-BLOCK UTTAM VIHAR BINDAPUR	691	Other Outage	Planned Outage	27-03-2026	13:20	27-03-2026	15:02	1:42	0.000000	REPLACEMENT OF HT BUSHING ROD
1763	27-03-2026	Part of : BLOCK B SITAPURI PART-2 SITAPURI	997	Other Outage	Planned Outage	27-03-2026	11:52	27-03-2026	13:53	2:01	0.000000	REPLACEMENT OF HT BUSHING ROD
1764	27-03-2026	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	1222	Other Outage	Planned Outage	27-03-2026	11:51	27-03-2026	13:52	2:01	0.000000	LT CIRCUIT MAINTENANCE
1765	28-03-2026	Part of : BLOCK F JEEVAN PARK BINDAPUR	642	Other Outage	Planned Outage	28-03-2026	11:12	28-03-2026	13:29	2:17	0.000000	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1766	30-03-2026	Part of : PARAM PURI UTTAM NAGAR,	1030	Other Outage	Planned Outage	30-03-2026	11:35	30-03-2026	15:12	3:37	0.000000	REPLACEMENT OF LT BUSHING ROD
1767	02-03-2026	Part of : VIKAS KUNJ VIKAS PURI,	60	Other Outage	Planned Outage	02-03-2026	12:21	02-03-2026	13:51	1:30	0.000000	REPLACEMENT OF LT BUSHING ROD
1768	02-03-2026	Part of : VIKAS KUNJ VIKAS PURI,	73	Other Outage	Planned Outage	02-03-2026	12:23	02-03-2026	13:51	1:28	0.000000	REPLACEMENT OF LT BUSHING ROD
1769	02-03-2026	Part of : JJ COLONY UTTAM NAGAR,	1057	Other Outage	Planned Outage	02-03-2026	11:15	02-03-2026	13:29	2:14	0.000000	REPLACEMENT OF LT BUSHING ROD
1770	02-03-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,	453	Other Outage	Planned Outage	02-03-2026	11:16	02-03-2026	13:30	2:14	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1771	03-03-2026	Part of : M-BLOCK VIKAS PURI	376	Other Outage	Planned Outage	03-03-2026	10:15	03-03-2026	12:56	2:41	0.000000	LT CIRCUIT MAINTENANCE
1772	05-03-2026	Part of : ANURODHYA APARTMENTS VIKAS PURI	47	Other Outage	Planned Outage	05-03-2026	10:05	05-03-2026	12:29	2:24	0.000000	REPLACEMENT OF LT BUSHING ROD
1773	06-03-2026	Part of : PHASE 1 OM VIHAR NAWADA,	317	Other Outage	Planned Outage	06-03-2026	12:04	06-03-2026	14:01	1:57	0.000000	3PH DB REPLACEMENT
1774	06-03-2026	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,	2468	Other Outage	Planned Outage	06-03-2026	11:20	06-03-2026	13:55	2:35	0.000000	3PH DB REPLACEMENT
1775	06-03-2026	Part of : DEEP ENCLAVE,	2117	Other Outage	Planned Outage	06-03-2026	11:17	06-03-2026	13:57	2:40	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1776	09-03-2026	Part of : BLOCK A 3 UTTAM NAGAR	1068	Other Outage	Planned Outage	09-03-2026	11:24	09-03-2026	13:55	2:31	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1777	10-03-2026	Part of : BLOCK E VIKAS PURI,	3	Other Outage	Planned Outage	10-03-2026	14:39	10-03-2026	16:10	1:31	0.000000	REPLACEMENT OF LT BUSHING ROD
1778	10-03-2026	Part of : BLOCK H3 VIKAS PURI,	72	Other Outage	Planned Outage	10-03-2026	10:51	10-03-2026	13:45	2:54	0.000000	REPLACEMENT OF LT BUSHING ROD
1779	10-03-2026	Part of : HOSTAL VIHAR OM VIHAR HASTSAL,	669	Other Outage	Planned Outage	10-03-2026	11:30	10-03-2026	13:47	2:17	0.000000	REPLACEMENT OF LT BUSHING ROD
1780	11-03-2026	Part of : H-BLOCK KESHOPUR INDUSTRIAL AREA VIKAS PURI	29	Other Outage	Planned Outage	11-03-2026	14:53	11-03-2026	16:35	1:42	0.000000	LT CIRCUIT MAINTENANCE
1781	11-03-2026	Part of : SHIV VIHAR WEST	19	Other Outage	Planned Outage	11-03-2026	11:36	11-03-2026	14:44	3:08	0.000000	REPLACEMENT OF HT BUSHING ROD
1782	11-03-2026	Part of : DEEP ENCLAVE & NAIDER ENCLAVE	1252	Other Outage	Planned Outage	11-03-2026	11:35	11-03-2026	14:44	3:09	0.000000	LT CIRCUIT MAINTENANCE
1783	11-03-2026	Part of : H-BLOCK KESHOPUR INDUSTRIAL AREA VIKAS PURI	4	Other Outage	Planned Outage	11-03-2026	10:21	11-03-2026	13:42	3:21	0.000000	LT CIRCUIT MAINTENANCE
1784	12-03-2026	Part of : YADAV ENCLAVE & VIKAS VIHAR	939	Other Outage	Planned Outage	12-03-2026	11:15	12-03-2026	13:55	2:40	0.000000	REPLACEMENT OF HT BUSHING ROD
1785	14-03-2026	Part of : R&S BLOCK VIKAS NAGAR,SHIV VIHAR WEST,GUPTA ENCLAVE,	962	Other Outage	Planned Outage	14-03-2026	12:00	14-03-2026	14:14	2:14	0.000000	REPLACEMENT OF HT BUSHING ROD
1786	16-03-2026	Part of : SHIV VIHAR HASTSAL	923	Other Outage	Planned Outage	16-03-2026	11:35	16-03-2026	13:43	2:08	0.000000	REPLACEMENT OF HT BUSHING ROD
1787	17-03-2026	Part of : DDA LIG FLATS HASTSAL	798	Other Outage	Unplanned Outage	17-03-2026	10:36	17-03-2026	11:16	0:40	0.000799	CABLE FAULT
1788	17-03-2026	Part of : SAINIK ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,PRESS ENCLAVE	1560	Other Outage	Planned Outage	17-03-2026	12:34	17-03-2026	13:54	1:20	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1789	17-03-2026	Part of : BLOCK A 1 UTTAM NAGAR	791	Other Outage	Planned Outage	17-03-2026	12:32	17-03-2026	13:56	1:24	0.000000	REPLACEMENT OF LT BUSHING ROD
1790	18-03-2026	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL,	184	Other Outage	Planned Outage	18-03-2026	13:15	18-03-2026	15:23	2:08	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1791	18-03-2026	Part of : B-BLOCK VIKAS NAGAR,	125	Other Outage	Planned Outage	18-03-2026	11:11	18-03-2026	13:54	2:43	0.000000	REPLACEMENT OF LT BUSHING ROD
1792	18-03-2026	Part of : BLOCK H3 VIKAS PURI,	85	Other Outage	Planned Outage	18-03-2026	10:25	18-03-2026	12:37	2:12	0.000000	REPLACEMENT OF LT BUSHING ROD
1793	20-03-2026	Part of : MANOHAR NAGAR VIKAS PURI	89	Other Outage	Planned Outage	20-03-2026	10:13	20-03-2026	12:46	2:33	0.000000	LT CIRCUIT MAINTENANCE
1794	21-03-2026	Part of : B-BLOCK BOOSTER PUMP (HTC)	0	Other Outage	Unplanned Outage	21-03-2026	13:21	21-03-2026	14:01	0:40	0.000019	CABLE FAULT
1795	23-03-2026	Part of : GANGOTRI APARTMENT VIKAS PURI	117	Other Outage	Planned Outage	23-03-2026	10:00	23-03-2026	13:10	3:10	0.000000	LT CIRCUIT MAINTENANCE
1796	24-03-2026	Part of : D-BLOCK JJ COLONY	884	Other Outage	Planned Outage	24-03-2026	11:43	24-03-2026	14:12	2:29	0.000000	REPLACEMENT OF HT BUSHING ROD
1797	24-03-2026	Part of : BHIM ENCLAVE	1365	Other Outage	Planned Outage	24-03-2026	11:41	24-03-2026	14:11	2:30	0.000000	LT CIRCUIT MAINTENANCE
1798	24-03-2026	Part of : VIKAS PURI PHASE 1	72	Other Outage	Planned Outage	24-03-2026	10:10	24-03-2026	12:24	2:14	0.000000	LT CIRCUIT MAINTENANCE
1799	25-03-2026	Part of : K-5 EXTN. AND DEEPAK VIHAR	243	Other Outage	Planned Outage	25-03-2026	12:29	25-03-2026	14:21	1:52	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1800	25-03-2026	Part of : S-BLOCK VIKAS NAGAR,F-BLOCK VIKAS NAGAR,SHIV VIHAR COLONY	1794	Other Outage	Planned Outage	25-03-2026	12:08	25-03-2026	14:19	2:11	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1801	25-03-2026	Part of : GUPTA ENCLAVE	1091	Other Outage	Planned Outage	25-03-2026	12:07	25-03-2026	14:20	2:13	0.000000	GUARD WIRES SAGGING PER SPAN
1802	25-03-2026	Part of : PHASE 1 VIKAS PURI	106	Other Outage	Planned Outage	25-03-2026	10:05	25-03-2026	12:33	2:28	0.000000	REPLACEMENT OF LT BUSHING ROD
1803	27-03-2026	Part of : VIKAS PURI PHASE 1	99	Other Outage	Planned Outage	27-03-2026	15:17	27-03-2026	16:14	0:57	0.000000	LT CIRCUIT MAINTENANCE
1804	27-03-2026	Part of : KG 2-BLOCK VIKAS PURI	318	Other Outage	Planned Outage	27-03-2026	13:51	27-03-2026	14:59	1:08	0.000000	LT CIRCUIT MAINTENANCE
1805	27-03-2026	Part of : VIKAS PURI PHASE 1	66	Other Outage	Planned Outage	27-03-2026	13:54	27-03-2026	14:58	1:04	0.000000	LT CIRCUIT MAINTENANCE
1806	27-03-2026	Part of : A 3-BLOCK UTTAM NAGAR	2086	Other Outage	Planned Outage	27-03-2026	12:23	27-03-2026	14:38	2:15	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1807	27-03-2026	Part of : M-BLOCK VIKAS PURI	405	Other Outage	Planned Outage	27-03-2026	10:10	27-03-2026	12:21	2:11	0.000000	LT CIRCUIT MAINTENANCE
1808	28-03-2026	Part of : PHASE 1 VIKAS PURI	62	Other Outage	Planned Outage	28-03-2026	10:21	28-03-2026	12:30	2:09	0.000000	REPLACEMENT OF LT BUSHING ROD
1809	30-03-2026	Part of : D-BLOCK JJ COLONY,C-BLOCK SHIV VIHAR JJ COLONY,A-BLOCK SHIV VIHAR JJ COLONY,GOVT SCHOOL,E-BLOCK JJ COLONY	3799	Other Outage	Unplanned Outage	30-03-2026	16:13	30-03-2026	16:55	0:42	0.000669	HT SYSTEM FAULT
1810	30-03-2026	Part of : SAINIK ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,SURKAKHA ENCLAVE AND M-BLOCK COMMONDER CHOWK,PRESS ENCLAVE,	1625	Other Outage	Unplanned Outage	30-03-2026	11:16	30-03-2026	12:30	1:14	0.000000	REPAIRING OF HVDS CIRCUIT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1811	31-03-2026	Part of : AB&C-BLOCK L-2 MOHAN GARDEN,BLOCK K 7 ZAILDAR ENCLAVE HASTSAL,BLOCK M ZAILDAR ENCLAVE HASTSAL,PHASE 5 OM VIHAR HASTSAL	7281	Other Outage	Unplanned Outage	31-03-2026	17:25	31-03-2026	17:55	0:30	0.000467	CABLE FAULT