

Name of Distribution Licensee: BSES Rajdhani Power Limited												
Period of Outage: NOVEMBER 2025												
Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1	01-11-2025	Part of : TUGHLAKABAD EXTN	2712	Other Outage	Planned Outage	01-11-2025	12:53	01-11-2025	13:13	0:20	0.000000	REPLACEMET OF HT BUSHING ROD
2	01-11-2025	Part of : TUGHLAQABAD VILLAGE	608	Other Outage	Planned Outage	01-11-2025	12:50	01-11-2025	15:44	2:54	0.000967	REPLACEMENT OF LT BUSHING ROD
3	02-11-2025	Part of : C-BLOCK OKHLA PHASE-1,	1216	Other Outage	Planned Outage	02-11-2025	10:58	02-11-2025	13:38	2:40	0.004444	REPLACEMET OF HT BUSHING ROD
4	02-11-2025	Part of : B-BLOCK OKHLA PHASE-1,	397	Other Outage	Planned Outage	02-11-2025	10:29	02-11-2025	13:39	3:10	0.003167	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
5	03-11-2025	PART OF : GOVINDPURI	2566	Other Outage	Planned Outage	03-11-2025	11:02	03-11-2025	13:54	2:52	0.001433	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING
6	04-11-2025	Part of : S-BLOCK GK-2	225	Other Outage	Planned Outage	04-11-2025	11:27	04-11-2025	15:42	4:15	0.001063	REPLACEMENT OF HT BUSHING ROD
7	04-11-2025	Part of : TUGHLAQABAD VILLAGE	861	Other Outage	Planned Outage	04-11-2025	11:03	04-11-2025	13:58	2:55	0.003403	REPLACEMENT OF HT BUSHING ROD
8	05-11-2025	Part of : MELA GROUND, MARKET NO-4 CR PARK	1298	Other Outage	Unplanned Outage	05-11-2025	13:29	05-11-2025	14:16	0:47	0.000640	HT SYSTEM FAULT
9	05-11-2025	Part of : 9-BLOCK KALKA JI	286	Other Outage	Planned Outage	05-11-2025	11:10	05-11-2025	13:15	2:05	0.002431	REPLACEMET OF HT BUSHING ROD,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
10	06-11-2025	Part of : E-BLOCK MASJID MOTH,	184	Other Outage	Planned Outage	06-11-2025	12:14	06-11-2025	14:21	2:07	0.000706	REPLACEMENT OF LT BUSHING ROD
11	06-11-2025	Part of : TUGHLAQABAD VILLAGE TUGHLAKABAD,	685	Other Outage	Planned Outage	06-11-2025	11:17	06-11-2025	13:55	2:38	0.001097	REPLACEMENT OF LT BUSHING ROD
12	07-11-2025	Part of : J-BLOCK KALKA JI	770	Other Outage	Planned Outage	07-11-2025	11:16	07-11-2025	14:03	2:47	0.001392	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
13	07-11-2025	Part of : TUGHLAKABAD EXTN	1222	Other Outage	Planned Outage	07-11-2025	10:59	07-11-2025	13:57	2:58	0.000000	REPLACEMENT OF LT BUSHING ROD
14	07-11-2025	Part of : TEKHHAND VILLAGE	845	Other Outage	Planned Outage	07-11-2025	11:20	07-11-2025	13:56	2:36	0.003250	REPLACEMENT OF LT BUSHING ROD
15	08-11-2025	Part of : TUGHLAKABAD EXTN.	843	Other Outage	Planned Outage	08-11-2025	11:14	08-11-2025	14:28	3:14	0.000000	REPLACEMENT OF HT BUSHING ROD
16	08-11-2025	Part of : W-BLOCK GK-2	39	Other Outage	Planned Outage	08-11-2025	11:17	08-11-2025	14:27	3:10	0.000528	REPLACEMENT OF HT BUSHING ROD
17	09-11-2025	Part of : B-BLOCK OKHLA PHASE-1	305	Other Outage	Planned Outage	09-11-2025	11:57	09-11-2025	14:59	3:02	0.001769	REPLACEMET OF HT BUSHING ROD
18	09-11-2025	Part of : NBCC OKHLA PH-I (HTC)	1	Other Outage	Planned Outage	09-11-2025	11:08	09-11-2025	13:44	2:36	0.000650	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
19	09-11-2025	Part of : INDIRA KALYAN VIHAR OKHLA PHASE-1,D-BLOCK OKHLA PHASE-1	708	Other Outage	Planned Outage	09-11-2025	11:06	09-11-2025	13:44	2:38	0.002194	REPLACEMENT OF LT BUSHING ROD
20	10-11-2025	Part of : TUGHLAKABAD EXTN,	920	Other Outage	Planned Outage	10-11-2025	11:12	10-11-2025	14:04	2:52	0.000000	PREVENTIVE MAINTENANCE
21	10-11-2025	Part of : E-BLOCK MASJID MOTH,	531	Other Outage	Planned Outage	10-11-2025	11:49	10-11-2025	14:03	2:14	0.000744	PREVENTIVE MAINTENANCE
22	11-11-2025	Part of : GOVINDPURI	1989	Other Outage	Planned Outage	11-11-2025	11:11	11-11-2025	13:50	2:39	0.005300	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
23	11-11-2025	Part of : H-BLOCK CR PARK	603	Other Outage	Planned Outage	11-11-2025	11:07	11-11-2025	13:51	2:44	0.000911	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF HT BUSHING ROD
24	11-11-2025	Part of : TUGHLAQABAD VILLAGE	1415	Other Outage	Planned Outage	11-11-2025	11:08	11-11-2025	13:48	2:40	0.001111	REPLACEMENT OF LT BUSHING ROD
25	12-11-2025	Part of : SHAHEED RAJIV GANDHI COLONY GOVINDPURI	1093	Other Outage	Planned Outage	12-11-2025	10:43	12-11-2025	13:49	3:06	0.004650	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
26	12-11-2025	Part of : TUGHLAKABAD EXTN	1114	Other Outage	Planned Outage	12-11-2025	11:02	12-11-2025	13:47	2:45	0.000000	REPLACEMENT OF HT BUSHING ROD
27	12-11-2025	Part of : SAVITRI CINEMA	130	Other Outage	Planned Outage	12-11-2025	11:13	12-11-2025	13:47	2:34	0.000856	INSTALLATION OF BUS BAR,REPLACEMENT OF HT/LT CLEATS
28	13-11-2025	Part of : F-BLOCK OKHLA PHASE-1	731	Other Outage	Unplanned Outage	13-11-2025	19:26	13-11-2025	20:11	0:45	0.000550	CABLE FAULT
29	13-11-2025	Part of : S-BLOCK GK-2	461	Other Outage	Planned Outage	13-11-2025	11:34	13-11-2025	13:51	2:17	0.000951	REPLACEMENT OF LT BUSHING ROD
30	13-11-2025	Part of : A3-BLOCK KALKA JI EXTN	511	Other Outage	Planned Outage	13-11-2025	11:01	13-11-2025	13:50	2:49	0.000000	REPLACEMENT OF LT BUSHING ROD
31	13-11-2025	Part of : F-79-80 DLF UNIVERSAL OKHLA PHASE-1	548	Other Outage	Planned Outage	13-11-2025	11:07	13-11-2025	13:54	2:47	0.000928	REPLACEMET OF HT BUSHING ROD
32	14-11-2025	Part of : BLOCK E ENCLAVE 3 GREATER KAILASH	384	Other Outage	Planned Outage	14-11-2025	11:58	14-11-2025	14:27	2:29	0.000828	PREVENTIVE MAINTENANCE
33	14-11-2025	Part of : A3-BLOCK KALKA JI EXTN	509	Other Outage	Planned Outage	14-11-2025	11:01	14-11-2025	13:58	2:57	0.000000	REPLACEMET OF HT BUSHING ROD
34	14-11-2025	Part of : GOVINDPURI EXTENSION GOVINDPURI KALKAJI	1019	Other Outage	Planned Outage	14-11-2025	11:46	14-11-2025	13:57	2:11	0.003275	PREVENTIVE MAINTENANCE
35	14-11-2025	Part of : TUGHLAQABAD VILLAGE	544	Other Outage	Planned Outage	14-11-2025	11:14	14-11-2025	13:56	2:42	0.001125	LT CIRCUIT PREVENTIVE MAINTENANCE
36	15-11-2025	Part of : W-BLOCK GK-2	363	Other Outage	Planned Outage	15-11-2025	11:16	15-11-2025	13:45	2:29	0.001242	REPLACEMENT OF LT BUSHING ROD
37	16-11-2025	Part of : D-BLOCK OKHLA PHASE-1	215	Other Outage	Planned Outage	16-11-2025	10:58	16-11-2025	13:47	2:49	0.002817	REPLACEMENT OF HT BUSHING ROD
38	17-11-2025	Part of : E-BLOCK MASJID MOTH	489	Other Outage	Planned Outage	17-11-2025	13:16	17-11-2025	17:03	3:47	0.001261	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
39	17-11-2025	Part of : GOVINDPURI	1629	Other Outage	Planned Outage	17-11-2025	11:04	17-11-2025	13:55	2:51	0.004275	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
40	17-11-2025	Part of : A3-BLOCK KALKA JI EXTN	336	Other Outage	Planned Outage	17-11-2025	11:02	17-11-2025	13:35	2:33	0.000000	REPLACEMENT OF HT BUSHING ROD
41	18-11-2025	Part of : E-BLOCK MASJID MOTH,	228	Other Outage	Planned Outage	18-11-2025	11:06	18-11-2025	13:53	2:47	0.000928	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
42	18-11-2025	Part of : TUGHLAKABAD RAILWAY COLONY,	1559	Other Outage	Planned Outage	18-11-2025	11:04	18-11-2025	13:58	2:54	0.000967	REPLACEMENT OF HT BUSHING ROD
43	18-11-2025	Part of : A9-BLOCK KALKA JI EXTN,	246	Other Outage	Planned Outage	18-11-2025	11:04	18-11-2025	13:57	2:53	0.000000	REPLACEMENT OF HT BUSHING ROD
44	19-11-2025	Part of : TEHKHAND VILLAGE	679	Other Outage	Unplanned Outage	19-11-2025	11:28	19-11-2025	13:16	1:48	0.000000	REFILLING OIL IN LT TRANSFORMER
45	19-11-2025	Part of : C-BLOCK KALKA JI	506	Other Outage	Planned Outage	19-11-2025	11:07	19-11-2025	14:23	3:16	0.004900	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
46	20-11-2025	Part of : A 8-BLOCK KALKAJI EXTENSION	538	Other Outage	Planned Outage	20-11-2025	11:00	20-11-2025	13:59	2:59	0.000000	REPLACEMENT OF HT BUSHING ROD
47	20-11-2025	Part of : GREATER KAILASH PART-3	282	Other Outage	Planned Outage	20-11-2025	11:10	20-11-2025	13:58	2:48	0.001400	REPLACEMENT OF HT BUSHING ROD
48	20-11-2025	Part of : TUGHLAQABAD VILLAGE	402	Other Outage	Planned Outage	20-11-2025	11:07	20-11-2025	13:54	2:47	0.001392	LT CIRCUIT MAINTENANCE WORK
49	21-11-2025	Part of : DDA SHED OKHLA PHASE-1	45	Other Outage	Unplanned Outage	21-11-2025	10:59	21-11-2025	12:52	1:53	0.000314	TRANSFORMER OIL TOP UP WORK
50	21-11-2025	Part of : A4-BLOCK KALKA JI EXTN	311	Other Outage	Planned Outage	21-11-2025	11:49	21-11-2025	14:03	2:14	0.000000	REPLACEMENT OF LT BUSHING ROD
51	22-11-2025	Part of : TILAK KHAND GIRI NAGAR,	477	Other Outage	Planned Outage	22-11-2025	12:18	22-11-2025	14:10	1:52	0.003733	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
52	22-11-2025	Part of : C-BLOCK CR PARK,	994	Other Outage	Planned Outage	22-11-2025	11:12	22-11-2025	14:09	2:57	0.001475	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
53	22-11-2025	Part of : TUGHLAQABAD FORT TUGHLAKABAD,	497	Other Outage	Planned Outage	22-11-2025	10:59	22-11-2025	13:55	2:56	0.000978	REPLACEMENT OF LT BUSHING ROD
54	24-11-2025	Part of : BALMUKUND KHAND GOVINDPURI	599	Other Outage	Planned Outage	24-11-2025	11:09	24-11-2025	14:09	3:00	0.001500	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
55	24-11-2025	Part of : A-BLOCK CHITTARANJAN PARK	187	Other Outage	Planned Outage	24-11-2025	11:38	24-11-2025	14:08	2:30	0.001250	REPLACEMENT OF HT BUSHING ROD
56	24-11-2025	Part of : A10-BLOCK KALKA JI EXTN.	273	Other Outage	Planned Outage	24-11-2025	11:07	24-11-2025	13:58	2:51	0.000000	REPLACEMENT OF HT BUSHING ROD
57	25-11-2025	Part of : B-BLOCK OKHLA PHASE-1	333	Other Outage	Unplanned Outage	25-11-2025	13:06	25-11-2025	13:46	0:40	0.000378	CABLE DAMAGED BY OUT SIDE AGENCY (UNKNOWN)
58	25-11-2025	Part of : POCKET 52 CHITTARANJAN PARK	254	Other Outage	Planned Outage	25-11-2025	11:05	25-11-2025	13:46	2:41	0.000447	DT REPLACEMENT
59	26-11-2025	Part of : E-BLOCK KALKA JI,	174	Other Outage	Planned Outage	26-11-2025	10:58	26-11-2025	13:17	2:19	0.001158	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
60	26-11-2025	Part of : A13-BLOCK KALKA JI EXTN,	392	Other Outage	Planned Outage	26-11-2025	10:57	26-11-2025	13:44	2:47	0.000000	REPLACEMENT OF HT BUSHING ROD
61	26-11-2025	Part of : C-BLOCK CR PARK,	275	Other Outage	Planned Outage	26-11-2025	11:09	26-11-2025	13:45	2:36	0.000000	REPLACEMENT OF LT BUSHING ROD
62	27-11-2025	Part of : TUGHLAKABAD,TARA APARTMENT,TUGHLAQABAD FORT TUGHLAKABAD	183	Other Outage	Unplanned Outage	27-11-2025	13:55	27-11-2025	14:38	0:43	0.000908	HT SYSTEM FAULT
63	27-11-2025	Part of : D-BLOCK OKHLA PHASE-1	30	Other Outage	Unplanned Outage	27-11-2025	11:05	27-11-2025	13:02	1:57	0.000325	REPLACEMENT OF LT ACB
64	27-11-2025	Part of : A11-BLOCK KALKA JI EXTN	330	Other Outage	Planned Outage	27-11-2025	11:04	27-11-2025	14:14	3:10	0.000000	REPLACEMENT OF LT BUSHING ROD
65	28-11-2025	Part of : GANGOTRI ENCLAVE	501	Other Outage	Planned Outage	28-11-2025	11:13	28-11-2025	13:28	2:15	0.000750	REPLACEMENT OF GAS KIT AND OIL SEAL
66	28-11-2025	Part of : E-BLOCK KALKA JI	289	Other Outage	Planned Outage	28-11-2025	11:12	28-11-2025	14:06	2:54	0.004350	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING
67	28-11-2025	Part of : A12-BLOCK KALKA JI EXTN.	280	Other Outage	Planned Outage	28-11-2025	11:14	28-11-2025	14:06	2:52	0.000000	REPLACEMENT OF HT BUSHING ROD
68	29-11-2025	Part of : BLOCK D HARIJAN COLONY GOVINDPURI KALKAJI	932	Other Outage	Planned Outage	29-11-2025	10:59	29-11-2025	13:44	2:45	0.000000	REPLACEMENT OF HT BUSHING ROD
69	30-11-2025	Part of : B-BLOCK OKHLA PHASE-1,	427	Other Outage	Planned Outage	30-11-2025	11:10	30-11-2025	14:11	3:01	0.004022	REPLACEMENT OF HT BUSHING ROD
70	30-11-2025	Part of : DDA SHED OKHLA PHASE-1,	98	Other Outage	Planned Outage	30-11-2025	11:02	30-11-2025	13:43	2:41	0.000671	REPLACEMENT OF LT BUSHING ROD
71	30-11-2025	Part of : B-BLOCK OKHLA PHASE-1,	272	Other Outage	Planned Outage	30-11-2025	11:01	30-11-2025	13:42	2:41	0.000671	REPLACEMENT OF LT BUSHING ROD
72	01-11-2025	Part of : SULTANPUR	172	Other Outage	Planned Outage	01-11-2025	13:54	01-11-2025	15:20	1:26	0.000000	1PH DB REPLACEMENT,3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,LT AB SAGGING PER SPAN
73	03-11-2025	PART OF : RAJPUR KHURD EXTENSION CHHATARPUR	221	Other Outage	Planned Outage	03-11-2025	10:43	03-11-2025	14:00	3:17	0.000000	3PH HT AB END TERMINATION REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
74	03-11-2025	PART OF : SULTANPUR	6	Other Outage	Planned Outage	03-11-2025	10:55	03-11-2025	14:05	3:10	0.001267	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD
75	03-11-2025	PART OF : DERA VILLAGE	310	Other Outage	Planned Outage	03-11-2025	11:10	03-11-2025	13:34	2:24	0.000000	BUS BAR REPLACEMENT PER PHASE
76	03-11-2025	PART OF : SULTANPUR	1205	Other Outage	Planned Outage	03-11-2025	10:30	03-11-2025	13:34	3:04	0.000000	3PH DB REPLACEMENT
77	04-11-2025	Part of : ANSAL SATBARI	39	Other Outage	Planned Outage	04-11-2025	13:07	04-11-2025	15:42	2:35	0.002153	HT FEEDER PILLAR CLEANING
78	04-11-2025	Part of : LANGARI DHANI	69	Other Outage	Planned Outage	04-11-2025	13:10	04-11-2025	15:42	2:32	0.002111	HT FEEDER PILLAR CLEANING
79	04-11-2025	Part of : AYA NAGAR VILLAGE	1259	Other Outage	Planned Outage	04-11-2025	11:21	04-11-2025	15:08	3:47	0.000631	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
80	04-11-2025	Part of : NEW GAWALPAHARI VILLAGE,GAWALPAHARI VILLAGE,DERA VILLAGE,MANDI VILLAGE,AMBEDKAR COLONY MANDI	2184	Other Outage	Planned Outage	04-11-2025	11:12	04-11-2025	15:27	4:15	0.007083	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,JUMPER REPLACEMENT PER POLE
81	04-11-2025	Part of : AYA NAGAR PHASE 1	28	Other Outage	Planned Outage	04-11-2025	10:59	04-11-2025	15:06	4:07	0.001647	REPLACEMENT OF HT BUSHING ROD
82	05-11-2025	Part of : AYA NAGAR PHASE 1,ADARSH ENCLAVE AYA NAGAR EXTENSION	1467	Other Outage	Planned Outage	05-11-2025	10:26	05-11-2025	11:28	1:02	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF HT BOOTS
83	05-11-2025	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	502	Other Outage	Planned Outage	05-11-2025	11:13	05-11-2025	14:26	3:13	0.001340	REPLACEMENT OF HT BUSHING ROD
84	06-11-2025	Part of : CHANDAN HOLA,FATEHPUR BERI,ANSAL VILLAS SAT BARI,ASOLA,	1751	Other Outage	Unplanned Outage	06-11-2025	14:59	06-11-2025	15:33	0:34	0.000000	CONDUCTOR REPLACEMENT ON HT O/H CIRCUIT
85	06-11-2025	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION AYA NAGAR,	1457	Other Outage	Planned Outage	06-11-2025	11:31	06-11-2025	15:06	3:35	0.000000	INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL
86	06-11-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,ANSAL VILLAS SAT BARI,	2218	Other Outage	Planned Outage	06-11-2025	10:34	06-11-2025	13:53	3:19	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
87	06-11-2025	Part of : MANDI VILLAGE,	443	Other Outage	Planned Outage	06-11-2025	10:58	06-11-2025	15:04	4:06	0.000000	1PH DB REPLACEMENT,1PH DB REVAMPING,3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER
88	07-11-2025	Part of : ANSAL VILLAS SAT BARI,GADAIPUR JAUNAPUR,JAUNAPUR VILLAGE	47	Other Outage	Unplanned Outage	07-11-2025	17:25	07-11-2025	17:50	0:25	0.000083	BIRDAGE
89	07-11-2025	Part of : DLF FARMS,CHHATARPUR,SULTANPUR	170	Other Outage	Unplanned Outage	07-11-2025	10:50	07-11-2025	11:18	0:28	0.000148	BIRDAGE
90	07-11-2025	Part of : BLOCK E & G AYA NAGAR EXTENSION AYA NAGAR,AYA NAGAR PHASE 1 AYA NAGAR,ADARSH ENCLAVE AYA NAGAR EXTENSION AYA NAGAR,SULTANPUR,GADAIPUR DLF FARMS,MANGLAPURI VILLAGE SULTANPUR	4337	Other Outage	Unplanned Outage	07-11-2025	08:41	07-11-2025	09:29	0:48	0.000627	CABLE FAULT
91	07-11-2025	Part of : GADPUR FARM DLF FARMS,GADAIPUR DLF FARMS,GADAIPUR JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,SULTANPUR	1491	Other Outage	Planned Outage	07-11-2025	12:33	07-11-2025	13:56	1:23	0.000000	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN,GUARD WIRES SAGGING PER SPAN,JUMPER REPLACEMENT PER POLE,TAPPING OF JUMPERS
92	08-11-2025	Part of : C-BLOCK CHHATARPUR EXTENSION,A1,D,G & F-BLOCK CHHATARPUR VILLAGE	4614	Other Outage	Planned Outage	08-11-2025	10:40	08-11-2025	13:54	3:14	0.000000	3PH HT AB CABLE REPLACEMENT
93	08-11-2025	Part of : MANDI VILLAGE	271	Other Outage	Planned Outage	08-11-2025	10:58	08-11-2025	15:02	4:04	0.000000	LT CIRCUIT MAINTENANCE WORK
94	10-11-2025	Part of : PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR	990	Other Outage	Unplanned Outage	10-11-2025	13:18	10-11-2025	14:17	0:59	0.000000	TRANSFORMER REPLACEMENT
95	10-11-2025	Part of : SAT BARI,	148	Other Outage	Planned Outage	10-11-2025	13:18	10-11-2025	16:06	2:48	0.002333	FEEDER PILLAR MAINTENANCE
96	10-11-2025	Part of : DERA VILLAGE,NEW GAWALPAHARI VILLAGE,BHATI KALAN,ASOLA,FATEHPUR BERI,	2995	Other Outage	Planned Outage	10-11-2025	13:18	10-11-2025	16:04	2:46	0.002306	FEEDER PILLAR MAINTENANCE
97	10-11-2025	Part of : PHASE 2 CHHATARPUR ENCLAVE CHHATARPUR,	228	Other Outage	Planned Outage	10-11-2025	11:21	10-11-2025	14:04	2:43	0.000906	PREVENTIVE MAINTENANCE
98	10-11-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,BHIM BASTI JUANAPUR,AMBEDKAR COLONY MANDI,MANDI VILLAGE,SULTANPUR,	3534	Other Outage	Planned Outage	10-11-2025	10:58	10-11-2025	15:38	4:40	0.000000	MAINTENANCE
99	10-11-2025	Part of : AYA NAGAR VILLAGE AYA NAGAR,	773	Other Outage	Planned Outage	10-11-2025	11:37	10-11-2025	15:35	3:58	0.000000	LUGS DAMAGE
100	11-11-2025	Part of : BLOCK F AYA NAGAR EXTENSION AYA NAGAR	328	Other Outage	Planned Outage	11-11-2025	14:34	11-11-2025	15:28	0:54	0.000210	REPLACEMENT OF HT BUSHING ROD
101	11-11-2025	Part of : BHATI KALAN	82	Other Outage	Planned Outage	11-11-2025	14:35	11-11-2025	16:21	1:46	0.001472	BUS BAR REPLACEMENT PER PHASE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
102	11-11-2025	Part of : SULTANPUR	198	Other Outage	Planned Outage	11-11-2025	11:44	11-11-2025	14:08	2:24	0.000400	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
103	11-11-2025	Part of : AYA NAGAR PHASE 1 AYA NAGAR	2	Other Outage	Planned Outage	11-11-2025	10:13	11-11-2025	14:22	4:09	0.001660	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
104	11-11-2025	Part of : PHASE 2 CHHATARPUR ENCLAVE	192	Other Outage	Planned Outage	11-11-2025	10:25	11-11-2025	13:47	3:22	0.001122	REPLACEMENT OF HT BUSHING ROD
105	11-11-2025	Part of : BLOCK A1 CHHATARPUR VILLAGE	774	Other Outage	Planned Outage	11-11-2025	11:28	11-11-2025	13:48	2:20	0.000389	REPLACEMENT OF HT BUSHING ROD
106	11-11-2025	Part of : CHHATARPUR	750	Other Outage	Planned Outage	11-11-2025	10:35	11-11-2025	15:11	4:36	0.000000	3PH DB REPLACEMENT
107	12-11-2025	Part of : FATEHPUR BERI	788	Other Outage	Planned Outage	12-11-2025	14:45	12-11-2025	15:56	1:11	0.000592	BUS BAR REPLACEMENT PER PHASE
108	12-11-2025	Part of : BLOCK C CHHATARPUR EXTENSION	333	Other Outage	Planned Outage	12-11-2025	10:46	12-11-2025	14:14	3:28	0.001156	REPLACEMENT OF HT BUSHING ROD
109	13-11-2025	Part of : BLOCK F AYA NAGAR EXTENSION	294	Other Outage	Planned Outage	13-11-2025	12:04	13-11-2025	14:45	2:41	0.000626	REPLACEMENT OF LT BUSHING ROD
110	13-11-2025	Part of : CHHATARPUR	21	Other Outage	Planned Outage	13-11-2025	11:51	13-11-2025	14:56	3:05	0.000000	REPLACEMENT OF HT BUSHING ROD
111	13-11-2025	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	269	Other Outage	Planned Outage	13-11-2025	12:00	13-11-2025	15:00	3:00	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
112	13-11-2025	Part of : AYA NAGAR PHASE 1	2	Other Outage	Planned Outage	13-11-2025	10:17	13-11-2025	14:46	4:29	0.001046	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
113	13-11-2025	Part of : SULTANPUR	352	Other Outage	Planned Outage	13-11-2025	10:56	13-11-2025	15:04	4:08	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
114	14-11-2025	Part of : FATEHPUR BERI,ASOLA	1742	Other Outage	Planned Outage	14-11-2025	16:08	14-11-2025	17:03	0:55	0.000764	FEEDER PILLAR MAINTENANCE
115	14-11-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR,ANSAL VILLAS SAT BARI	2220	Other Outage	Planned Outage	14-11-2025	11:37	14-11-2025	14:51	3:14	0.000000	AB CABLE REPLACEMENT
116	14-11-2025	Part of : AYA NAGAR PHASE 1	2	Other Outage	Planned Outage	14-11-2025	09:59	14-11-2025	14:39	4:40	0.001089	PREVENTIVE MAINTENANCE
117	15-11-2025	Part of : AYA NAGAR VILLAGE AYA NAGAR	1268	Other Outage	Planned Outage	15-11-2025	10:18	15-11-2025	13:47	3:29	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR
118	15-11-2025	Part of : MITTAL GARDEN SAINIK FARM,DR AMBEDKAR COLONY CHHATARPUR	218	Other Outage	Planned Outage	15-11-2025	09:44	15-11-2025	13:11	3:27	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
119	15-11-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR	216	Other Outage	Planned Outage	15-11-2025	10:34	15-11-2025	13:48	3:14	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF LUGS
120	16-11-2025	Part of : ASOLA,ANSAL VILLAS SAT BARI	740	Other Outage	Unplanned Outage	16-11-2025	05:38	16-11-2025	06:13	0:35	0.000350	LT POLE BROKEN BY UNKNOWN VEHICLE
121	17-11-2025	Part of : AYA NAGAR PHASE 1	1	Other Outage	Planned Outage	17-11-2025	15:30	17-11-2025	16:23	0:53	0.000206	REPLACEMENT OF LT BUSHING ROD
122	17-11-2025	Part of : AYA NAGAR PHASE 1	2	Other Outage	Planned Outage	17-11-2025	12:57	17-11-2025	14:03	1:06	0.000257	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
123	17-11-2025	Part of : PHASE-V AYA NAGAR EXTENSION	927	Other Outage	Planned Outage	17-11-2025	12:31	17-11-2025	15:37	3:06	0.000723	REPLACEMENT OF LT BUSHING ROD
124	17-11-2025	Part of : BLOCK D CHHATARPUR VILLAGE,BLOCK C CHHATARPUR EXTENSION, BLOCK A1 CHHATARPUR VILLAGE	4616	Other Outage	Planned Outage	17-11-2025	10:34	17-11-2025	13:58	3:24	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
125	17-11-2025	Part of : JAUNAPUR VILLAGE	887	Other Outage	Planned Outage	17-11-2025	11:05	17-11-2025	14:48	3:43	0.000000	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
126	18-11-2025	Part of : CHHATARPUR ENCLAVE CHHATARPUR,	11	Other Outage	Planned Outage	18-11-2025	10:10	18-11-2025	13:38	3:28	0.000000	REPLACEMENT OF FAULTY END BOX
127	18-11-2025	Part of : ARJUN GARH AYA NAGAR,	7	Other Outage	Planned Outage	18-11-2025	11:24	18-11-2025	14:08	2:44	0.000638	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
128	19-11-2025	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR	183	Other Outage	Planned Outage	19-11-2025	12:03	19-11-2025	13:30	1:27	0.000580	REPLACEMENT OF LT BUSHING ROD
129	19-11-2025	Part of : BLOCK C CHHATARPUR EXTENSION	441	Other Outage	Planned Outage	19-11-2025	10:55	19-11-2025	14:16	3:21	0.001117	REPLACEMENT OF LT BUSHING ROD
130	19-11-2025	Part of : POCKET A & B DR AMBEDKAR COLONY CHHATARPUR,DR AMBEDKAR COLONY CHHATARPUR	2676	Other Outage	Planned Outage	19-11-2025	10:05	19-11-2025	12:13	2:08	0.000000	3PH HT AB END TERMINATION REPLACEMENT
131	19-11-2025	Part of : JAUNAPUR VILLAGE	599	Other Outage	Planned Outage	19-11-2025	11:32	19-11-2025	14:18	2:46	0.000000	DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING ROD
132	20-11-2025	Part of : SAT BARI	19	Other Outage	Planned Outage	20-11-2025	15:31	20-11-2025	16:17	0:46	0.000639	FEEDEER PILLAR CLEANING
133	20-11-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	224	Other Outage	Planned Outage	20-11-2025	11:43	20-11-2025	15:14	3:31	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
134	20-11-2025	Part of : AYA NAGAR VILLAGE	1259	Other Outage	Planned Outage	20-11-2025	11:01	20-11-2025	14:02	3:01	0.000503	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF SILICAGEL IN BREATHER
135	20-11-2025	Part of : SHIV MANDIR AYA NAGAR	1457	Other Outage	Planned Outage	20-11-2025	11:18	20-11-2025	14:38	3:20	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
136	20-11-2025	Part of : A1-BLOCK CHHATARPUR VILLAGE	697	Other Outage	Planned Outage	20-11-2025	10:23	20-11-2025	14:01	3:38	0.003028	REPLACEMENT OF HT BUSHING ROD
137	21-11-2025	Part of : SULTANPUR, JAUNAPUR VILLAGE, RADHEY MOHAN DRIVE, DLF FARMS, GADAIPUR JAUNAPUR	87	Other Outage	Unplanned Outage	21-11-2025	15:25	21-11-2025	16:53	1:28	0.000269	TREE TOUCHING
138	21-11-2025	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	601	Other Outage	Planned Outage	21-11-2025	12:59	21-11-2025	16:08	3:09	0.000000	REPLACEMENT OF LT BUSHING ROD
139	21-11-2025	Part of : ANSAL VILLAS SAT BARI	36	Other Outage	Planned Outage	21-11-2025	13:23	21-11-2025	16:13	2:50	0.002361	BUS BAR REPLACEMENT PER PHASE
140	21-11-2025	Part of : RAJPUR KHURD VILLAGE CHHATARPUR,PHASE 2 CHHATARPUR ENCLAVE,MITTAL GARDEN SAINIK FARM	4129	Other Outage	Planned Outage	21-11-2025	10:47	21-11-2025	13:50	3:03	0.000000	3PH HT AB END TERMINATION REPLACEMENT
141	21-11-2025	Part of : SULTANPUR	80	Other Outage	Planned Outage	21-11-2025	10:27	21-11-2025	14:41	4:14	0.000000	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
142	22-11-2025	Part of : MITTAL GARDEN SAINIK FARM,DR AMBEDKAR COLONY CHHATARPUR,	211	Other Outage	Planned Outage	22-11-2025	10:14	22-11-2025	12:03	1:49	0.000000	3PH HT AB END TERMINATION REPLACEMENT
143	22-11-2025	Part of : CHHATARPUR,	750	Other Outage	Planned Outage	22-11-2025	10:27	22-11-2025	13:39	3:12	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
144	24-11-2025	Part of : ASOLA,ANSAL VILLAS,SAT BARI	759	Other Outage	Unplanned Outage	24-11-2025	07:46	24-11-2025	08:29	0:43	0.000669	BIRDAGE
145	24-11-2025	Part of : ASOLA	358	Other Outage	Planned Outage	24-11-2025	13:34	24-11-2025	15:44	2:10	0.001806	BUS BAR REPLACEMENT PER PHASE
146	24-11-2025	Part of : C-BLOCK CHHATARPUR EXTENSION	45	Other Outage	Planned Outage	24-11-2025	10:53	24-11-2025	13:50	2:57	0.000983	REPLACEMENT OF HT BUSHING ROD
147	24-11-2025	Part of : DERA VILLAGE,NEW GAWALPAHARI VILLAGE,MANDI VILLAGE,GAWALPAHARI VILLAGE,AMBEDKAR COLONY MANDI	2248	Other Outage	Planned Outage	24-11-2025	11:08	24-11-2025	15:07	3:59	0.000000	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMENT,CONNECTING OF NEW EARTHING PER EARTHING,JUMPER REPLACEMENT PER POLE
148	24-11-2025	Part of : SULTANPUR	100	Other Outage	Planned Outage	24-11-2025	10:19	24-11-2025	14:57	4:38	0.000000	LT CIRCUIT MAINTENANCE WORK
149	25-11-2025	Part of : CHHATARPUR ENCLAVE	313	Other Outage	Planned Outage	25-11-2025	10:49	25-11-2025	14:11	3:22	0.000000	REPLACEMENT OF LT BUSHING ROD
150	25-11-2025	Part of : ASOLA	161	Other Outage	Planned Outage	25-11-2025	11:05	25-11-2025	13:34	2:29	0.001242	BUS BAR REPLACEMENT PER PHASE
151	25-11-2025	Part of : SULTANPUR	202	Other Outage	Planned Outage	25-11-2025	11:26	25-11-2025	14:56	3:30	0.000817	REPLACEMENT OF LT BUSHING ROD
152	25-11-2025	Part of : SULTANPUR	86	Other Outage	Planned Outage	25-11-2025	10:38	25-11-2025	14:38	4:00	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR
153	26-11-2025	Part of : ASOLA,ASOLA WILD LIFE SANCTUARY ASOLA	1627	Other Outage	Unplanned Outage	26-11-2025	04:02	26-11-2025	04:04	0:02	0.000005	HT SYSTEM FAULT
154	26-11-2025	Part of : PHASE 2 CHHATARPUR ENCLAVE CHHATARPUR,	465	Other Outage	Planned Outage	26-11-2025	11:16	26-11-2025	14:10	2:54	0.001450	REPLACEMENT OF LT BUSHING ROD
155	26-11-2025	Part of : ANSAL VILLAS SAT BARI,	11	Other Outage	Planned Outage	26-11-2025	11:43	26-11-2025	13:58	2:15	0.001875	BUS BAR REPLACEMENT PER PHASE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
156	26-11-2025	Part of : PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR,	141	Other Outage	Planned Outage	26-11-2025	10:26	26-11-2025	14:08	3:42	0.001233	REPLACEMENT OF LT BUSHING ROD
157	26-11-2025	Part of : AMBEDKAR COLONY MANDI,	832	Other Outage	Planned Outage	26-11-2025	10:42	26-11-2025	14:34	3:52	0.000902	3PH DB REPLACEMENT,LT AB SAGGING PER SPAN
158	27-11-2025	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR	827	Other Outage	Planned Outage	27-11-2025	11:24	27-11-2025	13:09	1:45	0.000000	3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER
159	27-11-2025	Part of : BLOCK G AYA NAGAR EXTENSION AYA NAGAR	1177	Other Outage	Planned Outage	27-11-2025	12:42	27-11-2025	15:48	3:06	0.000000	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
160	27-11-2025	Part of : BLOCK C CHHATARPUR EXTENSION	540	Other Outage	Planned Outage	27-11-2025	11:01	27-11-2025	15:06	4:05	0.000000	REPLACEMENT OF FAULTY END BOX
161	27-11-2025	Part of : SULTANPUR	938	Other Outage	Planned Outage	27-11-2025	10:45	27-11-2025	14:40	3:55	0.000914	1PH DB REVAMPING,3PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
162	28-11-2025	Part of : FATEHPUR BERI	788	Other Outage	Planned Outage	28-11-2025	13:37	28-11-2025	15:42	2:05	0.001736	BUS BAR REPLACEMENT PER PHASE
163	28-11-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	222	Other Outage	Planned Outage	28-11-2025	10:19	28-11-2025	14:14	3:55	0.000000	3PH HT AB CABLE REPLACEMENT
164	28-11-2025	Part of : AYA NAGAR PHASE-1	28	Other Outage	Planned Outage	28-11-2025	10:30	28-11-2025	12:45	2:15	0.000000	LT CIRCUIT MAINTENANCE
165	29-11-2025	Part of : ANSAL VILLAS SAT BARI	211	Other Outage	Planned Outage	29-11-2025	12:23	29-11-2025	14:12	1:49	0.000908	FEEDER PILLAR CLEANING
166	29-11-2025	Part of : SULTANPUR	41	Other Outage	Planned Outage	29-11-2025	11:01	29-11-2025	14:16	3:15	0.001354	REPLACEMET OF HT BUSHING ROD
167	29-11-2025	Part of : DLF FARMS	38	Other Outage	Planned Outage	29-11-2025	10:57	29-11-2025	14:15	3:18	0.000000	REPLACEMET OF FAULTY END BOX
168	29-11-2025	Part of : ARJUN GARH AYA NAGAR	568	Other Outage	Planned Outage	29-11-2025	11:07	29-11-2025	14:18	3:11	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS
169	29-11-2025	Part of : MANDI VILLAGE	443	Other Outage	Planned Outage	29-11-2025	11:01	29-11-2025	13:30	2:29	0.000000	3PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
170	01-11-2025	Part of : LAL GUMBAD BASTI SADHNA ENCLAVE PANCHSHILA PARK	317	Other Outage	Planned Outage	01-11-2025	12:51	01-11-2025	14:46	1:55	0.000256	END TERMINATION COVER REPLACEMENT,REPLACEMENT OF FAULTY END BOX
171	01-11-2025	Part of : BLOCK B GULMOHAR PARK	328	Other Outage	Planned Outage	01-11-2025	12:48	01-11-2025	13:56	1:08	0.000227	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
172	01-11-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	489	Other Outage	Planned Outage	01-11-2025	12:48	01-11-2025	14:11	1:23	0.000000	3PH DB REVAMPING,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
173	02-11-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT,	422	Other Outage	Planned Outage	02-11-2025	11:12	02-11-2025	13:58	2:46	0.000323	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
174	03-11-2025	Part of : C-7 , HAUZ KHAS	0	Other Outage	Unplanned Outage	03-11-2025	06:35	03-11-2025	07:11	0:36	0.000260	CABLE FAULT
175	03-11-2025	PART OF : BLOCK M SOUTH EXTENSION II	3	Other Outage	Planned Outage	03-11-2025	08:54	03-11-2025	10:47	1:53	0.000314	FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,LT AB SAGGING PER SPAN
176	03-11-2025	PART OF : DEER PARK HAUZ KHAS	207	Other Outage	Planned Outage	03-11-2025	11:07	03-11-2025	13:10	2:03	0.000513	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
177	03-11-2025	PART OF : BLOCK A KATWARIA SARAI	613	Other Outage	Planned Outage	03-11-2025	12:51	03-11-2025	15:18	2:27	0.000082	3PH DB REPLACEMENT,3PH DB REVAMPING,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
178	03-11-2025	PART OF : SHAHPUR JAT VILLAGE SIRI FORT	489	Other Outage	Planned Outage	03-11-2025	11:24	03-11-2025	13:38	2:14	0.000298	1PH DB REVAMPING,3PH DB REPLACEMENT,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
179	04-11-2025	Part of : TEL. EXCHANGE HAUZ KHAS (HT CONSUMER)	1	Other Outage	Planned Outage	04-11-2025	12:38	04-11-2025	13:25	0:47	0.000131	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
180	04-11-2025	Part of : A-BLOCK SOUTH EXTENSION-2	449	Other Outage	Planned Outage	04-11-2025	13:13	04-11-2025	14:51	1:38	0.001225	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
181	04-11-2025	Part of : IIT MINI CAMPUS	88	Other Outage	Planned Outage	04-11-2025	11:56	04-11-2025	13:33	1:37	0.000189	REPLACEMENT OF FAULTY END BOX
182	04-11-2025	Part of : MAYFAIR GARDEN HAUZ KHAS	302	Other Outage	Planned Outage	04-11-2025	12:13	04-11-2025	13:55	1:42	0.000198	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
183	04-11-2025	Part of : YUSUF SARAI	401	Other Outage	Planned Outage	04-11-2025	09:59	04-11-2025	12:05	2:06	0.000280	LT CIRCUIT MAINTENANCE WORK
184	06-11-2025	Part of : BLOCK B 3 SAFDARJUNG ENCLAVE,	278	Other Outage	Planned Outage	06-11-2025	11:17	06-11-2025	13:09	1:52	0.000249	CONDUCTOR REPLACEMENT PER SPAN
185	06-11-2025	Part of : HTC:KAMAL CINEMA	1	Other Outage	Planned Outage	06-11-2025	13:20	06-11-2025	16:26	3:06	0.000517	END TERMINATION COVER REPLACEMENT,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,SF6 GAS FILLING
186	06-11-2025	Part of : BLOCK A QUTAB INSTITUTIONAL AREA,	21	Other Outage	Planned Outage	06-11-2025	11:44	06-11-2025	14:14	2:30	0.000292	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
187	06-11-2025	Part of : BLOCK D GULMOHAR PARK,	286	Other Outage	Planned Outage	06-11-2025	10:26	06-11-2025	14:02	3:36	0.000300	3PH DB REVAMPING,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
188	07-11-2025	Part of : B-6 SJ ENCLAVE	2	Other Outage	Planned Outage	07-11-2025	11:09	07-11-2025	12:26	1:17	0.000321	AUXILARY SUPPLY FOR RELAYS,END TERMINATION COVER REPLACEMENT,SF6 GAS FILLING
189	07-11-2025	Part of : GAUTAM NAGAR	1053	Other Outage	Planned Outage	07-11-2025	10:10	07-11-2025	13:41	3:31	0.001407	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
190	07-11-2025	Part of : POCKET B KATWARIA SARAI	1300	Other Outage	Planned Outage	07-11-2025	11:17	07-11-2025	14:51	3:34	0.000416	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
191	07-11-2025	Part of : BLOCK F POLICE COLONY HAUZ KHAS	183	Other Outage	Planned Outage	07-11-2025	11:18	07-11-2025	13:36	2:18	0.000192	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
192	08-11-2025	Part of : G-BLOCK HAUZ KHAS	160	Other Outage	Planned Outage	08-11-2025	11:16	08-11-2025	13:42	2:26	0.000324	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
193	08-11-2025	Part of : M/S DIR OF WORKS MINE (HT CONSUMER)	1	Other Outage	Planned Outage	08-11-2025	11:31	08-11-2025	13:36	2:05	0.000243	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
194	08-11-2025	Part of : MASJID MOTH VILLAGE SOUTH EXTENSION-2	1262	Other Outage	Planned Outage	08-11-2025	10:34	08-11-2025	13:46	3:12	0.001280	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
195	09-11-2025	Part of : RAJ NAGAR, NAUROJI NAGAR SAFDARJUNG ENCLAVE, NDMA SFDERJUNG ENCLAVE (HTC)	841	Other Outage	Unplanned Outage	09-11-2025	11:07	09-11-2025	12:02	0:55	0.000626	HT SYSTEM FAULT
196	10-11-2025	Part of : HTC:JNU NEW CAMPUS	2	Other Outage	Planned Outage	10-11-2025	12:45	10-11-2025	13:08	0:23	0.000045	MAINTENANCE
197	10-11-2025	Part of : HTC:JNU NEW CAMPUS	2	Other Outage	Planned Outage	10-11-2025	12:43	10-11-2025	13:07	0:24	0.000067	MAINTENANCE
198	10-11-2025	Part of : BLOCK B 7 ARJUN NAGAR SAFDARJUNG ENCLAVE,	488	Other Outage	Planned Outage	10-11-2025	11:12	10-11-2025	12:59	1:47	0.000743	PREVENTIVE MAINTENANCE
199	10-11-2025	Part of : BLOCK B KATWARIA SARAI,	1712	Other Outage	Planned Outage	10-11-2025	11:11	10-11-2025	14:16	3:05	0.000925	PREVENTIVE MAINTENANCE
200	10-11-2025	Part of : BLOCK G HAUZ KHAS,	137	Other Outage	Planned Outage	10-11-2025	10:47	10-11-2025	14:00	3:13	0.000804	PREVENTIVE MAINTENANCE
201	10-11-2025	Part of : UDAY PARK SOUTH EXTENSION II,	361	Other Outage	Planned Outage	10-11-2025	10:16	10-11-2025	13:27	3:11	0.000318	LT CIRCUIT FEEDER PILLAR MAINTENANCE
202	11-11-2025	Part of : BLOCK P SOUTH EXTENSION II	842	Other Outage	Planned Outage	11-11-2025	10:52	11-11-2025	13:53	3:01	0.001106	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
203	11-11-2025	Part of : BLOCK X HAUZ KHAS	256	Other Outage	Planned Outage	11-11-2025	10:59	11-11-2025	13:37	2:38	0.000132	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
204	12-11-2025	Part of : ASIAN GAMES VILLAGE COMPLEX SIRI FORT	379	Other Outage	Unplanned Outage	12-11-2025	01:17	12-11-2025	02:07	0:50	0.000444	CABLE FAULT
205	12-11-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	271	Other Outage	Planned Outage	12-11-2025	12:42	12-11-2025	17:03	4:21	0.000000	DT REPLACEMENT
206	12-11-2025	Part of : BLOCK B 4 SAFDARJUNG ENCLAVE	700	Other Outage	Planned Outage	12-11-2025	11:10	12-11-2025	14:56	3:46	0.001883	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMENT
207	12-11-2025	Part of : GULMOHAR ENCLAVE GULMOHAR PARK	954	Other Outage	Planned Outage	12-11-2025	10:18	12-11-2025	12:35	2:17	0.000038	LT CIRCUIT MAINTENANCE
208	13-11-2025	Part of : BLOCK C7 BHIM NAGAR HAUZ KHAS	282	Other Outage	Planned Outage	13-11-2025	11:50	13-11-2025	13:08	1:18	0.000217	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
209	13-11-2025	Part of : BLOCK C QUTAB INSTITUTIONAL AREA	10	Other Outage	Planned Outage	13-11-2025	11:34	13-11-2025	14:40	3:06	0.000362	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
210	13-11-2025	Part of : BLOCK L KAUSALYA PARK PADMINI ENCLAVE HAUZ KHAS	251	Other Outage	Planned Outage	13-11-2025	11:36	13-11-2025	14:06	2:30	0.000583	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
211	13-11-2025	Part of : BLOCK D SOUTH EXTENSION II	192	Other Outage	Planned Outage	13-11-2025	10:46	13-11-2025	14:44	3:58	0.000132	3PH DB REVAMPING,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPARATOR PER SPAN,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
212	14-11-2025	Part of : HTC:NDMA SFDERJUNG ENCLAVE	1	Other Outage	Planned Outage	14-11-2025	11:07	14-11-2025	12:24	1:17	0.000428	SF6 GAS FILLING MAINTENANCE
213	14-11-2025	Part of : X BLOCK HAUZ KHAS	154	Other Outage	Planned Outage	14-11-2025	11:25	14-11-2025	13:33	2:08	0.000107	LT CIRCUIT MAINTENANCE
214	15-11-2025	Part of : AYUR VIGYAN NAGAR SADIQ NAGAR,ANDREWS GANJ EXTENSION ANDREWS GANJ	276	Other Outage	Unplanned Outage	15-11-2025	04:29	15-11-2025	05:10	0:41	0.000171	CABLE FAULT
215	15-11-2025	Part of : BLOCK B KATWARIA SARAI	428	Other Outage	Planned Outage	15-11-2025	15:30	15-11-2025	15:53	0:23	0.000045	REPLACEMENT OF HT/LT CLEATS
216	15-11-2025	Part of : BLOCK A GREEN PARK EXTENSION	70	Other Outage	Planned Outage	15-11-2025	11:10	15-11-2025	13:05	1:55	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
217	15-11-2025	Part of : BLOCK E SOUTH EXTENSION II	188	Other Outage	Planned Outage	15-11-2025	10:14	15-11-2025	12:30	2:16	0.000453	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
218	15-11-2025	Part of : BLOCK E HAUZ KHAS	231	Other Outage	Planned Outage	15-11-2025	11:00	15-11-2025	14:00	3:00	0.000150	3PH DB REVAMPING,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPARATOR PER SPAN
219	15-11-2025	Part of : POCKET B KATWARIA SARAI	478	Other Outage	Planned Outage	15-11-2025	11:27	15-11-2025	15:10	3:43	0.000310	LT AB SAGGING PER SPAN
220	16-11-2025	Part of : DEER PARK HAUZ KHAS	191	Other Outage	Unplanned Outage	16-11-2025	01:36	16-11-2025	03:25	1:49	0.001060	CABLE FAULT
221	16-11-2025	Part of : SIRI FORT INSTITUTIONAL AREA	3	Other Outage	Planned Outage	16-11-2025	13:37	16-11-2025	16:23	2:46	0.000138	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
222	17-11-2025	Part of : DEER PARK HAUZ KHAS	121	Other Outage	Planned Outage	17-11-2025	15:09	17-11-2025	15:49	0:40	0.000111	DT REPLACEMENT
223	17-11-2025	Part of : BLOCK V GREEN PARK	814	Other Outage	Planned Outage	17-11-2025	11:01	17-11-2025	13:17	2:16	0.000756	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
224	17-11-2025	Part of : BLOCK C SOUTH EXTENSION II	515	Other Outage	Planned Outage	17-11-2025	10:14	17-11-2025	15:18	5:04	0.000676	3PH DB REVAMPING,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPARATOR PER SPAN,JUMPER REPLACEMENT PER POLE,PRC REPLACEMENT PER FEEDER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
225	18-11-2025	Part of : BLOCK D SOAMI NAGAR SOUTH SOAMI NAGAR,	508	Other Outage	Planned Outage	18-11-2025	15:22	18-11-2025	15:59	0:37	0.000072	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
226	18-11-2025	Part of : BLOCK P HAUZ KHAS ENCLAVE HAUZ KHAS,	234	Other Outage	Planned Outage	18-11-2025	11:08	18-11-2025	14:06	2:58	0.001236	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
227	18-11-2025	Part of : NEETI BAGH,	392	Other Outage	Planned Outage	18-11-2025	10:08	18-11-2025	14:16	4:08	0.001240	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
228	19-11-2025	Part of : BLOCK B 7 ARJUN NAGAR SAFDARJUNG ENCLAVE	1651	Other Outage	Planned Outage	19-11-2025	11:30	19-11-2025	12:48	1:18	0.000433	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
229	19-11-2025	Part of : BLOCK Y HAUZ KHAS	125	Other Outage	Planned Outage	19-11-2025	14:09	19-11-2025	16:48	2:39	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
230	19-11-2025	Part of : BLOCK X HAUZ KHAS	256	Other Outage	Planned Outage	19-11-2025	11:01	19-11-2025	13:52	2:51	0.000190	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,RELAY REPLACEMENT/VPI/FPI,REPLACEMENT OF FAULTY END BOX
231	19-11-2025	Part of : BLOCK E SOUTH EXTENSION II	21	Other Outage	Planned Outage	19-11-2025	11:13	19-11-2025	13:54	2:41	0.000224	FEEDER PILLAR CLEANING,HRC FUSE/HRC BASE REPLACEMENT,TAPPING OF MAIN CABLES,TAPPING OF SERVICE CABLES
232	20-11-2025	Part of : D-BLOCK PANCHSHEEL ENCLAVE	149	Other Outage	Planned Outage	20-11-2025	11:19	20-11-2025	13:56	2:37	0.000087	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
233	20-11-2025	Part of : A-BLOCK KATWARIA SARAI	616	Other Outage	Planned Outage	20-11-2025	11:56	20-11-2025	15:04	3:08	0.000000	LT CIRCUIT MAINTENANCE WORK
234	20-11-2025	Part of : GAUTAM NAGAR	553	Other Outage	Planned Outage	20-11-2025	10:43	20-11-2025	12:57	2:14	0.000074	LT CIRCUIT MAINTENANCE WORK
235	21-11-2025	Part of : BLOCK S PANCHSHILA PARK SOUTH, ASIAN GAMES VILLAGE COMPLEX SIRI FORT, BLOCK N PANCHSHILA PARK NORTH, PANCHSHEEL CLUB (HTC)	470	Other Outage	Unplanned Outage	21-11-2025	14:11	21-11-2025	14:59	0:48	0.000827	HT SYSTEM FAULT
236	21-11-2025	Part of : INDIAN INSTITUTE OF TECHNOLOGY DELHI HAUZ KHAS	330	Other Outage	Planned Outage	21-11-2025	12:18	21-11-2025	13:50	1:32	0.000077	CONDUCTOR REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
237	21-11-2025	Part of : BLOCK Z GREEN PARK EXTENSION GREEN PARK	22	Other Outage	Planned Outage	21-11-2025	11:12	21-11-2025	13:46	2:34	0.000513	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
238	21-11-2025	Part of : BEER SARAI	88	Other Outage	Planned Outage	21-11-2025	11:02	21-11-2025	14:39	3:37	0.000603	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
239	21-11-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	1131	Other Outage	Planned Outage	21-11-2025	11:14	21-11-2025	15:02	3:48	0.000887	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,TIGHTENEING OF NUT BOLT
240	22-11-2025	Part of : HTC:NISDOC	1	Other Outage	Planned Outage	22-11-2025	11:58	22-11-2025	14:16	2:18	0.000115	CLEANING OF HT BUSHING PER WAY,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
241	22-11-2025	Part of : ANDREWS GANJ EXTENSION ANDREWS GANJ,	225	Other Outage	Planned Outage	22-11-2025	10:31	22-11-2025	14:32	4:01	0.000536	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
242	22-11-2025	Part of : BLOCK C PANCHSHEEL ENCLAVE,	730	Other Outage	Planned Outage	22-11-2025	11:22	22-11-2025	13:28	2:06	0.000490	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
243	24-11-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	734	Other Outage	Planned Outage	24-11-2025	12:02	24-11-2025	13:46	1:44	0.000000	LT CIRCUIT MAINTENANCE WORK

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
244	24-11-2025	Part of : M-BLOCK SOUTH EXTENSION-2	217	Other Outage	Planned Outage	24-11-2025	10:38	24-11-2025	13:19	2:41	0.000089	LT CIRCUIT MAINTENANCE WORK
245	26-11-2025	Part of : AYUR VIGYAN NAGAR SADIQ NAGAR,ANDREWS GANJ EXTENSION ANDREWS GANJ	275	Other Outage	Unplanned Outage	26-11-2025	21:42	26-11-2025	22:18	0:36	0.000360	HT SYSTEM FAULT
246	26-11-2025	Part of : BEER SARAI,	594	Other Outage	Planned Outage	26-11-2025	11:18	26-11-2025	13:02	1:44	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
247	26-11-2025	Part of : BLOCK A GREEN PARK EXTENSION GREEN PARK,	521	Other Outage	Planned Outage	26-11-2025	11:09	26-11-2025	13:01	1:52	0.000622	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
248	26-11-2025	Part of : ANDREWS GANJ,	365	Other Outage	Planned Outage	26-11-2025	10:26	26-11-2025	12:57	2:31	0.000210	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
249	27-11-2025	Part of : BLOCK A 1 NAUROJI NAGAR SAFDARJUNG ENCLAVE	431	Other Outage	Planned Outage	27-11-2025	14:58	27-11-2025	15:33	0:35	0.000097	RELAY REPLACEMENT/VPI/FPI
250	27-11-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	422	Other Outage	Planned Outage	27-11-2025	13:35	27-11-2025	15:18	1:43	0.000229	1PH DB REVAMPING,3PH DB REPLACEMENT,CONDUCTOR REPLACEMENT PER SPAN
251	27-11-2025	Part of : POLICE COLONY SOUTH EXTENSION II	369	Other Outage	Planned Outage	27-11-2025	10:12	27-11-2025	13:36	3:24	0.000680	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
252	27-11-2025	Part of : MAYFAIR GARDEN HAUZ KHAS	304	Other Outage	Planned Outage	27-11-2025	13:37	27-11-2025	16:23	2:46	0.000138	3PH DB REPLACEMENT,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSULATOR REPLACEMENT PER POLE
253	28-11-2025	Part of : B-BLOCK QUTAB INSTITUTIONAL AREA	101	Other Outage	Planned Outage	28-11-2025	11:14	28-11-2025	14:42	3:28	0.000578	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
254	28-11-2025	Part of : YUSUF SARAI	931	Other Outage	Planned Outage	28-11-2025	10:55	28-11-2025	14:14	3:19	0.001106	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
255	28-11-2025	Part of : G-BLOCK HAUZ KHAS	159	Other Outage	Planned Outage	28-11-2025	11:51	28-11-2025	15:02	3:11	0.000371	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
256	29-11-2025	Part of : BLOCK C NEETI BAGH	199	Other Outage	Planned Outage	29-11-2025	11:01	29-11-2025	13:00	1:59	0.000397	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
257	29-11-2025	Part of : ANDREWS GANJ	223	Other Outage	Planned Outage	29-11-2025	13:42	29-11-2025	15:49	2:07	0.000106	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
258	29-11-2025	Part of : BLOCK A HAUZ KHAS	509	Other Outage	Planned Outage	29-11-2025	11:04	29-11-2025	14:37	3:33	0.000828	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
259	29-11-2025	Part of : KENDRIYA(RASTRIYA) HINDI SANSTHAN (HTC)	1	Other Outage	Planned Outage	29-11-2025	11:11	29-11-2025	14:57	3:46	0.000439	RELAY REPLACEMET/VPI/FPI,REPLACMET OF FAULTY END BOX
260	01-11-2025	Part of : TIGRI COLONY TIGRI SANGAM VIHAR	2865	Other Outage	Planned Outage	01-11-2025	14:14	01-11-2025	14:58	0:44	0.000134	REPLACEMENT OF LT BUSHING ROD
261	01-11-2025	Part of : BLOCK 1 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	1545	Other Outage	Planned Outage	01-11-2025	12:49	01-11-2025	14:03	1:14	0.000226	REPLACMET OF HT BUSHING ROD
262	03-11-2025	PART OF : DURGA VIHAR DEVL I SANGAM VIHAR,POCKET B JAWAHAR PARK KHANPUR	508	Other Outage	Planned Outage	03-11-2025	11:04	03-11-2025	12:02	0:58	0.000177	3PH HT AB END TERMINATION REPLACEMENT
263	03-11-2025	PART OF : BLOCK D SANGAM VIHAR	1590	Other Outage	Planned Outage	03-11-2025	11:24	03-11-2025	12:59	1:35	0.000290	REPLACMET OF HT BUSHING ROD
264	03-11-2025	PART OF : BLOCK B DEVL I SANGAM VIHAR	622	Other Outage	Planned Outage	03-11-2025	11:07	03-11-2025	12:55	1:48	0.000900	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
265	03-11-2025	PART OF : DEOLI GAON NAI BASTI SANGAM VIHAR	1022	Other Outage	Planned Outage	03-11-2025	11:05	03-11-2025	12:55	1:50	0.000336	REPLACMET OF HT BUSHING ROD
266	04-11-2025	Part of : SURAJ CAMP,PREM NAGAR,NARADANA TUGHLAKABAD,AIRFORCE STATION,TUKLAQABAD FORT	1276	Other Outage	Unplanned Outage	04-11-2025	14:56	04-11-2025	15:29	0:33	0.000037	CABLE DAMAGE BY OUTSIDE AGENCY (DMRC)
267	04-11-2025	Part of : TIGRI EXTENSION SANGAM VIHAR	1590	Other Outage	Planned Outage	04-11-2025	11:32	04-11-2025	13:21	1:49	0.000333	REPLACEMENT OF HT BUSHING ROD
268	04-11-2025	Part of : C-BLOCK SECTOR 5 DAKSHINPURI	1179	Other Outage	Planned Outage	04-11-2025	11:00	04-11-2025	13:44	2:44	0.000501	REPLACEMENT OF HT BUSHING ROD
269	04-11-2025	Part of : L 2-BLOCK DEVL I SANGAM VIHAR	1468	Other Outage	Planned Outage	04-11-2025	09:54	04-11-2025	12:05	2:11	0.000400	3PH HT AB END TERMINATION REPLACEMENT
270	05-11-2025	Part of : TUKLAQABAD FORT,AIRFORCE STATION TUGHLAKABAD, SURAJ CAMP PREM NAGAR TUGHLAKABAD,TUGHLAKABAD EXTN.,NARADANA TUGHLAKABAD	1276	Other Outage	Unplanned Outage	05-11-2025	10:20	05-11-2025	10:49	0:29	0.000387	CABLE FAULT
271	06-11-2025	Part of : JAWAHAR PARK SANGAM VIHAR,BLOCK B TIGRI EXTENSION SANGAM VIHAR,DEOLI GAON NAI BASTI SANGAM VIHAR,TIGRI EXTENSION TIGRI SANGAM VIHAR,BLOCK A TIGRI EXTENSION SANGAM VIHAR	5988	Other Outage	Unplanned Outage	06-11-2025	00:44	06-11-2025	01:27	0:43	0.000561	FAULT IN HT CONSUMER PANEL (BSF TIGRI)
272	06-11-2025	Part of : BLOCK I 1 SANGAM VIHAR,BLOCK K SANGAM VIHAR,BLOCK G 2 SANGAM VIHAR,	3600	Other Outage	Planned Outage	06-11-2025	11:59	06-11-2025	15:04	3:05	0.000565	3PH HT AB END TERMINATION REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
273	06-11-2025	Part of : POCKET C RAJU PARK SANGAM VIHAR,DEOLI GAON NAI BASTI SANGAM VIHAR,	3568	Other Outage	Planned Outage	06-11-2025	10:52	06-11-2025	13:45	2:53	0.000529	3PH HT AB END TERMINATION REPLACEMENT
274	06-11-2025	Part of : SURAJ CAMP PREM NAGAR TUGHLAKABAD,	85	Other Outage	Planned Outage	06-11-2025	10:58	06-11-2025	13:35	2:37	0.000480	REPLACEMET OF HT BUSHING ROD
275	06-11-2025	Part of : BLOCK L 2 DEVLII SANGAM VIHAR,	3413	Other Outage	Planned Outage	06-11-2025	09:59	06-11-2025	12:10	2:11	0.000400	3PH HT AB END TERMINATION REPLACEMENT
276	07-11-2025	Part of : SURAJ CAMP PREM NAGAR TUGHLAKABAD,TUKLAQABAD FORT,MADANGIR VILLAGE MADANGIR,BLOCK E SANGAM VIHAR,DDA PARK LAL KUAN,VISHWAKARMA COLONY PULPEHLADPUR,TUGHLAKABAD,DURGA VIHAR DEVLII SANGAM VIHAR	1276	Other Outage	Unplanned Outage	07-11-2025	13:53	07-11-2025	14:11	0:18	0.000115	HT SYSTEM FAULT
277	07-11-2025	Part of : BLOCK F2, F3 & G2 SANGAM VIHAR,BLOCK C DEVLII SANGAM VIHAR,VAYUSENA VIHAR VAYUSENABAD	7900	Other Outage	Unplanned Outage	07-11-2025	17:17	07-11-2025	17:51	0:34	0.000142	HT SYSTEM FAULT
278	07-11-2025	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	1088	Other Outage	Planned Outage	07-11-2025	10:08	07-11-2025	12:02	1:54	0.000348	3PH HT AB END TERMINATION REPLACEMENT
279	07-11-2025	Part of : BLOCK A, C, F & G VISHWAKARMA COLONY PULPEHLADPUR	1855	Other Outage	Planned Outage	07-11-2025	11:01	07-11-2025	14:06	3:05	0.000565	REPLACEMET OF HT BUSHING ROD
280	08-11-2025	Part of : F 2-BLOCK SANGAM VIHAR	1450	Other Outage	Planned Outage	08-11-2025	11:42	08-11-2025	14:52	3:10	0.000581	REPLACEMENT OF HT BUSHING ROD
281	08-11-2025	Part of : KHANPUR EXTENSION,KHANPUR VILLAGE,POCKET A DUGGAL COLONY,G-BLOCK SECTOR 5 DAKSHINPURI,JAWAHAR PARK	1230	Other Outage	Planned Outage	08-11-2025	10:50	08-11-2025	13:37	2:47	0.000510	3PH HT AB END TERMINATION REPLACEMENT
282	08-11-2025	Part of : A,C & D-BLOCK VISHWAKARMA COLONY PULPEHLADPUR	1895	Other Outage	Planned Outage	08-11-2025	10:59	08-11-2025	13:58	2:59	0.000547	REPLACEMENT OF HT BUSHING ROD
283	08-11-2025	Part of : TIGRI EXTENSION,DEOLI GAON NAI BASTI,TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD	5278	Other Outage	Planned Outage	08-11-2025	10:53	08-11-2025	13:43	2:50	0.000519	REPLACEMENT OF HT BUSHING ROD
284	09-11-2025	Part of : BLOCK A & C PULPEHLADPUR,BLOCK RZ H PULPEHLADPUR,HR-BLOCK PULPEHLADPUR,BLOCK R ZTO F PULPEHLADPUR	4635	Other Outage	Unplanned Outage	09-11-2025	10:25	09-11-2025	11:20	0:55	0.001788	HT SYSTEM FAULT
285	10-11-2025	Part of : SURAJ CAMP PREM NAGAR TUGHLAKABAD,TUKLAQABAD FORT,MADANGIR VILLAGE MADANGIR,BLOCK E SANGAM VIHAR,DDA PARK LAL KUAN,BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,TUGHLAKABAD,DURGA VIHAR DEVLII SANGAM VIHAR,BLOCK 8 DAKSHINPURI	1276	Other Outage	Unplanned Outage	10-11-2025	02:44	10-11-2025	03:02	0:18	0.000095	BIRDAGE
286	10-11-2025	Part of : TALIMABAD SANGAM VIHAR,BLOCK G 2 SANGAM VIHAR,BLOCK E SANGAM VIHAR,ASOLA WILD LIFE SANCTUARY, AIRFORCE STATION TUGHLAKABAD	232	Other Outage	Unplanned Outage	10-11-2025	10:17	10-11-2025	10:49	0:32	0.000684	HT SYSTEM FAULT
287	10-11-2025	Part of : NARADANA TUGHLAKABAD	460	Other Outage	Unplanned Outage	10-11-2025	11:24	10-11-2025	11:50	0:26	0.000000	REPAIR OF RMU
288	10-11-2025	Part of : BLOCK J DEVLII SANGAM VIHAR,	123	Other Outage	Planned Outage	10-11-2025	12:03	10-11-2025	13:48	1:45	0.000321	NEW LTAB CIRCUIT LAYING
289	10-11-2025	Part of : BLOCK F 3 SANGAM VIHAR,	1335	Other Outage	Planned Outage	10-11-2025	11:06	10-11-2025	14:06	3:00	0.000550	PREVENTIVE MAINTENANCE
290	10-11-2025	Part of : DR AMBEDKAR NAGAR MADANGIR,	487	Other Outage	Planned Outage	10-11-2025	11:12	10-11-2025	14:26	3:14	0.000593	PREVENTIVE MAINTENANCE
291	10-11-2025	Part of : BLOCK L 2 DEVLII SANGAM VIHAR,	1468	Other Outage	Planned Outage	10-11-2025	10:04	10-11-2025	13:17	3:13	0.000590	MAINTENANCE
292	11-11-2025	Part of : BLOCK F 2 SANGAM VIHAR	1860	Other Outage	Planned Outage	11-11-2025	11:15	11-11-2025	14:06	2:51	0.000523	REPLACEMENT OF LT BUSHING ROD
293	11-11-2025	Part of : BLOCK A & HR PULPEHLADPUR	1101	Other Outage	Planned Outage	11-11-2025	11:03	11-11-2025	14:13	3:10	0.000581	3PH HT AB END TERMINATION REPLACEMENT
294	11-11-2025	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	2448	Other Outage	Planned Outage	11-11-2025	10:59	11-11-2025	13:57	2:58	0.000544	REPLACEMENT OF HT BUSHING ROD
295	11-11-2025	Part of : JAWAHAR PARK SANGAM VIHAR	101	Other Outage	Planned Outage	11-11-2025	10:38	11-11-2025	13:25	2:47	0.000510	3PH HT AB END TERMINATION REPLACEMENT
296	12-11-2025	Part of : BLOCK G 2,K,I 1 SANGAM VIHAR,ASOLA WILD LIFE SANCTUARY, TUGHLAKABAD	3600	Other Outage	Planned Outage	12-11-2025	10:47	12-11-2025	13:56	3:09	0.000578	3PH HT AB END TERMINATION REPLACEMENT
297	12-11-2025	Part of : DDA PARK LAL KUAN	395	Other Outage	Planned Outage	12-11-2025	11:12	12-11-2025	13:50	2:38	0.000483	REPLACEMENT OF HT BUSHING ROD
298	12-11-2025	Part of : POCKET A DUGGAL COLONY KHANPUR EXTENSION SANGAM VIHAR	1240	Other Outage	Planned Outage	12-11-2025	10:52	12-11-2025	13:34	2:42	0.000495	3PH HT AB CABLE REPLACEMENT
299	12-11-2025	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	3411	Other Outage	Planned Outage	12-11-2025	10:01	12-11-2025	12:08	2:07	0.000388	3PH HT AB END TERMINATION REPLACEMENT
300	13-11-2025	Part of : POCKET C RAJU PARK SANGAM VIHAR	290	Other Outage	Planned Outage	13-11-2025	10:56	13-11-2025	13:39	2:43	0.000498	REPLACEMET OF HT BUSHING ROD
301	13-11-2025	Part of : BLOCK C DEVLII SANGAM VIHAR	1038	Other Outage	Planned Outage	13-11-2025	11:09	13-11-2025	13:54	2:45	0.000504	REPLACEMET OF HT BUSHING ROD
302	13-11-2025	Part of : BLOCK L 2 DEVLII SANGAM VIHAR	2781	Other Outage	Planned Outage	13-11-2025	10:58	13-11-2025	14:06	3:08	0.000574	3PH HT AB CABLE REPLACEMENT PER SPAN
303	13-11-2025	Part of : BLOCK A & B PULPEHLADPUR,HR-BLOCK PULPEHLADPUR	497	Other Outage	Planned Outage	13-11-2025	11:08	13-11-2025	13:57	2:49	0.000516	REPLACEMET OF HT BUSHING ROD
304	14-11-2025	Part of : HAMDARD NAGAR	17	Other Outage	Planned Outage	14-11-2025	13:32	14-11-2025	14:25	0:53	0.000162	REPLACEMENT OF LT BUSHING ROD
305	14-11-2025	Part of : KHANPUR VILLAGE KHANPUR	222	Other Outage	Planned Outage	14-11-2025	13:24	14-11-2025	14:00	0:36	0.000110	ACB REPLACEMENT PER ACB

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
306	14-11-2025	Part of : 1 BLOCK DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI	2897	Other Outage	Planned Outage	14-11-2025	12:12	14-11-2025	14:32	2:20	0.000428	NEW LTAB CIRCUIT LAYING
307	14-11-2025	Part of : A BLOCK JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	2339	Other Outage	Planned Outage	14-11-2025	11:04	14-11-2025	14:07	3:03	0.000559	REPLACEMET OF HT BUSHING ROD
308	14-11-2025	Part of : DDA LIG FLATS PULPEHLADPUR,BLOCK C PULPEHLADPUR,HR-BLOCK PULPEHLADPUR	2225	Other Outage	Planned Outage	14-11-2025	11:01	14-11-2025	14:00	2:59	0.000547	PREVENTIVE MAINTENANCE
309	14-11-2025	Part of : DURGA VIHAR DEVL, BLOCK N SOUTH SAINIK FARM SAINIK FARM,BLOCK L 2 DEVL SANGAM VIHAR	15	Other Outage	Planned Outage	14-11-2025	11:00	14-11-2025	13:58	2:58	0.000544	HVDS TRANSFORMER MAINTENANCE
310	15-11-2025	Part of : BLOCK F JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	1447	Other Outage	Planned Outage	15-11-2025	11:36	15-11-2025	14:16	2:40	0.000489	REPLACEMENT OF LT BUSHING ROD
311	15-11-2025	Part of : BLOCK G 1 TALIMABAD SANGAM VIHAR,BLOCK H SANGAM VIHAR	1583	Other Outage	Planned Outage	15-11-2025	11:00	15-11-2025	14:03	3:03	0.000559	3PH HT AB CABLE REPLACEMENT PER SPAN
312	15-11-2025	Part of : BLOCK G VISHWAKARMA COLONY PULPEHLADPUR	230	Other Outage	Planned Outage	15-11-2025	11:06	15-11-2025	14:02	2:56	0.000538	REPLACEMENT OF LT BUSHING ROD
313	15-11-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR	3412	Other Outage	Planned Outage	15-11-2025	09:54	15-11-2025	13:12	3:18	0.000605	3PH HT AB CABLE REPLACEMENT PER SPAN
314	16-11-2025	Part of : BLOCK B SECTOR 5 DAKSHINPURI	0	Other Outage	Unplanned Outage	16-11-2025	21:26	16-11-2025	22:14	0:48	0.000080	CABLE FAULT
315	17-11-2025	Part of : M BLOCK GALI NO-9 SANGAM VIHAR	0	Other Outage	Unplanned Outage	17-11-2025	19:22	17-11-2025	19:40	0:18	0.000100	HT SYSTEM FAULT
316	17-11-2025	Part of : BLOCK D SANGAM VIHAR	1327	Other Outage	Planned Outage	17-11-2025	10:46	17-11-2025	13:51	3:05	0.000565	REPLACEMENT OF HT BUSHING ROD
317	17-11-2025	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR	446	Other Outage	Planned Outage	17-11-2025	10:51	17-11-2025	13:25	2:34	0.000471	REPLACEMENT OF GAS KIT AND OIL SEAL
318	17-11-2025	Part of : SHIV PARK DUGGAL COLONY KHANPUR,POCKET B DUGGAL COLONY KHANPUR,KHANPUR VILLAGE	2916	Other Outage	Planned Outage	17-11-2025	10:51	17-11-2025	13:29	2:38	0.000483	3PH HT AB CABLE REPLACEMENT PER SPAN
319	18-11-2025	Part of : HTC:GARRISON ENGG TKD	0	Other Outage	Unplanned Outage	18-11-2025	16:35	18-11-2025	17:03	0:28	0.000132	FAULT IN HT CONSUMER PANEL (GARRISON ENGG COLLEGE)
320	18-11-2025	Part of : BLOCK 18 DAKSHINPURI EXTENSION SECTOR 6 DAKSHINPURI,	1225	Other Outage	Planned Outage	18-11-2025	11:26	18-11-2025	13:27	2:01	0.000370	REPLACEMET OF HT BUSHING ROD
321	18-11-2025	Part of : DDA LIG FLATS PULPEHLADPUR,BLOCK C PULPEHLADPUR,HR-BLOCK PULPEHLADPUR,	2228	Other Outage	Planned Outage	18-11-2025	10:46	18-11-2025	14:08	3:22	0.000617	3PH HT AB END TERMINATION REPLACEMENT
322	18-11-2025	Part of : BLOCK F 3 SANGAM VIHAR,	659	Other Outage	Planned Outage	18-11-2025	10:57	18-11-2025	13:44	2:47	0.000510	REPLACEMENT OF LT BUSHING ROD
323	18-11-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR,	2782	Other Outage	Planned Outage	18-11-2025	10:06	18-11-2025	12:29	2:23	0.000437	3PH HT AB END TERMINATION REPLACEMENT
324	19-11-2025	Part of : BLOCK C DEVL SANGAM VIHAR	3	Other Outage	Planned Outage	19-11-2025	11:54	19-11-2025	13:38	1:44	0.000318	REPLACEMENT OF HT BUSHING ROD
325	19-11-2025	Part of : BLOCK A, C, RZ F & RZ TO F PULPEHLADPUR	2547	Other Outage	Planned Outage	19-11-2025	10:51	19-11-2025	14:10	3:19	0.000608	REPLACEMENT OF HT BUSHING ROD
326	19-11-2025	Part of : BLOCK D JJ COLONY KHANPUR	1358	Other Outage	Planned Outage	19-11-2025	11:17	19-11-2025	14:58	3:41	0.000675	DT REPLACEMENT
327	19-11-2025	Part of : KHANPUR EXTENSION SANGAM VIHAR	166	Other Outage	Planned Outage	19-11-2025	11:01	19-11-2025	13:52	2:51	0.000523	REPLACEMENT OF HT BUSHING ROD
328	19-11-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR	1468	Other Outage	Planned Outage	19-11-2025	10:11	19-11-2025	13:08	2:57	0.000541	3PH HT AB CABLE REPLACEMENT PER SPAN
329	20-11-2025	Part of : A-BLOCK PULPEHLADPUR	780	Other Outage	Planned Outage	20-11-2025	15:56	20-11-2025	17:32	1:36	0.000293	REPLACEMENT OF HT BUSHING ROD
330	20-11-2025	Part of : B-BLOCK TIGRI EXTENSION SANGAM VIHAR	1221	Other Outage	Planned Outage	20-11-2025	13:06	20-11-2025	15:47	2:41	0.000492	DT REPLACEMENT
331	20-11-2025	Part of : J-BLOCK SECTOR 5 DAKSHINPURI	2032	Other Outage	Planned Outage	20-11-2025	11:07	20-11-2025	13:31	2:24	0.000440	REPLACEMENT OF HT BUSHING ROD
332	20-11-2025	Part of : NARADANA TUGHLAKABAD	460	Other Outage	Planned Outage	20-11-2025	11:00	20-11-2025	13:59	2:59	0.000547	REPLACEMENT OF HT BUSHING ROD
333	20-11-2025	Part of : L2-BLOCK DEVL SANGAM VIHAR	3412	Other Outage	Planned Outage	20-11-2025	09:58	20-11-2025	12:21	2:23	0.000437	3PH HT AB END TERMINATION REPLACEMENT
334	21-11-2025	Part of : BLOCK D SANGAM VIHAR	219	Other Outage	Planned Outage	21-11-2025	11:40	21-11-2025	14:06	2:26	0.000446	REPLACEMENT OF LT BUSHING ROD
335	21-11-2025	Part of : BLOCK E DR AMBEDKAR NAGAR MADANGIR	1096	Other Outage	Planned Outage	21-11-2025	11:01	21-11-2025	13:57	2:56	0.000538	HT BUSHING ROD REPLACEMENT
336	21-11-2025	Part of : DDA LIG FLATS PULPEHLADPUR,BLOCK C PULPEHLADPUR	2225	Other Outage	Planned Outage	21-11-2025	11:16	21-11-2025	14:01	2:45	0.000504	REPLACEMENT OF LT BUSHING ROD
337	21-11-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR	2782	Other Outage	Planned Outage	21-11-2025	09:54	21-11-2025	12:00	2:06	0.000385	3PH HT AB END TERMINATION REPLACEMENT
338	22-11-2025	Part of : RPS COLONY MADANGIR,KHANPUR EXTENSION SANGAM VIHAR,POCKET A DUGGAL COLONY KHANPUR,KHANPUR VILLAGE KHANPUR,BLOCK G SECTOR 5 DAKSHINPURI,JAWAHAR PARK SANGAM VIHAR,	2300	Other Outage	Planned Outage	22-11-2025	11:21	22-11-2025	14:18	2:57	0.000541	REPLACEMET OF HT BUSHING ROD
339	22-11-2025	Part of : BLOCK J 2 DEVL SANGAM VIHAR,	4073	Other Outage	Planned Outage	22-11-2025	11:18	22-11-2025	14:05	2:47	0.000510	3PH HT AB END TERMINATION REPLACEMENT
340	22-11-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR,	1468	Other Outage	Planned Outage	22-11-2025	10:05	22-11-2025	12:57	2:52	0.000526	3PH HT AB CABLE REPLACEMENT PER SPAN
341	24-11-2025	Part of : BLOCK B SECTOR 5 DAKSHINPURI	0	Other Outage	Unplanned Outage	24-11-2025	23:28	25-11-2025	00:08	0:40	0.000033	CABLE FAULT BY UNKNOWN AGENCY
342	24-11-2025	Part of : D-BLOCK JJ COLONY KHANPUR	550	Other Outage	Planned Outage	24-11-2025	13:08	24-11-2025	15:30	2:22	0.000434	REPLACEMENT OF HT BUSHING ROD
343	24-11-2025	Part of : POCKET C DUGGAL COLONY & JJ COLONY DUGGAL COLONY KHANPUR	748	Other Outage	Planned Outage	24-11-2025	11:11	24-11-2025	13:57	2:46	0.000507	3PH HT AB END TERMINATION REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
344	24-11-2025	Part of : G 1-BLOCK TALIMABAD SANGAM VIHAR	2570	Other Outage	Planned Outage	24-11-2025	11:26	24-11-2025	14:09	2:43	0.000498	REPLACEMENT OF HT BUSHING ROD
345	24-11-2025	Part of : A,C & D-BLOCK VISHWAKARMA COLONY PULPEHLADPUR	1895	Other Outage	Planned Outage	24-11-2025	10:36	24-11-2025	14:10	3:34	0.000654	REPLACEMENT OF HT BUSHING ROD
346	24-11-2025	Part of : A-BLOCK JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	2338	Other Outage	Planned Outage	24-11-2025	10:46	24-11-2025	13:37	2:51	0.000523	HT CONDUCTOR REPLACEMENT
347	24-11-2025	Part of : L 2-BLOCK DEVLİ SANGAM VIHAR	3412	Other Outage	Planned Outage	24-11-2025	09:57	24-11-2025	12:22	2:25	0.000443	3PH HT AB END TERMINATION REPLACEMENT
348	25-11-2025	Part of : TUKLAQABAD FORT	9	Other Outage	Planned Outage	25-11-2025	11:52	25-11-2025	14:40	2:48	0.000513	REPLACEMENT OF HT BUSHING ROD
349	25-11-2025	Part of : BLOCK G 1 TALIMABAD SANGAM VIHAR	1578	Other Outage	Planned Outage	25-11-2025	11:09	25-11-2025	14:02	2:53	0.000529	3PH HT AB END TERMINATION REPLACEMENT
350	25-11-2025	Part of : BLOCK B SECTOR 5 DAKSHINPURI	423	Other Outage	Planned Outage	25-11-2025	10:58	25-11-2025	13:44	2:46	0.000507	REPLACEMENT OF GAS KIT AND OIL SEAL
351	25-11-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR	2789	Other Outage	Planned Outage	25-11-2025	09:46	25-11-2025	13:32	3:46	0.000691	3PH HT AB CABLE REPLACEMENT PER SPAN
352	26-11-2025	Part of : DDA TIGRI, VAYUSENABAD SHIV MANDIR, INSTITUTIONAL AREA, M B ROAD RMU NEW	0	Other Outage	Unplanned Outage	26-11-2025	14:23	26-11-2025	14:54	0:31	0.000336	CABLE DAMAGE BY OUTSIDE AGENCY (DMRC)
353	26-11-2025	Part of : TIGRI COLONY TIGRI SANGAM VIHAR,KHANPUR EXTENSION SANGAM VIHAR	4201	Other Outage	Unplanned Outage	26-11-2025	13:20	26-11-2025	13:57	0:37	0.000473	CABLE DAMAGE BY OUTSIDE AGENCY (DMRC)
354	26-11-2025	Part of : HTC:GARRISON ENG TKD	0	Other Outage	Unplanned Outage	26-11-2025	11:25	26-11-2025	11:58	0:33	0.000037	FAULT IN HT CONSUMER PANEL (GARRISON ENGG)
355	26-11-2025	Part of : DDA PARK LAL KUAN,BLOCK A VISHWAKARMA COLONY PULPEHLADPUR,LAL KUAN,CHUNGI NO 2 KOTLA MAHINGIRAN LAL KUAN,BLOCK D VISHWAKARMA COLONY PULPEHLADPUR,BLOCK C VISHWAKARMA COLONY PULPEHLADPUR	4139	Other Outage	Unplanned Outage	26-11-2025	06:49	26-11-2025	07:36	0:47	0.001188	BIRDAGE
356	26-11-2025	Part of : BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,BLOCK C VISHWAKARMA COLONY PULPEHLADPUR,BLOCK C LAL KUAN,BLOCK B VISHWAKARMA COLONY PULPEHLADPUR,BLOCK F VISHWAKARMA COLONY PULPEHLADPUR,BLOCK A VISHWAKARMA COLONY PULPEHLADPUR.	1855	Other Outage	Planned Outage	26-11-2025	10:54	26-11-2025	14:39	3:45	0.000688	REPLACEMENT OF LT BUSHING ROD
357	26-11-2025	Part of : SHIV PARK DUGGAL COLONY KHANPUR,	331	Other Outage	Planned Outage	26-11-2025	10:48	26-11-2025	13:39	2:51	0.000523	REPLACEMENT OF HT BUSHING ROD
358	26-11-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR,	3727	Other Outage	Planned Outage	26-11-2025	10:02	26-11-2025	13:46	3:44	0.000684	3PH HT AB CABLE REPLACEMENT PER SPAN
359	27-11-2025	Part of : BLOCK A, C & D VISHWAKARMA COLONY PULPEHLADPUR	1895	Other Outage	Planned Outage	27-11-2025	11:03	27-11-2025	14:04	3:01	0.000553	REPLACEMENT OF HT BUSHING ROD
360	27-11-2025	Part of : JJ COLONY DUGGAL COLONY KHANPUR	519	Other Outage	Planned Outage	27-11-2025	10:59	27-11-2025	13:49	2:50	0.000519	REPLACEMENT OF GAS KIT AND OIL SEAL
361	27-11-2025	Part of : BLOCK F SANGAM VIHAR	1161	Other Outage	Planned Outage	27-11-2025	10:39	27-11-2025	13:51	3:12	0.000587	REPLACEMENT OF HT BUSHING ROD
362	27-11-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR	1468	Other Outage	Planned Outage	27-11-2025	10:08	27-11-2025	13:20	3:12	0.000587	3PH HT AB CABLE REPLACEMENT PER SPAN
363	28-11-2025	Part of : SURAJ CAMP,PREM NAGAR,TUGHLAKABAD,NARADANA,AIRFORCE STATION,TUKLAQABAD FORT	1276	Other Outage	Unplanned Outage	28-11-2025	06:35	28-11-2025	06:59	0:24	0.000000	CABLE FAULT
364	28-11-2025	Part of : A-BLOCK JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,C & H-BLOCK SECTOR 5 DAKSHINPURI	4682	Other Outage	Unplanned Outage	28-11-2025	02:55	28-11-2025	04:11	1:16	0.000000	HT SYSTEM FAULT
365	28-11-2025	Part of : D-BLOCK JJ COLONY KHANPUR	1358	Other Outage	Planned Outage	28-11-2025	11:17	28-11-2025	14:06	2:49	0.000516	REPLACEMENT OF HT BUSHING ROD
366	28-11-2025	Part of : B-BLOCK TIGRI EXTENSION SANGAM VIHAR	1691	Other Outage	Planned Outage	28-11-2025	11:11	28-11-2025	13:41	2:30	0.000458	REPLACEMENT OF HT BUSHING ROD
367	28-11-2025	Part of : C-BLOCK PULPEHLADPUR	822	Other Outage	Planned Outage	28-11-2025	11:00	28-11-2025	13:55	2:55	0.000535	REPLACEMENT OF HT BUSHING ROD
368	29-11-2025	Part of : TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD	10	Other Outage	Planned Outage	29-11-2025	11:22	29-11-2025	13:56	2:34	0.000471	REPLACEMENT OF HT BUSHING ROD
369	29-11-2025	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR	2338	Other Outage	Planned Outage	29-11-2025	11:01	29-11-2025	13:55	2:54	0.000532	CONDUCTOR REPLACEMENT PER SPAN
370	01-11-2025	Part of : BLOCK H SHAHEEN BAGH JASOLA VIHAR	787	Other Outage	Planned Outage	01-11-2025	12:49	01-11-2025	13:46	0:57	0.000000	REPLACEMENT OF HT BUSHING ROD
371	01-11-2025	Part of : BATLA HOUSE OKHLA	690	Other Outage	Planned Outage	01-11-2025	13:15	01-11-2025	15:01	1:46	0.001031	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),SUB STATION CLEANING
372	03-11-2025	PART OF : BLOCK B JOGA BAI OKHLA	574	Other Outage	Planned Outage	03-11-2025	12:02	03-11-2025	12:56	0:54	0.000900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
373	03-11-2025	PART OF : ISWAR NAGAR NEW FRIENDS COLONY	51	Other Outage	Planned Outage	03-11-2025	10:58	03-11-2025	13:41	2:43	0.000996	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,SUB STATION CLEANING
374	03-11-2025	PART OF : BLOCK D NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	655	Other Outage	Planned Outage	03-11-2025	10:58	03-11-2025	13:43	2:45	0.001375	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
375	04-11-2025	Part of : VILLAGE JASOLA,JASOLA VIHAR	5093	Other Outage	Unplanned Outage	04-11-2025	02:50	04-11-2025	03:21	0:31	0.000327	CABLE FAULT
376	04-11-2025	Part of : BATLA HOUSE OKHLA	1712	Other Outage	Planned Outage	04-11-2025	13:01	04-11-2025	15:19	2:18	0.001533	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
377	04-11-2025	Part of : C-BLOCK SHAHEEN BAGH JASOLA VIHAR	520	Other Outage	Planned Outage	04-11-2025	10:16	04-11-2025	12:43	2:27	0.002246	REPLACEMENT OF HT BUSHING ROD
378	05-11-2025	Part of : BLOCK N PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	946	Other Outage	Planned Outage	05-11-2025	10:01	05-11-2025	12:43	2:42	0.002430	REPLACEMENT OF LT BUSHING ROD
379	06-11-2025	Part of : BLOCK C JOGA BAI EXTENSION OKHLA,	730	Other Outage	Planned Outage	06-11-2025	13:12	06-11-2025	15:25	2:13	0.001663	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
380	06-11-2025	Part of : BLOCK H SRINIVAS PURI,	1418	Other Outage	Planned Outage	06-11-2025	10:58	06-11-2025	13:39	2:41	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
381	07-11-2025	Part of : BLOCK A NEW FRIENDS COLONY WEST NEW FRIENDS COLONY,ISWAR NAGAR NEW FRIENDS COLONY	787	Other Outage	Unplanned Outage	07-11-2025	08:08	07-11-2025	08:40	0:32	0.000124	CABLE FAULT
382	07-11-2025	Part of : BATLA HOUSE OKHLA	690	Other Outage	Planned Outage	07-11-2025	13:59	07-11-2025	15:06	1:07	0.001117	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
383	07-11-2025	Part of : BLOCK B TAIMOOR NAGAR NEW FRIENDS COLONY	1037	Other Outage	Planned Outage	07-11-2025	10:58	07-11-2025	13:30	2:32	0.001689	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,REPLACEMET OF LUGS
384	08-11-2025	Part of : MUJEEB BAGH,A & C-BLOCK OKHLA VIHAR JAMIA NAGAR OKHLA	4798	Other Outage	Unplanned Outage	08-11-2025	00:38	08-11-2025	01:05	0:27	0.000323	CABLE FAULT
385	08-11-2025	Part of : C-BLOCK JOGA BAI EXTENSION OKHLA	3964	Other Outage	Unplanned Outage	08-11-2025	15:50	08-11-2025	16:26	0:36	0.000550	CABLE FAULT
386	08-11-2025	Part of : JOGA BAI OKHLA	2808	Other Outage	Planned Outage	08-11-2025	13:03	08-11-2025	15:39	2:36	0.002600	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
387	08-11-2025	Part of : BHARAT NAGAR NEW FRIENDS COLONY	402	Other Outage	Planned Outage	08-11-2025	10:58	08-11-2025	13:44	2:46	0.001383	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
388	08-11-2025	Part of : B-BLOCK ABUL FAZAL ENCLAVE PART 1 JAMIA NAGAR	2303	Other Outage	Planned Outage	08-11-2025	10:11	08-11-2025	13:16	3:05	0.002672	REPLACEMENT OF HT BUSHING ROD
389	09-11-2025	Part of : JOGA BAI EXTENSION OKHLA	3964	Other Outage	Unplanned Outage	09-11-2025	11:22	09-11-2025	11:59	0:37	0.000021	CABLE FAULT
390	10-11-2025	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR	82	Other Outage	Unplanned Outage	10-11-2025	17:20	10-11-2025	17:56	0:36	0.000340	CABLE FAULT
391	10-11-2025	Part of : A ,C & F BLOCK EAST NEW FRIENDS COLONY	263	Other Outage	Unplanned Outage	10-11-2025	12:50	10-11-2025	13:23	0:33	0.000413	CABLE FAULT
392	10-11-2025	Part of : BLOCK C JOGA BAI EXTENSION OKHLA,	729	Other Outage	Planned Outage	10-11-2025	10:58	10-11-2025	12:00	1:02	0.001033	PREVENTIVE MAINTENANCE
393	10-11-2025	Part of : JOGA BAI OKHLA,	842	Other Outage	Planned Outage	10-11-2025	13:15	10-11-2025	15:50	2:35	0.002583	PREVENTIVE MAINTENANCE
394	10-11-2025	Part of : KHIZARABAD BHAGOL VILLAGE NEW FRIENDS COLONY,NEW FRIENDS COLONY,BLOCK B NEW FRIENDS COLONY,BLOCK C NEW FRIENDS COLONY,	3243	Other Outage	Planned Outage	10-11-2025	10:58	10-11-2025	13:44	2:46	0.002306	PREVENTIVE MAINTENANCE
395	11-11-2025	Part of : BLOCK D & G PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	2019	Other Outage	Unplanned Outage	11-11-2025	14:47	11-11-2025	15:25	0:38	0.000665	CABLE FAULT
396	11-11-2025	Part of : JOGA BAI OKHLA	956	Other Outage	Planned Outage	11-11-2025	11:01	11-11-2025	12:08	1:07	0.001117	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING INSULATOR,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
397	11-11-2025	Part of : JAMIA NAGAR OKHLA	761	Other Outage	Planned Outage	11-11-2025	13:04	11-11-2025	15:23	2:19	0.000772	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
398	11-11-2025	Part of : BLOCK D NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	656	Other Outage	Planned Outage	11-11-2025	11:01	11-11-2025	13:17	2:16	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
399	12-11-2025	Part of : ISWAR NAGAR NEW FRIENDS COLONY	303	Other Outage	Unplanned Outage	12-11-2025	13:46	12-11-2025	14:30	0:44	0.000330	CABLE FAULT
400	12-11-2025	Part of : EAST NEW FRIENDS COLONY	181	Other Outage	Planned Outage	12-11-2025	11:06	12-11-2025	13:23	2:17	0.000761	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
401	13-11-2025	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR	39	Other Outage	Planned Outage	13-11-2025	11:13	13-11-2025	12:51	1:38	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
402	13-11-2025	Part of : BLOCK C SHAHEEN BAGH JASOLA VIHAR	614	Other Outage	Planned Outage	13-11-2025	14:23	13-11-2025	16:32	2:09	0.001254	REPLACEMENT OF HT BUSHING ROD
403	13-11-2025	Part of : BLOCK B JOGA BAI EXTENSION JOGA BAI OKHLA	637	Other Outage	Planned Outage	13-11-2025	13:05	13-11-2025	15:25	2:20	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
404	13-11-2025	Part of : BLOCK B SHAHEEN BAGH JASOLA VIHAR	352	Other Outage	Planned Outage	13-11-2025	10:07	13-11-2025	12:24	2:17	0.000457	INSTALLATION OF HT BOOTS,REPLACEMENT OF LT BUSHING ROD
405	14-11-2025	Part of : CANAL COLONY OKHLA	1303	Other Outage	Planned Outage	14-11-2025	14:08	14-11-2025	16:27	2:19	0.001351	REPLACEMENT OF HT BUSHING ROD
406	14-11-2025	Part of : B BLOCK TAIMOOR NAGAR NEW FRIENDS COLONY	621	Other Outage	Planned Outage	14-11-2025	10:59	14-11-2025	13:21	2:22	0.000000	PREVENTIVE MAINTENANCE
407	14-11-2025	Part of : C BLOCK NEW FRIENDS COLONY	196	Other Outage	Planned Outage	14-11-2025	10:59	14-11-2025	13:20	2:21	0.001175	REPLACEMENT OF HT/LT CLEATS
408	15-11-2025	Part of : JAMIA NAGAR OKHLA	768	Other Outage	Planned Outage	15-11-2025	11:09	15-11-2025	12:41	1:32	0.001533	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,SUB STATION CLEANING
409	15-11-2025	Part of : JAMIA MILLIA ISLAMIA OKHLA	535	Other Outage	Planned Outage	15-11-2025	12:59	15-11-2025	15:37	2:38	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
410	15-11-2025	Part of : BLOCK E SHAHEEN BAGH JASOLA VIHAR	479	Other Outage	Planned Outage	15-11-2025	10:24	15-11-2025	12:26	2:02	0.001356	REPLACEMENT OF LT BUSHING ROD
411	16-11-2025	Part of : BLOCK B JOGA BAI EXTENSION	1492	Other Outage	Planned Outage	16-11-2025	12:37	16-11-2025	14:36	1:59	0.001983	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
412	16-11-2025	Part of : HT CONSUMER UDYOG SHEEL MAHILA	1	Other Outage	Planned Outage	16-11-2025	11:29	16-11-2025	13:04	1:35	0.001372	GUARD WIRES SAGGING
413	17-11-2025	Part of : POCKET A SUKHDEV VIHAR OKHLA	447	Other Outage	Unplanned Outage	17-11-2025	10:53	17-11-2025	13:03	2:10	0.000794	RMU BYPASS
414	17-11-2025	Part of : ISWAR NAGAR NEW FRIENDS COLONY	436	Other Outage	Planned Outage	17-11-2025	11:00	17-11-2025	13:25	2:25	0.001208	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
415	18-11-2025	Part of : ISWAR NAGAR NEW FRIENDS COLONY,	159	Other Outage	Planned Outage	18-11-2025	14:01	18-11-2025	14:41	0:40	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
416	18-11-2025	Part of : BATLA HOUSE OKHLA,	285	Other Outage	Planned Outage	18-11-2025	13:06	18-11-2025	15:38	2:32	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
417	18-11-2025	Part of : BLOCK B PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA,	2303	Other Outage	Planned Outage	18-11-2025	10:18	18-11-2025	12:36	2:18	0.001917	REPLACEMENT OF LT BUSHING ROD
418	19-11-2025	Part of : BLOCK H PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	920	Other Outage	Planned Outage	19-11-2025	10:07	19-11-2025	12:28	2:21	0.001371	REPLACEMENT OF LT BUSHING ROD
419	20-11-2025	Part of : JOGA BAI OKHLA	842	Other Outage	Planned Outage	20-11-2025	11:19	20-11-2025	12:17	0:58	0.000967	APPLY OF INSULATION TAPE HT/LT BUSHINGS,SUB STATION CLEANING
420	20-11-2025	Part of : GAFOOR NAGAR OKHLA	1059	Other Outage	Planned Outage	20-11-2025	13:00	20-11-2025	15:34	2:34	0.001069	REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
421	21-11-2025	Part of : JOGA BAI OKHLA, GALI NO.-22 ZAKIR NAGAR, DETAL COLLEGE JAMIA (HTC)	3880	Other Outage	Unplanned Outage	21-11-2025	10:37	21-11-2025	11:02	0:25	0.000514	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
422	21-11-2025	Part of : BLOCK B JOGA BAI EXTENSION JOGA BAI OKHLA	637	Other Outage	Planned Outage	21-11-2025	11:09	21-11-2025	13:05	1:56	0.001933	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,SUB STATION CLEANING
423	21-11-2025	Part of : KHIZARABAD BHAGOL VILLAGE NEW FRIENDS COLONY	764	Other Outage	Planned Outage	21-11-2025	11:06	21-11-2025	13:39	2:33	0.000850	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
424	22-11-2025	Part of : JAMIA NAGAR OKHLA,	562	Other Outage	Planned Outage	22-11-2025	13:05	22-11-2025	15:22	2:17	0.000571	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
425	22-11-2025	Part of : BLOCK A NEW FRIENDS COLONY WEST NEW FRIENDS COLONY,	1	Other Outage	Planned Outage	22-11-2025	10:58	22-11-2025	13:35	2:37	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD
426	22-11-2025	Part of : POCKET 12 JASOLA VIHAR,	188	Other Outage	Planned Outage	22-11-2025	10:21	22-11-2025	12:29	2:08	0.000711	REPLACEMET OF HT BUSHING ROD
427	24-11-2025	Part of : BATLA HOUSE OKHLA	1718	Other Outage	Planned Outage	24-11-2025	13:12	24-11-2025	16:00	2:48	0.002800	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
428	25-11-2025	Part of : GAFOOR NAGAR OKHLA	766	Other Outage	Planned Outage	25-11-2025	13:01	25-11-2025	15:43	2:42	0.000450	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,TIGHTENEING OF NUT BOLT
429	26-11-2025	Part of : NEW FRIENDS COLONY,	382	Other Outage	Planned Outage	26-11-2025	11:14	26-11-2025	14:06	2:52	0.000956	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
430	26-11-2025	Part of : BLOCK G SHAHEEN BAGH JASOLA VIHAR,	484	Other Outage	Planned Outage	26-11-2025	10:08	26-11-2025	12:38	2:30	0.001458	REPLACEMET OF HT BUSHING ROD
431	27-11-2025	Part of : BLOCK C OKHLA VIHAR JAMIA NAGAR OKHLA	1332	Other Outage	Planned Outage	27-11-2025	13:22	27-11-2025	15:44	2:22	0.002367	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
432	27-11-2025	Part of : GAFOOR NAGAR OKHLA	1067	Other Outage	Planned Outage	27-11-2025	11:22	27-11-2025	13:38	2:16	0.002267	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
433	27-11-2025	Part of : BLOCK A NEW FRIENDS COLONY EAST NEW FRIENDS COLONY	116	Other Outage	Planned Outage	27-11-2025	11:23	27-11-2025	13:25	2:02	0.000000	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD
434	27-11-2025	Part of : BLOCK F SHAHEEN BAGH JASOLA VIHAR	1208	Other Outage	Planned Outage	27-11-2025	10:18	27-11-2025	12:59	2:41	0.002326	REPLACEMENT OF LT BUSHING ROD
435	28-11-2025	Part of : BHARAT NAGAR,B-BLOCK MAHARANI BAGH,C & D-BLOCK NEW FRIENDS COLONY EAST	1325	Other Outage	Unplanned Outage	28-11-2025	16:46	28-11-2025	17:14	0:28	0.000272	CABLE FAULT
436	28-11-2025	Part of : B-BLOCK NEW FRIENDS COLONY	1277	Other Outage	Planned Outage	28-11-2025	11:02	28-11-2025	13:41	2:39	0.001767	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
437	29-11-2025	Part of : ZAKIR NAGAR JOGA BAI OKHLA	467	Other Outage	Planned Outage	29-11-2025	12:58	29-11-2025	16:06	3:08	0.000522	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
438	29-11-2025	Part of : BLOCK C KALINDI COLONY NEW FRIENDS COLONY	191	Other Outage	Planned Outage	29-11-2025	11:10	29-11-2025	14:25	3:15	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD
439	29-11-2025	Part of : BLOCK G PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA	745	Other Outage	Planned Outage	29-11-2025	10:11	29-11-2025	12:19	2:08	0.001849	REPLACEMENT OF LT BUSHING ROD
440	30-11-2025	Part of : BLOCK E SHAHEEN BAGH JASOLA VIHAR,BLOCK N PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA,BLOCK A SHAHEEN BAGH JASOLA VIHAR	5973	Other Outage	Unplanned Outage	30-11-2025	04:34	30-11-2025	05:12	0:38	0.000306	HT SYSTEM FAULT
441	01-11-2025	Part of : BLOCK N GREATER KAILASH I	121	Other Outage	Planned Outage	01-11-2025	13:13	01-11-2025	14:31	1:18	0.001127	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
442	02-11-2025	Part of : POCKET A SANJAY COLONY II OKHLA PHASE II OKHLA INDUSTRIAL AREA,	150	Other Outage	Planned Outage	02-11-2025	11:01	02-11-2025	14:03	3:02	0.001769	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
443	03-11-2025	Part of : MOUNT KAILASH APARTMENT EAST OF KAILASH	116	Other Outage	Unplanned Outage	03-11-2025	14:49	03-11-2025	15:16	0:27	0.000390	REPAIRING OF RMU
444	03-11-2025	PART OF : MOUNT KAILASH APARTMENT EAST OF KAILASH	84	Other Outage	Planned Outage	03-11-2025	10:14	03-11-2025	10:57	0:43	0.000621	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING
445	03-11-2025	PART OF : SIRI FORT	151	Other Outage	Planned Outage	03-11-2025	11:07	03-11-2025	13:55	2:48	0.002427	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
446	04-11-2025	Part of : C-BLOCK GREATER KAILASH ENCLAVE 1	253	Other Outage	Planned Outage	04-11-2025	11:54	04-11-2025	13:46	1:52	0.001618	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
447	05-11-2025	Part of : POCKET E OKHLA PHASE II OKHLA INDUSTRIAL AREA	1	Other Outage	Unplanned Outage	05-11-2025	15:25	05-11-2025	16:10	0:45	0.001000	CABLE FAULT
448	05-11-2025	Part of : POCKET B OKHLA PHASE II OKHLA INDUSTRIAL AREA	32	Other Outage	Unplanned Outage	05-11-2025	11:17	05-11-2025	13:16	1:59	0.001322	REPLACEMENT OF DAMAGE POLE
449	06-11-2025	Part of : HEMKUNT COLONY GREATER KAILASH,	121	Other Outage	Planned Outage	06-11-2025	11:15	06-11-2025	13:44	2:29	0.002152	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
450	06-11-2025	Part of : MOUNT KAILASH APARTMENT EAST OF KAILASH,	50	Other Outage	Planned Outage	06-11-2025	10:01	06-11-2025	12:53	2:52	0.002484	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING
451	07-11-2025	Part of : HARKESH NAGAR OKHLA INDUSTRIAL AREA	470	Other Outage	Unplanned Outage	07-11-2025	12:11	07-11-2025	12:58	0:47	0.000718	CABLE FAULT
452	07-11-2025	Part of : MASJID MOTH GREATER KAILASH	243	Other Outage	Planned Outage	07-11-2025	11:23	07-11-2025	14:03	2:40	0.002311	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
453	07-11-2025	Part of : SHERA MOHALLA GARHI EAST OF KAILASH	910	Other Outage	Planned Outage	07-11-2025	09:58	07-11-2025	12:53	2:55	0.002528	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING
454	09-11-2025	Part of : POCKET D OKHLA PHASE II OKHLA INDUSTRIAL AREA	328	Other Outage	Planned Outage	09-11-2025	11:01	09-11-2025	13:55	2:54	0.001933	REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS
455	10-11-2025	Part of : POCKET D OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA	722	Other Outage	Unplanned Outage	10-11-2025	00:11	10-11-2025	01:12	1:01	0.000254	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
456	10-11-2025	Part of : BLOCK C DAYANAND COLONY LAJPAT NAGAR,	609	Other Outage	Planned Outage	10-11-2025	10:04	10-11-2025	11:15	1:11	0.001026	PREVENTIVE MAINTENANCE
457	11-11-2025	Part of : SIRI FORT	233	Other Outage	Planned Outage	11-11-2025	11:25	11-11-2025	14:15	2:50	0.002456	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
458	11-11-2025	Part of : BLOCK C APB GARHI EAST OF KAILASH	290	Other Outage	Planned Outage	11-11-2025	10:01	11-11-2025	13:22	3:21	0.002903	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR
459	12-11-2025	Part of : NATIONAL PARK LAJPAT NAGAR	379	Other Outage	Planned Outage	12-11-2025	10:10	12-11-2025	12:00	1:50	0.001589	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR
460	13-11-2025	Part of : BLOCK E GREATER KAILASH I	233	Other Outage	Planned Outage	13-11-2025	10:58	13-11-2025	13:55	2:57	0.002557	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
461	13-11-2025	Part of : NATIONAL PARK LAJPAT NAGAR	255	Other Outage	Planned Outage	13-11-2025	09:59	13-11-2025	13:03	3:04	0.002658	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
462	14-11-2025	Part of : B BLOCK AMAR COLONY LAJPAT NAGAR	436	Other Outage	Planned Outage	14-11-2025	10:00	14-11-2025	12:49	2:49	0.002441	PREVENTIVE MAINTENANCE
463	15-11-2025	Part of : POCKET B, X & Z OKHLA PHASE II OKHLA INDUSTRIAL AREA	560	Other Outage	Unplanned Outage	15-11-2025	21:28	15-11-2025	22:06	0:38	0.000338	TREE TOUCHING
464	15-11-2025	Part of : MOUNT KAILASH APARTMENT EAST OF KAILASH,NATIONAL PARK LAJPAT NAGAR,BLOCK B & C AMAR COLONY LAJPAT NAGAR	2367	Other Outage	Unplanned Outage	15-11-2025	11:15	15-11-2025	13:03	1:48	0.001500	RMU GAS REFILLING
465	15-11-2025	Part of : BLOCK E GREATER KAILASH I	168	Other Outage	Planned Outage	15-11-2025	11:11	15-11-2025	13:55	2:44	0.002369	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
466	16-11-2025	Part of : HEMKUNT COLONY GREATER KAILASH	152	Other Outage	Planned Outage	16-11-2025	10:58	16-11-2025	13:28	2:30	0.002167	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,
467	16-11-2025	Part of : BLOCK A OKHLA PHASE II OKHLA INDUSTRIAL AREA	141	Other Outage	Planned Outage	16-11-2025	10:55	16-11-2025	14:38	3:43	0.001239	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
468	17-11-2025	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA,OKHLA SABZEE MUNDI OKHLA INDUSTRIAL AREA	827	Other Outage	Unplanned Outage	17-11-2025	16:35	17-11-2025	17:20	0:45	0.000888	BIRDAGE
469	17-11-2025	Part of : BLOCK C KAILASH HILL EAST OF KAILASH	287	Other Outage	Planned Outage	17-11-2025	10:38	17-11-2025	11:06	0:28	0.000404	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
470	17-11-2025	Part of : BLOCK R GREATER KAILASH I	156	Other Outage	Planned Outage	17-11-2025	11:10	17-11-2025	14:20	3:10	0.002744	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
471	18-11-2025	Part of : POCKET D OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET B OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET E OKHLA PHASE II OKHLA INDUSTRIAL AREA	375	Other Outage	Unplanned Outage	18-11-2025	07:38	18-11-2025	08:30	0:52	0.000144	HT SYSTEM FAULT
472	18-11-2025	Part of : BLOCK E GREATER KAILASH I GREATER KAILASH,	154	Other Outage	Planned Outage	18-11-2025	12:07	18-11-2025	13:55	1:48	0.001560	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
473	19-11-2025	Part of : POCKET E & Z OKHLA PHASE II OKHLA INDUSTRIAL AREA	289	Other Outage	Unplanned Outage	19-11-2025	12:53	19-11-2025	13:48	0:55	0.001008	HT SYSTEM FAULT
474	19-11-2025	Part of : BLOCK M GREATER KAILASH I	148	Other Outage	Planned Outage	19-11-2025	11:23	19-11-2025	14:39	3:16	0.002831	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
475	20-11-2025	Part of : VIKRAM VIHAR LAJPAT NAGAR IV,NATIONAL PARK LAJPAT NAGAR	532	Other Outage	Unplanned Outage	20-11-2025	17:41	20-11-2025	18:28	0:47	0.000509	CABLE FAULT
476	20-11-2025	Part of : B-BLOCK EAST OF KAILASH	481	Other Outage	Unplanned Outage	20-11-2025	14:24	20-11-2025	15:26	1:02	0.000896	GAS REFILLING & REPAIRING OF RMU
477	20-11-2025	Part of : E-BLOCK GREATER KAILASH ENCLAVE 1	159	Other Outage	Planned Outage	20-11-2025	11:35	20-11-2025	13:37	2:02	0.001762	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
478	21-11-2025	Part of : BLOCK A KAILASH COLONY GREATER KAILASH	99	Other Outage	Planned Outage	21-11-2025	11:27	21-11-2025	14:31	3:04	0.002658	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
479	22-11-2025	Part of : BLOCK N GREATER KAILASH I GREATER KAILASH,	76	Other Outage	Planned Outage	22-11-2025	11:31	22-11-2025	13:57	2:26	0.002109	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
480	23-11-2025	Part of : BLOCK A OKHLA PHASE II OKHLA INDUSTRIAL AREA	386	Other Outage	Planned Outage	23-11-2025	11:03	23-11-2025	13:46	2:43	0.001358	1C 300 SQ MM CABLE REPLACEMENT PER PHASE
481	24-11-2025	Part of : C-BLOCK KAILASH HILL EAST OF KAILASH	287	Other Outage	Unplanned Outage	24-11-2025	10:53	24-11-2025	12:46	1:53	0.001632	GAS REFILLING/ REPAIRING OF RMU

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
482	24-11-2025	Part of : MASJID MOTH PHASE 2	200	Other Outage	Planned Outage	24-11-2025	11:08	24-11-2025	13:43	2:35	0.002239	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
483	24-11-2025	Part of : NATIONAL PARK LAJPAT NAGAR	7	Other Outage	Planned Outage	24-11-2025	10:01	24-11-2025	12:20	2:19	0.002008	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR
484	25-11-2025	Part of : BLOCK N GREATER KAILASH I	92	Other Outage	Planned Outage	25-11-2025	11:42	25-11-2025	13:05	1:23	0.001199	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
485	26-11-2025	Part of : BLOCK A KAILASH COLONY GREATER KAILASH,	88	Other Outage	Planned Outage	26-11-2025	11:01	26-11-2025	14:41	3:40	0.003178	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
486	26-11-2025	Part of : BLOCK F EAST OF KAILASH,	204	Other Outage	Planned Outage	26-11-2025	09:59	26-11-2025	12:47	2:48	0.002427	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
487	27-11-2025	Part of : BLOCK E GREATER KAILASH I GREATER KAILASH	449	Other Outage	Planned Outage	27-11-2025	11:08	27-11-2025	14:02	2:54	0.002513	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
488	27-11-2025	Part of : BLOCK B DAYANAND COLONY LAJPAT NAGAR	449	Other Outage	Planned Outage	27-11-2025	10:00	27-11-2025	12:47	2:47	0.002412	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
489	28-11-2025	Part of : R-BLOCK GREATER KAILASH-1	158	Other Outage	Planned Outage	28-11-2025	11:01	28-11-2025	13:50	2:49	0.002441	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
490	28-11-2025	Part of : B-BLOCK DAYANAND COLONY LAJPAT NAGAR	450	Other Outage	Planned Outage	28-11-2025	09:59	28-11-2025	12:46	2:47	0.002412	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INULATOR
491	29-11-2025	Part of : NEHRU PLACE	163	Other Outage	Unplanned Outage	29-11-2025	10:32	29-11-2025	10:54	0:22	0.000306	RMU HT BUSHING REPLACEMENT
492	29-11-2025	Part of : BUILDING NO.-20,37 & 43 NEHRU PLACE	123	Other Outage	Unplanned Outage	29-11-2025	10:48	29-11-2025	13:41	2:53	0.000000	RMU HT BUSHING REPLACEMENT
493	29-11-2025	Part of : NEHRU PLACE	163	Other Outage	Unplanned Outage	29-11-2025	10:47	29-11-2025	13:40	2:53	0.000000	RMU HT BUSHING REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
494	29-11-2025	Part of : BLOCK R GREATER KAILASH I	248	Other Outage	Planned Outage	29-11-2025	11:14	29-11-2025	13:03	1:49	0.001574	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
495	30-11-2025	Part of : POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA,	39	Other Outage	Planned Outage	30-11-2025	10:30	30-11-2025	14:17	3:47	0.000631	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
496	03-11-2025	PART OF : BLOCK D LAJPAT NAGAR I LAJPAT NAGAR	1065	Other Outage	Planned Outage	03-11-2025	11:56	03-11-2025	15:51	3:55	0.001763	REPLACEMET OF HT BUSHING ROD
497	04-11-2025	Part of : FEROUZ GANDHI ROAD LAJPAT NAGAR-3	400	Other Outage	Planned Outage	04-11-2025	12:12	04-11-2025	16:21	4:09	0.002767	REPLACEMENT OF HT BUSHING ROD
498	04-11-2025	Part of : THAPAR CHAMBER	962	Other Outage	Planned Outage	04-11-2025	11:19	04-11-2025	16:11	4:52	0.001622	REPLACEMENT OF HT BUSHING ROD
499	04-11-2025	Part of : B-6-BLOCK JANGPURA	303	Other Outage	Planned Outage	04-11-2025	11:25	04-11-2025	15:06	3:41	0.001842	REPLACEMENT OF HT BUSHING ROD
500	04-11-2025	Part of : A-BLOCK DEFENCE COLONY	258	Other Outage	Planned Outage	04-11-2025	11:21	04-11-2025	16:08	4:47	0.001594	REPLACEMENT OF HT BUSHING ROD
501	06-11-2025	Part of : RISHI NAGAR SOUTH EXTENSION PART 1,	647	Other Outage	Planned Outage	06-11-2025	15:06	06-11-2025	17:54	2:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
502	06-11-2025	Part of : NEHRU NAGAR LAJPAT NAGAR,	699	Other Outage	Planned Outage	06-11-2025	11:40	06-11-2025	15:43	4:03	0.000608	REPLACEMENT OF HT BUSHING ROD
503	07-11-2025	Part of : BLOCK C DEFENCE COLONY	200	Other Outage	Planned Outage	07-11-2025	11:58	07-11-2025	14:43	2:45	0.000550	REPLACEMENT OF HT BUSHING ROD
504	07-11-2025	Part of : JANGPURA INDUTRIAL AREA JANGPURA	576	Other Outage	Planned Outage	07-11-2025	12:08	07-11-2025	15:28	3:20	0.001167	REPLACEMENT OF HT BUSHING ROD
505	08-11-2025	Part of : A-BLOCK NIZAMUDDIN WEST	957	Other Outage	Planned Outage	08-11-2025	11:03	08-11-2025	14:11	3:08	0.001253	REPLACEMENT OF HT BUSHING ROD
506	08-11-2025	Part of : C-BLOCK DEFENCE COLONY	216	Other Outage	Planned Outage	08-11-2025	11:04	08-11-2025	14:12	3:08	0.000627	REPLACEMENT OF HT BUSHING ROD
507	09-11-2025	Part of : SEWAGE TREATMENT PLANT (HTC), N.I.A HEAD QUATER LODHI ROAD (HTC)	0	Other Outage	Unplanned Outage	09-11-2025	17:37	09-11-2025	18:18	0:41	0.000000	FAULT IN HT CONSUMER PANEL (NIA)
508	10-11-2025	Part of : BASTI NIZAMUDDIN (DHOBIWALA)	0	Other Outage	Unplanned Outage	10-11-2025	14:24	10-11-2025	15:12	0:48	0.000667	CABLE FAULT
509	10-11-2025	Part of : BLOCK C DEFENCE COLONY,	268	Other Outage	Planned Outage	10-11-2025	10:58	10-11-2025	15:22	4:24	0.001467	PREVENTIVE MAINTENANCE
510	10-11-2025	Part of : BLOCK B SARAI KALE KHAN,	1006	Other Outage	Planned Outage	10-11-2025	11:08	10-11-2025	15:53	4:45	0.005542	LT ACB REPLACEMENT
511	10-11-2025	Part of : BLOCK L LAJPAT NAGAR II LAJPAT NAGAR,	304	Other Outage	Planned Outage	10-11-2025	11:10	10-11-2025	16:02	4:52	0.002433	PREVENTIVE MAINTENANCE
512	11-11-2025	Part of : KILOKARI PHASE 1 SUNLIGHT COLONY	122	Other Outage	Planned Outage	11-11-2025	11:09	11-11-2025	14:55	3:46	0.000000	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
513	11-11-2025	Part of : DEFENCE COLONY	224	Other Outage	Planned Outage	11-11-2025	11:11	11-11-2025	14:53	3:42	0.001850	REPLACEMENT OF HT BUSHING ROD
514	11-11-2025	Part of : BLOCK H & L LAJPAT NAGAR II	782	Other Outage	Planned Outage	11-11-2025	11:05	11-11-2025	16:01	4:56	0.002467	3PH HT AB CABLE REPLACEMENT PER SPAN
515	12-11-2025	Part of : BHOGAL JANGPURA	1025	Other Outage	Planned Outage	12-11-2025	11:25	12-11-2025	15:44	4:19	0.001079	REPLACEMENT OF HT BUSHING ROD
516	13-11-2025	Part of : BLOCK A DEFENCE COLONY	152	Other Outage	Planned Outage	13-11-2025	11:33	13-11-2025	14:54	3:21	0.000670	REPLACEMENT OF HT BUSHING ROD
517	13-11-2025	Part of : BLOCK VINOBA PURI LAJPAT NAGAR II	376	Other Outage	Planned Outage	13-11-2025	11:57	13-11-2025	15:18	3:21	0.000558	REPLACEMENT OF HT BUSHING ROD
518	14-11-2025	Part of : NEHRU NAGAR LAJPAT NAGAR	202	Other Outage	Planned Outage	14-11-2025	14:27	14-11-2025	16:54	2:27	0.000613	REPLACEMENT OF HT BUSHING ROD
519	14-11-2025	Part of : PRAGATI VIHAR	265	Other Outage	Planned Outage	14-11-2025	12:09	14-11-2025	15:20	3:11	0.000796	PREVENTIVE MAINTENANCE
520	14-11-2025	Part of : JANGUPURA EXTENSION	1174	Other Outage	Planned Outage	14-11-2025	11:03	14-11-2025	14:30	3:27	0.000863	REPLACEMENT OF HT BUSHING ROD
521	15-11-2025	Part of : PANT NAGAR JANGPURA,BLOCK K JANGUPURA EXTENSION JANGPURA,CGO COMPLEX PRAGATI VIHAR,NIZAMUDDIN WEST	1694	Other Outage	Unplanned Outage	15-11-2025	15:07	15-11-2025	15:58	0:51	0.000893	HT SYSTEM FAULT
522	15-11-2025	Part of : RISHI NAGAR SOUTH EXTENSION PART 1	1657	Other Outage	Planned Outage	15-11-2025	15:29	15-11-2025	17:17	1:48	0.001260	GUARD WIRES SAGGING PER SPAN,HT SLEEVE INSTALLATION PER SPAN,TIGHTENING OF HARDWARE FITTINGS
523	15-11-2025	Part of : PRAGATI VIHAR	755	Other Outage	Planned Outage	15-11-2025	11:05	15-11-2025	14:32	3:27	0.002300	REPLACEMENT OF HT BUSHING ROD
524	15-11-2025	Part of : BLOCK B GANGA VIHAR SARAI KALE KHAN	23	Other Outage	Planned Outage	15-11-2025	10:55	15-11-2025	14:01	3:06	0.000258	REPLACEMENT OF HT BUSHING ROD
525	15-11-2025	Part of : BLOCK C DEFENCE COLONY	725	Other Outage	Planned Outage	15-11-2025	10:54	15-11-2025	14:38	3:44	0.001556	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
526	16-11-2025	Part of : RISHI NAGAR SOUTH EXTENSION PART 1,PREM NAGAR BK DUTT COLONY	2119	Other Outage	Unplanned Outage	16-11-2025	12:20	16-11-2025	13:05	0:45	0.000025	REPAIRING OF RMU
527	17-11-2025	Part of : SUNDAR NAGAR	58	Other Outage	Planned Outage	17-11-2025	11:49	17-11-2025	15:09	3:20	0.000000	SF6 GAS FILLING
528	17-11-2025	Part of : BLOCK C DEFENCE COLONY	273	Other Outage	Planned Outage	17-11-2025	11:51	17-11-2025	15:10	3:19	0.001935	REPLACEMENT OF HT BUSHING ROD
529	17-11-2025	Part of : BLOCK I LAJPAT NAGAR III	270	Other Outage	Planned Outage	17-11-2025	11:13	17-11-2025	16:06	4:53	0.001139	REPLACEMENT OF HT BUSHING ROD
530	18-11-2025	Part of : BHOGAL JANGPURA,	777	Other Outage	Planned Outage	18-11-2025	12:53	18-11-2025	15:58	3:05	0.000000	DT REPLACEMENT
531	18-11-2025	Part of : BLOCK C LAJPAT NAGAR I LAJPAT NAGAR,	362	Other Outage	Planned Outage	18-11-2025	12:01	18-11-2025	16:05	4:04	0.000813	DT REPLACEMENT
532	18-11-2025	Part of : BLOCK C DEFENCE COLONY,	164	Other Outage	Planned Outage	18-11-2025	11:11	18-11-2025	13:48	2:37	0.000611	DT REPLACEMENT
533	18-11-2025	Part of : KILOKARI PHASE 1 SUNLIGHT COLONY,PHASE 2 SUNLIGHT COLONY,	1688	Other Outage	Planned Outage	18-11-2025	11:08	18-11-2025	16:00	4:52	0.003244	REPLACEMET OF HT BUSHING ROD
534	18-11-2025	Part of : BLOCK B SARAI KALE KHAN,	1013	Other Outage	Planned Outage	18-11-2025	12:01	18-11-2025	15:56	3:55	0.002154	CONDUCTOR REPLACEMET PER SPAN
535	19-11-2025	Part of : BLOCK E LAJPAT NAGAR III LAJPAT NAGAR	643	Other Outage	Planned Outage	19-11-2025	12:31	19-11-2025	15:45	3:14	0.001617	REPLACEMENT OF HT BUSHING ROD
536	20-11-2025	Part of : SHIV NAGAR & WAZIR NAGAR KOTLA MUBARAKPUR SOUTH EXTENSION PART-1	3128	Other Outage	Unplanned Outage	20-11-2025	19:10	20-11-2025	19:32	0:22	0.000000	CABLE FAULT
537	20-11-2025	Part of : H & L-BLOCK LAJPAT NAGAR-2	782	Other Outage	Planned Outage	20-11-2025	12:15	20-11-2025	16:18	4:03	0.000810	HT BUSHING REPLACEMENT
538	20-11-2025	Part of : KILOKARI PHASE 1,SUNLIGHT COLONY	1000	Other Outage	Planned Outage	20-11-2025	11:07	20-11-2025	15:33	4:26	0.000739	REPLACEMENT OF HT BUSHING ROD
539	20-11-2025	Part of : LODI COLONY INSTITUTIONAL AREA	3	Other Outage	Planned Outage	20-11-2025	11:28	20-11-2025	13:41	2:13	0.000369	REPLACEMENT OF HT BUSHING ROD
540	21-11-2025	Part of : SEWA NAGAR, KASTURBA NAGAR SEWA NAGAR, SUBASH MARKET KOTLA MUBARAKPUR, ALIGANJ KOTLA MUBARAKPUR	3011	Other Outage	Unplanned Outage	21-11-2025	16:02	21-11-2025	16:47	0:45	0.000813	CABLE FAULT
541	21-11-2025	Part of : JANGUPURA EXTENSION	935	Other Outage	Planned Outage	21-11-2025	11:43	21-11-2025	14:36	2:53	0.001057	REPLACEMET OF HT BUSHING ROD
542	22-11-2025	Part of : CGO COMPLEX PRAGATI VIHAR,	8	Other Outage	Planned Outage	22-11-2025	13:40	22-11-2025	14:48	1:08	0.000340	REPLACEMET OF HT BUSHING ROD
543	24-11-2025	Part of : H & L-BLOCK LAJPAT NAGAR-2	824	Other Outage	Unplanned Outage	24-11-2025	14:04	24-11-2025	14:51	0:47	0.000000	BIRDAGE
544	24-11-2025	Part of : WAZIR NAGAR SOUTH EXTENSION PART-1	2257	Other Outage	Planned Outage	24-11-2025	12:25	24-11-2025	16:11	3:46	0.002888	REPLACEMENT OF HT BUSHING ROD
545	24-11-2025	Part of : E-BLOCK LAJPAT NAGAR-2	313	Other Outage	Planned Outage	24-11-2025	11:08	24-11-2025	16:09	5:01	0.003010	REPLACEMENT OF HT BUSHING ROD
546	24-11-2025	Part of : D-BLOCK SARAI KALE KHAN VILLAGE	645	Other Outage	Planned Outage	24-11-2025	11:07	24-11-2025	15:16	4:09	0.000830	REPLACEMENT OF HT BUSHING ROD
547	25-11-2025	Part of : BLOCK VINOBA PURI LAJPAT NAGAR II	376	Other Outage	Planned Outage	25-11-2025	10:59	25-11-2025	13:59	3:00	0.001000	REPLACEMENT OF LT BUSHING ROD
548	26-11-2025	Part of : RISHI NAGAR SOUTH EXTENSION PART 1,PREM NAGAR BK DUTT COLONY,	2123	Other Outage	Unplanned Outage	26-11-2025	12:14	26-11-2025	14:11	1:57	0.000975	REPAIRING OF RMU
549	26-11-2025	Part of : LODHI ROAD QUARTERS LODI COLONY,	308	Other Outage	Planned Outage	26-11-2025	10:50	26-11-2025	14:54	4:04	0.001356	REPLACEMET OF HT BUSHING ROD
550	26-11-2025	Part of : BLOCK D LAJPAT NAGAR I LAJPAT NAGAR,	355	Other Outage	Planned Outage	26-11-2025	11:06	26-11-2025	14:56	3:50	0.000958	REPLACEMET OF HT BUSHING ROD
551	30-11-2025	Part of : ISBT SARAI KALE KHAN SARAI KALE KHAN,	3	Other Outage	Planned Outage	30-11-2025	11:14	30-11-2025	14:37	3:23	0.001128	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
552	01-11-2025	Part of : SATYA NIKETAN MOTI BAGH SOUTH	75	Other Outage	Planned Outage	01-11-2025	12:49	01-11-2025	13:15	0:26	0.000108	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
553	01-11-2025	Part of : MUNIRKA	1792	Other Outage	Planned Outage	01-11-2025	12:49	01-11-2025	14:31	1:42	0.001842	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS,TIGHTENEING OF NUT BOLT
554	03-11-2025	PART OF : BLOCK A WEST END,	62	Other Outage	Planned Outage	03-11-2025	10:08	03-11-2025	12:52	2:44	0.000592	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING
555	04-11-2025	Part of : SECTOR 5 & 6 RAMAKRISHNA PURAM,RBI COLONY,SONIA GANDHI CAMP	1849	Other Outage	Unplanned Outage	04-11-2025	10:44	04-11-2025	11:19	0:35	0.000243	CABLE FAULT
556	04-11-2025	Part of : SECTOR 1,4 & 5 RAMAKRISHNA PURAM,EAST BLOCK ADARSH BASTI RAMAKRISHNA PURAM	988	Other Outage	Unplanned Outage	04-11-2025	19:47	04-11-2025	20:57	1:10	0.001536	CABLE FAULT
557	04-11-2025	Part of : SECTOR 2 RAMAKRISHNA PURAM	504	Other Outage	Unplanned Outage	04-11-2025	14:00	04-11-2025	16:05	2:05	0.000035	REPAIRING OF RMU
558	04-11-2025	Part of : TRIKOOT NO.-1 & 2, B.C.PLACE	1	Other Outage	Planned Outage	04-11-2025	16:04	04-11-2025	17:01	0:57	0.000238	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
559	04-11-2025	Part of : H-BLOCK NANAKPURA MOTI BAGH SOUTH	1083	Other Outage	Planned Outage	04-11-2025	14:45	04-11-2025	17:37	2:52	0.001051	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
560	04-11-2025	Part of : D-BLOCK VASANT VIHAR	161	Other Outage	Planned Outage	04-11-2025	10:16	04-11-2025	14:17	4:01	0.002008	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
561	05-11-2025	Part of : BUILDING NO.-7 PNB B.C.PLACE (HTC)	1	Other Outage	Planned Outage	05-11-2025	14:38	05-11-2025	16:17	1:39	0.000193	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
562	05-11-2025	Part of : MOHAMMADPUR RAMAKRISHNA PURAM	17	Other Outage	Planned Outage	05-11-2025	10:59	05-11-2025	13:17	2:18	0.001150	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
563	06-11-2025	Part of : SECTOR 2 RAMAKRISHNA PURAM,	502	Other Outage	Unplanned Outage	06-11-2025	14:08	06-11-2025	14:49	0:41	0.000000	STATION CLEANING REPAIR OF RMU
564	06-11-2025	Part of : BLOCK BA MUNIRKA,	265	Other Outage	Planned Outage	06-11-2025	11:37	06-11-2025	13:12	1:35	0.001583	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
565	06-11-2025	Part of : RESIDNT QRTRS,LOK SABHA SECTT,SEC-2,RKP,	172	Other Outage	Planned Outage	06-11-2025	11:04	06-11-2025	14:47	3:43	0.001239	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
566	06-11-2025	Part of : BLOCK B ANAND NIKETAN,	247	Other Outage	Planned Outage	06-11-2025	10:07	06-11-2025	13:37	3:30	0.000875	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
567	06-11-2025	Part of : MUNIRKA,	1087	Other Outage	Planned Outage	06-11-2025	10:14	06-11-2025	14:11	3:57	0.002304	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS
568	07-11-2025	Part of : SECTOR 1 RAMAKRISHNA PURAM	1359	Other Outage	Unplanned Outage	07-11-2025	12:14	07-11-2025	12:58	0:44	0.000244	REPAIRING OF RMU
569	07-11-2025	Part of : SECTOR 1 R.K PURAM	1360	Other Outage	Planned Outage	07-11-2025	11:13	07-11-2025	14:18	3:05	0.002056	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
570	07-11-2025	Part of : BLOCK E VASANT VIHAR	265	Other Outage	Planned Outage	07-11-2025	10:17	07-11-2025	14:11	3:54	0.004550	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
571	08-11-2025	Part of : WEST BLOCK & SECTOR 5 RAMAKRISHNA PURAM	362	Other Outage	Unplanned Outage	08-11-2025	11:55	08-11-2025	12:45	0:50	0.000125	CABLE FAULT
572	08-11-2025	Part of : SECTOR 1 RAMAKRISHNA PURAM,RAMA COLONY,MOHAMMADPUR,EAST BLOCK RAMAKRISHNA PURAM	3134	Other Outage	Unplanned Outage	08-11-2025	00:02	08-11-2025	00:47	0:45	0.000363	CABLE FAULT
573	08-11-2025	Part of : SECTOR 5 SHANTI NIKETAN	1	Other Outage	Planned Outage	08-11-2025	10:59	08-11-2025	12:18	1:19	0.000241	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
574	08-11-2025	Part of : BLDG. NO 6 (ANSAL CH.2) BHIKAJI	364	Other Outage	Planned Outage	08-11-2025	10:59	08-11-2025	14:10	3:11	0.002122	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
575	08-11-2025	Part of : MUNIRKA	1008	Other Outage	Planned Outage	08-11-2025	10:28	08-11-2025	13:53	3:25	0.002563	DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER
576	10-11-2025	Part of : NEAR WATER TANK,SECTOR-3,R.K.PURAM	106	Other Outage	Planned Outage	10-11-2025	11:12	10-11-2025	13:53	2:41	0.000537	PREVENTIVE MAINTENANCE
577	10-11-2025	Part of : BLOCK B ANAND NIKETAN,	192	Other Outage	Planned Outage	10-11-2025	10:28	10-11-2025	13:12	2:44	0.000592	PREVENTIVE MAINTENANCE
578	11-11-2025	Part of : DHAULA KUAN ENCLAVE I	3	Other Outage	Unplanned Outage	11-11-2025	14:40	11-11-2025	15:07	0:27	0.000075	REPAIRING OF RMU
579	11-11-2025	Part of : SECTOR-3, R.K.PURAM	996	Other Outage	Planned Outage	11-11-2025	11:03	11-11-2025	14:19	3:16	0.000817	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
580	11-11-2025	Part of : BLOCK E VASANT VIHAR	442	Other Outage	Planned Outage	11-11-2025	10:29	11-11-2025	14:43	4:14	0.004586	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
581	12-11-2025	Part of : SECTOR 2 RAMAKRISHNA PURAM	505	Other Outage	Planned Outage	12-11-2025	11:16	12-11-2025	14:07	2:51	0.001663	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
582	12-11-2025	Part of : BASANT GAON VASANT VIHAR	422	Other Outage	Planned Outage	12-11-2025	10:44	12-11-2025	14:44	4:00	0.005333	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
583	12-11-2025	Part of : BLOCK A WEST END	102	Other Outage	Planned Outage	12-11-2025	10:09	12-11-2025	13:37	3:28	0.000751	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
584	13-11-2025	Part of : SEC-3 RK.PURAM NEAR STORE CPWD	193	Other Outage	Planned Outage	13-11-2025	11:14	13-11-2025	13:43	2:29	0.000497	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
585	13-11-2025	Part of : BLOCK F VASANT VIHAR	298	Other Outage	Planned Outage	13-11-2025	10:23	13-11-2025	14:27	4:04	0.004406	DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
586	14-11-2025	Part of : G BLOCK NANAHPURA MOTI BAGH SOUTH	269	Other Outage	Planned Outage	14-11-2025	10:17	14-11-2025	13:31	3:14	0.000701	PREVENTIVE MAINTENANCE
587	15-11-2025	Part of : MTNL (PLOT NO.-8) B.C.PLACE (HTC)	2	Other Outage	Planned Outage	15-11-2025	14:38	15-11-2025	15:38	1:00	0.000333	CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE,CONNECTING OF NEW EARTHING PER EARTHING,GUARD WIRES SAGGING PER SPAN
588	15-11-2025	Part of : POCKET 2 SECTOR 2 DWARKA	7	Other Outage	Planned Outage	15-11-2025	10:57	15-11-2025	12:43	1:46	0.000265	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
589	15-11-2025	Part of : BLDG. NO.-9 (SOMDUTT CHAMBERS-2)	367	Other Outage	Planned Outage	15-11-2025	11:11	15-11-2025	13:51	2:40	0.001333	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
590	15-11-2025	Part of : BASANT LOK VASANT VIHAR	163	Other Outage	Planned Outage	15-11-2025	10:09	15-11-2025	14:07	3:58	0.003967	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
591	17-11-2025	Part of : VAN VIGAYAN BHAWAN (HT CONSUMER), SECTOR-5 R.K PURAM	1	Other Outage	Planned Outage	17-11-2025	14:31	17-11-2025	16:39	2:08	0.000533	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
592	17-11-2025	Part of : SECTOR 5 RAMAKRISHNA PURAM	267	Other Outage	Planned Outage	17-11-2025	11:05	17-11-2025	14:02	2:57	0.000590	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
593	17-11-2025	Part of : BLOCK H NANAKPURA MOTI BAGH SOUTH	374	Other Outage	Planned Outage	17-11-2025	10:15	17-11-2025	13:00	2:45	0.000688	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
594	18-11-2025	Part of : SECTOR 4 RAMAKRISHNA PURAM,	981	Other Outage	Planned Outage	18-11-2025	11:09	18-11-2025	14:07	2:58	0.001483	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
595	18-11-2025	Part of : CGHC COLONY VASANT VIHAR,	257	Other Outage	Planned Outage	18-11-2025	10:23	18-11-2025	14:13	3:50	0.002875	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
596	19-11-2025	Part of : MUNIRKA ENCLAVE	909	Other Outage	Unplanned Outage	19-11-2025	15:12	19-11-2025	15:45	0:33	0.000000	REPLACEMENT OF RMU
597	19-11-2025	Part of : SECTOR 4 RAMAKRISHNA PURAM	185	Other Outage	Planned Outage	19-11-2025	11:04	19-11-2025	13:40	2:36	0.000650	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
598	19-11-2025	Part of : BLOCK H NANAKPURA MOTI BAGH SOUTH	376	Other Outage	Planned Outage	19-11-2025	10:17	19-11-2025	13:59	3:42	0.000740	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
599	20-11-2025	Part of : D-BLOCK VASANT VIHAR	1078	Other Outage	Planned Outage	20-11-2025	10:46	20-11-2025	14:15	3:29	0.001161	REPLACEMENT OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
600	21-11-2025	Part of : SONIA GANDHI CAMP SECTOR 6 RAMAKRISHNA PURAM	304	Other Outage	Planned Outage	21-11-2025	11:52	21-11-2025	14:05	2:13	0.000554	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
601	21-11-2025	Part of : BLOCK C MOTI BAGH SOUTH MARKET MOTI BAGH SOUTH	461	Other Outage	Planned Outage	21-11-2025	10:25	21-11-2025	12:52	2:27	0.000613	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
602	22-11-2025	Part of : INDIAN AIR LINES AND AIR INDIA ESTATE VASANT VIHAR,	5	Other Outage	Planned Outage	22-11-2025	12:01	22-11-2025	13:05	1:04	0.000533	SF6 GAS FILLING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
603	22-11-2025	Part of : HTC:EAST BLOCK, R.K.PURAM	1	Other Outage	Planned Outage	22-11-2025	11:46	22-11-2025	13:25	1:39	0.000413	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
604	22-11-2025	Part of : BASANT LOK VASANT VIHAR,	62	Other Outage	Planned Outage	22-11-2025	10:05	22-11-2025	13:55	3:50	0.003514	APPLY OF INSULATION TAPE HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
605	23-11-2025	Part of : MUNIRKA,MUNIRKA ENCLAVE MUNIRKA,BASANT LOK VASANT VIHAR	2782	Other Outage	Unplanned Outage	23-11-2025	15:55	23-11-2025	16:39	0:44	0.001210	CABLE FAULT
606	24-11-2025	Part of : SECTOR 5 RAMAKRISHNA PURAM	323	Other Outage	Planned Outage	24-11-2025	10:26	24-11-2025	13:10	2:44	0.000683	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
607	24-11-2025	Part of : SECTOR 1 SHANTI NIKETAN	120	Other Outage	Planned Outage	24-11-2025	10:10	24-11-2025	13:26	3:16	0.000599	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
608	25-11-2025	Part of : BASANT GAON VASANT VIHAR	1132	Other Outage	Planned Outage	25-11-2025	10:40	25-11-2025	14:49	4:09	0.002767	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
609	26-11-2025	Part of : SECTOR 9 RAMAKRISHNA PURAM,	455	Other Outage	Planned Outage	26-11-2025	11:11	26-11-2025	14:59	3:48	0.001583	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
610	26-11-2025	Part of : SECTOR 2 SHANTI NIKETAN,	97	Other Outage	Planned Outage	26-11-2025	10:19	26-11-2025	13:51	3:32	0.000589	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
611	27-11-2025	Part of : MOTILAL NEHRU COLLEGE, BENITO ZUAREZ MAR, SOUTH CAMPUS	1	Other Outage	Planned Outage	27-11-2025	10:20	27-11-2025	11:21	1:01	0.000136	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
612	27-11-2025	Part of : MUNIRKA ENCLAVE MUNIRKA	627	Other Outage	Planned Outage	27-11-2025	11:52	27-11-2025	14:11	2:19	0.000579	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
613	27-11-2025	Part of : BLOCK F VASANT VIHAR	120	Other Outage	Planned Outage	27-11-2025	10:24	27-11-2025	13:33	3:09	0.001575	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF HT BOOTS,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
614	27-11-2025	Part of : SECTOR 6 RAMAKRISHNA PURAM	501	Other Outage	Planned Outage	27-11-2025	11:35	27-11-2025	14:13	2:38	0.001317	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
615	28-11-2025	Part of : SECTOR 2 SHANTI NIKETAN	215	Other Outage	Planned Outage	28-11-2025	10:02	28-11-2025	12:52	2:50	0.000614	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
616	29-11-2025	Part of : SADHU BASWANI MEDICAL CENTRE (HTC)	1	Other Outage	Planned Outage	29-11-2025	10:50	29-11-2025	12:48	1:58	0.000131	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
617	29-11-2025	Part of : SECTOR 5 RAMAKRISHNA PURAM	720	Other Outage	Planned Outage	29-11-2025	10:58	29-11-2025	14:18	3:20	0.001667	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
618	29-11-2025	Part of : DHAULA KUAN ENCLAVE I	3	Other Outage	Planned Outage	29-11-2025	11:04	29-11-2025	13:44	2:40	0.000444	CLEANING OF HT BUSHING PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS,RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
619	29-11-2025	Part of : BASANT LOK VASANT VIHAR	38	Other Outage	Planned Outage	29-11-2025	10:04	29-11-2025	13:29	3:25	0.001708	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
620	01-11-2025	Part of : FREEDOM FIGHTER VIHAR,BLOCK A,C,D & E PARYAVARAN COMPLEX SAINIK FARM	2444	Other Outage	Planned Outage	01-11-2025	12:50	01-11-2025	15:54	3:04	0.005622	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB CABLE REPLACEMENT PER SPAN,LT BUSHING REPLACEMENT,ST.TH JOINT ON 3PH HT AB
621	01-11-2025	Part of : BLOCK A SHIVALIK MALVIYA NAGAR	776	Other Outage	Planned Outage	01-11-2025	12:55	01-11-2025	15:07	2:12	0.000367	REPLACEMENT OF LT BUSHING ROD
622	03-11-2025	PART OF : CHIRAG DELHI	1392	Other Outage	Planned Outage	03-11-2025	11:02	03-11-2025	14:11	3:09	0.000000	REPLACEMET OF HT BUSHING ROD
623	03-11-2025	PART OF : NAI BASTI LADO SARAI	721	Other Outage	Planned Outage	03-11-2025	11:00	03-11-2025	13:51	2:51	0.004750	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
624	03-11-2025	PART OF : SAIYAD UL AJAIB VILLAGE SAINIK FARM	156	Other Outage	Planned Outage	03-11-2025	10:40	03-11-2025	13:50	3:10	0.005278	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
625	03-11-2025	PART OF : VIJAY MANDAL ENCLAVE KALU SARAI	4	Other Outage	Planned Outage	03-11-2025	10:03	03-11-2025	12:57	2:54	0.000242	REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS,SUB STATION CLEANING
626	04-11-2025	Part of : POCKET K SHEIKH SARAI PHASE-2	903	Other Outage	Unplanned Outage	04-11-2025	11:20	04-11-2025	12:11	0:51	0.000241	CABLE FAULT
627	04-11-2025	Part of : C-BLOCK MALVIYA NAGAR	761	Other Outage	Planned Outage	04-11-2025	10:30	04-11-2025	14:16	3:46	0.000000	REPLACEMENT OF HT BUSHING ROD
628	04-11-2025	Part of : LADO SARAI EXTENSION	1110	Other Outage	Planned Outage	04-11-2025	11:26	04-11-2025	14:13	2:47	0.005103	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
629	04-11-2025	Part of : KUTUB GOLF COURSE LADO SARAI	1	Other Outage	Planned Outage	04-11-2025	10:18	04-11-2025	12:32	2:14	0.000186	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
630	05-11-2025	Part of : FREEDOM FIGHTER VIHAR,BLOCK A,C & D PARYAVARAN COMPLEX SAINIK FARM	2444	Other Outage	Planned Outage	05-11-2025	11:32	05-11-2025	14:06	2:34	0.004706	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,HT BUSHING ROD REPLACEMENT,LT BUSHING REPLACEMENT,LT JUMPER REPLACEMENT,ST.TH JOINT ON 3PH HT AB

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
631	06-11-2025	Part of : KUTUB GOLF COURSE LADO SARAI,	1	Other Outage	Planned Outage	06-11-2025	14:04	06-11-2025	15:42	1:38	0.002994	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
632	06-11-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,	406	Other Outage	Planned Outage	06-11-2025	12:03	06-11-2025	15:44	3:41	0.006139	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
633	06-11-2025	Part of : CHIRAG DELHI,	141	Other Outage	Planned Outage	06-11-2025	10:45	06-11-2025	14:07	3:22	0.000561	REPLACEMENT OF LT BUSHING ROD
634	06-11-2025	Part of : KHIRKI EXT. JC-43 PKG	1	Other Outage	Planned Outage	06-11-2025	10:57	06-11-2025	14:46	3:49	0.000000	REPLACEMET OF HT BUSHING ROD
635	06-11-2025	Part of : NAI BASTI LADO SARAI,	926	Other Outage	Planned Outage	06-11-2025	11:04	06-11-2025	13:47	2:43	0.004981	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
636	06-11-2025	Part of : BHAVISHYANIDHI ENCLAVE MALVIYA NAGAR,	107	Other Outage	Planned Outage	06-11-2025	10:07	06-11-2025	12:57	2:50	0.000000	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS,REPLACEMET OF FAULTY END BOX
637	07-11-2025	Part of : POCKET C PHASE I SHEIKH SARAI	107	Other Outage	Planned Outage	07-11-2025	10:56	07-11-2025	13:59	3:03	0.000508	REPLACEMET OF HT BUSHING ROD
638	07-11-2025	Part of : NAI BASTI LADO SARAI	781	Other Outage	Planned Outage	07-11-2025	11:11	07-11-2025	13:51	2:40	0.004889	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
639	07-11-2025	Part of : JAHANPANAH MONUMENT MALVIYA NAGAR	1	Other Outage	Planned Outage	07-11-2025	09:55	07-11-2025	12:45	2:50	0.000094	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
640	08-11-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	406	Other Outage	Planned Outage	08-11-2025	12:43	08-11-2025	16:40	3:57	0.006583	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT
641	08-11-2025	Part of : H-BLOCK NEB SARAI SAINIK FARM	44	Other Outage	Planned Outage	08-11-2025	11:14	08-11-2025	13:53	2:39	0.004417	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
642	08-11-2025	Part of : PANCHSHEEL EXTENSION MALVIYA NAGAR	778	Other Outage	Planned Outage	08-11-2025	10:47	08-11-2025	14:13	3:26	0.000000	REPLACEMENT OF HT BUSHING ROD
643	10-11-2025	Part of : NEW COLONY KHIDKI EXTENSION MALVIYA NAGAR,GANDHI PARK MALVIYA NAGAR,BLOCK T MALVIYA NAGAR	3546	Other Outage	Unplanned Outage	10-11-2025	00:59	10-11-2025	01:54	0:55	0.000535	FAULT IN HT CONSUMER PANEL (MGF MALL)
644	10-11-2025	Part of : BLOCK C MALVIYA NAGAR,	761	Other Outage	Planned Outage	10-11-2025	10:15	10-11-2025	12:03	1:48	0.000300	PREVENTIVE MAINTENANCE
645	10-11-2025	Part of : BLOCK L MALVIYA NAGAR,	2266	Other Outage	Planned Outage	10-11-2025	10:16	10-11-2025	12:01	1:45	0.000292	PREVENTIVE MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
646	10-11-2025	Part of : SETH SARAI MEHRAULI,KUTUB GOLF COURSE LADO SARAI,NAI BASTI LADO SARAI,BLOCK C QUTAB INSTITUTIONAL AREA,	954	Other Outage	Planned Outage	10-11-2025	11:04	10-11-2025	13:55	2:51	0.004750	TREE TRIMMING
647	10-11-2025	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE,	233	Other Outage	Planned Outage	10-11-2025	10:07	10-11-2025	13:04	2:57	0.000246	PREVENTIVE MAINTENANCE
648	10-11-2025	Part of : NEW COLONY KHIDKI EXTENSION MALVIYA NAGAR,	1344	Other Outage	Planned Outage	10-11-2025	10:21	10-11-2025	13:11	2:50	0.000000	PREVENTIVE MAINTENANCE
649	11-11-2025	Part of : POCKET C PHASE I SHEIKH SARAI	107	Other Outage	Planned Outage	11-11-2025	11:02	11-11-2025	11:16	0:14	0.000039	REPLACEMENT OF HT BUSHING ROD
650	11-11-2025	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	5	Other Outage	Planned Outage	11-11-2025	10:07	11-11-2025	11:08	1:01	0.000085	REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING
651	11-11-2025	Part of : JAGDAMBA CAMP SHEIKH SARAI	1579	Other Outage	Planned Outage	11-11-2025	10:43	11-11-2025	14:15	3:32	0.000589	REPLACEMENT OF HT BUSHING ROD
652	11-11-2025	Part of : CHHATRI WALA KUNA LADO SARAI	348	Other Outage	Planned Outage	11-11-2025	10:59	11-11-2025	14:14	3:15	0.006500	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
653	11-11-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	433	Other Outage	Planned Outage	11-11-2025	11:47	11-11-2025	14:13	2:26	0.004056	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
654	12-11-2025	Part of : CHIRAG DELHI	142	Other Outage	Planned Outage	12-11-2025	11:37	12-11-2025	12:13	0:36	0.000100	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
655	12-11-2025	Part of : BLOCK H,A 1 NEB SARAI SAINIK FARM,ROCKY AREA STONE QUARRIES	729	Other Outage	Planned Outage	12-11-2025	11:20	12-11-2025	14:09	2:49	0.004694	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE
656	12-11-2025	Part of : BLOCK D DDA FLATE MALVIYA NAGAR	644	Other Outage	Planned Outage	12-11-2025	10:49	12-11-2025	14:02	3:13	0.000000	REPLACEMENT OF HT BUSHING ROD
657	12-11-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	700	Other Outage	Planned Outage	12-11-2025	12:27	12-11-2025	15:54	3:27	0.000575	LT CIRCUIT MAINTENANCE
658	13-11-2025	Part of : NEW COLONY KHIDKI EXTENSION MALVIYA NAGAR	1526	Other Outage	Planned Outage	13-11-2025	11:36	13-11-2025	12:24	0:48	0.000000	REPLACEMENT OF HT BUSHING ROD
659	13-11-2025	Part of : CHHATRI WALA KUNA LADO SARAI	108	Other Outage	Planned Outage	13-11-2025	11:51	13-11-2025	13:05	1:14	0.002467	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
660	13-11-2025	Part of : BLOCK B NAVJIVAN VIHAR MALVIYA NAGAR	142	Other Outage	Planned Outage	13-11-2025	10:18	13-11-2025	13:08	2:50	0.000472	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF HT BUSHING ROD
661	14-11-2025	Part of : CHIRAG DELHI	1392	Other Outage	Planned Outage	14-11-2025	12:23	14-11-2025	13:15	0:52	0.000144	PREVENTIVE MAINTENANCE
662	14-11-2025	Part of : BLOCK J SAKET	171	Other Outage	Planned Outage	14-11-2025	14:47	14-11-2025	16:01	1:14	0.002056	REPLACEMENT OF HT BUSHING ROD
663	14-11-2025	Part of : BLOCK N SAKET	134	Other Outage	Planned Outage	14-11-2025	11:33	14-11-2025	14:35	3:02	0.006067	PREVENTIVE MAINTENANCE
664	14-11-2025	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI	629	Other Outage	Planned Outage	14-11-2025	10:35	14-11-2025	14:20	3:45	0.000000	PREVENTIVE MAINTENANCE
665	15-11-2025	Part of : BLOCK E & J SAINIK FARM,BLOCK H NEB SARAI SAINIK FARM	401	Other Outage	Unplanned Outage	15-11-2025	06:17	15-11-2025	07:01	0:44	0.000110	TRANSIENT FAULT
666	15-11-2025	Part of : LADO SARAI EXTENSION LADO SARAI,BANDALO WALA MOHALLA LADO SARAI,CHHATRI WALA KUNA LADO SARAI	3038	Other Outage	Unplanned Outage	15-11-2025	05:11	15-11-2025	06:27	1:16	0.000823	CABLE FAULT
667	15-11-2025	Part of : FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK A, C, D & E PARYAVARAN COMPLEX SAINIK FARM	2444	Other Outage	Planned Outage	15-11-2025	11:33	15-11-2025	13:58	2:25	0.004431	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,LT BUSHING REPLACEMENT
668	15-11-2025	Part of : MALVIYA NAGAR	1011	Other Outage	Planned Outage	15-11-2025	09:53	15-11-2025	13:02	3:09	0.000000	REPLACEMENT OF HT BUSHING ROD
669	15-11-2025	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI	833	Other Outage	Planned Outage	15-11-2025	10:11	15-11-2025	12:38	2:27	0.000000	REPLACEMENT OF HT BUSHING ROD
670	16-11-2025	Part of : SECTOR 1 PUSHPA VIHAR,G,L,H,N & J-BLOCK SAKET,ASHOK VIHAR PRESS ENCLAVE	1972	Other Outage	Unplanned Outage	16-11-2025	03:13	16-11-2025	04:12	0:59	0.000787	630 KVA TRANSFORMER FAULTY
671	17-11-2025	Part of : BLOCK N MALVIYA NAGAR	448	Other Outage	Planned Outage	17-11-2025	10:43	17-11-2025	14:03	3:20	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
672	17-11-2025	Part of : SECTOR 1 PUSHPA VIHAR	559	Other Outage	Planned Outage	17-11-2025	11:16	17-11-2025	14:06	2:50	0.005667	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
673	18-11-2025	Part of : SECTOR 3 PUSHPA VIHAR,	281	Other Outage	Planned Outage	18-11-2025	11:48	18-11-2025	15:13	3:25	0.006833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
674	18-11-2025	Part of : POCKET B PHASE I SHEIKH SARAI,	227	Other Outage	Planned Outage	18-11-2025	10:54	18-11-2025	14:01	3:07	0.000519	REPLACEMENT OF HT BUSHING ROD
675	18-11-2025	Part of : BLOCK C QUTAB INSTITUTIONAL AREA,	7	Other Outage	Planned Outage	18-11-2025	11:11	18-11-2025	14:28	3:17	0.005472	INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
676	19-11-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	1117	Other Outage	Planned Outage	19-11-2025	11:52	19-11-2025	16:10	4:18	0.007167	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT PER SPAN,INSULATOR REPLACEMENT,LT BUSHING REPLACEMENT
677	19-11-2025	Part of : POCKET K PHASE II SHEIKH SARAI	489	Other Outage	Planned Outage	19-11-2025	10:05	19-11-2025	13:40	3:35	0.000000	CONDUCTOR REPLACEMENT PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
678	20-11-2025	Part of : GOVERNMENT QUATERS SECTOR 4 PUSHPA VIHAR	455	Other Outage	Planned Outage	20-11-2025	11:44	20-11-2025	15:06	3:22	0.007294	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
679	20-11-2025	Part of : B-BLOCK NAVJIVAN VIHAR MALVIYA NAGAR	148	Other Outage	Planned Outage	20-11-2025	10:08	20-11-2025	13:19	3:11	0.000265	REPLACEMENT OF HT BUSHING ROD
680	20-11-2025	Part of : POCKET C SHEIKH SARAI PHASE-1	253	Other Outage	Planned Outage	20-11-2025	10:07	20-11-2025	12:45	2:38	0.000000	REPLACEMENT OF HT BUSHING ROD
681	21-11-2025	Part of : GOVERNMENT QUATERS SECTOR 4 PUSHPA VIHAR	312	Other Outage	Planned Outage	21-11-2025	11:03	21-11-2025	13:53	2:50	0.006139	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
682	21-11-2025	Part of : KALU SARAI	264	Other Outage	Planned Outage	21-11-2025	10:00	21-11-2025	12:37	2:37	0.000480	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD
683	21-11-2025	Part of : POCKET C PHASE I SHEIKH SARAI	146	Other Outage	Planned Outage	21-11-2025	09:55	21-11-2025	13:53	3:58	0.000000	REPLACEMENT OF HT BUSHING ROD
684	22-11-2025	Part of : BLOCK A MALVIYA NAGAR,	413	Other Outage	Planned Outage	22-11-2025	10:55	22-11-2025	14:00	3:05	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
685	22-11-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM,	366	Other Outage	Planned Outage	22-11-2025	11:02	22-11-2025	14:01	2:59	0.004972	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
686	24-11-2025	Part of : PTS (HT CONSUMER)	1	Other Outage	Planned Outage	24-11-2025	11:05	24-11-2025	12:15	1:10	0.000000	REPLACEMENT OF FAULTY END BOX,SF6 GAS FILLING
687	24-11-2025	Part of : SECTOR 7 PUSHPA VIHAR	209	Other Outage	Planned Outage	24-11-2025	11:01	24-11-2025	13:54	2:53	0.006247	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
688	24-11-2025	Part of : BLOCK 3 SARVAPRIYA VIHAR	274	Other Outage	Planned Outage	24-11-2025	10:26	24-11-2025	13:18	2:52	0.000239	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
689	24-11-2025	Part of : CHIRAG DELHI	565	Other Outage	Planned Outage	24-11-2025	10:03	24-11-2025	13:01	2:58	0.000000	REPLACEMENT OF HT BUSHING ROD
690	25-11-2025	Part of : DISTRICT PARK PHASE I SHEIKH SARAI	1686	Other Outage	Planned Outage	25-11-2025	12:23	25-11-2025	13:36	1:13	0.000000	REPLACEMET OF HT BUSHING ROD
691	25-11-2025	Part of : BLOCK 7 SARVAPRIYA VIHAR	232	Other Outage	Planned Outage	25-11-2025	10:22	25-11-2025	13:00	2:38	0.000219	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
692	25-11-2025	Part of : CHIRAG DELHI	429	Other Outage	Planned Outage	25-11-2025	11:00	25-11-2025	13:35	2:35	0.000000	REPLACEMET OF HT BUSHING ROD
693	25-11-2025	Part of : SECTOR 7 PUSHPA VIHAR	337	Other Outage	Planned Outage	25-11-2025	11:10	25-11-2025	13:47	2:37	0.005669	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
694	26-11-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM,POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,BLOCK D FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK D PARYAVARAN COMPLEX SAINIK FARM,SAINIK FARM,BLOCK B FREEDOM FIGHTER VIHAR SAINIK FARM	600	Other Outage	Unplanned Outage	26-11-2025	09:01	26-11-2025	09:45	0:44	0.000037	ELECTROCUTION OF MONKEY
695	26-11-2025	Part of : SPG QUATERS SECTOR 4 PUSHPA VIHAR,	637	Other Outage	Planned Outage	26-11-2025	11:14	26-11-2025	13:53	2:39	0.001325	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
696	26-11-2025	Part of : KALU SARAI,	262	Other Outage	Planned Outage	26-11-2025	10:10	26-11-2025	12:33	2:23	0.000477	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
697	26-11-2025	Part of : BLOCK H PANCHSHEEL VIHAR SHEIKH SARAI VILLAGE SHEIKH SARAI,	846	Other Outage	Planned Outage	26-11-2025	10:10	26-11-2025	13:35	3:25	0.000000	REPLACEMET OF HT BUSHING ROD
698	27-11-2025	Part of : AUROBINDO COLLEGE MALVIYA NAGAR	1	Other Outage	Planned Outage	27-11-2025	11:17	27-11-2025	12:02	0:45	0.000000	REPLACEMENT OF FAULTY END BOX,SF6 GAS FILLING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
699	27-11-2025	Part of : MADHUKAR HOSPITAL, MALVIYANAGAR (HTC)	1	Other Outage	Planned Outage	27-11-2025	12:05	27-11-2025	12:55	0:50	0.000000	REPLACEMENT OF FAULTY END BOX,SF6 GAS FILLING
700	27-11-2025	Part of : BLOCK D MALVIYA NAGAR	511	Other Outage	Planned Outage	27-11-2025	11:06	27-11-2025	12:21	1:15	0.000000	REPLACEMENT OF HT BUSHING ROD
701	27-11-2025	Part of : KALU SARAI	267	Other Outage	Planned Outage	27-11-2025	11:51	27-11-2025	13:52	2:01	0.000168	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
702	27-11-2025	Part of : CHIRAG DELHI	1384	Other Outage	Planned Outage	27-11-2025	11:04	27-11-2025	14:08	3:04	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
703	27-11-2025	Part of : SECTOR 1 PUSHPA VIHAR	531	Other Outage	Planned Outage	27-11-2025	10:54	27-11-2025	13:42	2:48	0.006067	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
704	28-11-2025	Part of : SECTOR 5 PUSHPA VIHAR	430	Other Outage	Planned Outage	28-11-2025	10:54	28-11-2025	13:51	2:57	0.006883	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
705	28-11-2025	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	171	Other Outage	Planned Outage	28-11-2025	10:07	28-11-2025	13:06	2:59	0.000249	REPLACEMET OF HT BUSHING ROD
706	28-11-2025	Part of : N-BLOCK MALVIYA NAGAR	1258	Other Outage	Planned Outage	28-11-2025	10:36	28-11-2025	14:17	3:41	0.000000	REPLACEMET OF HT BUSHING ROD
707	29-11-2025	Part of : CHIRAG DELHI	421	Other Outage	Planned Outage	29-11-2025	10:42	29-11-2025	14:01	3:19	0.000000	REPLACEMET OF HT BUSHING ROD
708	29-11-2025	Part of : SPG QUATERS SECTOR 4 PUSHPA VIHAR	361	Other Outage	Planned Outage	29-11-2025	11:02	29-11-2025	13:56	2:54	0.004833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
709	01-11-2025	Part of : F-BLOCK HARI NAGAR EXTN	15	Other Outage	Planned Outage	01-11-2025	13:49	01-11-2025	14:39	0:50	0.001528	INSTALLATION OF BUS BAR
710	02-11-2025	Part of : BLOCK E MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR,	2	Other Outage	Planned Outage	02-11-2025	10:14	02-11-2025	12:58	2:44	0.005011	REPLACEMET OF FAULTY END BOX
711	03-11-2025	PART OF : MOLARBAND	1091	Other Outage	Planned Outage	03-11-2025	10:41	03-11-2025	13:57	3:16	0.004900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF BUS BAR,REPLACEMENT OF LT BUSHING ROD
712	04-11-2025	Part of : N,O & E-BLOCK SAURABH VIHAR	1340	Other Outage	Planned Outage	04-11-2025	11:07	04-11-2025	12:33	1:26	0.001433	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
713	04-11-2025	Part of : POCKET K SARITA VIHAR	162	Other Outage	Planned Outage	04-11-2025	11:08	04-11-2025	13:33	2:25	0.002819	REPLACEMENT OF HT BUSHING ROD
714	05-11-2025	Part of : MITHAPUR	687	Other Outage	Planned Outage	05-11-2025	11:17	05-11-2025	13:56	2:39	0.003975	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING
715	06-11-2025	Part of : BADARPUR VILLAGE BADARPUR,	924	Other Outage	Planned Outage	06-11-2025	11:03	06-11-2025	13:48	2:45	0.000458	REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
716	07-11-2025	Part of : F-BLOCK HARI NAGAR EXTN,E-BLOCK HARI NAGAR EXTN,D2-BLOCK HARI NAGAR EXTN-III	1047	Other Outage	Planned Outage	07-11-2025	13:56	07-11-2025	15:50	1:54	0.003483	REPLACEMENT OF LT BUSHING ROD
717	07-11-2025	Part of : BLOCK E1, E2 & F MOLARBAND EXTENSION BADARPUR	14	Other Outage	Planned Outage	07-11-2025	11:26	07-11-2025	14:16	2:50	0.000944	3PH HT AB CABLE REPLACEMENT PER SPAN
718	07-11-2025	Part of : MADANPUR KHADAR	300	Other Outage	Planned Outage	07-11-2025	10:56	07-11-2025	13:40	2:44	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF GAS KIT AND OIL SEAL
719	08-11-2025	Part of : KHADDA COLONY JAIPUR	3008	Other Outage	Planned Outage	08-11-2025	10:59	08-11-2025	13:39	2:40	0.001333	3PH HT AB CABLE REPLACEMENT
720	08-11-2025	Part of : C-BLOCK MOLARBAND EXTENSION BADARPUR	419	Other Outage	Planned Outage	08-11-2025	12:16	08-11-2025	15:05	2:49	0.000469	INSTALLATION OF HT BOOTS,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF LUGS

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
721	09-11-2025	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	35	Other Outage	Unplanned Outage	09-11-2025	10:37	09-11-2025	11:17	0:40	0.000144	CABLE FAULT
722	09-11-2025	Part of : KHADDA COLONY JAIPUR	965	Other Outage	Planned Outage	09-11-2025	10:56	09-11-2025	12:23	1:27	0.000000	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
723	10-11-2025	Part of : J BLOCK SAURABH VIHAR,ABC BLOCK HARI NAGAR MOLARBAND,K-BLOCK SAURABH VIHAR,D-BLOCK SAURABH,	1375	Other Outage	Planned Outage	10-11-2025	10:54	10-11-2025	13:49	2:55	0.002917	HVDS TRANSFORMER
724	10-11-2025	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR,	769	Other Outage	Planned Outage	10-11-2025	09:57	10-11-2025	14:13	4:16	0.008533	PREVENTIVE MAINTENANCE
725	11-11-2025	Part of : ABC BLOCK HARI NAGAR MOLARBAND	615	Other Outage	Planned Outage	11-11-2025	11:12	11-11-2025	13:03	1:51	0.002775	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF HT BUSHING ROD
726	11-11-2025	Part of : MADANPUR KHADAR VILLAGE	614	Other Outage	Planned Outage	11-11-2025	10:25	11-11-2025	12:20	1:55	0.004792	REPLACEMENT OF LT BUSHING ROD
727	12-11-2025	Part of : HARSH VIHAR MOLARBAND	1411	Other Outage	Planned Outage	12-11-2025	11:02	12-11-2025	14:16	3:14	0.004850	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF LT BUSHING ROD
728	12-11-2025	Part of : LALU COLONY ALI	1088	Other Outage	Planned Outage	12-11-2025	11:21	12-11-2025	13:36	2:15	0.003750	REPLACEMENT OF HT BUSHING ROD
729	13-11-2025	Part of : BLOCK B MOLARBAND EXTENSION BADARPUR	498	Other Outage	Planned Outage	13-11-2025	11:10	13-11-2025	14:06	2:56	0.000489	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
730	14-11-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1609	Other Outage	Planned Outage	14-11-2025	11:01	14-11-2025	12:57	1:56	0.000967	HT AB CABLE REPLACEMENT
731	14-11-2025	Part of : BADARPUR VILLAGE	2	Other Outage	Planned Outage	14-11-2025	11:37	14-11-2025	13:14	1:37	0.000269	HT BUSHING DAMAGE
732	15-11-2025	Part of : MITHAPUR	861	Other Outage	Planned Outage	15-11-2025	12:02	15-11-2025	15:02	3:00	0.001500	CONDUCTOR REPLACEMENT PER SPAN
733	15-11-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1383	Other Outage	Planned Outage	15-11-2025	10:58	15-11-2025	13:08	2:10	0.001083	3PH HT AB CABLE REPLACEMENT PER SPAN
734	16-11-2025	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	8	Other Outage	Planned Outage	16-11-2025	11:34	16-11-2025	12:40	1:06	0.000550	REPLACEMENT OF HT BUSHING ROD
735	16-11-2025	Part of : BLOCK E MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	35	Other Outage	Planned Outage	16-11-2025	11:42	16-11-2025	13:56	2:14	0.000744	REPLACEMENT OF FAULTY END BOX
736	16-11-2025	Part of : BLOCK E MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	7	Other Outage	Planned Outage	16-11-2025	09:39	16-11-2025	11:45	2:06	0.000350	REPLACEMENT OF HT BUSHING ROD
737	17-11-2025	Part of : BADARPUR	1	Other Outage	Planned Outage	17-11-2025	12:20	17-11-2025	14:28	2:08	0.001422	REPLACEMENT OF FAULTY END BOX
738	17-11-2025	Part of : E-BLOCK HARI NAGAR EXT PART-2	489	Other Outage	Planned Outage	17-11-2025	11:33	17-11-2025	14:01	2:28	0.003700	DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS
739	17-11-2025	Part of : ALI VILLAGE	463	Other Outage	Planned Outage	17-11-2025	11:00	17-11-2025	13:37	2:37	0.003489	REPLACEMENT OF HT BUSHING ROD
740	18-11-2025	Part of : JAIPUR EXTN B-BLOCK,	1271	Other Outage	Planned Outage	18-11-2025	13:18	18-11-2025	14:32	1:14	0.000308	SUB STATION CLEANING
741	18-11-2025	Part of : ALI VILLAGE ALI,	464	Other Outage	Planned Outage	18-11-2025	10:56	18-11-2025	13:32	2:36	0.001733	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR
742	18-11-2025	Part of : SAIDABAD SARITA VIHAR,	238	Other Outage	Planned Outage	18-11-2025	10:56	18-11-2025	13:36	2:40	0.001778	REPLACEMET OF HT BUSHING ROD
743	19-11-2025	Part of : LALU COLONY ALI	1096	Other Outage	Planned Outage	19-11-2025	10:53	19-11-2025	14:05	3:12	0.000000	REPLACEMENT OF HT BUSHING ROD
744	19-11-2025	Part of : MADANPUR KHADAR VILLAGE	703	Other Outage	Planned Outage	19-11-2025	10:54	19-11-2025	14:05	3:11	0.003714	REPLACEMENT OF HT BUSHING ROD
745	20-11-2025	Part of : F-BLOCK HARI NAGAR EXTN	15	Other Outage	Planned Outage	20-11-2025	11:21	20-11-2025	12:52	1:31	0.000253	SUB STATION CLEANING
746	20-11-2025	Part of : MITHAPUR	712	Other Outage	Planned Outage	20-11-2025	11:21	20-11-2025	13:16	1:55	0.003514	REPLACEMENT OF FAULTY END BOX
747	20-11-2025	Part of : MOHAN BABA NAGAR,BADARPUR EXTENSION,A-BLOCK BUDH BIHAR	2402	Other Outage	Planned Outage	20-11-2025	12:27	20-11-2025	15:19	2:52	0.005256	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
748	20-11-2025	Part of : KHADDA COLONY JAIPUR	609	Other Outage	Planned Outage	20-11-2025	10:56	20-11-2025	13:25	2:29	0.000000	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS
749	20-11-2025	Part of : BADARPUR VILLAGE	1767	Other Outage	Planned Outage	20-11-2025	11:20	20-11-2025	14:00	2:40	0.000889	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
750	21-11-2025	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR	21	Other Outage	Planned Outage	21-11-2025	12:54	21-11-2025	13:45	0:51	0.000142	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
751	21-11-2025	Part of : KHADDA COLONY JAIPUR	3008	Other Outage	Planned Outage	21-11-2025	10:52	21-11-2025	13:31	2:39	0.001325	3PH HT AB CABLE REPLACEMENT PER SPAN
752	21-11-2025	Part of : BADARPUR EXTENSION TAJPUR	977	Other Outage	Planned Outage	21-11-2025	11:17	21-11-2025	13:47	2:30	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
753	22-11-2025	Part of : KHADDA COLONY JAIPUR,	3008	Other Outage	Planned Outage	22-11-2025	10:57	22-11-2025	13:41	2:44	0.001367	3PH HT AB CABLE REPLACEMENT PER SPAN
754	22-11-2025	Part of : BADARPUR VILLAGE BADARPUR,	1098	Other Outage	Planned Outage	22-11-2025	11:13	22-11-2025	14:04	2:51	0.000475	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
755	23-11-2025	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	5	Other Outage	Planned Outage	23-11-2025	12:25	23-11-2025	13:03	0:38	0.000317	REPLACEMENT OF HT BUSHING ROD
756	24-11-2025	Part of : GAYATRI KUNJ ALI VILLAGE	1378	Other Outage	Planned Outage	24-11-2025	10:57	24-11-2025	13:49	2:52	0.003822	REPLACEMENT OF HT BUSHING ROD
757	25-11-2025	Part of : SAIDABAD SARITA VIHAR	838	Other Outage	Planned Outage	25-11-2025	10:54	25-11-2025	13:18	2:24	0.003200	REPLACEMET OF HT BUSHING ROD
758	25-11-2025	Part of : VILLAGE JAIPUR	653	Other Outage	Planned Outage	25-11-2025	11:20	25-11-2025	13:20	2:00	0.003333	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
759	26-11-2025	Part of : RAJ NAGAR MADANPUR KHADAR,MADANPUR KHADAR	4020	Other Outage	Unplanned Outage	26-11-2025	09:38	26-11-2025	10:11	0:33	0.000000	CABLE FAULT
760	26-11-2025	Part of : MITHAPUR,	1673	Other Outage	Planned Outage	26-11-2025	12:11	26-11-2025	13:56	1:45	0.002625	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD
761	26-11-2025	Part of : MADANPUR KHADAR VILLAGE MADANPUR KHADAR,	754	Other Outage	Planned Outage	26-11-2025	11:03	26-11-2025	13:48	2:45	0.003667	REPLACEMET OF HT BUSHING ROD
762	27-11-2025	Part of : GAGAN VIHAR MITHAPUR EXTENSION MITHAPUR	191	Other Outage	Unplanned Outage	27-11-2025	12:52	27-11-2025	14:26	1:34	0.000000	REPLACEMENT OF HT BUSHING
763	27-11-2025	Part of : BLOCK C, E 1 & E2 MOLARBAND EXTENSION BADARPUR	1903	Other Outage	Planned Outage	27-11-2025	11:37	27-11-2025	13:45	2:08	0.001067	DB REVAMPING,DT REPLACEMENT PER DT,HT BUSHING ROD REPLACEMENT,LT BUSHING REPLACEMENT,LT JUMPER REPLACEMENT
764	27-11-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1388	Other Outage	Planned Outage	27-11-2025	10:58	27-11-2025	13:13	2:15	0.001125	3PH HT AB CABLE REPLACEMENT PER SPAN
765	28-11-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1609	Other Outage	Planned Outage	28-11-2025	11:01	28-11-2025	13:33	2:32	0.001267	3PH HT AB CABLE REPLACEMENT
766	28-11-2025	Part of : MOHAN BABA NAGAR,TAJPUR PAHARI VILLAGE,BADARPUR EXTENSION	1864	Other Outage	Planned Outage	28-11-2025	11:19	28-11-2025	13:56	2:37	0.000436	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT
767	29-11-2025	Part of : POCKET G SARITA VIHAR	145	Other Outage	Planned Outage	29-11-2025	13:55	29-11-2025	14:56	1:01	0.002372	INSTALLATION OF BUS BAR
768	29-11-2025	Part of : HARSH VIHAR MOLARBAND	973	Other Outage	Planned Outage	29-11-2025	11:44	29-11-2025	14:40	2:56	0.001956	CONDUCTOR REPLACEMENT PER SPAN
769	29-11-2025	Part of : KHADDA COLONY JAIPUR	1	Other Outage	Planned Outage	29-11-2025	11:35	29-11-2025	13:36	2:01	0.000000	CONDUCTOR REPLACEMENT PER SPAN
770	29-11-2025	Part of : KHADDA COLONY JAIPUR	615	Other Outage	Planned Outage	29-11-2025	11:34	29-11-2025	13:36	2:02	0.000000	INSTALLATION OF BUS BAR
771	01-11-2025	Part of : GHITORNI VILLAGE	39	Other Outage	Planned Outage	01-11-2025	12:52	01-11-2025	14:02	1:10	0.000194	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
772	01-11-2025	Part of : CHRISTIAN COLONY MEHRAULI	202	Other Outage	Planned Outage	01-11-2025	12:50	01-11-2025	14:18	1:28	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
773	01-11-2025	Part of : ROOPAM WALA KUNWA MEHRAULI	965	Other Outage	Planned Outage	01-11-2025	12:53	01-11-2025	14:18	1:25	0.000944	3PH DB REPLACEMENT,LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
774	01-11-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ	63	Other Outage	Planned Outage	01-11-2025	12:48	01-11-2025	15:01	2:13	0.000924	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
775	03-11-2025	PART OF : MAHIPALPUR EXTENSION MAHIPALPUR	644	Other Outage	Planned Outage	03-11-2025	13:58	03-11-2025	16:05	2:07	0.002293	REPLACEMENT OF LT BUSHING ROD
776	03-11-2025	PART OF : SAMALKA,PUSHPANJALI FARMS	2310	Other Outage	Planned Outage	03-11-2025	11:28	03-11-2025	14:20	2:52	0.000717	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER
777	03-11-2025	PART OF : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	863	Other Outage	Planned Outage	03-11-2025	10:19	03-11-2025	13:14	2:55	0.003403	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
778	03-11-2025	PART OF : BLOCK B MAHIPALPUR VILLAGE	453	Other Outage	Planned Outage	03-11-2025	10:36	03-11-2025	13:55	3:19	0.001106	REPLACEMENT OF LT BUSHING ROD
779	03-11-2025	PART OF : POCKET C SECTOR A VASANT KUNJ	182	Other Outage	Planned Outage	03-11-2025	10:41	03-11-2025	14:18	3:37	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
780	03-11-2025	PART OF : DALMIA VIHAR BIJWASAN	273	Other Outage	Planned Outage	03-11-2025	09:44	03-11-2025	11:46	2:02	0.000000	REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
781	04-11-2025	Part of : MEHRAM NAGAR EAST & WEST,POLICE COLONY	2158	Other Outage	Unplanned Outage	04-11-2025	10:56	04-11-2025	11:42	0:46	0.000971	CABLE FAULT
782	04-11-2025	Part of : MOTHER DAIRY MEHRAULI	965	Other Outage	Planned Outage	04-11-2025	15:07	04-11-2025	16:04	0:57	0.000000	PRC REPLACEMENT
783	04-11-2025	Part of : TEACHER COLONY & BRAHMAN MOHALLA MEHRAULI	2964	Other Outage	Planned Outage	04-11-2025	10:13	04-11-2025	13:18	3:05	0.001799	1PH HT AB END TERMINATION REPLACEMENT,3PH HT AB CABLE REPLACEMENT
784	04-11-2025	Part of : KAPAS HERA ESTATE	431	Other Outage	Planned Outage	04-11-2025	10:38	04-11-2025	14:50	4:12	0.004060	CHECKING VALUE OF FENCING EARTHING
785	04-11-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ	153	Other Outage	Planned Outage	04-11-2025	10:26	04-11-2025	13:23	2:57	0.001229	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
786	06-11-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA,	342	Other Outage	Planned Outage	06-11-2025	08:56	06-11-2025	09:18	0:22	0.000354	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
787	06-11-2025	Part of : ANAND GRAM GHITORNI,	4	Other Outage	Planned Outage	06-11-2025	11:08	06-11-2025	13:42	2:34	0.001882	GUARD WIRE LACS INSTALLTION PER SPAN,HT SLEEVE INSTALLATION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
788	06-11-2025	Part of : BLOCK RZ MAHIPALPUR VILLAGE MAHIPALPUR,	181	Other Outage	Planned Outage	06-11-2025	10:58	06-11-2025	13:56	2:58	0.000989	REPLACEMENT OF LT BUSHING ROD
789	06-11-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ,	4	Other Outage	Planned Outage	06-11-2025	10:19	06-11-2025	13:16	2:57	0.002950	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
790	06-11-2025	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ,	160	Other Outage	Planned Outage	06-11-2025	10:44	06-11-2025	13:56	3:12	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
791	06-11-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ,	865	Other Outage	Planned Outage	06-11-2025	11:14	06-11-2025	14:04	2:50	0.000944	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
792	07-11-2025	Part of : BLOCK K MAHIPALPUR VILLAGE	1929	Other Outage	Planned Outage	07-11-2025	13:03	07-11-2025	15:53	2:50	0.004014	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
793	07-11-2025	Part of : POCKET C SECTOR A VASANT KUNJ	144	Other Outage	Planned Outage	07-11-2025	10:45	07-11-2025	13:54	3:09	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
794	07-11-2025	Part of : POCKET 8 SECTOR D VASANT KUNJ	249	Other Outage	Planned Outage	07-11-2025	10:19	07-11-2025	13:19	3:00	0.001000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
795	07-11-2025	Part of : KAPAS HERA EXTENSION	589	Other Outage	Planned Outage	07-11-2025	10:59	07-11-2025	13:06	2:07	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
796	08-11-2025	Part of : POCKET 1 SECTOR B VASANT KUNJ	219	Other Outage	Planned Outage	08-11-2025	10:55	08-11-2025	13:05	2:10	0.001986	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING
797	08-11-2025	Part of : B-BLOCK MAHIPALPUR VILLAGE	563	Other Outage	Planned Outage	08-11-2025	10:28	08-11-2025	14:00	3:32	0.004711	REPLACEMENT OF HT BUSHING ROD
798	08-11-2025	Part of : RAJOKRI VILLAGE	989	Other Outage	Planned Outage	08-11-2025	11:00	08-11-2025	13:09	2:09	0.002078	REPLACEMENT OF HT BUSHING INULATOR
799	08-11-2025	Part of : POCKET 7 SECTOR B VASANT KUNJ	200	Other Outage	Planned Outage	08-11-2025	10:28	08-11-2025	13:22	2:54	0.003383	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
800	10-11-2025	Part of : POCKET 1 SECTOR B VASANT KUNJ,	189	Other Outage	Planned Outage	10-11-2025	10:55	10-11-2025	11:59	1:04	0.000978	PREVENTIVE MAINTENANCE
801	10-11-2025	Part of : RAJOKRI VILLAGE RAJOKRI,	497	Other Outage	Planned Outage	10-11-2025	11:22	10-11-2025	13:22	2:00	0.001933	PREVENTIVE MAINTENANCE
802	10-11-2025	Part of : POCKET 8 SECTOR D VASANT KUNJ,	261	Other Outage	Planned Outage	10-11-2025	10:48	10-11-2025	13:41	2:53	0.001442	PREVENTIVE MAINTENANCE
803	10-11-2025	Part of : BRIJBASI COLONY MEHRAULI,	130	Other Outage	Planned Outage	10-11-2025	10:54	10-11-2025	13:48	2:54	0.000000	PREVENTIVE MAINTENANCE
804	10-11-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA,	514	Other Outage	Planned Outage	10-11-2025	10:37	10-11-2025	12:49	2:12	0.000000	PREVENTIVE MAINTENANCE
805	11-11-2025	Part of : PALAM FARMS	33	Other Outage	Planned Outage	11-11-2025	10:52	11-11-2025	11:19	0:27	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL
806	11-11-2025	Part of : HARIJAN BASTI RAJOKRI	556	Other Outage	Planned Outage	11-11-2025	11:02	11-11-2025	12:32	1:30	0.001450	REPLACEMENT OF HT BUSHING ROD
807	11-11-2025	Part of : BLOCK R MAHIPALPUR VILLAGE	986	Other Outage	Planned Outage	11-11-2025	10:18	11-11-2025	13:55	3:37	0.001507	REPLACEMENT OF LT BUSHING ROD
808	11-11-2025	Part of : POCKET B 10 SECTOR B VASANT KUNJ	226	Other Outage	Planned Outage	11-11-2025	10:30	11-11-2025	13:23	2:53	0.001922	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
809	12-11-2025	Part of : ROOPAM WALA KUNWA & LAKHI NATH KUTI MEHRAULI	1449	Other Outage	Unplanned Outage	12-11-2025	10:17	12-11-2025	10:48	0:31	0.000164	CABLE FAULT
810	12-11-2025	Part of : POCKET 1 SECTOR B VASANT KUNJ	222	Other Outage	Planned Outage	12-11-2025	11:01	12-11-2025	12:59	1:58	0.001475	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
811	12-11-2025	Part of : KHANDSA COLONY MEHRAULI	6	Other Outage	Planned Outage	12-11-2025	10:55	12-11-2025	12:38	1:43	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
812	12-11-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	326	Other Outage	Planned Outage	12-11-2025	11:22	12-11-2025	12:59	1:37	0.000000	LT CIRCUIT MAINTENANCE
813	12-11-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	1175	Other Outage	Planned Outage	12-11-2025	11:43	12-11-2025	14:37	2:54	0.002417	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
814	12-11-2025	Part of : RAJOKRI VILLAGE RAJOKRI	619	Other Outage	Planned Outage	12-11-2025	10:54	12-11-2025	14:45	3:51	0.003465	REPLACEMENT OF HT BUSHING ROD
815	12-11-2025	Part of : PALAM FARMS	18	Other Outage	Planned Outage	12-11-2025	10:39	12-11-2025	13:54	3:15	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
816	13-11-2025	Part of : KAPAS HERA EXTENSION	636	Other Outage	Planned Outage	13-11-2025	15:08	13-11-2025	15:40	0:32	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
817	13-11-2025	Part of : POCKET 1 SECTOR B VASANT KUNJ	122	Other Outage	Planned Outage	13-11-2025	10:55	13-11-2025	12:14	1:19	0.000987	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
818	13-11-2025	Part of : DESU COLONY VASANT KUNJ	149	Other Outage	Planned Outage	13-11-2025	10:56	13-11-2025	13:49	2:53	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
819	13-11-2025	Part of : POCKET 8 SECTOR B VASANT KUNJ	277	Other Outage	Planned Outage	13-11-2025	10:34	13-11-2025	13:32	2:58	0.001978	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
820	13-11-2025	Part of : RAJOKRI VILLAGE	340	Other Outage	Planned Outage	13-11-2025	11:07	13-11-2025	13:08	2:01	0.001949	REPLACEMET OF HT BUSHING ROD
821	13-11-2025	Part of : HARIAN BASTI BIJWASAN	555	Other Outage	Planned Outage	13-11-2025	10:48	13-11-2025	12:57	2:09	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE
822	14-11-2025	Part of : AVENUE BOUGANVILLEA RANGPURI	1	Other Outage	Planned Outage	14-11-2025	15:07	14-11-2025	15:36	0:29	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
823	14-11-2025	Part of : POCKET 1 SECTOR B VASANT KUNJ	191	Other Outage	Planned Outage	14-11-2025	10:50	14-11-2025	13:59	3:09	0.002100	PREVENTIVE MAINTENANCE
824	14-11-2025	Part of : AVENUE BOUGANVILLEA RANGPURI	604	Other Outage	Planned Outage	14-11-2025	11:18	14-11-2025	13:52	2:34	0.000428	PREVENTIVE MAINTENANCE
825	14-11-2025	Part of : AHINSHA ENCLAVE MEHRAULI	503	Other Outage	Planned Outage	14-11-2025	11:22	14-11-2025	13:56	2:34	0.000000	PREVENTIVE MAINTENANCE
826	14-11-2025	Part of : RAJOKRI VILLAGE RAJOKRI	394	Other Outage	Planned Outage	14-11-2025	11:02	14-11-2025	13:26	2:24	0.002320	REPLACEMET OF HT BUSHING ROD
827	14-11-2025	Part of : POCKET 6 SECTOR D VASANT KUNJ	120	Other Outage	Planned Outage	14-11-2025	10:21	14-11-2025	13:15	2:54	0.001208	PREVENTIVE MAINTENANCE
828	14-11-2025	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS	3404	Other Outage	Planned Outage	14-11-2025	10:33	14-11-2025	14:30	3:57	0.000000	CONDUCTOR REPLACEMET
829	15-11-2025	Part of : GANDHI COLONY MEHRAULI,KHANDSA COLONY MEHRAULI,DESU COLONY VASANT KUNJ	3528	Other Outage	Unplanned Outage	15-11-2025	13:50	15-11-2025	14:28	0:38	0.000538	BIRDAGE
830	15-11-2025	Part of : LAKHI NATH KUTI MEHRAULI,ROOPAM WALA KUNWA MEHRAULI	3760	Other Outage	Unplanned Outage	15-11-2025	16:20	15-11-2025	17:06	0:46	0.000767	TREE TRIMMING
831	15-11-2025	Part of : PALAM FARMS	8	Other Outage	Planned Outage	15-11-2025	10:44	15-11-2025	11:16	0:32	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
832	15-11-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA	245	Other Outage	Planned Outage	15-11-2025	10:58	15-11-2025	12:54	1:56	0.001869	REPLACEMENT OF LT BUSHING ROD
833	15-11-2025	Part of : POCKET 1 SECTOR B VASANT KUNJ	190	Other Outage	Planned Outage	15-11-2025	10:50	15-11-2025	14:03	3:13	0.002413	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
834	15-11-2025	Part of : POCKET C SECTOR A VASANT KUNJ	282	Other Outage	Planned Outage	15-11-2025	11:01	15-11-2025	14:27	3:26	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
835	15-11-2025	Part of : AVENUE BOUGANVILLEA RANGPURI	604	Other Outage	Planned Outage	15-11-2025	10:57	15-11-2025	13:57	3:00	0.001250	REPLACEMENT OF LT BUSHING ROD
836	15-11-2025	Part of : POCKET 4 SECTOR C VASANT KUNJ	34	Other Outage	Planned Outage	15-11-2025	10:39	15-11-2025	13:29	2:50	0.002361	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
837	16-11-2025	Part of : DESU COLONY VASANT KUNJ,KHANDSA COLONY & BRIJBASI COLONY MEHRAULI	1813	Other Outage	Unplanned Outage	16-11-2025	12:11	16-11-2025	12:48	0:37	0.000349	CABLE FAULT
838	16-11-2025	Part of : ISLAM COLONY & TEACHER COLONY MEHRAULI	1020	Other Outage	Unplanned Outage	16-11-2025	12:11	16-11-2025	12:45	0:34	0.000633	CABLE FAULT
839	17-11-2025	Part of : POCKET 4 SECTOR D VASANT KUNJ	242	Other Outage	Planned Outage	17-11-2025	10:38	17-11-2025	12:15	1:37	0.001213	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
840	17-11-2025	Part of : SECTOR D VASANT KUNJ	179	Other Outage	Planned Outage	17-11-2025	10:57	17-11-2025	13:07	2:10	0.000361	3PH DB REPLACEMENT,AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
841	17-11-2025	Part of : SECTOR D VASANT KUNJ	193	Other Outage	Planned Outage	17-11-2025	10:45	17-11-2025	13:40	2:55	0.001215	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
842	17-11-2025	Part of : BRIJBASI COLONY MEHRAULI	140	Other Outage	Planned Outage	17-11-2025	10:43	17-11-2025	14:09	3:26	0.000000	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
843	18-11-2025	Part of : WEST END GREENS RANGPURI,AVENUE BOUGANVILLEA RANGPURI	123	Other Outage	Unplanned Outage	18-11-2025	22:25	18-11-2025	22:54	0:29	0.000306	CABLE FAULT
844	18-11-2025	Part of : BLOCK B MAHIPALPUR VILLAGE MAHIPALPUR,RANGPURI,AVENUE BOUGANVILLEA RANGPURI,MAHIPALPUR VILLAGE MAHIPALPUR,MAHIPALPUR EXTENSION MAHIPALPUR,RANGPURI NALLAPAR RANGPURI,KHANDSA COLONY MEHRAULI,AVENUE BOUGANVILLEA RANGPURI,SETH SARAI MEHRAULI WEST END GRFFNS RANGPURI	123	Other Outage	Unplanned Outage	18-11-2025	11:55	18-11-2025	12:41	0:46	0.000537	TREE TOUCHING
845	18-11-2025	Part of : POCKET 4 SECTOR D VASANT KUNJ,	172	Other Outage	Planned Outage	18-11-2025	10:48	18-11-2025	12:50	2:02	0.001525	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
846	18-11-2025	Part of : SAMALKA,	307	Other Outage	Planned Outage	18-11-2025	10:57	18-11-2025	13:25	2:28	0.003494	REPLACEMET OF HT BUSHING ROD
847	18-11-2025	Part of : MAHIPALPUR EXTENSION MAHIPALPUR,	1003	Other Outage	Planned Outage	18-11-2025	10:23	18-11-2025	13:57	3:34	0.001189	REPLACEMENT OF LT BUSHING ROD
848	18-11-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA,	1118	Other Outage	Planned Outage	18-11-2025	11:29	18-11-2025	14:21	2:52	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMET OF HT BUSHING ROD
849	18-11-2025	Part of : POCKET 4 SECTOR C VASANT KUNJ,	65	Other Outage	Planned Outage	18-11-2025	10:28	18-11-2025	13:24	2:56	0.001956	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
850	18-11-2025	Part of : ISLAM COLONY MEHRAULI,POCKET A SECTOR A VASANT KUNJ,KALKA DASS MEHRAULI,	3116	Other Outage	Planned Outage	18-11-2025	10:08	18-11-2025	12:26	2:18	0.001227	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT,ST.TH JOINT ON 3PH HT AB
851	18-11-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA,	389	Other Outage	Planned Outage	18-11-2025	10:15	18-11-2025	14:18	4:03	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLAINING OF HT/LT BUSHINGS (DRY DT)
852	19-11-2025	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ,POCKET C SECTOR A VASANT KUNJ	1726	Other Outage	Unplanned Outage	19-11-2025	19:43	19-11-2025	20:21	0:38	0.000317	CABLE FAULT
853	19-11-2025	Part of : PUSHPANJALI FARMS	9	Other Outage	Planned Outage	19-11-2025	10:49	19-11-2025	12:47	1:58	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
854	19-11-2025	Part of : DALMIA VIHAR BIJWASAN	273	Other Outage	Planned Outage	19-11-2025	10:49	19-11-2025	12:13	1:24	0.000000	REPLACEMENT OF HT BUSHING ROD
855	19-11-2025	Part of : ISLAM COLONY MEHRAULI	399	Other Outage	Planned Outage	19-11-2025	10:33	19-11-2025	12:22	1:49	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
856	19-11-2025	Part of : POCKET 4 SECTOR D VASANT KUNJ	91	Other Outage	Planned Outage	19-11-2025	10:41	19-11-2025	13:37	2:56	0.001956	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
857	19-11-2025	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	902	Other Outage	Planned Outage	19-11-2025	10:20	19-11-2025	13:15	2:55	0.003889	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
858	19-11-2025	Part of : BLOCK L MAHIPALPUR VILLAGE	548	Other Outage	Planned Outage	19-11-2025	10:55	19-11-2025	13:55	3:00	0.000500	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
859	19-11-2025	Part of : PUSHANJALI FARMS	269	Other Outage	Planned Outage	19-11-2025	10:54	19-11-2025	13:24	2:30	0.002417	REPLACEMENT OF HT BUSHING ROD
860	20-11-2025	Part of : ASSET NO.-10 & 11 AEROCITY, ASPEN BUILDTECH, BIRD HOTEL (HT CONSUMER)	0	Other Outage	Unplanned Outage	20-11-2025	00:32	20-11-2025	00:58	0:26	0.000383	CABLE FAULT
861	20-11-2025	Part of : RANGPURI NALLAPAR, MAHIPALPUR VILLAGE	1159	Other Outage	Unplanned Outage	20-11-2025	15:10	20-11-2025	15:56	0:46	0.000294	CABLE FAULT
862	20-11-2025	Part of : PUSHANJALI FARMS	11	Other Outage	Planned Outage	20-11-2025	11:18	20-11-2025	12:04	0:46	0.000000	REPLACEMENT OF HT BUSHING ROD
863	20-11-2025	Part of : PUSHANJALI FARMS	11	Other Outage	Planned Outage	20-11-2025	11:02	20-11-2025	13:49	2:47	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
864	20-11-2025	Part of : POCKET 4 SECTOR C VASANT KUNJ	68	Other Outage	Planned Outage	20-11-2025	10:42	20-11-2025	13:39	2:57	0.001967	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
865	20-11-2025	Part of : SAMALKA	561	Other Outage	Planned Outage	20-11-2025	11:12	20-11-2025	13:29	2:17	0.002207	REPLACEMENT OF HT BUSHING ROD
866	20-11-2025	Part of : LAKHI NATH KUTI MEHRAULI	175	Other Outage	Planned Outage	20-11-2025	10:44	20-11-2025	13:45	3:01	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER, CHECKING VALUE OF FENCING EARTHING
867	20-11-2025	Part of : POCKET 4 SECTOR D VASANT KUNJ	267	Other Outage	Planned Outage	20-11-2025	09:58	20-11-2025	12:39	2:41	0.002013	APPLY OF INSULATION TAPE HT/LT BUSHINGS, CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
868	21-11-2025	Part of : GANDHI COLONY MEHRAULI, ISLAM COLONY, KHANDSA COLONY MEHRAULI, DESU COLONY VASANT KUNJ	3542	Other Outage	Unplanned Outage	21-11-2025	07:22	21-11-2025	07:46	0:24	0.000460	TREE TOUCHING
869	21-11-2025	Part of : POCKET 4 SECTOR D VASANT KUNJ	68	Other Outage	Planned Outage	21-11-2025	14:33	21-11-2025	16:07	1:34	0.001175	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS, MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES), REPLACEMENT OF SILICAGEL IN BREATHER, REPLACEMENT OF HT/LT CLEATS, SUB STATION CLEANING, TIGHTENEING OF NUT BOLT
870	21-11-2025	Part of : ANAND GRAM GHITORNI, GHITORNI VILLAGE	118	Other Outage	Planned Outage	21-11-2025	11:41	21-11-2025	13:04	1:23	0.000346	CONDUCTOR REPLACEMENT PER SPAN, GUARD WIRES SAGGING PER SPAN
871	21-11-2025	Part of : POCKET 3 SECTOR D VASANT KUNJ	212	Other Outage	Planned Outage	21-11-2025	10:25	21-11-2025	12:10	1:45	0.000438	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS, INSTALLATION OF BUS BAR, OIL TOP UP IN TRANSFORMER , OIL TOP UP IN TRANSFORMER
872	21-11-2025	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ	120	Other Outage	Planned Outage	21-11-2025	12:05	21-11-2025	15:07	3:02	0.000000	INSTALLATION OF PHASE SEPARATOR PER SPAN, JUMPER REPLACEMENT PER POLE, LT AB SAGGING PER SPAN, PRC REPLACEMENT PER FEEDER
873	21-11-2025	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	534	Other Outage	Planned Outage	21-11-2025	10:24	21-11-2025	13:18	2:54	0.003867	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
874	21-11-2025	Part of : DESU COLONY VASANT KUNJ	80	Other Outage	Planned Outage	21-11-2025	10:14	21-11-2025	13:47	3:33	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER, CHECKING VALUE OF FENCING EARTHING, DT OIL SAMPLING TO CHECK BDV VALUE, GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT), OIL TOP UP IN TRANSFORMER , OIL TOP UP IN TRANSFORMER , REPLACEMENT OF SILICAGEL IN BREATHER, SUB STATION CLEANING, TIGHTENEING OF NUT BOLT
875	22-11-2025	Part of : RUCHI VIHAR VASANT KUNJ, BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ, SECTOR D VASANT KUNJ, IAA COLONY SECTOR D VASANT KUNJ	2958	Other Outage	Unplanned Outage	22-11-2025	23:31	23-11-2025	00:13	0:42	0.000000	CABLE FAULT
876	22-11-2025	Part of : SECTOR D VASANT KUNJ,	114	Other Outage	Planned Outage	22-11-2025	14:19	22-11-2025	15:57	1:38	0.000408	APPLY OF INSULATION TAPE HT/LT BUSHINGS, REPLACEMENT OF GAS KIT AND OIL SEAL
877	22-11-2025	Part of : SAMALKA,	484	Other Outage	Planned Outage	22-11-2025	10:58	22-11-2025	12:27	1:29	0.001434	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
878	22-11-2025	Part of : CHRISTIAN COLONY MEHRAULI,	355	Other Outage	Planned Outage	22-11-2025	10:53	22-11-2025	14:09	3:16	0.000817	CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
879	22-11-2025	Part of : POCKET 5 SECTOR C VASANT KUNJ,	215	Other Outage	Planned Outage	22-11-2025	10:42	22-11-2025	13:41	2:59	0.001989	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT)
880	22-11-2025	Part of : MEHRAM NAGAR EAST MEHRAM NAGAR,	923	Other Outage	Planned Outage	22-11-2025	10:31	22-11-2025	13:29	2:58	0.000989	REPLACEMENT OF LT BUSHING ROD
881	22-11-2025	Part of : POCKET 3 SECTOR D VASANT KUNJ,	173	Other Outage	Planned Outage	22-11-2025	10:02	22-11-2025	12:54	2:52	0.002150	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
882	24-11-2025	Part of : SAMALKA,PUSHPANJALI FARMS	2313	Other Outage	Planned Outage	24-11-2025	13:09	24-11-2025	13:47	0:38	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
883	24-11-2025	Part of : GHITORNI VILLAGE	856	Other Outage	Planned Outage	24-11-2025	12:54	24-11-2025	14:32	1:38	0.002178	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOT
884	24-11-2025	Part of : POCKET 2 SECTOR D VASANT KUNJ	107	Other Outage	Planned Outage	24-11-2025	10:25	24-11-2025	12:12	1:47	0.001338	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF LUGS,SUB STATION CLEANING
885	24-11-2025	Part of : PUSHPANJALI FARMS	9	Other Outage	Planned Outage	24-11-2025	10:58	24-11-2025	13:04	2:06	0.000000	REPLACEMENT OF HT BUSHING ROD
886	24-11-2025	Part of : RUCHI VIHAR VASANT KUNJ	358	Other Outage	Planned Outage	24-11-2025	10:21	24-11-2025	13:20	2:59	0.003978	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
887	24-11-2025	Part of : SAMALKA	33	Other Outage	Planned Outage	24-11-2025	11:06	24-11-2025	13:10	2:04	0.001998	REPLACEMENT OF HT BUSHING ROD
888	25-11-2025	Part of : RAJOKRI VILLAGE	992	Other Outage	Planned Outage	25-11-2025	14:04	25-11-2025	14:22	0:18	0.000100	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
889	25-11-2025	Part of : KAPAS HERA EXTENSION	478	Other Outage	Planned Outage	25-11-2025	10:48	25-11-2025	13:26	2:38	0.002546	REPLACEMET OF HT BUSHING ROD
890	25-11-2025	Part of : POCKET 3 SECTOR C VASANT KUNJ	212	Other Outage	Planned Outage	25-11-2025	10:51	25-11-2025	13:37	2:46	0.001844	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
891	25-11-2025	Part of : ROOPAM WALA KUNWA MEHRAULI	965	Other Outage	Planned Outage	25-11-2025	10:40	25-11-2025	13:06	2:26	0.001622	1PH DB REPLACEMENT,LT AB SAGGING PER SPAN
892	26-11-2025	Part of : SLASH PUR VILLAGE PALAM FARMS,PALAM FARMS	3436	Other Outage	Unplanned Outage	26-11-2025	09:40	26-11-2025	09:48	0:08	0.000211	TREE BRANCH FALLING ON O/H HT LINE
893	26-11-2025	Part of : RANGPURI,	1105	Other Outage	Planned Outage	26-11-2025	13:00	26-11-2025	13:56	0:56	0.000311	REPLACEMENT OF LT BUSHING ROD
894	26-11-2025	Part of : KAPAS HERA ESTATE,	219	Other Outage	Planned Outage	26-11-2025	10:31	26-11-2025	14:34	4:03	0.003915	REPLACEMET OF HT BUSHING ROD
895	26-11-2025	Part of : LAKHI NATH KUTI MEHRAULI,	482	Other Outage	Planned Outage	26-11-2025	10:49	26-11-2025	13:27	2:38	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
896	26-11-2025	Part of : RUCHI VIHAR VASANT KUNJ,IAA COLONY SECTOR D VASANT KUNJ,	7	Other Outage	Planned Outage	26-11-2025	10:30	26-11-2025	13:24	2:54	0.002417	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
897	26-11-2025	Part of : POCKET 2 SECTOR D VASANT KUNJ,	322	Other Outage	Planned Outage	26-11-2025	10:27	26-11-2025	12:46	2:19	0.001738	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF HT BOOTS,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
898	27-11-2025	Part of : AVENUE BOUGANVILLEA RANGPURI,WEST END GREENS RANGPURI,HARIJAN BASTI RAJOKRI,AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	223	Other Outage	Unplanned Outage	27-11-2025	15:58	27-11-2025	16:35	0:37	0.000000	TREE TOUCHING
899	27-11-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA	344	Other Outage	Planned Outage	27-11-2025	11:01	27-11-2025	12:05	1:04	0.001031	REPLACEMENT OF LT BUSHING ROD
900	27-11-2025	Part of : POCKET 1 SECTOR D VASANT KUNJ	198	Other Outage	Planned Outage	27-11-2025	10:19	27-11-2025	12:08	1:49	0.001363	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING
901	27-11-2025	Part of : INDIRA GANDHI INTERNATIONAL AIRPORT	5	Other Outage	Planned Outage	27-11-2025	10:37	27-11-2025	13:51	3:14	0.001347	REPLACEMENT OF LT BUSHING ROD
902	27-11-2025	Part of : POCKET C SECTOR A VASANT KUNJ	40	Other Outage	Planned Outage	27-11-2025	10:39	27-11-2025	13:33	2:54	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
903	27-11-2025	Part of : POCKET 3 SECTOR C VASANT KUNJ	25	Other Outage	Planned Outage	27-11-2025	10:28	27-11-2025	13:17	2:49	0.001878	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
904	27-11-2025	Part of : PUSHSPANJALI FARMS	117	Other Outage	Planned Outage	27-11-2025	10:24	27-11-2025	12:33	2:09	0.000000	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER,CONDUCTOR REPLACEMENT PER SPAN
905	28-11-2025	Part of : KAPAS HERA EXTENSION,PUSHSPANJALI FARMS,PALAM FARMS	1872	Other Outage	Planned Outage	28-11-2025	10:35	28-11-2025	12:17	1:42	0.000000	BIRD SPIKES INSTALLATION PER POLE,GUARD WIRE LACS INSTALLTION
906	28-11-2025	Part of : KISHANGARH VILLAGE SECTOR A VASANT KUNJ	120	Other Outage	Planned Outage	28-11-2025	13:58	28-11-2025	16:26	2:28	0.000822	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLAINING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
907	28-11-2025	Part of : GHITORNI VILLAGE	305	Other Outage	Planned Outage	28-11-2025	12:20	28-11-2025	14:41	2:21	0.003525	3PH DB REPLACEMENT,INSTALLATION OF PHASE SEPERATOR
908	28-11-2025	Part of : SECTOR D VASANT KUNJ	179	Other Outage	Planned Outage	28-11-2025	11:21	28-11-2025	14:02	2:41	0.000671	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
909	28-11-2025	Part of : MEHRAULI VILLAGE	281	Other Outage	Planned Outage	28-11-2025	11:04	28-11-2025	14:03	2:59	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
910	28-11-2025	Part of : RUCHI VIHAR VASANT KUNJ	291	Other Outage	Planned Outage	28-11-2025	10:34	28-11-2025	13:31	2:57	0.003933	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
911	28-11-2025	Part of : KAPAS HERA EXTENSION	467	Other Outage	Planned Outage	28-11-2025	10:59	28-11-2025	13:18	2:19	0.002239	REPLACEMENT OF HT BUSHING ROD
912	29-11-2025	Part of : LAKHI NATH KUTI MEHRAULI,ROOPAM WALA KUNWA MEHRAULI	3769	Other Outage	Planned Outage	29-11-2025	13:38	29-11-2025	14:28	0:50	0.000556	BIRD SPIKES INSTALLATION PER POLE,CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMENT PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING,JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
913	29-11-2025	Part of : BLOCK RZ MAHIPALPUR VILLAGE	199	Other Outage	Planned Outage	29-11-2025	11:47	29-11-2025	14:55	3:08	0.001044	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
914	29-11-2025	Part of : KAPAS HERA EXTENSION	465	Other Outage	Planned Outage	29-11-2025	11:08	29-11-2025	13:27	2:19	0.002239	REPLACEMET OF HT BUSHING ROD
915	29-11-2025	Part of : GHITORNI VILLAGE	219	Other Outage	Planned Outage	29-11-2025	11:05	29-11-2025	13:12	2:07	0.003175	3PH DB REPLACEMENT,INSTALLATION OF PHASE SEPERATOR PER SPAN
916	29-11-2025	Part of : ROOPAM WALA KUNWA MEHRAULI,LAKHI NATH KUTI MEHRAULI	2826	Other Outage	Planned Outage	29-11-2025	10:00	29-11-2025	13:41	3:41	0.002456	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMET PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING,GUARD WIRES SAGGING PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
917	03-11-2025	PART OF : SECTOR 4 DWARKA	106	Other Outage	Planned Outage	03-11-2025	10:19	03-11-2025	12:49	2:30	0.000000	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS
918	04-11-2025	Part of : POCKET 3 SECTOR 19 DWARKA	87	Other Outage	Unplanned Outage	04-11-2025	11:20	04-11-2025	12:13	0:53	0.000029	BIRDAGE
919	04-11-2025	Part of : POCKET 1 & 2 SECTOR 2 DWARKA,ADARSH APARTMENT MADHU VIHAR	1514	Other Outage	Unplanned Outage	04-11-2025	13:42	04-11-2025	14:47	1:05	0.000000	INSTALLATION OF ADDITIONAL TRANSFORMER
920	04-11-2025	Part of : SUKH RAM PARK MATIALA	1056	Other Outage	Unplanned Outage	04-11-2025	15:07	04-11-2025	17:36	2:29	0.000000	DT METER/CT REPLACEMENT
921	04-11-2025	Part of : SECTOR 13 DWARKA	145	Other Outage	Planned Outage	04-11-2025	13:43	04-11-2025	14:28	0:45	0.000000	INSTALLATION OF HT BOOTS
922	06-11-2025	Part of : RAJU ENCLAVE SECTOR 15 DWARKA,HARI VIHAR SECTOR 15 DWARKA,SECTOR 13 DWARKA,HARI VIHAR SECTOR 16A DWARKA,BLOCK B PATEL GARDEN SECTOR 15 DWARKA,SURAJ VIHAR DWARKA,CHANDAN PARK DWARKA,BLOCK RZ PATEL GARDEN EXTENTION SECTOR 15 DWARKA,BLOCK WZ PATEL GARDEN EXTENTION SECTOR 15 DWARKA,BAJAJ ENCLAVE SECTOR 15 DWARKA,	4498	Other Outage	Unplanned Outage	06-11-2025	12:25	06-11-2025	14:15	1:50	0.000000	JOINTING OF HT CABLE
923	06-11-2025	Part of : D-BLOCK MADHU VIHAR,	730	Other Outage	Planned Outage	06-11-2025	15:25	06-11-2025	16:06	0:41	0.000000	REPLACEMENT OF LT BUSHING ROD
924	07-11-2025	Part of : GURPREET NAGAR MATIALA	1548	Other Outage	Unplanned Outage	07-11-2025	20:48	07-11-2025	21:16	0:28	0.000117	CABLE FAULT
925	07-11-2025	Part of : BLOCK A RAJAPURI MATIALA,SECTOR 3 DWARKA	1887	Other Outage	Unplanned Outage	07-11-2025	18:17	07-11-2025	19:00	0:43	0.000681	FAULT IN HT CONSUMER PANEL (AKASH HOSPITAL)
926	07-11-2025	Part of : JAIN COLONY MATIALA,BLOCK C UTTAM VIHAR BINDAPUR	2816	Other Outage	Unplanned Outage	07-11-2025	13:53	07-11-2025	14:46	0:53	0.000250	HVDS FAULT
927	07-11-2025	Part of : POCKET 4 SECTOR 16B DWARKA	800	Other Outage	Planned Outage	07-11-2025	14:13	07-11-2025	16:20	2:07	0.000000	DT REPLACEMENT
928	08-11-2025	Part of : TRANSIT CAMP,BHARAT VIHAR,POCKET 1 SECTOR 14 DWARKA	2230	Other Outage	Unplanned Outage	08-11-2025	15:35	08-11-2025	16:27	0:52	0.000376	HVDS FAULT
929	08-11-2025	Part of : DDA FLATS SEC-14 DWARKA,BHARAT VIHAR,SARV PRIYA CGHS	0	Other Outage	Unplanned Outage	08-11-2025	09:01	08-11-2025	09:51	0:50	0.000042	CABLE FAULT
930	08-11-2025	Part of : D-BLOCK UTTAM VIHAR BINDAPUR	401	Other Outage	Planned Outage	08-11-2025	11:23	08-11-2025	12:28	1:05	0.000000	LT CIRCUIT MAINTENANCE WORK
931	10-11-2025	Part of : SECTOR 3 DWARKA	1200	Other Outage	Unplanned Outage	10-11-2025	01:50	10-11-2025	02:36	0:46	0.000294	CABLE FAULT
932	10-11-2025	Part of : TRANSIT CAMP DWARKA,VIKAS NAGAR SECTOR 15 DWARKA,RAJU PARAK EXTENSION DWARKA,TARA NAGAR DWARKA,BHARAT VIHAR DWARKA	6558	Other Outage	Unplanned Outage	10-11-2025	00:05	10-11-2025	00:44	0:39	0.000119	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
933	11-11-2025	Part of : NISHAT PARK SECTOR 15 DWARKA,BLOCK A & WZ PATEL GARDEN SECTOR 15 DWARKA,SURAJ VIHAR DWARKA	3825	Other Outage	Unplanned Outage	11-11-2025	23:43	12-11-2025	00:47	1:04	0.000907	CABLE FAULT
934	11-11-2025	Part of : SECTOR 10 DWARKA	6	Other Outage	Planned Outage	11-11-2025	14:24	11-11-2025	16:08	1:44	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
935	12-11-2025	Part of : POCKET 4 SECTOR 16B DWARKA	186	Other Outage	Planned Outage	12-11-2025	14:41	12-11-2025	14:50	0:09	0.000000	REPLACEMENT OF LUGS
936	13-11-2025	Part of : SECTOR 13 DWARKA	108	Other Outage	Planned Outage	13-11-2025	11:19	13-11-2025	11:50	0:31	0.000000	REPLACEMENT OF HT BUSHING INULATOR
937	13-11-2025	Part of : HARI VIHAR SECTOR 16A DWARKA	808	Other Outage	Planned Outage	13-11-2025	14:29	13-11-2025	15:25	0:56	0.000000	ACB REPLACEMENT PER ACB
938	14-11-2025	Part of : JAIN COLONY MATIALA,BLOCK C UTTAM VIHAR BINDAPUR	2820	Other Outage	Unplanned Outage	14-11-2025	11:19	14-11-2025	12:15	0:56	0.000669	CABLE FAULT
939	14-11-2025	Part of : SECTOR 13 DWARKA	263	Other Outage	Planned Outage	14-11-2025	11:32	14-11-2025	11:55	0:23	0.000000	REPLACEMET OF HT BUSHING ROD
940	15-11-2025	Part of : SECTOR 11 DWARKA,POCKET 1 SECTOR-5 MARKET SECTOR 5 DWARKA,SECTOR 5 DWARKA,POCKET 1 SECTOR 11 DWARKA	2136	Other Outage	Unplanned Outage	15-11-2025	18:13	15-11-2025	19:27	1:14	0.001439	HT SYSTEM FAULT
941	15-11-2025	Part of : SECTOR 13 DWARKA	397	Other Outage	Planned Outage	15-11-2025	11:27	15-11-2025	11:54	0:27	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
942	17-11-2025	Part of : POCKET B SECTOR 13 DWARKA	245	Other Outage	Planned Outage	17-11-2025	10:06	17-11-2025	10:43	0:37	0.000000	INSTALLATION OF HT BOOTS
943	17-11-2025	Part of : JAIN COLONY MATIALA,BLOCK G JAIN COLONY MATIALA	4502	Other Outage	Planned Outage	17-11-2025	10:50	17-11-2025	13:01	2:11	0.000000	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
944	18-11-2025	Part of : BHARAT VIHAR DWARKA,TRANSIT CAMP DWARKA,	3555	Other Outage	Unplanned Outage	18-11-2025	11:48	18-11-2025	13:32	1:44	0.000000	REPAIRING OF HVDS CIRCUIT
945	18-11-2025	Part of : POCKET B SECTOR 13 DWARKA,	197	Other Outage	Planned Outage	18-11-2025	13:49	18-11-2025	14:25	0:36	0.000000	INSTALLATION OF HT BOOTS
946	19-11-2025	Part of : BLOCK RZ A MADHU VIHAR,C-BLOCK MADHU VIHAR,BLOCK RZ MADHU VIHAR	1175	Other Outage	Unplanned Outage	19-11-2025	11:23	19-11-2025	12:57	1:34	0.000000	REPAIRING OF HVDS CIRCUIT
947	19-11-2025	Part of : POCKET 1 SECTOR 2 DWARKA	59	Other Outage	Planned Outage	19-11-2025	14:25	19-11-2025	15:19	0:54	0.000000	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
948	19-11-2025	Part of : POCKET E SECTOR 17 DWARKA	390	Other Outage	Planned Outage	19-11-2025	10:33	19-11-2025	12:33	2:00	0.000000	DT REPLACEMENT
949	21-11-2025	Part of : IGL CNG STATION SEC-18 DWARKA (HTC), NHAI HOUSING SOCIETY B-5 SEC-17 DWARKA (HTC), N. K. BAGRODIA DWARKA SEC-17 DWARKA (HTC)	0	Other Outage	Unplanned Outage	21-11-2025	20:16	21-11-2025	20:48	0:32	0.000080	FAULT IN HT CONSUMER PANEL (CNG PUMP)
950	22-11-2025	Part of : MAHAVIR ENCLAVE PART 3 MAHAVIR ENCLAVE	4295	Other Outage	Unplanned Outage	22-11-2025	15:07	22-11-2025	15:52	0:45	0.000475	CABLE FAULT
951	23-11-2025	Part of : SECTOR 13 DWARKA,BHARAT VIHAR DWARKA,RAJU PARAK EXTENSION DWARKA	3166	Other Outage	Unplanned Outage	23-11-2025	15:40	23-11-2025	16:21	0:41	0.000034	BIRDAGE
952	23-11-2025	Part of : POCKET 2 SECTOR 19 DWARKA,POCKET 1 SECTOR 19 DWARKA,POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA,POCKET 3 SECTOR 19 DWARKA,SECTOR 19 DWARKA	3115	Other Outage	Unplanned Outage	23-11-2025	02:43	23-11-2025	04:11	1:28	0.000660	CABLE FAULT
953	24-11-2025	Part of : ISHWAR APPTT. PLOT-4 SEC-12 DWARKA	1	Other Outage	Planned Outage	24-11-2025	10:17	24-11-2025	11:14	0:57	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT)
954	24-11-2025	Part of : JAIN COLONY,C & D-BLOCK UTTAM VIHAR,A & B-BLOCK BHARAT NAGAR MADHU VIHAR,B-BLOCK RAJAPURI MATIALA	2563	Other Outage	Planned Outage	24-11-2025	11:23	24-11-2025	12:50	1:27	0.000000	DB REVAMPING,HT BUSHING ROD REPLACEMENT
955	26-11-2025	Part of : POCKET 2 SECTOR 19 DWARKA,POCKET 1 SECTOR 19 DWARKA,POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA,POCKET 3 SECTOR 19 DWARKA,SECTOR 19 DWARKA	3120	Other Outage	Unplanned Outage	26-11-2025	13:46	26-11-2025	14:27	0:41	0.000080	HT SYSTEM FAULT
956	27-11-2025	Part of : POCKET 1 SECTOR 4 DWARKA,POCKET 1 SECTOR-5 MARKET SECTOR 5 DWARKA	919	Other Outage	Unplanned Outage	27-11-2025	12:33	27-11-2025	14:19	1:46	0.000000	REPAIRING OF HVDS CIRCUIT
957	01-11-2025	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	2328	Other Outage	Planned Outage	01-11-2025	15:59	01-11-2025	16:59	1:00	0.000833	REPLACEMET OF HT BUSHING ROD
958	01-11-2025	Part of : MANDHELA KALAN VILLAGE	3	Other Outage	Planned Outage	01-11-2025	14:34	01-11-2025	16:02	1:28	0.001222	REPLACEMET OF HT BUSHING ROD
959	01-11-2025	Part of : SARANGPUR VILLAGE	462	Other Outage	Planned Outage	01-11-2025	13:08	01-11-2025	15:01	1:53	0.001569	REPLACEMET OF HT BUSHING ROD
960	01-11-2025	Part of : SAMAZPUR KHALSA	359	Other Outage	Planned Outage	01-11-2025	13:07	01-11-2025	15:00	1:53	0.001569	REPLACEMET OF HT BUSHING ROD
961	01-11-2025	Part of : SHYAM ENCAVE NAJAFGARH	309	Other Outage	Planned Outage	01-11-2025	13:47	01-11-2025	16:42	2:55	0.002431	REPLACEMET OF HT BUSHING ROD
962	03-11-2025	PART OF : MANDHELA KALAN VILLAGE,KAIR VILLAGE	409	Other Outage	Planned Outage	03-11-2025	11:57	03-11-2025	14:22	2:25	0.002014	REPLACEMET OF HT BUSHING ROD
963	03-11-2025	PART OF : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	1051	Other Outage	Planned Outage	03-11-2025	11:51	03-11-2025	14:47	2:56	0.002444	REPLACEMET OF HT BUSHING ROD
964	03-11-2025	PART OF : BADHOSRA	7	Other Outage	Planned Outage	03-11-2025	10:58	03-11-2025	13:13	2:15	0.001875	REPLACEMET OF HT BUSHING ROD
965	03-11-2025	PART OF : KHERA DABAS VILLAGE	336	Other Outage	Planned Outage	03-11-2025	11:02	03-11-2025	13:43	2:41	0.002236	REPLACEMET OF HT BUSHING ROD
966	04-11-2025	Part of : JAIN PUR VILLAGE	272	Other Outage	Planned Outage	04-11-2025	13:59	04-11-2025	16:50	2:51	0.001900	REPLACEMENT OF HT BUSHING ROD
967	04-11-2025	Part of : QAZIPUR VILLAGE	9	Other Outage	Planned Outage	04-11-2025	11:00	04-11-2025	13:37	2:37	0.001744	REPLACEMENT OF HT BUSHING ROD
968	04-11-2025	Part of : NANU RAM PARK NAJAFGARH	590	Other Outage	Planned Outage	04-11-2025	11:02	04-11-2025	13:56	2:54	0.001933	REPLACEMENT OF HT BUSHING ROD
969	04-11-2025	Part of : MITRAON VILLAGE NAJAFGARH	485	Other Outage	Planned Outage	04-11-2025	11:01	04-11-2025	13:55	2:54	0.001933	REPLACEMENT OF HT BUSHING ROD
970	06-11-2025	Part of : KAIR VILLAGE	28	Other Outage	Unplanned Outage	06-11-2025	11:53	06-11-2025	12:43	0:50	0.000014	TREE BRANCH FALLING ON O/H HT LINE
971	06-11-2025	Part of : KRISHAN VIHAR NAJAFGARH,	1	Other Outage	Planned Outage	06-11-2025	10:57	06-11-2025	13:55	2:58	0.002967	REPLACEMENT OF LT BUSHING ROD
972	06-11-2025	Part of : DHANSA VILLAGE,	15	Other Outage	Planned Outage	06-11-2025	11:06	06-11-2025	13:39	2:33	0.003400	REPLACEMENT OF LT BUSHING ROD
973	06-11-2025	Part of : MALIKPUR ZER VILLAGE,	399	Other Outage	Planned Outage	06-11-2025	11:01	06-11-2025	13:45	2:44	0.002733	REPLACEMENT OF HT BUSHING ROD
974	06-11-2025	Part of : SRI HANS NAGAR,	501	Other Outage	Planned Outage	06-11-2025	10:58	06-11-2025	13:53	2:55	0.003889	REPLACEMENT OF LT BUSHING ROD
975	07-11-2025	Part of : SUREHRA VILLAGE,MITRAON VILLAGE NAJAFGARH	544	Other Outage	Unplanned Outage	07-11-2025	10:26	07-11-2025	10:58	0:32	0.000356	HVDS FAULT
976	07-11-2025	Part of : SARANGPUR VILLAGE	9	Other Outage	Planned Outage	07-11-2025	14:04	07-11-2025	14:49	0:45	0.001000	REPLACEMET OF HT BUSHING ROD
977	07-11-2025	Part of : SARSWATI ENCLAVE GOPAL NAGAR NAJAFGARH	602	Other Outage	Planned Outage	07-11-2025	14:06	07-11-2025	16:13	2:07	0.002822	REPLACEMET OF HT BUSHING ROD
978	07-11-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1398	Other Outage	Planned Outage	07-11-2025	11:01	07-11-2025	13:59	2:58	0.002967	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
979	07-11-2025	Part of : KAIR VILLAGE	1	Other Outage	Planned Outage	07-11-2025	11:18	07-11-2025	13:21	2:03	0.002050	REPLACEMENT OF LT BUSHING ROD
980	08-11-2025	Part of : MITRAON VILLAGE NAJAFGARH	305	Other Outage	Planned Outage	08-11-2025	13:07	08-11-2025	14:58	1:51	0.001542	REPLACEMENT OF HT BUSHING ROD
981	08-11-2025	Part of : BAQAR GARH VILLAGE	1	Other Outage	Planned Outage	08-11-2025	11:18	08-11-2025	13:12	1:54	0.001583	REPLACEMENT OF HT BUSHING ROD
982	08-11-2025	Part of : JAFARPUR KALAN VILLAGE	248	Other Outage	Planned Outage	08-11-2025	11:09	08-11-2025	13:14	2:05	0.001736	REPLACEMENT OF HT BUSHING ROD
983	08-11-2025	Part of : HAIBUTPUR	663	Other Outage	Planned Outage	08-11-2025	11:05	08-11-2025	13:13	2:08	0.001778	REPLACEMENT OF HT BUSHING ROD
984	10-11-2025	Part of : SAMAZPUR KHALSA,	293	Other Outage	Planned Outage	10-11-2025	15:37	10-11-2025	16:45	1:08	0.000944	PREVENTIVE MAINTENANCE
985	10-11-2025	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN,	667	Other Outage	Planned Outage	10-11-2025	12:53	10-11-2025	15:40	2:47	0.002319	PREVENTIVE MAINTENANCE
986	10-11-2025	Part of : GHUMAN HERA JAINPUR VILLAGE,	247	Other Outage	Planned Outage	10-11-2025	11:02	10-11-2025	13:36	2:34	0.002139	PREVENTIVE MAINTENANCE
987	10-11-2025	Part of : QAZIPUR VILLAGE,	2	Other Outage	Planned Outage	10-11-2025	10:58	10-11-2025	13:56	2:58	0.002472	PREVENTIVE MAINTENANCE
988	11-11-2025	Part of : HAIBUTPUR,SARSWATI ENCLAVE GOPAL NAGAR NAJAFGARH,KRISHAN VIHAR NAJAFGARH	3458	Other Outage	Unplanned Outage	11-11-2025	13:55	11-11-2025	14:27	0:32	0.000231	CABLE FAULT
989	11-11-2025	Part of : BABA HARI DAS ENCLAVE JHARODA KALAN,BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN	478	Other Outage	Unplanned Outage	11-11-2025	09:11	11-11-2025	10:00	0:49	0.000476	CABLE FAULT
990	11-11-2025	Part of : MANDHELA KHURD VILLAGE	2	Other Outage	Planned Outage	11-11-2025	13:09	11-11-2025	14:59	1:50	0.001222	REPLACEMENT OF HT BUSHING ROD
991	11-11-2025	Part of : JANTA VIHAR HAIBUTPUR	259	Other Outage	Planned Outage	11-11-2025	13:08	11-11-2025	14:41	1:33	0.001033	REPLACEMENT OF HT BUSHING ROD
992	11-11-2025	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	670	Other Outage	Planned Outage	11-11-2025	14:58	11-11-2025	17:34	2:36	0.001733	REPLACEMENT OF HT BUSHING ROD
993	11-11-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	982	Other Outage	Planned Outage	11-11-2025	13:07	11-11-2025	15:46	2:39	0.001767	REPLACEMENT OF HT BUSHING ROD
994	11-11-2025	Part of : BASCO COLONY ARYA NAGAR NAJAFGARH	10	Other Outage	Planned Outage	11-11-2025	11:56	11-11-2025	14:41	2:45	0.001833	REPLACEMENT OF HT BUSHING ROD
995	11-11-2025	Part of : ISSAPUR VILLAGE	4	Other Outage	Planned Outage	11-11-2025	11:11	11-11-2025	13:38	2:27	0.001633	REPLACEMENT OF HT BUSHING ROD
996	11-11-2025	Part of : GHALLBPUR VILLAGE	1	Other Outage	Planned Outage	11-11-2025	10:59	11-11-2025	14:00	3:01	0.002011	REPLACEMENT OF HT BUSHING ROD
997	12-11-2025	Part of : JAFARPUR KALAN VILLAGE	9	Other Outage	Planned Outage	12-11-2025	14:06	12-11-2025	15:57	1:51	0.001233	REPLACEMENT OF HT BUSHING ROD
998	12-11-2025	Part of : MITRAON VILLAGE NAJAFGARH	16	Other Outage	Planned Outage	12-11-2025	14:22	12-11-2025	16:42	2:20	0.001556	REPLACEMENT OF HT BUSHING ROD
999	12-11-2025	Part of : GOPAL NAGAR NAJAFGARH	487	Other Outage	Planned Outage	12-11-2025	13:38	12-11-2025	15:56	2:18	0.001533	REPLACEMENT OF HT BUSHING ROD
1000	12-11-2025	Part of : DHANSA VILLAGE	14	Other Outage	Planned Outage	12-11-2025	11:05	12-11-2025	13:25	2:20	0.001556	REPLACEMENT OF HT BUSHING ROD
1001	12-11-2025	Part of : JAFARPUR KALAN VILLAGE	460	Other Outage	Planned Outage	12-11-2025	11:12	12-11-2025	13:21	2:09	0.001433	REPLACEMENT OF HT BUSHING ROD
1002	13-11-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1398	Other Outage	Planned Outage	13-11-2025	10:59	13-11-2025	13:54	2:55	0.002917	REPLACEMENT OF LT BUSHING ROD
1003	13-11-2025	Part of : DAURALA VILLAGE	185	Other Outage	Planned Outage	13-11-2025	11:06	13-11-2025	13:53	2:47	0.003711	REPLACEMENT OF LT BUSHING ROD
1004	13-11-2025	Part of : JANTA VIHAR HAIBUTPUR	516	Other Outage	Planned Outage	13-11-2025	11:41	13-11-2025	13:55	2:14	0.002978	REPLACEMENT OF LT BUSHING ROD
1005	13-11-2025	Part of : SAMAZPUR KHALSA	190	Other Outage	Planned Outage	13-11-2025	11:09	13-11-2025	13:51	2:42	0.002700	REPLACEMENT OF LT BUSHING ROD
1006	13-11-2025	Part of : ISSAPUR VILLAGE	45	Other Outage	Planned Outage	13-11-2025	10:17	13-11-2025	12:37	2:20	0.003111	REPLACEMENT OF LT BUSHING ROD
1007	14-11-2025	Part of : Z BLOCK CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	687	Other Outage	Planned Outage	14-11-2025	15:07	14-11-2025	16:47	1:40	0.001667	REPLACEMENT OF LT BUSHING ROD
1008	14-11-2025	Part of : GHUMAN HERA JAINPUR VILLAGE	242	Other Outage	Planned Outage	14-11-2025	14:15	14-11-2025	16:10	1:55	0.002556	REPLACEMENT OF HT BUSHING ROD
1009	14-11-2025	Part of : BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN	132	Other Outage	Planned Outage	14-11-2025	12:03	14-11-2025	14:44	2:41	0.003578	PREVENTIVE MAINTENANCE
1010	14-11-2025	Part of : MANDHELA KALAN VILLAGE	5	Other Outage	Planned Outage	14-11-2025	12:00	14-11-2025	14:44	2:44	0.003644	PREVENTIVE MAINTENANCE
1011	14-11-2025	Part of : ISSAPUR VILLAGE	2	Other Outage	Planned Outage	14-11-2025	11:17	14-11-2025	13:25	2:08	0.002844	PREVENTIVE MAINTENANCE
1012	14-11-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	989	Other Outage	Planned Outage	14-11-2025	11:18	14-11-2025	13:53	2:35	0.002583	REPLACEMET OF LT BUSHING ROD
1013	15-11-2025	Part of : DARYAPUR KHURD VILLAGE	366	Other Outage	Planned Outage	15-11-2025	14:54	15-11-2025	16:41	1:47	0.001486	REPLACEMENT OF HT BUSHING ROD
1014	15-11-2025	Part of : SUREHRA VILLAGE	455	Other Outage	Planned Outage	15-11-2025	14:49	15-11-2025	17:10	2:21	0.001958	REPLACEMENT OF HT BUSHING ROD
1015	15-11-2025	Part of : BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN	650	Other Outage	Planned Outage	15-11-2025	11:48	15-11-2025	15:59	4:11	0.003486	REPLACEMENT OF HT BUSHING ROD
1016	15-11-2025	Part of : ISSAPUR VILLAGE	12	Other Outage	Planned Outage	15-11-2025	11:05	15-11-2025	13:11	2:06	0.001750	REPLACEMENT OF HT BUSHING ROD
1017	17-11-2025	Part of : KHARKHARI JATMAL VILLAGE	308	Other Outage	Planned Outage	17-11-2025	15:22	17-11-2025	16:51	1:29	0.001236	REPLACEMENT OF HT BUSHING ROD
1018	17-11-2025	Part of : JANTA VIHAR HAIBUTPUR	260	Other Outage	Planned Outage	17-11-2025	14:31	17-11-2025	16:29	1:58	0.001639	REPLACEMENT OF HT BUSHING ROD
1019	17-11-2025	Part of : SAMAZPUR KHALSA	171	Other Outage	Planned Outage	17-11-2025	12:12	17-11-2025	14:29	2:17	0.001903	REPLACEMENT OF HT BUSHING ROD
1020	17-11-2025	Part of : SARSWATI ENCLAVE GOPAL NAGAR NAJAFGARH	682	Other Outage	Planned Outage	17-11-2025	11:05	17-11-2025	13:56	2:51	0.002375	REPLACEMENT OF HT BUSHING ROD
1021	17-11-2025	Part of : SARANGPUR VILLAGE	2	Other Outage	Planned Outage	17-11-2025	11:09	17-11-2025	13:47	2:38	0.002194	REPLACEMENT OF HT BUSHING ROD
1022	18-11-2025	Part of : MITRAON VILLAGE NAJAFGARH,	243	Other Outage	Planned Outage	18-11-2025	14:18	18-11-2025	16:35	2:17	0.001522	REPLACEMET OF HT BUSHING ROD
1023	18-11-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE,	982	Other Outage	Planned Outage	18-11-2025	14:32	18-11-2025	16:45	2:13	0.001478	REPLACEMET OF HT BUSHING ROD
1024	18-11-2025	Part of : BLOCK A1 VINOBHA ENCLAVE CRPF COLONY JHARODA KALAN,	273	Other Outage	Planned Outage	18-11-2025	12:32	18-11-2025	14:57	2:25	0.001611	REPLACEMET OF HT BUSHING ROD
1025	18-11-2025	Part of : MANDHELA KHURD VILLAGE,	2	Other Outage	Planned Outage	18-11-2025	10:59	18-11-2025	13:31	2:32	0.001689	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1026	18-11-2025	Part of : DAURALA VILLAGE,	185	Other Outage	Planned Outage	18-11-2025	10:07	18-11-2025	13:01	2:54	0.001933	REPLACEMET OF HT BUSHING ROD
1027	19-11-2025	Part of : SAMAZPUR KHALSA	359	Other Outage	Planned Outage	19-11-2025	15:51	19-11-2025	16:52	1:01	0.000678	REPLACEMENT OF HT BUSHING ROD
1028	19-11-2025	Part of : MANDHELA KALAN VILLAGE	4	Other Outage	Planned Outage	19-11-2025	12:10	19-11-2025	14:00	1:50	0.001222	REPLACEMENT OF HT BUSHING ROD
1029	19-11-2025	Part of : SARSWATI ENCLAVE GOPAL NAGAR NAJAFGARH	396	Other Outage	Planned Outage	19-11-2025	13:42	19-11-2025	15:52	2:10	0.001444	REPLACEMENT OF HT BUSHING ROD
1030	19-11-2025	Part of : DHANSA VILLAGE	262	Other Outage	Planned Outage	19-11-2025	11:02	19-11-2025	13:21	2:19	0.001544	REPLACEMENT OF HT BUSHING ROD
1031	20-11-2025	Part of : GOPAL NAGAR PHASE-2	668	Other Outage	Planned Outage	20-11-2025	11:05	20-11-2025	14:14	3:09	0.000525	REPLACEMENT OF HT BUSHING ROD
1032	20-11-2025	Part of : RAWTA	273	Other Outage	Planned Outage	20-11-2025	10:34	20-11-2025	12:52	2:18	0.000383	REPLACEMENT OF HT BUSHING ROD
1033	20-11-2025	Part of : SHYAM COLONY MALIKPUR	335	Other Outage	Planned Outage	20-11-2025	10:23	20-11-2025	12:54	2:31	0.000419	REPLACEMENT OF LT BUSHING ROD
1034	21-11-2025	Part of : A-BLOCK GOPAL NAGAR	1076	Other Outage	Planned Outage	21-11-2025	15:03	21-11-2025	16:24	1:21	0.000225	REPLACEMET OF HT BUSHING ROD
1035	21-11-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	714	Other Outage	Planned Outage	21-11-2025	15:05	21-11-2025	16:49	1:44	0.001444	REPLACEMET OF HT BUSHING ROD
1036	21-11-2025	Part of : MANDHELA KALAN VILLAGE	2	Other Outage	Planned Outage	21-11-2025	13:23	21-11-2025	15:10	1:47	0.001486	REPLACEMET OF HT BUSHING ROD
1037	21-11-2025	Part of : DHANSA	355	Other Outage	Planned Outage	21-11-2025	14:10	21-11-2025	16:13	2:03	0.000342	REPLACEMET OF HT BUSHING ROD
1038	21-11-2025	Part of : SHIV VIHAR COLONY GOPAL NAGAR NAJAFGARH	456	Other Outage	Planned Outage	21-11-2025	10:49	21-11-2025	14:06	3:17	0.002736	REPLACEMET OF HT BUSHING ROD
1039	21-11-2025	Part of : GHUMENHERA	399	Other Outage	Planned Outage	21-11-2025	11:06	21-11-2025	14:05	2:59	0.000497	REPLACEMENT OF LT BUSHING ROD
1040	22-11-2025	Part of : KHERA DABAS VILLAGE,	251	Other Outage	Planned Outage	22-11-2025	15:28	22-11-2025	16:17	0:49	0.000681	REPLACEMET OF HT BUSHING ROD
1041	22-11-2025	Part of : SUREHRA VILLAGE,	13	Other Outage	Planned Outage	22-11-2025	14:01	22-11-2025	15:36	1:35	0.001319	REPLACEMET OF HT BUSHING ROD
1042	22-11-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH,	3734	Other Outage	Planned Outage	22-11-2025	10:59	22-11-2025	13:48	2:49	0.002347	GUARD WIRE LACS INSTALLTION PER SPAN
1043	24-11-2025	Part of : MALIKPUR ZER VILLAGE,JAFARPUR KALAN VILLAGE,SAMAZPUR KHALSA	1663	Other Outage	Planned Outage	24-11-2025	12:15	24-11-2025	14:54	2:39	0.002208	REPLACEMENT OF HT BUSHING ROD
1044	24-11-2025	Part of : ISSAPUR VILLAGE	267	Other Outage	Planned Outage	24-11-2025	11:57	24-11-2025	14:45	2:48	0.002333	REPLACEMENT OF HT BUSHING ROD
1045	24-11-2025	Part of : GOPAL NAGAR NAJAFGARH	398	Other Outage	Planned Outage	24-11-2025	12:35	24-11-2025	14:55	2:20	0.001944	REPLACEMENT OF HT BUSHING ROD
1046	24-11-2025	Part of : GHALLBPUR VILLAGE	418	Other Outage	Planned Outage	24-11-2025	11:04	24-11-2025	13:54	2:50	0.002361	REPLACEMENT OF HT BUSHING ROD
1047	25-11-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH, BLOCK B NANDA ENCLAVE, KRISHNA VIHAR WEST, VILLAGE MITRAON	3861	Other Outage	Unplanned Outage	25-11-2025	15:29	25-11-2025	16:17	0:48	0.000613	HT SYSTEM FAULT
1048	26-11-2025	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN,	1099	Other Outage	Planned Outage	26-11-2025	13:02	26-11-2025	15:31	2:29	0.001656	REPLACEMET OF HT BUSHING ROD
1049	26-11-2025	Part of : BADHOSRA,	1	Other Outage	Planned Outage	26-11-2025	12:08	26-11-2025	14:45	2:37	0.001744	REPLACEMET OF HT BUSHING ROD
1050	26-11-2025	Part of : MANDHELA KHURD VILLAGE,	1	Other Outage	Planned Outage	26-11-2025	11:10	26-11-2025	13:21	2:11	0.001456	REPLACEMET OF HT BUSHING ROD
1051	26-11-2025	Part of : BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,	317	Other Outage	Planned Outage	26-11-2025	11:14	26-11-2025	13:55	2:41	0.001789	REPLACEMET OF HT BUSHING ROD
1052	26-11-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE,	703	Other Outage	Planned Outage	26-11-2025	11:08	26-11-2025	13:56	2:48	0.001867	REPLACEMET OF HT BUSHING ROD
1053	27-11-2025	Part of : MALIKPUR ZER VILLAGE	214	Other Outage	Planned Outage	27-11-2025	14:43	27-11-2025	16:36	1:53	0.002511	REPLACEMENT OF HT BUSHING ROD
1054	27-11-2025	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN	666	Other Outage	Planned Outage	27-11-2025	14:38	27-11-2025	16:34	1:56	0.000322	REPLACEMENT OF HT BUSHING ROD
1055	27-11-2025	Part of : KAIR VILLAGE	675	Other Outage	Planned Outage	27-11-2025	13:42	27-11-2025	16:34	2:52	0.002389	REPLACEMENT OF HT BUSHING ROD
1056	27-11-2025	Part of : BAQAR GARH VILLAGE	1	Other Outage	Planned Outage	27-11-2025	11:59	27-11-2025	14:01	2:02	0.002033	REPLACEMENT OF LT BUSHING ROD
1057	27-11-2025	Part of : SRI HANS NAGAR	502	Other Outage	Planned Outage	27-11-2025	11:18	27-11-2025	13:55	2:37	0.000436	REPLACEMENT OF HT BUSHING ROD
1058	28-11-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE,JAFARPUR KALAN VILLAGE	2842	Other Outage	Unplanned Outage	28-11-2025	16:00	28-11-2025	17:37	1:37	0.001347	ATTENDING WEAK POINTS/HOT SPOT
1059	28-11-2025	Part of : B-BLOCK NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	547	Other Outage	Planned Outage	28-11-2025	14:41	28-11-2025	17:15	2:34	0.002567	REPLACEMET OF HT BUSHING ROD
1060	28-11-2025	Part of : DARYAPUR KHURD VILLAGE	2	Other Outage	Planned Outage	28-11-2025	14:31	28-11-2025	17:15	2:44	0.003644	REPLACEMET OF HT BUSHING ROD
1061	28-11-2025	Part of : D-BLOCK BANGALI COLONY NAVEEN PALACE JHARODA KALAN	668	Other Outage	Planned Outage	28-11-2025	12:44	28-11-2025	14:53	2:09	0.002150	REPLACEMET OF HT BUSHING ROD
1062	28-11-2025	Part of : QAZIPUR VILLAGE	331	Other Outage	Planned Outage	28-11-2025	11:20	28-11-2025	13:49	2:29	0.003311	REPLACEMET OF HT BUSHING ROD
1063	28-11-2025	Part of : MANDHELA KHURD VILLAGE	5	Other Outage	Planned Outage	28-11-2025	11:01	28-11-2025	13:23	2:22	0.002367	REPLACEMET OF HT BUSHING ROD
1064	28-11-2025	Part of : MANDHELA KHURD VILLAGE	2	Other Outage	Planned Outage	28-11-2025	11:00	28-11-2025	13:24	2:24	0.002400	REPLACEMET OF HT BUSHING ROD
1065	29-11-2025	Part of : BAQAR GARH VILLAGE	5	Other Outage	Planned Outage	29-11-2025	13:28	29-11-2025	15:32	2:04	0.001722	REPLACEMET OF HT BUSHING ROD
1066	29-11-2025	Part of : SHYAM ENCAVE NAJAFGARH	8	Other Outage	Planned Outage	29-11-2025	11:04	29-11-2025	13:59	2:55	0.002431	REPLACEMET OF HT BUSHING ROD
1067	29-11-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	989	Other Outage	Planned Outage	29-11-2025	11:09	29-11-2025	13:57	2:48	0.002333	REPLACEMET OF HT BUSHING ROD
1068	29-11-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	3739	Other Outage	Planned Outage	29-11-2025	11:03	29-11-2025	13:52	2:49	0.002347	GUARD WIRES SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1069	01-11-2025	Part of : BLOCK A & E MAYAPURI INDUSTRIAL AREA PHASE II	1152	Other Outage	Unplanned Outage	01-11-2025	18:32	01-11-2025	19:44	1:12	0.000000	CABLE FAULT
1070	01-11-2025	Part of : BLOCK D MAYAPURI INDUSTRIAL AREA PHASE II	705	Other Outage	Planned Outage	01-11-2025	13:02	01-11-2025	14:09	1:07	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1071	01-11-2025	Part of : POCKET G HARI NAGAR JANAK PURI	835	Other Outage	Planned Outage	01-11-2025	13:01	01-11-2025	14:08	1:07	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1072	01-11-2025	Part of : BLOCK 3 SUBHASH NAGAR	249	Other Outage	Planned Outage	01-11-2025	13:05	01-11-2025	15:37	2:32	0.000000	ACB REPLACEMENT PER ACB MEASUREMET OF INSULATION
1073	01-11-2025	Part of : BLOCK C MAYAPURI INDUSTRIAL AREA PHASE II	107	Other Outage	Planned Outage	01-11-2025	12:59	01-11-2025	15:15	2:16	0.000000	RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1074	02-11-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	493	Other Outage	Unplanned Outage	02-11-2025	05:48	02-11-2025	06:42	0:54	0.000600	FAULT IN HT CONSUMER PANEL (B-125 MAYAPURI PH-1)
1075	02-11-2025	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	129	Other Outage	Planned Outage	02-11-2025	12:20	02-11-2025	14:45	2:25	0.000000	ACB REPLACEMENT PER ACB
1076	02-11-2025	Part of : BLOCK FC MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	75	Other Outage	Planned Outage	02-11-2025	11:11	02-11-2025	13:44	2:33	0.000000	ACB REPLACEMENT PER ACB
1077	03-11-2025	Part of : BLOCK VA VIRENDRA NAGAR JANAK PURI,BLOCK VB VIRENDRA NAGAR JANAK PURI	2211	Other Outage	Unplanned Outage	03-11-2025	14:29	03-11-2025	15:24	0:55	0.000886	CABLE FAULT
1078	03-11-2025	PART OF : BLOCK WZ LAJWANTI GARDEN JANAK PURI	555	Other Outage	Planned Outage	03-11-2025	12:58	03-11-2025	13:58	1:00	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1079	03-11-2025	PART OF : POCKET G HARI NAGAR JANAK PURI	836	Other Outage	Planned Outage	03-11-2025	12:33	03-11-2025	14:03	1:30	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1080	03-11-2025	PART OF : BLOCK S RAJOURI GARDEN	422	Other Outage	Planned Outage	03-11-2025	12:34	03-11-2025	13:34	1:00	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1081	03-11-2025	PART OF : BLOCK A NANAK PURA HARI NAGAR	905	Other Outage	Planned Outage	03-11-2025	11:15	03-11-2025	14:06	2:51	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1082	03-11-2025	PART OF : JANAK CINEMA, C BLK PANKHA RD (HTC)	1	Other Outage	Planned Outage	03-11-2025	11:22	03-11-2025	13:30	2:08	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1083	04-11-2025	Part of : B-BLOCK FATEH NAGAR JANAK PURI	246	Other Outage	Planned Outage	04-11-2025	14:51	04-11-2025	16:11	1:20	0.000444	LT CIRCUIT MAINTENANCE WORK
1084	04-11-2025	Part of : WZ-BLOCK LAJWANTI GARDEN JANAK PURI	719	Other Outage	Planned Outage	04-11-2025	11:47	04-11-2025	13:25	1:38	0.000544	PRC REPLACEMENT
1085	04-11-2025	Part of : AT CAMP JAIL NO-4	1	Other Outage	Planned Outage	04-11-2025	12:06	04-11-2025	14:50	2:44	0.000911	LT CIRCUIT MAINTENANCE WORK
1086	04-11-2025	Part of : A-BLOCK NANAK PURA HARI NAGAR	715	Other Outage	Planned Outage	04-11-2025	11:05	04-11-2025	13:45	2:40	0.000889	LT CIRCUIT MAINTENANCE WORK
1087	04-11-2025	Part of : B 2-BLOCK SHIV NAGAR JANAK PURI	6	Other Outage	Planned Outage	04-11-2025	11:52	04-11-2025	14:26	2:34	0.000856	LT CIRCUIT MAINTENANCE WORK
1088	05-11-2025	Part of : DISTRICT CENTRE JANAK PURI	147	Other Outage	Planned Outage	05-11-2025	11:11	05-11-2025	12:52	1:41	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1089	06-11-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,POCKET D 1A JANAK PURI	762	Other Outage	Unplanned Outage	06-11-2025	13:25	06-11-2025	14:22	0:57	0.000950	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1090	06-11-2025	Part of : BLOCK D MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,POCKET WS1 MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,KHAJAN BASTI MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,BOLOCK C KHAJAN BASTI MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	2450	Other Outage	Unplanned Outage	06-11-2025	00:56	06-11-2025	02:09	1:13	0.000994	TRANSIENT FAULT
1091	06-11-2025	Part of : DDU HOSPITAL C BLOCK JANAK PURI,	31	Other Outage	Planned Outage	06-11-2025	12:48	06-11-2025	14:16	1:28	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1092	06-11-2025	Part of : BLOCK Z RAJOURI GARDEN EXTENSION RAJOURI GARDEN,	317	Other Outage	Planned Outage	06-11-2025	12:59	06-11-2025	16:36	3:37	0.001808	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1093	06-11-2025	Part of : BLOCK C JANAK PURI,	7	Other Outage	Planned Outage	06-11-2025	11:18	06-11-2025	13:30	2:12	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1094	06-11-2025	Part of : BLOCK VB VIRENDRA NAGAR JANAK PURI,	258	Other Outage	Planned Outage	06-11-2025	11:28	06-11-2025	14:00	2:32	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1095	07-11-2025	Part of : BLOCK C FATEH NAGAR	1918	Other Outage	Planned Outage	07-11-2025	12:24	07-11-2025	13:35	1:11	0.000592	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1096	07-11-2025	Part of : POCKET G HARI NAGAR JANAK PURI	230	Other Outage	Planned Outage	07-11-2025	14:17	07-11-2025	15:27	1:10	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1097	07-11-2025	Part of : POCKET D2A NANGAL RAYA JANAK PURI	414	Other Outage	Planned Outage	07-11-2025	11:54	07-11-2025	13:39	1:45	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1098	07-11-2025	Part of : BLOCK J RAJOURI GARDEN EXTENSION RAJOURI GARDEN	268	Other Outage	Planned Outage	07-11-2025	11:52	07-11-2025	13:45	1:53	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1099	08-11-2025	Part of : RZ-BLOCK MOHAN NAGAR SAGARPUR MAIN	302	Other Outage	Planned Outage	08-11-2025	11:43	08-11-2025	12:24	0:41	0.000228	LT CIRCUIT MAINTENANCE WORK
1100	08-11-2025	Part of : C & C C2-BLOCK JANAK PURI,PRATAP NAGAR MAYA ENCLAVE,DDU HOSPITAL	2244	Other Outage	Planned Outage	08-11-2025	12:56	08-11-2025	14:29	1:33	0.000775	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1101	08-11-2025	Part of : J-BLOCK RAJOURI GARDEN EXTENSION	388	Other Outage	Planned Outage	08-11-2025	14:19	08-11-2025	15:20	1:01	0.000339	LT CIRCUIT MAINTENANCE WORK
1102	08-11-2025	Part of : VA-BLOCK VIRENDRA NAGAR JANAK PURI	615	Other Outage	Planned Outage	08-11-2025	12:07	08-11-2025	13:30	1:23	0.000461	LT CIRCUIT MAINTENANCE WORK
1103	08-11-2025	Part of : H-BLOCK NANAK PURA HARI NAGAR	658	Other Outage	Planned Outage	08-11-2025	14:20	08-11-2025	17:30	3:10	0.001583	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1104	08-11-2025	Part of : BF-BLOCK JANAK PURI	321	Other Outage	Planned Outage	08-11-2025	12:17	08-11-2025	14:58	2:41	0.000894	LT CIRCUIT MAINTENANCE WORK
1105	08-11-2025	Part of : A-BLOCK MAYAPURI INDUSTRIAL AREA PHASE-2	80	Other Outage	Planned Outage	08-11-2025	11:55	08-11-2025	14:23	2:28	0.000822	LT CIRCUIT MAINTENANCE WORK
1106	08-11-2025	Part of : POCKET EL HARI NAGAR	427	Other Outage	Planned Outage	08-11-2025	11:22	08-11-2025	13:48	2:26	0.000811	LT CIRCUIT MAINTENANCE WORK
1107	09-11-2025	Part of : POCKET WS1 MAYAPURI INDUSTRIAL AREA PHASE II	151	Other Outage	Planned Outage	09-11-2025	12:04	09-11-2025	14:56	2:52	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1108	10-11-2025	Part of : BLOCK WZ PADAM BASTI NANGAL RAYA JANAK PURI,	309	Other Outage	Planned Outage	10-11-2025	11:33	10-11-2025	13:30	1:57	0.000000	LT CIRCUIT MAINTENANCE
1109	10-11-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	45	Other Outage	Planned Outage	10-11-2025	12:07	10-11-2025	15:04	2:57	0.000000	LT ACB REPLACEMENT
1110	10-11-2025	Part of : BLOCK BE HARI NAGAR,	511	Other Outage	Planned Outage	10-11-2025	12:21	10-11-2025	14:37	2:16	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
1111	10-11-2025	Part of : BLOCK C1 JANAK PURI,	3	Other Outage	Planned Outage	10-11-2025	12:01	10-11-2025	14:27	2:26	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
1112	10-11-2025	Part of : BLOCK C JANAK PURI,	148	Other Outage	Planned Outage	10-11-2025	11:46	10-11-2025	14:40	2:54	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
1113	10-11-2025	Part of : BLOCK J RAJOURI GARDEN EXTENSION RAJOURI GARDEN,	105	Other Outage	Planned Outage	10-11-2025	11:26	10-11-2025	15:03	3:37	0.000000	LT CIRCUIT MAINTENANCE
1114	11-11-2025	Part of : TIHAR CENTRAL JAIL JANAK PURI	69	Other Outage	Planned Outage	11-11-2025	13:00	11-11-2025	15:49	2:49	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
1115	11-11-2025	Part of : BLOCK C2 JANAK PURI	226	Other Outage	Planned Outage	11-11-2025	11:37	11-11-2025	14:20	2:43	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1116	11-11-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	40	Other Outage	Planned Outage	11-11-2025	12:11	11-11-2025	15:18	3:07	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1117	11-11-2025	Part of : BLOCK A 3 ASALATPUR VILLAGE JANAK PURI	228	Other Outage	Planned Outage	11-11-2025	11:37	11-11-2025	14:18	2:41	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1118	12-11-2025	Part of : FC-BLOCK & POCKET GI MAYAPURI INDUSTRIAL AREA PHASE-2	683	Other Outage	Unplanned Outage	12-11-2025	03:55	12-11-2025	05:11	1:16	0.000971	CABLE FAULT
1119	12-11-2025	Part of : ADITI APARTMENTS JANAK PURI	333	Other Outage	Planned Outage	12-11-2025	13:07	12-11-2025	14:12	1:05	0.000361	LT CIRCUIT MAINTENANCE
1120	12-11-2025	Part of : BLOCK WZ NANGAL RAYA JANAK PURI	986	Other Outage	Planned Outage	12-11-2025	12:23	12-11-2025	16:21	3:58	0.001983	DT REPLACEMENT
1121	12-11-2025	Part of : BLOCK C 2C JANAK PURI	82	Other Outage	Planned Outage	12-11-2025	12:13	12-11-2025	14:45	2:32	0.000844	LT CIRCUIT MAINTENANCE
1122	12-11-2025	Part of : MANAK VIHAR TIHAR VILLAGE	801	Other Outage	Planned Outage	12-11-2025	11:14	12-11-2025	13:47	2:33	0.000850	LT AB SAGGING
1123	12-11-2025	Part of : BLOCK A 2B ASALATPUR VILLAGE JANAK PURI	220	Other Outage	Planned Outage	12-11-2025	11:43	12-11-2025	14:14	2:31	0.000839	LT CIRCUIT MAINTENANCE
1124	12-11-2025	Part of : DELHI MILK SSCHEME COLONY HARI NAGAR	1008	Other Outage	Planned Outage	12-11-2025	11:37	12-11-2025	14:10	2:33	0.000850	LT CIRCUIT MAINTENANCE
1125	13-11-2025	Part of : BLOCK CA & CB HARI NAGAR,BLOCK CB MAYA ENCLAVE HARI NAGAR, PRATAP NAGAR, POLICE STATION & QUARTERS HARI NAGAR	3086	Other Outage	Unplanned Outage	13-11-2025	02:44	13-11-2025	03:34	0:50	0.000250	CABLE FAULT
1126	13-11-2025	Part of : BLOCK BE HARI NAGAR	513	Other Outage	Unplanned Outage	13-11-2025	13:40	13-11-2025	13:54	0:14	0.000000	RMU COVER INSTALLATION WORK
1127	13-11-2025	Part of : TIHAR CENTRAL JAIL JANAK PURI	7	Other Outage	Planned Outage	13-11-2025	13:44	13-11-2025	14:56	1:12	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1128	13-11-2025	Part of : BLOCK C1 JANAK PURI	175	Other Outage	Planned Outage	13-11-2025	11:59	13-11-2025	14:42	2:43	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1129	13-11-2025	Part of : POCKET B FATEH NAGAR	685	Other Outage	Planned Outage	13-11-2025	12:43	13-11-2025	15:10	2:27	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1130	13-11-2025	Part of : BLOCK A 3 ASALATPUR VILLAGE JANAK PURI	227	Other Outage	Planned Outage	13-11-2025	11:20	13-11-2025	14:11	2:51	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1131	13-11-2025	Part of : MANAK VIHAR TIHAR VILLAGE	893	Other Outage	Planned Outage	13-11-2025	11:09	13-11-2025	13:33	2:24	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1132	14-11-2025	Part of : RZ BLOCK VASHISHT PARK SAGARPUR	855	Other Outage	Planned Outage	14-11-2025	12:25	14-11-2025	13:29	1:04	0.000000	LT CIRCUIT MAINTENANCE
1133	14-11-2025	Part of : A BLOCK MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	120	Other Outage	Planned Outage	14-11-2025	12:34	14-11-2025	14:12	1:38	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
1134	14-11-2025	Part of : POSSANGIPUR VILLAGE JANAK PURI	404	Other Outage	Planned Outage	14-11-2025	11:58	14-11-2025	14:15	2:17	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
1135	14-11-2025	Part of : C1 BLOCK JANAK PURI	32	Other Outage	Planned Outage	14-11-2025	11:16	14-11-2025	13:59	2:43	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
1136	14-11-2025	Part of : V BLOCK RAJOURI GARDEN	244	Other Outage	Planned Outage	14-11-2025	10:59	14-11-2025	13:53	2:54	0.000000	LT CIRCUIT MAINTENANCE
1137	15-11-2025	Part of : BLOCK C 1A JANAK PURI	351	Other Outage	Planned Outage	15-11-2025	11:12	15-11-2025	14:20	3:08	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1138	15-11-2025	Part of : BLOCK A 5B POSSANGIPUR VILLAGE JANAK PURI	636	Other Outage	Planned Outage	15-11-2025	12:23	15-11-2025	15:22	2:59	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1139	15-11-2025	Part of : POCKET D 1A JANAK PURI	21	Other Outage	Planned Outage	15-11-2025	11:16	15-11-2025	14:01	2:45	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
1140	15-11-2025	Part of : BOLOCK C KHAJAN BASTI MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	107	Other Outage	Planned Outage	15-11-2025	12:24	15-11-2025	15:56	3:32	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1141	15-11-2025	Part of : BLOCK B PRESS COLONY MAYAPURI	563	Other Outage	Planned Outage	15-11-2025	11:45	15-11-2025	14:34	2:49	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1142	16-11-2025	Part of : NARANG COLONY CHANDAR NAGAR,A 3-BLOCK ASALATPUR VILLAGE,A 4C-BLOCK P & T COLONY JANAK PURI	787	Other Outage	Unplanned Outage	16-11-2025	01:58	16-11-2025	03:11	1:13	0.001014	CABLE FAULT
1143	16-11-2025	Part of : BLOCK B MAYAPURI INDUSTRIAL AREA PHASE I	493	Other Outage	Planned Outage	16-11-2025	12:43	16-11-2025	16:42	3:59	0.001992	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1144	16-11-2025	Part of : BLOCK FC MAYAPURI INDUSTRIAL AREA PHASE II	75	Other Outage	Planned Outage	16-11-2025	11:22	16-11-2025	15:20	3:58	0.001983	DT REPLACEMENT
1145	16-11-2025	Part of : POCKET S MAYAPURI INDUSTRIAL AREA PHASE II	360	Other Outage	Planned Outage	16-11-2025	11:21	16-11-2025	13:50	2:29	0.000414	REPLACEMENT OF GAS KIT AND OIL SEAL
1146	17-11-2025	Part of : POCKET D 1A JANAK PURI	25	Other Outage	Planned Outage	17-11-2025	11:38	17-11-2025	12:50	1:12	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
1147	17-11-2025	Part of : BLOCK WZ NANGAL RAYA JANAK PURI	986	Other Outage	Planned Outage	17-11-2025	12:34	17-11-2025	15:21	2:47	0.001392	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1148	17-11-2025	Part of : BLOCK 1 ASHOK NAGAR	515	Other Outage	Planned Outage	17-11-2025	12:46	17-11-2025	17:46	5:00	0.000833	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1149	17-11-2025	Part of : HARI ENCLAVE HARI NAGAR	493	Other Outage	Planned Outage	17-11-2025	13:46	17-11-2025	15:59	2:13	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1150	17-11-2025	Part of : BLOCK A 2 ASALATPUR VILLAGE JANAK PURI	245	Other Outage	Planned Outage	17-11-2025	12:44	17-11-2025	14:57	2:13	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1151	17-11-2025	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI	610	Other Outage	Planned Outage	17-11-2025	11:51	17-11-2025	14:13	2:22	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1152	18-11-2025	Part of : BLOCK S MEENAKSHI GARDEN ASHOK NAGAR,	510	Other Outage	Planned Outage	18-11-2025	14:52	18-11-2025	16:23	1:31	0.000000	SUB STATION CLEANING
1153	18-11-2025	Part of : POCKET D 1A JANAK PURI,	13	Other Outage	Planned Outage	18-11-2025	13:34	18-11-2025	16:10	2:36	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
1154	18-11-2025	Part of : BLOCK C 2D JANAK PURI,	89	Other Outage	Planned Outage	18-11-2025	12:12	18-11-2025	14:26	2:14	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1155	18-11-2025	Part of : BLOCK C3 RAJOURI GARDEN,	141	Other Outage	Planned Outage	18-11-2025	11:14	18-11-2025	13:25	2:11	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1156	18-11-2025	Part of : VIKRANT ENCLAVE PRESS COLONY MAYAPURI,	290	Other Outage	Planned Outage	18-11-2025	11:27	18-11-2025	14:05	2:38	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1157	18-11-2025	Part of : BLOCK A 3 ASALATPUR VILLAGE JANAK PURI,	248	Other Outage	Planned Outage	18-11-2025	11:36	18-11-2025	14:26	2:50	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1158	19-11-2025	Part of : BLOCK RZ SAGARPUR	262	Other Outage	Planned Outage	19-11-2025	12:06	19-11-2025	13:22	1:16	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
1159	19-11-2025	Part of : BLOCK A RAJOURI GARDEN	245	Other Outage	Planned Outage	19-11-2025	11:30	19-11-2025	14:39	3:09	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1160	19-11-2025	Part of : BLOCK A 2B ASALATPUR VILLAGE JANAK PURI	258	Other Outage	Planned Outage	19-11-2025	12:28	19-11-2025	14:44	2:16	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1161	19-11-2025	Part of : BLOCK C4B JANAK PURI	536	Other Outage	Planned Outage	19-11-2025	11:31	19-11-2025	14:38	3:07	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1162	19-11-2025	Part of : VIKRANT ENCLAVE PRESS COLONY MAYAPURI	462	Other Outage	Planned Outage	19-11-2025	11:30	19-11-2025	14:42	3:12	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1163	20-11-2025	Part of : DISTRICT CENTRE JANAK PURI,B 1C-BLOCK JANAK PURI	1111	Other Outage	Unplanned Outage	20-11-2025	10:49	20-11-2025	11:38	0:49	0.000694	CABLE FAULT
1164	20-11-2025	Part of : DISTRICT CENTRE JANAK PURI	880	Other Outage	Unplanned Outage	20-11-2025	10:02	20-11-2025	10:52	0:50	0.000389	CABLE FAULT
1165	20-11-2025	Part of : E-BLOCK RAGHU NAGAR DABRI	620	Other Outage	Planned Outage	20-11-2025	11:34	20-11-2025	13:01	1:27	0.000483	LT CIRCUIT MAINTENANCE WORK
1166	20-11-2025	Part of : WZ-BLOCK NANGAL RAYA JANAK PURI	1749	Other Outage	Planned Outage	20-11-2025	13:34	20-11-2025	15:42	2:08	0.001600	REPLACEMENT OF HT BUSHING ROD
1167	20-11-2025	Part of : WZ-BLOCK NANGAL RAYA JANAK PURI	986	Other Outage	Planned Outage	20-11-2025	11:06	20-11-2025	13:26	2:20	0.001167	REPLACEMENT OF FAULTY END BOX
1168	20-11-2025	Part of : A 1-BLOCK JANAK PURI	110	Other Outage	Planned Outage	20-11-2025	12:53	20-11-2025	15:02	2:09	0.000717	LT CIRCUIT MAINTENANCE WORK
1169	20-11-2025	Part of : C4F-BLOCK JANAK PURI	490	Other Outage	Planned Outage	20-11-2025	11:55	20-11-2025	14:14	2:19	0.000772	LT CIRCUIT MAINTENANCE WORK
1170	20-11-2025	Part of : RAJOURI GARDEN	72	Other Outage	Planned Outage	20-11-2025	11:49	20-11-2025	14:16	2:27	0.000817	LT CIRCUIT MAINTENANCE WORK
1171	20-11-2025	Part of : J-BLOCK RAJOURI GARDEN	273	Other Outage	Planned Outage	20-11-2025	11:14	20-11-2025	13:46	2:32	0.000000	LT CIRCUIT MAINTENANCE WORK
1172	21-11-2025	Part of : BLOCK J BERI WALA BAGH HARI NAGAR	780	Other Outage	Planned Outage	21-11-2025	14:55	21-11-2025	17:27	2:32	0.001478	REPLACEMENT OF GAS KIT AND OIL SEAL
1173	21-11-2025	Part of : BLOCK S MEENAKSHI GARDEN ASHOK NAGAR	510	Other Outage	Planned Outage	21-11-2025	10:21	21-11-2025	16:42	6:21	0.002117	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1174	21-11-2025	Part of : BLOCK C 5B JANAK PURI	488	Other Outage	Planned Outage	21-11-2025	10:59	21-11-2025	13:37	2:38	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1175	21-11-2025	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI	449	Other Outage	Planned Outage	21-11-2025	11:25	21-11-2025	13:59	2:34	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
1176	21-11-2025	Part of : POCKET B 1 B 1 MARKET SUPER BAZAR JANAK PURI	49	Other Outage	Planned Outage	21-11-2025	12:29	21-11-2025	15:09	2:40	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1177	21-11-2025	Part of : RAJOURI GARDEN	130	Other Outage	Planned Outage	21-11-2025	11:14	21-11-2025	13:38	2:24	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1178	22-11-2025	Part of : BLOCK C1 JANAK PURI	526	Other Outage	Unplanned Outage	22-11-2025	12:52	22-11-2025	13:51	0:59	0.000967	CABLE FAULT
1179	22-11-2025	Part of : BLOCK EA MAYA ENCLAVE HARI NAGAR,	60	Other Outage	Planned Outage	22-11-2025	11:13	22-11-2025	12:19	1:06	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1180	22-11-2025	Part of : BLOCK FC MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	75	Other Outage	Planned Outage	22-11-2025	14:41	22-11-2025	16:42	2:01	0.000000	ACB REPLACEMENT PER ACB
1181	22-11-2025	Part of : BLOCK A 3 ASALATPUR VILLAGE JANAK PURI,	248	Other Outage	Planned Outage	22-11-2025	14:02	22-11-2025	16:40	2:38	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1182	22-11-2025	Part of : BLOCK 5 SUBHASH NAGAR,	618	Other Outage	Planned Outage	22-11-2025	11:13	22-11-2025	13:59	2:46	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1183	23-11-2025	Part of : BOLOCK C KHAJAN BASTI MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI	169	Other Outage	Planned Outage	23-11-2025	13:41	23-11-2025	15:52	2:11	0.001237	3PH DB REPLACEMENT
1184	24-11-2025	Part of : HARI ENCLAVE HARI,J-BLOCK BERI WALA BAGH HARI NAGAR	782	Other Outage	Unplanned Outage	24-11-2025	07:13	24-11-2025	08:07	0:54	0.000240	HT SYSTEM FAULT
1185	24-11-2025	Part of : VIKRANT ENCLAVE PRESS COLONY MAYAPURI,POCKET J-B HARI ENCLAVE HARI NAGAR	2768	Other Outage	Unplanned Outage	24-11-2025	00:25	24-11-2025	01:27	1:02	0.000413	CABLE FAULT
1186	24-11-2025	Part of : A-BLOCK KARAN MARKET NANGAL RAYA JANAK PURI	929	Other Outage	Planned Outage	24-11-2025	11:57	24-11-2025	13:17	1:20	0.000444	LT CIRCUIT MAINTENANCE WORK
1187	24-11-2025	Part of : BLOCK 1 SUBHASH NAGAR	735	Other Outage	Planned Outage	24-11-2025	12:34	24-11-2025	14:36	2:02	0.000678	LT CIRCUIT MAINTENANCE WORK
1188	24-11-2025	Part of : C 5D-BLOCK JANAK PURI	402	Other Outage	Planned Outage	24-11-2025	11:14	24-11-2025	13:37	2:23	0.000794	LT CIRCUIT MAINTENANCE WORK
1189	24-11-2025	Part of : EC-BLOCK MAYA ENCLAVE HARI NAGAR	177	Other Outage	Planned Outage	24-11-2025	11:11	24-11-2025	13:19	2:08	0.000711	LT CIRCUIT MAINTENANCE WORK
1190	24-11-2025	Part of : A 2-BLOCK ASALATPUR VILLAGE JANAK PURI	534	Other Outage	Planned Outage	24-11-2025	11:08	24-11-2025	13:38	2:30	0.000833	LT CIRCUIT MAINTENANCE WORK

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1191	25-11-2025	Part of : PREM NAGAR, BLOCK B2 SHIV NAGAR JANAK PURI, BLOCK BA GURUNANAK PURA JANAK PURI, JANAK PURI, B2-BLK BOOSTERPUMP (HTC)	1690	Other Outage	Unplanned Outage	25-11-2025	02:58	25-11-2025	03:32	0:34	0.000406	CABLE FAULT
1192	25-11-2025	Part of : BLOCK 1 SUBHASH NAGAR	156	Other Outage	Unplanned Outage	25-11-2025	10:13	25-11-2025	11:40	1:27	0.000483	LT ACB BYPASS
1193	25-11-2025	Part of : BLOCK VB VIRENDRA NAGAR JANAK PURI	697	Other Outage	Planned Outage	25-11-2025	11:04	25-11-2025	11:43	0:39	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1194	25-11-2025	Part of : BLOCK 2 SUBHASH NAGAR	628	Other Outage	Planned Outage	25-11-2025	14:37	25-11-2025	16:18	1:41	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1195	25-11-2025	Part of : NANGAL VILLAGE DELHI CANTONMENT	844	Other Outage	Planned Outage	25-11-2025	11:23	25-11-2025	13:09	1:46	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1196	25-11-2025	Part of : BLOCK EC MAYA ENCLAVE HARI NAGAR	105	Other Outage	Planned Outage	25-11-2025	11:23	25-11-2025	13:53	2:30	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1197	26-11-2025	Part of : POCKET G HARI NAGAR JANAK PURI,POCKET A 1 DTC COLONY MAYA ENCLAVE HARI NAGAR,SHIV NAGAR JANAK PURI,BLOCK C JANAK PURI	2371	Other Outage	Unplanned Outage	26-11-2025	09:58	26-11-2025	10:53	0:55	0.000611	CABLE FAULT
1198	26-11-2025	Part of : DDU HOSPITAL C BLOCK JANAK PURI,BLOCK C JANAK PURI,BLOCK C 2C JANAK PURI	539	Other Outage	Unplanned Outage	26-11-2025	19:49	26-11-2025	21:33	1:44	0.000289	CABLE FAULT
1199	26-11-2025	Part of : POCKET G HARI NAGAR JANAK PURI,	230	Other Outage	Planned Outage	26-11-2025	14:21	26-11-2025	15:27	1:06	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1200	26-11-2025	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN SAGARPUR,	490	Other Outage	Planned Outage	26-11-2025	12:47	26-11-2025	15:20	2:33	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,INSULATOR REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
1201	26-11-2025	Part of : BLOCK EC MAYA ENCLAVE HARI NAGAR,	204	Other Outage	Planned Outage	26-11-2025	11:19	26-11-2025	14:05	2:46	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1202	26-11-2025	Part of : BLOCK S MEENAKSHI GARDEN ASHOK NAGAR,	512	Other Outage	Planned Outage	26-11-2025	11:12	26-11-2025	14:09	2:57	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1203	27-11-2025	Part of : BLOCK VA VIRENDRA NAGAR JANAK PURI	640	Other Outage	Planned Outage	27-11-2025	14:46	27-11-2025	15:50	1:04	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,TIGHTENEING OF NUT BOLT
1204	27-11-2025	Part of : BLOCK EA MAYA ENCLAVE HARI NAGAR	114	Other Outage	Planned Outage	27-11-2025	12:39	27-11-2025	14:20	1:41	0.000000	MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
1205	27-11-2025	Part of : BLOCK WZ NANGAL RAYA JANAK PURI	985	Other Outage	Planned Outage	27-11-2025	11:57	27-11-2025	14:08	2:11	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
1206	27-11-2025	Part of : BLOCK S MEENAKSHI GARDEN ASHOK NAGAR	612	Other Outage	Planned Outage	27-11-2025	11:10	27-11-2025	13:36	2:26	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1207	27-11-2025	Part of : RWA COLONY JANAK PURI	116	Other Outage	Planned Outage	27-11-2025	11:14	27-11-2025	13:55	2:41	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1208	28-11-2025	Part of : B 3-BLOCK JANAK PURI	388	Other Outage	Unplanned Outage	28-11-2025	12:19	28-11-2025	13:51	1:32	0.000511	REPAIRING OF LT CIRCUIT
1209	28-11-2025	Part of : POCKET D 1 JANAK PURI	532	Other Outage	Planned Outage	28-11-2025	12:22	28-11-2025	14:19	1:57	0.000650	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1210	28-11-2025	Part of : POCKET A 1 DTC COLONY MAYA ENCLAVE HARI NAGAR	125	Other Outage	Planned Outage	28-11-2025	11:44	28-11-2025	13:29	1:45	0.000583	LT CIRCUIT MAINTENANCE
1211	28-11-2025	Part of : RWA COLONY JANAK PURI	132	Other Outage	Planned Outage	28-11-2025	11:17	28-11-2025	13:38	2:21	0.000783	LT CIRCUIT MAINTENANCE
1212	28-11-2025	Part of : MEENAKSHI GARDEN ASHOK NAGAR	470	Other Outage	Planned Outage	28-11-2025	11:45	28-11-2025	14:14	2:29	0.000828	LT CIRCUIT MAINTENANCE
1213	29-11-2025	Part of : BLOCK WH MAYAPURI INDUSTRIAL AREA PHASE I	52	Other Outage	Unplanned Outage	29-11-2025	11:46	29-11-2025	13:46	2:00	0.000333	FOR TAKING LOAD ON REPAIRED CABLE
1214	29-11-2025	Part of : BLOCK C4H JANAK PURI	227	Other Outage	Planned Outage	29-11-2025	13:06	29-11-2025	14:55	1:49	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1215	29-11-2025	Part of : BLOCK 6 SUBHASH NAGAR	432	Other Outage	Planned Outage	29-11-2025	12:34	29-11-2025	14:25	1:51	0.000000	DT REPLACEMET PER DT
1216	29-11-2025	Part of : BLOCK BF JANAK PURI	379	Other Outage	Planned Outage	29-11-2025	11:48	29-11-2025	14:32	2:44	0.000911	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1217	29-11-2025	Part of : NANGAL RAYA JANAK PURI	881	Other Outage	Planned Outage	29-11-2025	12:08	29-11-2025	14:39	2:31	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1218	02-11-2025	Part of : NETAJI SUBHASH VIHAR MUNDKA,	60	Other Outage	Planned Outage	02-11-2025	12:46	02-11-2025	16:14	3:28	0.002889	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS
1219	02-11-2025	Part of : BLOCK C MUNDKA,	54	Other Outage	Planned Outage	02-11-2025	13:06	02-11-2025	15:39	2:33	0.002125	CONDUCTOR REPLACEMENT PER SPAN
1220	04-11-2025	Part of : GEETANJALI ENCLAVE	874	Other Outage	Planned Outage	04-11-2025	13:27	04-11-2025	16:02	2:35	0.000646	HT CONDUCTOR REPLACEMENT
1221	04-11-2025	Part of : MUNDKA VILLAGE	130	Other Outage	Planned Outage	04-11-2025	11:28	04-11-2025	14:18	2:50	0.001417	REPLACEMENT OF GAS KIT AND OIL SEAL
1222	06-11-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	42	Other Outage	Planned Outage	06-11-2025	13:54	06-11-2025	14:53	0:59	0.000328	REPLACEMENT OF GAS KIT AND OIL SEAL
1223	06-11-2025	Part of : RAM NAGAR KAMARUDDIN NAGAR,	568	Other Outage	Planned Outage	06-11-2025	12:20	06-11-2025	14:14	1:54	0.000633	REPLACEMENT OF LT BUSHING ROD
1224	06-11-2025	Part of : BANI AIR FORCE CAMP JAI VIHAR BAPROLA,NIRMAL VIHAR BAPROLA,	1400	Other Outage	Planned Outage	06-11-2025	12:03	06-11-2025	13:42	1:39	0.000413	GUARD WIRES SAGGING PER SPAN
1225	06-11-2025	Part of : RATAN BAGH NANGLOI,	1147	Other Outage	Planned Outage	06-11-2025	11:50	06-11-2025	13:46	1:56	0.000967	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1226	07-11-2025	Part of : RAJENDRA PARK EXTENSION NANGLOI EXTENSION NANGLOI	962	Other Outage	Planned Outage	07-11-2025	11:35	07-11-2025	13:17	1:42	0.001133	REPLACEMENT OF LT BUSHING ROD
1227	07-11-2025	Part of : POCKET C LOKNAYAK PURAM BAKARWALA	207	Other Outage	Planned Outage	07-11-2025	11:45	07-11-2025	15:10	3:25	0.001708	REPLACEMET OF HT BUSHING ROD
1228	07-11-2025	Part of : BLOCK 4 ABC NANGLOI EXTENSION NANGLOI	559	Other Outage	Planned Outage	07-11-2025	11:01	07-11-2025	13:19	2:18	0.000767	REPLACEMET OF HT BUSHING ROD
1229	07-11-2025	Part of : RANHOLLA	1172	Other Outage	Planned Outage	07-11-2025	11:01	07-11-2025	13:54	2:53	0.001442	REPLACEMET OF FAULTY END BOX
1230	07-11-2025	Part of : TIKRI KALAN	548	Other Outage	Planned Outage	07-11-2025	10:54	07-11-2025	13:53	2:59	0.002486	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1231	08-11-2025	Part of : NEELWAL VILLAGE,TIKRI KALAN,NEW PVC MARKET,NETAJI SUBHASH VIHAR MUNDKA	3688	Other Outage	Unplanned Outage	08-11-2025	07:05	08-11-2025	07:39	0:34	0.001322	CABLE FAULT
1232	08-11-2025	Part of : TIKRI KALAN	878	Other Outage	Planned Outage	08-11-2025	12:02	08-11-2025	14:13	2:11	0.001092	HT AB SAGGING
1233	08-11-2025	Part of : RANHOLLA	241	Other Outage	Planned Outage	08-11-2025	11:24	08-11-2025	14:25	3:01	0.001257	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1234	08-11-2025	Part of : WEST CABIN BLOCK MUNDKA	130	Other Outage	Planned Outage	08-11-2025	11:23	08-11-2025	14:24	3:01	0.002011	HT AB SAGGING
1235	09-11-2025	Part of : MUNDKA INDUSTRIAL AREA	8	Other Outage	Planned Outage	09-11-2025	12:53	09-11-2025	14:57	2:04	0.000689	CONDUCTOR REPLACEMENT PER SPAN
1236	09-11-2025	Part of : TYAGI VIHAR MUNDKA	34	Other Outage	Planned Outage	09-11-2025	11:06	09-11-2025	13:49	2:43	0.003169	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1237	09-11-2025	Part of : MUNDKA INDUSTRIAL AREA	36	Other Outage	Planned Outage	09-11-2025	10:24	09-11-2025	13:30	3:06	0.003617	CONDUCTOR REPLACEMENT PER SPAN
1238	10-11-2025	Part of : BLOCK 4 ABC NANGLOI EXTENSION NANGLOI,	520	Other Outage	Planned Outage	10-11-2025	11:10	10-11-2025	13:05	1:55	0.000958	PREVENTIVE MAINTENANCE
1239	10-11-2025	Part of : WEST CABIN BLOCK MUNDKA,	1017	Other Outage	Planned Outage	10-11-2025	11:24	10-11-2025	13:05	1:41	0.001122	PREVENTIVE MAINTENANCE
1240	10-11-2025	Part of : JOHAR VILLAGE NANGLOI EXTENSION NANGLOI,	673	Other Outage	Planned Outage	10-11-2025	11:16	10-11-2025	13:57	2:41	0.001789	PREVENTIVE MAINTENANCE
1241	11-11-2025	Part of : BLOCK C TYAGI VIHAR MUNDKA,VEENA ENCLAVE MUNDKA,MUNDKA INDUSTRIAL AREA MUNDKA,WEST CABIN BLOCK MUNDKA	3013	Other Outage	Planned Outage	11-11-2025	10:19	11-11-2025	12:46	2:27	0.002042	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1242	11-11-2025	Part of : JOHAR VILLAGE NANGLOI EXTENSION NANGLOI	606	Other Outage	Planned Outage	11-11-2025	10:59	11-11-2025	13:58	2:59	0.002486	REPLACEMENT OF HT BUSHING ROD
1243	12-11-2025	Part of : VEENA ENCLAVE MUNDKA	219	Other Outage	Planned Outage	12-11-2025	11:37	12-11-2025	14:21	2:44	0.000911	REPLACEMENT OF HT BUSHING ROD
1244	12-11-2025	Part of : JOHAR VILLAGE NANGLOI EXTENSION NANGLOI	354	Other Outage	Planned Outage	12-11-2025	10:35	12-11-2025	14:05	3:30	0.001750	REPLACEMENT OF HT BUSHING ROD
1245	13-11-2025	Part of : TIKRI KALAN	551	Other Outage	Planned Outage	13-11-2025	10:54	13-11-2025	11:46	0:52	0.001156	REPLACEMENT OF GAS KIT AND OIL SEAL
1246	13-11-2025	Part of : TIKRI KALAN	879	Other Outage	Planned Outage	13-11-2025	11:27	13-11-2025	14:13	2:46	0.000922	LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1247	13-11-2025	Part of : JOHAR VILLAGE NANGLOI EXTENSION NANGLOI	391	Other Outage	Planned Outage	13-11-2025	11:17	13-11-2025	13:28	2:11	0.001092	REPLACEMET OF HT BUSHING ROD
1248	13-11-2025	Part of : BLOCK A TYAGI VIHAR MUNDKA	62	Other Outage	Planned Outage	13-11-2025	11:39	13-11-2025	14:07	2:28	0.000822	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1249	13-11-2025	Part of : BLOCK A TYAGI VIHAR MUNDKA	1	Other Outage	Planned Outage	13-11-2025	11:38	13-11-2025	14:11	2:33	0.000850	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1250	14-11-2025	Part of : RATAN BAGH NANGLOI	930	Other Outage	Planned Outage	14-11-2025	12:07	14-11-2025	14:12	2:05	0.001736	PREVENTIVE MAINTENANCE
1251	14-11-2025	Part of : JAI VIHAR KAMARUDDIN NAGAR	267	Other Outage	Planned Outage	14-11-2025	11:07	14-11-2025	14:00	2:53	0.000961	PREVENTIVE MAINTENANCE
1252	15-11-2025	Part of : MUNDKA EXTENSION	2	Other Outage	Planned Outage	15-11-2025	11:15	15-11-2025	13:07	1:52	0.000467	LT AB SAGGING PER SPAN
1253	15-11-2025	Part of : RANHOLLA	567	Other Outage	Planned Outage	15-11-2025	10:26	15-11-2025	13:07	2:41	0.001565	CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE
1254	15-11-2025	Part of : BAKKARWALA VILLAGE BAKARWALA	614	Other Outage	Planned Outage	15-11-2025	11:14	15-11-2025	14:37	3:23	0.002256	REPLACEMENT OF HT BUSHING ROD
1255	15-11-2025	Part of : RATAN BAGH NANGLOI	1163	Other Outage	Planned Outage	15-11-2025	11:01	15-11-2025	14:38	3:37	0.002411	REPLACEMENT OF HT BUSHING ROD
1256	16-11-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	0	Other Outage	Unplanned Outage	16-11-2025	07:03	16-11-2025	07:39	0:36	0.000380	CABLE FAULT
1257	16-11-2025	Part of : MUNDKA INDUSTRIAL AREA	47	Other Outage	Planned Outage	16-11-2025	13:39	16-11-2025	16:35	2:56	0.004889	REPLACEMENT OF HT BUSHING ROD
1258	16-11-2025	Part of : MUNDKA INDUSTRIAL AREA	37	Other Outage	Planned Outage	16-11-2025	13:09	16-11-2025	15:45	2:36	0.000867	REPLACEMENT OF HT BUSHING ROD
1259	16-11-2025	Part of : MUNDKA INDUSTRIAL AREA	8	Other Outage	Planned Outage	16-11-2025	10:43	16-11-2025	14:01	3:18	0.001100	3PH DB REPLACEMENT
1260	16-11-2025	Part of : MUNDKA INDUSTRIAL AREA	39	Other Outage	Planned Outage	16-11-2025	10:13	16-11-2025	13:08	2:55	0.000972	REPLACEMENT OF GAS KIT AND OIL SEAL
1261	17-11-2025	Part of : MUNDKA EXTENSION	2	Other Outage	Unplanned Outage	17-11-2025	15:58	17-11-2025	16:40	0:42	0.000012	CABLE FAULT
1262	17-11-2025	Part of : AMAR COLONY NANGLOI EXTENSION NANGLOI	1457	Other Outage	Planned Outage	17-11-2025	12:36	17-11-2025	15:13	2:37	0.001744	REPLACEMENT OF HT BUSHING ROD
1263	17-11-2025	Part of : BLOCK D KUNWAR SINGH NAGAR KAMARUDDIN NAGAR	1120	Other Outage	Planned Outage	17-11-2025	10:52	17-11-2025	13:43	2:51	0.000950	REPLACEMENT OF HT BUSHING ROD
1264	17-11-2025	Part of : TIKRI KALAN	880	Other Outage	Planned Outage	17-11-2025	10:36	17-11-2025	13:40	3:04	0.001022	CONDUCTOR REPLACEMENT PER SPAN
1265	18-11-2025	Part of : BLOCK C TYAGI VIHAR MUNDKA,	2	Other Outage	Planned Outage	18-11-2025	10:49	18-11-2025	13:14	2:25	0.002819	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1266	19-11-2025	Part of : MUNDKA EXTENSION	9	Other Outage	Planned Outage	19-11-2025	15:41	19-11-2025	16:52	1:11	0.000394	REPLACEMENT OF HT BUSHING ROD
1267	20-11-2025	Part of : VEENA ENCLAVE MUNDKA	60	Other Outage	Planned Outage	20-11-2025	15:03	20-11-2025	16:25	1:22	0.000456	REPLACEMENT OF HT BUSHING ROD
1268	20-11-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	1535	Other Outage	Planned Outage	20-11-2025	13:28	20-11-2025	15:46	2:18	0.001150	REPLACEMENT OF HT BUSHING ROD
1269	20-11-2025	Part of : D-BLOC KUNWAR SINGH NAGAR KAMARUDDIN NAGAR,LAXMI PARK COLONY	3402	Other Outage	Planned Outage	20-11-2025	11:22	20-11-2025	14:15	2:53	0.001442	GUARD WIRES SAGGING,JUMPER REPLACEMENT PER POLE
1270	21-11-2025	Part of : BAKKARWALA VILLAGE	511	Other Outage	Planned Outage	21-11-2025	15:02	21-11-2025	16:45	1:43	0.000858	REPLACEMET OF HT BUSHING ROD
1271	21-11-2025	Part of : TIKRI KALAN	881	Other Outage	Planned Outage	21-11-2025	13:22	21-11-2025	14:27	1:05	0.000181	CONDUCTOR REPLACEMENT PER SPAN
1272	21-11-2025	Part of : RATAN BAGH NANGLOI	931	Other Outage	Planned Outage	21-11-2025	11:29	21-11-2025	13:15	1:46	0.000883	REPLACEMET OF HT BUSHING ROD
1273	21-11-2025	Part of : RANHOLLA	386	Other Outage	Planned Outage	21-11-2025	13:12	21-11-2025	16:03	2:51	0.000950	SUB STATION CLEANING
1274	22-11-2025	Part of : MUNDKA EXTENSION MUNDKA,	2	Other Outage	Planned Outage	22-11-2025	17:13	22-11-2025	17:42	0:29	0.000081	LT AB SAGGING PER SPAN
1275	22-11-2025	Part of : BLOCK C JJ COLONY 2 NANGLOI,	2591	Other Outage	Planned Outage	22-11-2025	11:50	22-11-2025	13:13	1:23	0.000461	CONDUCTOR REPLACEMENT PER SPAN
1276	22-11-2025	Part of : RAJENDRA PARK NANGLOI EXTENSION NANGLOI,TYAGI COLONY NANGLOI EXTENSION NANGLOI,BLOCK B YADAV PARK NANGLOI EXTENSION NANGLOI,	1146	Other Outage	Planned Outage	22-11-2025	12:00	22-11-2025	13:11	1:11	0.000394	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1277	22-11-2025	Part of : RANHOLLA,	567	Other Outage	Planned Outage	22-11-2025	10:35	22-11-2025	13:12	2:37	0.000872	CONDUCTOR REPLACEMENT PER SPAN
1278	23-11-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA	8	Other Outage	Planned Outage	23-11-2025	15:13	23-11-2025	16:05	0:52	0.000144	CONDUCTOR REPLACEMENT PER SPAN,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
1279	23-11-2025	Part of : GULSHAN PARK WEST CABIN BLOCK MUNDKA	12	Other Outage	Planned Outage	23-11-2025	15:12	23-11-2025	16:06	0:54	0.000150	CONDUCTOR REPLACEMENT PER SPAN,INSTALLATION OF PHASE SEPERATOR PER SPAN
1280	23-11-2025	Part of : BLOCK C MUNDKA	54	Other Outage	Planned Outage	23-11-2025	12:03	23-11-2025	15:05	3:02	0.002022	CONDUCTOR REPLACEMENT PER SPAN
1281	23-11-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA	60	Other Outage	Planned Outage	23-11-2025	10:33	23-11-2025	13:22	2:49	0.001878	REPLACEMENT OF HT BUSHING ROD
1282	23-11-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA	8	Other Outage	Planned Outage	23-11-2025	08:46	23-11-2025	12:06	3:20	0.000556	CONDUCTOR REPLACEMENT PER SPAN,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER
1283	24-11-2025	Part of : MUNDKA EXTENSION	2	Other Outage	Planned Outage	24-11-2025	13:59	24-11-2025	15:49	1:50	0.000611	REPLACEMENT OF HT BUSHING ROD
1284	24-11-2025	Part of : AAKASH VIHAR	858	Other Outage	Planned Outage	24-11-2025	14:06	24-11-2025	15:47	1:41	0.000421	REPLACEMENT OF HT BUSHING ROD
1285	24-11-2025	Part of : BABA HARIDAS NAGAR TIKRI KALAN	1503	Other Outage	Planned Outage	24-11-2025	10:53	24-11-2025	12:20	1:27	0.000725	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1286	24-11-2025	Part of : RATAN BAGH NANGLOI	1038	Other Outage	Planned Outage	24-11-2025	11:55	24-11-2025	14:02	2:07	0.001058	REPLACEMENT OF HT BUSHING ROD
1287	24-11-2025	Part of : LAXMI PARK COLONY,MUNDKA EXTENSION,C-BLOCK MUNDKA,MUNDKA VILLAGE,FRIENDS COLONY	2908	Other Outage	Planned Outage	24-11-2025	11:54	24-11-2025	14:03	2:09	0.000717	REPLACEMENT OF HT BUSHING ROD
1288	25-11-2025	Part of : BAKKARWALA VILLAGE	553	Other Outage	Planned Outage	25-11-2025	14:56	25-11-2025	16:33	1:37	0.000539	REPLACEMET OF HT BUSHING ROD
1289	25-11-2025	Part of : BLOCK C MUNDKA	43	Other Outage	Planned Outage	25-11-2025	14:56	25-11-2025	16:32	1:36	0.000533	REPLACEMET OF HT BUSHING ROD
1290	25-11-2025	Part of : NEELWAL VILLAGE	72	Other Outage	Planned Outage	25-11-2025	15:02	25-11-2025	16:30	1:28	0.000489	REPLACEMET OF HT BUSHING ROD
1291	25-11-2025	Part of : RANHOLLA	1171	Other Outage	Planned Outage	25-11-2025	12:06	25-11-2025	13:15	1:09	0.000383	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS
1292	26-11-2025	Part of : NEELWAL VILLAGE,	10	Other Outage	Planned Outage	26-11-2025	15:47	26-11-2025	16:50	1:03	0.000263	REPLACEMENT OF LT BUSHING ROD
1293	26-11-2025	Part of : BAKKARWALA VILLAGE BAKARWALA,JJ COLONY BAKARWALA,MUNDKA INDUSTRIAL AREA MUNDKA,	5575	Other Outage	Planned Outage	26-11-2025	15:49	26-11-2025	16:51	1:02	0.000861	REPLACEMENT OF LT BUSHING ROD
1294	26-11-2025	Part of : BLOCK B MUNDKA,SAVITA VIHAR MUNDKA,FRIENDS COLONY MUNDKA,BLOCK C MUNDKA,BLOCK D MUNDKA,	5110	Other Outage	Planned Outage	26-11-2025	14:28	26-11-2025	15:59	1:31	0.000000	REPLACEMET OF HT BUSHING ROD
1295	26-11-2025	Part of : RATAN BAGH NANGLOI,	2077	Other Outage	Planned Outage	26-11-2025	14:27	26-11-2025	15:58	1:31	0.000506	REPLACEMENT OF GAS KIT AND OIL SEAL
1296	26-11-2025	Part of : BANI AIR FORCE CAMP JAI VIHAR BAPROLA,NIRMAL VIHAR BAPROLA,	1400	Other Outage	Planned Outage	26-11-2025	11:00	26-11-2025	12:58	1:58	0.000983	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1297	27-11-2025	Part of : BLOCK 4 ABC NANGLOI EXTENSION NANGLOI	2085	Other Outage	Planned Outage	27-11-2025	12:05	27-11-2025	13:51	1:46	0.000883	REPLACEMENT OF HT BUSHING ROD
1298	27-11-2025	Part of : RATAN BAGH NANGLOI,BLOCK A, 1B & 4 ABC NANGLOI EXTENSION NANGLOI	4605	Other Outage	Planned Outage	27-11-2025	12:12	27-11-2025	14:58	2:46	0.001383	REPLACEMENT OF HT BUSHING ROD
1299	27-11-2025	Part of : BLOCK C MUNDKA	674	Other Outage	Planned Outage	27-11-2025	11:57	27-11-2025	14:56	2:59	0.001492	REPLACEMENT OF HT BUSHING ROD
1300	28-11-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	1141	Other Outage	Unplanned Outage	28-11-2025	03:49	28-11-2025	04:24	0:35	0.000165	CABLE FAULT
1301	28-11-2025	Part of : JAI VIHAR KAMARUDDIN NAGAR	266	Other Outage	Planned Outage	28-11-2025	13:52	28-11-2025	15:44	1:52	0.000467	REPLACEMET OF HT BUSHING ROD
1302	28-11-2025	Part of : MUNDKA INDUSTRIAL AREA	149	Other Outage	Planned Outage	28-11-2025	11:15	28-11-2025	13:55	2:40	0.000889	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS
1303	28-11-2025	Part of : MUNDKA VILLAGE	57	Other Outage	Planned Outage	28-11-2025	10:34	28-11-2025	13:43	3:09	0.001050	REPLACEMET OF HT BUSHING ROD
1304	01-11-2025	Part of : PHASE 1 OM VIHAR NAWADA	627	Other Outage	Planned Outage	01-11-2025	12:52	01-11-2025	14:04	1:12	0.000000	DT REPLACEMENT
1305	01-11-2025	Part of : BLOCK C VIPIN GARDEN NAWADA	1099	Other Outage	Planned Outage	01-11-2025	13:42	01-11-2025	16:14	2:32	0.000000	GUARD WIRES SAGGING PER SPAN
1306	01-11-2025	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD,RAZA PUR KHURD VIKAS NAGAR	1460	Other Outage	Planned Outage	01-11-2025	13:16	01-11-2025	15:39	2:23	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1307	02-11-2025	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,	2197	Other Outage	Unplanned Outage	02-11-2025	16:10	02-11-2025	17:24	1:14	0.000617	POLE ERECTION/ STRAIGHTENING
1308	03-11-2025	Part of : VIPIN GARDEN EXTENSION NAWADA,SAINIK ENCLAVE VIPIN GARDEN NAWADA	4580	Other Outage	Unplanned Outage	03-11-2025	11:35	03-11-2025	12:54	1:19	0.000000	REPAIRING OF O/H CIRCUIT
1309	03-11-2025	PART OF : BLOCK M ZAILDAR ENCLAVE HASTSAL	1401	Other Outage	Planned Outage	03-11-2025	14:33	03-11-2025	16:03	1:30	0.000000	DT REPLACEMET PER DT
1310	03-11-2025	PART OF : BLOCK B SEWAK PARK DWARKA	1322	Other Outage	Planned Outage	03-11-2025	14:35	03-11-2025	16:02	1:27	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1311	03-11-2025	PART OF : BLOCK K 4, K5 & K7 ZAILDAR ENCLAVE HASTSAL,A,B&C-BLOCK MAHARANI ENCLAVE,RAJAN VIHAR AND D-BLOCK VIJAY NAGAR	1572	Other Outage	Planned Outage	03-11-2025	11:28	03-11-2025	12:50	1:22	0.000000	DT REPLACEMET PER DT
1312	03-11-2025	PART OF : BLOCK E, L, H & DBHAGWATI GARDEN NAWADA	3436	Other Outage	Planned Outage	03-11-2025	11:55	03-11-2025	14:33	2:38	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1313	03-11-2025	PART OF : BLOCK W, WE, R & RK MOHAN GARDEN RAZAPUR KHURD	1887	Other Outage	Planned Outage	03-11-2025	11:23	03-11-2025	13:46	2:23	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1314	03-11-2025	PART OF : SAINIK ENCLAVE VIPIN GARDEN NAWADA	1197	Other Outage	Planned Outage	03-11-2025	13:47	03-11-2025	16:04	2:17	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1315	04-11-2025	Part of : PHASE 2 OM VIHAR NAWADA	740	Other Outage	Planned Outage	04-11-2025	14:34	04-11-2025	16:08	1:34	0.000522	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1316	04-11-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,WE & RK - BLOCK MOHAN GARDEN RAZAPUR KHURD	2306	Other Outage	Planned Outage	04-11-2025	13:11	04-11-2025	15:31	2:20	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1317	04-11-2025	Part of : SAINIK ENCLAVE,VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA,LAXMI VIHAR	6421	Other Outage	Planned Outage	04-11-2025	12:53	04-11-2025	16:06	3:13	0.000000	GUARD WIRE LACS INSTALLTION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1318	04-11-2025	Part of : C-BLOCK VIPIN GARDEN NAWADA	1099	Other Outage	Planned Outage	04-11-2025	12:52	04-11-2025	16:05	3:13	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1319	04-11-2025	Part of : OM VIHAR PHASE-1 NAWADA	753	Other Outage	Planned Outage	04-11-2025	11:44	04-11-2025	13:50	2:06	0.000000	DT REPLACEMENT PER DT
1320	04-11-2025	Part of : A-BLOCK RAMA PARK BHAGWATI GARDEN NAWADA	135	Other Outage	Planned Outage	04-11-2025	11:19	04-11-2025	13:36	2:17	0.000761	HT AB SAGGING
1321	04-11-2025	Part of : R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	324	Other Outage	Planned Outage	04-11-2025	11:17	04-11-2025	13:19	2:02	0.000000	LT CIRCUIT MAINTENANCE WORK
1322	05-11-2025	Part of : BLOCK P,R1,R5 & WE MOHAN GARDEN RAZAPUR KHURD, Z BLOCK COMMERCIAL ENCLAVE, BLOCK Q RAJAPUR KHURD	4993	Other Outage	Unplanned Outage	05-11-2025	10:14	05-11-2025	10:53	0:39	0.000293	HT SYSTEM FAULT
1323	05-11-2025	Part of : MOHAN GARDEN RAZAPUR KHURD, RAZA PUR KHURD VIKAS NAGAR, BLOCK S BARAT GHAR	6815	Other Outage	Unplanned Outage	05-11-2025	02:49	05-11-2025	03:28	0:39	0.000000	HVDS FAULT
1324	05-11-2025	Part of : BLOCK E BHAGWATI GARDEN NAWADA,BLOCK A & B MAHAVIR ENCLAVE NAWADA,BLOCK F ZAILDAR ENCLAVE NAWADA	4072	Other Outage	Unplanned Outage	05-11-2025	11:50	05-11-2025	13:46	1:56	0.000000	ATTEND WEAK POINT/HOT SPOT
1325	05-11-2025	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD	921	Other Outage	Planned Outage	05-11-2025	13:57	05-11-2025	17:01	3:04	0.000000	DT REPLACEMENT
1326	06-11-2025	NAWADA EXTENSION NAWADA	4156	Other Outage	Unplanned Outage	06-11-2025	23:14	06-11-2025	23:39	0:25	0.000382	CABLE FAULT
1327	06-11-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD	4649	Other Outage	Unplanned Outage	06-11-2025	21:59	06-11-2025	23:07	1:08	0.001171	CABLE FAULT
1328	06-11-2025	Part of : BLOCK D BHAGWATI GARDEN NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,LAXMI VIHAR NAWADA,BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,ROSHAN GARDEN BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA,	5106	Other Outage	Planned Outage	06-11-2025	12:57	06-11-2025	15:42	2:45	0.000000	GUARD WIRES SAGGING PER SPAN
1329	06-11-2025	Part of : BLOCK C VIPIN GARDEN NAWADA,	1099	Other Outage	Planned Outage	06-11-2025	12:52	06-11-2025	15:43	2:51	0.000000	GUARD WIRES SAGGING PER SPAN
1330	06-11-2025	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK N 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK S MOHAN GARDEN RAZAPUR KHURD,BLOCK E BHAGWATI GARDEN NAWADA	6326	Other Outage	Planned Outage	06-11-2025	12:14	06-11-2025	14:49	2:35	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1331	06-11-2025	Part of : PHASE 1 OM VIHAR NAWADA,	329	Other Outage	Planned Outage	06-11-2025	11:16	06-11-2025	13:30	2:14	0.000000	DT REPLACEMENT
1332	07-11-2025	Part of : LAXMI VIHAR NAWADA	1765	Other Outage	Planned Outage	07-11-2025	11:33	07-11-2025	13:26	1:53	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1333	07-11-2025	Part of : SAINIK ENCLAVE VIPIN GARDEN NAWADA	1198	Other Outage	Planned Outage	07-11-2025	13:11	07-11-2025	15:50	2:39	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1334	07-11-2025	Part of : PHASE 2 OM VIHAR NAWADA	1168	Other Outage	Planned Outage	07-11-2025	11:10	07-11-2025	13:27	2:17	0.000000	DT REPLACEMENT
1335	07-11-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	1580	Other Outage	Planned Outage	07-11-2025	12:07	07-11-2025	14:00	1:53	0.000000	3PH DB REVAMPING
1336	08-11-2025	Part of : R,R1,R5, P2, N1,N2 & S-BLOCK MOHAN GARDEN RAZAPUR KHURD,M-BLOCK ZAILDAR ENCLAVE HASTSAL	5058	Other Outage	Unplanned Outage	08-11-2025	08:02	08-11-2025	08:11	0:09	0.000138	BIRDAGE
1337	08-11-2025	Part of : D-BLOCK MANSAL RAM PARK UTTAM NAGAR	1614	Other Outage	Unplanned Outage	08-11-2025	13:58	08-11-2025	15:08	1:10	0.000039	CABLE FAULT
1338	08-11-2025	Part of : SAINIK ENCLAVE,VIPIN GARDEN EXTENSION,VIPIN GARDEN NAWADA	4581	Other Outage	Unplanned Outage	08-11-2025	11:25	08-11-2025	12:20	0:55	0.000000	REPAIRING OF RMU
1339	08-11-2025	Part of : H-BLOCK BHAGWATI GARDEN NAWADA	838	Other Outage	Planned Outage	08-11-2025	11:45	08-11-2025	13:36	1:51	0.000000	3PH HT AB CABLE REPLACEMENT
1340	08-11-2025	Part of : BHAGWATI GARDEN NAWADA	128	Other Outage	Planned Outage	08-11-2025	12:54	08-11-2025	15:55	3:01	0.000000	DT REPLACEMENT
1341	08-11-2025	Part of : P & P 2-BLOCK MOHAN GARDEN RAZAPUR KHURD	1314	Other Outage	Planned Outage	08-11-2025	11:19	08-11-2025	13:35	2:16	0.000000	3PH HT AB CABLE REPLACEMENT
1342	08-11-2025	Part of : SHYAM PARK NAWADA MAJRA VILLAGE,NAWADA EXTENSION,OM VIHAR PHASE 2	2540	Other Outage	Planned Outage	08-11-2025	11:29	08-11-2025	13:37	2:08	0.000000	DT REPLACEMENT
1343	08-11-2025	Part of : R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	207	Other Outage	Planned Outage	08-11-2025	12:53	08-11-2025	15:55	3:02	0.000000	LT CIRCUIT NETWORK UPGRADATION
1344	09-11-2025	Part of : ROSHAN GARDEN BHAGWATI GARDEN NAWADA	187	Other Outage	Planned Outage	09-11-2025	09:56	09-11-2025	13:36	3:40	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1345	10-11-2025	Part of : BLOCK K 4 ZAILDAR ENCLAVE HASTSAL,A,B&C-BLOCK MAHARANI ENCLAVE,BLOCK K 5 ZAILDAR ENCLAVE HASTSAL,RAJAN VIHAR AND D-BLOCK VIJAY NAGAR,BLOCK K 7 ZAILDAR ENCLAVE HASTSAL,	1572	Other Outage	Planned Outage	10-11-2025	16:00	10-11-2025	16:42	0:42	0.000000	MAINTENANCE
1346	10-11-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,	135	Other Outage	Planned Outage	10-11-2025	12:42	10-11-2025	13:40	0:58	0.000000	LT CIRCUIT NETWORK UPGRADATION
1347	10-11-2025	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,	3653	Other Outage	Planned Outage	10-11-2025	14:54	10-11-2025	16:35	1:41	0.000000	MAINTENANCE
1348	10-11-2025	Part of : BLOCK H BHAGWATI GARDEN NAWADA,	4	Other Outage	Planned Outage	10-11-2025	12:25	10-11-2025	13:38	1:13	0.000000	LT CIRCUIT NETWORK UPGRADATION
1349	10-11-2025	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,RAZAPUR KHURD,	1758	Other Outage	Planned Outage	10-11-2025	14:13	10-11-2025	16:36	2:23	0.000000	MAINTENANCE
1350	11-11-2025	Part of : RAZAPUR KHURD,BLOCK N 2 & N3 MOHAN GARDEN RAZAPUR KHURD,K5 & K6 AND DEFENCE ENCLAVE PART-1 MOHAN GARDEN	3602	Other Outage	Unplanned Outage	11-11-2025	20:58	11-11-2025	21:23	0:25	0.000000	HVDS FAULT
1351	11-11-2025	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA,SAINIK ENCLAVE VIPIN GARDEN NAWADA	4581	Other Outage	Unplanned Outage	11-11-2025	05:02	11-11-2025	05:43	0:41	0.000456	BIRDAGE
1352	11-11-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK A MAHAVIR ENCLAVE NAWADA,BLOCK B BHAGWATI GARDEN NAWADA	471	Other Outage	Unplanned Outage	11-11-2025	11:26	11-11-2025	12:46	1:20	0.000444	JUMPER REPLACEMENT
1353	11-11-2025	Part of : SHYAM PARK NAWADA MAJRA VILLAGE NAWADA,NAWADA MAJRA VILLAGE NAWADA	270	Other Outage	Unplanned Outage	11-11-2025	11:19	11-11-2025	12:45	1:26	0.000478	REPAIRING OF TRANSFORMER
1354	11-11-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	207	Other Outage	Planned Outage	11-11-2025	14:21	11-11-2025	16:00	1:39	0.000000	DT REPLACEMENT
1355	11-11-2025	Part of : BLOCK A, B, D & H BHAGWATI GARDEN NAWADA,LAXMI VIHAR NAWADA,ROSHAN GARDEN BHAGWATI GARDEN NAWADA	5106	Other Outage	Planned Outage	11-11-2025	11:23	11-11-2025	13:49	2:26	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1356	11-11-2025	Part of : BHAGWATI GARDEN NAWADA	1122	Other Outage	Planned Outage	11-11-2025	12:54	11-11-2025	15:59	3:05	0.000000	DT REPLACEMENT
1357	11-11-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD	385	Other Outage	Planned Outage	11-11-2025	12:32	11-11-2025	14:39	2:07	0.000000	DT REPLACEMENT
1358	11-11-2025	Part of : SAINIK ENCLAVE VIPIN GARDEN NAWADA	1198	Other Outage	Planned Outage	11-11-2025	12:31	11-11-2025	14:41	2:10	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1359	12-11-2025	Part of : C,D,E,F & R-BLOCK NAWADA HOUSING COMP,BHAGWATI GARDEN EXTN,BG-BLOCK MOHANGARDEN,AMAR SHOPPING COMPLEX,SIDDHARTHI ENCLAVE,DWARKA MOR	7969	Other Outage	Unplanned Outage	12-11-2025	08:23	12-11-2025	08:50	0:27	0.000263	CABLE FAULT
1360	12-11-2025	Part of : H-BLOCK BHAGWATI GARDEN NAWADA,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	4129	Other Outage	Unplanned Outage	12-11-2025	15:26	12-11-2025	16:02	0:36	0.000400	HT SYSTEM FAULT
1361	12-11-2025	Part of : SHYAM PARK,NAWADA MAJRA VILLAGE	270	Other Outage	Unplanned Outage	12-11-2025	11:30	12-11-2025	12:48	1:18	0.000433	REPAIRING OF TRANSFORMER
1362	12-11-2025	Part of : PHASE 2 OM VIHAR NAWADA	1197	Other Outage	Planned Outage	12-11-2025	14:33	12-11-2025	15:58	1:25	0.000944	REPLACEMENT OF HT BUSHING ROD
1363	12-11-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	207	Other Outage	Planned Outage	12-11-2025	11:48	12-11-2025	13:34	1:46	0.000000	LT CIRCUIT MAINTENANCE
1364	13-11-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD	721	Other Outage	Planned Outage	13-11-2025	14:27	13-11-2025	15:26	0:59	0.000000	3PH DB REPLACEMENT
1365	13-11-2025	Part of : RAZAPUR KHURD,VIKAS KUNJ AND VIKAS KUNJ EXTN.	867	Other Outage	Planned Outage	13-11-2025	13:13	13-11-2025	15:24	2:11	0.000000	DT REPLACEMET PER DT
1366	13-11-2025	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA	940	Other Outage	Planned Outage	13-11-2025	11:38	13-11-2025	13:51	2:13	0.001478	REPLACEMENT OF CROSS-ARMS AND POLES
1367	13-11-2025	Part of : NAWADA EXTENSION NAWADA	134	Other Outage	Planned Outage	13-11-2025	10:59	13-11-2025	13:47	2:48	0.000000	REPLACEMET OF HT BUSHING ROD
1368	14-11-2025	Part of : BLOCK RK MOHAN GARDEN RAZAPUR KHURD,RAZA PUR KHURD VIKAS NAGAR	4041	Other Outage	Unplanned Outage	14-11-2025	04:26	14-11-2025	05:20	0:54	0.000000	CABLE FAULT
1369	14-11-2025	Part of : JAI BHARAT ENCLAVE BHAGWATI GARDEN NAWADA	903	Other Outage	Unplanned Outage	14-11-2025	11:09	14-11-2025	12:22	1:13	0.000406	LT CONDUCTOR REPLACEMET
1370	14-11-2025	Part of : R 5 BLOCK MOHAN GARDEN RAZAPUR KHURD	207	Other Outage	Planned Outage	14-11-2025	14:59	14-11-2025	15:39	0:40	0.000000	LT CIRCUIT NETWORK UPGRADATION
1371	14-11-2025	Part of : PHASE 2 OM VIHAR NAWADA	1197	Other Outage	Planned Outage	14-11-2025	13:26	14-11-2025	14:31	1:05	0.000722	REPLACEMET OF HT BUSHING ROD
1372	14-11-2025	Part of : PHASE 2 OM VIHAR NAWADA	1197	Other Outage	Planned Outage	14-11-2025	10:58	14-11-2025	12:45	1:47	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
1373	14-11-2025	Part of : NAWADA EXTENSION NAWADA	648	Other Outage	Planned Outage	14-11-2025	13:37	14-11-2025	15:39	2:02	0.000000	NEW LTAB CIRCUIT LAYING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1374	14-11-2025	Part of : RAZAPUR KHURD,SAI& SETHI ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE	852	Other Outage	Planned Outage	14-11-2025	12:04	14-11-2025	14:31	2:27	0.000000	DT REPLACEMET PER DT
1375	14-11-2025	Part of : PHASE 1 OM VIHAR NAWADA	999	Other Outage	Planned Outage	14-11-2025	11:20	14-11-2025	13:38	2:18	0.000000	MAINTENANCE
1376	15-11-2025	Part of : BLOCK B BHAGWATI GARDEN NAWADA	1343	Other Outage	Unplanned Outage	15-11-2025	14:21	15-11-2025	15:47	1:26	0.000000	ATTENDING WEAK POINTS/HOT SPOT
1377	15-11-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	1251	Other Outage	Planned Outage	15-11-2025	14:23	15-11-2025	16:43	2:20	0.000000	DT REPLACEMENT PER DT
1378	15-11-2025	Part of : PHASE 2 OM VIHAR NAWADA	955	Other Outage	Planned Outage	15-11-2025	11:12	15-11-2025	13:57	2:45	0.000000	REPLACEMENT OF HT BUSHING ROD
1379	17-11-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA	1523	Other Outage	Unplanned Outage	17-11-2025	11:58	17-11-2025	13:39	1:41	0.000561	REPAIR OF RMU
1380	17-11-2025	Part of : BLOCK K 4 &5 ZAILDAR ENCLAVE HASTSAL,A,B&C-BLOCK MAHARANI ENCLAVE	1572	Other Outage	Planned Outage	17-11-2025	14:17	17-11-2025	16:28	2:11	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1381	17-11-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK F ZAILDAR ENCLAVE NAWADA	1401	Other Outage	Planned Outage	17-11-2025	12:07	17-11-2025	14:50	2:43	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1382	17-11-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD	726	Other Outage	Planned Outage	17-11-2025	13:45	17-11-2025	16:53	3:08	0.000000	3PH DB REVAMPING
1383	17-11-2025	Part of : BLOCK H BHAGWATI GARDEN NAWADA	4	Other Outage	Planned Outage	17-11-2025	11:36	17-11-2025	14:49	3:13	0.000000	3PH DB REVAMPING
1384	17-11-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	323	Other Outage	Planned Outage	17-11-2025	11:14	17-11-2025	13:41	2:27	0.000000	3PH DB REPLACEMENT
1385	18-11-2025	Part of : SHANTI PARK DWARKA,BLOCK B SEWAK PARK DWARKA,BLOCK B1 SEWAK PARK DWARKA	1981	Other Outage	Unplanned Outage	18-11-2025	08:29	18-11-2025	09:02	0:33	0.000431	CABLE FAULT
1386	18-11-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD	4671	Other Outage	Unplanned Outage	18-11-2025	02:58	18-11-2025	04:08	1:10	0.000544	CABLE FAULT
1387	18-11-2025	Part of : BLOCK B BHAGWATI GARDEN NAWADA,	1894	Other Outage	Planned Outage	18-11-2025	14:24	18-11-2025	16:46	2:22	0.000000	DT REPLACEMENT
1388	18-11-2025	Part of : PHASE 1 OM VIHAR NAWADA,	1009	Other Outage	Planned Outage	18-11-2025	14:42	18-11-2025	16:46	2:04	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1389	18-11-2025	Part of : NAWADA EXTENSION NAWADA,	648	Other Outage	Planned Outage	18-11-2025	12:42	18-11-2025	16:45	4:03	0.002700	3PH HT AB CABLE REPLACEMENT PER SPAN
1390	18-11-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,RAZAPUR KHURD,	703	Other Outage	Planned Outage	18-11-2025	11:59	18-11-2025	14:39	2:40	0.001778	3PH HT AB CABLE REPLACEMENT PER SPAN
1391	18-11-2025	Part of : ROSHAN GARDEN BHAGWATI GARDEN NAWADA,	1444	Other Outage	Planned Outage	18-11-2025	10:49	18-11-2025	13:31	2:42	0.001800	REPLACEMENT OF CROSS-ARMS AND POLES
1392	18-11-2025	Part of : PHASE 1 OM VIHAR NAWADA,	753	Other Outage	Planned Outage	18-11-2025	11:03	18-11-2025	13:33	2:30	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1393	19-11-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,RAZAPUR KHURD,VIKAS KUNJ AND VIKAS KUNJ EXTN.,SAI& SETHI ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE	5193	Other Outage	Unplanned Outage	19-11-2025	01:19	19-11-2025	01:52	0:33	0.000220	CABLE FAULT
1394	19-11-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD	385	Other Outage	Planned Outage	19-11-2025	15:16	19-11-2025	16:16	1:00	0.000000	3PH DB REPLACEMENT
1395	19-11-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	209	Other Outage	Planned Outage	19-11-2025	12:29	19-11-2025	14:17	1:48	0.000000	3PH DB REPLACEMENT
1396	19-11-2025	Part of : BLOCK H BHAGWATI GARDEN NAWADA	4	Other Outage	Planned Outage	19-11-2025	11:52	19-11-2025	13:42	1:50	0.000000	3PH DB REPLACEMENT
1397	19-11-2025	Part of : BHAGWATI GARDEN NAWADA	1246	Other Outage	Planned Outage	19-11-2025	14:15	19-11-2025	16:15	2:00	0.000000	REPLACEMENT OF HT BUSHING ROD
1398	19-11-2025	Part of : BHAGWATI GARDEN NAWADA	1250	Other Outage	Planned Outage	19-11-2025	11:06	19-11-2025	13:39	2:33	0.001700	REPLACEMENT OF HT BUSHING ROD
1399	19-11-2025	Part of : PHASE 1 OM VIHAR NAWADA	999	Other Outage	Planned Outage	19-11-2025	11:27	19-11-2025	13:39	2:12	0.000000	DT REPLACEMENT
1400	19-11-2025	Part of : BHAGWATI GARDEN NAWADA	128	Other Outage	Planned Outage	19-11-2025	11:07	19-11-2025	13:41	2:34	0.000000	REPLACEMENT OF LT BUSHING ROD
1401	20-11-2025	Part of : C-BLOCK VIPIN GARDEN NAWADA,R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD,SAINIK ENCLAVE	4127	Other Outage	Unplanned Outage	20-11-2025	10:41	20-11-2025	11:22	0:41	0.000319	HT SYSTEM FAULT
1402	20-11-2025	Part of : A,B,D & H-BLOCK BHAGWATI GARDEN,LAXMI VIHAR,ROSHAN GARDEN	6214	Other Outage	Unplanned Outage	20-11-2025	10:07	20-11-2025	11:25	1:18	0.000000	REPAIRING OF RMU
1403	20-11-2025	Part of : LAXMI VIHAR NAWADA	789	Other Outage	Unplanned Outage	20-11-2025	12:34	20-11-2025	13:55	1:21	0.001125	REPAIRING OF LT ACB
1404	20-11-2025	Part of : R1, R5,N1,N2,P2 & S-BLOCK MOHAN GARDEN RAZAPUR KHURD,M-BLOCK ZAILDAR ENCLAVE HASTSAL,E-BLOCK BHAGWATI GARDEN NAWADA	6326	Other Outage	Planned Outage	20-11-2025	13:08	20-11-2025	15:06	1:58	0.000000	3PH HT AB CABLE REPLACEMENT
1405	20-11-2025	Part of : OM VIHAR PHASE-2 NAWADA	955	Other Outage	Planned Outage	20-11-2025	11:06	20-11-2025	12:30	1:24	0.000000	LT CIRCUIT MAINTENANCE WORK
1406	20-11-2025	Part of : OM VIHAR PHASE 2 NAWADA	955	Other Outage	Planned Outage	20-11-2025	12:29	20-11-2025	15:05	2:36	0.000000	REPLACEMENT OF HT BUSHING ROD
1407	20-11-2025	Part of : A-BLOCK RAMA PARK BHAGWATI GARDEN NAWADA	135	Other Outage	Planned Outage	20-11-2025	13:07	20-11-2025	15:30	2:23	0.000000	LT CIRCUIT MAINTENANCE WORK

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1408	21-11-2025	Part of : BLOCK P,P2 & R5 MOHAN GARDEN RAZAPUR KHURD, BLOCK B1 SEWAK PARK DWARKA, BLOCK H & L BHAGWATI GARDEN NAWADA	4626	Other Outage	Unplanned Outage	21-11-2025	15:58	21-11-2025	16:59	1:01	0.000000	HT SYSTEM FAULT
1409	21-11-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD	1111	Other Outage	Unplanned Outage	21-11-2025	13:06	21-11-2025	14:52	1:46	0.000589	CONNECTION/DISCONNECTION OF LT CABLE
1410	21-11-2025	Part of : BLOCK D & H BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,LAXMI VIHAR NAWADA	3973	Other Outage	Unplanned Outage	21-11-2025	11:48	21-11-2025	13:20	1:32	0.000767	REPAIRING OF HVDS CIRCUIT
1411	21-11-2025	Part of : BLOCK A & BMAHAVIR ENCLAVE NAWADA	703	Other Outage	Planned Outage	21-11-2025	15:58	21-11-2025	17:54	1:56	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1412	21-11-2025	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA	1676	Other Outage	Planned Outage	21-11-2025	12:54	21-11-2025	15:49	2:55	0.000000	DT REPLACEMENT
1413	21-11-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,RAZAPUR KHURD,BLOCK R MOHAN GARDEN RAZAPUR KHURD	1413	Other Outage	Planned Outage	21-11-2025	12:02	21-11-2025	14:51	2:49	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1414	21-11-2025	Part of : PHASE 1 OM VIHAR NAWADA	1960	Other Outage	Planned Outage	21-11-2025	11:08	21-11-2025	13:23	2:15	0.000000	REPLACEMET OF HT BUSHING ROD
1415	22-11-2025	Part of : BLOCK C VIPIN GARDEN NAWADA,	551	Other Outage	Unplanned Outage	22-11-2025	12:48	22-11-2025	12:56	0:08	0.000000	REPAIRING OF RMU
1416	22-11-2025	Part of : BLOCK C VIPIN GARDEN NAWADA,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,SAINIK ENCLAVE VIPIN GARDEN NAWADA,	4130	Other Outage	Unplanned Outage	22-11-2025	12:57	22-11-2025	14:15	1:18	0.000000	REPAIRING OF RMU
1417	22-11-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,	2551	Other Outage	Planned Outage	22-11-2025	12:00	22-11-2025	14:41	2:41	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1418	22-11-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,	1428	Other Outage	Planned Outage	22-11-2025	12:18	22-11-2025	15:03	2:45	0.000000	DT REPLACEMENT
1419	22-11-2025	Part of : PHASE 2 OM VIHAR NAWADA,	1197	Other Outage	Planned Outage	22-11-2025	11:25	22-11-2025	14:03	2:38	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1420	23-11-2025	Part of : BLOCK WE, R1 & R MOHAN GARDEN RAZAPUR KHURD,RAZA PUR KHURD VIKAS NAGAR,RAZAPUR KHURD	4056	Other Outage	Unplanned Outage	23-11-2025	02:25	23-11-2025	02:58	0:33	0.000422	CABLE FAULT
1421	24-11-2025	Part of : M & F-BLOCK ZAILDAR ENCLAVE HASTSAL	1401	Other Outage	Planned Outage	24-11-2025	14:25	24-11-2025	16:09	1:44	0.000000	3PH HT AB CABLE REPLACEMENT
1422	24-11-2025	Part of : B-BLOCK SEWAK PARK,D & H-BLOCK BHAGWATI GARDEN,LAXMI VIHAR	1322	Other Outage	Planned Outage	24-11-2025	14:33	24-11-2025	16:08	1:35	0.000000	3PH HT AB CABLE REPLACEMENT
1423	24-11-2025	Part of : R-BLOCK MOHAN GARDEN RAZAPUR KHURD	726	Other Outage	Planned Outage	24-11-2025	14:44	24-11-2025	16:42	1:58	0.000000	LT CIRCUIT MAINTENANCE WORK
1424	24-11-2025	Part of : R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	209	Other Outage	Planned Outage	24-11-2025	13:51	24-11-2025	15:32	1:41	0.000000	LT CIRCUIT MAINTENANCE WORK
1425	24-11-2025	Part of : BHAGWATI GARDEN NAWADA	1250	Other Outage	Planned Outage	24-11-2025	13:31	24-11-2025	15:33	2:02	0.000000	REPLACEMENT OF HT BUSHING ROD
1426	24-11-2025	Part of : H-BLOCK BHAGWATI GARDEN, R 5-BLOCK MOHAN GARDEN	4	Other Outage	Planned Outage	24-11-2025	11:19	24-11-2025	13:48	2:29	0.000000	HT CONDUCTOR REPLACEMENT
1427	24-11-2025	Part of : K 4, K 5 & K 7-BLOCK ZAILDAR ENCLAVE,A,B&C-BLOCK MAHARANI ENCLAVE,RAJAN VIHAR,D-BLOCK VIJAY NAGAR	1572	Other Outage	Planned Outage	24-11-2025	11:39	24-11-2025	13:43	2:04	0.000000	3PH HT AB CABLE REPLACEMENT
1428	24-11-2025	Part of : R 1-BLOCK MOHAN GARDEN RAZAPUR KHURD	129	Other Outage	Planned Outage	24-11-2025	11:09	24-11-2025	13:41	2:32	0.000000	LT CIRCUIT MAINTENANCE WORK
1429	25-11-2025	Part of : BLOCK C VIPIN GARDEN NAWADA, SAINIK ENCLAVE NAWADA, BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD, NAWADA HOUSING COMPLEX	4130	Other Outage	Unplanned Outage	25-11-2025	07:22	25-11-2025	08:04	0:42	0.000233	CABLE FAULT
1430	25-11-2025	Part of : BLOCK A,B & C SEWAK PARK DWARKA, BLOCK B1 SEWAK PARK DWARKA, SHANTI PARK DWARKA, DWARKA MOR	3745	Other Outage	Unplanned Outage	25-11-2025	06:49	25-11-2025	07:26	0:37	0.000134	BIRDAGE
1431	25-11-2025	Part of : PHASE 1 OM VIHAR NAWADA	1008	Other Outage	Planned Outage	25-11-2025	14:39	25-11-2025	15:25	0:46	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1432	25-11-2025	Part of : PHASE 1 OM VIHAR NAWADA	751	Other Outage	Planned Outage	25-11-2025	13:06	25-11-2025	15:21	2:15	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1433	25-11-2025	Part of : ROSHAN GARDEN BHAGWATI GARDEN NAWADA	1482	Other Outage	Planned Outage	25-11-2025	12:50	25-11-2025	15:20	2:30	0.000000	REPLACEMET OF FAULTY END BOX
1434	26-11-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,	744	Other Outage	Unplanned Outage	26-11-2025	12:09	26-11-2025	13:42	1:33	0.000258	REPAIRING OF HVDS CIRCUIT
1435	26-11-2025	Part of : PHASE 2 OM VIHAR NAWADA,	1197	Other Outage	Unplanned Outage	26-11-2025	12:04	26-11-2025	13:40	1:36	0.000267	JUMPER REPLACEMENT OF LT CIRCUIT
1436	26-11-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,	726	Other Outage	Planned Outage	26-11-2025	15:10	26-11-2025	16:31	1:21	0.000000	3PH DB REPLACEMENT
1437	26-11-2025	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK P MOHAN GARDEN RAZAPUR KHURD,	1331	Other Outage	Planned Outage	26-11-2025	12:13	26-11-2025	14:31	2:18	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1438	26-11-2025	Part of : BLOCK A BHAGWATI GARDEN EXTENSION BHAGWATI GARDEN NAWADA,BLOCK D BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,BLOCK B BHAGWATI GARDEN NAWADA,	3653	Other Outage	Planned Outage	26-11-2025	11:37	26-11-2025	14:31	2:54	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1439	26-11-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,	105	Other Outage	Planned Outage	26-11-2025	11:07	26-11-2025	13:35	2:28	0.000000	REPLACEMENT OF LT BUSHING ROD
1440	27-11-2025	Part of : LAXMI VIHAR NAWADA,BLOCK A, B, D & H BHAGWATI GARDEN NAWADA	6340	Other Outage	Unplanned Outage	27-11-2025	12:26	27-11-2025	13:19	0:53	0.000398	CABLE FAULT
1441	27-11-2025	Part of : PHASE 1 OM VIHAR NAWADA	2194	Other Outage	Planned Outage	27-11-2025	15:08	27-11-2025	16:08	1:00	0.000000	DT REPLACEMENT
1442	27-11-2025	Part of : BLOCK H BHAGWATI GARDEN NAWADA	838	Other Outage	Planned Outage	27-11-2025	14:19	27-11-2025	16:06	1:47	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1443	27-11-2025	Part of : BLOCK H & R5 BHAGWATI GARDEN NAWADA	4	Other Outage	Planned Outage	27-11-2025	12:15	27-11-2025	14:19	2:04	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1444	27-11-2025	Part of : NAWADA EXTENSION NAWADA	440	Other Outage	Planned Outage	27-11-2025	12:32	27-11-2025	14:54	2:22	0.000000	3PH DB REPLACEMENT
1445	28-11-2025	Part of : A-BLOCK MAHAVIR ENCLAVE NAWADA	383	Other Outage	Unplanned Outage	28-11-2025	16:38	28-11-2025	17:44	1:06	0.000367	LOAD SHIFTING FROM HVDS TRANSFORMER
1446	28-11-2025	Part of : M-BLOCK ZAILDAR ENCLAVE HASTSAL	1428	Other Outage	Planned Outage	28-11-2025	15:13	28-11-2025	16:22	1:09	0.000000	DT REPLACEMENT
1447	28-11-2025	Part of : BHAGWATI GARDEN NAWADA	128	Other Outage	Planned Outage	28-11-2025	14:11	28-11-2025	16:21	2:10	0.000000	3PH DB REPLACEMENT
1448	28-11-2025	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA	1512	Other Outage	Planned Outage	28-11-2025	14:08	28-11-2025	16:20	2:12	0.000000	DT REPLACEMENT
1449	28-11-2025	Part of : M-BLOCK ZAILDAR ENCLAVE HASTSAL	511	Other Outage	Planned Outage	28-11-2025	12:04	28-11-2025	14:35	2:31	0.000000	LT CIRCUIT MAINTENANCE
1450	28-11-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	334	Other Outage	Planned Outage	28-11-2025	12:14	28-11-2025	14:35	2:21	0.000000	LT CIRCUIT MAINTENANCE
1451	29-11-2025	Part of : BLOCK D,E,H & L BHAGWATI GARDEN NAWADA	2635	Other Outage	Unplanned Outage	29-11-2025	11:22	29-11-2025	13:57	2:35	0.000000	REPAIRING OF HVDS CIRCUIT
1452	29-11-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	1	Other Outage	Planned Outage	29-11-2025	12:16	29-11-2025	14:54	2:38	0.000000	DT REPLACEMENT
1453	29-11-2025	Part of : PHASE 1 OM VIHAR NAWADA	998	Other Outage	Planned Outage	29-11-2025	11:10	29-11-2025	13:53	2:43	0.000000	JUMPER REPLACEMENT PER POLE
1454	01-11-2025	Part of : NILOTHI VILLAGE,CHANDER VIHAR,RISALA GARDEN NILOTHI	2266	Other Outage	Planned Outage	01-11-2025	13:07	01-11-2025	14:44	1:37	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
1455	01-11-2025	Part of : GRAM SABHA COLONY,VIKASPURI EXTN,TEACHER VIHAR,GURUNANAK VIHAR	3210	Other Outage	Planned Outage	01-11-2025	14:34	01-11-2025	16:39	2:05	0.000000	3PH HT AB END TERMINATION REPLACEMENT
1456	01-11-2025	Part of : BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI	284	Other Outage	Planned Outage	01-11-2025	12:55	01-11-2025	15:55	3:00	0.000000	REPLACEMET OF HT BUSHING ROD
1457	01-11-2025	Part of : BLOCK GH 12 PASCHIM VIHAR	63	Other Outage	Planned Outage	01-11-2025	13:23	01-11-2025	15:56	2:33	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1458	01-11-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	280	Other Outage	Planned Outage	01-11-2025	13:09	01-11-2025	15:55	2:46	0.000000	REPLACEMET OF HT BUSHING ROD
1459	02-11-2025	Part of : UDYOG NAGAR MANGOLPURI,	11	Other Outage	Planned Outage	02-11-2025	11:10	02-11-2025	14:30	3:20	0.000833	REPLACEMET OF HT BUSHING ROD
1460	02-11-2025	Part of : NANGLOI JAT NANGLOI,	597	Other Outage	Planned Outage	02-11-2025	11:33	02-11-2025	16:17	4:44	0.000789	REPLACEMET OF HT BUSHING ROD
1461	03-11-2025	PART OF : UDAI VIHAR,RANJEET VIHAR	1715	Other Outage	Planned Outage	03-11-2025	14:48	03-11-2025	17:08	2:20	0.000000	TIGHTENING OF HARDWARE FITTINGS
1462	03-11-2025	PART OF : BLOCK A 3 MIYANWALI NAGAR PASCHIM VIHAR	651	Other Outage	Planned Outage	03-11-2025	11:59	03-11-2025	15:00	3:01	0.000000	REPLACEMET OF HT BUSHING ROD
1463	03-11-2025	PART OF : RANHOLLA	973	Other Outage	Planned Outage	03-11-2025	10:57	03-11-2025	14:06	3:09	0.000000	REPLACEMET OF HT BUSHING ROD
1464	03-11-2025	PART OF : BLOCK 2C NANGLOI EXTENSION NANGLOI	291	Other Outage	Planned Outage	03-11-2025	11:08	03-11-2025	14:06	2:58	0.000000	REPLACEMET OF HT BUSHING ROD
1465	03-11-2025	PART OF : EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR	217	Other Outage	Planned Outage	03-11-2025	11:04	03-11-2025	14:05	3:01	0.000000	REPLACEMET OF HT BUSHING ROD
1466	03-11-2025	PART OF : INDER ENCLAVE PASCHIM VIHAR	38	Other Outage	Planned Outage	03-11-2025	11:04	03-11-2025	14:04	3:00	0.000000	REPLACEMET OF HT BUSHING ROD
1467	04-11-2025	Part of : VIKASPURI EXTN,TEACHER VIHAR,GURUNANAK VIHAR,GRAM SABHA COLONY	3212	Other Outage	Planned Outage	04-11-2025	10:59	04-11-2025	14:08	3:09	0.002625	TIGHTENING OF HARDWARE FITTINGS
1468	04-11-2025	Part of : BLOCK 1,5,13 SUNDER VIHAR PASCHIM VIHAR	2051	Other Outage	Planned Outage	04-11-2025	10:56	04-11-2025	14:05	3:09	0.000945	REPLACEMENT OF CROSS-ARMS AND POLES
1469	04-11-2025	Part of : INDER ENCLAVE PASCHIM VIHAR	229	Other Outage	Planned Outage	04-11-2025	12:13	04-11-2025	14:24	2:11	0.000182	LT CIRCUIT MAINTENANCE WORK
1470	04-11-2025	Part of : M-BLOCK JJ COLONY 3 NANGLOI	1019	Other Outage	Planned Outage	04-11-2025	11:24	04-11-2025	14:03	2:39	0.000883	LT CIRCUIT MAINTENANCE WORK
1471	04-11-2025	Part of : JAI VIHAR PH-1 & 3	534	Other Outage	Planned Outage	04-11-2025	10:55	04-11-2025	14:04	3:09	0.001050	LT CIRCUIT MAINTENANCE WORK
1472	06-11-2025	Part of : PRASHANT ENCLAVE,	988	Other Outage	Planned Outage	06-11-2025	14:37	06-11-2025	16:52	2:15	0.000375	REPLACEMET OF HT BUSHING ROD
1473	06-11-2025	Part of : GURUNANAK VIHAR,	401	Other Outage	Planned Outage	06-11-2025	12:36	06-11-2025	15:13	2:37	0.000436	REPLACEMET OF HT BUSHING ROD
1474	06-11-2025	Part of : VIRAT APARTMENT PASCHIM VIHAR,	105	Other Outage	Planned Outage	06-11-2025	11:55	06-11-2025	14:01	2:06	0.000350	REPLACEMET OF HT BUSHING ROD
1475	06-11-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR,	360	Other Outage	Planned Outage	06-11-2025	10:44	06-11-2025	14:18	3:34	0.000594	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1476	06-11-2025	Part of : BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,BLOCK C KAMRUDDIN NAGAR NANGLOI,	1	Other Outage	Planned Outage	06-11-2025	10:48	06-11-2025	14:15	3:27	0.001438	REPLACEMENT OF CROSS-ARMS AND POLES
1477	06-11-2025	Part of : RAO VIHAR NANGLOI,	1412	Other Outage	Planned Outage	06-11-2025	11:01	06-11-2025	14:11	3:10	0.001056	REPLACEMET OF HT BUSHING ROD
1478	06-11-2025	Part of : BLOCK NS MIYANWALI NAGAR PASCHIM VIHAR,	785	Other Outage	Planned Outage	06-11-2025	10:53	06-11-2025	14:16	3:23	0.000846	REPLACEMET OF HT BUSHING ROD
1479	06-11-2025	Part of : BLOCK A MIRA BAGH PASCHIM VIHAR,	74	Other Outage	Planned Outage	06-11-2025	10:50	06-11-2025	14:12	3:22	0.000561	REPLACEMET OF HT BUSHING ROD
1480	07-11-2025	Part of : GH 6 & GH 5 PASCHIM VIHAR,GH 6 WHITE APPARTMENTS PASCHIM VIHAR,BLOCK A MIRA BAGH PASCHIM VIHAR	2695	Other Outage	Unplanned Outage	07-11-2025	14:43	07-11-2025	15:34	0:51	0.000864	CABLE FAULT
1481	07-11-2025	Part of : RISALA GARDEN NILOTHI,NILOTHI VILLAGE,CHANDER VIHAR	1713	Other Outage	Planned Outage	07-11-2025	13:17	07-11-2025	15:46	2:29	0.000000	3PH HT AB END TERMINATION REPLACEMENT
1482	07-11-2025	Part of : BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI	1997	Other Outage	Planned Outage	07-11-2025	10:53	07-11-2025	13:50	2:57	0.000492	REPLACEMET OF HT BUSHING ROD
1483	07-11-2025	Part of : RANHOLLA	401	Other Outage	Planned Outage	07-11-2025	10:58	07-11-2025	13:15	2:17	0.000381	REPLACEMET OF HT BUSHING ROD
1484	08-11-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	720	Other Outage	Planned Outage	08-11-2025	12:09	08-11-2025	15:30	3:21	0.000558	REPLACEMENT OF LT BUSHING ROD
1485	08-11-2025	Part of : D-BLOCK VANDANA VIHAR NANGLOI	816	Other Outage	Planned Outage	08-11-2025	12:00	08-11-2025	15:30	3:30	0.000583	LT CIRCUIT MAINTENANCE WORK
1486	08-11-2025	Part of : D-BLOCK VANDANA VIHAR NANGLOI	1527	Other Outage	Planned Outage	08-11-2025	11:09	08-11-2025	14:27	3:18	0.000550	LT CIRCUIT MAINTENANCE WORK
1487	08-11-2025	Part of : GH5-BLOCK PASCHIM VIHAR	631	Other Outage	Planned Outage	08-11-2025	11:14	08-11-2025	14:26	3:12	0.000533	LT CIRCUIT MAINTENANCE WORK
1488	08-11-2025	Part of : CHANDER VIHAR	1236	Other Outage	Planned Outage	08-11-2025	11:10	08-11-2025	14:27	3:17	0.000547	LT CIRCUIT MAINTENANCE WORK
1489	09-11-2025	Part of : NARESH PARK NANGLOI	43	Other Outage	Planned Outage	09-11-2025	11:03	09-11-2025	13:56	2:53	0.001442	REPLACEMET OF HT BUSHING ROD
1490	09-11-2025	Part of : UDYOG NAGAR MANGOLPURI	11	Other Outage	Planned Outage	09-11-2025	11:42	09-11-2025	13:55	2:13	0.000369	REPLACEMET OF HT BUSHING ROD
1491	10-11-2025	Part of : HTC:NILOTHI SEWAGE PLANT	0	Other Outage	Unplanned Outage	10-11-2025	16:46	10-11-2025	17:34	0:48	0.001573	CABLE FAULT
1492	10-11-2025	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI,TILANGPUR KOTLA VILLAGE,RISHAL GARDEN,TILANGPUR KOTLA,RANHOLLA,	8731	Other Outage	Planned Outage	10-11-2025	11:01	10-11-2025	14:01	3:00	0.002250	PREVENTIVE MAINTENANCE
1493	10-11-2025	Part of : JAI VIHAR PH-1, PH-3,RANHOLLA,TILANGPUR KOTLA VILLAGE,PRATAP VIHAR,	2586	Other Outage	Planned Outage	10-11-2025	11:00	10-11-2025	14:01	3:01	0.002263	PREVENTIVE MAINTENANCE
1494	10-11-2025	Part of : NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI,	1259	Other Outage	Planned Outage	10-11-2025	12:00	10-11-2025	15:27	3:27	0.001725	LT CIRCUIT PREVENTIVE MAINTENANCE
1495	10-11-2025	Part of : NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI,	691	Other Outage	Planned Outage	10-11-2025	11:59	10-11-2025	15:28	3:29	0.002322	LT CIRCUIT PREVENTIVE MAINTENANCE
1496	10-11-2025	Part of : CAMP NO-4 ,S/STN NO-1	1712	Other Outage	Planned Outage	10-11-2025	11:14	10-11-2025	13:59	2:45	0.000229	LT CIRCUIT PREVENTIVE MAINTENANCE
1497	11-11-2025	Part of : CHANDER VIHAR	1130	Other Outage	Planned Outage	11-11-2025	11:45	11-11-2025	13:41	1:56	0.000322	REPLACEMENT OF HT BUSHING ROD
1498	11-11-2025	Part of : TILANGPUR KOTLA VILLAGE	1115	Other Outage	Planned Outage	11-11-2025	11:05	11-11-2025	13:47	2:42	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1499	11-11-2025	Part of : TILANGPUR KOTLA VILLAGE	1115	Other Outage	Planned Outage	11-11-2025	11:06	11-11-2025	13:46	2:40	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1500	11-11-2025	Part of : BLOCK GH 8 PASCHIM VIHAR	201	Other Outage	Planned Outage	11-11-2025	14:08	11-11-2025	16:16	2:08	0.000356	REPLACEMENT OF HT BUSHING ROD
1501	11-11-2025	Part of : JWALAPURI CAMP NO-4	971	Other Outage	Planned Outage	11-11-2025	11:13	11-11-2025	13:43	2:30	0.000417	REPLACEMENT OF HT BUSHING ROD
1502	11-11-2025	Part of : BLOCK GH 8 PASCHIM VIHAR	221	Other Outage	Planned Outage	11-11-2025	11:10	11-11-2025	13:45	2:35	0.000861	REPLACEMENT OF HT BUSHING ROD
1503	11-11-2025	Part of : POCKET B NARESH PARK NANGLOI	126	Other Outage	Planned Outage	11-11-2025	11:15	11-11-2025	13:45	2:30	0.001667	REPLACEMENT OF HT BUSHING ROD
1504	12-11-2025	Part of : CHANDER VIHAR,RISALA GARDEN,NILOTHI VILLAGE	2037	Other Outage	Unplanned Outage	12-11-2025	23:37	13-11-2025	00:28	0:51	0.000255	CABLE FAULT
1505	12-11-2025	Part of : UDYOG NAGAR MANGOLPURI	38	Other Outage	Unplanned Outage	12-11-2025	16:17	12-11-2025	17:05	0:48	0.002333	BIRDAGE
1506	12-11-2025	Part of : CHANDER VIHAR	1996	Other Outage	Planned Outage	12-11-2025	15:07	12-11-2025	17:01	1:54	0.000950	LT CIRCUIT MAINTENANCE
1507	12-11-2025	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	871	Other Outage	Planned Outage	12-11-2025	11:35	12-11-2025	14:12	2:37	0.000785	LT CIRCUIT MAINTENANCE
1508	12-11-2025	Part of : VIKASPURI EXTN	809	Other Outage	Planned Outage	12-11-2025	11:04	12-11-2025	14:13	3:09	0.001313	LT CIRCUIT MAINTENANCE
1509	12-11-2025	Part of : JAWALAPURI CAMP NO.4 UDYOG NAGAR	712	Other Outage	Planned Outage	12-11-2025	11:08	12-11-2025	14:02	2:54	0.000242	LT CIRCUIT MAINTENANCE
1510	13-11-2025	Part of : SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	1008	Other Outage	Planned Outage	13-11-2025	11:00	13-11-2025	13:46	2:46	0.001153	REPLACEMET OF HT BUSHING ROD
1511	13-11-2025	Part of : GURUNANAK VIHAR	402	Other Outage	Planned Outage	13-11-2025	12:23	13-11-2025	14:55	2:32	0.000000	REPLACEMET OF HT BUSHING ROD
1512	13-11-2025	Part of : CAMP NO-4 JAWALAPURI	758	Other Outage	Planned Outage	13-11-2025	11:11	13-11-2025	13:45	2:34	0.000856	REPLACEMET OF HT BUSHING ROD
1513	13-11-2025	Part of : NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	328	Other Outage	Planned Outage	13-11-2025	11:12	13-11-2025	13:45	2:33	0.001063	REPLACEMET OF HT BUSHING ROD
1514	13-11-2025	Part of : GRAM SABHA COLONY	798	Other Outage	Planned Outage	13-11-2025	11:10	13-11-2025	13:44	2:34	0.000428	REPLACEMET OF HT BUSHING ROD
1515	14-11-2025	Part of : UDYOG NAGAR MANGOLPURI	121	Other Outage	Unplanned Outage	14-11-2025	12:31	14-11-2025	13:14	0:43	0.002126	HT SYSTEM FAULT
1516	14-11-2025	Part of : CHANDER VIHAR	894	Other Outage	Planned Outage	14-11-2025	11:53	14-11-2025	15:01	3:08	0.000522	LT CIRCUIT PREVENTIVE MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1517	14-11-2025	Part of : CHANDER VIHAR	511	Other Outage	Planned Outage	14-11-2025	11:52	14-11-2025	15:01	3:09	0.000525	LT CIRCUIT PREVENTIVE MAINTENANCE
1518	15-11-2025	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,EKTA ENCLAVE PEERAGARHI VILLAGE PASCHIM VIHAR,NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	1293	Other Outage	Unplanned Outage	15-11-2025	23:32	16-11-2025	00:15	0:43	0.000394	CABLE FAULT
1519	15-11-2025	Part of : BHERA ENCLAVE PASCHIM VIHAR,NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	1390	Other Outage	Planned Outage	15-11-2025	11:16	15-11-2025	13:55	2:39	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1520	15-11-2025	Part of : GURUNANAK VIHAR	401	Other Outage	Planned Outage	15-11-2025	13:51	15-11-2025	16:41	2:50	0.000000	REPLACEMENT OF HT BUSHING ROD
1521	15-11-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1125	Other Outage	Planned Outage	15-11-2025	11:16	15-11-2025	13:58	2:42	0.000000	REPLACEMENT OF HT BUSHING ROD
1522	15-11-2025	Part of : RANHOLLA	155	Other Outage	Planned Outage	15-11-2025	11:12	15-11-2025	13:57	2:45	0.000000	REPLACEMENT OF HT BUSHING ROD
1523	16-11-2025	Part of : NARESH PARK NANGLOI	93	Other Outage	Planned Outage	16-11-2025	10:56	16-11-2025	14:06	3:10	0.001056	LT CIRCUIT MAINTENANCE
1524	16-11-2025	Part of : UDYOG NAGAR MANGOLPURI	19	Other Outage	Planned Outage	16-11-2025	11:18	16-11-2025	14:04	2:46	0.000231	LT CIRCUIT MAINTENANCE
1525	17-11-2025	Part of : BLOCK A MIRA BAGH PASCHIM VIHAR	762	Other Outage	Planned Outage	17-11-2025	13:24	17-11-2025	15:00	1:36	0.000000	REPLACEMENT OF LT BUSHING ROD
1526	17-11-2025	Part of : CHANDER VIHAR	1272	Other Outage	Planned Outage	17-11-2025	13:15	17-11-2025	14:59	1:44	0.000000	REPLACEMENT OF HT BUSHING ROD
1527	17-11-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	280	Other Outage	Planned Outage	17-11-2025	11:41	17-11-2025	12:55	1:14	0.000000	REPLACEMENT OF LT BUSHING ROD
1528	17-11-2025	Part of : JAI VIHAR PH-1, PH-3,RANHOLLA,TILANGPUR KOTLA VILLAGE,PRATAP VIHAR	2579	Other Outage	Planned Outage	17-11-2025	11:26	17-11-2025	13:52	2:26	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1529	17-11-2025	Part of : ISHWAR VATIKA ADHYAPAK NAGAR NANGLOI,TILANGPUR KOTLA VILLAGE	8706	Other Outage	Planned Outage	17-11-2025	11:23	17-11-2025	13:53	2:30	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1530	17-11-2025	Part of : RAIL NEER PLANT NANGLOI	836	Other Outage	Planned Outage	17-11-2025	10:48	17-11-2025	13:54	3:06	0.001292	REPLACEMENT OF HT BUSHING ROD
1531	17-11-2025	Part of : CAMP NO-4 JAWALAPURI	359	Other Outage	Planned Outage	17-11-2025	10:57	17-11-2025	13:56	2:59	0.000249	REPLACEMENT OF HT BUSHING ROD
1532	17-11-2025	Part of : BLOCK E JEEVAN NIKETAN PASCHIM VIHAR	428	Other Outage	Planned Outage	17-11-2025	10:55	17-11-2025	13:55	3:00	0.000800	REPLACEMENT OF HT BUSHING ROD
1533	18-11-2025	Part of : VANDANA VIHAR NANGLOI,BLOCK D VANDANA VIHAR NANGLOI,BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI	5496	Other Outage	Unplanned Outage	18-11-2025	18:20	18-11-2025	19:07	0:47	0.000601	HVDS FAULT
1534	18-11-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI,DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	7841	Other Outage	Unplanned Outage	18-11-2025	11:20	18-11-2025	12:11	0:51	0.001020	CABLE FAULT
1535	18-11-2025	Part of : NILOTHI VILLAGE,CHANDER VIHAR,RISALA GARDEN NILOTHI	3737	Other Outage	Unplanned Outage	18-11-2025	10:53	18-11-2025	11:32	0:39	0.000878	HT SYSTEM FAULT
1536	18-11-2025	Part of : BLOCK S JAWALAPURI EXTENSION PASCHIM VIHAR,	666	Other Outage	Planned Outage	18-11-2025	11:53	18-11-2025	14:15	2:22	0.000394	REPLACEMENT OF LT BUSHING ROD
1537	18-11-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,	1358	Other Outage	Planned Outage	18-11-2025	11:00	18-11-2025	14:11	3:11	0.001061	REPLACEMET OF HT BUSHING ROD
1538	18-11-2025	Part of : NANGLI VIHAR,	1060	Other Outage	Planned Outage	18-11-2025	11:04	18-11-2025	13:54	2:50	0.000944	REPLACEMET OF HT BUSHING ROD
1539	19-11-2025	Part of : JAI VIHAR PH-1, PH-3	690	Other Outage	Planned Outage	19-11-2025	11:38	19-11-2025	13:40	2:02	0.000000	REPLACEMENT OF HT BUSHING ROD
1540	19-11-2025	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	429	Other Outage	Planned Outage	19-11-2025	11:06	19-11-2025	13:41	2:35	0.000000	REPLACEMENT OF HT BUSHING ROD
1541	19-11-2025	Part of : BLOCK GH 9 PASCHIM VIHAR	206	Other Outage	Planned Outage	19-11-2025	11:05	19-11-2025	13:39	2:34	0.000000	REPLACEMENT OF HT BUSHING ROD
1542	20-11-2025	Part of : POCKET A & A,B-BLOCK NARESH PARK EXTENSION,B-BLOCK AMANPURI KAMRUDDIN NAGAR,NANGLOI JAT,B-BLOCK LAXMI PARK	4157	Other Outage	Planned Outage	20-11-2025	11:10	20-11-2025	14:13	3:03	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1543	20-11-2025	Part of : RANHOLLA	156	Other Outage	Planned Outage	20-11-2025	13:39	20-11-2025	16:04	2:25	0.000604	LT CIRCUIT MAINTENANCE WORK
1544	20-11-2025	Part of : GURUNANAK VIHAR	402	Other Outage	Planned Outage	20-11-2025	12:41	20-11-2025	15:10	2:29	0.000621	LT CIRCUIT MAINTENANCE WORK
1545	20-11-2025	Part of : JAI VIHAR PH-1 & 3	946	Other Outage	Planned Outage	20-11-2025	11:01	20-11-2025	13:59	2:58	0.001731	LT CIRCUIT MAINTENANCE WORK
1546	20-11-2025	Part of : D-BLOCK DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	977	Other Outage	Planned Outage	20-11-2025	11:21	20-11-2025	14:00	2:39	0.000221	LT CIRCUIT MAINTENANCE WORK
1547	21-11-2025	Part of : RANHOLLA, RISHAL GARDEN, JAI VIHAR PH-1, PRATAP VIHAR, TILANGPUR KOTLA VILLAGE	9852	Other Outage	Unplanned Outage	21-11-2025	16:19	21-11-2025	17:01	0:42	0.000782	HT SYSTEM FAULT
1548	21-11-2025	Part of : UDYOG NAGAR MANGOLPURI	121	Other Outage	Unplanned Outage	21-11-2025	09:34	21-11-2025	10:14	0:40	0.001389	FAULT IN HT CONSUMER PANEL (E-4 UDHYOG NAGAR)
1549	21-11-2025	Part of : VIRAT APARTMENT PASCHIM VIHAR,BLOCK C JAWALAPURI PASCHIM VIHAR	2655	Other Outage	Planned Outage	21-11-2025	11:47	21-11-2025	13:06	1:19	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1550	21-11-2025	Part of : SHRI RAM COLONY,SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,TEK CHAND COLONY	1787	Other Outage	Planned Outage	21-11-2025	11:01	21-11-2025	13:08	2:07	0.000000	3PH HT AB END TERMINATION REPLACEMENT
1551	21-11-2025	Part of : POCKET B NARESH PARK NANGLOI,BLOCK B NARESH PARK EXTENSION NANGLOI	659	Other Outage	Planned Outage	21-11-2025	10:49	21-11-2025	13:05	2:16	0.000944	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1552	21-11-2025	Part of : BLOCK GH 9 PASCHIM VIHAR	173	Other Outage	Planned Outage	21-11-2025	10:52	21-11-2025	13:04	2:12	0.000000	REPLACEMET OF HT BUSHING ROD
1553	22-11-2025	Part of : JAI VIHAR BAPROLA,	1283	Other Outage	Planned Outage	22-11-2025	11:10	22-11-2025	14:12	3:02	0.001011	REPLACEMET OF HT BUSHING ROD
1554	23-11-2025	Part of : UDYOG NAGAR MANGOLPURI	11	Other Outage	Planned Outage	23-11-2025	12:45	23-11-2025	16:11	3:26	0.000000	REPLACEMENT OF HT BUSHING ROD
1555	23-11-2025	Part of : UDYOG NAGAR MANGOLPURI	6	Other Outage	Planned Outage	23-11-2025	11:01	23-11-2025	14:02	3:01	0.000000	REPLACEMENT OF HT BUSHING ROD
1556	24-11-2025	Part of : UDYOG NAGAR MANGOLPURI	119	Other Outage	Unplanned Outage	24-11-2025	06:10	24-11-2025	07:01	0:51	0.000567	BIRDAGE
1557	24-11-2025	Part of : X-BLOCK JJ COLONY-3,SHIV VIHAR,B-BLOCK LAXMI PARK,NANGLOI JAT	3052	Other Outage	Planned Outage	24-11-2025	13:23	24-11-2025	14:55	1:32	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1558	24-11-2025	Part of : C-BLOCK KAMRUDDIN NAGAR NANGLOI	1638	Other Outage	Planned Outage	24-11-2025	11:36	24-11-2025	14:56	3:20	0.001111	LT CIRCUIT MAINTENANCE WORK
1559	24-11-2025	Part of : CHANDER VIHAR	1359	Other Outage	Planned Outage	24-11-2025	11:14	24-11-2025	14:14	3:00	0.001500	LT CIRCUIT MAINTENANCE WORK
1560	24-11-2025	Part of : VIRAT APARTMENT PASCHIM VIHAR	85	Other Outage	Planned Outage	24-11-2025	11:05	24-11-2025	14:06	3:01	0.000251	LT CIRCUIT MAINTENANCE WORK
1561	24-11-2025	Part of : NANGLI VIHAR	1058	Other Outage	Planned Outage	24-11-2025	11:37	24-11-2025	14:10	2:33	0.000213	LT CIRCUIT MAINTENANCE WORK
1562	24-11-2025	Part of : GH 14-BLOCK PASCHIM VIHAR	23	Other Outage	Planned Outage	24-11-2025	10:55	24-11-2025	14:08	3:13	0.000536	LT CIRCUIT MAINTENANCE WORK
1563	25-11-2025	Part of : RANHOLLA	156	Other Outage	Planned Outage	25-11-2025	11:18	25-11-2025	14:07	2:49	0.000000	REPLACEMET OF HT BUSHING ROD
1564	26-11-2025	Part of : SHIV VIHAR A, B BLOCK,	373	Other Outage	Planned Outage	26-11-2025	10:53	26-11-2025	13:47	2:54	0.001933	REPLACEMET OF FAULTY END BOX,SF6 GAS FILLING
1565	26-11-2025	Part of : UDYOG NAGAR MANGOLPURI,	283	Other Outage	Planned Outage	26-11-2025	11:50	26-11-2025	14:08	2:18	0.000192	REPLACEMET OF HT BUSHING ROD
1566	26-11-2025	Part of : BHERA ENCLAVE PASCHIM VIHAR,	149	Other Outage	Planned Outage	26-11-2025	10:55	26-11-2025	14:09	3:14	0.000647	REPLACEMET OF HT BUSHING ROD
1567	26-11-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,	715	Other Outage	Planned Outage	26-11-2025	10:54	26-11-2025	14:07	3:13	0.001072	REPLACEMET OF HT BUSHING ROD
1568	26-11-2025	Part of : HARPHOOL VIHAR,	3317	Other Outage	Planned Outage	26-11-2025	10:53	26-11-2025	14:09	3:16	0.001906	REPLACEMET OF HT BUSHING ROD
1569	26-11-2025	Part of : NANGLI VIHAR,	1058	Other Outage	Planned Outage	26-11-2025	11:26	26-11-2025	14:06	2:40	0.000444	REPLACEMET OF HT BUSHING ROD
1570	27-11-2025	Part of : BLOCK A, B & I NARESH PARK EXTENSION NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI,BLOCK D KUNWAR SINGH NAGAR KAMARUDDIN NAGAR	267	Other Outage	Planned Outage	27-11-2025	10:14	27-11-2025	14:35	4:21	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1571	27-11-2025	Part of : TILANGPUR KOTLA VILLAGE	1456	Other Outage	Planned Outage	27-11-2025	12:23	27-11-2025	15:04	2:41	0.000000	REPLACEMENT OF HT BUSHING ROD
1572	27-11-2025	Part of : AMBIKA VIHAR PASCHIM VIHAR	280	Other Outage	Planned Outage	27-11-2025	10:48	27-11-2025	14:36	3:48	0.000443	REPLACEMENT OF HT BUSHING ROD
1573	28-11-2025	Part of : RANHOLLA,RISALA GARDEN NILOTHI	184	Other Outage	Planned Outage	28-11-2025	11:04	28-11-2025	13:57	2:53	0.001922	GUARD WIRE LACS INSTALLTION
1574	28-11-2025	Part of : C-BLOCK KAMRUDDIN NAGAR NANGLOI	895	Other Outage	Planned Outage	28-11-2025	13:08	28-11-2025	15:44	2:36	0.000867	LT CIRCUIT MAINTENANCE
1575	28-11-2025	Part of : GH 14-BLOCK PASCHIM VIHAR	206	Other Outage	Planned Outage	28-11-2025	11:03	28-11-2025	13:56	2:53	0.000961	LT CIRCUIT MAINTENANCE
1576	29-11-2025	Part of : RANJEET VIHAR,UDAI VIHAR	1712	Other Outage	Planned Outage	29-11-2025	14:42	29-11-2025	17:15	2:33	0.000000	GUARD WIRE LACS INSTALLTION PER SPAN
1577	29-11-2025	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR,EKTA ENCLAVE PEERAGARHI VILLAGE	1120	Other Outage	Planned Outage	29-11-2025	11:02	29-11-2025	14:28	3:26	0.001144	REPLACEMENT OF CROSS-ARMS AND POLES
1578	29-11-2025	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI	681	Other Outage	Planned Outage	29-11-2025	11:12	29-11-2025	14:45	3:33	0.001183	REPLACEMET OF HT BUSHING ROD
1579	29-11-2025	Part of : CHANDER VIHAR	1305	Other Outage	Planned Outage	29-11-2025	11:09	29-11-2025	14:29	3:20	0.002778	REPLACEMET OF HT BUSHING ROD
1580	30-11-2025	Part of : POCKET B NARESH PARK NANGLOI,	126	Other Outage	Planned Outage	30-11-2025	11:06	30-11-2025	14:14	3:08	0.001306	REPLACEMET OF HT BUSHING ROD
1581	30-11-2025	Part of : UDYOG NAGAR MANGOLPURI,	12	Other Outage	Planned Outage	30-11-2025	11:14	30-11-2025	14:00	2:46	0.000231	REPLACEMET OF HT BUSHING ROD
1582	01-11-2025	Part of : SAMTA ENCLAVE QUTUB VIHAR	950	Other Outage	Planned Outage	01-11-2025	13:11	01-11-2025	15:09	1:58	0.002950	REPLACEMET OF HT BUSHING ROD
1583	01-11-2025	Part of : PIND WALA KHURD VILLAGE	23	Other Outage	Planned Outage	01-11-2025	13:09	01-11-2025	14:43	1:34	0.000261	REPLACEMENT OF LT BUSHING ROD
1584	01-11-2025	Part of : 40-MGD WATER TREATMENT PLANT (HTC), L&T AT POLICE CHAWKI DJB (HTC)	2	Other Outage	Planned Outage	01-11-2025	13:20	01-11-2025	14:45	1:25	0.001181	REPLACEMET OF HT BUSHING ROD
1585	01-11-2025	Part of : DURGA VIHAR I DINPUR,DURGA VIHAR II DINPUR,DINPUR LAL DORA EXTN DINPUR,TODARMAL COLONY NAJAFGARH	967	Other Outage	Planned Outage	01-11-2025	13:28	01-11-2025	16:43	3:15	0.002167	REPLACEMENT OF CROSS-ARMS AND POLES
1586	01-11-2025	Part of : SHYAM ENCLAVE DINPUR,BLOCK E SHYAM VIHAR I NAJAFGARH	540	Other Outage	Planned Outage	01-11-2025	13:19	01-11-2025	15:38	2:19	0.000000	REPLACEMET OF HT BUSHING ROD
1587	01-11-2025	Part of : NATHU RAM PARK MASUDABAD NAJAFGARH	179	Other Outage	Planned Outage	01-11-2025	13:22	01-11-2025	15:40	2:18	0.003450	REPLACEMET OF HT BUSHING ROD
1588	02-11-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	19	Other Outage	Unplanned Outage	02-11-2025	06:25	02-11-2025	07:04	0:39	0.000141	CABLE FAULT
1589	02-11-2025	Part of : SANGAM VIHAR DHARAMPURA NAJAFGARH,	12	Other Outage	Planned Outage	02-11-2025	11:55	02-11-2025	14:37	2:42	0.001350	REPLACEMENT OF LT BUSHING ROD
1590	03-11-2025	PART OF : SHERPUR EXTENTION,KHERA DABAS VILLAGE,KHARKHARI ROND VILLAGE,PIND WALA KHURD VILLAGE,PIND WALA KALAN VILLAGE	1650	Other Outage	Planned Outage	03-11-2025	11:23	03-11-2025	11:26	0:03	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1591	03-11-2025	PART OF : RANAJI ENCLAVE MASUDABAD NAJAFGARH	270	Other Outage	Planned Outage	03-11-2025	14:17	03-11-2025	15:53	1:36	0.000000	REPLACEMET OF HT BUSHING ROD
1592	03-11-2025	PART OF : DHARAMPURA NAJAFGARH	514	Other Outage	Planned Outage	03-11-2025	10:29	03-11-2025	12:22	1:53	0.001256	REPLACEMENT OF GAS KIT AND OIL SEAL
1593	03-11-2025	PART OF : BHARTHAL VILLAGE DWARKA	621	Other Outage	Planned Outage	03-11-2025	10:50	03-11-2025	12:31	1:41	0.002525	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1594	03-11-2025	PART OF : PAPRAWAT VILLAGE	371	Other Outage	Planned Outage	03-11-2025	15:22	03-11-2025	17:23	2:01	0.000504	REPLACEMENT OF LT BUSHING ROD
1595	03-11-2025	PART OF : DICHAN ENCLAVE DICHAN KALAN	238	Other Outage	Planned Outage	03-11-2025	10:33	03-11-2025	13:28	2:55	0.003889	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1596	03-11-2025	PART OF : NANGLI SANKRANTI NANGLI SAKRAWATI	389	Other Outage	Planned Outage	03-11-2025	10:55	03-11-2025	13:48	2:53	0.000000	REPLACEMET OF HT BUSHING ROD
1597	03-11-2025	PART OF : KANGANHERI VILLAGE	171	Other Outage	Planned Outage	03-11-2025	10:50	03-11-2025	13:44	2:54	0.004350	REPLACEMENT OF LT BUSHING ROD
1598	04-11-2025	Part of : SARASWATI KUNJ,LOKESH PARK EXTN,B-BLOCK NAVEEN PALACE,SURYA KUNJ,DHANAK MOHALLA HAIBUTPUR,INDRA MARKET,BABA HARIDAS ENCLAVE,KRISHNA ENCLAVE,NEW VISION COLONY,SARASWATI ENCLAVE	6627	Other Outage	Unplanned Outage	04-11-2025	13:32	04-11-2025	14:24	0:52	0.001300	TRANSFORMER REPLACEMENT
1599	04-11-2025	Part of : AGARWAL COLONY HAIBUTPUR	32	Other Outage	Planned Outage	04-11-2025	11:30	04-11-2025	13:30	2:00	0.002667	REPLACEMENT OF HT BUSHING ROD
1600	04-11-2025	Part of : LAXMI NAGAR	821	Other Outage	Planned Outage	04-11-2025	14:06	04-11-2025	16:57	2:51	0.002375	REPLACEMENT OF HT BUSHING ROD
1601	04-11-2025	Part of : CHAWLA	435	Other Outage	Planned Outage	04-11-2025	13:05	04-11-2025	15:59	2:54	0.004350	REPLACEMENT OF HT BUSHING ROD
1602	04-11-2025	Part of : A-BLOCK POCHANPUR DWARKA	1075	Other Outage	Planned Outage	04-11-2025	11:33	04-11-2025	14:11	2:38	0.002633	REPLACEMENT OF HT BUSHING ROD
1603	04-11-2025	Part of : KHAIRA VILLAGE	242	Other Outage	Planned Outage	04-11-2025	10:25	04-11-2025	13:20	2:55	0.000729	REPLACEMENT OF HT BUSHING ROD
1604	04-11-2025	Part of : SHIV PURI II DINPUR	276	Other Outage	Planned Outage	04-11-2025	10:24	04-11-2025	12:58	2:34	0.000000	REPLACEMENT OF HT BUSHING ROD
1605	04-11-2025	Part of : B & D-BLOCK LAXMI VIHAR COLONY NANGLI SAKRAWATI,SAI BABA ENCLAVE MASUDABAD NAJAFGARH,NAJAFGARH EXTENSION	1319	Other Outage	Planned Outage	04-11-2025	11:02	04-11-2025	14:53	3:51	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1606	06-11-2025	Part of : DURGA VIHAR II DINPUR,	430	Other Outage	Planned Outage	06-11-2025	13:23	06-11-2025	15:35	2:12	0.000550	REPLACEMET OF HT BUSHING ROD
1607	06-11-2025	Part of : DHARAMPURA NAJAFGARH,	834	Other Outage	Planned Outage	06-11-2025	12:47	06-11-2025	15:39	2:52	0.004300	REPLACEMENT OF LT BUSHING ROD
1608	06-11-2025	Part of : DAULATPUR VILLAGE,	394	Other Outage	Planned Outage	06-11-2025	12:31	06-11-2025	15:26	2:55	0.000000	REPLACEMENT OF HT BUSHING ROD
1609	06-11-2025	Part of : BHARTHAL VILLAGE DWARKA,	168	Other Outage	Planned Outage	06-11-2025	12:26	06-11-2025	15:21	2:55	0.004375	REPLACEMENT OF LT BUSHING ROD
1610	06-11-2025	Part of : BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR,	438	Other Outage	Planned Outage	06-11-2025	11:56	06-11-2025	14:48	2:52	0.004300	REPLACEMET OF HT BUSHING ROD
1611	06-11-2025	Part of : REWLA KHANPUR VILLAGE,	40	Other Outage	Planned Outage	06-11-2025	11:54	06-11-2025	14:47	2:53	0.004325	REPLACEMENT OF LT BUSHING ROD
1612	06-11-2025	Part of : SARASWATI KUNJ JHARODA KALAN,	499	Other Outage	Planned Outage	06-11-2025	12:10	06-11-2025	14:51	2:41	0.004025	REPLACEMENT OF HT BUSHING ROD
1613	06-11-2025	Part of : NIRMAL VIHAR DICHAN KALAN,	28	Other Outage	Planned Outage	06-11-2025	10:20	06-11-2025	13:16	2:56	0.000000	REPLACEMENT OF HT BUSHING ROD
1614	06-11-2025	Part of : DHARAMPURA NAJAFGARH,	200	Other Outage	Planned Outage	06-11-2025	10:29	06-11-2025	12:53	2:24	0.000000	REPLACEMET OF HT BUSHING ROD
1615	07-11-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	173	Other Outage	Planned Outage	07-11-2025	14:33	07-11-2025	16:27	1:54	0.000000	REPLACEMET OF HT BUSHING ROD
1616	07-11-2025	Part of : BLOCK B LAXMI VIHAR COLONY NANGLI SAKRAWATI	821	Other Outage	Planned Outage	07-11-2025	15:16	07-11-2025	17:29	2:13	0.003325	REPLACEMENT OF LT BUSHING ROD
1617	07-11-2025	Part of : SULTAN GARDEN,SHIV ENCLAVE NAJAFGARH,SAINIK NIKETAN NAJAFGARH,NEW HEERA PARK NAJAFGARH,NEW HIRA NAGAR DICHAN KALAN,SHIV NAGAR DICHAN KALAN	2490	Other Outage	Planned Outage	07-11-2025	11:10	07-11-2025	14:01	2:51	0.004275	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1618	07-11-2025	Part of : BLOCK B INDRA PARK MASUDABAD NAJAFGARH	97	Other Outage	Planned Outage	07-11-2025	10:55	07-11-2025	13:51	2:56	0.000000	REPLACEMET OF HT BUSHING ROD
1619	08-11-2025	Part of : SECTOR 24 DWARKA	2	Other Outage	Planned Outage	08-11-2025	14:05	08-11-2025	15:21	1:16	0.001900	REPLACEMENT OF HT BUSHING ROD
1620	08-11-2025	Part of : E-BLOCK NEW ROSHAN PURA NAJAFGARH	403	Other Outage	Planned Outage	08-11-2025	10:40	08-11-2025	13:20	2:40	0.000000	REPLACEMENT OF HT BUSHING ROD
1621	08-11-2025	Part of : ROSHAN VIHAR & TODARMAL COLONY NAJAFGARH	1934	Other Outage	Planned Outage	08-11-2025	10:35	08-11-2025	12:45	2:10	0.002167	REPLACEMENT OF CROSS-ARMS AND POLES
1622	08-11-2025	Part of : BADUSARAI	398	Other Outage	Planned Outage	08-11-2025	10:18	08-11-2025	13:09	2:51	0.004275	REPLACEMENT OF HT BUSHING ROD
1623	08-11-2025	Part of : NAJAFGARH PARK COLONY	646	Other Outage	Planned Outage	08-11-2025	10:34	08-11-2025	13:28	2:54	0.004350	REPLACEMENT OF HT BUSHING ROD
1624	08-11-2025	Part of : SHIV NAGAR DICHAN KALAN,	226	Other Outage	Planned Outage	08-11-2025	10:35	08-11-2025	13:29	2:54	0.004350	REPLACEMENT OF HT BUSHING ROD
1625	08-11-2025	Part of : D-BLOCK LAXMI VIHAR COLONY NANGLI SAKRAWATI	61	Other Outage	Planned Outage	08-11-2025	07:25	08-11-2025	09:47	2:22	0.000000	REPLACEMENT OF HT BUSHING ROD
1626	09-11-2025	Part of : NATHU RAM PARK MASUDABAD NAJAFGARH	179	Other Outage	Planned Outage	09-11-2025	11:17	09-11-2025	14:05	2:48	0.004200	REPLACEMENT OF LT BUSHING ROD
1627	09-11-2025	Part of : OLD NAGPAL NANGLI	322	Other Outage	Planned Outage	09-11-2025	11:17	09-11-2025	14:05	2:48	0.002333	REPLACEMET OF HT BUSHING ROD
1628	10-11-2025	Part of : POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA,	247	Other Outage	Planned Outage	10-11-2025	12:12	10-11-2025	15:14	3:02	0.004550	NETWORK UPGRADATION
1629	10-11-2025	Part of : ASALATPUR KHAWAD,	335	Other Outage	Planned Outage	10-11-2025	12:11	10-11-2025	14:49	2:38	0.000000	PREVENTIVE MAINTENANCE
1630	10-11-2025	Part of : DHARAMPURA NAJAFGARH,	342	Other Outage	Planned Outage	10-11-2025	12:02	10-11-2025	15:27	3:25	0.005125	NETWORK UPGRADATION
1631	10-11-2025	Part of : KHAIRA VILLAGE,	165	Other Outage	Planned Outage	10-11-2025	11:15	10-11-2025	13:40	2:25	0.000604	PREVENTIVE MAINTENANCE
1632	10-11-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,	4	Other Outage	Planned Outage	10-11-2025	07:19	10-11-2025	10:17	2:58	0.000000	PREVENTIVE MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1633	11-11-2025	Part of : DHARAMPURA NAJAFGARH	835	Other Outage	Planned Outage	11-11-2025	12:58	11-11-2025	14:21	1:23	0.000000	3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1634	11-11-2025	Part of : ROSHAN PURA NAJAFGARH	276	Other Outage	Planned Outage	11-11-2025	11:27	11-11-2025	13:22	1:55	0.000479	REPLACEMENT OF HT BUSHING ROD
1635	11-11-2025	Part of : KANGANHERI VILLAGE	171	Other Outage	Planned Outage	11-11-2025	12:17	11-11-2025	15:01	2:44	0.004100	REPLACEMENT OF GAS KIT AND OIL SEAL
1636	11-11-2025	Part of : CHAWLA	513	Other Outage	Planned Outage	11-11-2025	12:19	11-11-2025	15:02	2:43	0.002717	REPLACEMENT OF HT BUSHING ROD
1637	11-11-2025	Part of : NAJAFGARH PARK COLONY NAJAFGARH	645	Other Outage	Planned Outage	11-11-2025	11:23	11-11-2025	14:19	2:56	0.004400	REPLACEMENT OF LT BUSHING ROD
1638	11-11-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	245	Other Outage	Planned Outage	11-11-2025	10:41	11-11-2025	13:18	2:37	0.000000	REPLACEMENT OF HT BUSHING ROD
1639	11-11-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	333	Other Outage	Planned Outage	11-11-2025	10:49	11-11-2025	13:29	2:40	0.000000	REPLACEMENT OF HT BUSHING ROD
1640	12-11-2025	Part of : SATYAMPURAM	822	Other Outage	Planned Outage	12-11-2025	14:35	12-11-2025	16:14	1:39	0.002475	REPLACEMENT OF HT BUSHING ROD
1641	12-11-2025	Part of : SARASWATI KUNJ JHARODA KALAN	510	Other Outage	Planned Outage	12-11-2025	12:28	12-11-2025	14:42	2:14	0.003350	REPLACEMENT OF HT BUSHING ROD
1642	12-11-2025	Part of : ASALATPUR KHAWAD	380	Other Outage	Planned Outage	12-11-2025	11:17	12-11-2025	13:43	2:26	0.000000	REPLACEMENT OF HT BUSHING ROD
1643	12-11-2025	Part of : GANDHI PARK DINPUR,SHYAM VIHAR - II	2054	Other Outage	Planned Outage	12-11-2025	10:34	12-11-2025	13:19	2:45	0.000000	REPLACEMENT OF HT BUSHING ROD
1644	12-11-2025	Part of : BLOCK A QUTUB VIHAR PHASE 1	439	Other Outage	Planned Outage	12-11-2025	10:28	12-11-2025	12:55	2:27	0.003675	REPLACEMENT OF GAS KIT AND OIL SEAL
1645	12-11-2025	Part of : KHAIRA VILLAGE	39	Other Outage	Planned Outage	12-11-2025	11:08	12-11-2025	13:10	2:02	0.000508	REPLACEMENT OF HT BUSHING ROD
1646	12-11-2025	Part of : BLOCK A1 ROSHAN GARDEN MASUDABAD NAJAFGARH	3174	Other Outage	Planned Outage	12-11-2025	10:38	12-11-2025	14:17	3:39	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1647	13-11-2025	Part of : POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA	1	Other Outage	Planned Outage	13-11-2025	12:02	13-11-2025	14:56	2:54	0.002417	REPLACEMENT OF HT BUSHING ROD
1648	13-11-2025	Part of : DHARAMPURA NAJAFGARH	1174	Other Outage	Planned Outage	13-11-2025	10:42	13-11-2025	13:26	2:44	0.000000	REPLACEMENT OF HT BUSHING ROD
1649	13-11-2025	Part of : PIND WALA KHURD VILLAGE	510	Other Outage	Planned Outage	13-11-2025	12:12	13-11-2025	14:42	2:30	0.000000	REPLACEMENT OF HT BUSHING ROD
1650	13-11-2025	Part of : VIRENDRA MARKET	266	Other Outage	Planned Outage	13-11-2025	11:45	13-11-2025	14:50	3:05	0.004625	REPLACEMENT OF HT BUSHING ROD
1651	13-11-2025	Part of : SAI BABA ENCLAVE MASUDABAD NAJAFGARH,ROSHAN MANDI MASUDABAD NAJAFGARH,NAJAFGARH EXTENSION	5263	Other Outage	Planned Outage	13-11-2025	11:18	13-11-2025	14:21	3:03	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1652	13-11-2025	Part of : REWLA KHANPUR VILLAGE	231	Other Outage	Planned Outage	13-11-2025	09:58	13-11-2025	13:00	3:02	0.004550	REPLACEMENT OF GAS KIT AND OIL SEAL
1653	14-11-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	528	Other Outage	Planned Outage	14-11-2025	13:45	14-11-2025	14:44	0:59	0.000000	PREVENTIVE MAINTENANCE
1654	14-11-2025	Part of : SECTOR 29 DWARKA	195	Other Outage	Planned Outage	14-11-2025	10:28	14-11-2025	13:40	3:12	0.004800	REPLACEMENT OF LT BUSHING ROD
1655	14-11-2025	Part of : SAI BABA ENCLAVE MASUDABAD NAJAFGARH	144	Other Outage	Planned Outage	14-11-2025	10:31	14-11-2025	13:42	3:11	0.000000	PREVENTIVE MAINTENANCE
1656	14-11-2025	Part of : JHATIKARA,BADUSARAI,PAPRAWAT VILLAGE,SHIKARPUR VILLAGE,PIND WALA KHURD VILLAGE,PREM NAGAR PAPRAWAT VILLAGE	2067	Other Outage	Planned Outage	14-11-2025	12:06	14-11-2025	14:48	2:42	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1657	14-11-2025	Part of : BADUSARAI	398	Other Outage	Planned Outage	14-11-2025	11:05	14-11-2025	14:06	3:01	0.004525	PREVENTIVE MAINTENANCE
1658	15-11-2025	Part of : SECTOR 27 DWARKA,NANAK HERI VILLAGE	1842	Other Outage	Unplanned Outage	15-11-2025	12:03	15-11-2025	12:18	0:15	0.000208	CONNECTION/DISCONNECTION OF HT/LT CABLES
1659	15-11-2025	Part of : SHERPUR EXTENTION,KHERA DABAS VILLAGE,KHARKHARI ROND VILLAGE,PIND WALA KHURD VILLAGE,PIND WALA KALAN VILLAGE	715	Other Outage	Planned Outage	15-11-2025	11:07	15-11-2025	11:09	0:02	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1660	15-11-2025	Part of : PAPRAWAT VILLAGE,DELHI TEACHERS COLONY DINDARPUR NAJAFGARH,SARIKA VIHAR DINPUR,DURGA PARK NAJAFGARH,DURGA VIHAR I DINPUR,DATA RAM PARK DINPUR,ROSHAN VIHAR 1 NAJAFGARH	1005	Other Outage	Planned Outage	15-11-2025	10:39	15-11-2025	13:39	3:00	0.002750	REPLACEMENT OF CROSS-ARMS AND POLES
1661	15-11-2025	Part of : DURGA VIHAR I DINPUR,DURGA VIHAR II DINPUR,DINPUR LAL DORA EXTN DINPUR,DATA RAM PARK DINPUR,ROSHAN VIHAR 1 NAJAFGARH,MUNIRKA KUNJ DINPUR,SHANTI VIHAR DINPUR	777	Other Outage	Planned Outage	15-11-2025	10:36	15-11-2025	13:29	2:53	0.002643	REPLACEMENT OF CROSS-ARMS AND POLES
1662	15-11-2025	Part of : SHYAM VIHAR I NAJAFGARH,SHYAM KUNJ DINPUR	1591	Other Outage	Planned Outage	15-11-2025	10:28	15-11-2025	13:11	2:43	0.000000	REPLACEMENT OF HT BUSHING ROD
1663	15-11-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI	43	Other Outage	Planned Outage	15-11-2025	07:47	15-11-2025	10:26	2:39	0.000000	REPLACEMENT OF HT BUSHING ROD
1664	16-11-2025	Part of : NANGLI SANKRANTI	65	Other Outage	Planned Outage	16-11-2025	12:22	16-11-2025	15:26	3:04	0.000000	HT CONDUCTOR REPLACEMENT
1665	16-11-2025	Part of : NANGLI SANKRANTI	324	Other Outage	Planned Outage	16-11-2025	12:22	16-11-2025	15:26	3:04	0.000000	HT CONDUCTOR REPLACEMENT
1666	17-11-2025	Part of : NEW HEERA PARK NAJAFGARH	1	Other Outage	Planned Outage	17-11-2025	15:24	17-11-2025	16:16	0:52	0.000000	CONDUCTOR REPLACEMENT PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1667	17-11-2025	Part of : NEW HIRA NAGAR DICHAON KALAN	476	Other Outage	Planned Outage	17-11-2025	15:28	17-11-2025	16:25	0:57	0.000000	CONDUCTOR REPLACEMENT PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1668	17-11-2025	Part of : PAPRAWAT VILLAGE	371	Other Outage	Planned Outage	17-11-2025	10:47	17-11-2025	11:47	1:00	0.000250	REPLACEMENT OF HT BUSHING ROD
1669	17-11-2025	Part of : PAPRAWAT VILLAGE	29	Other Outage	Planned Outage	17-11-2025	10:46	17-11-2025	11:47	1:01	0.000169	REPLACEMENT OF GAS KIT AND OIL SEAL
1670	17-11-2025	Part of : BABA HARIDAS ENCLAVE,JHARODA KALAN,SHIV NAGAR DICHAON KALAN	2967	Other Outage	Planned Outage	17-11-2025	13:29	17-11-2025	16:21	2:52	0.003344	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
1671	17-11-2025	Part of : TODARMAL COLONY NAJAFGARH	236	Other Outage	Planned Outage	17-11-2025	10:41	17-11-2025	13:48	3:07	0.000519	SUB STATION CLEANING
1672	17-11-2025	Part of : RANAJI ENCLAVE MASUDABAD NAJAFGARH,JAI VIHAR COLONY MASUDABAD NAJAFGARH	270	Other Outage	Planned Outage	17-11-2025	10:51	17-11-2025	13:39	2:48	0.000000	REPLACEMENT OF HT BUSHING ROD
1673	17-11-2025	Part of : CHAWLA	971	Other Outage	Planned Outage	17-11-2025	11:16	17-11-2025	13:51	2:35	0.003875	REPLACEMENT OF GAS KIT AND OIL SEAL
1674	17-11-2025	Part of : BLOCK B POCHANPUR DWARKA	981	Other Outage	Planned Outage	17-11-2025	10:33	17-11-2025	13:36	3:03	0.003050	REPLACEMENT OF HT BUSHING ROD
1675	17-11-2025	Part of : ASALETPUR KHAWAD VILLAGE	535	Other Outage	Planned Outage	17-11-2025	10:22	17-11-2025	13:37	3:15	0.000000	REPLACEMENT OF HT BUSHING ROD
1676	17-11-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	502	Other Outage	Planned Outage	17-11-2025	11:23	17-11-2025	14:13	2:50	0.000000	CONDUCTOR REPLACEMENT PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1677	18-11-2025	Part of : PIND WALA KALAN VILLAGE,KHARKHARI NAHA VILLAGE,	655	Other Outage	Planned Outage	18-11-2025	11:20	18-11-2025	11:33	0:13	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1678	18-11-2025	Part of : DHARAMPURA NAJAFGARH,	829	Other Outage	Planned Outage	18-11-2025	13:16	18-11-2025	14:55	1:39	0.000000	REPLACEMET OF HT BUSHING ROD
1679	18-11-2025	Part of : GOYALA DAIRY QUTUB VIHAR,	642	Other Outage	Planned Outage	18-11-2025	11:49	18-11-2025	13:23	1:34	0.002350	REPLACEMENT OF GAS KIT AND OIL SEAL
1680	18-11-2025	Part of : HTC:CLUSTER BUS DEPOT, DWARKA SEC-22	1	Other Outage	Planned Outage	18-11-2025	11:17	18-11-2025	14:44	3:27	0.002875	REPLACEMET OF HT BUSHING ROD
1681	18-11-2025	Part of : JHARODA KALAN,	270	Other Outage	Planned Outage	18-11-2025	11:30	18-11-2025	14:49	3:19	0.003869	REPLACEMET OF HT BUSHING ROD
1682	19-11-2025	Part of : MGD WATER TREATMENT PLANT (HTC)	0	Other Outage	Unplanned Outage	19-11-2025	15:07	19-11-2025	16:01	0:54	0.000270	CABLE FAULT
1683	19-11-2025	Part of : PREM NAGAR NAJAFGARH	403	Other Outage	Planned Outage	19-11-2025	11:09	19-11-2025	13:28	2:19	0.000579	REPLACEMENT OF HT BUSHING ROD
1684	19-11-2025	Part of : DHARAMPURA NAJAFGARH	835	Other Outage	Planned Outage	19-11-2025	11:22	19-11-2025	14:24	3:02	0.000506	REPLACEMENT OF HT BUSHING ROD
1685	19-11-2025	Part of : GOYLA KHURD	516	Other Outage	Planned Outage	19-11-2025	12:23	19-11-2025	15:39	3:16	0.000000	3PH DB REVAMPING,LT AB SAGGING PER SPAN
1686	19-11-2025	Part of : JHATIKARA,BADUSARAI,PAPRAWAT VILLAGE,SHIKARPUR VILLAGE,PIND WALA KHURD VILLAGE,PREM NAGAR PAPRAWAT VILLAGE,DAULATPUR VILLAGE,ASALATPUR KHAWAD,KANGANHERI VILLAGE	2067	Other Outage	Planned Outage	19-11-2025	10:18	19-11-2025	13:24	3:06	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1687	20-11-2025	Part of : GOYALA DAIRY,SAMTA ENCLAVE,A-BLOCK QUTUB VIHAR PHASE-1,TAJPUR KHURD,QUTUB VIHAR PHASE-2	6783	Other Outage	Unplanned Outage	20-11-2025	16:07	20-11-2025	17:00	0:53	0.000677	CABLE FAULT
1688	20-11-2025	Part of : DURGA PARK NAJAFGARH	179	Other Outage	Planned Outage	20-11-2025	13:08	20-11-2025	14:30	1:22	0.000000	REPLACEMENT OF HT BUSHING ROD
1689	20-11-2025	Part of : SAMTA ENCLAVE QUTUB VIHAR	1328	Other Outage	Planned Outage	20-11-2025	10:46	20-11-2025	12:33	1:47	0.000000	3PH DB REPLACEMENT,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1690	20-11-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,	6	Other Outage	Planned Outage	20-11-2025	10:33	20-11-2025	13:39	3:06	0.000775	REPLACEMENT OF HT BUSHING ROD
1691	20-11-2025	Part of : PIND WALA KHURD VILLAGE	360	Other Outage	Planned Outage	20-11-2025	10:32	20-11-2025	13:27	2:55	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1692	21-11-2025	Part of : GOYALA DAIRY QUTUB VIHAR,SAMTA ENCLAVE QUTUB VIHAR,BLOCK A QUTUB VIHAR PHASE 1	6783	Other Outage	Unplanned Outage	21-11-2025	11:40	21-11-2025	12:37	0:57	0.001583	ATTEND WEAK POINT/HOT SPOT
1693	21-11-2025	Part of : HASANPUR VILLAGE,ASALETPUR KHAWAD VILLAGE,DAULATPUR VILLAGE	3215	Other Outage	Planned Outage	21-11-2025	11:39	21-11-2025	11:45	0:06	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1694	21-11-2025	Part of : NAJAFGARH VILLAGE	620	Other Outage	Planned Outage	21-11-2025	14:07	21-11-2025	16:04	1:57	0.003250	REPLACEMET OF HT BUSHING ROD
1695	21-11-2025	Part of : KHAIRA VILLAGE	586	Other Outage	Planned Outage	21-11-2025	14:09	21-11-2025	16:01	1:52	0.003111	REPLACEMET OF HT BUSHING ROD
1696	21-11-2025	Part of : SULTAN GARDEN,SHIV ENCLAVE NAJAFGARH,DICHAON KALAN VILLAGE	2490	Other Outage	Planned Outage	21-11-2025	11:33	21-11-2025	14:14	2:41	0.004025	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1697	21-11-2025	Part of : SHYAM KUNJ DINPUR,BLOCK E SHYAM VIHAR I NAJAFGARH	1589	Other Outage	Planned Outage	21-11-2025	10:49	21-11-2025	14:12	3:23	0.000000	REPLACEMET OF HT BUSHING ROD
1698	21-11-2025	Part of : PAHARWA COLONY CHAWLA	289	Other Outage	Planned Outage	21-11-2025	11:50	21-11-2025	14:30	2:40	0.002889	REPLACEMENT OF LT BUSHING ROD
1699	22-11-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH,	17	Other Outage	Planned Outage	22-11-2025	13:26	22-11-2025	14:55	1:29	0.000000	REPLACEMET OF HT BUSHING ROD
1700	22-11-2025	Part of : CHAWLA,	435	Other Outage	Planned Outage	22-11-2025	11:56	22-11-2025	14:32	2:36	0.002167	REPLACEMENT OF GAS KIT AND OIL SEAL
1701	22-11-2025	Part of : SECTOR 27 DWARKA,	321	Other Outage	Planned Outage	22-11-2025	12:17	22-11-2025	14:30	2:13	0.002956	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1702	22-11-2025	Part of : NAJAFGARH VILLAGE NAJAFGARH,ROSHAN PURA NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,PREM NAGAR NAJAFGARH,	351	Other Outage	Planned Outage	22-11-2025	10:41	22-11-2025	13:32	2:51	0.002850	REPLACEMENT OF CROSS-ARMS AND POLES
1703	23-11-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	65	Other Outage	Planned Outage	23-11-2025	13:56	23-11-2025	16:20	2:24	0.000800	REPLACEMENT OF LT BUSHING ROD
1704	24-11-2025	Part of : NAJAFGARH EXTENSION,AJAY PARK & NATHU RAM PARK MASUDABAD NAJAFGARH	1990	Other Outage	Unplanned Outage	24-11-2025	13:02	24-11-2025	13:05	0:03	0.000058	CONNECTION/DISCONNECTION OF HT/LT CABLES
1705	24-11-2025	Part of : A-BLOCK GOYLA VIHAR GOYLA KHURD	689	Other Outage	Planned Outage	24-11-2025	13:39	24-11-2025	16:12	2:33	0.003613	REPLACEMENT OF HT BUSHING ROD
1706	24-11-2025	Part of : POCKET 1 SECTOR 19 DWARKA	301	Other Outage	Planned Outage	24-11-2025	10:51	24-11-2025	14:04	3:13	0.004289	REPLACEMENT OF HT BUSHING ROD
1707	24-11-2025	Part of : DURGA PARK,DINARPUR EXTENSION,E-BLOCK SHYAM VIHAR-1 NAJAFGARH	1479	Other Outage	Planned Outage	24-11-2025	10:01	24-11-2025	13:10	3:09	0.000000	REPLACEMENT OF HT BUSHING ROD
1708	24-11-2025	Part of : NAJAFGARH VILLAGE	1244	Other Outage	Planned Outage	24-11-2025	10:22	24-11-2025	13:15	2:53	0.000961	REPLACEMENT OF HT BUSHING ROD
1709	25-11-2025	Part of : HASANPUR VILLAGE,ASALETPUR KHAWAD VILLAGE,DAULATPUR VILLAGE	3219	Other Outage	Planned Outage	25-11-2025	11:22	25-11-2025	11:43	0:21	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1710	25-11-2025	Part of : BLOCK A POCHANPUR DWARKA	1108	Other Outage	Planned Outage	25-11-2025	13:26	25-11-2025	15:02	1:36	0.000533	REPLACEMET OF HT BUSHING ROD
1711	25-11-2025	Part of : DHULSIRAS VILLAGE DWARKA	235	Other Outage	Planned Outage	25-11-2025	11:32	25-11-2025	13:25	1:53	0.002511	REPLACEMET OF HT BUSHING ROD
1712	25-11-2025	Part of : SAMTA ENCLAVE QUTUB VIHAR	1330	Other Outage	Planned Outage	25-11-2025	14:14	25-11-2025	16:33	2:19	0.001158	REPLACEMET OF HT BUSHING ROD
1713	25-11-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	524	Other Outage	Planned Outage	25-11-2025	12:35	25-11-2025	15:05	2:30	0.000000	FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1714	25-11-2025	Part of : PAPRAWAT VILLAGE	792	Other Outage	Planned Outage	25-11-2025	10:44	25-11-2025	12:56	2:12	0.000550	REPLACEMET OF HT BUSHING ROD
1715	25-11-2025	Part of : JAI VIHAR COLONY MASUDABAD NAJAFGARH	40	Other Outage	Planned Outage	25-11-2025	10:43	25-11-2025	12:54	2:11	0.000000	REPLACEMET OF HT BUSHING ROD
1716	25-11-2025	Part of : INDRA MARKET	318	Other Outage	Planned Outage	25-11-2025	11:06	25-11-2025	13:30	2:24	0.003600	REPLACEMET OF HT BUSHING ROD
1717	25-11-2025	Part of : QUTUB VIHAR PHASE 2	904	Other Outage	Planned Outage	25-11-2025	10:35	25-11-2025	12:53	2:18	0.002875	REPLACEMET OF HT BUSHING ROD
1718	26-11-2025	Part of : TODARMAL COLONY NAJAFGARH,NAJAFGARH VILLAGE,ROSHAN PURA NAJAFGARH,ROSHAN VIHAR NAJAFGARH,PREM NAGAR NAJAFGARH	2790	Other Outage	Unplanned Outage	26-11-2025	15:23	26-11-2025	16:04	0:41	0.000000	FAULT IN HT CONSUMER PANEL (PUMP HOUSE)
1719	26-11-2025	Part of : NAJAFGARH VILLAGE,TODARMAL COLONY NAJAFGARH,BLOCK A2 ROSHAN GARDEN MASUDABAD NAJAFGARH,ROSHAN PURA NAJAFGARH,ROSHAN VIHAR NAJAFGARH,PREM NAGAR NAJAFGARH	2924	Other Outage	Unplanned Outage	26-11-2025	14:18	26-11-2025	15:09	0:51	0.000000	HVDS FAULT
1720	26-11-2025	Part of : GOPAL EXTENSION II NAJAFGARH,	559	Other Outage	Planned Outage	26-11-2025	13:22	26-11-2025	16:01	2:39	0.000663	REPLACEMET OF HT BUSHING ROD
1721	26-11-2025	Part of : UGGERSAIN PARK,	430	Other Outage	Planned Outage	26-11-2025	11:32	26-11-2025	14:00	2:28	0.003700	REPLACEMET OF HT BUSHING ROD
1722	26-11-2025	Part of : SECTOR 29 DWARKA,	298	Other Outage	Planned Outage	26-11-2025	11:43	26-11-2025	15:00	3:17	0.002736	REPLACEMET OF HT BUSHING ROD
1723	26-11-2025	Part of : BLOCK Q NEW ROSHAN PURA NAJAFGARH,BLOCK E NEW ROSHAN PURA NAJAFGARH,	901	Other Outage	Planned Outage	26-11-2025	10:27	26-11-2025	12:58	2:31	0.000000	REPLACEMET OF HT BUSHING ROD
1724	26-11-2025	Part of : KANGANHERI VILLAGE,	170	Other Outage	Planned Outage	26-11-2025	11:54	26-11-2025	15:01	3:07	0.002338	REPLACEMET OF HT BUSHING ROD
1725	26-11-2025	Part of : ROSHAN PURA NAJAFGARH,	289	Other Outage	Planned Outage	26-11-2025	11:11	26-11-2025	13:21	2:10	0.000361	REPLACEMENT OF LT BUSHING ROD
1726	27-11-2025	Part of : SHIV NAGAR DICHAN KALAN	4	Other Outage	Planned Outage	27-11-2025	13:31	27-11-2025	16:13	2:42	0.004050	REPLACEMENT OF HT BUSHING ROD
1727	27-11-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	168	Other Outage	Planned Outage	27-11-2025	14:07	27-11-2025	16:14	2:07	0.000000	REPLACEMENT OF HT BUSHING ROD
1728	27-11-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	534	Other Outage	Planned Outage	27-11-2025	13:23	27-11-2025	15:26	2:03	0.000683	REPLACEMENT OF LT BUSHING ROD
1729	27-11-2025	Part of : POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA	247	Other Outage	Planned Outage	27-11-2025	13:05	27-11-2025	15:30	2:25	0.000806	REPLACEMENT OF LT BUSHING ROD
1730	27-11-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH,DURGA PARK NAJAFGARH,BLOCK Q NEW ROSHAN PURA NAJAFGARH	1107	Other Outage	Planned Outage	27-11-2025	10:02	27-11-2025	13:00	2:58	0.000000	REPLACEMENT OF HT BUSHING ROD
1731	27-11-2025	Part of : KANGANHERI VILLAGE	448	Other Outage	Planned Outage	27-11-2025	09:57	27-11-2025	13:00	3:03	0.002288	REPLACEMENT OF LT BUSHING ROD
1732	28-11-2025	Part of : VIL CHHAWLA,B.S.F CHAWLA CAMP	4159	Other Outage	Unplanned Outage	28-11-2025	05:46	28-11-2025	06:25	0:39	0.000455	CABLE FAULT
1733	28-11-2025	Part of : B-BLOCK NAVEEN PALACE JHARODA KALAN	503	Other Outage	Planned Outage	28-11-2025	13:41	28-11-2025	15:09	1:28	0.002200	REPLACEMET OF HT BUSHING ROD
1734	28-11-2025	Part of : B-BLOCK POCHANPUR DWARKA	981	Other Outage	Planned Outage	28-11-2025	14:49	28-11-2025	15:56	1:07	0.001489	REPLACEMET OF HT BUSHING ROD
1735	28-11-2025	Part of : A-BLOCK QUTUB VIHAR PHASE-1	738	Other Outage	Planned Outage	28-11-2025	13:06	28-11-2025	15:52	2:46	0.002306	REPLACEMET OF HT BUSHING ROD
1736	28-11-2025	Part of : RANAJI ENCLAVE & JAI VIHAR COLONY MASUDABAD NAJAFGARH	2370	Other Outage	Planned Outage	28-11-2025	10:39	28-11-2025	13:38	2:59	0.000000	REPLACEMET OF HT BUSHING ROD
1737	28-11-2025	Part of : NANGLI DAIRY NANGLI SAKRAWATI	323	Other Outage	Planned Outage	28-11-2025	11:27	28-11-2025	14:25	2:58	0.001483	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1738	29-11-2025	Part of : CHAWLA,SECTOR 27,28 & 29 DWARKA,SOMESH VIHAR CHAWLA	1402	Other Outage	Unplanned Outage	29-11-2025	09:11	29-11-2025	09:49	0:38	0.000011	CABLE FAULT
1739	29-11-2025	Part of : HASANPUR VILLAGE,ASALETPUR KHAWAD VILLAGE,DAULATPUR VILLAGE,KHERA DABAS VILLAGE	3220	Other Outage	Planned Outage	29-11-2025	11:12	29-11-2025	11:14	0:02	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1740	29-11-2025	Part of : BHARTHAL VILLAGE DWARKA	188	Other Outage	Planned Outage	29-11-2025	11:24	29-11-2025	12:52	1:28	0.001956	REPLACEMET OF HT BUSHING ROD
1741	29-11-2025	Part of : BLOCK X NEW ROSHAN PURA NAJAFGARH	1	Other Outage	Planned Outage	29-11-2025	10:33	29-11-2025	13:05	2:32	0.000000	REPLACEMET OF HT BUSHING ROD
1742	29-11-2025	Part of : NAJAFGARH VILLAGE,ROSHAN PURA NAJAFGARH,BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	351	Other Outage	Planned Outage	29-11-2025	11:32	29-11-2025	13:51	2:19	0.002124	REPLACEMENT OF CROSS-ARMS AND POLES
1743	29-11-2025	Part of : GOYLA KHURD	517	Other Outage	Planned Outage	29-11-2025	11:10	29-11-2025	14:57	3:47	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1744	30-11-2025	Part of : JHARODA KALAN,SHIV NAGAR DICHAN KALAN,BABA HARI DAS ENCLAVE JHARODA KALAN,TIKRI KALAN,BABA HARIDAS ENCLAVE,BLOCK A NAVEEN PALACE JHARODA KALAN	2572	Other Outage	Unplanned Outage	30-11-2025	12:37	30-11-2025	13:19	0:42	0.000782	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1745	01-11-2025	Part of : JANTA COLONY PASCHIM VIHAR	1587	Other Outage	Planned Outage	01-11-2025	13:14	01-11-2025	14:56	1:42	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1746	03-11-2025	PART OF : MADIPUR PUNJABI BAGH	856	Other Outage	Planned Outage	03-11-2025	14:50	03-11-2025	16:47	1:57	0.000650	INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1747	03-11-2025	PART OF : BLOCK A 6 PASCHIM VIHAR	490	Other Outage	Planned Outage	03-11-2025	12:20	03-11-2025	13:51	1:31	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1748	03-11-2025	PART OF : PUNJABI BAGH EXTENSION	371	Other Outage	Planned Outage	03-11-2025	10:25	03-11-2025	12:26	2:01	0.000672	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1749	03-11-2025	PART OF : BLOCK D MANOHAR PARK PUNJABI BAGH EAST PUNJABI BAGH	185	Other Outage	Planned Outage	03-11-2025	10:12	03-11-2025	12:22	2:10	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1750	04-11-2025	Part of : RBI ENCLAVE PASCHIM VIHAR	109	Other Outage	Planned Outage	04-11-2025	15:15	04-11-2025	17:06	1:51	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1751	06-11-2025	Part of : BLOCK C JAIDEV PARK PUNJABI BAGH EAST PUNJABI BAGH,GOLDEN PARK TRI NAGAR,BLOCK B MADAN PARK PUNJABI BAGH EAST PUNJABI BAGH,BLOCK D MANOHAR PARK PUNJABI BAGH EAST PUNJABI BAGH,ASHOK PARK EXTENSION PUNJABI BAGH EAST PUNJABI BAGH	1685	Other Outage	Unplanned Outage	06-11-2025	17:14	06-11-2025	18:01	0:47	0.000548	CABLE FAULT
1752	06-11-2025	Part of : MADHUBAN ENCLAVE PUNJABI BAGH,	748	Other Outage	Unplanned Outage	06-11-2025	15:25	06-11-2025	17:14	1:49	0.000303	MOBILE TRANSFORMER REPLACEMENT
1753	06-11-2025	Part of : BLOCK B MADAN PARK PUNJABI BAGH EAST PUNJABI BAGH,	150	Other Outage	Unplanned Outage	06-11-2025	14:19	06-11-2025	16:00	1:41	0.000281	MOBILE TRANSFORMER REPLACEMENT
1754	06-11-2025	Part of : BLOCK D JANTA COLONY PASCHIM VIHAR,	1161	Other Outage	Planned Outage	06-11-2025	12:11	06-11-2025	14:07	1:56	0.000483	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
1755	06-11-2025	Part of : COTTAGE ENCLAVE PASCHIM VIHAR,	129	Other Outage	Planned Outage	06-11-2025	12:12	06-11-2025	14:06	1:54	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
1756	06-11-2025	Part of : POCKET 1 PASCHIM PURI PASCHIM VIHAR,	1255	Other Outage	Planned Outage	06-11-2025	10:24	06-11-2025	12:12	1:48	0.000450	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
1757	06-11-2025	Part of : COTTAGE ENCLAVE PASCHIM VIHAR,	150	Other Outage	Planned Outage	06-11-2025	10:23	06-11-2025	12:11	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1758	07-11-2025	Part of : BLOCK A 5B PASCHIM VIHAR	462	Other Outage	Planned Outage	07-11-2025	11:05	07-11-2025	13:04	1:59	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1759	07-11-2025	Part of : BLOCK S SHIVAJI PARK PUNJABI BAGH	470	Other Outage	Planned Outage	07-11-2025	09:57	07-11-2025	12:17	2:20	0.000583	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
1760	07-11-2025	Part of : GOLDEN PARK TRI NAGAR	437	Other Outage	Planned Outage	07-11-2025	10:16	07-11-2025	12:16	2:00	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1761	08-11-2025	Part of : POCKET 1 PASCHIM PURI PASCHIM VIHAR	252	Other Outage	Planned Outage	08-11-2025	14:43	08-11-2025	17:04	2:21	0.000588	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1762	08-11-2025	Part of : PUNJABI BAGH EXTENSION	210	Other Outage	Planned Outage	08-11-2025	10:28	08-11-2025	13:58	3:30	0.000875	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
1763	10-11-2025	Part of : PASCHIM VIHAR EXTENSION PASCHIM VIHAR,	1339	Other Outage	Planned Outage	10-11-2025	12:43	10-11-2025	13:57	1:14	0.000308	PREVENTIVE MAINTENANCE
1764	10-11-2025	Part of : COTTAGE ENCLAVE PASCHIM VIHAR,	85	Other Outage	Planned Outage	10-11-2025	12:00	10-11-2025	13:58	1:58	0.000000	PREVENTIVE MAINTENANCE
1765	10-11-2025	Part of : PASCHIM VIHAR EXTENSION PASCHIM VIHAR,	1176	Other Outage	Planned Outage	10-11-2025	10:58	10-11-2025	12:44	1:46	0.000294	PREVENTIVE MAINTENANCE
1766	10-11-2025	Part of : COTTAGE ENCLAVE PASCHIM VIHAR,	62	Other Outage	Planned Outage	10-11-2025	10:08	10-11-2025	11:45	1:37	0.000000	PREVENTIVE MAINTENANCE
1767	11-11-2025	Part of : ASHOK PARK MAIN TRI NAGAR	171	Other Outage	Planned Outage	11-11-2025	10:07	11-11-2025	11:51	1:44	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,REPLACEMENT OF GAS KIT AND OIL SEAL
1768	11-11-2025	Part of : POCKET GH2 DISTRICT PARK PASCHIM VIHAR	18	Other Outage	Planned Outage	11-11-2025	11:24	11-11-2025	13:29	2:05	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1769	13-11-2025	Part of : BLOCK A 1 KRISHNA APARTMENT PASCHIM VIHAR	222	Other Outage	Planned Outage	13-11-2025	10:38	13-11-2025	12:59	2:21	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
1770	14-11-2025	Part of : A 2 BLOCK PASCHIM VIHAR	125	Other Outage	Planned Outage	14-11-2025	10:36	14-11-2025	13:24	2:48	0.000000	PREVENTIVE MAINTENANCE
1771	14-11-2025	Part of : PUNJABI BAGH EXTENSION	129	Other Outage	Planned Outage	14-11-2025	11:03	14-11-2025	14:36	3:33	0.000000	PREVENTIVE MAINTENANCE
1772	16-11-2025	Part of : POCKET 1 & 3 PASCHIM PURI PASCHIM VIHAR,JANTA COLONY PASCHIM VIHAR	3690	Other Outage	Unplanned Outage	16-11-2025	11:23	16-11-2025	12:10	0:47	0.000862	HT SYSTEM FAULT
1773	16-11-2025	Part of : BLOCK M SURYA ENCLAVE SHAKURBASTI	531	Other Outage	Planned Outage	16-11-2025	12:02	16-11-2025	13:39	1:37	0.000404	LT AB SAGGING
1774	17-11-2025	Part of : BLOCK BG 3 PASCHIM VIHAR	280	Other Outage	Unplanned Outage	17-11-2025	14:38	17-11-2025	16:46	2:08	0.000356	MOBILE TRANSFORMER REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1775	17-11-2025	Part of : KARAMPURA INDUSTRIAL AREA	659	Other Outage	Planned Outage	17-11-2025	10:05	17-11-2025	12:00	1:55	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1776	17-11-2025	Part of : PUNJABI BAGH EXTENSION	100	Other Outage	Planned Outage	17-11-2025	10:44	17-11-2025	12:35	1:51	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
1777	17-11-2025	Part of : BLOCK BG 6 PASCHIM VIHAR	343	Other Outage	Planned Outage	17-11-2025	10:28	17-11-2025	12:59	2:31	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
1778	18-11-2025	Part of : ARIHANT NAGAR PUNJABI BAGH,	261	Other Outage	Unplanned Outage	18-11-2025	14:01	18-11-2025	16:08	2:07	0.000353	REPAIRING OF LT CIRCUIT
1779	18-11-2025	Part of : BLOCK D MANOHAR PARK PUNJABI BAGH EAST PUNJABI BAGH,	971	Other Outage	Planned Outage	18-11-2025	12:20	18-11-2025	14:08	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1780	18-11-2025	Part of : POCKET GH2 DISTRICT PARK PASCHIM VIHAR,	42	Other Outage	Planned Outage	18-11-2025	12:24	18-11-2025	14:07	1:43	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1781	18-11-2025	Part of : POCKET GH2 DISTRICT PARK PASCHIM VIHAR,	234	Other Outage	Planned Outage	18-11-2025	10:28	18-11-2025	12:25	1:57	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1782	18-11-2025	Part of : BLOCK D MANOHAR PARK PUNJABI BAGH EAST PUNJABI BAGH,	971	Other Outage	Planned Outage	18-11-2025	10:01	18-11-2025	11:55	1:54	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1783	20-11-2025	Part of : A 5-BLOCK KRISHNA APARTMENT PASCHIM VIHAR	627	Other Outage	Planned Outage	20-11-2025	10:31	20-11-2025	12:00	1:29	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1784	21-11-2025	Part of : PUNJABI BAGH EXTENSION	274	Other Outage	Planned Outage	21-11-2025	10:27	21-11-2025	12:35	2:08	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1785	21-11-2025	Part of : BLOCK P PHASE 3 NEW MOTI NAGAR MOTI NAGAR	125	Other Outage	Planned Outage	21-11-2025	10:20	21-11-2025	12:32	2:12	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1786	21-11-2025	Part of : BLOCK B STATE BANK COLONY PASCHIM VIHAR	850	Other Outage	Planned Outage	21-11-2025	10:19	21-11-2025	12:34	2:15	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1787	22-11-2025	Part of : ASHOK PARK EXTENSION PUNJABI BAGH EAST PUNJABI BAGH,	373	Other Outage	Planned Outage	22-11-2025	11:39	22-11-2025	15:33	3:54	0.000650	ACB REPLACEMENT PER ACB
1788	24-11-2025	Part of : C-BLOCK SHIVAJI PARK,RAILWAY COLONY NORTH SHAKURBASTI,WEST PUNJABI BAGH	1305	Other Outage	Unplanned Outage	24-11-2025	15:37	24-11-2025	16:26	0:49	0.000000	CABLE FAULT
1789	24-11-2025	Part of : B4-BLOCK PASCHIM VIHAR	169	Other Outage	Planned Outage	24-11-2025	12:03	24-11-2025	12:15	0:12	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1790	24-11-2025	Part of : B 4-BLOCK PASCHIM VIHAR	169	Other Outage	Planned Outage	24-11-2025	10:33	24-11-2025	11:57	1:24	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1791	24-11-2025	Part of : POCKET 1 PASCHIM PURI PASCHIM VIHAR	1016	Other Outage	Planned Outage	24-11-2025	11:00	24-11-2025	13:52	2:52	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1792	25-11-2025	Part of : BLOCK A 2B PASCHIM VIHAR	223	Other Outage	Planned Outage	25-11-2025	11:56	25-11-2025	12:44	0:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1793	26-11-2025	Part of : JWALAHERI VILLAGE PASCHIM VIHAR,IFCI COLONY PASCHIM VIHAR,BLOCK B 3 PASCHIM VIHAR	1785	Other Outage	Unplanned Outage	26-11-2025	09:25	26-11-2025	10:13	0:48	0.000480	CABLE FAULT
1794	26-11-2025	Part of : BLOCK D MANOHAR PARK PUNJABI BAGH EAST PUNJABI BAGH,	353	Other Outage	Unplanned Outage	26-11-2025	13:54	26-11-2025	16:09	2:15	0.000000	MOBILE TRANSFORMER REPLACEMENT
1795	26-11-2025	Part of : STATE BANK COLONY PASCHIM VIHAR,	103	Other Outage	Planned Outage	26-11-2025	13:12	26-11-2025	14:00	0:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1796	26-11-2025	Part of : JANTA COLONY PASCHIM VIHAR,	1415	Other Outage	Planned Outage	26-11-2025	10:52	26-11-2025	13:14	2:22	0.000789	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1797	26-11-2025	Part of : STATE BANK COLONY PASCHIM VIHAR,	103	Other Outage	Planned Outage	26-11-2025	10:43	26-11-2025	13:13	2:30	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1798	27-11-2025	Part of : BLOCK BG 6 PASCHIM VIHAR	190	Other Outage	Planned Outage	27-11-2025	10:35	27-11-2025	12:35	2:00	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
1799	28-11-2025	Part of : POCKET GH2 DISTRICT PARK PASCHIM VIHAR	165	Other Outage	Planned Outage	28-11-2025	13:42	28-11-2025	15:05	1:23	0.000000	CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
1800	28-11-2025	Part of : A 5B-BLOCK PASCHIM VIHAR	462	Other Outage	Planned Outage	28-11-2025	10:39	28-11-2025	12:27	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1801	28-11-2025	Part of : HOUSE COMPLEX MARKET KARAMPURA INDUSTRIAL AREA	129	Other Outage	Planned Outage	28-11-2025	10:03	28-11-2025	12:01	1:58	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF GAS KIT AND OIL SEAL
1802	29-11-2025	Part of : JWALAHERI VILLAGE, IFCI COLONY PASCHIM VIHAR, BLOCK B 3 PASCHIM VIHAR, PEERAGARHI BOOSTER PASCHIM VIHAR (HTC)	1785	Other Outage	Unplanned Outage	29-11-2025	05:58	29-11-2025	06:44	0:46	0.000243	FAULT IN HT CONSUMER PANEL (BOOSTER PUMP)
1803	29-11-2025	Part of : BLOCK I KARAMPURA WEST	276	Other Outage	Planned Outage	29-11-2025	09:57	29-11-2025	12:50	2:53	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1804	01-11-2025	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY MAHAVIR ENCLAVE PART 2	1832	Other Outage	Planned Outage	01-11-2025	13:32	01-11-2025	15:05	1:33	0.000517	DB REVAMPING,LT BUSHING REPLACEMENT
1805	01-11-2025	Part of : BLOCK G 1 MAHAVIR ENCLAVE PART 1	1749	Other Outage	Planned Outage	01-11-2025	13:27	01-11-2025	14:35	1:08	0.000378	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1806	01-11-2025	Part of : JAGDAMBA VIHAR SAGARPUR WEST	1422	Other Outage	Planned Outage	01-11-2025	13:37	01-11-2025	15:06	1:29	0.000494	DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
1807	01-11-2025	Part of : BLOCK J PALAM	1234	Other Outage	Planned Outage	01-11-2025	13:25	01-11-2025	14:35	1:10	0.000389	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1808	01-11-2025	Part of : BLOCK A RAJ NAGAR 1	708	Other Outage	Planned Outage	01-11-2025	13:23	01-11-2025	15:26	2:03	0.000683	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1809	03-11-2025	PART OF : BLOCK RZB SABZI MANDI SAGARPUR MAIN	1172	Other Outage	Planned Outage	03-11-2025	10:40	03-11-2025	12:23	1:43	0.000572	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL SUB STATION CLEANING
1810	03-11-2025	PART OF : PALAM EXTENSION PALAM	158	Other Outage	Planned Outage	03-11-2025	11:14	03-11-2025	15:04	3:50	0.001278	GUARD WIRES SAGGING PER SPAN
1811	03-11-2025	PART OF : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE	632	Other Outage	Planned Outage	03-11-2025	11:11	03-11-2025	14:05	2:54	0.000967	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1812	03-11-2025	PART OF : BLOCK A RAJ NAGAR 1 RAJ NAGAR	881	Other Outage	Planned Outage	03-11-2025	11:18	03-11-2025	16:04	4:46	0.001589	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1813	03-11-2025	PART OF : PALAM VIHAR SADH NAGAR 1 PALAM	1136	Other Outage	Planned Outage	03-11-2025	11:04	03-11-2025	13:49	2:45	0.000917	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1814	04-11-2025	Part of : MAHAVIR ENCLAVE PART-2,PALAM COLONY	4476	Other Outage	Unplanned Outage	04-11-2025	17:05	04-11-2025	17:30	0:25	0.000104	HVDS FAULT
1815	04-11-2025	Part of : DELHI POLICE RESIDENCE SEC-9 DWARKA	130	Other Outage	Planned Outage	04-11-2025	13:57	04-11-2025	14:36	0:39	0.000217	HT CONDUCTOR REPLACEMENT
1816	04-11-2025	Part of : MOHAN BLK SGR PUR	628	Other Outage	Planned Outage	04-11-2025	15:00	04-11-2025	16:56	1:56	0.000644	LT AB SAGGING
1817	04-11-2025	Part of : C-BLOCK SADH NAGAR II PALAM	1874	Other Outage	Planned Outage	04-11-2025	10:59	04-11-2025	12:17	1:18	0.000433	LT CIRCUIT MAINTENANCE WORK
1818	04-11-2025	Part of : BHARAT VANDANA PARK,SEC-20	1	Other Outage	Planned Outage	04-11-2025	11:17	04-11-2025	12:52	1:35	0.000528	LT AB SAGGING
1819	04-11-2025	Part of : B-BLOCK SECTOR 8 DWARKA	193	Other Outage	Planned Outage	04-11-2025	11:40	04-11-2025	16:57	5:17	0.001761	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1820	04-11-2025	Part of : D-BLOCK RAJ NAGAR 1	867	Other Outage	Planned Outage	04-11-2025	13:52	04-11-2025	16:12	2:20	0.000778	LT CIRCUIT MAINTENANCE WORK
1821	04-11-2025	Part of : CHATRI WALA MARG RAJ NAGAR	869	Other Outage	Planned Outage	04-11-2025	11:16	04-11-2025	13:53	2:37	0.000872	LT AB SAGGING
1822	04-11-2025	Part of : H-BLOCK PALAM EXTENSION	712	Other Outage	Planned Outage	04-11-2025	11:01	04-11-2025	13:53	2:52	0.000956	LT CIRCUIT MAINTENANCE WORK
1823	04-11-2025	Part of : A-BLOCK MAHAVIR ENCLAVE	31	Other Outage	Planned Outage	04-11-2025	10:52	04-11-2025	13:25	2:33	0.000850	LT CIRCUIT MAINTENANCE WORK
1824	06-11-2025	Part of : VAISHALI EXTENSION DASRATHPURI,	601	Other Outage	Planned Outage	06-11-2025	14:52	06-11-2025	16:07	1:15	0.000417	LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1825	06-11-2025	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN SAGARPUR,	1301	Other Outage	Planned Outage	06-11-2025	10:58	06-11-2025	12:55	1:57	0.000650	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF LUGS,SUB STATION CLEANING
1826	06-11-2025	Part of : SHASTRI MARG, RAJ NAGAR	552	Other Outage	Planned Outage	06-11-2025	12:57	06-11-2025	15:41	2:44	0.000911	LT AB SAGGING PER SPAN
1827	06-11-2025	Part of : BLOCK A MAHAVIR ENCLAVE,	4	Other Outage	Planned Outage	06-11-2025	10:57	06-11-2025	13:50	2:53	0.000961	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1828	06-11-2025	Part of : BLOCK RZ PALAM,	506	Other Outage	Planned Outage	06-11-2025	11:12	06-11-2025	13:56	2:44	0.000911	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1829	06-11-2025	Part of : BLOCK WZ RAJ NAGAR 2 RAJ NAGAR,	1304	Other Outage	Planned Outage	06-11-2025	11:03	06-11-2025	14:51	3:48	0.001267	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1830	07-11-2025	Part of : NASIRPUR	203	Other Outage	Planned Outage	07-11-2025	15:35	07-11-2025	16:39	1:04	0.000356	INSTALLATION OF BUS BAR
1831	07-11-2025	Part of : BLOCK B 2 DASRATHPURI,BLOCK C DASRATHPURI,BLOCK B DABRI EXTENSION EAST DABRI,DURGA PARK COLONY DASRATHPURI	868	Other Outage	Planned Outage	07-11-2025	14:03	07-11-2025	15:47	1:44	0.000578	DB REVAMPING,LT BUSHING REPLACEMENT
1832	07-11-2025	Part of : DURGA PARK	1199	Other Outage	Planned Outage	07-11-2025	11:24	07-11-2025	14:02	2:38	0.000878	INSTALLATION OF BUS BAR
1833	07-11-2025	Part of : BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR,SECTOR 8 DWARKA	959	Other Outage	Planned Outage	07-11-2025	11:00	07-11-2025	14:49	3:49	0.001272	DB REVAMPING,ST.TH JOINT ON 1PH HT AB
1834	07-11-2025	Part of : BLOCK B SADH NAGAR II PALAM	1420	Other Outage	Planned Outage	07-11-2025	10:44	07-11-2025	13:27	2:43	0.000906	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1835	07-11-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM	518	Other Outage	Planned Outage	07-11-2025	11:55	07-11-2025	13:29	1:34	0.000522	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1836	07-11-2025	Part of : BLOCK R RAGHU NAGAR DABRI	678	Other Outage	Planned Outage	07-11-2025	12:03	07-11-2025	15:45	3:42	0.001233	LT AB SAGGING PER SPAN
1837	07-11-2025	Part of : INDRAPARK	687	Other Outage	Planned Outage	07-11-2025	11:25	07-11-2025	15:12	3:47	0.001261	LT AB SAGGING PER SPAN
1838	08-11-2025	Part of : C-BLOCK VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE	483	Other Outage	Planned Outage	08-11-2025	12:30	08-11-2025	14:26	1:56	0.000644	LT CIRCUIT MAINTENANCE WORK
1839	08-11-2025	Part of : SECTOR 8 DWARKA,P-BLOCK RAJ NAGAR EXTENSION	55	Other Outage	Planned Outage	08-11-2025	11:13	08-11-2025	14:58	3:45	0.001250	DB REVAMPING,HT BUSHING ROD REPLACEMENT
1840	08-11-2025	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART-1,MIRZAPUR MAHAVIR ENCLAVE	829	Other Outage	Planned Outage	08-11-2025	11:15	08-11-2025	14:04	2:49	0.000939	DB REVAMPING,HT BUSHING REPLACEMENT
1841	08-11-2025	Part of : D-BLOCK RAJ NAGAR-1	869	Other Outage	Planned Outage	08-11-2025	13:12	08-11-2025	16:54	3:42	0.001233	LT CIRCUIT MAINTENANCE WORK
1842	08-11-2025	Part of : RZB-BLOCK SABZI MANDI SAGARPUR MAIN	1174	Other Outage	Planned Outage	08-11-2025	12:38	08-11-2025	16:26	3:48	0.001267	LT CIRCUIT MAINTENANCE WORK
1843	08-11-2025	Part of : RZ-BLOCK GANDHI MARKET SAGARPUR MAIN	848	Other Outage	Planned Outage	08-11-2025	10:37	08-11-2025	13:30	2:53	0.000961	LT CIRCUIT MAINTENANCE WORK
1844	10-11-2025	Part of : BLOCK E SITAPURI PART 1 SITAPURI,	1758	Other Outage	Planned Outage	10-11-2025	13:52	10-11-2025	14:51	0:59	0.000328	LT CIRCUIT NETWORK UPGRADATION
1845	10-11-2025	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,	901	Other Outage	Planned Outage	10-11-2025	15:05	10-11-2025	16:13	1:08	0.000378	LT CIRCUIT NETWORK UPGRADATION
1846	10-11-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM,	1384	Other Outage	Planned Outage	10-11-2025	12:11	10-11-2025	13:55	1:44	0.000578	LT CIRCUIT PREVENTIVE MAINTENANCE
1847	10-11-2025	Part of : BLOCK B DASRATHPURI,DABRI VILLAGE DABRI,VAISHALI EXTENSION DASRATHPURI,	246	Other Outage	Planned Outage	10-11-2025	12:01	10-11-2025	14:56	2:55	0.000972	MAINTENANCE
1848	10-11-2025	Part of : PALAM EXTENSION PALAM,	158	Other Outage	Planned Outage	10-11-2025	10:08	10-11-2025	13:49	3:41	0.000000	PROBLEM IN RMU
1849	10-11-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM,	518	Other Outage	Planned Outage	10-11-2025	11:12	10-11-2025	13:59	2:47	0.000928	MAINTENANCE
1850	10-11-2025	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI,	628	Other Outage	Planned Outage	10-11-2025	12:54	10-11-2025	15:48	2:54	0.000967	LT CIRCUIT NETWORK UPGRADATION

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1851	10-11-2025	Part of : BLOCK C PALAM EXTENSION PALAM,	827	Other Outage	Planned Outage	10-11-2025	11:27	10-11-2025	14:01	2:34	0.000856	LT CIRCUIT PREVENTIVE MAINTENANCE
1852	10-11-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1187	Other Outage	Planned Outage	10-11-2025	11:39	10-11-2025	14:49	3:10	0.001056	LT CIRCUIT PREVENTIVE MAINTENANCE
1853	11-11-2025	Part of : VEER NAGAR SAGARPUR WEST SAGARPUR	1265	Other Outage	Planned Outage	11-11-2025	11:32	11-11-2025	13:16	1:44	0.000578	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1854	11-11-2025	Part of : BLOCK G & J SAGARPUR WEST SAGARPUR	645	Other Outage	Planned Outage	11-11-2025	12:40	11-11-2025	15:21	2:41	0.000894	DB REVAMPING,LT BUSHING REPLACEMENT
1855	11-11-2025	Part of : BHARAT VANDANA PARK,SEC-20	1	Other Outage	Planned Outage	11-11-2025	11:37	11-11-2025	15:16	3:39	0.001217	LT AB SAGGING PER SPAN
1856	11-11-2025	Part of : VAISHALI EXTENSION DASRATHPURI	601	Other Outage	Planned Outage	11-11-2025	13:03	11-11-2025	15:43	2:40	0.000889	LT AB SAGGING PER SPAN
1857	11-11-2025	Part of : MANGALPURI I PALAM	1077	Other Outage	Planned Outage	11-11-2025	11:44	11-11-2025	14:07	2:23	0.000794	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER
1858	11-11-2025	Part of : BLOCK B RAJ NAGAR 2 RAJ NAGAR	1832	Other Outage	Planned Outage	11-11-2025	11:35	11-11-2025	15:17	3:42	0.001233	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1859	12-11-2025	Part of : A-BLOCK MAHAVIR ENCLAVE,VAISHALI EXTENSION DASRATHPURI	386	Other Outage	Unplanned Outage	12-11-2025	14:55	12-11-2025	15:41	0:46	0.000473	CABLE FAULT
1860	12-11-2025	Part of : BLOCK B DABRI EXTENSION EAST	1246	Other Outage	Unplanned Outage	12-11-2025	18:20	12-11-2025	18:46	0:26	0.000014	REPAIR/REPLACEMENT OF DB AND SERVICE LINE
1861	12-11-2025	Part of : BLOCK A MAHAVIR ENCLAVE	544	Other Outage	Planned Outage	12-11-2025	11:10	12-11-2025	12:56	1:46	0.000589	LT AB SAGGING
1862	12-11-2025	Part of : POCKET 10 SECTOR I DURGA PARK COLONY DASRATHPURI	582	Other Outage	Planned Outage	12-11-2025	11:26	12-11-2025	14:15	2:49	0.000939	DB REVAMPING,HT BUSHING REPLACEMENT
1863	12-11-2025	Part of : BLOCK B RAJ NAGAR 2 RAJ NAGAR	1453	Other Outage	Planned Outage	12-11-2025	12:03	12-11-2025	15:47	3:44	0.001244	LT CIRCUIT MAINTENANCE
1864	12-11-2025	Part of : PALAM VILLAGE PALAM	595	Other Outage	Planned Outage	12-11-2025	12:02	12-11-2025	14:46	2:44	0.000911	LT CIRCUIT MAINTENANCE
1865	12-11-2025	Part of : VEER NAGAR SAGARPUR WEST SAGARPUR	1269	Other Outage	Planned Outage	12-11-2025	12:01	12-11-2025	15:48	3:47	0.001261	LT CIRCUIT MAINTENANCE
1866	12-11-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE	1051	Other Outage	Planned Outage	12-11-2025	11:13	12-11-2025	14:55	3:42	0.001233	LT AB SAGGING
1867	12-11-2025	Part of : BLOCK R RAGHU NAGAR DABRI	671	Other Outage	Planned Outage	12-11-2025	11:20	12-11-2025	14:54	3:34	0.001189	LT AB SAGGING
1868	13-11-2025	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI	1687	Other Outage	Planned Outage	13-11-2025	11:57	13-11-2025	13:24	1:27	0.000483	LT AB SAGGING PER SPAN
1869	13-11-2025	Part of : BLOCK F RAJ NAGAR EXTENSION	1367	Other Outage	Planned Outage	13-11-2025	12:35	13-11-2025	14:08	1:33	0.000517	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1870	13-11-2025	Part of : BLOCK F RAJ NAGAR EXTENSION	1968	Other Outage	Planned Outage	13-11-2025	11:14	13-11-2025	15:01	3:47	0.001261	DB REVAMPING,HT BUSHING ROD REPLACEMENT
1871	13-11-2025	Part of : BLOCK D RAJ NAGAR 1	869	Other Outage	Planned Outage	13-11-2025	11:03	13-11-2025	14:53	3:50	0.001278	LT AB SAGGING PER SPAN
1872	13-11-2025	Part of : PALAM VILLAGE	562	Other Outage	Planned Outage	13-11-2025	11:41	13-11-2025	14:26	2:45	0.000917	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1873	13-11-2025	Part of : BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM	1560	Other Outage	Planned Outage	13-11-2025	10:28	13-11-2025	13:01	2:33	0.000850	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
1874	14-11-2025	Part of : PALAM COLONY SADH NAGAR PALAM,KHERA VILLAGE SADH NAGAR PALAM	3832	Other Outage	Unplanned Outage	14-11-2025	16:05	14-11-2025	16:48	0:43	0.000287	BIRDAGE
1875	14-11-2025	Part of : A BLOCK MAHAVIR ENCLAVE	411	Other Outage	Planned Outage	14-11-2025	13:02	14-11-2025	15:47	2:45	0.000917	LT CIRCUIT PREVENTIVE MAINTENANCE
1876	14-11-2025	Part of : WZ BLOCK RAJ NAGAR 2 RAJ NAGAR	1636	Other Outage	Planned Outage	14-11-2025	11:07	14-11-2025	14:58	3:51	0.001283	LT CIRCUIT PREVENTIVE MAINTENANCE
1877	14-11-2025	Part of : MAHAVIR ENCLAVE PART 2	1097	Other Outage	Planned Outage	14-11-2025	10:52	14-11-2025	12:54	2:02	0.000678	LT CIRCUIT PREVENTIVE MAINTENANCE
1878	15-11-2025	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,SECTOR 1 DWARKA,MIRZAPUR MAHAVIR ENCLAVE	7166	Other Outage	Unplanned Outage	15-11-2025	09:36	15-11-2025	10:09	0:33	0.000458	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1879	15-11-2025	Part of : BLOCK B MANGALPURI II PALAM	556	Other Outage	Unplanned Outage	15-11-2025	04:35	15-11-2025	05:22	0:47	0.000261	TRANSIENT FAULT
1880	15-11-2025	Part of : BLOCK WZ RAJ NAGAR 2	983	Other Outage	Planned Outage	15-11-2025	13:46	15-11-2025	15:13	1:27	0.000483	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1881	15-11-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR	1968	Other Outage	Planned Outage	15-11-2025	10:57	15-11-2025	14:48	3:51	0.001283	1PH HT AB CABLE REPLACEMENT PER SPAN,1PH HT AB END TERMINATION REPLACEMENT
1882	15-11-2025	Part of : SECTOR 20 DWARKA	1	Other Outage	Planned Outage	15-11-2025	12:40	15-11-2025	15:26	2:46	0.000922	LT AB SAGGING PER SPAN
1883	15-11-2025	Part of : BLOCK A MAHAVIR ENCLAVE	545	Other Outage	Planned Outage	15-11-2025	12:40	15-11-2025	15:13	2:33	0.000850	LT AB SAGGING PER SPAN
1884	15-11-2025	Part of : POCKET 13 MANGALPURI I PALAM	278	Other Outage	Planned Outage	15-11-2025	11:13	15-11-2025	13:48	2:35	0.000861	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1885	15-11-2025	Part of : BLOCK RZ GEETANJALI PARK SAGARPUR WEST SAGARPUR	1780	Other Outage	Planned Outage	15-11-2025	11:46	15-11-2025	13:47	2:01	0.000672	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
1886	15-11-2025	Part of : BLOCK R RAGHU NAGAR DABRI	678	Other Outage	Planned Outage	15-11-2025	10:35	15-11-2025	14:26	3:51	0.001283	LT AB SAGGING PER SPAN
1887	17-11-2025	Part of : KAILASHPURI MAIN PALAM,BLOCK R INDRA PARK PALEM KAILASHPURI MAIN PALAM,BLOCK RZ KAMAL PARK KAILASHPURI MAIN PALAM	8718	Other Outage	Unplanned Outage	17-11-2025	02:16	17-11-2025	02:46	0:30	0.000183	CABLE FAULT
1888	17-11-2025	Part of : BLOCK B MANGALPURI II PALAM	556	Other Outage	Unplanned Outage	17-11-2025	07:31	17-11-2025	08:22	0:51	0.000935	BIRDAGE
1889	17-11-2025	Part of : BLOCK J RAJ NAGAR 2	1401	Other Outage	Planned Outage	17-11-2025	12:35	17-11-2025	14:12	1:37	0.000539	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1890	17-11-2025	Part of : TAMILAR ENCLAVE VIJAY ENCLAVE MAHAVIR ENCLAVE	356	Other Outage	Planned Outage	17-11-2025	10:53	17-11-2025	13:22	2:29	0.000828	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
1891	17-11-2025	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	1165	Other Outage	Planned Outage	17-11-2025	10:53	17-11-2025	13:33	2:40	0.000889	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
1892	17-11-2025	Part of : PALAM VILLAGE	76	Other Outage	Planned Outage	17-11-2025	11:07	17-11-2025	13:49	2:42	0.000900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1893	17-11-2025	Part of : BLOCK A MAHAVIR ENCLAVE	539	Other Outage	Planned Outage	17-11-2025	11:40	17-11-2025	14:38	2:58	0.000989	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1894	18-11-2025	Part of : PALAM VILLAGE PALAM,	953	Other Outage	Planned Outage	18-11-2025	11:16	18-11-2025	12:59	1:43	0.000572	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1895	18-11-2025	Part of : BLOCK G RAJ NAGAR 2 RAJ NAGAR,	712	Other Outage	Planned Outage	18-11-2025	11:00	18-11-2025	14:54	3:54	0.001300	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1896	18-11-2025	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,PALAM COLONY MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,	526	Other Outage	Planned Outage	18-11-2025	10:50	18-11-2025	13:41	2:51	0.001425	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF LUGS,SUB STATION CLEANING
1897	18-11-2025	Part of : DABRI VILLAGE DABRI,	500	Other Outage	Planned Outage	18-11-2025	11:33	18-11-2025	14:10	2:37	0.000872	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1898	19-11-2025	Part of : POCKET B & R KAILASHPURI EAST KAILASHPURI MAIN PALAM,INDRA PARK PALEM KAILASHPURI MAIN PALAM,KAILASHPURI MAIN PALAM	2879	Other Outage	Planned Outage	19-11-2025	11:04	19-11-2025	13:22	2:18	0.000767	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1899	19-11-2025	Part of : PALAM EXTENSION PALAM	158	Other Outage	Planned Outage	19-11-2025	10:39	19-11-2025	13:16	2:37	0.001090	REPLACEMENT OF FAULTY END BOX
1900	19-11-2025	Part of : BLOCK B DABRI EXTENSION EAST DABRI	1253	Other Outage	Planned Outage	19-11-2025	12:11	19-11-2025	15:19	3:08	0.001044	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1901	19-11-2025	Part of : BLOCK D SECTOR 8 DWARKA	793	Other Outage	Planned Outage	19-11-2025	11:05	19-11-2025	14:54	3:49	0.001272	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1902	19-11-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM	519	Other Outage	Planned Outage	19-11-2025	11:12	19-11-2025	14:00	2:48	0.000933	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1903	20-11-2025	Part of : POCKET B & RZ-BLOCK KAMAL PARK KAILASHPURI MAIN PALAM,INDIRA PARK EXTENSION	1787	Other Outage	Planned Outage	20-11-2025	11:28	20-11-2025	14:15	2:47	0.000928	DB REVAMPING,HT BUSHING ROD REPLACEMENT
1904	20-11-2025	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM	332	Other Outage	Planned Outage	20-11-2025	12:25	20-11-2025	15:19	2:54	0.000967	LT CIRCUIT MAINTENANCE WORK
1905	20-11-2025	Part of : D-BLOCK RAJ NAGAR-1	910	Other Outage	Planned Outage	20-11-2025	10:44	20-11-2025	14:28	3:44	0.001244	LT CIRCUIT MAINTENANCE WORK
1906	20-11-2025	Part of : B-BLOCK SECTOR 8 DWARKA	573	Other Outage	Planned Outage	20-11-2025	11:11	20-11-2025	15:00	3:49	0.001272	LT CIRCUIT MAINTENANCE WORK
1907	20-11-2025	Part of : DABRI EXTENSION EAST	1281	Other Outage	Planned Outage	20-11-2025	11:12	20-11-2025	15:02	3:50	0.001278	LT CIRCUIT MAINTENANCE WORK
1908	20-11-2025	Part of : C-BLOCK MAHAVIR ENCLAVE PART-1	1347	Other Outage	Planned Outage	20-11-2025	11:10	20-11-2025	14:00	2:50	0.000944	LT CIRCUIT MAINTENANCE WORK
1909	21-11-2025	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY MAHAVIR ENCLAVE PART 2	2619	Other Outage	Planned Outage	21-11-2025	11:24	21-11-2025	13:51	2:27	0.000817	DB REVAMPING,HT BUSHING ROD REPLACEMENT,INSULATOR REPLACEMENT
1910	21-11-2025	Part of : VEER NAGAR SAGARPUR WEST	1269	Other Outage	Planned Outage	21-11-2025	13:03	21-11-2025	15:40	2:37	0.000872	LT AB SAGGING PER SPAN
1911	21-11-2025	Part of : VAISHALI EXTENSION DASRATHPURI	766	Other Outage	Planned Outage	21-11-2025	11:12	21-11-2025	14:56	3:44	0.001244	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1912	21-11-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1	551	Other Outage	Planned Outage	21-11-2025	10:53	21-11-2025	13:45	2:52	0.000956	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1913	21-11-2025	Part of : SECTOR 8 DWARKA	548	Other Outage	Planned Outage	21-11-2025	11:32	21-11-2025	15:24	3:52	0.001289	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1914	22-11-2025	Part of : PALAM EXTENSION PALAM	507	Other Outage	Unplanned Outage	22-11-2025	04:05	22-11-2025	04:58	0:53	0.000000	HT SYSTEM FAULT
1915	22-11-2025	Part of : JAGDAMBA VIHAR SAGARPUR WEST SAGARPUR,	1241	Other Outage	Planned Outage	22-11-2025	12:10	22-11-2025	13:51	1:41	0.000561	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF LUGS,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1916	22-11-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	1482	Other Outage	Planned Outage	22-11-2025	12:11	22-11-2025	13:52	1:41	0.000561	LT AB SAGGING PER SPAN
1917	22-11-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1346	Other Outage	Planned Outage	22-11-2025	12:13	22-11-2025	14:43	2:30	0.000833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1918	22-11-2025	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN PALAM,	900	Other Outage	Planned Outage	22-11-2025	10:58	22-11-2025	14:41	3:43	0.001239	LT AB SAGGING PER SPAN
1919	22-11-2025	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	1101	Other Outage	Planned Outage	22-11-2025	11:49	22-11-2025	14:17	2:28	0.000822	DB REVAMPING,LT BUSHING REPLACEMENT
1920	22-11-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1192	Other Outage	Planned Outage	22-11-2025	11:47	22-11-2025	13:53	2:06	0.000700	LT AB SAGGING PER SPAN
1921	22-11-2025	Part of : VAISHALI COLONY DASRATHPURI,	267	Other Outage	Planned Outage	22-11-2025	11:24	22-11-2025	14:14	2:50	0.000944	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,SUB STATION CLEANING
1922	24-11-2025	Part of : SECTOR 22 DWARKA	11	Other Outage	Planned Outage	24-11-2025	12:06	24-11-2025	13:32	1:26	0.000478	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1923	24-11-2025	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1,MIRZAPUR	829	Other Outage	Planned Outage	24-11-2025	12:08	24-11-2025	13:34	1:26	0.000478	HT BUSHING REPLACEMENT,ST.TH JOINT ON 1PH HT AB
1924	24-11-2025	Part of : JAGDAMBA VIHAR SAGARPUR WEST	1422	Other Outage	Planned Outage	24-11-2025	12:01	24-11-2025	13:31	1:30	0.000500	LT CIRCUIT MAINTENANCE WORK
1925	24-11-2025	Part of : TAMILAR ENCLAVE VIJAY ENCLAVE MAHAVIR ENCLAVE	355	Other Outage	Planned Outage	24-11-2025	12:09	24-11-2025	13:31	1:22	0.000456	LT CIRCUIT MAINTENANCE WORK
1926	24-11-2025	Part of : A-BLOCK RAJ NAGAR-1	968	Other Outage	Planned Outage	24-11-2025	10:58	24-11-2025	12:36	1:38	0.000544	LT CIRCUIT MAINTENANCE WORK
1927	24-11-2025	Part of : JAGDAMBA VIHAR SAGARPUR WEST	1421	Other Outage	Planned Outage	24-11-2025	10:19	24-11-2025	12:02	1:43	0.000572	LT CIRCUIT MAINTENANCE WORK
1928	24-11-2025	Part of : F-BLOCK RAJ NAGAR EXTENSION	1354	Other Outage	Planned Outage	24-11-2025	11:38	24-11-2025	15:30	3:52	0.001289	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1929	24-11-2025	Part of : B-BLOCK DASRATHPURI	894	Other Outage	Planned Outage	24-11-2025	11:07	24-11-2025	15:02	3:55	0.001306	LT CIRCUIT MAINTENANCE WORK
1930	24-11-2025	Part of : SECTOR 1 DWARKA	553	Other Outage	Planned Outage	24-11-2025	11:05	24-11-2025	13:59	2:54	0.000967	LT CIRCUIT MAINTENANCE WORK
1931	25-11-2025	Part of : POCKET B KAILASHPURI EAST KAILASHPURI MAIN	900	Other Outage	Planned Outage	25-11-2025	13:34	25-11-2025	14:29	0:55	0.000306	LT AB SAGGING PER SPAN
1932	25-11-2025	Part of : POCKET 1 SECTOR 23 DWARKA	162	Other Outage	Planned Outage	25-11-2025	12:11	25-11-2025	13:38	1:27	0.000242	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
1933	25-11-2025	Part of : BLOCK G RAJ NAGAR 2	922	Other Outage	Planned Outage	25-11-2025	12:10	25-11-2025	13:37	1:27	0.000483	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1934	25-11-2025	Part of : BLOCK B DASRATHPURI	785	Other Outage	Planned Outage	25-11-2025	11:45	25-11-2025	14:29	2:44	0.000911	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1935	26-11-2025	Part of : POCKET 13 MANGALPURI I PALAM,	161	Other Outage	Planned Outage	26-11-2025	12:50	26-11-2025	14:15	1:25	0.000472	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1936	26-11-2025	Part of : BLOCK P RAJ NAGAR EXTENSION RAJ NAGAR,	864	Other Outage	Planned Outage	26-11-2025	11:34	26-11-2025	15:30	3:56	0.001311	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1937	26-11-2025	Part of : BLOCK B CHANDAR VIHAR PALAM EXTENSION PALAM,	388	Other Outage	Planned Outage	26-11-2025	10:49	26-11-2025	13:40	2:51	0.000950	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1938	26-11-2025	Part of : BLOCK B SADH NAGAR II PALAM,	1420	Other Outage	Planned Outage	26-11-2025	11:04	26-11-2025	13:34	2:30	0.000833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,SUB STATION CLEANING
1939	26-11-2025	Part of : BLOCK RZ SAGARPUR,	1611	Other Outage	Planned Outage	26-11-2025	11:36	26-11-2025	14:43	3:07	0.001039	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1940	26-11-2025	Part of : PALAM EXTENSION PALAM,	37	Other Outage	Planned Outage	26-11-2025	10:49	26-11-2025	13:39	2:50	0.000944	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1941	26-11-2025	Part of : SECTOR 22 DWARKA,	11	Other Outage	Planned Outage	26-11-2025	10:20	26-11-2025	14:13	3:53	0.001294	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1942	27-11-2025	Part of : BLOCK RZ GANDHI MARKET SAGARPUR MAIN SAGARPUR	493	Other Outage	Planned Outage	27-11-2025	10:58	27-11-2025	12:40	1:42	0.000567	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1943	27-11-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR	1957	Other Outage	Planned Outage	27-11-2025	12:29	27-11-2025	16:11	3:42	0.001233	DB REVAMPING,HT BUSHING ROD REPLACEMENT
1944	27-11-2025	Part of : BLOCK B SECTOR 8 DWARKA,BLOCK F & J RAJ NAGAR EXTENSION	1329	Other Outage	Planned Outage	27-11-2025	10:39	27-11-2025	14:29	3:50	0.001278	GUARD WIRE LACS INSTALLTION PER SPAN
1945	27-11-2025	Part of : BLOCK B SECTOR 8 DWARKA,BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR	958	Other Outage	Planned Outage	27-11-2025	10:40	27-11-2025	14:28	3:48	0.001267	GUARD WIRE LACS INSTALLTION PER SPAN
1946	27-11-2025	Part of : BLOCK I RAGHU ENCLAVE DABRI EXTENSION EAST DABRI	613	Other Outage	Planned Outage	27-11-2025	12:32	27-11-2025	15:47	3:15	0.001083	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1947	27-11-2025	Part of : BLOCK A MAHAVIR ENCLAVE PART 1	1165	Other Outage	Planned Outage	27-11-2025	11:07	27-11-2025	14:01	2:54	0.000967	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER
1948	28-11-2025	Part of : SECTOR 9 DWARKA	105	Other Outage	Planned Outage	28-11-2025	13:34	28-11-2025	15:31	1:57	0.000325	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1949	28-11-2025	Part of : SEC-7 PLOT-15 SENT COLUMBUS (HT CONSUMER)	1	Other Outage	Planned Outage	28-11-2025	11:12	28-11-2025	13:08	1:56	0.000644	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY,REPLACMET OF FAULTY END BOX
1950	28-11-2025	Part of : HARIJAN BASTI PALAM EXTENSION	836	Other Outage	Planned Outage	28-11-2025	11:11	28-11-2025	13:08	1:57	0.000650	LT CIRCUIT MAINTENANCE
1951	28-11-2025	Part of : A,B & D-BLOCK SECTOR 8 DWARKA	1153	Other Outage	Planned Outage	28-11-2025	11:04	28-11-2025	14:53	3:49	0.001272	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1952	28-11-2025	Part of : B-BLOCK SECTOR 8 DWARKA	193	Other Outage	Planned Outage	28-11-2025	11:14	28-11-2025	14:54	3:40	0.001222	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1953	28-11-2025	Part of : D-BLOCK RAJ NAGAR-1	869	Other Outage	Planned Outage	28-11-2025	10:55	28-11-2025	14:49	3:54	0.001300	LT CIRCUIT MAINTENANCE
1954	28-11-2025	Part of : PALAM COLONY SADH NAGAR-1	519	Other Outage	Planned Outage	28-11-2025	11:12	28-11-2025	13:48	2:36	0.000867	LT CIRCUIT MAINTENANCE
1955	28-11-2025	Part of : J-BLOCK SAGARPUR WEST	426	Other Outage	Planned Outage	28-11-2025	11:25	28-11-2025	14:48	3:23	0.001128	LT CIRCUIT MAINTENANCE
1956	28-11-2025	Part of : R-BLOCK RAGHU NAGAR DABRI	693	Other Outage	Planned Outage	28-11-2025	11:03	28-11-2025	13:46	2:43	0.000906	LT CIRCUIT MAINTENANCE
1957	28-11-2025	Part of : SADH NAGAR -2 PALAM	534	Other Outage	Planned Outage	28-11-2025	10:34	28-11-2025	13:10	2:36	0.000867	LT CIRCUIT MAINTENANCE
1958	29-11-2025	Part of : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE	483	Other Outage	Planned Outage	29-11-2025	12:37	29-11-2025	14:33	1:56	0.000644	LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1959	29-11-2025	Part of : DURGA PARK COLONY DASRATHPURI	212	Other Outage	Planned Outage	29-11-2025	11:02	29-11-2025	12:52	1:50	0.000611	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1960	29-11-2025	Part of : MAHAVIR ENCLAVE PART 2	1064	Other Outage	Planned Outage	29-11-2025	10:43	29-11-2025	12:59	2:16	0.000756	DB REVAMPING,INSULATOR REPLACEMENT
1961	29-11-2025	Part of : BLOCK A RAJ NAGAR 1	966	Other Outage	Planned Outage	29-11-2025	10:59	29-11-2025	14:48	3:49	0.001272	LT AB SAGGING PER SPAN
1962	29-11-2025	Part of : SECTOR 1 DWARKA	731	Other Outage	Planned Outage	29-11-2025	11:26	29-11-2025	14:06	2:40	0.000889	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1963	29-11-2025	Part of : PALAM VILLAGE	601	Other Outage	Planned Outage	29-11-2025	10:58	29-11-2025	13:48	2:50	0.000944	LT AB SAGGING PER SPAN
1964	29-11-2025	Part of : BLOCK B RAJ NAGAR 2	750	Other Outage	Planned Outage	29-11-2025	11:26	29-11-2025	14:49	3:23	0.001128	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1965	30-11-2025	Part of : POCKET 4 SECTOR 1 DWARKA	395	Other Outage	Unplanned Outage	30-11-2025	02:37	30-11-2025	03:11	0:34	0.000170	CABLE FAULT
1966	01-11-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	824	Other Outage	Planned Outage	01-11-2025	13:11	01-11-2025	16:01	2:50	0.000472	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1967	01-11-2025	Part of : VIKASHPURI EXTENSION TILAK NAGAR	286	Other Outage	Planned Outage	01-11-2025	13:13	01-11-2025	16:06	2:53	0.000481	REPLACEMET OF HT BUSHING ROD
1968	02-11-2025	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN,	929	Other Outage	Planned Outage	02-11-2025	11:42	02-11-2025	14:53	3:11	0.000796	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1969	02-11-2025	Part of : BLOCK S KHAYALA VISHNU GARDEN,	1840	Other Outage	Planned Outage	02-11-2025	11:23	02-11-2025	14:26	3:03	0.000763	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1970	03-11-2025	PART OF : BLOCK C VISHAL ENCLAVE TAGORE GARDEN EXTENSION	515	Other Outage	Planned Outage	03-11-2025	12:31	03-11-2025	14:53	2:22	0.000394	FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1971	03-11-2025	PART OF : BLOCK WZ KRISHNA NAGAR CHAUKHANDI VISHNU GARDEN	1834	Other Outage	Planned Outage	03-11-2025	10:43	03-11-2025	13:41	2:58	0.000494	REPLACEMET OF HT BUSHING ROD
1972	03-11-2025	PART OF : CHAUKHANDI VISHNU GARDEN	1806	Other Outage	Planned Outage	03-11-2025	11:12	03-11-2025	13:41	2:29	0.000414	REPLACEMET OF HT BUSHING ROD
1973	03-11-2025	PART OF : BLOCK N JJ COLONY TAGORE GARDEN TAGORE GARDEN EXTENSION	1313	Other Outage	Planned Outage	03-11-2025	10:34	03-11-2025	13:14	2:40	0.000444	REPLACEMENT OF LT BUSHING ROD
1974	04-11-2025	Part of : BLOCK 1,16,17 & 24 TILAK NAGAR,B-BLOCK GANESH NAGAR	1665	Other Outage	Unplanned Outage	04-11-2025	09:59	04-11-2025	10:50	0:51	0.000510	BIRDAGE
1975	04-11-2025	Part of : B-BLOCK PRITHVI PARK TILAK NAGAR	1090	Other Outage	Planned Outage	04-11-2025	11:26	04-11-2025	13:40	2:14	0.000372	REPLACEMENT OF HT BUSHING ROD
1976	04-11-2025	Part of : EC-BLOCK VISHAL ENCLAVE TAGORE GARDEN EXTENSION	313	Other Outage	Planned Outage	04-11-2025	10:43	04-11-2025	13:40	2:57	0.000492	REPLACEMENT OF HT BUSHING ROD
1977	06-11-2025	Part of : RAVI NAGAR VISHNU GARDEN,BLOCK WZ KHAYALA VISHNU GARDEN	1999	Other Outage	Unplanned Outage	06-11-2025	19:17	06-11-2025	20:05	0:48	0.000653	CABLE FAULT
1978	06-11-2025	Part of : BLOCK G TILAK NAGAR,	1177	Other Outage	Planned Outage	06-11-2025	10:51	06-11-2025	14:26	3:35	0.000896	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD
1979	06-11-2025	Part of : BLOCK C VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	436	Other Outage	Planned Outage	06-11-2025	11:01	06-11-2025	14:26	3:25	0.000569	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER
1980	07-11-2025	Part of : CHAUKHANDI VISHNU GARDEN	1331	Other Outage	Planned Outage	07-11-2025	12:26	07-11-2025	15:52	3:26	0.000572	REPLACEMET OF HT BUSHING ROD
1981	07-11-2025	Part of : BLOCK S KHAYALA VISHNU GARDEN,BLOCK F TAGORE GARDEN TAGORE GARDEN EXTENSION,POCKET A RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	3437	Other Outage	Planned Outage	07-11-2025	11:08	07-11-2025	14:46	3:38	0.000908	REPLACEMET OF HT BUSHING ROD
1982	07-11-2025	Part of : BLOCK 6 TILAK NAGAR	522	Other Outage	Planned Outage	07-11-2025	10:37	07-11-2025	13:51	3:14	0.000539	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
1983	07-11-2025	Part of : KRISHNA PARK EXTENSION TILAK NAGAR	627	Other Outage	Planned Outage	07-11-2025	10:35	07-11-2025	13:52	3:17	0.000547	REPLACEMET OF HT BUSHING ROD
1984	08-11-2025	Part of : NEW CHAUKHANDI VISHNU GARDEN,SANT NAGAR	2201	Other Outage	Unplanned Outage	08-11-2025	12:56	08-11-2025	13:45	0:49	0.000286	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1985	08-11-2025	Part of : WZ-BLOCK MBS NAGAR,WZ-BLOCK KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	5025	Other Outage	Unplanned Outage	08-11-2025	07:05	08-11-2025	08:01	0:56	0.000296	HT POLE BROKEN BY UNKNOWN VEHICLE
1986	08-11-2025	Part of : POCKET A RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	2149	Other Outage	Planned Outage	08-11-2025	11:02	08-11-2025	14:10	3:08	0.000522	REPLACEMENT OF HT BUSHING ROD
1987	10-11-2025	Part of : BLOCK D VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	468	Other Outage	Planned Outage	10-11-2025	10:46	10-11-2025	13:33	2:47	0.000464	PREVENTIVE MAINTENANCE
1988	10-11-2025	Part of : KRISHNA PARK EXTENSION TILAK NAGAR,	1413	Other Outage	Planned Outage	10-11-2025	11:04	10-11-2025	13:46	2:42	0.000900	PREVENTIVE MAINTENANCE
1989	12-11-2025	Part of : BLOCK FA TAGORE GARDEN	644	Other Outage	Planned Outage	12-11-2025	10:33	12-11-2025	12:27	1:54	0.000317	REPLACEMENT OF HT BUSHING ROD
1990	12-11-2025	Part of : NEW CHAUKHANDI VISHNU GARDEN	139	Other Outage	Planned Outage	12-11-2025	11:37	12-11-2025	14:47	3:10	0.000528	REPLACEMENT OF HT BUSHING ROD
1991	12-11-2025	Part of : BLOCK C MAHAVIR NAGAR NEW TILAK NAGAR	1396	Other Outage	Planned Outage	12-11-2025	11:09	12-11-2025	14:38	3:29	0.000871	REPLACEMENT OF HT BUSHING ROD
1992	13-11-2025	Part of : BLOCK 1,16 & 24 TILAK NAGAR,BLOCK B GANESH NAGAR TILAK NAGAR,BLOCK 17 CENTRAL MARKET TILAK NAGAR, MATA GUJRI HOSPITAL TILAK NAGAR (HTC)	1668	Other Outage	Unplanned Outage	13-11-2025	23:44	14-11-2025	00:11	0:27	0.000210	CABLE DAMAGED BY OUTSIDE AGENCY (PWD)
1993	13-11-2025	Part of : RAVI NAGAR VISHNU GARDEN, CHAND NAGAR, AB-BLOCK KHYALA, KHYALA JJ COLONY	5176	Other Outage	Unplanned Outage	13-11-2025	12:23	13-11-2025	13:15	0:52	0.000549	CABLE FAULT
1994	13-11-2025	Part of : BLOCK F TAGORE GARDEN EXTENSION	898	Other Outage	Planned Outage	13-11-2025	10:59	13-11-2025	13:50	2:51	0.000475	REPLACEMET OF HT BUSHING ROD
1995	13-11-2025	Part of : BLOCK WZ KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	127	Other Outage	Planned Outage	13-11-2025	11:08	13-11-2025	13:24	2:16	0.000567	REPLACEMET OF HT BUSHING ROD
1996	14-11-2025	Part of : H BLOCK JANTA COLONY TAGORE GARDEN EXTENSION,BLOCK FD JANTA COLONY TAGORE GARDEN EXTENSION	2997	Other Outage	Unplanned Outage	14-11-2025	00:47	14-11-2025	01:30	0:43	0.000060	CABLE FAULT
1997	14-11-2025	Part of : SANT NAGAR CHAUKHANDI VISHNU GARDEN	543	Other Outage	Planned Outage	14-11-2025	11:32	14-11-2025	14:30	2:58	0.000494	PREVENTIVE MAINTENANCE
1998	14-11-2025	Part of : BLOCK WZ KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	89	Other Outage	Planned Outage	14-11-2025	10:55	14-11-2025	14:13	3:18	0.000550	REPLACEMET OF HT BUSHING ROD
1999	15-11-2025	Part of : BLOCK T KHAYALA VISHNU GARDEN	2653	Other Outage	Planned Outage	15-11-2025	12:30	15-11-2025	16:04	3:34	0.001189	REPLACEMENT OF HT BUSHING ROD
2000	15-11-2025	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN	304	Other Outage	Planned Outage	15-11-2025	12:21	15-11-2025	16:05	3:44	0.000622	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS,REPLACEMENT OF FAULTY END BOX
2001	15-11-2025	Part of : BLOCK WZ KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	425	Other Outage	Planned Outage	15-11-2025	11:21	15-11-2025	13:32	2:11	0.000364	REPLACEMENT OF HT BUSHING ROD
2002	15-11-2025	Part of : BLOCK D KHAYALA VISHNU GARDEN	545	Other Outage	Planned Outage	15-11-2025	12:12	15-11-2025	15:08	2:56	0.000489	RELAY REPLACEMENT/VPI/FPI,REPLACEMENT OF LUGS/NUT BOLTS/BOOTS,REPLACEMENT OF FAULTY END BOX
2003	15-11-2025	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN	909	Other Outage	Planned Outage	15-11-2025	11:47	15-11-2025	15:06	3:19	0.000000	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN
2004	17-11-2025	Part of : BLOCK WZ KESHAVPUR VEGETABLE MARKET CHAUKHANDI VISHNU GARDEN	4	Other Outage	Planned Outage	17-11-2025	10:53	17-11-2025	14:13	3:20	0.000556	REPLACEMENT OF HT BUSHING ROD
2005	17-11-2025	Part of : BLOCK 12,13,16 & 18 TILAK NAGAR,VIKASHPURI EXTENSION TILAK NAGAR	4861	Other Outage	Planned Outage	17-11-2025	10:54	17-11-2025	13:53	2:59	0.000497	GUARD WIRES SAGGING PER SPAN,TIGHTENING OF HARDWARE FITTINGS
2006	17-11-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	25	Other Outage	Planned Outage	17-11-2025	13:07	17-11-2025	16:17	3:10	0.000000	1C 300 SQ MM CABLE REPLACEMENT PER PHASE,1C 630 SQ MM CABLE REPLACEMENT PER PHASE,300 SQ MM LUGS REPLACEMENT PER LUG,630 SQ MM LUGS REPLACEMENT PER LUG,MISSING BUSBAR INSTALLATION PER ACB,PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER LT ACB,TAPPING/SPRAY OF ALL BUS BARS IN LT ACB PER ACB
2007	18-11-2025	Part of : BLOCK 24 TILAK NAGAR,	472	Other Outage	Planned Outage	18-11-2025	10:24	18-11-2025	13:42	3:18	0.000550	REPLACEMET OF HT BUSHING ROD
2008	18-11-2025	Part of : BLOCK D JANTA COLONY TAGORE GARDEN EXTENSION,	1174	Other Outage	Planned Outage	18-11-2025	10:59	18-11-2025	14:27	3:28	0.000578	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD
2009	19-11-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	594	Other Outage	Planned Outage	19-11-2025	11:28	19-11-2025	15:04	3:36	0.000600	REPLACEMENT OF HT BUSHING ROD
2010	19-11-2025	Part of : BLOCK BA TAGORE GARDEN EXTENSION,	624	Other Outage	Planned Outage	19-11-2025	11:18	19-11-2025	14:01	2:43	0.000453	REPLACEMENT OF HT BUSHING ROD
2011	19-11-2025	Part of : MANOHAR NAGAR VIKASHPURI EXTENSION TILAK NAGAR	688	Other Outage	Planned Outage	19-11-2025	10:22	19-11-2025	14:02	3:40	0.000611	REPLACEMENT OF HT BUSHING ROD
2012	20-11-2025	Part of : E & F-BLOCK OLD MAHAVIR NAGAR TILAK NAGAR	1137	Other Outage	Planned Outage	20-11-2025	10:56	20-11-2025	13:58	3:02	0.000758	REPLACEMENT OF HT BUSHING ROD
2013	20-11-2025	Part of : AE-BLOCK TAGORE GARDEN EXTENSION	275	Other Outage	Planned Outage	20-11-2025	10:56	20-11-2025	13:54	2:58	0.000494	REPLACEMENT OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2014	21-11-2025	Part of : BLOCK 21 TILAK NAGAR	1354	Other Outage	Planned Outage	21-11-2025	10:56	21-11-2025	13:51	2:55	0.000486	REPLACEMET OF HT BUSHING ROD
2015	21-11-2025	Part of : BLOCK EC VISHAL ENCLAVE TAGORE GARDEN EXTENSION	545	Other Outage	Planned Outage	21-11-2025	10:54	21-11-2025	13:56	3:02	0.000758	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD
2016	22-11-2025	Part of : BLOCK B 2 RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	3899	Other Outage	Unplanned Outage	22-11-2025	09:01	22-11-2025	09:58	0:57	0.000586	CABLE FAULT
2017	22-11-2025	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN	989	Other Outage	Unplanned Outage	22-11-2025	07:49	22-11-2025	08:44	0:55	0.000978	CABLE FAULT
2018	22-11-2025	Part of : BLOCK H JANTA COLONY TAGORE GARDEN EXTENSION,	984	Other Outage	Planned Outage	22-11-2025	12:06	22-11-2025	14:07	2:01	0.000336	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD
2019	23-11-2025	Part of : BLOCK EC VISHAL ENCLAVE TAGORE GARDEN EXTENSION,BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION	1872	Other Outage	Unplanned Outage	23-11-2025	11:07	23-11-2025	12:11	1:04	0.000462	HT SYSTEM FAULT
2020	24-11-2025	Part of : I-BLOCK KHAYALA VILLAGE VISHNU GARDEN	441	Other Outage	Planned Outage	24-11-2025	10:45	24-11-2025	13:36	2:51	0.000713	AL LUGS PUCHING ON LT XLPE TO HT AB PER FEEDER
2021	24-11-2025	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	726	Other Outage	Planned Outage	24-11-2025	11:35	24-11-2025	14:14	2:39	0.000442	REPLACEMENT OF HT BUSHING ROD
2022	24-11-2025	Part of : 5 A-BLOCK TILAK NAGAR	229	Other Outage	Planned Outage	24-11-2025	10:30	24-11-2025	13:30	3:00	0.000500	REPLACEMENT OF HT BUSHING ROD
2023	24-11-2025	Part of : N-BLOCK JJ COLONY TAGORE GARDEN EXTENSION	905	Other Outage	Planned Outage	24-11-2025	10:31	24-11-2025	13:26	2:55	0.000486	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
2024	26-11-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN,	2223	Other Outage	Unplanned Outage	26-11-2025	12:26	26-11-2025	14:25	1:59	0.000331	REPAIRING OF HT O/H CIRCUIT
2025	26-11-2025	Part of : BLOCK RG RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	695	Other Outage	Planned Outage	26-11-2025	11:18	26-11-2025	13:59	2:41	0.000447	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD
2026	26-11-2025	Part of : BLOCK 14 TILAK NAGAR,	853	Other Outage	Planned Outage	26-11-2025	10:38	26-11-2025	13:31	2:53	0.000721	REPLACEMET OF HT BUSHING ROD
2027	27-11-2025	Part of : BLOCK M, N & J RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	4772	Other Outage	Unplanned Outage	27-11-2025	12:56	27-11-2025	14:01	1:05	0.001174	CABLE FAULT
2028	27-11-2025	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN	20	Other Outage	Planned Outage	27-11-2025	12:07	27-11-2025	15:03	2:56	0.000489	CONDUCTOR REPLACEMENT PER SPAN
2029	27-11-2025	Part of : BLOCK 9 NURSERY TILAK NAGAR	448	Other Outage	Planned Outage	27-11-2025	10:56	27-11-2025	13:57	3:01	0.000503	REPLACEMENT OF HT BUSHING ROD
2030	27-11-2025	Part of : BLOCK D VISHAL ENCLAVE TAGORE GARDEN EXTENSION	244	Other Outage	Planned Outage	27-11-2025	11:14	27-11-2025	13:56	2:42	0.000675	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD
2031	28-11-2025	Part of : E & H-BLOCK KHAYALA VISHNU GARDEN	2932	Other Outage	Unplanned Outage	28-11-2025	01:19	28-11-2025	02:09	0:50	0.001264	CABLE FAULT
2032	28-11-2025	Part of : EA-BLOCK TAGORE GARDEN EXTENSION.	651	Other Outage	Planned Outage	28-11-2025	10:44	28-11-2025	13:46	3:02	0.000758	REPLACEMET OF HT BUSHING ROD
2033	29-11-2025	Part of : BLOCK M RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	1309	Other Outage	Planned Outage	29-11-2025	11:04	29-11-2025	13:10	2:06	0.000350	REPLACEMET OF HT BUSHING ROD
2034	01-11-2025	Part of : UTTAM VIHAR BINDAPUR	1424	Other Outage	Planned Outage	01-11-2025	13:58	01-11-2025	15:41	1:43	0.000000	DT REPLACEMENT
2035	01-11-2025	Part of : PARJAPAT COLONY BINDAPUR,NAND RAM PARK NEW UTTAM NAGAR,BINDAPUR	679	Other Outage	Planned Outage	01-11-2025	14:00	01-11-2025	16:12	2:12	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2036	01-11-2025	Part of : BHAGAT ENCLAVE BINDAPUR	997	Other Outage	Planned Outage	01-11-2025	14:03	01-11-2025	16:15	2:12	0.000000	DT REPLACEMENT
2037	03-11-2025	PART OF : OLD JANKI PURI BINDAPUR	637	Other Outage	Planned Outage	03-11-2025	12:27	03-11-2025	13:51	1:24	0.000000	DT REPLACEMENT
2038	03-11-2025	PART OF : BLOCK C MAHINDRA PARK BINDAPUR	804	Other Outage	Planned Outage	03-11-2025	11:21	03-11-2025	13:45	2:24	0.000000	DT REPLACEMENT
2039	03-11-2025	PART OF : BINDAPUR	435	Other Outage	Planned Outage	03-11-2025	11:56	03-11-2025	14:32	2:36	0.000000	DT REPLACEMENT
2040	03-11-2025	PART OF : SANTOSH PARK UTTAM NAGAR	1570	Other Outage	Planned Outage	03-11-2025	11:19	03-11-2025	13:44	2:25	0.000000	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
2041	04-11-2025	Part of : F-BLOCK JEEVAN PARK BINDAPUR	504	Other Outage	Planned Outage	04-11-2025	11:38	04-11-2025	13:31	1:53	0.000000	DT REPLACEMENT
2042	04-11-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	1282	Other Outage	Planned Outage	04-11-2025	11:13	04-11-2025	13:32	2:19	0.000000	DT REPLACEMENT
2043	06-11-2025	Part of : POCKET 4 CHANAKYA PLACE I SITAPURI,BLOCK C CHANAKYA PLACE I SITAPURI,MAHINDRA PARK BINDAPUR,BLOCK A 3 HARIJAN COLONY SITAPURI PART 1 SITAPURI	5302	Other Outage	Unplanned Outage	06-11-2025	00:29	06-11-2025	00:53	0:24	0.000113	BIRDAGE
2044	06-11-2025	Part of : BLOCK A SITAPURI PART 2 SITAPURI,	1803	Other Outage	Planned Outage	06-11-2025	11:43	06-11-2025	13:35	1:52	0.000000	DT REPLACEMENT
2045	06-11-2025	Part of : BLOCK E UTTAM VIHAR BINDAPUR,	768	Other Outage	Planned Outage	06-11-2025	11:06	06-11-2025	13:39	2:33	0.000000	DT REPLACEMENT
2046	06-11-2025	Part of : BLOCK E PARAM PURI UTTAM NAGAR,	330	Other Outage	Planned Outage	06-11-2025	11:05	06-11-2025	13:34	2:29	0.000000	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
2047	07-11-2025	Part of : OLD JANKI PURI BINDAPUR	637	Other Outage	Planned Outage	07-11-2025	11:33	07-11-2025	13:28	1:55	0.000000	DT REPLACEMENT
2048	07-11-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	801	Other Outage	Planned Outage	07-11-2025	11:07	07-11-2025	13:27	2:20	0.000000	DT REPLACEMENT
2049	07-11-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	995	Other Outage	Planned Outage	07-11-2025	11:03	07-11-2025	13:29	2:26	0.000000	DT REPLACEMENT
2050	07-11-2025	Part of : INDRA PARK RAM DATT ENCLAVE UTTAM NAGAR	1258	Other Outage	Planned Outage	07-11-2025	11:22	07-11-2025	13:31	2:09	0.000000	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
2051	08-11-2025	Part of : A & H-BLOCK SITAPURI PART 2,ANUP NAGAR ADARSH NAGAR BINDAPUR	684	Other Outage	Unplanned Outage	08-11-2025	12:59	08-11-2025	14:16	1:17	0.000000	REPLACEMENT OF HVDS TRANSFORMER
2052	08-11-2025	Part of : PARJAPAT COLONY BINDAPUR	679	Other Outage	Planned Outage	08-11-2025	11:08	08-11-2025	13:34	2:26	0.000000	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2053	10-11-2025	Part of : BHAGAT ENCLAVE BINDAPUR,	997	Other Outage	Planned Outage	10-11-2025	15:44	10-11-2025	16:33	0:49	0.000000	LT CIRCUIT NETWORK UPGRADATION
2054	10-11-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR,	2380	Other Outage	Planned Outage	10-11-2025	10:58	10-11-2025	13:45	2:47	0.000000	PREVENTIVE MAINTENANCE
2055	10-11-2025	Part of : NEW UTTAM NAGAR UTTAM NAGAR,	1445	Other Outage	Planned Outage	10-11-2025	11:22	10-11-2025	13:44	2:22	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
2056	11-11-2025	Part of : MAHINDRA PARK BINDAPUR,POCKET 4 CHANAKYA PLACE I SITAPURI,BLOCK A 3 HARJAN COLONY SITAPURI PART 1,BLOCK C CHANAKYA PLACE I SITAPURI	5304	Other Outage	Unplanned Outage	11-11-2025	05:14	11-11-2025	06:04	0:50	0.000181	BIRDAGE
2057	11-11-2025	Part of : UTTAM VIHAR BINDAPUR	1426	Other Outage	Planned Outage	11-11-2025	12:22	11-11-2025	13:47	1:25	0.000000	3PH DB REVAMPING
2058	11-11-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	156	Other Outage	Planned Outage	11-11-2025	11:04	11-11-2025	13:48	2:44	0.000000	DT REPLACEMENT
2059	11-11-2025	Part of : BLOCK B UTTAM NAGAR	842	Other Outage	Planned Outage	11-11-2025	11:47	11-11-2025	14:52	3:05	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2060	11-11-2025	Part of : BLOCK C CHANAKYA PLACE I SITAPURI	1565	Other Outage	Planned Outage	11-11-2025	11:00	11-11-2025	13:47	2:47	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2061	12-11-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	268	Other Outage	Planned Outage	12-11-2025	11:49	12-11-2025	13:31	1:42	0.000000	LT CIRCUIT MAINTENANCE
2062	12-11-2025	Part of : BLOCK K PARAM PURI UTTAM NAGAR	931	Other Outage	Planned Outage	12-11-2025	11:13	12-11-2025	13:33	2:20	0.000000	LT CIRCUIT MAINTENANCE
2063	13-11-2025	Part of : KIRAN GARDEN, GULABHI BAGH, OM VIHAR UTTAM NAGAR, MAHINDRU HOSPITAL (HTC)	2489	Other Outage	Unplanned Outage	13-11-2025	12:53	13-11-2025	13:43	0:50	0.000833	CABLE FAULT
2064	13-11-2025	Part of : BHAGWATI VIHAR BINDAPUR	2430	Other Outage	Planned Outage	13-11-2025	11:32	13-11-2025	13:31	1:59	0.000000	DT REPLACEMENT
2065	13-11-2025	Part of : BLOCK D JJ COLONY UTTAM NAGAR	1308	Other Outage	Planned Outage	13-11-2025	12:33	13-11-2025	14:35	2:02	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2066	13-11-2025	Part of : OLD JANKI PURI BINDAPUR	646	Other Outage	Planned Outage	13-11-2025	11:46	13-11-2025	13:49	2:03	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2067	13-11-2025	Part of : BLOCK H SITAPURI PART 2	674	Other Outage	Planned Outage	13-11-2025	11:11	13-11-2025	13:32	2:21	0.000000	DT REPLACEMENT
2068	14-11-2025	Part of : F BLOCK UTTAM VIHAR BINDAPUR	2833	Other Outage	Planned Outage	14-11-2025	11:49	14-11-2025	13:42	1:53	0.000000	DT REPLACEMENT
2069	14-11-2025	Part of : A BLOCK UTTAM VIHAR BINDAPUR	754	Other Outage	Planned Outage	14-11-2025	11:48	14-11-2025	13:40	1:52	0.000000	LT CIRCUIT NETWORK UPGRADATION
2070	14-11-2025	Part of : D BLOCK JJ COLONY UTTAM NAGAR	176	Other Outage	Planned Outage	14-11-2025	10:45	14-11-2025	13:43	2:58	0.000000	MAINTENANCE
2071	14-11-2025	Part of : H BLOCK SITAPURI PART 2 SITAPURI	997	Other Outage	Planned Outage	14-11-2025	11:02	14-11-2025	13:41	2:39	0.000000	LT CIRCUIT DT REPLACEMENT
2072	15-11-2025	Part of : BLOCK A RAM NAGAR OM VIHAR UTTAM NAGAR	49	Other Outage	Planned Outage	15-11-2025	11:59	15-11-2025	15:00	3:01	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2073	17-11-2025	Part of : BLOCK E PARAM PURI UTTAM NAGAR	4017	Other Outage	Unplanned Outage	17-11-2025	12:42	17-11-2025	15:16	2:34	0.000000	REPAIR OF RMU
2074	17-11-2025	Part of : OLD JANKI PURI BINDAPUR	786	Other Outage	Planned Outage	17-11-2025	11:53	17-11-2025	13:44	1:51	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
2075	17-11-2025	Part of : OLD JANKI PURI BINDAPUR	555	Other Outage	Planned Outage	17-11-2025	11:12	17-11-2025	13:42	2:30	0.000000	REPLACEMENT OF LT BUSHING ROD
2076	17-11-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR	1581	Other Outage	Planned Outage	17-11-2025	11:10	17-11-2025	13:43	2:33	0.000000	DT REPLACEMENT
2077	17-11-2025	Part of : INDRA PARK RAM DATT ENCLAVE UTTAM NAGAR	699	Other Outage	Planned Outage	17-11-2025	11:11	17-11-2025	13:44	2:33	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2078	18-11-2025	Part of : BLOCK E UTTAM VIHAR BINDAPUR,	782	Other Outage	Planned Outage	18-11-2025	15:36	18-11-2025	16:47	1:11	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2079	18-11-2025	Part of : POCKET 4 CHANAKYA PLACE I SITAPURI,	336	Other Outage	Planned Outage	18-11-2025	12:09	18-11-2025	13:29	1:20	0.000000	REPLACEMENT OF LT BUSHING ROD
2080	18-11-2025	Part of : BLOCK C MAHINDRA PARK BINDAPUR,	804	Other Outage	Planned Outage	18-11-2025	14:26	18-11-2025	16:47	2:21	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
2081	18-11-2025	Part of : PARJAPAT COLONY BINDAPUR,	1307	Other Outage	Planned Outage	18-11-2025	11:21	18-11-2025	13:30	2:09	0.000000	DT REPLACEMENT
2082	18-11-2025	Part of : BHAGAT ENCLAVE BINDAPUR,	1004	Other Outage	Planned Outage	18-11-2025	11:22	18-11-2025	13:28	2:06	0.000000	DT REPLACEMENT
2083	19-11-2025	Part of : OLD JANKI PURI BINDAPUR	637	Other Outage	Planned Outage	19-11-2025	12:46	19-11-2025	13:38	0:52	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2084	19-11-2025	Part of : OLD JANKI PURI BINDAPUR	637	Other Outage	Planned Outage	19-11-2025	14:01	19-11-2025	15:52	1:51	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
2085	19-11-2025	Part of : BLOCK O UTTAM NAGAR	429	Other Outage	Planned Outage	19-11-2025	11:17	19-11-2025	13:41	2:24	0.000000	REPLACEMENT OF LT BUSHING ROD
2086	20-11-2025	Part of : C-BLOCK CHANAKYA PLACE-1	348	Other Outage	Planned Outage	20-11-2025	12:45	20-11-2025	13:23	0:38	0.000000	LT CIRCUIT MAINTENANCE WORK
2087	20-11-2025	Part of : PARAM PURI UTTAM NAGAR	822	Other Outage	Planned Outage	20-11-2025	11:23	20-11-2025	13:22	1:59	0.000000	LT CIRCUIT MAINTENANCE WORK
2088	20-11-2025	Part of : E-BLOCK PARAM PURI UTTAM NAGAR	3279	Other Outage	Planned Outage	20-11-2025	11:48	20-11-2025	15:04	3:16	0.000000	GUARD WIRES SAGGING
2089	21-11-2025	Part of : BLOCK I UTTAM NAGAR	1647	Other Outage	Planned Outage	21-11-2025	11:32	21-11-2025	13:25	1:53	0.000000	REPLACEMENT OF HT BUSHING ROD
2090	21-11-2025	Part of : BHAGWATI VIHAR BINDAPUR	1811	Other Outage	Planned Outage	21-11-2025	11:06	21-11-2025	13:26	2:20	0.000000	DT REPLACEMENT
2091	21-11-2025	Part of : BLOCK A SITAPURI PART 2	261	Other Outage	Planned Outage	21-11-2025	11:05	21-11-2025	13:27	2:22	0.000000	DT REPLACEMENT
2092	22-11-2025	Part of : UTTAM VIHAR BINDAPUR,	1426	Other Outage	Planned Outage	22-11-2025	12:41	22-11-2025	13:58	1:17	0.000000	3PH DB REVAMPING
2093	22-11-2025	Part of : PARJAPAT COLONY BINDAPUR,	679	Other Outage	Planned Outage	22-11-2025	10:48	22-11-2025	14:39	3:51	0.000000	DT REPLACEMENT PER DT
2094	22-11-2025	Part of : BLOCK E PARAM PURI UTTAM NAGAR,	5	Other Outage	Planned Outage	22-11-2025	11:08	22-11-2025	13:56	2:48	0.000000	REPLACEMENT OF LT BUSHING ROD
2095	22-11-2025	Part of : BLOCK C MAHINDRA PARK BINDAPUR,	804	Other Outage	Planned Outage	22-11-2025	11:30	22-11-2025	14:04	2:34	0.000000	DT REPLACEMENT
2096	24-11-2025	Part of : F-BLOCK UTTAM VIHAR BINDAPUR	1156	Other Outage	Planned Outage	24-11-2025	14:12	24-11-2025	16:06	1:54	0.000000	LT CIRCUIT MAINTENANCE WORK
2097	24-11-2025	Part of : BHAGAT ENCLAVE BINDAPUR	1003	Other Outage	Planned Outage	24-11-2025	12:00	24-11-2025	13:42	1:42	0.000000	LT CIRCUIT MAINTENANCE WORK

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2098	24-11-2025	Part of : PARAM PURI UTTAM NAGAR	822	Other Outage	Planned Outage	24-11-2025	10:31	24-11-2025	13:47	3:16	0.000000	DT REPLACEMENT
2099	24-11-2025	Part of : F-BLOCK JEEVAN PARK BINDAPUR	1390	Other Outage	Planned Outage	24-11-2025	11:42	24-11-2025	13:46	2:04	0.000000	DT REPLACEMENT
2100	25-11-2025	Part of : ADARSH NAGAR, BINDAPUR PKT-4, B-BLOCK J.J.COLONY, OLD JANKI PURI BINDAPUR	1915	Other Outage	Unplanned Outage	25-11-2025	11:29	25-11-2025	12:34	1:05	0.001625	BIRDAGE
2101	25-11-2025	Part of : PARJAPAT COLONY BINDAPUR	1307	Other Outage	Planned Outage	25-11-2025	12:46	25-11-2025	15:19	2:33	0.000000	DT REPLACEMENT
2102	26-11-2025	Part of : BLOCK B UTTAM NAGAR,	705	Other Outage	Planned Outage	26-11-2025	11:22	26-11-2025	13:39	2:17	0.000000	REPLACEMENT OF LT BUSHING ROD
2103	26-11-2025	Part of : BLOCK C MAHINDRA PARK BINDAPUR,BLOCK D 2 MAHINDRA PARK BINDAPUR,	2426	Other Outage	Planned Outage	26-11-2025	11:23	26-11-2025	13:36	2:13	0.000000	DT REPLACEMENT
2104	27-11-2025	Part of : BHAGAT ENCLAVE BINDAPUR	1004	Other Outage	Planned Outage	27-11-2025	11:40	27-11-2025	13:34	1:54	0.000000	3PH DB REPLACEMENT
2105	27-11-2025	Part of : PARJAPAT COLONY BINDAPUR,BINDAPUR,NAND RAM PARK NEW UTTAM NAGAR UTTAM NAGAR	679	Other Outage	Planned Outage	27-11-2025	13:50	27-11-2025	16:07	2:17	0.000000	DB REVAMPING
2106	27-11-2025	Part of : BLOCK A SITAPURI PART 2 SITAPURI	1799	Other Outage	Planned Outage	27-11-2025	10:58	27-11-2025	13:33	2:35	0.000000	DT REPLACEMENT
2107	27-11-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR	557	Other Outage	Planned Outage	27-11-2025	10:57	27-11-2025	13:35	2:38	0.000000	DT REPLACEMENT
2108	28-11-2025	Part of : OLD JANKI PURI BINDAPUR	1336	Other Outage	Planned Outage	28-11-2025	15:08	28-11-2025	16:20	1:12	0.000000	DT REPLACEMENT
2109	28-11-2025	Part of : A & H-BLOCK SITAPURI PART 2,ANUP NAGAR ADARSH NAGAR BINDAPUR	679	Other Outage	Planned Outage	28-11-2025	11:57	28-11-2025	13:45	1:48	0.000000	DT REPLACEMENT
2110	28-11-2025	Part of : A-BLOCK UTTAM VIHAR BINDAPUR	23	Other Outage	Planned Outage	28-11-2025	11:48	28-11-2025	14:37	2:49	0.000000	DT REPLACEMENT
2111	28-11-2025	Part of : UTTAM NAGAR EAST	1412	Other Outage	Planned Outage	28-11-2025	11:56	28-11-2025	14:37	2:41	0.000000	LT CIRCUIT MAINTENANCE
2112	29-11-2025	Part of : INDIRA PARK BINDAPUR	965	Other Outage	Planned Outage	29-11-2025	11:22	29-11-2025	13:56	2:34	0.000000	DT REPLACEMENT
2113	03-11-2025	PART OF : SAINIK ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,SURKAKHA ENCLAVE AND M-BLOCK COMMONDER CHOWK,PRESS ENCLAVE	1522	Other Outage	Planned Outage	03-11-2025	11:00	03-11-2025	13:47	2:47	0.000000	DT REPLACEMENT
2114	03-11-2025	PART OF : A,B&C-BLOCK MAHARANI ENCLAVE	1965	Other Outage	Planned Outage	03-11-2025	10:58	03-11-2025	13:43	2:45	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
2115	03-11-2025	PART OF : DDA LIG FLATS HASTSAL	565	Other Outage	Planned Outage	03-11-2025	11:01	03-11-2025	13:48	2:47	0.000000	DT REPLACEMENT
2116	03-11-2025	PART OF : BLOCK A SHANKER GARDEN VIKAS PURI	273	Other Outage	Planned Outage	03-11-2025	10:19	03-11-2025	12:49	2:30	0.000000	DT REPLACEMENT
2117	04-11-2025	Part of : C&D BLOCK VIKAS NAGAR,SHIV VIHAR HASTSAL,VIKAS NAGAR EXTN.,SURKAKHA ENCLAVE & M- BLOCK COMMONDER CHOWK,DEEPAK VIHAR,PRESS ENCLAVE,VIKAS ENCLAVE,B-BLOCK VIKAS NAGAR EXTN.	3108	Other Outage	Unplanned Outage	04-11-2025	02:53	04-11-2025	03:46	0:53	0.000427	HVDS FAULT
2118	04-11-2025	Part of : LIG MIG FLATS POCKET B HASTSAL	461	Other Outage	Planned Outage	04-11-2025	10:10	04-11-2025	12:18	2:08	0.000000	LT CIRCUIT MAINTENANCE WORK
2119	04-11-2025	Part of : A-BLOCK SHANKER GARDEN VIKAS PURI	201	Other Outage	Planned Outage	04-11-2025	10:00	04-11-2025	12:19	2:19	0.000000	LT CIRCUIT MAINTENANCE WORK
2120	05-11-2025	Part of : NEW KRISHNA PARK, VIKASPURI	701	Other Outage	Unplanned Outage	05-11-2025	23:59	06-11-2025	00:49	0:50	0.000528	CABLE FAULT
2121	06-11-2025	Part of : C-BLOCK SHIV VIHAR JJ COLONY,	666	Other Outage	Planned Outage	06-11-2025	11:32	06-11-2025	13:32	2:00	0.000000	DT REPLACEMENT
2122	06-11-2025	Part of : SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE,	3061	Other Outage	Planned Outage	06-11-2025	11:33	06-11-2025	13:33	2:00	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2123	06-11-2025	Part of : LIG MIG FLATS POCKET C HASTSAL,	573	Other Outage	Planned Outage	06-11-2025	10:13	06-11-2025	12:40	2:27	0.000000	DT REPLACEMENT
2124	06-11-2025	Part of : BLOCK C VIKAS PURI,	487	Other Outage	Planned Outage	06-11-2025	10:07	06-11-2025	12:41	2:34	0.000000	DT REPLACEMENT
2125	07-11-2025	Part of : BLOCK A 1 UTTAM NAGAR	793	Other Outage	Planned Outage	07-11-2025	11:02	07-11-2025	13:30	2:28	0.000000	DT REPLACEMENT
2126	07-11-2025	Part of : BLOCK B VIKAS PURI	118	Other Outage	Planned Outage	07-11-2025	10:10	07-11-2025	12:22	2:12	0.000000	DT REPLACEMENT
2127	08-11-2025	Part of : VIKAS KUNJ & VIKAS KUNJ EXTN.,SAI& SETHI ENCLAVE,VIKRANT VIHAR,PANCHSHEEL ENCLAVE	3267	Other Outage	Unplanned Outage	08-11-2025	12:50	08-11-2025	13:39	0:49	0.000898	CABLE FAULT
2128	08-11-2025	Part of : H2-BLOCK VIKAS PURI	288	Other Outage	Planned Outage	08-11-2025	11:34	08-11-2025	13:38	2:04	0.000000	LT CIRCUIT MAINTENANCE WORK
2129	10-11-2025	Part of : K-5 EXTN. AND DEEPAK VIHAR,	1636	Other Outage	Planned Outage	10-11-2025	14:28	10-11-2025	16:32	2:04	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
2130	10-11-2025	Part of : DDA LIG FLATS HASTSAL,	296	Other Outage	Planned Outage	10-11-2025	10:49	10-11-2025	13:44	2:55	0.000000	LT CIRCUIT LOAD UNBALANCING
2131	10-11-2025	Part of : POCKET DG 2 VIKAS PURI,	308	Other Outage	Planned Outage	10-11-2025	10:06	10-11-2025	12:36	2:30	0.000000	LT CIRCUIT PREVENTIVE MAINTENANCE
2132	11-11-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL,BLOCK A 2 UTTAM NAGAR,PHASE 2 OM VIHAR HASTSAL,HOSTAL VIHAR OM VIHAR HASTSAL	3144	Other Outage	Unplanned Outage	11-11-2025	11:31	11-11-2025	12:12	0:41	0.000399	HT SYSTEM FAULT
2133	11-11-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL	881	Other Outage	Unplanned Outage	11-11-2025	08:32	11-11-2025	09:13	0:41	0.000444	HT SYSTEM FAULT
2134	11-11-2025	Part of : VIKAS NAGAR PHASE-I,II,III,SHIV VIHAR HASTSAL,BHIM ENCLAVE,HASTSAL EXTN. AND VIKAS NAGAR PHASE-II	3397	Other Outage	Unplanned Outage	11-11-2025	08:32	11-11-2025	09:13	0:41	0.000592	HT SYSTEM FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
2135	11-11-2025	Part of : MANOHAR NAGAR VIKAS PURI,BLOCK JG 1, JG 2 & GG2 VIKAS PURI,KESHOPUR VIKAS PURI,KESHOPUR VILLAGE VIKAS PURI,GUJRANWALA VIKAS PURI	3495	Other Outage	Unplanned Outage	11-11-2025	13:20	11-11-2025	13:21	0:01	0.000000	REPAIRING OF RMU
2136	11-11-2025	Part of : VIKAS NAGAR EXTN	110	Other Outage	Planned Outage	11-11-2025	12:11	11-11-2025	14:40	2:29	0.000000	DT REPLACEMENT
2137	11-11-2025	Part of : BLOCK DG 3 VIKAS PURI	174	Other Outage	Planned Outage	11-11-2025	11:41	11-11-2025	14:43	3:02	0.000000	DT REPLACEMENT
2138	13-11-2025	Part of : BLOCK H2 VIKAS PURI	299	Other Outage	Planned Outage	13-11-2025	12:24	13-11-2025	13:52	1:28	0.000000	DT REPLACEMENT
2139	13-11-2025	Part of : BLOCK P & P2 MOHAN GARDEN RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL	2774	Other Outage	Planned Outage	13-11-2025	11:35	13-11-2025	13:48	2:13	0.000000	3PH DB REPLACEMENT
2140	13-11-2025	Part of : PHASE 3 OM VIHAR HASTSAL	945	Other Outage	Planned Outage	13-11-2025	10:27	13-11-2025	12:36	2:09	0.000000	DT REPLACEMENT
2141	14-11-2025	Part of : SHIV VIHAR HASTSAL, VIKAS NAGAR	5579	Other Outage	Unplanned Outage	14-11-2025	11:22	14-11-2025	12:22	1:00	0.000483	BIRDAGE
2142	14-11-2025	Part of : A 2 BLOCK UTTAM NAGAR	761	Other Outage	Planned Outage	14-11-2025	11:10	14-11-2025	13:39	2:29	0.000000	LT CIRCUIT DT REPLACEMENT
2143	14-11-2025	Part of : A BLOCK SHANKER GARDEN VIKAS PURI	6	Other Outage	Planned Outage	14-11-2025	10:12	14-11-2025	13:39	3:27	0.000000	LT CIRCUIT DT REPLACEMENT
2144	15-11-2025	Part of : A,B&C-BLOCK MAHARANI ENCLAVE	1966	Other Outage	Planned Outage	15-11-2025	11:29	15-11-2025	13:55	2:26	0.000000	3PH DB REVAMPING
2145	15-11-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL	1120	Other Outage	Planned Outage	15-11-2025	10:35	15-11-2025	12:47	2:12	0.000000	DT REPLACEMENT PER DT
2146	15-11-2025	Part of : BLOCK DG 3 VIKAS PURI	736	Other Outage	Planned Outage	15-11-2025	10:17	15-11-2025	12:46	2:29	0.000000	DT REPLACEMENT
2147	17-11-2025	Part of : VIKAS ENCLAVE AND B-BLOCK VIKAS NAGAR EXTN	1920	Other Outage	Planned Outage	17-11-2025	13:39	17-11-2025	16:26	2:47	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
2148	17-11-2025	Part of : HASTSAL VIHAR HASTSAL VILLAGE HASTSAL	137	Other Outage	Planned Outage	17-11-2025	10:53	17-11-2025	13:42	2:49	0.000000	3PH DB REPLACEMENT
2149	17-11-2025	Part of : BLOCK DG 3 VIKAS PURI	283	Other Outage	Planned Outage	17-11-2025	10:20	17-11-2025	12:26	2:06	0.000000	DT REPLACEMENT
2150	18-11-2025	Part of : HOSTAL VIHAR OM VIHAR HASTSAL,	664	Other Outage	Planned Outage	18-11-2025	11:00	18-11-2025	13:30	2:30	0.000000	REPLACEMENT OF LT BUSHING ROD
2151	18-11-2025	Part of : POCKET A KRISHNA PARK VIKAS PURI,	261	Other Outage	Planned Outage	18-11-2025	10:06	18-11-2025	12:22	2:16	0.000000	DT REPLACEMENT
2152	19-11-2025	Part of : DEEP ENCLAVE AND NAIDER ENCLAVE	1221	Other Outage	Planned Outage	19-11-2025	15:02	19-11-2025	16:17	1:15	0.000000	DT REPLACEMENT
2153	19-11-2025	Part of : HASTSAL VIHAR HASTSAL VILLAGE	813	Other Outage	Planned Outage	19-11-2025	10:44	19-11-2025	13:37	2:53	0.000000	DT REPLACEMENT
2154	19-11-2025	Part of : BLOCK A SHANKER GARDEN VIKAS PURI	738	Other Outage	Planned Outage	19-11-2025	10:19	19-11-2025	12:23	2:04	0.000000	DT REPLACEMENT
2155	21-11-2025	Part of : D-BLOCK JJ COLONY	1584	Other Outage	Planned Outage	21-11-2025	14:09	21-11-2025	15:50	1:41	0.000000	DT REPLACEMENT
2156	21-11-2025	Part of : BLOCK A 2 UTTAM NAGAR,KRISHNA COLONY HASTSAL VILLAGE HASTSAL	1455	Other Outage	Planned Outage	21-11-2025	11:26	21-11-2025	13:29	2:03	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
2157	21-11-2025	Part of : BLOCK H2 VIKAS PURI	385	Other Outage	Planned Outage	21-11-2025	10:12	21-11-2025	12:27	2:15	0.000000	DT REPLACEMENT
2158	21-11-2025	Part of : BLOCK GG1 VIKAS PURI	466	Other Outage	Planned Outage	21-11-2025	13:31	21-11-2025	15:48	2:17	0.000000	REPLACEMET OF HT BUSHING ROD
2159	21-11-2025	Part of : A,B&C-BLOCK MAHARANI ENCLAVE	87	Other Outage	Planned Outage	21-11-2025	11:28	21-11-2025	13:28	2:00	0.000000	3PH DB REVAMPING
2160	22-11-2025	Part of : PHASE 3 OM VIHAR HASTSAL,	1258	Other Outage	Planned Outage	22-11-2025	10:54	22-11-2025	14:02	3:08	0.000000	REPLACEMENT OF LT BUSHING ROD
2161	22-11-2025	Part of : MANOHAR NAGAR VIKAS PURI,	201	Other Outage	Planned Outage	22-11-2025	10:19	22-11-2025	12:47	2:28	0.000000	DT REPLACEMENT
2162	24-11-2025	Part of : F & S-BLOCK VIKAS NAGAR,SHIV VIHAR COLONY,D-BLOCK JJ COLONY	5581	Other Outage	Unplanned Outage	24-11-2025	06:46	24-11-2025	07:22	0:36	0.000290	BIRDAGE
2163	24-11-2025	Part of : GUPTA ENCLAVE,SHIV VIHAR WEST	3336	Other Outage	Unplanned Outage	24-11-2025	06:46	24-11-2025	07:23	0:37	0.000463	BIRDAGE
2164	24-11-2025	Part of : SAINIK ENCLAVE & PANCHSHEEL ENCLAVE	3049	Other Outage	Planned Outage	24-11-2025	10:52	24-11-2025	13:47	2:55	0.000000	3PH HT AB CABLE REPLACEMENT
2165	24-11-2025	Part of : C-BLOCK VIKAS PURI	487	Other Outage	Planned Outage	24-11-2025	10:03	24-11-2025	12:27	2:24	0.000000	LT CIRCUIT MAINTENANCE WORK
2166	25-11-2025	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK, LIONS ENCLAVE, VIKAS NAGAR EXTN., SAINIK ENCLAVE	3689	Other Outage	Unplanned Outage	25-11-2025	11:13	25-11-2025	11:34	0:21	0.000140	HT SYSTEM FAULT
2167	25-11-2025	Part of : VIDHYA VIHAR, KRISHNA COLONY, HASTSAL VILLAGE, PHASE 2 OM VIHAR HASTSAL	3148	Other Outage	Unplanned Outage	25-11-2025	23:13	25-11-2025	23:45	0:32	0.000169	HVDS FAULT
2168	25-11-2025	Part of : GUPTA ENCLAVE, VIKAS NAGAR, SHIV VIHAR WEST	3336	Other Outage	Unplanned Outage	25-11-2025	16:55	25-11-2025	17:37	0:42	0.000408	HT SYSTEM FAULT
2169	26-11-2025	Part of : R&S BLOCK VIKAS NAGAR,SHIV VIHAR WEST,GUPTA ENCLAVE	2114	Other Outage	Unplanned Outage	26-11-2025	16:55	26-11-2025	17:30	0:35	0.000194	CABLE FAULT
2170	26-11-2025	Part of : VIKAS KUNJ AND VIKAS KUNJ EXTN.,SAI& SETHI ENCLAVE,VIKRANT VIHAR,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE	3271	Other Outage	Unplanned Outage	26-11-2025	16:53	26-11-2025	17:29	0:36	0.000240	CABLE FAULT
2171	26-11-2025	Part of : VIKAS NAGAR PHASE-I,II,III,SHIV VIHAR HASTSAL,BHIM ENCLAVE,HASTSAL EXTN. AND VIKAS NAGAR PHASE-II	3415	Other Outage	Unplanned Outage	26-11-2025	15:49	26-11-2025	16:32	0:43	0.000370	HT SYSTEM FAULT
2172	26-11-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE HASTSAL,	436	Other Outage	Planned Outage	26-11-2025	10:58	26-11-2025	13:38	2:40	0.000000	3PH DB REPLACEMENT
2173	26-11-2025	Part of : BLOCK KG 3 VIKAS PURI,	742	Other Outage	Planned Outage	26-11-2025	10:06	26-11-2025	12:46	2:40	0.000000	DT REPLACEMENT
2174	27-11-2025	Part of : BLOCK K 7 ZAILDAR ENCLAVE HASTSAL	1275	Other Outage	Unplanned Outage	27-11-2025	13:28	27-11-2025	14:45	1:17	0.000000	REPAIRING OF HVDS CIRCUIT
2175	27-11-2025	Part of : VIKAS KUNJ VIKAS PURI	1119	Other Outage	Unplanned Outage	27-11-2025	09:51	27-11-2025	11:27	1:36	0.000000	REPAIRING OF RMU

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
2176	27-11-2025	Part of : MANOHAR NAGAR VIKAS PURI	104	Other Outage	Planned Outage	27-11-2025	13:30	27-11-2025	15:35	2:05	0.000000	DT REPLACEMENT
2177	28-11-2025	Part of : D-BLOCK JJ COLONY	1584	Other Outage	Planned Outage	28-11-2025	11:26	28-11-2025	13:46	2:20	0.000000	DT REPLACEMENT
2178	28-11-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE	77	Other Outage	Planned Outage	28-11-2025	11:31	28-11-2025	13:44	2:13	0.000000	LT CIRCUIT MAINTENANCE
2179	28-11-2025	Part of : GG1-BLOCK VIKAS PURI	465	Other Outage	Planned Outage	28-11-2025	10:08	28-11-2025	12:45	2:37	0.000000	LT CIRCUIT MAINTENANCE
2180	29-11-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE, PHASE 2 OM VIHAR HASTSAL, HASTAL VIHAR, B-BLOCK VIDHYA VIHAR	3148	Other Outage	Unplanned Outage	29-11-2025	03:25	29-11-2025	03:56	0:31	0.000121	CABLE FAULT
2181	29-11-2025	Part of : YADAV ENCLAVE AND VIKAS VIHAR	126	Other Outage	Planned Outage	29-11-2025	13:34	29-11-2025	15:54	2:20	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
2182	29-11-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE	1049	Other Outage	Planned Outage	29-11-2025	11:52	29-11-2025	13:54	2:02	0.000000	3PH DB REPLACEMENT
2183	29-11-2025	Part of : BLOCK H KESHOPUR INDUSTRIAL AREA VIKAS PURI	10	Other Outage	Planned Outage	29-11-2025	14:20	29-11-2025	16:52	2:32	0.000000	REPLACEMENT OF LT BUSHING ROD
2184	29-11-2025	Part of : BLOCK JG 1 VIKAS PURI	196	Other Outage	Planned Outage	29-11-2025	10:19	29-11-2025	13:10	2:51	0.000000	DT REPLACEMENT