

Name of Distribution Licensee: BSES Rajdhani Power Limited												
Period of Outage: SEPTEMBER 2025												
Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1	04-09-2025	Part of : TILAK KHAND GIRI NAGAR,GOVINDPURI	1795	Other Outage	Unplanned Outage	04-09-2025	22:03	04-09-2025	22:46	0:43	0.001039	HT SYSTEM FAULT
2	07-09-2025	Part of : D-BLOCK OKHLA PHASE-1,	169	Other Outage	Planned Outage	07-09-2025	10:58	07-09-2025	16:00	5:02	0.005033	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
3	08-09-2025	Part of : AMIRCHAND KHAND GOVINDPURI	724	Other Outage	Planned Outage	08-09-2025	10:55	08-09-2025	13:53	2:58	0.000841	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
4	09-09-2025	Part of : GANGOTRI ENCLAVE,W-BLOCK GK-2	1498	Other Outage	Unplanned Outage	09-09-2025	12:14	09-09-2025	12:52	0:38	0.000243	HT SYSTEM FAULT
5	09-09-2025	Part of : MARKET NO-4 CR PARK	280	Other Outage	Planned Outage	09-09-2025	13:02	09-09-2025	16:45	3:43	0.000929	APPLY OF INSULATION TAPE HT/LT BUSHINGS
6	09-09-2025	Part of : MARKET NO-4 CR PARK	260	Other Outage	Planned Outage	09-09-2025	11:04	09-09-2025	13:47	2:43	0.000906	APPLY OF INSULATION TAPE HT/LT BUSHINGS
7	09-09-2025	Part of : MARKET NO-4 CR PARK	823	Other Outage	Planned Outage	09-09-2025	11:03	09-09-2025	13:49	2:46	0.001153	APPLY OF INSULATION TAPE HT/LT BUSHINGS
8	10-09-2025	Part of : E-BLOCK MASJID MOTH, BLOCK N CHITTARANJAN PARK, BLOCK E & M G.K-II, DLF LTD. E BLOCK GROUP HOUSING G.K-II	710	Other Outage	Unplanned Outage	10-09-2025	12:02	10-09-2025	12:54	0:52	0.000679	HT SYSTEM FAULT
9	10-09-2025	Part of : NILGIRI APARTMENT	196	Other Outage	Planned Outage	10-09-2025	11:10	10-09-2025	13:48	2:38	0.000878	DT REPLACEMENT
10	11-09-2025	Part of : A-BLOCK OKHLA PHASE-1,RAILWAY YARD,GOVINDPURI,B-BLOCK OKHLA PHASE-1,SUBASH KHAND GOVINDPURI,TUGHLAKABAD RAILWAY COLONY,C-BLOCK OKHLA PHASE-1,D-BLOCK OKHLA PHASE-1	346	Other Outage	Unplanned Outage	11-09-2025	10:50	11-09-2025	11:45	0:55	0.001176	
11	11-09-2025	Part of : A13-BLOCK KALKA JI EXTN,	186	Other Outage	Planned Outage	11-09-2025	13:05	11-09-2025	14:52	1:47	0.000297	DT REPLACEMENT
12	11-09-2025	Part of : B-BLOCK CR PARK,	377	Other Outage	Planned Outage	11-09-2025	13:30	11-09-2025	15:43	2:13	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
13	11-09-2025	Part of : B-BLOCK CR PARK,	386	Other Outage	Planned Outage	11-09-2025	10:55	11-09-2025	13:32	2:37	0.000872	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
14	11-09-2025	Part of : B-BLOCK CR PARK,	280	Other Outage	Planned Outage	11-09-2025	10:56	11-09-2025	13:33	2:37	0.000872	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
15	12-09-2025	Part of : SHIVALIK APARTMENT	237	Other Outage	Planned Outage	12-09-2025	11:13	12-09-2025	13:53	2:40	0.000444	DT REPLACEMENT
16	12-09-2025	Part of : BLOCK A 10 KALKAJI EXTENSION GOVINDPURI KALKAJI	797	Other Outage	Planned Outage	12-09-2025	11:28	12-09-2025	13:51	2:23	0.004767	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING
17	13-09-2025	Part of : MELA GROUND	218	Other Outage	Planned Outage	13-09-2025	14:07	13-09-2025	17:13	3:06	0.001033	REPLACEMET OF HT BUSHING ROD
18	13-09-2025	Part of : MELA GROUND	233	Other Outage	Planned Outage	13-09-2025	11:15	13-09-2025	14:08	2:53	0.000961	REPLACEMET OF HT BUSHING ROD
19	13-09-2025	Part of : BLOCK A 8 KALKAJI EXTENSION	958	Other Outage	Planned Outage	13-09-2025	11:01	13-09-2025	16:05	5:04	0.000844	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
20	14-09-2025	Part of : BLOCK A 10 KALKAJI EXTENSION GOVINDPURI	287	Other Outage	Planned Outage	14-09-2025	15:21	14-09-2025	15:50	0:29	0.000000	CLEANING OF INSULATORS PER POLE
21	14-09-2025	Part of : C-44 DDA SHED OKHLA PHASE-1	173	Other Outage	Planned Outage	14-09-2025	10:55	14-09-2025	12:39	1:44	0.000578	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
22	14-09-2025	Part of : D-BLOCK OKHLA PHASE-1	99	Other Outage	Planned Outage	14-09-2025	11:04	14-09-2025	13:33	2:29	0.002897	SUB STATION CLEANING
23	15-09-2025	Part of : A13-BLOCK KALKA JI EXTN,A14-BLOCK KALKA JI EXTN_DDA FLATS KALKAJI,A11-BLOCK KALKA JI EXTN	1726	Other Outage	Unplanned Outage	15-09-2025	00:02	15-09-2025	00:37	0:35	0.000671	CABLE FAULT
24	15-09-2025	Part of : TUGHLAKABAD EXTN,	991	Other Outage	Planned Outage	15-09-2025	11:45	15-09-2025	15:45	4:00	0.000000	DT REPLACEMENT
25	15-09-2025	Part of : TUGHLAQABAD VILLAGE TUGHLAKABAD,	819	Other Outage	Planned Outage	15-09-2025	11:31	15-09-2025	15:35	4:04	0.008133	REPLACEMENT OF LUGS/NUT BOLTS/BOOTS,RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
26	15-09-2025	Part of : GOVINDPURI,	1320	Other Outage	Planned Outage	15-09-2025	10:59	15-09-2025	13:58	2:59	0.001989	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS
27	16-09-2025	Part of : H-BLOCK CR PARK	390	Other Outage	Planned Outage	16-09-2025	15:14	16-09-2025	17:57	2:43	0.000906	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
28	16-09-2025	Part of : H-BLOCK CR PARK	335	Other Outage	Planned Outage	16-09-2025	11:25	16-09-2025	13:54	2:29	0.000828	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
29	16-09-2025	Part of : A4-BLOCK KALKA JI EXTN	18	Other Outage	Planned Outage	16-09-2025	11:24	16-09-2025	13:39	2:15	0.000038	DT REPLACEMENT
30	17-09-2025	Part of : TUGHLAQABAD VILLAGE	1151	Other Outage	Unplanned Outage	17-09-2025	22:08	17-09-2025	22:52	0:44	0.001014	CABLE FAULT
31	17-09-2025	Part of : HINDUSTAN STEEL YARD,B & D-BLOCK OKHLA PHASE-1,TEHKHAND TELEPHONE EXCHANGE	561	Other Outage	Unplanned Outage	17-09-2025	10:11	17-09-2025	10:59	0:48	0.001320	FAULT IN HT CONSUMER PANEL (STEEL AUTHORITY OF INDIA)
32	18-09-2025	Part of : POCKET 52 CHITTARANJAN PARK	307	Other Outage	Planned Outage	18-09-2025	11:15	18-09-2025	13:42	2:27	0.000817	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
33	18-09-2025	Part of : A4-BLOCK KALKA JI EXTN	25	Other Outage	Planned Outage	18-09-2025	10:57	18-09-2025	14:52	3:55	0.000653	DT REPLACEMENT
34	18-09-2025	Part of : TUGHLAQABAD FORT	492	Other Outage	Planned Outage	18-09-2025	11:01	18-09-2025	15:07	4:06	0.006833	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
35	19-09-2025	Part of : GOVINDPURI,	2485	Other Outage	Planned Outage	19-09-2025	11:22	19-09-2025	14:07	2:45	0.001833	DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING
36	19-09-2025	Part of : KALI MANDIR SOCIETY CHITTARANJAN PARK,	422	Other Outage	Planned Outage	19-09-2025	10:59	19-09-2025	14:08	3:09	0.001050	REPLACEMET OF HT BUSHING ROD
37	20-09-2025	Part of : Block A Chittaranjan Park,	153	Other Outage	Planned Outage	20-09-2025	14:19	20-09-2025	17:11	2:52	0.000956	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
38	20-09-2025	Part of : Block 13 Nehru Enclave East Kalkaji,	321	Other Outage	Planned Outage	20-09-2025	11:05	20-09-2025	14:11	3:06	0.001033	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
39	20-09-2025	Part of : Block A Chittaranjan Park,	270	Other Outage	Planned Outage	20-09-2025	11:06	20-09-2025	14:12	3:06	0.001033	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
40	21-09-2025	Part of : EFFULIANT TREATMENT PLANT (HT CONSUMER)	132	Other Outage	Unplanned Outage	21-09-2025	01:29	21-09-2025	02:21	0:52	0.000173	CABLE FAULT
41	21-09-2025	Part of : C-BLOCK OKHLA PHASE-1	19	Other Outage	Planned Outage	21-09-2025	13:57	21-09-2025	15:37	1:40	0.000556	REPLACEMENT OF HT BUSHING ROD
42	21-09-2025	Part of : D-90 OKHLA PHASE-1 HT CONSUMER	1	Other Outage	Planned Outage	21-09-2025	10:37	21-09-2025	12:33	1:56	0.001611	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
43	21-09-2025	Part of : C-BLOCK OKHLA PHASE-1	51	Other Outage	Planned Outage	21-09-2025	11:03	21-09-2025	13:59	2:56	0.000978	REPLACEMENT OF HT BUSHING ROD
44	21-09-2025	Part of : B-BLOCK OKHLA PHASE-1	287	Other Outage	Planned Outage	21-09-2025	11:04	21-09-2025	13:06	2:02	0.000847	LT CIRCUIT MAINTENANCE
45	22-09-2025	Part of : H-BLOCK KALKA JI	1134	Other Outage	Planned Outage	22-09-2025	11:12	22-09-2025	14:11	2:59	0.000994	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF LT BUSHING ROD
46	22-09-2025	Part of : A4-BLOCK KALKA JI EXTN	1566	Other Outage	Planned Outage	22-09-2025	11:09	22-09-2025	15:12	4:03	0.000675	DT REPLACEMENT
47	23-09-2025	Part of : BLOCK D HARIJAN COLONY GOVINDPURI KALKAJI,BLOCK A HARIJAN COLONY GOVINDPURI KALKAJI	3462	Other Outage	Unplanned Outage	23-09-2025	08:59	23-09-2025	09:35	0:36	0.000790	CABLE FAULT
48	23-09-2025	Part of : J-BLOCK CR PARK,	319	Other Outage	Planned Outage	23-09-2025	11:39	23-09-2025	13:32	1:53	0.000628	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
49	24-09-2025	Part of : E-BLOCK KALKA JI	364	Other Outage	Planned Outage	24-09-2025	10:43	24-09-2025	13:53	3:10	0.005014	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
50	24-09-2025	Part of : TUGHLAKABAD EXTN	2008	Other Outage	Planned Outage	24-09-2025	11:04	24-09-2025	13:52	2:48	0.000000	DT REPLACEMENT
51	25-09-2025	Part of : A & F-BLOCK OKHLA INDUSTRIAL AREA PHASE-1,ESI HOSPITAL	113	Other Outage	Unplanned Outage	25-09-2025	13:20	25-09-2025	14:00	0:40	0.000933	HT SYSTEM FAULT
52	25-09-2025	Part of : A & F-BLOCK OKHLA INDUSTRIAL AREA PHASE-1,ESI HOSPITAL	113	Other Outage	Unplanned Outage	25-09-2025	05:11	25-09-2025	05:53	0:42	0.000198	TREE TOUCHING
53	25-09-2025	Part of : M-BLOCK GK-2	93	Other Outage	Planned Outage	25-09-2025	14:20	25-09-2025	16:21	2:01	0.000672	APPLY OF INSULATION TAPE HT/LT BUSHINGS
54	25-09-2025	Part of : M-BLOCK GK-2	214	Other Outage	Planned Outage	25-09-2025	11:07	25-09-2025	13:52	2:45	0.000917	APPLY OF INSULATION TAPE HT/LT BUSHINGS
55	25-09-2025	Part of : M-BLOCK GK-2	158	Other Outage	Planned Outage	25-09-2025	11:09	25-09-2025	13:53	2:44	0.000911	APPLY OF INSULATION TAPE HT/LT BUSHINGS
56	26-09-2025	Part of : GOVINDPURI EXTENSION KALKAJI	995	Other Outage	Planned Outage	26-09-2025	10:52	26-09-2025	14:14	3:22	0.006733	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING
57	27-09-2025	Part of : L-BLOCK KALKA JI,	844	Other Outage	Planned Outage	27-09-2025	11:08	27-09-2025	13:46	2:38	0.004389	CHECKING VALUE OF FENCING EARTHING,DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS
58	27-09-2025	Part of : C-BLOCK CR PARK,	401	Other Outage	Planned Outage	27-09-2025	10:26	27-09-2025	12:51	2:25	0.000000	LT AB SAGGING PER SPAN
59	28-09-2025	Part of : NARMADA APARTMENT,YAMUNA APARTMENT,L1-BLOCK LIG KALKA JI,ARAWALI SHOPPING CENTRE,GODAVARI APARTMENT,ARAWALI APARTMENT,NILGIRI APARTMENT	2333	Other Outage	Unplanned Outage	28-09-2025	15:32	28-09-2025	16:20	0:48	0.001187	CABLE FAULT
60	28-09-2025	Part of : HINDUSTAN STEEL YARD,D-BLOCK OKHLA PHASE-1,B-BLOCK OKHLA PHASE-1,TEHKHAND TELEPHONE EXCHANGE	868	Other Outage	Planned Outage	28-09-2025	10:59	28-09-2025	14:16	3:17	0.001368	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
61	29-09-2025	Part of : BLOCK A 10 KALKAJI EXTENSION GOVINDPURI KALKAJI	757	Other Outage	Planned Outage	29-09-2025	11:07	29-09-2025	13:39	2:32	0.001267	DT OIL SAMPLING TO CHECK BDV VALUE
62	29-09-2025	Part of : A10-BLOCK KALKA JI EXTN	1329	Other Outage	Planned Outage	29-09-2025	10:57	29-09-2025	13:41	2:44	0.000000	REPLACEMENT OF LT BUSHING
63	30-09-2025	Part of : GREATER KAILASH PART 3, MASJID MOTH COMMUNITY CENTRE, VIPS INDIA MASJID MOTH (HTC)	198	Other Outage	Unplanned Outage	30-09-2025	05:47	30-09-2025	06:30	0:43	0.000084	CABLE FAULT
64	01-09-2025	Part of : SAT BARI,ANSAL VILLA	1428	Other Outage	Unplanned Outage	01-09-2025	17:57	01-09-2025	18:23	0:26	0.000000	TREE TOUCHING
65	01-09-2025	Part of : SULTANPUR,JAUNAPUR VILLAGE,RADHEY MOHAN DRIVE,DLF FARMS,GADAIPUR	84	Other Outage	Unplanned Outage	01-09-2025	15:35	01-09-2025	17:11	1:36	0.000293	TREE TOUCHING
66	03-09-2025	Part of : DLF FARMS,CHHATARPUR,SULTANPUR	161	Other Outage	Unplanned Outage	03-09-2025	17:26	03-09-2025	18:16	0:50	0.000569	TREE TOUCHING
67	03-09-2025	Part of : SULTANPUR,JAUNAPUR VILLAGE JAUNAPUR,RADHEY MOHAN DRIVE,DLF FARMS,GADAIPUR JAUNAPUR	84	Other Outage	Unplanned Outage	03-09-2025	17:26	03-09-2025	18:14	0:48	0.000147	TREE TOUCHING
68	03-09-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,BHIM BASTI JUANAPUR,AMBEDKAR COLONY MANDI,MANDI VILLAGE,SULTANPUR,	3481	Other Outage	Unplanned Outage	03-09-2025	14:13	03-09-2025	14:54	0:41	0.000000	REPAIRING OF RMU

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
69	04-09-2025	Part of : JAUNAPUR VILLAGE JAUNAPUR, WESTEND DLF CHATTARPUR FARMS DLF FARMS, BHIM BASTI JUANAPUR, AMBEDKAR COLONY MANDI	3481	Other Outage	Unplanned Outage	04-09-2025	11:49	04-09-2025	13:03	1:14	0.000493	REPAIRING OF RMU
70	05-09-2025	Part of : ANSAL VILLAS SAT BARI, FATEHPUR BERI, CHANDAN HOLA, ASOLA	1735	Other Outage	Unplanned Outage	05-09-2025	07:54	05-09-2025	08:01	0:07	0.000191	BIRDAGE
71	08-09-2025	Part of : MAIDAN GARHI VILLAGE CHHATARPUR, ANSAL VILLAS SAT BARI, ASOLA WILD LIFE SANCTUARY ASOLA, RAJPUR KHURD EXTENSION CHHATARPUR	306	Other Outage	Unplanned Outage	08-09-2025	11:44	08-09-2025	12:22	0:38	0.000412	TREE FALLEN ON HT O/H LINE
72	08-09-2025	Part of : RAJPUR KHURD VILLAGE CHHATARPUR	587	Other Outage	Planned Outage	08-09-2025	14:05	08-09-2025	15:30	1:25	0.000000	REPLACEMET OF HT BUSHING ROD
73	08-09-2025	Part of : BLOCK F AYA NAGAR EXTENSION	924	Other Outage	Planned Outage	08-09-2025	11:16	08-09-2025	14:39	3:23	0.000564	APPLY OF INSULATION TAPE HT/LT BUSHINGS
74	09-09-2025	Part of : DLF FARMS, ANSAL VILLAS SAT BARI	789	Other Outage	Planned Outage	09-09-2025	12:37	09-09-2025	13:04	0:27	0.000375	HT CONDUCTOR REPLACEMET
75	09-09-2025	Part of : G-BLOCK AYA NAGAR EXTENSION	1166	Other Outage	Planned Outage	09-09-2025	12:52	09-09-2025	15:38	2:46	0.000461	APPLY OF INSULATION TAPE HT/LT BUSHINGS, OIL TOP UP IN TRANSFORMER
76	10-09-2025	Part of : DLF FARMS, ANSAL VILLAS SAT BARI	789	Other Outage	Planned Outage	10-09-2025	13:13	10-09-2025	15:07	1:54	0.001583	CONDUCTOR REPLACEMET PER SPAN
77	10-09-2025	Part of : ASOLA	1446	Other Outage	Planned Outage	10-09-2025	11:34	10-09-2025	13:31	1:57	0.001625	CONDUCTOR REPLACEMET PER SPAN
78	10-09-2025	Part of : PHASE-V AYA NAGAR EXTENSION AYA NAGAR	823	Other Outage	Planned Outage	10-09-2025	11:30	10-09-2025	14:49	3:19	0.000553	APPLY OF INSULATION TAPE HT/LT BUSHINGS, OIL TOP UP IN TRANSFORMER, OIL TOP UP IN TRANSFORMER, REPLACEMENT OF SILICAGEL IN BREATHER, SUB STATION CLEANING, TIGHTENING OF NUT BOLT
79	10-09-2025	Part of : SULTANPUR	164	Other Outage	Planned Outage	10-09-2025	12:03	10-09-2025	14:14	2:11	0.000000	CONDUCTOR REPLACEMENT PER SPAN, INSTALLATION OF PHASE SEPARATOR PER SPAN, JUMPER REPLACEMENT PER POLE
80	11-09-2025	Part of : CHHATARPUR ENCLAVE CHHATARPUR,	379	Other Outage	Planned Outage	11-09-2025	10:29	11-09-2025	13:55	3:26	0.000000	REPLACEMET OF HT/LT CLEATS, REPLACEMET OF LUGS, TIGHTENING OF NUT BOLT
81	11-09-2025	Part of : FATEHPUR BERI,	1448	Other Outage	Planned Outage	11-09-2025	11:05	11-09-2025	14:32	3:27	0.002875	CONDUCTOR REPLACEMET PER SPAN
82	11-09-2025	Part of : SULTANPUR, JAUNAPUR VILLAGE JAUNAPUR, RADHEY MOHAN DRIVE, DLF FARMS, GADAI PUR JAUNAPUR,	69	Other Outage	Planned Outage	11-09-2025	10:16	11-09-2025	13:11	2:55	0.001167	REPLACEMENT OF LT BUSHING INSULATOR, REPLACEMENT OF LT BUSHING ROD
83	12-09-2025	Part of : BLOCK A1 CHHATARPUR VILLAGE	714	Other Outage	Planned Outage	12-09-2025	11:26	12-09-2025	14:01	2:35	0.001507	REPLACEMENT OF GAS KIT AND OIL SEAL
84	12-09-2025	Part of : MAIDAN GARHI VILLAGE CHHATARPUR	826	Other Outage	Planned Outage	12-09-2025	10:41	12-09-2025	13:51	3:10	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
85	13-09-2025	Part of : JAUNAPUR VILLAGE	568	Other Outage	Planned Outage	13-09-2025	11:24	13-09-2025	14:04	2:40	0.000000	JUMPER REPLACEMENT ON LT POLE
86	14-09-2025	Part of : ANSAL VILLAS SAT BARI, FATEHPUR BERI, CHANDAN HOLA, ASOLA	1735	Other Outage	Unplanned Outage	14-09-2025	06:11	14-09-2025	06:21	0:10	0.000353	BIRDAGE
87	15-09-2025	Part of : ADARSH ENCLAVE AYA NAGAR EXTENSION AYA NAGAR, PHASE-V AYA NAGAR EXTENSION AYA NAGAR	4601	Other Outage	Unplanned Outage	15-09-2025	18:06	15-09-2025	19:14	1:08	0.001568	CABLE DAMAGE BY OUTSIDE AGENCY (AIRTEL)
88	15-09-2025	Part of : PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR,	989	Other Outage	Planned Outage	15-09-2025	13:02	15-09-2025	14:19	1:17	0.000428	1PH HT AB END TERMINATION REPLACEMENT
89	15-09-2025	Part of : SAT BARI,	378	Other Outage	Planned Outage	15-09-2025	11:32	15-09-2025	13:27	1:55	0.001597	REPLACEMET OF HT BUSHING ROD
90	15-09-2025	Part of : CHHATARPUR,	749	Other Outage	Planned Outage	15-09-2025	10:55	15-09-2025	13:50	2:55	0.000000	1PH DB REPLACEMENT, 1PH DB REVAMPING, 3PH DB REPLACEMENT, 3PH DB REVAMPING, JUMPER REPLACEMENT PER POLE, PRC REPLACEMET PER FEEDER
91	15-09-2025	Part of : PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR,	988	Other Outage	Planned Outage	15-09-2025	10:35	15-09-2025	13:02	2:27	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
92	16-09-2025	Part of : MAIDAN GARHI VILLAGE CHHATARPUR	1193	Other Outage	Planned Outage	16-09-2025	12:17	16-09-2025	13:28	1:11	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
93	16-09-2025	Part of : DERA VILLAGE	569	Other Outage	Planned Outage	16-09-2025	10:58	16-09-2025	13:28	2:30	0.001042	REPLACEMENT OF LT BUSHING ROD
94	16-09-2025	Part of : ASOLA	359	Other Outage	Planned Outage	16-09-2025	10:43	16-09-2025	13:46	3:03	0.001525	BUS BAR REPLACEMENT PER PHASE
95	16-09-2025	Part of : SULTANPUR	1205	Other Outage	Planned Outage	16-09-2025	11:15	16-09-2025	14:15	3:00	0.000000	1PH DB REPLACEMENT, CONDUCTOR REPLACEMENT PER SPAN, FERRULE PUNCHING LT AB TO LT AB PER FEEDER
96	17-09-2025	Part of : CHATERPUR	0	Other Outage	Unplanned Outage	17-09-2025	17:41	17-09-2025	18:29	0:48	0.001813	HVDS FAULT
97	17-09-2025	Part of : BHATI KALAN	597	Other Outage	Planned Outage	17-09-2025	12:28	17-09-2025	14:05	1:37	0.000808	REPLACEMET OF HT BUSHING ROD
98	17-09-2025	Part of : GADPUR FARM DLF FARMS	524	Other Outage	Planned Outage	17-09-2025	12:43	17-09-2025	14:58	2:15	0.000375	APPLY OF INSULATION TAPE HT/LT BUSHINGS
99	17-09-2025	Part of : A 1-BLOCK CHHATARPUR VILLAGE	619	Other Outage	Planned Outage	17-09-2025	10:42	17-09-2025	14:30	3:48	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
100	18-09-2025	Part of : SAT BARI, ANSAL VILLAS SAT BARI, ADARSH COLONY KHARAK VILLAGE	1427	Other Outage	Unplanned Outage	18-09-2025	07:11	18-09-2025	07:34	0:23	0.000351	TREE BRANCH FALLEN ON HT LINE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
101	18-09-2025	Part of : AYA NAGAR VILLAGE	1421	Other Outage	Planned Outage	18-09-2025	14:20	18-09-2025	16:45	2:25	0.000403	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
102	18-09-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	254	Other Outage	Planned Outage	18-09-2025	10:34	18-09-2025	13:49	3:15	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
103	18-09-2025	Part of : SAT BARI	240	Other Outage	Planned Outage	18-09-2025	10:33	18-09-2025	13:02	2:29	0.001242	REPLACEMET OF HT BUSHING ROD
104	18-09-2025	Part of : BHIM BASTI JUANAPUR	813	Other Outage	Planned Outage	18-09-2025	12:10	18-09-2025	15:09	2:59	0.000000	1PH DB REPLACEMENT,1PH DB REVAMPING,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
105	19-09-2025	Part of : FATEHPUR BERI,	675	Other Outage	Planned Outage	19-09-2025	11:54	19-09-2025	14:07	2:13	0.001108	REPLACEMET OF HT BUSHING ROD
106	19-09-2025	Part of : WESTEND DLF CHATTARPUR FARMS DLF FARMS,JAUNAPUR VILLAGE JAUNAPUR,BHIM BASTI JUANAPUR,AMBEDKAR COLONY MANDI,MANDI VILLAGE,SULTANPUR,	3479	Other Outage	Planned Outage	19-09-2025	10:27	19-09-2025	14:05	3:38	0.006056	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
107	19-09-2025	Part of : BLOCK A1 CHHATARPUR VILLAGE CHHATARPUR,	827	Other Outage	Planned Outage	19-09-2025	10:31	19-09-2025	13:55	3:24	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
108	20-09-2025	Part of : Mandi Village,	761	Other Outage	Planned Outage	20-09-2025	11:12	20-09-2025	14:00	2:48	0.000000	1PH DB REPLACEMENT,1PH DB REVAMPING,3PH DB REPLACEMENT,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
109	22-09-2025	Part of : SAT BARI, ANSAL VILLAS SAT BARI, ADARSH COLONY KHARAK VILLAGE	1427	Other Outage	Unplanned Outage	22-09-2025	11:50	22-09-2025	12:11	0:21	0.000338	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
110	22-09-2025	Part of : PHASE 1 CHHATARPUR ENCLAVE	745	Other Outage	Planned Outage	22-09-2025	10:33	22-09-2025	13:20	2:47	0.000000	REPLACEMET OF HT BUSHING ROD
111	22-09-2025	Part of : FATEHPUR BERI	675	Other Outage	Planned Outage	22-09-2025	10:58	22-09-2025	15:38	4:40	0.002333	REPLACEMET OF HT BUSHING ROD
112	22-09-2025	Part of : BLOCK G AYA NAGAR EXTENSION	361	Other Outage	Planned Outage	22-09-2025	10:59	22-09-2025	14:01	3:02	0.000506	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
113	23-09-2025	Part of : GADPUR FARM DLF FARMS,GADAIPUR DLF FARMS,GADAIPUR JAUNAPUR,SULTANPUR,WESTEND DLF CHATTARPUR FARMS DLF FARMS,	1482	Other Outage	Planned Outage	23-09-2025	14:04	23-09-2025	15:21	1:17	0.002139	BIRD SPIKES INSTALLATION PER POLE,JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
114	23-09-2025	Part of : BHATI KALAN,	404	Other Outage	Planned Outage	23-09-2025	12:37	23-09-2025	14:09	1:32	0.000511	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
115	23-09-2025	Part of : AYA NAGAR PHASE 1 AYA NAGAR,	933	Other Outage	Planned Outage	23-09-2025	12:52	23-09-2025	15:41	2:49	0.000469	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
116	23-09-2025	Part of : PHASE 1 CHHATARPUR ENCLAVE CHHATARPUR,	754	Other Outage	Planned Outage	23-09-2025	11:08	23-09-2025	13:49	2:41	0.000000	3PH HT AB END TERMINATION REPLACEMENT
117	23-09-2025	Part of : CHHATARPUR ENCLAVE CHHATARPUR,	210	Other Outage	Planned Outage	23-09-2025	10:40	23-09-2025	13:49	3:09	0.000000	REPLACEMET OF HT BUSHING ROD
118	24-09-2025	Part of : AMBEDKAR COLONY MANDI	510	Other Outage	Planned Outage	24-09-2025	13:34	24-09-2025	14:22	0:48	0.000000	1PH DB REPLACEMENT,1PH DB REVAMPING,3PH DB REPLACEMENT,3PH DB REVAMPING,JUMPER REPLACEMENT PER POLE,PRC REPLACEMET PER FEEDER
119	24-09-2025	Part of : AYA NAGAR PHASE 1 AYA NAGAR	306	Other Outage	Planned Outage	24-09-2025	12:22	24-09-2025	14:23	2:01	0.000000	3PH DB REPLACEMENT,3PH DB REVAMPING,JUMPER REPLACEMENT PER POLE
120	25-09-2025	Part of : RAJPUR KHURD CHHATARPUR VILLAGE	314	Other Outage	Planned Outage	25-09-2025	10:54	25-09-2025	13:51	2:57	0.000000	REPLACEMET OF HT BUSHING ROD
121	25-09-2025	Part of : BHATI KALAN	448	Other Outage	Planned Outage	25-09-2025	11:45	25-09-2025	13:51	2:06	0.000700	REPLACEMET OF HT BUSHING ROD
122	25-09-2025	Part of : AYA NAGAR PHASE 1	306	Other Outage	Planned Outage	25-09-2025	11:31	25-09-2025	15:38	4:07	0.000000	REPLACEMENT OF LT BUSHING ROD
123	25-09-2025	Part of : SULTANPUR	75	Other Outage	Planned Outage	25-09-2025	11:31	25-09-2025	15:40	4:09	0.000000	LT CIRCUIT MAINTENANCE
124	26-09-2025	Part of : AMBEDKAR COLONY MANDI, JAUNAPUR VILLAGE, BHIM BASTI JUANAPUR	3882	Other Outage	Planned Outage	26-09-2025	10:28	26-09-2025	15:19	4:51	0.008083	BIRD SPIKES INSTALLATION PER POLE,JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
125	26-09-2025	Part of : BLOCK G AYA NAGAR EXTENSION	928	Other Outage	Planned Outage	26-09-2025	11:26	26-09-2025	15:19	3:53	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
126	27-09-2025	Part of : POCKET B DR AMBEDKAR COLONY CHHATARPUR,DR AMBEDKAR COLONY CHHATARPUR,POCKET A DR AMBEDKAR COLONY CHHATARPUR,	2676	Other Outage	Planned Outage	27-09-2025	10:16	27-09-2025	13:11	2:55	0.000486	3PH HT AB END TERMINATION REPLACEMENT
127	28-09-2025	Part of : SAT BARI,ANSAL VILLAS SAT BARI	1427	Other Outage	Unplanned Outage	28-09-2025	11:23	28-09-2025	11:49	0:26	0.000585	BIRDAGE
128	28-09-2025	Part of : SULTANPUR,JAUNAPUR VILLAGE JAUNAPUR,RADHEY MOHAN DRIVE,DLF FARMS,GADAI PUR JAUNAPUR	84	Other Outage	Unplanned Outage	28-09-2025	00:59	28-09-2025	01:24	0:25	0.000111	TREE BRANCH FALLEN ON O/H LINE
129	29-09-2025	Part of : MANGLAPURI VILLAGE SULTANPUR	1010	Other Outage	Planned Outage	29-09-2025	10:29	29-09-2025	13:21	2:52	0.000669	REPLACEMENT OF HT BUSHING
130	29-09-2025	Part of : RAJPUR KHURD EXTENSION CHHATARPUR	221	Other Outage	Planned Outage	29-09-2025	10:28	29-09-2025	12:47	2:19	0.000000	3PH HT AB END TERMINATION REPLACEMENT
131	29-09-2025	Part of : BLOCK G AYA NAGAR EXTENSION	575	Other Outage	Planned Outage	29-09-2025	12:28	29-09-2025	14:36	2:08	0.000000	REPLACEMENT OF LT BUSHING
132	30-09-2025	Part of : L&T CHATERPUR (HTC)	0	Other Outage	Unplanned Outage	30-09-2025	13:17	30-09-2025	14:22	1:05	0.002167	HVDS FAULT
133	02-09-2025	Part of : ANAND LOK SADIQ NAGAR, AYUR VIGYAN NAGAR SADIQ NAGAR, SIRI FORT INSTITUTIONAL AREA	904	Other Outage	Unplanned Outage	02-09-2025	09:23	02-09-2025	10:13	0:50	0.000750	HT SYSTEM FAULT
134	02-09-2025	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE, BLOCK B-6 S.D.A MAIN, DEER PARK BOOSTER PUMP (HTC)	1441	Other Outage	Unplanned Outage	02-09-2025	01:11	02-09-2025	01:55	0:44	0.000868	CABLE FAULT
135	03-09-2025	Part of : LAL GUMBAD BASTI SADHNA ENCLAVE PANCHSHILA PARK,	163	Other Outage	Planned Outage	03-09-2025	13:47	03-09-2025	14:55	1:08	0.000000	LT CIRCUIT MAINTENANCE
136	03-09-2025	Part of : BLOCK C7 BHIM NAGAR HAUZ KHAS,	331	Other Outage	Planned Outage	03-09-2025	12:01	03-09-2025	13:42	1:41	0.000140	TRANSFORMER MAINTENANCE
137	06-09-2025	Part of : BLOCK F POLICE COLONY HAUZ KHAS	187	Other Outage	Unplanned Outage	06-09-2025	11:43	06-09-2025	13:01	1:18	0.000043	REPAIRING OF LT CIRCUIT
138	06-09-2025	Part of : BLOCK S PANCHSHILA PARK SOUTH	141	Other Outage	Planned Outage	06-09-2025	13:31	06-09-2025	15:29	1:58	0.000098	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
139	06-09-2025	Part of : BLOCK D SOUTH EXTENSION II	210	Other Outage	Planned Outage	06-09-2025	11:10	06-09-2025	13:52	2:42	0.000900	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER
140	07-09-2025	Part of : SIRIFORT SPORTS COMPLEX	1	Other Outage	Unplanned Outage	07-09-2025	03:01	07-09-2025	03:48	0:47	0.000000	TRANSIENT FAULT
141	07-09-2025	Part of : HTC:NUCLEAR SCIENCE CENTRE	2	Other Outage	Planned Outage	07-09-2025	11:25	07-09-2025	13:29	2:04	0.000344	CHECKING OF EARTHING VALUE USING ONLINE TESTER,TAPPING OF JUMPERS ,TIGHTENING OF HARDWARE FITTINGS
142	08-09-2025	Part of : BLOCK B 6 HUMAYUNPUR SAFDARJUNG ENCLAVE	1441	Other Outage	Unplanned Outage	08-09-2025	11:31	08-09-2025	13:32	2:01	0.000000	ATTENDING WEAK POINTS/HOT SPOT
143	08-09-2025	Part of : BLOCK B 3 SAFDARJUNG ENCLAVE	741	Other Outage	Planned Outage	08-09-2025	11:14	08-09-2025	15:39	4:25	0.001472	APPLY OF INSULATION TAPE HT/LT BUSHINGS
144	08-09-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	488	Other Outage	Planned Outage	08-09-2025	11:05	08-09-2025	15:57	4:52	0.000243	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER
145	09-09-2025	Part of : GAUTAM NAGAR	1217	Other Outage	Planned Outage	09-09-2025	11:02	09-09-2025	13:52	2:50	0.001417	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
146	09-09-2025	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE	239	Other Outage	Planned Outage	09-09-2025	11:13	09-09-2025	13:49	2:36	0.000650	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
147	09-09-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	71	Other Outage	Planned Outage	09-09-2025	11:57	09-09-2025	14:06	2:09	0.000108	LT XLPE TO LT AB PER FEEDER
148	10-09-2025	Part of : LAL GUMBAD BASTI SADHNA ENCLAVE PANCHSHILA PARK	163	Other Outage	Planned Outage	10-09-2025	11:35	10-09-2025	13:18	1:43	0.000143	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER , EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER, FERRULE PUNCHING LT AB TO LT AB PER FEEDER , JUMPER REPLACEMENT PER POLE, OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE, PRC REPLACEMENT PER FEEDER
149	10-09-2025	Part of : BLOCK A QUTAB INSTITUTIONAL AREA	54	Other Outage	Planned Outage	10-09-2025	11:23	10-09-2025	14:13	2:50	0.000472	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER, CHECKING VALUE OF FENCING EARTHING, DT OIL SAMPLING TO CHECK BDV VALUE, GENERAL SURFACE CLEANING OF HT/LT BUSHINGS, MEASUREMENT OF INSULATION RESISTANCE (INCLUDING DISCONNECTION OF HT/LT CABLES), OIL TOP UP IN TRANSFORMER , OIL TOP UP IN TRANSFORMER , REPLACEMENT OF GAS KIT AND OIL SEAL, REPLACEMENT OF SILICAGEL IN BREATHER, SUB STATION CLEANING, TIGHTENING OF NUT BOLT
150	10-09-2025	Part of : HUMAYUNPUR SAFDARJUNG ENCLAVE	890	Other Outage	Planned Outage	10-09-2025	11:10	10-09-2025	14:02	2:52	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS, CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER, CHECKING VALUE OF FENCING EARTHING, MEASUREMENT OF INSULATION RESISTANCE (INCLUDING DISCONNECTION OF HT/LT CABLES), OIL TOP UP IN TRANSFORMER , OIL TOP UP IN TRANSFORMER , REPLACEMENT OF HT BUSHING ROD, REPLACEMENT OF LUGS, SUB STATION CLEANING, TIGHTENING OF NUT BOLT
151	11-09-2025	Part of : ANAND LOK SADIQ NAGAR,	297	Other Outage	Unplanned Outage	11-09-2025	11:22	11-09-2025	13:05	1:43	0.000029	CONNECTION OF NEW LT CABLE
152	11-09-2025	Part of : BLOCK S PANCHSHILA PARK SOUTH PANCHSHILA PARK,	78	Other Outage	Planned Outage	11-09-2025	11:50	11-09-2025	14:18	2:28	0.000288	APPLY OF INSULATION TAPE HT/LT BUSHINGS, CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER, CHECKING VALUE OF FENCING EARTHING, DT OIL SAMPLING TO CHECK BDV VALUE, GENERAL SURFACE CLEANING OF HT/LT BUSHINGS, INSTALLATION OF HT BOOTS, MEASUREMENT OF INSULATION RESISTANCE (INCLUDING DISCONNECTION OF HT/LT CABLES), OIL TOP UP IN TRANSFORMER , OIL TOP UP IN TRANSFORMER , REPLACEMENT OF SILICAGEL IN BREATHER, REPLACEMENT OF HT/LT CLEATS, SUB STATION CLEANING, TIGHTENING OF NUT BOLT
153	12-09-2025	Part of : BLOCK A SOUTH EXTENSION II	211	Other Outage	Planned Outage	12-09-2025	12:49	12-09-2025	16:01	3:12	0.001600	DT REPLACEMENT
154	12-09-2025	Part of : BLOCK A KATWARIA SARAI	1190	Other Outage	Planned Outage	12-09-2025	11:26	12-09-2025	14:18	2:52	0.000956	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
155	12-09-2025	Part of : BLOCK S PANCHSHILA PARK SOUTH	171	Other Outage	Planned Outage	12-09-2025	11:33	12-09-2025	14:20	2:47	0.000139	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER , CONDUCTOR REPLACEMENT PER SPAN, EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER
156	13-09-2025	Part of : I.O.C BLDG, SADIQUE NGR (HT CONSUMER)	1	Other Outage	Planned Outage	13-09-2025	12:16	13-09-2025	12:32	0:16	0.000053	CLEANING OF HT BUSHING
157	13-09-2025	Part of : BLOCK B 3 SAFDARJUNG ENCLAVE	710	Other Outage	Planned Outage	13-09-2025	11:23	13-09-2025	13:33	2:10	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
158	13-09-2025	Part of : GAUTAM NAGAR	1239	Other Outage	Planned Outage	13-09-2025	11:06	13-09-2025	13:54	2:48	0.001400	CHECKING OF EARTHING VALUE OF BODY EARTHING
159	13-09-2025	Part of : SHAHPUR JAT VILLAGE SIRI FORT	423	Other Outage	Planned Outage	13-09-2025	10:37	13-09-2025	13:01	2:24	0.000200	AL LUGS PUCHING ON LT XLPE TO LT
160	15-09-2025	Part of : BLOCK L GREEN PARK,	172	Other Outage	Unplanned Outage	15-09-2025	10:22	15-09-2025	12:04	1:42	0.000000	MOBILE TRANSFORMER REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
161	15-09-2025	Part of : BLOCK E HAUZ KHAS,	160	Other Outage	Planned Outage	15-09-2025	11:15	15-09-2025	13:45	2:30	0.000125	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
162	16-09-2025	Part of : BLOCK A 1 NAUROJI NAGAR SAFDARJUNG ENCLAVE	23	Other Outage	Planned Outage	16-09-2025	11:14	16-09-2025	12:56	1:42	0.000283	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
163	16-09-2025	Part of : PANCHSHILA PARK NORTH	310	Other Outage	Planned Outage	16-09-2025	11:39	16-09-2025	14:14	2:35	0.000344	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
164	16-09-2025	Part of : GAUTAM NAGAR	812	Other Outage	Planned Outage	16-09-2025	10:58	16-09-2025	13:53	2:55	0.000486	CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS
165	17-09-2025	Part of : B 4-BLOCK SAFDARJUNG ENCLAVE	1519	Other Outage	Planned Outage	17-09-2025	11:09	17-09-2025	14:40	3:31	0.000879	APPLY OF INSULATION TAPE HT/LT BUSHINGS
166	18-09-2025	Part of : BLOCK S PANCHSHILA PARK SOUTH	308	Other Outage	Unplanned Outage	18-09-2025	13:03	18-09-2025	13:26	0:23	0.000051	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
167	18-09-2025	Part of : BLOCK S PANCHSHILA PARK SOUTH	186	Other Outage	Unplanned Outage	18-09-2025	14:38	18-09-2025	15:25	0:47	0.000104	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
168	18-09-2025	Part of : ANAND LOK SADIQ NAGAR	168	Other Outage	Unplanned Outage	18-09-2025	12:09	18-09-2025	13:19	1:10	0.000019	TREE TRIMMING
169	18-09-2025	Part of : PANCHSHILA PARK NORTH	250	Other Outage	Planned Outage	18-09-2025	11:32	18-09-2025	13:28	1:56	0.000451	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
170	19-09-2025	Part of : BLOCK D GULMOHAR PARK,	373	Other Outage	Unplanned Outage	19-09-2025	12:48	19-09-2025	13:00	0:12	0.000003	REPAIRING OF LT CIRCUIT
171	19-09-2025	Part of : SECTOR 1 SADIQ NAGAR,	1309	Other Outage	Unplanned Outage	19-09-2025	11:58	19-09-2025	13:33	1:35	0.000528	REPAIRING OF TRANSFORMER
172	19-09-2025	Part of : JAWAHAR LAL NEHRU UNIVERSITY,	3	Other Outage	Planned Outage	19-09-2025	13:07	19-09-2025	14:02	0:55	0.000168	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
173	19-09-2025	Part of : BLOCK L KAUSALYA PARK PADMINI ENCLAVE HAUZ KHAS,	160	Other Outage	Planned Outage	19-09-2025	10:58	19-09-2025	13:47	2:49	0.000141	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,INSULATOR REPLACEMENT PER POLE,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
174	19-09-2025	Part of : BLOCK A GREEN PARK EXTENSION GREEN PARK,	228	Other Outage	Planned Outage	19-09-2025	11:34	19-09-2025	14:04	2:30	0.000583	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
175	20-09-2025	Part of : KATWARIA SARAI	1	Other Outage	Planned Outage	20-09-2025	12:56	20-09-2025	13:40	0:44	0.000196	CHECKING OF EARTHING VALUE USING ONLINE TESTER,TAPPING OF JUMPERS ,TAPPING OF UG CABLE TO OH JUMPER CONNECTION,TIGHTENING OF HARDWARE FITTINGS

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
176	20-09-2025	Part of : Humayunpur Safdarjung Enclave,	1	Other Outage	Planned Outage	20-09-2025	12:06	20-09-2025	13:40	1:34	0.000261	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
177	20-09-2025	Part of : Lal Gumbad Basti Sadhna Enclave Panchshila Park,	163	Other Outage	Planned Outage	20-09-2025	10:58	20-09-2025	13:43	2:45	0.000092	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FFFEDER
178	21-09-2025	Part of : RBF STAFF QUARTERS MAYFAIR GARDEN HAUZ KHAS	40	Other Outage	Unplanned Outage	21-09-2025	13:40	21-09-2025	15:36	1:56	0.000226	REPAIRING OF TRANSFORMER
179	22-09-2025	Part of : BLOCK H GREEN PARK EXTENSION	556	Other Outage	Planned Outage	22-09-2025	11:33	22-09-2025	14:36	3:03	0.000763	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
180	22-09-2025	Part of : BLOCK A SOAMI NAGAR NORTH	141	Other Outage	Planned Outage	22-09-2025	10:53	22-09-2025	13:52	2:59	0.000149	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
181	23-09-2025	Part of : BLOCK A GREEN PARK,	1	Other Outage	Planned Outage	23-09-2025	11:50	23-09-2025	13:27	1:37	0.000269	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
182	23-09-2025	Part of : BLOCK A GREEN PARK,	3	Other Outage	Planned Outage	23-09-2025	13:00	23-09-2025	15:29	2:29	0.000414	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
183	23-09-2025	Part of : BLOCK D SOAMI NAGAR SOUTH SOAMI NAGAR,	172	Other Outage	Planned Outage	23-09-2025	11:14	23-09-2025	13:39	2:25	0.000121	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
184	23-09-2025	Part of : ANDREWS GANJ,	770	Other Outage	Planned Outage	23-09-2025	10:48	23-09-2025	13:52	3:04	0.001022	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
185	24-09-2025	Part of : BLOCK N GREEN PARK EXTENSION	507	Other Outage	Planned Outage	24-09-2025	11:09	24-09-2025	14:01	2:52	0.001433	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
186	24-09-2025	Part of : BLOCK X HAUZ KHAS	154	Other Outage	Planned Outage	24-09-2025	10:59	24-09-2025	14:10	3:11	0.000000	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
187	25-09-2025	Part of : LAL GUMBAD BASTI SADHNA ENCLAVE PANCHSHILA PARK	480	Other Outage	Planned Outage	25-09-2025	11:02	25-09-2025	13:55	2:53	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
188	26-09-2025	Part of : BLOCK C7 BHIM NAGAR HAUZ KHAS, DEER PARK HAUZ KHAS, BLOCK C 3 SAFDARJUNG DEVELOPMENT AREA HAUZ KHAS	1690	Other Outage	Unplanned Outage	26-09-2025	09:59	26-09-2025	10:45	0:46	0.000856	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
189	26-09-2025	Part of : BEER SARAI	254	Other Outage	Planned Outage	26-09-2025	11:39	26-09-2025	13:29	1:50	0.000092	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
190	26-09-2025	Part of : BLOCK Y HAUZ KHAS	206	Other Outage	Planned Outage	26-09-2025	11:11	26-09-2025	13:22	2:11	0.000109	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FFEEDER
191	27-09-2025	Part of : BLOCK A GREEN PARK EXTENSION GREEN PARK,	228	Other Outage	Planned Outage	27-09-2025	13:45	27-09-2025	15:38	1:53	0.000314	DT REPLACEMENT
192	27-09-2025	Part of : RBF STAFF QUARTERS MAYFAIR GARDEN HAUZ KHAS,	40	Other Outage	Planned Outage	27-09-2025	11:20	27-09-2025	12:21	1:01	0.000034	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF GAS KIT AND OIL SEAL
193	27-09-2025	Part of : BLOCK D SOAMI NAGAR SOUTH SOAMI NAGAR,	508	Other Outage	Planned Outage	27-09-2025	14:03	27-09-2025	17:40	3:37	0.000844	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD
194	27-09-2025	Part of : BLOCK G HAUZ KHAS,	159	Other Outage	Planned Outage	27-09-2025	11:50	27-09-2025	13:51	2:01	0.000101	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,EARTHING VALUE OF POLE EARTHING USING ONLINE TESTER,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,INSTALLATION OF PHASE SEPERATOR PER SPAN,JUMPER REPLACEMENT PER POLE,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FFEEDER
195	27-09-2025	Part of : YUSUF SARAI,	545	Other Outage	Planned Outage	27-09-2025	11:03	27-09-2025	13:53	2:50	0.001133	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
196	29-09-2025	Part of : DEER PARK,RBF STAFF QUARTERS MAYFAIR GARDEN HAUZ,F-BLOCK POLICE COLONY,INDIAN INSTITUTE OF TECHNOLOGY DELHI HAUZ KHAS	1	Other Outage	Unplanned Outage	29-09-2025	04:02	29-09-2025	04:51	0:49	0.001797	CABLE FAULT
197	29-09-2025	Part of : BLOCK S PANCHSHILA PARK SOUTH	308	Other Outage	Planned Outage	29-09-2025	11:30	29-09-2025	13:26	1:56	0.000451	APPLY OF INSULATION TAPE HT BUSHINGS
198	02-09-2025	Part of : BLOCK A & F JJ COLONY DR AMBEDKAR NAGAR SECTOR 4,VAYUSENA VIHAR VAYUSENABAD, DAKSHIN PURI	8389	Other Outage	Unplanned Outage	02-09-2025	07:40	02-09-2025	08:26	0:46	0.000856	HT SYSTEM FAULT
199	02-09-2025	Part of : KHANPUR VILLAGE	993	Other Outage	Unplanned Outage	02-09-2025	11:45	02-09-2025	13:26	1:41	0.000701	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
200	03-09-2025	Part of : TIGRI EXTENSION TIGRI SANGAM VIHAR,	1095	Other Outage	Planned Outage	03-09-2025	12:56	03-09-2025	15:44	2:48	0.000513	TRANSFORMER MAINTENANCE
201	03-09-2025	Part of : BLOCK F DR AMBEDKAR NAGAR MADANGIR,	1173	Other Outage	Planned Outage	03-09-2025	12:08	03-09-2025	14:48	2:40	0.000489	TRANSFORMER MAINTENANCE
202	03-09-2025	Part of : BLOCK L DEVL I SANGAM VIHAR,BLOCK G DEVL I SANGAM VIHAR,	3274	Other Outage	Planned Outage	03-09-2025	10:05	03-09-2025	12:51	2:46	0.000507	HVDS MAINTENANCE
203	04-09-2025	Part of : BLOCK E, F 2 & G2 SANGAM VIHAR,TALIMABAD SANGAM VIHAR	2457	Other Outage	Planned Outage	04-09-2025	11:28	04-09-2025	14:01	2:33	0.000468	HVDS CIRCUIT NETWORK UPGRADATION
204	04-09-2025	Part of : BLOCK J & L DEVL I SANGAM VIHAR	3638	Other Outage	Planned Outage	04-09-2025	10:21	04-09-2025	12:50	2:29	0.000455	HVDS CIRCUIT NETWORK UPGRADATION
205	06-09-2025	Part of : VAYUSENA VIHAR VAYUSENABAD	2871	Other Outage	Planned Outage	06-09-2025	11:18	06-09-2025	13:56	2:38	0.000483	REPLACEMET OF HT BUSHING ROD
206	06-09-2025	Part of : BLOCK C TIGRI EXTENSION SANGAM VIHAR	842	Other Outage	Planned Outage	06-09-2025	11:11	06-09-2025	13:57	2:46	0.000507	REPLACEMET OF HT BUSHING ROD
207	06-09-2025	Part of : VISHWAKARMA COLONY PULPEHLADPUR.BLOCK C LAL KUAN	1849	Other Outage	Planned Outage	06-09-2025	10:58	06-09-2025	14:08	3:10	0.000581	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
208	06-09-2025	Part of : BLOCK L & L 2 DEVL SANGAM VIHAR	1951	Other Outage	Planned Outage	06-09-2025	10:00	06-09-2025	12:52	2:52	0.000526	3PH HT AB CABLE REPLACEMENT PER SPAN
209	08-09-2025	Part of : HAMDARD NAGAR,TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD,TALIMABAD SANGAM VIHAR	561	Other Outage	Unplanned Outage	08-09-2025	00:35	08-09-2025	00:59	0:24	0.000160	HT SYSTEM FAULT
210	08-09-2025	Part of : TIGRI EXTENSION TIGRI SANGAM VIHAR,DEOLI GAON NAI BASTI SANGAM VIHAR,TUGHLAKABAD INSTITUTIONAL AREA	5281	Other Outage	Unplanned Outage	08-09-2025	00:07	08-09-2025	00:26	0:19	0.000032	CABLE FAULT
211	08-09-2025	Part of : BLOCK H & G 2 SANGAM VIHAR	2292	Other Outage	Planned Outage	08-09-2025	13:01	08-09-2025	15:53	2:52	0.000526	3PH HT AB CABLE REPLACEMENT PER SPAN
212	08-09-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR	3698	Other Outage	Planned Outage	08-09-2025	10:10	08-09-2025	12:54	2:44	0.000501	3PH HT AB CABLE REPLACEMENT PER SPAN
213	09-09-2025	Part of : KHANPUR EXTENSION,KHANPUR VILLAGE,POCKET A DUGGAL COLONY,G-BLOCK SECTOR 5 DAKSHINPURI,JAWAHAR PARK	1228	Other Outage	Planned Outage	09-09-2025	11:00	09-09-2025	12:45	1:45	0.000321	3PH HT AB END TERMINATION REPLACEMENT
214	09-09-2025	Part of : A,C,R & RZ-BLOCK PULPEHLADPUR	2542	Other Outage	Planned Outage	09-09-2025	11:16	09-09-2025	14:03	2:47	0.000510	3PH HT AB CABLE REPLACEMENT
215	09-09-2025	Part of : B-BLOCK TIGRI EXTENSION SANGAM VIHAR	1691	Other Outage	Planned Outage	09-09-2025	11:17	09-09-2025	14:00	2:43	0.000498	REPLACEMET OF HT BUSHING ROD
216	10-09-2025	Part of : MADANGIR VILLAGE	2310	Other Outage	Planned Outage	10-09-2025	12:27	10-09-2025	15:14	2:47	0.000510	REPLACEMET OF HT BUSHING ROD
217	10-09-2025	Part of : BLOCK A LAL KUAN	932	Other Outage	Planned Outage	10-09-2025	11:44	10-09-2025	15:02	3:18	0.000605	LT AB SAGGING PER SPAN
218	10-09-2025	Part of : BLOCK A PULPEHLADPUR, HR-BLOCK PULPEHLADPUR	1098	Other Outage	Planned Outage	10-09-2025	10:49	10-09-2025	14:38	3:49	0.000700	3PH HT AB CABLE REPLACEMENT PER SPAN
219	10-09-2025	Part of : TIGRI EXTENSION SANGAM VIHAR	1580	Other Outage	Planned Outage	10-09-2025	11:02	10-09-2025	13:41	2:39	0.000486	REPLACEMET OF HT BUSHING ROD
220	10-09-2025	Part of : BLOCK L DEVL SANGAM VIHAR,BLOCK J DEVL SANGAM VIHAR	3638	Other Outage	Planned Outage	10-09-2025	10:02	10-09-2025	13:20	3:18	0.000605	3PH HT AB CABLE REPLACEMENT PER SPAN
221	11-09-2025	Part of : TUKLAQABAD FORT,SURAJ CAMP PREM NAGAR TUGHLAKABAD,TUGHLAKABAD,AIRFORCE STATION TUGHLAKABAD,PREM NAGAR TUGHLAKABAD,NARADANA TUGHLAKABAD	1276	Other Outage	Unplanned Outage	11-09-2025	14:47	11-09-2025	15:21	0:34	0.000926	HT SYSTEM FAULT
222	11-09-2025	Part of : BLOCK C DEVL SANGAM VIHAR,BLOCK L DEVL SANGAM VIHAR,BLOCK G DEVL SANGAM VIHAR,BLOCK J DEVL SANGAM VIHAR	4714	Other Outage	Unplanned Outage	11-09-2025	14:11	11-09-2025	14:55	0:44	0.001161	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
223	11-09-2025	Part of : RPS COLONY MADANGIR,POCKET A DUGGAL COLONY KHANPUR,KHANPUR EXTENSION SANGAM VIHAR,KHANPUR VILLAGE KHANPUR,BLOCK G SECTOR 5 DAKSHINPURI,JAWAHAR PARK SANGAM VIHAR	1554	Other Outage	Unplanned Outage	11-09-2025	06:44	11-09-2025	07:26	0:42	0.000373	HVDS FAULT
224	11-09-2025	Part of : KHANPUR EXTENSION SANGAM VIHAR,	1159	Other Outage	Planned Outage	11-09-2025	11:08	11-09-2025	13:52	2:44	0.000501	REPLACEMET OF HT BUSHING ROD
225	11-09-2025	Part of : JAWAHAR PARK SANGAM VIHAR,POCKET C JAWAHAR PARK KHANPUR,	101	Other Outage	Planned Outage	11-09-2025	11:02	11-09-2025	13:50	2:48	0.000513	3PH HT AB CABLE REPLACEMENT PER SPAN
226	11-09-2025	Part of : KHANPUR VILLAGE KHANPUR,	838	Other Outage	Planned Outage	11-09-2025	11:37	11-09-2025	14:21	2:44	0.000501	FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,LT AB SAGGING PER SPAN
227	11-09-2025	Part of : BLOCK A PULPEHLADPUR,	21	Other Outage	Planned Outage	11-09-2025	10:46	11-09-2025	13:59	3:13	0.000590	REPLACEMET OF HT BUSHING ROD
228	11-09-2025	Part of : DURGA VIHAR DEVL SANGAM VIHAR,	928	Other Outage	Planned Outage	11-09-2025	11:02	11-09-2025	13:57	2:55	0.000535	REPLACEMET OF HT BUSHING ROD
229	12-09-2025	Part of : TIGRI EXTENSION TIGRI SANGAM VIHAR	3253	Other Outage	Unplanned Outage	12-09-2025	23:50	13-09-2025	00:23	0:33	0.001348	CABLE FAULT
230	12-09-2025	Part of : BLOCK J 2 DEVL SANGAM VIHAR	2469	Other Outage	Planned Outage	12-09-2025	11:32	12-09-2025	14:02	2:30	0.000458	3PH HT AB END TERMINATION REPLACEMENT
231	12-09-2025	Part of : BLOCK 19 DAKSHINPURI EXTENSION SECTOR 6	1766	Other Outage	Planned Outage	12-09-2025	11:01	12-09-2025	14:08	3:07	0.000571	REPLACEMET OF HT BUSHING ROD
232	12-09-2025	Part of : HR-BLOCK PULPEHLADPUR	2224	Other Outage	Planned Outage	12-09-2025	11:03	12-09-2025	13:56	2:53	0.000529	REPLACEMET OF HT BUSHING ROD
233	12-09-2025	Part of : BLOCK L DEVL SANGAM VIHAR	1397	Other Outage	Planned Outage	12-09-2025	10:13	12-09-2025	12:51	2:38	0.000483	3PH HT AB END TERMINATION REPLACEMENT
234	13-09-2025	Part of : TIGRI EXTENSION SANGAM VIHAR	1	Other Outage	Unplanned Outage	13-09-2025	11:18	13-09-2025	12:06	0:48	0.000667	CABLE FAULT
235	13-09-2025	Part of : POCKET B DUGGAL COLONY KHANPUR	1455	Other Outage	Planned Outage	13-09-2025	11:07	13-09-2025	14:01	2:54	0.000532	REPLACEMET OF HT BUSHING ROD
236	13-09-2025	Part of : DDA LIG FLATS PULPEHLADPUR,C,HR-BLOCK PULPEHLADPUR	2224	Other Outage	Planned Outage	13-09-2025	11:06	13-09-2025	14:09	3:03	0.000559	3PH HT AB CABLE REPLACEMENT
237	13-09-2025	Part of : JAWAHAR PARK,DEOLI GAON NAI BASTI,BLOCK A TIGRI EXTENSION	1377	Other Outage	Planned Outage	13-09-2025	10:57	13-09-2025	13:56	2:59	0.000547	REPLACEMET OF HT BUSHING ROD
238	13-09-2025	Part of : DURGA VIHAR DEVL SANGAM VIHAR	441	Other Outage	Planned Outage	13-09-2025	10:58	13-09-2025	13:58	3:00	0.000550	REPLACEMET OF HT BUSHING ROD
239	13-09-2025	Part of : BLOCK L ,G&J DEVL SANGAM VIHAR	3279	Other Outage	Planned Outage	13-09-2025	10:04	13-09-2025	13:00	2:56	0.000538	3PH HT AB CABLE REPLACEMENT
240	15-09-2025	Part of : JAWAHAR PARK SANGAM VIHAR,DEOLI GAON NAI BASTI SANGAM VIHAR,BLOCK A TIGRI EXTENSION SANGAM VIHAR,	1377	Other Outage	Planned Outage	15-09-2025	11:09	15-09-2025	14:02	2:53	0.000529	REPLACEMET OF HT BUSHING ROD
241	15-09-2025	Part of : BLOCK R ZTO F PULPEHLADPUR,BLOCK C PULPEHLADPUR,	2043	Other Outage	Planned Outage	15-09-2025	11:00	15-09-2025	14:09	3:09	0.000578	3PH HT AB CABLE REPLACEMENT PER SPAN
242	15-09-2025	Part of : BLOCK A JJ COLONY DR AMBEDKAR NAGAR SECTOR 4 MADANGIR,	1030	Other Outage	Planned Outage	15-09-2025	10:40	15-09-2025	13:31	2:51	0.000523	REPLACEMET OF HT BUSHING ROD
243	15-09-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR,	3698	Other Outage	Planned Outage	15-09-2025	10:01	15-09-2025	13:06	3:05	0.000565	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
244	16-09-2025	Part of : RAILWAY COLONY TUGHLAKABAD,BLOCK G VISHWAKARMA COLONY PULPEHLADPUR,HR-BLOCK PULPEHLADPUR,DDA LIG FLATS PULPEHLADPUR	4912	Other Outage	Unplanned Outage	16-09-2025	12:29	16-09-2025	12:55	0:26	0.000672	CABLE FAULT
245	16-09-2025	Part of : KHANPUR VILLAGE,JAWAHAR PARK SANGAM VIHAR,POCKET C JAWAHAR PARK KHANPUR	3562	Other Outage	Unplanned Outage	16-09-2025	11:56	16-09-2025	12:36	0:40	0.001200	HT SYSTEM FAULT
246	16-09-2025	Part of : TIGRI COLONY TIGRI SANGAM VIHAR	2855	Other Outage	Planned Outage	16-09-2025	11:16	16-09-2025	14:04	2:48	0.000513	REPLACEMET OF HT BUSHING ROD
247	16-09-2025	Part of : BLOCK A, C, RZ H & RZ TO F PULPEHLADPUR	2542	Other Outage	Planned Outage	16-09-2025	10:57	16-09-2025	14:09	3:12	0.000587	3PH HT AB CABLE REPLACEMENT PER SPAN
248	16-09-2025	Part of : DURGA VIHAR DEVLİ SANGAM VIHAR	740	Other Outage	Planned Outage	16-09-2025	10:53	16-09-2025	13:55	3:02	0.000556	REPLACEMET OF HT BUSHING ROD
249	16-09-2025	Part of : POCKET C RAJU PARK SANGAM VIHAR	796	Other Outage	Planned Outage	16-09-2025	11:05	16-09-2025	14:15	3:10	0.000581	3PH HT AB CABLE REPLACEMENT PER SPAN
250	17-09-2025	Part of : KHANPUR VILLAGE,POCKET C JAWAHAR PARK,POCKET C DUGGAL COLONY KHANPUR	3563	Other Outage	Unplanned Outage	17-09-2025	06:32	17-09-2025	07:11	0:39	0.001018	HVDS FAULT
251	17-09-2025	Part of : DDA LIG FLATS PULPEHLADPUR	811	Other Outage	Planned Outage	17-09-2025	10:58	17-09-2025	13:54	2:56	0.000538	REPLACEMET OF HT BUSHING ROD
252	17-09-2025	Part of : H & G 2-BLOCK SANGAM VIHAR,TALIMABAD SANGAM VIHAR	2384	Other Outage	Planned Outage	17-09-2025	11:18	17-09-2025	14:06	2:48	0.000513	3PH HT AB CABLE REPLACEMENT
253	17-09-2025	Part of : KHANPUR VILLAGE	1721	Other Outage	Planned Outage	17-09-2025	11:02	17-09-2025	13:54	2:52	0.000526	REPLACEMET OF HT BUSHING ROD
254	17-09-2025	Part of : L 2-BLOCK DEVLİ SANGAM VIHAR	1951	Other Outage	Planned Outage	17-09-2025	09:57	17-09-2025	12:55	2:58	0.000544	3PH HT AB CABLE REPLACEMENT
255	18-09-2025	Part of : BLOCK C DEVLİ SANGAM VIHAR	1474	Other Outage	Planned Outage	18-09-2025	11:39	18-09-2025	15:05	3:26	0.000629	REPLACEMENT OF LT BUSHING ROD
256	18-09-2025	Part of : BLOCK B DEVLİ SANGAM VIHAR	2279	Other Outage	Planned Outage	18-09-2025	10:52	18-09-2025	13:54	3:02	0.000556	REPLACEMET OF HT BUSHING ROD
257	18-09-2025	Part of : DDA LIG FLATS PULPEHLADPUR, BLOCK C PULPEHLADPUR, HR-BLOCK PULPEHLADPUR	2224	Other Outage	Planned Outage	18-09-2025	10:42	18-09-2025	14:04	3:22	0.000617	3PH HT AB CABLE REPLACEMENT PER SPAN
258	19-09-2025	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,TUGHLAKABAD INSTITUTIONAL AREA VAYUSENABAD,BLOCK B DEVLİ SANGAM VIHAR,TIGRI EXTENSION TIGRI SANGAM VIHAR	4072	Other Outage	Unplanned Outage	19-09-2025	18:08	19-09-2025	18:38	0:30	0.000008	CABLE FAULT
259	19-09-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR,BLOCK L DEVLİ SANGAM VIHAR	6584	Other Outage	Unplanned Outage	19-09-2025	09:02	19-09-2025	09:34	0:32	0.000409	BIRDAGE
260	19-09-2025	Part of : POCKET A JAWAHAR PARK KHANPUR,	1850	Other Outage	Planned Outage	19-09-2025	11:02	19-09-2025	13:51	2:49	0.000516	REPLACEMET OF HT BUSHING ROD
261	19-09-2025	Part of : KHANPUR VILLAGE KHANPUR,	839	Other Outage	Planned Outage	19-09-2025	11:19	19-09-2025	14:04	2:45	0.000504	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,CONDUCTOR REPLACEMENT PER SPAN
262	19-09-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR,BLOCK L DEVLİ SANGAM VIHAR,	1951	Other Outage	Planned Outage	19-09-2025	10:36	19-09-2025	12:50	2:14	0.000409	3PH HT AB CABLE REPLACEMENT PER SPAN
263	20-09-2025	Part of : Deoli Gaon Nai Basti Sangam Vihar,Tughlakabad Institutional Area Vayusenabad,Block B Devli Sangam Vihar,Tigri Extension Tigri Sangam Vihar	4072	Other Outage	Unplanned Outage	20-09-2025	16:50	20-09-2025	17:26	0:36	0.000010	CABLE FAULT
264	20-09-2025	Part of : TUKLAQABAD FORT,Suraj Camp Prem Nagar Tughlakabad,Tughlakabad,Airforce Station Tughlakabad,Prem Nagar Tughlakabad,Naradana Tughlakabad	1276	Other Outage	Unplanned Outage	20-09-2025	06:53	20-09-2025	07:48	0:55	0.001360	BIRDAGE
265	20-09-2025	Part of : Block L Devli Sangam Vihar,	1	Other Outage	Planned Outage	20-09-2025	11:40	20-09-2025	13:07	1:27	0.000266	REPLACEMET OF HT BUSHING ROD
266	20-09-2025	Part of : RPS Colony Madangir,	1738	Other Outage	Planned Outage	20-09-2025	10:54	20-09-2025	14:05	3:11	0.000584	REPLACEMET OF HT BUSHING ROD
267	20-09-2025	Part of : Block J Devli Sangam Vihar,Block L Devli Sangam Vihar,	3638	Other Outage	Planned Outage	20-09-2025	10:02	20-09-2025	12:50	2:48	0.000513	3PH HT AB CABLE REPLACEMENT PER SPAN
268	20-09-2025	Part of : Block A Vishwakarma Colony Pulpehladpur,Block D Vishwakarma Colony Pulpehladpur,Block C Vishwakarma Colony Pulpehladpur,	1894	Other Outage	Planned Outage	20-09-2025	10:26	20-09-2025	14:26	4:00	0.000733	3PH HT AB CABLE REPLACEMENT PER SPAN
269	22-09-2025	Part of : DDA LIG FLATS PULPEHLADPUR	428	Other Outage	Planned Outage	22-09-2025	11:41	22-09-2025	14:59	3:18	0.000605	REPLACEMET OF HT BUSHING ROD
270	22-09-2025	Part of : DR AMBEDKAR NAGAR MADANGIR	1768	Other Outage	Planned Outage	22-09-2025	11:51	22-09-2025	14:44	2:53	0.000529	REPLACEMET OF HT BUSHING ROD
271	22-09-2025	Part of : BLOCK L 2 DEVLİ SANGAM VIHAR	3698	Other Outage	Planned Outage	22-09-2025	10:05	22-09-2025	13:28	3:23	0.000620	3PH HT AB END TERMINATION REPLACEMENT
272	23-09-2025	Part of : BLOCK A PULPEHLADPUR,BLOCK RZ H PULPEHLADPUR,BLOCK C PULPEHLADPUR,HR-BLOCK PULPEHLADPUR,BLOCK R ZTO F PULPEHLADPUR	4622	Other Outage	Unplanned Outage	23-09-2025	02:10	23-09-2025	02:25	0:15	0.000625	HT SYSTEM FAULT
273	23-09-2025	Part of : BLOCK B SECTOR 5 DAKSHINPURI,BLOCK A SECTOR 5 DAKSHINPURI,	2635	Other Outage	Planned Outage	23-09-2025	11:17	23-09-2025	12:58	1:41	0.000309	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
274	23-09-2025	Part of : BLOCK F 2 SANGAM VIHAR,	1140	Other Outage	Planned Outage	23-09-2025	10:48	23-09-2025	13:26	2:38	0.000000	REPLACEMET OF HT BUSHING ROD
275	24-09-2025	Part of : SHIV PARK DUGGAL COLONY KHANPUR,JJ COLONY DUGGAL COLONY KHANPUR,BLOCK F KHANPUR COLONY KHANPUR,KHANPUR VILLAGE	1275	Other Outage	Planned Outage	24-09-2025	11:05	24-09-2025	13:59	2:54	0.000532	3PH HT AB CABLE REPLACEMENT PER SPAN
276	24-09-2025	Part of : BLOCK A, C & H PULPEHLADPUR	2542	Other Outage	Planned Outage	24-09-2025	11:29	24-09-2025	14:03	2:34	0.000471	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
277	24-09-2025	Part of : BLOCK E SANGAM VIHAR	13	Other Outage	Planned Outage	24-09-2025	11:12	24-09-2025	13:53	2:41	0.000492	REPLACEMET OF HT BUSHING ROD
278	25-09-2025	Part of : RPS COLONY MADANGIR	1139	Other Outage	Unplanned Outage	25-09-2025	11:22	25-09-2025	11:45	0:23	0.000153	CABLE DAMAGE BY OUTSITE AGENCY (DMRC)
279	25-09-2025	Part of : F 2, F 3 & G 2-BLOCK SANGAM VIHAR,C-BLOCK DEVL, VAYUSENA VIHA	7866	Other Outage	Unplanned Outage	25-09-2025	06:32	25-09-2025	07:04	0:32	0.000276	HT SYSTEM FAULT
280	25-09-2025	Part of : KHANPUR VILLAGE	1744	Other Outage	Unplanned Outage	25-09-2025	16:07	25-09-2025	17:10	1:03	0.000000	REPLACEMENT OF DAMAGED LT AB CABLE
281	25-09-2025	Part of : BLOCK F, POCKET A,C,E,B&D JAWAHAR PARK KHANPUR COLONY	1378	Other Outage	Planned Outage	25-09-2025	10:55	25-09-2025	13:59	3:04	0.000562	3PH HT AB CABLE REPLACEMENT
282	25-09-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR	3404	Other Outage	Planned Outage	25-09-2025	10:57	25-09-2025	13:55	2:58	0.000544	REPLACEMET OF HT BUSHING ROD
283	25-09-2025	Part of : BLOCK D SANGAM VIHAR	1590	Other Outage	Planned Outage	25-09-2025	11:00	25-09-2025	13:50	2:50	0.000519	REPLACEMET OF HT BUSHING ROD
284	25-09-2025	Part of : BLOCK G ,C,B,F&AVISHWAKARMA COLONY PULPEHLADPUR	1849	Other Outage	Planned Outage	25-09-2025	10:12	25-09-2025	13:18	3:06	0.000568	3PH HT AB CABLE REPLACEMENT
285	26-09-2025	Part of : JAWAHAR PARK SANGAM VIHAR	169	Other Outage	Planned Outage	26-09-2025	10:52	26-09-2025	14:00	3:08	0.000574	REPLACEMET OF HT BUSHING ROD
286	26-09-2025	Part of : BLOCK G 1 TALIMABAD SANGAM VIHAR	1295	Other Outage	Planned Outage	26-09-2025	10:47	26-09-2025	13:57	3:10	0.000581	3PH HT AB CABLE REPLACEMENT PER SPAN
287	26-09-2025	Part of : BLOCK J DEVL SANGAM VIHAR, BLOCK L DEVL SANGAM VIHAR, AIRFORCE STATION TUGHLAKABAD	3638	Other Outage	Planned Outage	26-09-2025	10:02	26-09-2025	13:00	2:58	0.000544	3PH HT AB CABLE REPLACEMENT PER SPAN
288	27-09-2025	Part of : BLOCK G 2 SANGAM VIHAR, ASOLA WILD LIFE SANCTUARY, TUGHLAKABAD, BLOCK G 1 TALIMABAD SANGAM VIHAR, TALIMABAD SANGAM VIHAR, BLOCK F 2 SANGAM VIHAR, BLOCK H SANGAM VIHAR, BLOCK E SANGAM VIHAR, AIRFORCE STATION TUGHLAKABAD	2348	Other Outage	Unplanned Outage	27-09-2025	00:14	27-09-2025	00:58	0:44	0.000024	CABLE FAULT
289	27-09-2025	Part of : BLOCK B TIGRI EXTENSION SANGAM VIHAR,	1199	Other Outage	Planned Outage	27-09-2025	11:44	27-09-2025	14:54	3:10	0.000581	REPLACEMET OF HT BUSHING ROD
290	27-09-2025	Part of : BLOCK A PULPEHLADPUR, HR-BLOCK PULPEHLADPUR,	1098	Other Outage	Planned Outage	27-09-2025	11:07	27-09-2025	14:10	3:03	0.000559	3PH HT AB CABLE REPLACEMENT PER SPAN
291	27-09-2025	Part of : KHANPUR EXTENSION SANGAM VIHAR, KHANPUR VILLAGE KHANPUR, POCKET A DUGGAL COLONY KHANPUR, BLOCK G SECTOR 5 DAKSHINPURI, JAWAHAR PARK SANGAM VIHAR,	1227	Other Outage	Planned Outage	27-09-2025	10:54	27-09-2025	14:54	4:00	0.000733	3PH HT AB CABLE REPLACEMENT PER SPAN
292	27-09-2025	Part of : DEOLI GAON NAI BASTI SANGAM VIHAR,	1112	Other Outage	Planned Outage	27-09-2025	11:00	27-09-2025	13:54	2:54	0.000532	REPLACEMET OF HT BUSHING ROD
293	28-09-2025	Part of : TALIMABAD SANGAM VIHAR, BLOCK G 1 TALIMABAD SANGAM VIHAR	6193	Other Outage	Unplanned Outage	28-09-2025	08:17	28-09-2025	09:02	0:45	0.001200	CABLE FAULT
294	29-09-2025	Part of : BLOCK E SANGAM VIHAR	13	Other Outage	Planned Outage	29-09-2025	15:23	29-09-2025	15:52	0:29	0.000089	REPLACEMENT OF LT BUSHING
295	29-09-2025	Part of : BLOCK D SANGAM VIHAR	1384	Other Outage	Planned Outage	29-09-2025	11:14	29-09-2025	13:03	1:49	0.000333	REPLACEMET OF HT BUSHING
296	29-09-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR	3698	Other Outage	Planned Outage	29-09-2025	10:32	29-09-2025	12:01	1:29	0.000272	3PH HT AB CABLE REPLACEMENT
297	29-09-2025	Part of : KHANPUR VILLAGE	1744	Other Outage	Planned Outage	29-09-2025	11:20	29-09-2025	13:59	2:39	0.000486	CONDUCTOR REPLACEMENT
298	29-09-2025	Part of : JAWAHAR PARK SANGAM VIHAR, POCKET C JAWAHAR PARK KHANPUR	101	Other Outage	Planned Outage	29-09-2025	10:57	29-09-2025	13:05	2:08	0.000391	3PH HT AB CABLE REPLACEMENT
299	29-09-2025	Part of : BLOCK C PULPEHLADPUR	821	Other Outage	Planned Outage	29-09-2025	10:57	29-09-2025	14:31	3:34	0.000654	3PH HT AB CABLE REPLACEMENT
300	30-09-2025	Part of : RPS COLONY MADANGIR, POCKET A DUGGAL COLONY KHANPUR, KHANPUR EXTENSION, KHANPUR VILLAGE	1560	Other Outage	Unplanned Outage	30-09-2025	14:53	30-09-2025	15:27	0:34	0.000293	HT SYSTEM FAULT
301	30-09-2025	Part of : POCKET A, D & E JAWAHAR PARK KHANPUR, DEOLI GAON NAI BASTI SANGAM VIHAR	855	Other Outage	Planned Outage	30-09-2025	11:02	30-09-2025	11:54	0:52	0.000159	3PH HT AB END TERMINATION REPLACEMENT
302	30-09-2025	Part of : BLOCK B & C DEVL SANGAM VIHAR	1	Other Outage	Planned Outage	30-09-2025	11:15	30-09-2025	12:55	1:40	0.000306	3PH HT AB CABLE REPLACEMENT PER SPAN
303	30-09-2025	Part of : BLOCK L 2 DEVL SANGAM VIHAR	908	Other Outage	Planned Outage	30-09-2025	10:58	30-09-2025	13:09	2:11	0.000400	REPLACEMET OF HT BUSHING ROD
304	03-09-2025	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR,	30	Other Outage	Planned Outage	03-09-2025	11:50	03-09-2025	12:42	0:52	0.000144	HT O/H CIRCUIT MAINTENANCE
305	06-09-2025	Part of : BHARAT NAGAR NEW FRIENDS COLONY, BLOCK A-1 & B MAHARANI BAGH, BLOCK C & D NEW FRIENDS COLONY EAST	1313	Other Outage	Unplanned Outage	06-09-2025	00:02	06-09-2025	00:25	0:23	0.000351	CABLE FAULT
306	06-09-2025	Part of : ISWAR NAGAR NEW FRIENDS COLONY	8	Other Outage	Planned Outage	06-09-2025	11:16	06-09-2025	12:38	1:22	0.000228	CLEANING OF INSULATORS PER POLE, JUMPER REPLACEMENT PER POLE, REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN, TAPPING OF JUMPERS, TAPPING OF UG CABLE TO OH JUMPER CONNECTION
307	08-09-2025	Part of : BLOCK C JOGA BAI EXTENSION OKHLA	1146	Other Outage	Unplanned Outage	08-09-2025	12:50	08-09-2025	13:20	0:30	0.000342	CABLE FAULT
308	08-09-2025	Part of : POCKET 10B JASOLA VIHAR	320	Other Outage	Planned Outage	08-09-2025	11:20	08-09-2025	13:14	1:54	0.001742	REPLACEMET OF HT BUSHING ROD
309	08-09-2025	Part of : JOGA BAI OKHLA	2896	Other Outage	Planned Outage	08-09-2025	13:02	08-09-2025	16:15	3:13	0.002413	REPLACEMENT OF LT BUSHING ROD
310	08-09-2025	Part of : ISWAR NAGAR NEW FRIENDS COLONY	72	Other Outage	Planned Outage	08-09-2025	11:18	08-09-2025	16:14	4:56	0.000822	CLEANING OF INSULATORS PER POLE, JUMPER REPLACEMENT PER POLE, REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
311	09-09-2025	Part of : POCKET 2 JASOLA VIHAR	79	Other Outage	Planned Outage	09-09-2025	10:59	09-09-2025	13:29	2:30	0.002292	REPLACEMET OF HT BUSHING ROD
312	10-09-2025	Part of : JOGA BAI OKHLA	2791	Other Outage	Planned Outage	10-09-2025	13:07	10-09-2025	16:10	3:03	0.002135	REPLACEMENT OF LT BUSHING ROD
313	11-09-2025	Part of : POCKET 2 JASOLA VIHAR,	159	Other Outage	Planned Outage	11-09-2025	11:23	11-09-2025	13:58	2:35	0.002368	REPLACEMENT OF LT BUSHING ROD
314	11-09-2025	Part of : OKHLA DISPOSAL AREA JASOLA VIHAR,	37	Other Outage	Planned Outage	11-09-2025	11:07	11-09-2025	13:46	2:39	0.000442	CHECKING OF EARTHING VALUE USING ONLINE TESTER,TAPPING OF JUMPERS ,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
315	13-09-2025	Part of : A & C-BLOCK SHAHEEN BAGH JASOLA VIHAR	3079	Other Outage	Unplanned Outage	13-09-2025	22:59	13-09-2025	23:35	0:36	0.001520	CABLE FAULT
316	13-09-2025	Part of : AZIM DAIRY OKHLA	1345	Other Outage	Planned Outage	13-09-2025	12:55	13-09-2025	16:36	3:41	0.002701	REPLACEMET OF HT BUSHING ROD
317	13-09-2025	Part of : JASOLA VIHAR	7	Other Outage	Planned Outage	13-09-2025	11:38	13-09-2025	13:45	2:07	0.001588	REPLACEMET OF HT BUSHING ROD
318	13-09-2025	Part of : ISWAR NAGAR NEW FRIENDS COLONY	48	Other Outage	Planned Outage	13-09-2025	11:27	13-09-2025	14:34	3:07	0.000519	CHECKING OF EARTHING VALUE USING ONLINE TESTER
319	14-09-2025	Part of : GAFOOR NAGAR OKHLA, JOGA BAI OKHLA	2623	Other Outage	Unplanned Outage	14-09-2025	12:05	14-09-2025	12:43	0:38	0.000918	CABLE FAULT
320	15-09-2025	Part of : BLOCK B JOGA BAI EXTENSION JOGA BAI OKHLA,BLOCK R JOGA BAI OKHLA	3500	Other Outage	Unplanned Outage	15-09-2025	09:44	15-09-2025	10:08	0:24	0.001060	CABLE FAULT
321	15-09-2025	Part of : SUKHDEV VIHAR OKHLA,	221	Other Outage	Planned Outage	15-09-2025	11:11	15-09-2025	12:29	1:18	0.000217	CLEANING OF INSULATORS PER POLE,JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TAPPING OF UG CABLE TO OH JUMPER CONNECTION
322	15-09-2025	Part of : POCKET 11 JASOLA VIHAR,	903	Other Outage	Planned Outage	15-09-2025	11:17	15-09-2025	13:40	2:23	0.002185	REPLACEMET OF HT BUSHING ROD
323	16-09-2025	Part of : AZIM DAIRY OKHLA	1155	Other Outage	Planned Outage	16-09-2025	13:03	16-09-2025	16:20	3:17	0.002298	REPLACEMET OF HT BUSHING ROD
324	17-09-2025	Part of : C-BLOCK OKHLA VIHAR JAMIA NAGAR	1530	Other Outage	Planned Outage	17-09-2025	11:02	17-09-2025	13:36	2:34	0.002353	REPLACEMENT OF HT BUSHING ROD
325	18-09-2025	Part of : CRRRI SUKHDEV VIHAR OKHLA	81	Other Outage	Planned Outage	18-09-2025	11:05	18-09-2025	12:31	1:26	0.000239	CLEANING OF INSULATORS PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS ,TAPPING OF UG CABLE TO OH JUMPER CONNECTION,TIGHTENING OF HARDWARE FITTINGS
326	18-09-2025	Part of : BLOCK B JOGA BAI EXTENSION OKHLA	935	Other Outage	Planned Outage	18-09-2025	13:08	18-09-2025	16:18	3:10	0.001583	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
327	19-09-2025	Part of : BLOCK R JOGA BAI OKHLA	4581	Other Outage	Unplanned Outage	19-09-2025	11:20	19-09-2025	11:56	0:36	0.001420	CABLE FAULT
328	20-09-2025	Part of : Batla House Okhla,	1785	Other Outage	Planned Outage	20-09-2025	13:08	20-09-2025	16:46	3:38	0.003331	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
329	20-09-2025	Part of : Block E Shaheen Bagh Jasola Vihar,	480	Other Outage	Planned Outage	20-09-2025	11:07	20-09-2025	13:27	2:20	0.001750	REPLACEMET OF HT BUSHING ROD
330	22-09-2025	Part of : VILLAGE JASOLA JASOLA VIHAR, URDU BHAWAN (HTC), PURBANCHAL S WELFRE PLT-6 FC33 JASOLA (HTC)	760	Other Outage	Unplanned Outage	22-09-2025	16:47	22-09-2025	17:15	0:28	0.000179	CABLE FAULT
331	22-09-2025	Part of : BLOCK C JOGA BAI EXTENSION OKHLA	3957	Other Outage	Planned Outage	22-09-2025	13:02	22-09-2025	16:23	3:21	0.003350	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
332	22-09-2025	Part of : VILLAGE JASOLA JASOLA VIHAR	291	Other Outage	Planned Outage	22-09-2025	11:03	22-09-2025	13:51	2:48	0.002567	REPLACEMET OF HT BUSHING ROD
333	23-09-2025	Part of : BLOCK R JOGA BAI OKHLA,	2566	Other Outage	Planned Outage	23-09-2025	13:03	23-09-2025	16:22	3:19	0.002211	REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
334	24-09-2025	Part of : NEW FRIENDS COLONY EAST	15	Other Outage	Planned Outage	24-09-2025	11:18	24-09-2025	13:48	2:30	0.000417	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,JUMPER REPLACEMENT PER POLE,TAPPING OF JUMPERS
335	24-09-2025	Part of : POCKET 7 JASOLA VIHAR	226	Other Outage	Planned Outage	24-09-2025	11:01	24-09-2025	13:13	2:12	0.001650	REPLACEMENT OF HT BUSHING ROD
336	25-09-2025	Part of : BLOCK B JOGA BAI EXTENSION OKHLA	1471	Other Outage	Planned Outage	25-09-2025	13:13	25-09-2025	16:21	3:08	0.002089	REPLACEMENT OF HT/LT CLEATS
337	27-09-2025	Part of : SARAI JALINA OKHLA,ISWAR NAGAR NEW FRIENDS COLONY	1557	Other Outage	Unplanned Outage	27-09-2025	13:26	27-09-2025	13:59	0:33	0.000477	HT SYSTEM FAULT
338	27-09-2025	Part of : BATLA HOUSE OKHLA,	1546	Other Outage	Planned Outage	27-09-2025	13:07	27-09-2025	16:19	3:12	0.002133	REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
339	27-09-2025	Part of : BLOCK J PART 1 ABUL FAZAL ENCLAVE JAMIA NAGAR OKHLA,	962	Other Outage	Planned Outage	27-09-2025	10:15	27-09-2025	12:32	2:17	0.001979	REPLACEMENT OF LT BUSHING ROD
340	29-09-2025	Part of : BLOCK B SHAHEEN BAGH JASOLA VIHAR	776	Other Outage	Planned Outage	29-09-2025	10:29	29-09-2025	12:27	1:58	0.001704	REPLACEMENT OF LT BUSHING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
341	30-09-2025	Part of : BLOCK E SHAHEEN BAGH JASOLA VIHAR	1006	Other Outage	Planned Outage	30-09-2025	10:16	30-09-2025	12:08	1:52	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,REPLACEMET OF HT BUSHING ROD
342	02-09-2025	Part of : POCKET D & W OKHLA PHASE II OKHLA INDUSTRIAL AREA	717	Other Outage	Unplanned Outage	02-09-2025	05:38	02-09-2025	06:23	0:45	0.000238	HT SYSTEM FAULT
343	02-09-2025	Part of : POCKET B,D & S OKHLA PHASE II OKHLA INDUSTRIAL AREA	262	Other Outage	Unplanned Outage	02-09-2025	04:12	02-09-2025	04:53	0:41	0.000513	HT SYSTEM FAULT
344	03-09-2025	Part of : POCKET D OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET B OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET E OKHLA PHASE II OKHLA INDUSTRIAL AREA	375	Other Outage	Unplanned Outage	03-09-2025	08:55	03-09-2025	09:36	0:41	0.000171	TRANSIENT FAULT
345	04-09-2025	Part of : KRISHI VIHAR GREATER KAILASH,SIRI FORT,MASJID MOTH PHASE I GREATER KAILASH	982	Other Outage	Unplanned Outage	04-09-2025	05:20	04-09-2025	06:07	0:47	0.000170	HT SYSTEM FAULT
346	06-09-2025	Part of : DEVIKA TOWER NEHRU PLACE, BUILDING NO.- 20 & 28 NEHRU PLACE, PARAS CINEMA NEHRU PLACE (HTC)	413	Other Outage	Unplanned Outage	06-09-2025	00:17	06-09-2025	01:05	0:48	0.000307	TREE BRANCH FALLEN ON TRANSFORMER
347	07-09-2025	Part of : HARKESH NAGAR OKHLA INDUSTRIAL AREA,POCKET Z OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET A SANJAY COLONY II OKHLA PHASE II OKHLA INDUSTRIAL AREA,POCKET Y SANJAY COLONY II OKHLA PHASE II OKHLA INDUSTRIAL AREA	4105	Other Outage	Unplanned Outage	07-09-2025	21:17	07-09-2025	22:06	0:49	0.000449	CABLE FAULT
348	08-09-2025	Part of : NEHRU PLACE	65	Other Outage	Unplanned Outage	08-09-2025	21:44	08-09-2025	22:27	0:43	0.000084	HT SYSTEM FAULT
349	08-09-2025	Part of : BLOCK W GREATER KAILASH I	86	Other Outage	Planned Outage	08-09-2025	11:56	08-09-2025	16:09	4:13	0.003654	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE
350	08-09-2025	Part of : BLOCK D EAST OF KAILASH	467	Other Outage	Planned Outage	08-09-2025	10:06	08-09-2025	16:15	6:09	0.005330	APPLY OF INSULATION TAPE HT/LT BUSHINGS
351	09-09-2025	Part of : POCKET B,D & S-OKHLA INDUSTRIAL AREA PHASE-2	262	Other Outage	Unplanned Outage	09-09-2025	15:57	09-09-2025	16:44	0:47	0.001567	BIRDAGR
352	09-09-2025	Part of : F-BLOCK EAST OF KAILASH	189	Other Outage	Planned Outage	09-09-2025	09:59	09-09-2025	14:03	4:04	0.003524	APPLY OF INSULATION TAPE HT/LT BUSHINGS
353	10-09-2025	Part of : POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA	91	Other Outage	Unplanned Outage	10-09-2025	14:55	10-09-2025	16:23	1:28	0.000000	MAKING OF END TERMINATION
354	10-09-2025	Part of : BLOCK E EAST OF KAILASH	113	Other Outage	Planned Outage	10-09-2025	10:11	10-09-2025	12:07	1:56	0.001676	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
355	10-09-2025	Part of : BLOCK H KAILASH COLONY GREATER KAILASH	109	Other Outage	Planned Outage	10-09-2025	10:58	10-09-2025	15:15	4:17	0.003712	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
356	12-09-2025	Part of : BLOCK W GREATER KAILASH I	194	Other Outage	Planned Outage	12-09-2025	11:01	12-09-2025	16:15	5:14	0.004536	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
357	12-09-2025	Part of : BLOCK C AMAR COLONY LAJPAT NAGAR	544	Other Outage	Planned Outage	12-09-2025	10:07	12-09-2025	13:55	3:48	0.003293	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING
358	13-09-2025	Part of : FACTORY NO- 239,P.R.INDUSTRIES PVT.LTD, 237,VASDEV LOOND -238 OKHLA PHASE-3 (HT CONSUMER)	4	Other Outage	Unplanned Outage	13-09-2025	13:24	13-09-2025	14:09	0:45	0.000000	FAULT IN HT CONSUMER PANEL (P.R.INDUSTRIES PVT.LTD)
359	13-09-2025	Part of : BLOCK B DAYANAND COLONY LAJPAT NAGAR	448	Other Outage	Planned Outage	13-09-2025	09:58	13-09-2025	11:16	1:18	0.001127	APPLY OF INSULATION TAPE HT BUSHINGS,CHECKING OF EARTHING
360	14-09-2025	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA	21	Other Outage	Unplanned Outage	14-09-2025	13:08	14-09-2025	13:51	0:43	0.000119	FAULT IN HT CONSUMER PANEL (BUILDING NO 219)
361	14-09-2025	Part of : BLOCK 9 KALKAJI	68	Other Outage	Planned Outage	14-09-2025	11:02	14-09-2025	14:48	3:46	0.001883	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD
362	15-09-2025	Part of : BLOCK B ZAMRUPUR VILLAGE GREATER KAILASH,	150	Other Outage	Planned Outage	15-09-2025	11:02	15-09-2025	15:57	4:55	0.004261	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
363	15-09-2025	Part of : SANT NAGAR EAST OF KAILASH,	503	Other Outage	Planned Outage	15-09-2025	10:08	15-09-2025	12:59	2:51	0.002470	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
364	16-09-2025	Part of : BLOCK K LAJPAT NAGAR IV LAJPAT NAGAR	814	Other Outage	Planned Outage	16-09-2025	09:59	16-09-2025	14:04	4:05	0.003539	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
365	17-09-2025	Part of : GARHI JHARIA MARIA EAST OF KAILASH	327	Other Outage	Planned Outage	17-09-2025	09:58	17-09-2025	14:00	4:02	0.003496	APPLY OF INSULATION TAPE HT/LT BUSHINGS
366	18-09-2025	Part of : BLOCK A APB GARHI EAST OF KAILASH	359	Other Outage	Planned Outage	18-09-2025	10:12	18-09-2025	13:58	3:46	0.003264	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
367	19-09-2025	Part of : BLOCK M KAILASH COLONY GREATER KAILASH,	67	Other Outage	Planned Outage	19-09-2025	11:04	19-09-2025	16:38	5:34	0.004824	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
368	20-09-2025	Part of : Sant Nagar East Of Kailash,	391	Other Outage	Planned Outage	20-09-2025	10:08	20-09-2025	14:02	3:54	0.003380	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF LUGS,SUB STATION CLEANING
369	21-09-2025	Part of : OKHLA INDUSTRIAL AREA PHASE III	35	Other Outage	Planned Outage	21-09-2025	10:59	21-09-2025	13:54	2:55	0.000000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
370	22-09-2025	Part of : BLOCK B ZAMRUDPUR VILLAGE GREATER KAILASH	630	Other Outage	Planned Outage	22-09-2025	11:02	22-09-2025	16:21	5:19	0.004608	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMET OF LUGS,SUB STATION CLEANING
371	22-09-2025	Part of : BLOCK Q LAJPAT NAGAR IV	484	Other Outage	Planned Outage	22-09-2025	09:59	22-09-2025	14:06	4:07	0.003568	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
372	23-09-2025	Part of : BLOCK D EAST OF KAILASH,	91	Other Outage	Planned Outage	23-09-2025	10:01	23-09-2025	14:12	4:11	0.003626	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
373	24-09-2025	Part of : BLOCK C GREATER KAILASH I	206	Other Outage	Planned Outage	24-09-2025	11:03	24-09-2025	15:32	4:29	0.003886	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
374	24-09-2025	Part of : VIKRAM VIHAR LAJPAT NAGAR IV	286	Other Outage	Planned Outage	24-09-2025	10:01	24-09-2025	13:55	3:54	0.003380	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
375	25-09-2025	Part of : DEVIKA TOWER,D.D.A BUILDING,BUILDING NO.-20 & 28,PUMP HOUSE,PARAS CINEMA NEHRU PLACE	413	Other Outage	Unplanned Outage	25-09-2025	00:56	25-09-2025	01:42	0:46	0.000268	TREE TOUCHING
376	25-09-2025	Part of : VIKRAM VIHAR LAJPAT NAGAR-4	288	Other Outage	Planned Outage	25-09-2025	10:00	25-09-2025	13:58	3:58	0.003438	APPLY OF INSULATION TAPE HT/LT BUSHINGS
377	26-09-2025	Part of : BLOCK-A KAILASH COLONY GREATER KAILASH, BLOCK-E EAST OF KAILASH, BLOCK N GREATER KAILASH I, KALASH ENCLAVE GREATER KAILASH	2166	Other Outage	Unplanned Outage	26-09-2025	14:14	26-09-2025	15:01	0:47	0.001123	CABLE FAULT
378	26-09-2025	Part of : BLOCK M KAILASH COLONY GREATER KAILASH	242	Other Outage	Planned Outage	26-09-2025	10:59	26-09-2025	15:45	4:46	0.004131	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
379	27-09-2025	Part of : NEHRU PLACE	628	Other Outage	Unplanned Outage	27-09-2025	18:57	27-09-2025	19:38	0:41	0.001082	HT SYSTEM FAULT
380	27-09-2025	Part of : BLOCK A OKHLA PHASE II OKHLA INDUSTRIAL AREA	96	Other Outage	Unplanned Outage	27-09-2025	09:46	27-09-2025	10:29	0:43	0.000358	TREE BRANCH FALLEN ON TRANSFORMER
381	28-09-2025	Part of : OKHLA PHASE III OKHLA INDUSTRIAL AREA,BLOCK G KAILASH HILL EAST OF KAILASH	184	Other Outage	Unplanned Outage	28-09-2025	10:32	28-09-2025	13:44	3:12	0.001067	REPAIRING OF RMU
382	28-09-2025	Part of : POCKET W OKHLA PHASE II OKHLA INDUSTRIAL AREA	54	Other Outage	Planned Outage	28-09-2025	11:01	28-09-2025	14:01	3:00	0.002000	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE
383	30-09-2025	Part of : POCKET C OKHLA PHASE II OKHLA INDUSTRIAL AREA	313	Other Outage	Unplanned Outage	30-09-2025	13:26	30-09-2025	14:27	1:01	0.001898	CABLE FAULT
384	02-09-2025	Part of : ISBT SARAI KALE KHAN, BLOCK A GANGA VIHAR, CNG FILLING STN (HTC), L&T NEAR POWER GRID (HTC), IGL SARAI KALE KHAN (HTC)	13	Other Outage	Unplanned Outage	02-09-2025	05:01	02-09-2025	05:36	0:35	0.000681	HT SYSTEM FAULT
385	03-09-2025	Part of : BLOCK C JUNG PURA B JANG PURA,BLOCK B JUNG PURA B JANG PURA,BLOCK A NIZAMUDDIN WEST	2498	Other Outage	Unplanned Outage	03-09-2025	17:45	03-09-2025	18:35	0:50	0.000736	HT SYSTEM FAULT
386	08-09-2025	Part of : BLOCK B, E, F & M SEWA NAGAR,KASTURBA NAGAR SEWA NAGAR	3003	Other Outage	Unplanned Outage	08-09-2025	19:32	08-09-2025	20:21	0:49	0.000150	CABLE DAMAGED BY OUTSIDE AGENCY (ITDC)
387	09-09-2025	Part of : PUMPING RING ROAD KILOKARI (HT CONSUMER)	0	Other Outage	Unplanned Outage	09-09-2025	11:11	09-09-2025	12:05	0:54	0.000585	FAULT IN HT CONSUMER PANEL (SEWAGE PUMPING STATION)
388	10-09-2025	Part of : BLOCK F LAJPAT NAGAR II LAJPAT NAGAR	1608	Other Outage	Planned Outage	10-09-2025	12:23	10-09-2025	16:05	3:42	0.004317	REPLACEMET OF HT BUSHING ROD
389	10-09-2025	Part of : BLOCK A DEFENCE COLONY	504	Other Outage	Planned Outage	10-09-2025	11:57	10-09-2025	15:11	3:14	0.001347	REPLACEMET OF HT BUSHING ROD
390	10-09-2025	Part of : BEHLOLPUR BANGAR SARAI KALE KHAN	1021	Other Outage	Planned Outage	10-09-2025	11:32	10-09-2025	15:09	3:37	0.001808	REPLACEMET OF HT BUSHING ROD
391	10-09-2025	Part of : BLOCK H JANGUPURA EXTENSION	209	Other Outage	Planned Outage	10-09-2025	11:57	10-09-2025	14:59	3:02	0.001011	REPLACEMENT OF LT BUSHING ROD
392	11-09-2025	Part of : HTC:PWD UNDERPASS,AB-1,NR PRAGATI POWER	0	Other Outage	Unplanned Outage	11-09-2025	17:47	11-09-2025	18:28	0:41	0.000091	CABLE FAULT
393	11-09-2025	Part of : NATIONAL ZOOLOGICAL PARK SUNDAR NAGAR,SUNDAR NAGAR	209	Other Outage	Unplanned Outage	11-09-2025	16:20	11-09-2025	17:29	1:09	0.000460	CABLE FAULT
394	11-09-2025	Part of : PRAGATI VIHAR,	1040	Other Outage	Unplanned Outage	11-09-2025	11:56	11-09-2025	12:53	0:57	0.000190	TO CHECK PROTECTION CIRCUIT
395	11-09-2025	Part of : BLOCK A SARAI KALE KHAN,	362	Other Outage	Planned Outage	11-09-2025	11:09	11-09-2025	15:45	4:36	0.001150	REPLACEMET OF HT BUSHING ROD
396	11-09-2025	Part of : BLOCK D JANGUPURA EXTENSION JANGPURA,	345	Other Outage	Planned Outage	11-09-2025	10:49	11-09-2025	15:47	4:58	0.002483	REPLACEMET OF HT BUSHING ROD
397	11-09-2025	Part of : BLOCK H LAJPAT NAGAR II LAJPAT NAGAR,BLOCK L LAJPAT NAGAR II LAJPAT NAGAR,	783	Other Outage	Planned Outage	11-09-2025	10:58	11-09-2025	15:53	4:55	0.000983	REPLACEMET OF HT BUSHING ROD
398	12-09-2025	Part of : BLOCK D DEFENCE COLONY	1184	Other Outage	Unplanned Outage	12-09-2025	23:18	12-09-2025	23:59	0:41	0.000638	CABLE FAULT
399	12-09-2025	Part of : PANT NAGAR JANGPURA	829	Other Outage	Planned Outage	12-09-2025	11:07	12-09-2025	15:18	4:11	0.001394	REPLACEMET OF HT BUSHING ROD
400	12-09-2025	Part of : BLOCK D DEFENCE COLONY	86	Other Outage	Planned Outage	12-09-2025	11:12	12-09-2025	15:16	4:04	0.001356	REPLACEMET OF HT BUSHING ROD
401	13-09-2025	Part of : BLOCK N SOUTH EXTENSION PART 1	259	Other Outage	Planned Outage	13-09-2025	10:56	13-09-2025	15:12	4:16	0.001067	REPLACEMET OF HT BUSHING ROD
402	13-09-2025	Part of : SUNLIGHT COLONY	1678	Other Outage	Planned Outage	13-09-2025	11:00	13-09-2025	15:03	4:03	0.002025	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
403	15-09-2025	Part of : ISBT SARAI KALE KHAN SARAI KALE KHAN,BLOCK A GANGA VIHAR SARAI KALE KHAN	13	Other Outage	Unplanned Outage	15-09-2025	01:59	15-09-2025	02:55	0:56	0.001244	FAULT IN HT CONSUMER PANEL (DJB)
404	15-09-2025	Part of : BLOCK B GANGA VIHAR SARAI KALE KHAN,BLOCK A GANGA VIHAR SARAI KALE KHAN	209	Other Outage	Unplanned Outage	15-09-2025	22:50	15-09-2025	23:40	0:50	0.000181	FAULT IN HT CONSUMER PANEL (DTL BEHLOLPUR)
405	15-09-2025	Part of : BLOCK I LAJPAT NAGAR III LAJPAT NAGAR,	635	Other Outage	Planned Outage	15-09-2025	12:26	15-09-2025	15:50	3:24	0.001700	REPLACEMET OF HT BUSHING ROD
406	15-09-2025	Part of : ZAFAR NAGAR KOTLA MUBARAKPUR SOUTH EXTENSION PART 1,	825	Other Outage	Planned Outage	15-09-2025	10:54	15-09-2025	15:05	4:11	0.002092	REPLACEMET OF HT BUSHING ROD
407	16-09-2025	Part of : NATIONAL ZOOLOGICAL PARK SUNDAR NAGAR,NIZAMUDDIN WEST,BLOCK A NIZAMUDDIN WEST	3847	Other Outage	Unplanned Outage	16-09-2025	15:52	16-09-2025	16:46	0:54	0.002130	HT SYSTEM FAULT
408	16-09-2025	Part of : MAHAVEER NAGAR BHOLA NAGAR SOUTH EXTENSION PART 1,ARYA NAGAR KOTLA MUBARAKPUR SOUTH EXTENSION PART 1	5769	Other Outage	Unplanned Outage	16-09-2025	01:38	16-09-2025	02:16	0:38	0.003146	HT SYSTEM FAULT
409	16-09-2025	Part of : BLOCK A DEFENCE COLONY	1000	Other Outage	Unplanned Outage	16-09-2025	01:05	16-09-2025	01:50	0:45	0.003650	HT SYSTEM FAULT
410	16-09-2025	Part of : KOTLA MUBARAKPUR,SUKHDEV MARKET	3530	Other Outage	Unplanned Outage	16-09-2025	00:14	16-09-2025	01:05	0:51	0.003315	CABLE FAULT
411	16-09-2025	Part of : BLOCK M LAJPAT NAGAR III	379	Other Outage	Planned Outage	16-09-2025	12:15	16-09-2025	14:09	1:54	0.001267	REPLACEMENT OF LT BUSHING ROD
412	16-09-2025	Part of : RISHI NAGAR SOUTH EXTENSION PART 1	1521	Other Outage	Planned Outage	16-09-2025	12:45	16-09-2025	16:51	4:06	0.001640	CONDUCTOR REPLACEMENT PER SPAN
413	16-09-2025	Part of : BLOCK J SOUTH EXTENSION PART 1	26	Other Outage	Planned Outage	16-09-2025	11:33	16-09-2025	16:50	5:17	0.000704	REPLACEMET OF HT BUSHING ROD
414	16-09-2025	Part of : BLOCK J SOUTH EXTENSION PART 1	55	Other Outage	Planned Outage	16-09-2025	11:33	16-09-2025	16:49	5:16	0.000614	REPLACEMET OF HT BUSHING ROD
415	16-09-2025	Part of : BLOCK J SOUTH EXTENSION PART 1	86	Other Outage	Planned Outage	16-09-2025	11:32	16-09-2025	16:36	5:04	0.001267	REPLACEMET OF HT BUSHING ROD
416	17-09-2025	Part of : B & D-BLOCK SARAI KALE KHAN,A-BLOCK GANGA VIHAR	1737	Other Outage	Unplanned Outage	17-09-2025	22:44	17-09-2025	23:37	0:53	0.002046	FAULT IN HT CONSUMER PANEL (WONDER PARK)
417	17-09-2025	Part of : WAZIR NAGAR SOUTH EXTENSION PART 1,SHIV NAGAR KOTLA MUBARAKPUR SOUTH EXTENSION PART 1	3113	Other Outage	Unplanned Outage	17-09-2025	16:35	17-09-2025	17:42	1:07	0.001898	HT SYSTEM FAULT
418	17-09-2025	Part of : H-BLOCK LAJPAT NAGAR-2	781	Other Outage	Planned Outage	17-09-2025	11:58	17-09-2025	15:25	3:27	0.001725	REPLACEMENT OF LT BUSHING ROD
419	18-09-2025	Part of : BLOCK B & D SARAI KALE KHAN, SARAI KALE KHAN VILLAGE, BLOCK A GANGA VIHAR SARAI KALE KHAN, DDA SLUM QTRS. SARAI KALE KHAN	2696	Other Outage	Unplanned Outage	18-09-2025	15:06	18-09-2025	16:01	0:55	0.001513	HT SYSTEM FAULT
420	18-09-2025	Part of : BLOCK N SOUTH EXTENSION PART 1, WAZIR NAGAR SOUTH EXTENSION PART 1, B-BLOCK DEFENCE COLONY	1392	Other Outage	Unplanned Outage	18-09-2025	14:12	18-09-2025	14:55	0:43	0.001374	HT SYSTEM FAULT
421	18-09-2025	Part of : WAZIR NAGAR SOUTH EXTENSION PART 1	1998	Other Outage	Planned Outage	18-09-2025	11:27	18-09-2025	16:46	5:19	0.002658	REPLACEMET OF HT BUSHING ROD
422	18-09-2025	Part of : BLOCK M JANGUPURA EXTENSION	343	Other Outage	Planned Outage	18-09-2025	11:17	18-09-2025	14:42	3:25	0.002278	REPLACEMENT OF LT BUSHING ROD
423	19-09-2025	Part of : BLOCK H SOUTH EXTENSION PART 1,BLOCK C SOUTH EXTENSION PART 1,BLOCK G SOUTH EXTENSION PART 1	1818	Other Outage	Unplanned Outage	19-09-2025	03:19	19-09-2025	04:19	1:00	0.000967	FAULT IN HT CONSUMER PANEL (AAKASH EDU. SERVICES LTD)
424	19-09-2025	Part of : BLOCK L LAJPAT NAGAR III LAJPAT NAGAR,	400	Other Outage	Planned Outage	19-09-2025	12:28	19-09-2025	16:09	3:41	0.002210	REPLACEMET OF HT BUSHING ROD
425	19-09-2025	Part of : BLOCK D DEFENCE COLONY,	520	Other Outage	Planned Outage	19-09-2025	11:06	19-09-2025	15:39	4:33	0.002275	REPLACEMET OF HT BUSHING ROD
426	19-09-2025	Part of : KILOKARI PHASE 1 SUNLIGHT COLONY,	1003	Other Outage	Planned Outage	19-09-2025	11:29	19-09-2025	15:52	4:23	0.002192	REPLACEMET OF HT BUSHING ROD
427	20-09-2025	Part of : Block H Lajpat Nagar II Lajpat Nagar,Block L Lajpat Nagar II Lajpat Nagar	822	Other Outage	Unplanned Outage	20-09-2025	21:23	20-09-2025	22:08	0:45	0.000000	CABLE FAULT
428	20-09-2025	Part of : INA Type A Quarters INA Colony,	124	Other Outage	Planned Outage	20-09-2025	11:14	20-09-2025	14:38	3:24	0.001133	REPLACEMET OF HT BUSHING ROD
429	20-09-2025	Part of : Defence Colony Bhogal Jangpura,	950	Other Outage	Planned Outage	20-09-2025	10:58	20-09-2025	14:05	3:07	0.000000	REPLACEMET OF HT BUSHING ROD
430	21-09-2025	Part of : SIDDHARTHA ENCLAVE,SUNLIGHT COLONY	883	Other Outage	Unplanned Outage	21-09-2025	12:20	21-09-2025	13:25	1:05	0.001354	CABLE FAULT
431	22-09-2025	Part of : POCKET C SIDDHARTHA NAGAR, JANGPURA INDUSTRIAL AREA, SAM INDIA BUILTWELL PVT (HTC)	1000	Other Outage	Unplanned Outage	22-09-2025	01:47	22-09-2025	02:42	0:55	0.002551	CABLE FAULT
432	22-09-2025	Part of : PREM NAGAR BK DUTT COLONY	76	Other Outage	Planned Outage	22-09-2025	11:17	22-09-2025	15:15	3:58	0.001322	REPLACEMENT OF LT BUSHING ROD
433	22-09-2025	Part of : BLOCK I LAJPAT NAGAR II	620	Other Outage	Planned Outage	22-09-2025	10:57	22-09-2025	15:11	4:14	0.004233	REPLACEMENT OF LT BUSHING ROD
434	22-09-2025	Part of : BLOCK D SOUTH EXTENSION PART 1	104	Other Outage	Planned Outage	22-09-2025	10:58	22-09-2025	13:48	2:50	0.000944	REPLACEMENT OF LT BUSHING ROD
435	23-09-2025	Part of : BLOCK O VINOBA PURI LAJPAT NAGAR II LAJPAT NAGAR,	738	Other Outage	Planned Outage	23-09-2025	11:55	23-09-2025	15:19	3:24	0.005667	REPLACEMENT OF LT BUSHING ROD
436	23-09-2025	Part of : BLOCK B SARAI KALE KHAN,	1091	Other Outage	Planned Outage	23-09-2025	11:02	23-09-2025	15:00	3:58	0.006611	REPLACEMENT OF LT BUSHING ROD
437	23-09-2025	Part of : BLOCK B SOUTH EXTENSION PART 1,	878	Other Outage	Planned Outage	23-09-2025	11:03	23-09-2025	14:01	2:58	0.001286	REPLACEMET OF HT BUSHING ROD
438	24-09-2025	Part of : BLOCK 12 NEHRU NAGAR LAJPAT NAGAR	1182	Other Outage	Planned Outage	24-09-2025	11:24	24-09-2025	15:46	4:22	0.000873	DT REPLACEMENT
439	25-09-2025	Part of : ARJUN NAGAR KOTLA MUBARAKPUR SOUTH EXTENSION PART 1	1531	Other Outage	Planned Outage	25-09-2025	11:35	25-09-2025	16:08	4:33	0.003792	REPLACEMENT OF LT BUSHING ROD
440	25-09-2025	Part of : BHOGAL JANGPURA	710	Other Outage	Planned Outage	25-09-2025	10:52	25-09-2025	15:09	4:17	0.002856	REPLACEMET OF HT BUSHING ROD
441	25-09-2025	Part of : NEHRU NAGAR LAJPAT NAGAR	685	Other Outage	Planned Outage	25-09-2025	10:54	25-09-2025	15:34	4:40	0.003111	REPLACEMET OF HT BUSHING ROD
442	27-09-2025	Part of : HARI NAGAR ASHRAM,	1944	Other Outage	Planned Outage	27-09-2025	12:11	27-09-2025	15:44	3:33	0.001657	REPLACEMET OF HT BUSHING ROD
443	27-09-2025	Part of : BLOCK C 2 LODI COLONY,	297	Other Outage	Planned Outage	27-09-2025	11:07	27-09-2025	15:13	4:06	0.000820	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
444	28-09-2025	Part of : BLOCK H & L LAJPAT NAGAR II	822	Other Outage	Unplanned Outage	28-09-2025	13:17	28-09-2025	14:09	0:52	0.000000	HVDS FAULT
445	29-09-2025	Part of : BLOCK B LAJPAT NAGAR I	966	Other Outage	Planned Outage	29-09-2025	10:54	29-09-2025	13:59	3:05	0.005139	REPLACEMET OF HT BUSHING
446	29-09-2025	Part of : RAILWAY STATION LAJPAT NAGAR	412	Other Outage	Planned Outage	29-09-2025	10:58	29-09-2025	14:01	3:03	0.005083	REPLACEMET OF HT BUSHING
447	01-09-2025	Part of : N.I.F.P.H., FAMILY PLANNING MUNIRKA (HT CONSUMER)	1	Other Outage	Planned Outage	01-09-2025	16:56	01-09-2025	17:30	0:34	0.000142	RMU RELAY REPLACEMET/VPI/FPI
448	03-09-2025	Part of : BLOCK B MOTI BAGH SOUTH,SECTOR 3 SHANTI NIKETAN,SECTOR 4 SHANTI NIKETAN,BLOCK C MOTI BAGH SOUTH MARKET MOTI BAGH SOUTH,BLOCK E MOTI BAGH SOUTH,BLOCK I MOTI BAGH SOUTH	2104	Other Outage	Unplanned Outage	03-09-2025	07:17	03-09-2025	08:06	0:49	0.000858	CABLE FAULT
449	03-09-2025	Part of : JHARERA VILLAGE ASMARALINES DELHI CANTONMENT,	471	Other Outage	Planned Outage	03-09-2025	10:58	03-09-2025	14:31	3:33	0.000710	TRANSFORMER MAINTENANCE
450	05-09-2025	Part of : MTNL (PLOT NO.-8) B.C.PLACE (HT CONSUMER)	0	Other Outage	Unplanned Outage	05-09-2025	03:23	05-09-2025	04:05	0:42	0.000070	FAULT IN HT CONSUMER PANEL (M.T.N.L)
451	05-09-2025	Part of : MTNL (PLOT NO.-8) B.C.PLACE (HT CONSUMER)	0	Other Outage	Unplanned Outage	05-09-2025	00:32	05-09-2025	01:33	1:01	0.000102	FAULT IN HT CONSUMER PANEL (M.T.N.L)
452	06-09-2025	Part of : INDIAN AIR LINES AND AIR INDIA ESTATE VASANT VIHAR	915	Other Outage	Planned Outage	06-09-2025	11:04	06-09-2025	15:01	3:57	0.004608	DT REPLACEMENT
453	06-09-2025	Part of : SOUTH CAMPUS MOTI BAGH SOUTH	1	Other Outage	Planned Outage	06-09-2025	11:01	06-09-2025	14:07	3:06	0.000103	DT REPLACEMENT,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMET OF LUGS,SUB STATION CLEANING
454	06-09-2025	Part of : BHIKAJI CAMA PLACE RAMAKRISHNA PURAM	19	Other Outage	Planned Outage	06-09-2025	11:14	06-09-2025	13:48	2:34	0.001069	DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
455	07-09-2025	Part of : RAMA COLONY RAMAKRISHNA PURAM,EAST BLOCK RAMAKRISHNA PURAM,SECTOR 1 RAMAKRISHNA PURAM,MOHAMMADPUR RAMAKRISHNA PURAM	3919	Other Outage	Unplanned Outage	07-09-2025	00:17	07-09-2025	01:06	0:49	0.000776	CABLE FAULT
456	08-09-2025	Part of : POLICE COLONY SECTOR 12 RAMAKRISHNA PURAM	105	Other Outage	Planned Outage	08-09-2025	10:22	08-09-2025	13:26	3:04	0.000767	DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
457	09-09-2025	Part of : JHARERA VILLAGE ASMARALINES DELHI CANTONMENT	425	Other Outage	Planned Outage	09-09-2025	11:05	09-09-2025	14:13	3:08	0.000679	CHECKING VALUE OF FENCING EARTHING,DT REPLACEMENT
458	09-09-2025	Part of : A-BLOCK VASANT VIHAR	321	Other Outage	Planned Outage	09-09-2025	11:05	09-09-2025	15:01	3:56	0.004589	DT REPLACEMENT
459	09-09-2025	Part of : NIVEDITA KUNJ SECTOR 10 RAMAKRISHNA PURAM	129	Other Outage	Planned Outage	09-09-2025	10:32	09-09-2025	13:41	3:09	0.000788	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
460	10-09-2025	Part of : SUBROTO PARK, RK PURAM, MES SUBROTO PARK (HTC)	2697	Other Outage	Unplanned Outage	10-09-2025	07:26	10-09-2025	08:11	0:45	0.001088	CABLE FAULT
461	10-09-2025	Part of : SUBROTO PARK	4	Other Outage	Planned Outage	10-09-2025	13:57	10-09-2025	16:31	2:34	0.000257	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET
462	11-09-2025	Part of : BLOCK B VASANT VIHAR,	273	Other Outage	Planned Outage	11-09-2025	11:03	11-09-2025	15:38	4:35	0.004583	APPLY OF INSULATION TAPE HT/LT BUSHINGS,MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
463	11-09-2025	Part of : KD COLONY SECTOR 12 RAMAKRISHNA PURAM,	1220	Other Outage	Planned Outage	11-09-2025	10:14	11-09-2025	14:01	3:47	0.002018	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
464	12-09-2025	Part of : JHARERA VILLAGE ASMARA LINES DELHI CANTONMENT	325	Other Outage	Planned Outage	12-09-2025	10:54	12-09-2025	14:44	3:50	0.000831	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
465	12-09-2025	Part of : SOM VIHAR RAMAKRISHNA PURAM,NIVEDITA KUNJ SECTOR 7 & 10 RAMAKRISHNA PURAM	1007	Other Outage	Planned Outage	12-09-2025	10:27	12-09-2025	13:32	3:05	0.001799	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT
466	13-09-2025	Part of : BLOCK B VASANT VIHAR	242	Other Outage	Planned Outage	13-09-2025	11:06	13-09-2025	15:11	4:05	0.006465	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
467	13-09-2025	Part of : SOUTH CAMPUS MOTI BAGH SOUTH	4	Other Outage	Planned Outage	13-09-2025	11:02	13-09-2025	15:10	4:08	0.000344	CHECKING VALUE OF FENCING EARTHING,DT REPLACEMENT
468	13-09-2025	Part of : BHIKAJI CAMA PLACE RAMAKRISHNA PURAM	99	Other Outage	Planned Outage	13-09-2025	11:02	13-09-2025	13:08	2:06	0.000875	APPLY OF INSULATION TAPE HT BUSHINGS,DT REPLACEMENT
469	15-09-2025	Part of : SECTOR 3 RAMAKRISHNA PURAM,	908	Other Outage	Planned Outage	15-09-2025	10:45	15-09-2025	14:11	3:26	0.001144	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
470	16-09-2025	Part of : BLOCK C VASANT VIHAR	199	Other Outage	Planned Outage	16-09-2025	11:06	16-09-2025	15:13	4:07	0.004803	CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS
471	16-09-2025	Part of : JHARERA VILLAGE ASMARA LINES DELHI CANTONMENT	351	Other Outage	Planned Outage	16-09-2025	11:03	16-09-2025	15:06	4:03	0.000878	CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS
472	16-09-2025	Part of : WEST BLOCK RAMAKRISHNA PURAM	860	Other Outage	Planned Outage	16-09-2025	10:49	16-09-2025	13:39	2:50	0.001889	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
473	17-09-2025	Part of : SUBROTO PARK	7	Other Outage	Planned Outage	17-09-2025	11:11	17-09-2025	12:15	1:04	0.000124	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
474	18-09-2025	Part of : RBI COLONY SECTOR 6 RAMAKRISHNA PURAM	438	Other Outage	Planned Outage	18-09-2025	10:44	18-09-2025	13:03	2:19	0.001544	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
475	19-09-2025	Part of : SECTOR 7 RAMAKRISHNA PURAM,	416	Other Outage	Planned Outage	19-09-2025	14:24	19-09-2025	17:49	3:25	0.001139	INSTALLATION OF BUS BAR,REPLACEMENT OF GAS KIT AND OIL SEAL
476	19-09-2025	Part of : HTC:MES B.I.LINES	1	Other Outage	Planned Outage	19-09-2025	11:57	19-09-2025	15:13	3:16	0.000218	CLEANING OF INSULATORS PER POLE,JUMPER REPLACEMENT PER POLE,REPLACEMENT OF CROSS-ARMS AND POLES
477	19-09-2025	Part of : BLOCK E VASANT VIHAR,BLOCK A VASANT VIHAR,BLOCK F VASANT VIHAR,	903	Other Outage	Planned Outage	19-09-2025	11:57	19-09-2025	16:16	4:19	0.005756	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
478	19-09-2025	Part of : SECTOR 1 RAMAKRISHNA PURAM,	1370	Other Outage	Planned Outage	19-09-2025	10:51	19-09-2025	13:20	2:29	0.001863	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
479	19-09-2025	Part of : BHIKAJI CAMA PLACE RAMAKRISHNA PURAM,	6	Other Outage	Planned Outage	19-09-2025	10:54	19-09-2025	13:22	2:28	0.001028	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
480	20-09-2025	Part of : HTC:RAMLAL ANAND & ARYABHATTA COLLEGE	2	Other Outage	Planned Outage	20-09-2025	11:05	20-09-2025	12:54	1:49	0.000394	CLEANING OF HT BUSHING PER WAY,RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
481	20-09-2025	Part of : Block B Vasant Vihar,	273	Other Outage	Planned Outage	20-09-2025	11:11	20-09-2025	15:00	3:49	0.000000	CHECKING VALUE OF FENCING EARTHING,DT REPLACEMENT,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
482	20-09-2025	Part of : Mohammadpur Ramakrishna Puram,	3	Other Outage	Planned Outage	20-09-2025	10:43	20-09-2025	13:31	2:48	0.001867	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
483	22-09-2025	Part of : SUBROTO PARK	5	Other Outage	Planned Outage	22-09-2025	11:00	22-09-2025	14:57	3:57	0.000329	CHECKING VALUE OF FENCING EARTHING,MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
484	22-09-2025	Part of : EAST BLOCK RAMAKRISHNA PURAM	14	Other Outage	Planned Outage	22-09-2025	10:46	22-09-2025	15:07	4:21	0.002538	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
485	23-09-2025	Part of : SUBROTO PARK,	1	Other Outage	Planned Outage	23-09-2025	11:23	23-09-2025	14:36	3:13	0.000483	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
486	23-09-2025	Part of : BLOCK C VASANT VIHAR,	205	Other Outage	Planned Outage	23-09-2025	11:05	23-09-2025	15:02	3:57	0.005267	GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACEMET,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
487	23-09-2025	Part of : SECTOR 5 RAMAKRISHNA PURAM,	250	Other Outage	Planned Outage	23-09-2025	10:38	23-09-2025	14:01	3:23	0.001128	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
488	24-09-2025	Part of : BHIKAJI CAMA PLACE RAMAKRISHNA PURAM	10	Other Outage	Planned Outage	24-09-2025	10:50	24-09-2025	13:58	3:08	0.001044	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER
489	25-09-2025	Part of : SOUTH CAMPUS MOTI BAGH SOUTH	1	Other Outage	Planned Outage	25-09-2025	15:41	25-09-2025	16:55	1:14	0.000164	DT REPLACEMENT
490	25-09-2025	Part of : BLOCK H NANAKPURA MOTI BAGH SOUTH	1080	Other Outage	Planned Outage	25-09-2025	13:50	25-09-2025	15:18	1:28	0.000733	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACMET
491	25-09-2025	Part of : POLICE COLONY SECTOR 12 RAMAKRISHNA PURAM	146	Other Outage	Planned Outage	25-09-2025	10:34	25-09-2025	14:15	3:41	0.002149	MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACMET
492	26-09-2025	Part of : SECTOR 7 RAMAKRISHNA PURAM	725	Other Outage	Planned Outage	26-09-2025	10:46	26-09-2025	13:47	3:01	0.002011	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
493	27-09-2025	Part of : HTC:VENKTESHWAR COLLEGE	1	Other Outage	Planned Outage	27-09-2025	11:19	27-09-2025	12:49	1:30	0.000200	CLEANING OF HT BUSHING PER WAY,RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
494	27-09-2025	Part of : MOHAMMADPUR RAMAKRISHNA PURAM,	11	Other Outage	Planned Outage	27-09-2025	14:01	27-09-2025	16:05	2:04	0.001378	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
495	27-09-2025	Part of : BLOCK A VASANT VIHAR,	151	Other Outage	Planned Outage	27-09-2025	11:05	27-09-2025	15:23	4:18	0.003942	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MOBILE TRANSFORMER INSTALLATION FOR PLINT REPLACMET,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
496	28-09-2025	Part of : BLOCK B, C, E & I MOTI BAGH SOUTH,SECTOR 3 & 4 SHANTI NIKETAN	2098	Other Outage	Unplanned Outage	28-09-2025	18:21	28-09-2025	18:59	0:38	0.000939	CABLE FAULT
497	28-09-2025	Part of : BLOCK B & E VASANT VIHAR	877	Other Outage	Unplanned Outage	28-09-2025	15:41	28-09-2025	16:25	0:44	0.001039	CABLE FAULT
498	28-09-2025	Part of : WEST BLOCK RAMAKRISHNA PURAM,SECTOR 8 & 7 RAMAKRISHNA PURAM,NIVEDITA KUNJ SECTOR 10 RAMAKRISHNA PURAM	4330	Other Outage	Unplanned Outage	28-09-2025	07:41	28-09-2025	08:28	0:47	0.000940	CABLE FAULT
499	29-09-2025	Part of : SECTOR 3 RAMAKRISHNA PURAM	158	Other Outage	Planned Outage	29-09-2025	11:12	29-09-2025	15:57	4:45	0.001583	APPLY OF INSULATION TAPE HT BUSHINGS
500	30-09-2025	Part of : MES SUBROTO PARK (HTC)	0	Other Outage	Unplanned Outage	30-09-2025	16:38	30-09-2025	17:28	0:50	0.001597	FAULT IN HT CONSUMER PANEL (MES)
501	30-09-2025	Part of : EAST BLOCK RAMAKRISHNA PURAM	1484	Other Outage	Planned Outage	30-09-2025	10:34	30-09-2025	14:41	4:07	0.003088	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT REPLACEMENT,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER SUB STATION CLEANING
502	30-09-2025	Part of : SECTOR 8 SHANTI NIKETAN	41	Other Outage	Planned Outage	30-09-2025	10:02	30-09-2025	14:30	4:28	0.000893	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT REPLACEMENT,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
503	01-09-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI,A-BLOCK NEB SARAI SAINIK FARM	1697	Other Outage	Unplanned Outage	01-09-2025	12:32	01-09-2025	13:28	0:56	0.001556	REPLACEMENT OF SOCKETS
504	01-09-2025	Part of : JAGDAMBA CAMP SHEIKH SARAI	1579	Other Outage	Unplanned Outage	01-09-2025	10:28	01-09-2025	12:09	1:41	0.000281	MOBILE TRANSFORMER REPLACEMENT
505	02-09-2025	Part of : SECTOR 1 PUSHPA VIHAR, BLOCK G,H,L & N SAKET,ASHOK VIHAR PRESS ENCLAVE SAKET, MODI HOSPITAL (HTC)	1975	Other Outage	Unplanned Outage	02-09-2025	22:56	02-09-2025	23:47	0:51	0.001502	CABLE FAULT
506	03-09-2025	Part of : SAINIK FARM,BLOCK G NEB SARAI SAINIK FARM,BLOCK B SAINIK FARMS COLONY SAINIK FARM,SECTOR 6 PUSHPA VIHAR,BLOCK E SAINIK FARM	444	Other Outage	Unplanned Outage	03-09-2025	03:41	03-09-2025	04:30	0:49	0.000150	HT SYSTEM FAULT
507	03-09-2025	Part of : HTC:DLF RETAIL DEVLOPERS, A-1,SAKET	0	Other Outage	Unplanned Outage	03-09-2025	00:14	03-09-2025	01:13	0:59	0.000000	CABLE FAULT
508	03-09-2025	Part of : BLOCK B KHIKDI EXTENSION MALVIYA NAGAR,	1091	Other Outage	Planned Outage	03-09-2025	11:17	03-09-2025	13:58	2:41	0.000000	TRANSFORMER MAINTENANCE
509	04-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	205	Other Outage	Planned Outage	04-09-2025	10:55	04-09-2025	15:00	4:05	0.006806	MAINTENANCE OF TRANFORMER
510	04-09-2025	Part of : PANCHSHEEL EXTENSION MALVIYA NAGAR	1796	Other Outage	Planned Outage	04-09-2025	10:08	04-09-2025	15:21	5:13	0.000000	MAINTENANCE OF TRANFORMER
511	06-09-2025	Part of : BLOCK B KHIKDI EXTENSION MALVIYA NAGAR	1092	Other Outage	Unplanned Outage	06-09-2025	11:17	06-09-2025	13:06	1:49	0.000000	REPAIR OF DAMAGED WIRE ON POLES
512	06-09-2025	Part of : BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM	364	Other Outage	Planned Outage	06-09-2025	11:49	06-09-2025	13:32	1:43	0.002861	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
513	06-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	1468	Other Outage	Planned Outage	06-09-2025	13:30	06-09-2025	16:20	2:50	0.002597	1PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB CABLE REPLACEMENT PER SPAN
514	07-09-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,BLOCK A 1 NEB SARAI SAINIK FARM	2703	Other Outage	Unplanned Outage	07-09-2025	16:38	07-09-2025	17:22	0:44	0.000489	HT SYSTEM FAULT
515	08-09-2025	Part of : BLOCK B SAINIK FARMS COLONY	32	Other Outage	Planned Outage	08-09-2025	10:54	08-09-2025	15:20	4:26	0.007389	APPLY OF INSULATION TAPE HT/LT BUSHINGS
516	08-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	1217	Other Outage	Planned Outage	08-09-2025	11:12	08-09-2025	16:07	4:55	0.008194	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
517	08-09-2025	Part of : KALU SARAI	267	Other Outage	Planned Outage	08-09-2025	10:03	08-09-2025	13:23	3:20	0.000833	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
518	08-09-2025	Part of : BLOCK L MALVIYA NAGAR	2252	Other Outage	Planned Outage	08-09-2025	10:27	08-09-2025	13:29	3:02	0.000000	REPLACEMET OF HT BUSHING ROD
519	09-09-2025	Part of : A 1-BLOCK NEB SARAI SAINIK FARM	794	Other Outage	Planned Outage	09-09-2025	10:59	09-09-2025	13:55	2:56	0.004889	APPLY OF INSULATION TAPE HT/LT BUSHINGS
520	09-09-2025	Part of : SAINIK FARM	46	Other Outage	Planned Outage	09-09-2025	10:47	09-09-2025	13:57	3:10	0.005278	APPLY OF INSULATION TAPE HT/LT BUSHINGS
521	09-09-2025	Part of : T-BLOCK MALVIYA NAGAR	1193	Other Outage	Planned Outage	09-09-2025	10:37	09-09-2025	13:45	3:08	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
522	10-09-2025	Part of : SAINIK FARM	25	Other Outage	Planned Outage	10-09-2025	11:15	10-09-2025	15:15	4:00	0.006667	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING
523	10-09-2025	Part of : BLOCK A SARVODYA ENCLAVE	255	Other Outage	Planned Outage	10-09-2025	10:00	10-09-2025	13:04	3:04	0.000767	REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
524	10-09-2025	Part of : BLOCK D DDA FLATE MALVIYA NAGAR	828	Other Outage	Planned Outage	10-09-2025	10:31	10-09-2025	13:36	3:05	0.000000	REPLACMET OF HT BUSHING ROD
525	11-09-2025	Part of : BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM,	364	Other Outage	Planned Outage	11-09-2025	12:30	11-09-2025	16:16	3:46	0.006278	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
526	11-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM,	765	Other Outage	Planned Outage	11-09-2025	11:14	11-09-2025	15:55	4:41	0.003903	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
527	11-09-2025	Part of : SARVODYA ENCLAVE,	474	Other Outage	Planned Outage	11-09-2025	09:59	11-09-2025	13:05	3:06	0.000775	REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS,TIGHTENEING OF NUT BOLT
528	11-09-2025	Part of : BLOCK H PANCHSHEEL VIHAR SHEIKH SARAI VILLAGE SHEIKH SARAI,	1968	Other Outage	Planned Outage	11-09-2025	10:36	11-09-2025	13:23	2:47	0.000000	REPLACMET OF HT BUSHING ROD
529	12-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	596	Other Outage	Planned Outage	12-09-2025	14:31	12-09-2025	16:13	1:42	0.000850	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING
530	12-09-2025	Part of : BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM	7	Other Outage	Planned Outage	12-09-2025	11:28	12-09-2025	16:11	4:43	0.002751	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
531	12-09-2025	Part of : BLOCK H PANCHSHEEL VIHAR SHEIKH SARAI VILLAGE SHEIKH SARAI	1987	Other Outage	Planned Outage	12-09-2025	10:45	12-09-2025	13:34	2:49	0.000000	REPLACMET OF HT BUSHING ROD
532	13-09-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	550	Other Outage	Planned Outage	13-09-2025	13:06	13-09-2025	14:15	1:09	0.001917	APPLY OF INSULATION TAPE HT/LT BUSHINGS
533	13-09-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM	1117	Other Outage	Planned Outage	13-09-2025	11:36	13-09-2025	15:20	3:44	0.006222	OIL TOP UP IN TRANSFORMER
534	15-09-2025	Part of : BLOCK 13 SARVAPRIYA VIHAR,	319	Other Outage	Unplanned Outage	15-09-2025	13:36	15-09-2025	13:43	0:07	0.000000	PREVENTIVE MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
535	15-09-2025	Part of : NAI BASTI LADO SARAI,	925	Other Outage	Planned Outage	15-09-2025	14:31	15-09-2025	17:07	2:36	0.004333	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
536	15-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM,	137	Other Outage	Planned Outage	15-09-2025	11:42	15-09-2025	14:57	3:15	0.001896	CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
537	15-09-2025	Part of : BLOCK L MALVIYA NAGAR,	2252	Other Outage	Planned Outage	15-09-2025	11:00	15-09-2025	14:13	3:13	0.000000	REPLACEMET OF HT BUSHING ROD
538	15-09-2025	Part of : BLOCK 13 SARVAPRIYA VIHAR,	118	Other Outage	Planned Outage	15-09-2025	10:10	15-09-2025	12:59	2:49	0.000423	CHECKING OF EARTHING VALUE USING ONLINE TESTER,CLEANING OF INSULATORS PER POLE,TAPPING OF JUMPERS
539	16-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	121	Other Outage	Planned Outage	16-09-2025	11:54	16-09-2025	14:30	2:36	0.001733	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
540	16-09-2025	Part of : BLOCK L MALVIYA NAGAR	959	Other Outage	Planned Outage	16-09-2025	11:47	16-09-2025	14:37	2:50	0.000000	REPLACEMET OF HT BUSHING ROD
541	17-09-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,A 1-BLOCK NEB SARAI SAINIK FARM	450	Other Outage	Planned Outage	17-09-2025	12:48	17-09-2025	15:53	3:05	0.005139	APPLY OF INSULATION TAPE HT/LT BUSHINGS
542	17-09-2025	Part of : H 5-BLOCK MALVIYA NAGAR	1102	Other Outage	Planned Outage	17-09-2025	10:39	17-09-2025	13:45	3:06	0.000000	REPLACEMET OF HT BUSHING ROD
543	18-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	1456	Other Outage	Planned Outage	18-09-2025	14:12	18-09-2025	15:53	1:41	0.002806	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
544	18-09-2025	Part of : BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM	364	Other Outage	Planned Outage	18-09-2025	12:30	18-09-2025	16:49	4:19	0.007194	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT
545	18-09-2025	Part of : BLOCK B NAVJIVAN VIHAR MALVIYA NAGAR	275	Other Outage	Planned Outage	18-09-2025	10:00	18-09-2025	13:15	3:15	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF HT BOOTS,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
546	19-09-2025	Part of : BANDALO WALA MOHALLA LADO SARAI,	1163	Other Outage	Planned Outage	19-09-2025	12:32	19-09-2025	15:59	3:27	0.005750	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
547	19-09-2025	Part of : PHASE II SHEIKH SARAI,	9	Other Outage	Planned Outage	19-09-2025	10:19	19-09-2025	14:00	3:41	0.000000	REPLACMET OF HT BUSHING ROD
548	20-09-2025	Part of : District Park Phase I Sheikh Sarai,Savitri Nagar Village Sheikh Sarai	2825	Other Outage	Unplanned Outage	20-09-2025	02:29	20-09-2025	03:29	1:00	0.001267	CABLE FAULT
549	20-09-2025	Part of : Pocket E Bees Sutri Harijan Basti Sainik Farm,Block A 1 Neb Sarai Sainik Farm,	450	Other Outage	Planned Outage	20-09-2025	11:09	20-09-2025	16:08	4:59	0.004568	REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING
550	20-09-2025	Part of : Pocket E Bees Sutri Harijan Basti Sainik Farm,	1117	Other Outage	Planned Outage	20-09-2025	11:50	20-09-2025	15:10	3:20	0.005556	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
551	20-09-2025	Part of : Block C Shivalik Malviya Nagar,Bhavishyanidhi Enclave Malviya Nagar,	1126	Other Outage	Planned Outage	20-09-2025	10:24	20-09-2025	13:37	3:13	0.000000	REPLACMET OF HT BUSHING ROD
552	22-09-2025	Part of : BUTTERFLY PARK QILA RAI PITHORA SAINIK FARM	274	Other Outage	Unplanned Outage	22-09-2025	13:10	22-09-2025	13:55	0:45	0.001250	ATTENDING WEAK POINTS/HOT SPOT
553	22-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	769	Other Outage	Planned Outage	22-09-2025	13:29	22-09-2025	15:13	1:44	0.002889	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,REPLACEMENT OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,TIGHTENEING OF NUT BOLT
554	22-09-2025	Part of : CHIRAG DELHI	1370	Other Outage	Planned Outage	22-09-2025	11:07	22-09-2025	13:23	2:16	0.000000	CONDUCTOR REPLACEMENT PER SPAN
555	22-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	1456	Other Outage	Planned Outage	22-09-2025	11:33	22-09-2025	16:25	4:52	0.008111	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
556	22-09-2025	Part of : BLOCK C SARVODYA ENCLAVE	253	Other Outage	Planned Outage	22-09-2025	10:05	22-09-2025	12:59	2:54	0.000822	REPLACEMENT OF LT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING
557	23-09-2025	Part of : BLOCK B FREEDOM FIGHTER VIHAR SAINIK FARM,	382	Other Outage	Planned Outage	23-09-2025	11:25	23-09-2025	14:55	3:30	0.007000	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING
558	23-09-2025	Part of : BLOCK D DDA FLATE MALVIYA NAGAR,	828	Other Outage	Planned Outage	23-09-2025	10:43	23-09-2025	14:13	3:30	0.000000	REPLACMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
559	24-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM,POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,BLOCK B & D FREEDOM FIGHTER VIHAR SAINIK FARM,BLOCK D PARYAVARAN COMPLEX SAINIK FARM,SAINIK FARM	601	Other Outage	Unplanned Outage	24-09-2025	15:11	24-09-2025	16:03	0:52	0.001777	CABLE FAULT
560	24-09-2025	Part of : BLOCK A, C, D & E PARYAVARAN COMPLEX SAINIK FARM	2444	Other Outage	Planned Outage	24-09-2025	11:14	24-09-2025	14:28	3:14	0.005389	3PH HT AB CABLE REPLACEMENT PER SPAN,HT BUSHING ROD REPLACEMENT,ST.TH JOINT ON 1PH HT AB,ST.TH JOINT ON 3PH HT AB
561	24-09-2025	Part of : BLOCK L MALVIYA NAGAR	959	Other Outage	Planned Outage	24-09-2025	10:08	24-09-2025	14:00	3:52	0.000000	REPLACEMENT OF HT BUSHING ROD
562	25-09-2025	Part of : KALU SARAI	278	Other Outage	Planned Outage	25-09-2025	10:06	25-09-2025	13:00	2:54	0.000773	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
563	26-09-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM, BLOCK A FREEDOM FIGHTER VIHAR SAINIK FARM	1931	Other Outage	Unplanned Outage	26-09-2025	13:17	26-09-2025	14:03	0:46	0.001648	CABLE FAULT
564	26-09-2025	Part of : SAIYAD UL AJAIB EXTENSION SAINIK FARM, BLOCK D SAKET , SAIYAD UL AJAIB VILLAGE SAINIK FARM	2035	Other Outage	Unplanned Outage	26-09-2025	12:01	26-09-2025	12:39	0:38	0.001056	ATTEND WEAK POINT/HOT SPOT
565	26-09-2025	Part of : BLOCK D FREEDOM FIGHTER VIHAR SAINIK FARM	391	Other Outage	Planned Outage	26-09-2025	12:14	26-09-2025	16:35	4:21	0.002900	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
566	26-09-2025	Part of : SAVITRI NAGAR VILLAGE SHEIKH SARAI	1603	Other Outage	Planned Outage	26-09-2025	10:49	26-09-2025	13:43	2:54	0.000000	REPLACEMET OF HT BUSHING ROD
567	27-09-2025	Part of : POCKET E BEES SUTRI HARIJAN BASTI SAINIK FARM,	534	Other Outage	Planned Outage	27-09-2025	11:42	27-09-2025	15:02	3:20	0.005556	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INSULATOR,REPLACEMET OF HT BUSHING ROD,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
568	27-09-2025	Part of : DISTRICT PARK PHASE I SHEIKH SARAI,	1671	Other Outage	Planned Outage	27-09-2025	11:14	27-09-2025	14:04	2:50	0.000000	REPLACEMET OF HT BUSHING ROD
569	29-09-2025	Part of : BLOCK A 1 NEB SARAI SAINIK FARM	433	Other Outage	Planned Outage	29-09-2025	11:03	29-09-2025	13:47	2:44	0.004556	APPLY OF INSULATION TAPE HT BUSHINGS
570	29-09-2025	Part of : BLOCK D SAKET	36	Other Outage	Planned Outage	29-09-2025	10:34	29-09-2025	13:48	3:14	0.005389	APPLY OF INSULATION TAPE HT BUSHINGS
571	29-09-2025	Part of : ADHCHINI VILLAGE QUTAB ENCLAVE	237	Other Outage	Planned Outage	29-09-2025	10:03	29-09-2025	12:57	2:54	0.000677	REPLACEMET OF HT BUSHING
572	30-09-2025	Part of : PHASE II SHEIKH SARAI	2447	Other Outage	Planned Outage	30-09-2025	10:34	30-09-2025	11:31	0:57	0.000000	REPLACEMENT OF LT BUSHING ROD
573	30-09-2025	Part of : VIJAY MANDAL ENCLAVE KALU SARAI	350	Other Outage	Planned Outage	30-09-2025	10:04	30-09-2025	12:59	2:55	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
574	01-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	3984	Other Outage	Unplanned Outage	01-09-2025	06:14	01-09-2025	06:56	0:42	0.000000	CABLE FAULT
575	01-09-2025	Part of : MADANPUR KHADAR,RAJ NAGAR	1879	Other Outage	Unplanned Outage	01-09-2025	05:56	01-09-2025	06:38	0:42	0.001097	CABLE FAULT
576	01-09-2025	Part of : VILLAGE-JAITPUR	476	Other Outage	Planned Outage	01-09-2025	10:12	01-09-2025	12:33	2:21	0.001175	HT/LT BUSHINGS INSTALLATION OF HT BOOTS
577	03-09-2025	Part of : ABC BLOCK HARI NAGAR MOLARBAND,E-BLOCK HARI NAGAR EXT PART-2,F-BLOCK SAURABH VIHAR,MOLARBAND	4315	Other Outage	Unplanned Outage	03-09-2025	14:11	03-09-2025	14:55	0:44	0.001124	HT SYSTEM FAULT
578	03-09-2025	Part of : MITHAPUR,	1353	Other Outage	Planned Outage	03-09-2025	10:59	03-09-2025	14:37	3:38	0.001211	TRANSFORMER MAINTENANCE
579	03-09-2025	Part of : KHADDA COLONY JAITPUR,	3012	Other Outage	Planned Outage	03-09-2025	10:58	03-09-2025	16:52	5:54	0.000000	HVDS MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
580	03-09-2025	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR,	537	Other Outage	Planned Outage	03-09-2025	11:00	03-09-2025	14:27	3:27	0.000575	TRANSFORMER MAINTENANCE
581	03-09-2025	Part of : POCKET E SARITA VIHAR,	923	Other Outage	Planned Outage	03-09-2025	10:57	03-09-2025	15:16	4:19	0.003597	HT O/H CIRCUIT MAINTENANCE
582	04-09-2025	Part of : BADARPUR EXTENSION TAJPUR BADARPUR	761	Other Outage	Planned Outage	04-09-2025	10:59	04-09-2025	15:15	4:16	0.001422	MAINTENANCE OF TRANFORMER
583	04-09-2025	Part of : KHADDA COLONY JAIPUR	2358	Other Outage	Planned Outage	04-09-2025	10:59	04-09-2025	15:28	4:29	0.003363	HVDS CIRCUIT NETWORK UPGRADATION
584	06-09-2025	Part of : MANBHARI KUNJ EXTN., MITHAPUR EXTN.	2900	Other Outage	Unplanned Outage	06-09-2025	18:11	06-09-2025	18:48	0:37	0.000997	CABLE FAULT APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
585	06-09-2025	Part of : BLOCK D TAJPUR PAHARI VILLAGE BADARPUR	1147	Other Outage	Planned Outage	06-09-2025	11:08	06-09-2025	14:36	3:28	0.001156	3PH HT AB CABLE REPLACEMENT PER SPAN
586	06-09-2025	Part of : KHADDA COLONY JAIPUR	1413	Other Outage	Planned Outage	06-09-2025	12:07	06-09-2025	14:12	2:05	0.003576	REPAIRING OF TRANSFORMER
587	08-09-2025	Part of : MADANPUR KHADAR VILLAGE	667	Other Outage	Unplanned Outage	08-09-2025	12:07	08-09-2025	14:14	2:07	0.000882	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR
588	08-09-2025	Part of : MITHAPUR	516	Other Outage	Planned Outage	08-09-2025	11:04	08-09-2025	14:08	3:04	0.001022	APPLY OF INSULATION TAPE HT/LT BUSHINGS
589	08-09-2025	Part of : BADARPUR VILLAGE	230	Other Outage	Planned Outage	08-09-2025	10:55	08-09-2025	14:20	3:25	0.001139	DB REVAMPING
590	08-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1632	Other Outage	Planned Outage	08-09-2025	11:16	08-09-2025	16:20	5:04	0.002871	TAPPING OF JUMPERS
591	08-09-2025	Part of : LALU COLONY ALI,GAYATRI KUNJ ALI	470	Other Outage	Planned Outage	08-09-2025	11:15	08-09-2025	15:52	4:37	0.001539	DT REPLACEMENT
592	09-09-2025	Part of : MITHAPUR	860	Other Outage	Planned Outage	09-09-2025	12:32	09-09-2025	13:29	0:57	0.000317	OIL TOP UP IN TRANSFORMER
593	09-09-2025	Part of : MITHAPUR	912	Other Outage	Planned Outage	09-09-2025	10:52	09-09-2025	15:46	4:54	0.002205	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
594	09-09-2025	Part of : BADARPUR VILLAGE	758	Other Outage	Planned Outage	09-09-2025	11:02	09-09-2025	15:19	4:17	0.001428	3PH HT AB CABLE REPLACEMENT
595	09-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1380	Other Outage	Planned Outage	09-09-2025	10:55	09-09-2025	14:22	3:27	0.009488	HT SYSTEM FAULT
596	10-09-2025	Part of : SUDERSHAN PARK, LAKHPAT COLONY MITHAPUR, MEETHA PUR VILLAGE	3629	Other Outage	Unplanned Outage	10-09-2025	20:59	10-09-2025	21:42	0:43	0.000920	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,TIGHTENEING OF NUT BOLT
597	10-09-2025	Part of : LAKHPAT COLONY MITHAPUR	1377	Other Outage	Planned Outage	10-09-2025	11:23	10-09-2025	14:28	3:05	0.001285	3PH HT AB END TERMINATION REPLACEMENT
598	10-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1440	Other Outage	Planned Outage	10-09-2025	11:04	10-09-2025	16:04	5:00	0.010417	REPLACEMENT OF LT BUSHING ROD
599	10-09-2025	Part of : POCKET E SARITA VIHAR	667	Other Outage	Planned Outage	10-09-2025	11:03	10-09-2025	15:15	4:12	0.001400	

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
600	10-09-2025	Part of : BADARPUR VILLAGE	1448	Other Outage	Planned Outage	10-09-2025	11:12	10-09-2025	14:50	3:38	0.001211	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS
601	11-09-2025	Part of : MITHAPUR,	1486	Other Outage	Unplanned Outage	11-09-2025	12:08	11-09-2025	13:57	1:49	0.000000	PREDICTIVE MAINTENANCE
602	11-09-2025	Part of : LAKHPAT COLONY MITHAPUR,	802	Other Outage	Planned Outage	11-09-2025	11:03	11-09-2025	14:05	3:02	0.000961	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
603	11-09-2025	Part of : GAYATRI KUNJ ALI,	1372	Other Outage	Planned Outage	11-09-2025	11:16	11-09-2025	14:59	3:43	0.001239	REPLACEMENT OF GAS KIT AND OIL SEAL
604	11-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR,	1885	Other Outage	Planned Outage	11-09-2025	11:36	11-09-2025	14:52	3:16	0.005771	LT BUSHING REPLACEMENT
605	11-09-2025	Part of : BADARPUR EXTENSION TAJPUR BADARPUR,	384	Other Outage	Planned Outage	11-09-2025	10:59	11-09-2025	15:44	4:45	0.000792	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
606	12-09-2025	Part of : ABC BLOCK HARI NAGAR MOLARBAND	611	Other Outage	Planned Outage	12-09-2025	11:02	12-09-2025	15:14	4:12	0.001540	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF HT BUSHING INULATOR
607	12-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1604	Other Outage	Planned Outage	12-09-2025	11:02	12-09-2025	14:40	3:38	0.008781	3PH HT AB CABLE REPLACEMENT PER SPAN
608	12-09-2025	Part of : BUDH VIHAR COLONY TAJPUR PAHARI VILLAGE BADARPUR	792	Other Outage	Planned Outage	12-09-2025	10:52	12-09-2025	14:40	3:48	0.001267	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING
609	12-09-2025	Part of : MADANPUR KHADAR VILLAGE	1245	Other Outage	Planned Outage	12-09-2025	11:00	12-09-2025	14:35	3:35	0.001493	FERRULE PUNCHING LT AB TO LT AB PER FEEDER
610	13-09-2025	Part of : ABC BLOCK HARI NAGAR MOLARBAND	780	Other Outage	Planned Outage	13-09-2025	11:10	13-09-2025	14:03	2:53	0.000721	OIL TOP UP IN TRANSFORMER
611	13-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1385	Other Outage	Planned Outage	13-09-2025	11:33	13-09-2025	16:01	4:28	0.007891	3PH HT AB CABLE REPLACEMENT
612	13-09-2025	Part of : MOHAN BABA NAGAR TAJPUR PAHARI VILLAGE BADARPUR	432	Other Outage	Planned Outage	13-09-2025	11:02	13-09-2025	14:47	3:45	0.001250	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING
613	14-09-2025	Part of : BLOCK B MOHAN COOPERATIVE INDUSTRIAL ESTATE BADARPUR	1	Other Outage	Planned Outage	14-09-2025	11:08	14-09-2025	15:18	4:10	0.001389	INSTALLATION OF BUS BAR
614	15-09-2025	Part of : KHADDA COLONY JAIPUR,	3007	Other Outage	Planned Outage	15-09-2025	11:06	15-09-2025	14:04	2:58	0.010383	3PH HT AB CABLE REPLACEMENT PER SPAN
615	15-09-2025	Part of : F-BLOCK SAURABH VIHAR,	538	Other Outage	Planned Outage	15-09-2025	11:05	15-09-2025	15:29	4:24	0.001320	INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
616	15-09-2025	Part of : LALU COLONY ALI,GAYATRI KUNJ ALI,	470	Other Outage	Planned Outage	15-09-2025	11:05	15-09-2025	15:52	4:47	0.001993	3PH HT AB CABLE REPLACEMENT PER SPAN
617	15-09-2025	Part of : BADARPUR VILLAGE BADARPUR,	561	Other Outage	Planned Outage	15-09-2025	10:49	15-09-2025	14:43	3:54	0.003900	REPLACEMENT OF CROSS-ARMS AND POLES
618	16-09-2025	Part of : MOLARBAND	161	Other Outage	Planned Outage	16-09-2025	11:42	16-09-2025	14:37	2:55	0.001215	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
619	16-09-2025	Part of : KHADDA COLONY JAIPUR	1796	Other Outage	Planned Outage	16-09-2025	11:38	16-09-2025	13:58	2:20	0.005639	3PH HT AB CABLE REPLACEMENT PER SPAN
620	16-09-2025	Part of : ALI VIHAR ALI,PRIYANKA CAMP ALI	981	Other Outage	Planned Outage	16-09-2025	11:35	16-09-2025	14:19	2:44	0.000911	3PH HT AB END TERMINATION REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
621	17-09-2025	Part of : ABC & E BLOCK HARI NAGAR MOLARBAND,F-BLOCK SAURABH VIHAR	4321	Other Outage	Unplanned Outage	17-09-2025	16:59	17-09-2025	17:49	0:50	0.001514	HT SYSTEM FAULT
622	17-09-2025	Part of : ABC BLOCK HARI NAGAR MOLARBAND	571	Other Outage	Planned Outage	17-09-2025	11:09	17-09-2025	14:21	3:12	0.001333	OIL TOP UP IN TRANSFORMER
623	18-09-2025	Part of : ABC BLOCK HARI NAGAR MOLARBAND, BLOCK D,J,K,N & O SAURABH VIHAR, E-BLOCK HARI NAGAR EXT PART-2, NTPC WATER TREATMENT PLANT BADARPUR	4308	Other Outage	Unplanned Outage	18-09-2025	03:44	18-09-2025	04:42	0:58	0.001498	HT SYSTEM FAULT
624	18-09-2025	Part of : KHADDA COLONY JAIPUR	2358	Other Outage	Planned Outage	18-09-2025	11:03	18-09-2025	15:57	4:54	0.000000	LT BUSHING REPLACEMENT
625	18-09-2025	Part of : BUDH VIHAR COLONY TAJPUR PAHARI VILLAGE BADARPUR	796	Other Outage	Planned Outage	18-09-2025	11:03	18-09-2025	15:24	4:21	0.001450	DT REPLACEMENT
626	18-09-2025	Part of : POCKET E SARITA VIHAR	667	Other Outage	Planned Outage	18-09-2025	11:03	18-09-2025	15:55	4:52	0.002433	3PH DB REPLACEMENT
627	18-09-2025	Part of : BUDH VIHAR COLONY TAJPUR PAHARI VILLAGE BADARPUR	452	Other Outage	Planned Outage	18-09-2025	11:04	18-09-2025	16:05	5:01	0.000836	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
628	19-09-2025	Part of : KHADDA COLONY JAIPUR,	1413	Other Outage	Planned Outage	19-09-2025	11:00	19-09-2025	14:45	3:45	0.000000	DB REVAMPING
629	19-09-2025	Part of : BADARPUR VILLAGE BADARPUR,	654	Other Outage	Planned Outage	19-09-2025	11:40	19-09-2025	14:44	3:04	0.001022	DT REPLACEMENT
630	19-09-2025	Part of : BLOCK C MOLARBAND EXTENSION BADARPUR,	17	Other Outage	Planned Outage	19-09-2025	11:21	19-09-2025	15:54	4:33	0.002275	1PH HT AB CABLE REPLACEMENT PER SPAN,DB REVAMPING,DT REPLACEMET PER DT,LT BUSHING REPLACEMENT,LT JUMPER REPLACEMENT
631	20-09-2025	Part of : ABC Block Hari Nagar Molarband,K-BLOCK SAURABH VIHAR,Raj Nagar Madanpur Khadar,O-BLOCK SAURABH VIHAR,E-BLOCK HARI NAGAR EXT PART-2,D-BLOCK SAURABH,J BLOCK SAURABH VIHAR,N-BLOCK SAURABH VIHAR,NTPC Water Treatment Plant Badarpur	4309	Other Outage	Unplanned Outage	20-09-2025	15:40	20-09-2025	16:39	0:59	0.001491	CABLE FAULT
632	20-09-2025	Part of : L-BLOCK SAURABH VIHAR,K-BLOCK SAURABH VIHAR,M-BLOCK SAURABH VIHAR,Jaitpur,H BLOCK SAURABH VIHAR,F-BLOCK SAURABH VIHAR	2021	Other Outage	Unplanned Outage	20-09-2025	15:32	20-09-2025	16:34	1:02	0.000000	CABLE FAULT
633	20-09-2025	Part of : E-BLOCK HARI NAGAR EXT PART-2,	61	Other Outage	Unplanned Outage	20-09-2025	11:14	20-09-2025	12:06	0:52	0.000722	REPAIRING OF RMU
634	20-09-2025	Part of : F-BLOCK SAURABH VIHAR,	497	Other Outage	Planned Outage	20-09-2025	11:10	20-09-2025	13:06	1:56	0.000902	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
635	20-09-2025	Part of : Block D Molarband Extension Badarpur,Block E 2 Molarband Extension Badarpur,Block E 1 Molarband Extension Badarpur,Block F Molarband Extension Badarpur,	14	Other Outage	Planned Outage	20-09-2025	11:04	20-09-2025	14:58	3:54	0.001950	DB REVAMPING,DT REPLACEMET PER DT,HT BUSHING ROD REPLACEMENT,LT BUSHING REPLACEMENT,LT JUMPER REPLACEMENT
636	21-09-2025	Part of : RAJ NAGAR,MADANPUR KHADAR	1885	Other Outage	Unplanned Outage	21-09-2025	15:32	21-09-2025	15:59	0:27	0.000427	BIRDAGE
637	21-09-2025	Part of : KHADDA COLONY JAIPUR	5905	Other Outage	Unplanned Outage	21-09-2025	12:44	21-09-2025	13:03	0:19	0.000412	CABLE DAMAGE BY OUTSIDE AGENCY (PWD)
638	22-09-2025	Part of : JJ COLONY P-III, MADANPUR KHADAR EXTN., RAJ NAGAR MADANPUR KHADAR	1886	Other Outage	Unplanned Outage	22-09-2025	18:29	22-09-2025	19:03	0:34	0.000482	KITE STRING FOUND ON HT O/H LINE
639	22-09-2025	Part of : JAIPUR EXTN A-BLOCK	1977	Other Outage	Planned Outage	22-09-2025	10:50	22-09-2025	16:18	5:28	0.001822	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTTENEING OF NUT BOLT
640	22-09-2025	Part of : ALI VIHAR, PRIYANKA CAMP ALI	981	Other Outage	Planned Outage	22-09-2025	11:03	22-09-2025	17:07	6:04	0.003033	CLEANING OF HT BUSHING PER WAY
641	22-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1632	Other Outage	Planned Outage	22-09-2025	11:02	22-09-2025	14:09	3:07	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
642	23-09-2025	Part of : N-BLOCK SAURABH VIHAR,O-BLOCK SAURABH VIHAR,E-BLOCK HARI NAGAR EXT PART-2,	1341	Other Outage	Unplanned Outage	23-09-2025	10:55	23-09-2025	13:10	2:15	0.003375	REPAIR/REPLACEMENT OF CONDUCTOR
643	23-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR,	1379	Other Outage	Planned Outage	23-09-2025	10:53	23-09-2025	13:31	2:38	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
644	24-09-2025	Part of : MADANPUR KHADAR VILLAGE	1245	Other Outage	Planned Outage	24-09-2025	10:59	24-09-2025	16:19	5:20	0.002667	CONDUCTOR REPLACEMENT PER SPAN
645	25-09-2025	Part of : MOLARBAND VILLAGE BADARPUR	459	Other Outage	Planned Outage	25-09-2025	10:32	25-09-2025	15:00	4:28	0.001489	DT REPLACEMENT
646	25-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1882	Other Outage	Planned Outage	25-09-2025	11:04	25-09-2025	15:22	4:18	0.000000	3PH HT AB CABLE REPLACEMENT
647	26-09-2025	Part of : RAJ NAGAR, MADANPUR KHADAR	3992	Other Outage	Unplanned Outage	26-09-2025	12:05	26-09-2025	12:44	0:39	0.000000	CABLE FAULT
648	26-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1600	Other Outage	Planned Outage	26-09-2025	11:00	26-09-2025	16:40	5:40	0.000000	HT BUSHING ROD REPLACEMENT
649	26-09-2025	Part of : BADARPUR VILLAGE	767	Other Outage	Planned Outage	26-09-2025	10:56	26-09-2025	15:19	4:23	0.001461	DT REPLACEMENT
650	27-09-2025	Part of : KHADDA COLONY JAIPUR,	1	Other Outage	Planned Outage	27-09-2025	11:19	27-09-2025	14:26	3:07	0.000000	DT REPLACEMENT
651	29-09-2025	Part of : POCKET E SARITA VIHAR	923	Other Outage	Planned Outage	29-09-2025	12:35	29-09-2025	16:29	3:54	0.007150	REPLACEMENT OF GAS KIT AND OIL SEAL
652	29-09-2025	Part of : MITHAPUR	858	Other Outage	Planned Outage	29-09-2025	10:40	29-09-2025	13:32	2:52	0.000956	APPLY OF INSULATION TAPE HT BUSHINGS
653	29-09-2025	Part of : LAKHPAT COLONY MITHAPUR	1373	Other Outage	Planned Outage	29-09-2025	10:39	29-09-2025	13:32	2:53	0.000000	DT REPLACEMENT
654	30-09-2025	Part of : GAGAN VIHAR MITHAPUR EXTENSION	1667	Other Outage	Planned Outage	30-09-2025	11:10	30-09-2025	12:29	1:19	0.000549	REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD,REPLACMET OF HT/LT CLEATS,REPLACMET OF LUGS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
655	30-09-2025	Part of : MITHAPUR	1361	Other Outage	Planned Outage	30-09-2025	11:13	30-09-2025	12:28	1:15	0.000313	INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF LT BUSHING INSULATOR
656	30-09-2025	Part of : RAJ NAGAR MADANPUR KHADAR	1632	Other Outage	Planned Outage	30-09-2025	11:03	30-09-2025	12:27	1:24	0.001307	3PH HT AB CABLE REPLACEMENT PER SPAN
657	30-09-2025	Part of : MOLARBAND VILLAGE BADARPUR	390	Other Outage	Planned Outage	30-09-2025	11:47	30-09-2025	13:47	2:00	0.001000	DB REVAMPING,DT REPLACEMET PER DT,LT BUSHING REPLACEMENT,LT JUMPER REPLACEMENT
658	01-09-2025	Part of : DESU COLONY VASANT KUNJ,KHANDSA COLONY & BRIJBASI COLONY MEHRAULI	1813	Other Outage	Unplanned Outage	01-09-2025	21:11	01-09-2025	21:49	0:38	0.000422	HT SYSTEM FAULT
659	01-09-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE	1115	Other Outage	Planned Outage	01-09-2025	11:31	01-09-2025	14:13	2:42	0.001125	LT BUSHINGS INSTALLATION OF BUS BAR
660	03-09-2025	Part of : ANAND GRAM GHITORNI,GHITORNI VILLAGE GHITORNI	118	Other Outage	Unplanned Outage	03-09-2025	09:44	03-09-2025	10:33	0:49	0.000000	TREE TOUCHING
661	03-09-2025	Part of : ANAND GRAM GHITORNI,GHITORNI VILLAGE GHITORNI,	118	Other Outage	Unplanned Outage	03-09-2025	15:58	03-09-2025	16:17	0:19	0.000185	REPAIRING OF HT O/H CIRCUIT
662	03-09-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA,PALAM FARMS,	3336	Other Outage	Planned Outage	03-09-2025	10:36	03-09-2025	11:46	1:10	0.001594	TREE TRIMMING
663	03-09-2025	Part of : SLASH PUR VILLAGE PALAM FARMS,	432	Other Outage	Planned Outage	03-09-2025	11:18	03-09-2025	14:13	2:55	0.000000	LT CIRCUIT MAINTENANCE
664	03-09-2025	Part of : TEACHER COLONY MEHRAULI,BRAHMAN MOHALLA MEHRAULI,LAKHI NATH KUTI MEHRAULI,	1584	Other Outage	Planned Outage	03-09-2025	10:04	03-09-2025	13:52	3:48	0.000000	HVDS TRANSFORMER MAINTENANCE
665	03-09-2025	Part of : RUCHI VIHAR VASANT KUNJ,IAA COLONY SECTOR D VASANT KUNJ,	7	Other Outage	Planned Outage	03-09-2025	10:48	03-09-2025	14:31	3:43	0.002478	TREE TRIMMING
666	04-09-2025	Part of : SAMALKA,PUSHPANJALI FARMS	2592	Other Outage	Planned Outage	04-09-2025	10:39	04-09-2025	11:55	1:16	0.001794	HT CIRCUIT NETWORK UPGRADATION
667	05-09-2025	Part of : KAPAS HERA EXTENSION & KAPAS HERA VILLAGE	838	Other Outage	Unplanned Outage	05-09-2025	20:39	05-09-2025	21:11	0:32	0.000000	HT SYSTEM FAULT
668	08-09-2025	Part of : ROOPAM WALA KUNWA MEHRAULI,LAKHI NATH KUTI MEHRAULI	2799	Other Outage	Unplanned Outage	08-09-2025	13:17	08-09-2025	14:06	0:49	0.000939	HT SYSTEM FAULT
669	08-09-2025	Part of : TEACHER COLONY MEHRAULI,BRAHMAN MOHALLA MEHRAULI,LAKHI NATH KUTI MEHRAULI	3394	Other Outage	Unplanned Outage	08-09-2025	13:17	08-09-2025	14:05	0:48	0.000933	HT SYSTEM FAULT
670	08-09-2025	Part of : POCKET 2 & 6 SECTOR C VASANT KUNJ	848	Other Outage	Unplanned Outage	08-09-2025	12:50	08-09-2025	13:45	0:55	0.001344	CABLE FAULT
671	08-09-2025	Part of : MAHIPALPUR EXTENSION	0	Other Outage	Unplanned Outage	08-09-2025	10:56	08-09-2025	11:40	0:44	0.001198	CABLE FAULT
672	08-09-2025	Part of : KAPAS HERA EXTENSION	2078	Other Outage	Planned Outage	08-09-2025	10:51	08-09-2025	11:40	0:49	0.000953	BIRD SPIKES INSTALLATION PER POLE
673	08-09-2025	Part of : SAMALKA,KAPAS HERA ESTATE,PUSHPANJALI FARMS,KAPAS HERA EXTENSION	2588	Other Outage	Planned Outage	08-09-2025	10:52	08-09-2025	11:38	0:46	0.000690	BIRD SPIKES INSTALLATION PER POLE
674	08-09-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	46	Other Outage	Planned Outage	08-09-2025	10:31	08-09-2025	14:49	4:18	0.004300	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
675	08-09-2025	Part of : NAYAK PURA BIJWASAN	1073	Other Outage	Planned Outage	08-09-2025	10:32	08-09-2025	12:35	2:03	0.003758	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
676	09-09-2025	Part of : B-BLOCK NANGAL DEWAT SECTOR D VASANT KUNJ	596	Other Outage	Planned Outage	09-09-2025	13:25	09-09-2025	15:15	1:50	0.001833	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
677	09-09-2025	Part of : KAPAS HERA EXTENSION,KAPAS HERA ESTATE	2073	Other Outage	Planned Outage	09-09-2025	10:38	09-09-2025	12:08	1:30	0.001375	BIRD SPIKES INSTALLATION PER POLE
678	09-09-2025	Part of : PUSHPANJALI FARMS BIJWASAN	40	Other Outage	Planned Outage	09-09-2025	10:15	09-09-2025	14:43	4:28	0.008189	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES
679	10-09-2025	Part of : MAHIPALPUR EXTENSION, MAHIPALPUR VILLAGE, DJB MAHIPALPUR (HTC)	901	Other Outage	Unplanned Outage	10-09-2025	10:32	10-09-2025	11:13	0:41	0.000205	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
680	10-09-2025	Part of : POCKET 3 SECTOR D VASANT KUNJ, GHITORNI VILLAGE, SECTOR D VASANT KUNJ	884	Other Outage	Unplanned Outage	10-09-2025	09:20	10-09-2025	10:12	0:52	0.000000	HT SYSTEM FAULT
681	10-09-2025	Part of : KAPAS HERA ESTATE, AVENUE BOUGANVILLEA RANGPURI,YAWANTIKA COLONY RANGPURI	303	Other Outage	Planned Outage	10-09-2025	10:41	10-09-2025	11:43	1:02	0.000999	BIRD SPIKES INSTALLATION PER POLE
682	10-09-2025	Part of : KHANDSA COLONY MEHRAULI	774	Other Outage	Planned Outage	10-09-2025	13:45	10-09-2025	15:49	2:04	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
683	10-09-2025	Part of : RANGPURI PAHARI , BLOCK K MAHIPALPUR VILLAGE	5452	Other Outage	Planned Outage	10-09-2025	11:08	10-09-2025	14:02	2:54	0.004350	REPLACEMENT OF LT BUSHING ROD
684	10-09-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	369	Other Outage	Planned Outage	10-09-2025	10:43	10-09-2025	14:53	4:10	0.004861	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
685	11-09-2025	Part of : ANAND GRAM GHITORNI,GHITORNI VILLAGE GHITORNI,	118	Other Outage	Unplanned Outage	11-09-2025	13:13	11-09-2025	14:03	0:50	0.000000	ATTENDING WEAK POINTS/HOT SPOT
686	11-09-2025	Part of : SAMALKA,KAPAS HERA ESTATE,RAJOKRI VILLAGE RAJOKRI,YAWANTIKA COLONY RANGPURI,AVENUE BOUGANVILLEA RANGPURI,	875	Other Outage	Planned Outage	11-09-2025	10:45	11-09-2025	11:50	1:05	0.001011	BIRD SPIKES INSTALLATION PER POLE
687	11-09-2025	Part of : KALKA DASS MEHRAULI,	1239	Other Outage	Planned Outage	11-09-2025	11:08	11-09-2025	14:16	3:08	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
688	11-09-2025	Part of : RUCHI VIHAR VASANT KUNJ,	247	Other Outage	Planned Outage	11-09-2025	10:34	11-09-2025	14:16	3:42	0.003700	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
689	11-09-2025	Part of : NAYAK PURA BIJWASAN,	484	Other Outage	Planned Outage	11-09-2025	10:48	11-09-2025	13:17	2:29	0.001035	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF LT BUSHING ROD
690	12-09-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	374	Other Outage	Planned Outage	12-09-2025	14:44	12-09-2025	16:41	1:57	0.001950	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
691	12-09-2025	Part of : SAMALKA	51	Other Outage	Planned Outage	12-09-2025	10:33	12-09-2025	13:59	3:26	0.003319	BIRD SPIKES INSTALLATION PER POLE
692	12-09-2025	Part of : MEHRAULI	228	Other Outage	Planned Outage	12-09-2025	11:26	12-09-2025	15:57	4:31	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE
693	12-09-2025	Part of : POCKET 9 SECTOR C VASANT KUNJ	141	Other Outage	Planned Outage	12-09-2025	09:56	12-09-2025	14:04	4:08	0.000689	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
694	12-09-2025	Part of : RANGPURI PAHARI	542	Other Outage	Planned Outage	12-09-2025	10:33	12-09-2025	13:18	2:45	0.002521	REPLACEMENT OF LT BUSHING ROD
695	13-09-2025	Part of : SAMALKA,KAPAS HERA ESTATE,RAJOKRI VILLAGE,YAWANTIKA COLONY & AVENUE BOUGANVILLEA RANGPURI	751	Other Outage	Unplanned Outage	13-09-2025	00:29	13-09-2025	00:56	0:27	0.000375	TREE TOUCHING
696	13-09-2025	Part of : AMPC POST OFFICE (HT CONSUMER)	0	Other Outage	Unplanned Outage	13-09-2025	15:20	13-09-2025	15:56	0:36	0.000000	CABLE FAULT
697	13-09-2025	Part of : RAJOKRI VILLAGE,WEST END GREENS RANGPURI,AVENUE JHAKARANDA GOLDEN GRITERS	1653	Other Outage	Planned Outage	13-09-2025	11:00	13-09-2025	11:35	0:35	0.000817	BIRD SPIKES INSTALLATION PER POLE
698	13-09-2025	Part of : PALAM FARMS BIJWASAN	11	Other Outage	Planned Outage	13-09-2025	10:45	13-09-2025	11:58	1:13	0.000000	REPLACEMET OF HT/LT CLEATS
699	13-09-2025	Part of : POCKET 4 SECTOR B VASANT KUNJ	1025	Other Outage	Planned Outage	13-09-2025	11:12	13-09-2025	15:26	4:14	0.000000	FERRULE PUNCHING LT AB TO LT AB

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
700	13-09-2025	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	528	Other Outage	Planned Outage	13-09-2025	11:06	13-09-2025	14:22	3:16	0.003267	MEASUREMET OF INSULATION RESISTANCE
701	15-09-2025	Part of : RAJOKRI VILLAGE RAJOKRI,HARIJAN BASTI RAJOKRI,AVENUE BOUGANVILLEA RANGPURI,	2527	Other Outage	Planned Outage	15-09-2025	10:59	15-09-2025	12:06	1:07	0.001619	BIRD SPIKES INSTALLATION PER POLE
702	15-09-2025	Part of : MAHIPALPUR VILLAGE MAHIPALPUR,	897	Other Outage	Planned Outage	15-09-2025	10:58	15-09-2025	13:56	2:58	0.002225	REPLACEMENT OF LT BUSHING ROD
703	15-09-2025	Part of : KHANDSA COLONY MEHRAULI,	904	Other Outage	Planned Outage	15-09-2025	10:54	15-09-2025	15:20	4:26	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,INSTALLATION OF BUS BAR,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING TIGHTENING OF NUT BOLT
704	15-09-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ,	734	Other Outage	Planned Outage	15-09-2025	10:43	15-09-2025	15:03	4:20	0.004333	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
705	16-09-2025	Part of : AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI,AVENUE BOUGANVILLEA RANGPURI	2025	Other Outage	Planned Outage	16-09-2025	11:06	16-09-2025	11:44	0:38	0.000918	BIRD SPIKES INSTALLATION PER POLE
706	16-09-2025	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	241	Other Outage	Planned Outage	16-09-2025	10:54	16-09-2025	14:58	4:04	0.004067	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
707	17-09-2025	Part of : RANGPURI,GHITORNI VILLAGE,KAPAS HERA ESTATE,KISHANGARH VILLAG, SECTOR A VASANT KUNJ,	529	Other Outage	Unplanned Outage	17-09-2025	15:29	17-09-2025	16:20	0:51	0.000638	HT SYSTEM FAULT
708	17-09-2025	Part of : JHAKARANDA GOLDEN GRITERS BOUGANVILLEA,WEST END GREENS ,HARIJAN BASTI RAJOKRI,RANGPURI	221	Other Outage	Planned Outage	17-09-2025	10:53	17-09-2025	11:49	0:56	0.001338	BIRD SPIKES INSTALLATION PER POLE
709	17-09-2025	Part of : RANGPURI PAHARI	620	Other Outage	Planned Outage	17-09-2025	12:08	17-09-2025	15:02	2:54	0.002658	REPLACEMENT OF LT BUSHING ROD
710	17-09-2025	Part of : ROOPAM WALA KUNWA MEHRAULI	494	Other Outage	Planned Outage	17-09-2025	11:56	17-09-2025	15:39	3:43	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
711	17-09-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	46	Other Outage	Planned Outage	17-09-2025	11:02	17-09-2025	14:44	3:42	0.003700	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
712	17-09-2025	Part of : NAYAK PURA BIJWASAN	564	Other Outage	Planned Outage	17-09-2025	11:17	17-09-2025	14:11	2:54	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
713	18-09-2025	Part of : MEHRAM NAGAR WEST,POLICE COLONY MEHRAM NAGAR,MEHRAM NAGAR EAST	2151	Other Outage	Unplanned Outage	18-09-2025	12:49	18-09-2025	13:14	0:25	0.000528	TREE BRANCH FALLEN ON HT LINE
714	18-09-2025	Part of : POCKET 9 SECTOR C VASANT KUNJ	661	Other Outage	Unplanned Outage	18-09-2025	18:50	18-09-2025	19:44	0:54	0.000705	CABLE FAULT
715	18-09-2025	Part of : TEMP JKUMAR AEROCITY (HTC)	0	Other Outage	Unplanned Outage	18-09-2025	14:35	18-09-2025	15:21	0:46	0.000000	CABLE FAULT
716	18-09-2025	Part of : DALMIA VIHAR BIJWASAN	612	Other Outage	Planned Outage	18-09-2025	15:12	18-09-2025	15:49	0:37	0.000000	REPLACEMENT OF LT BUSHING ROD
717	18-09-2025	Part of : BLOCK R MAHIPALPUR VILLAGE	542	Other Outage	Planned Outage	18-09-2025	11:00	18-09-2025	12:51	1:51	0.002775	REPLACEMENT OF LT BUSHING ROD
718	18-09-2025	Part of : KAPAS HERA EXTENSION,PUSHPANJALI FARMS,PALAM FARMS	1866	Other Outage	Planned Outage	18-09-2025	11:05	18-09-2025	12:11	1:06	0.001595	BIRD SPIKES INSTALLATION PER POLE
719	18-09-2025	Part of : BRIJBASI COLONY MEHRAULI	1083	Other Outage	Planned Outage	18-09-2025	10:58	18-09-2025	13:30	2:32	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING
720	18-09-2025	Part of : BLOCK B NANGAL DEWAT SECTOR D VASANT KUNJ	59	Other Outage	Planned Outage	18-09-2025	10:58	18-09-2025	14:36	3:38	0.003028	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
721	19-09-2025	Part of : BLOCK B MAHIPALPUR VILLAGE MAHIPALPUR,RANGPURI,AVENUE BOUGANVILLEA RANGPURI,MAHIPALPUR VILLAGE MAHIPALPUR,MAHIPALPUR EXTENSION MAHIPALPUR,RANGPURI NALLAPAR RANGPURI,KHANDSA COLONY MEHRAULI,AVENUE BOUGANVILLEA RANGPURI,SETH SARAI MEHRAULI WEST END GREENS RANGPURI	123	Other Outage	Unplanned Outage	19-09-2025	13:20	19-09-2025	14:03	0:43	0.000884	CABLE FAULT
722	19-09-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA,KAPAS HERA ESTATE,	2571	Other Outage	Planned Outage	19-09-2025	11:00	19-09-2025	12:05	1:05	0.001535	BIRD SPIKES INSTALLATION PER POLE
723	19-09-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ,	683	Other Outage	Planned Outage	19-09-2025	11:06	19-09-2025	14:47	3:41	0.004297	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
724	19-09-2025	Part of : ROOPAM WALA KUNWA MEHRAULI,	1146	Other Outage	Planned Outage	19-09-2025	11:12	19-09-2025	15:04	3:52	0.003867	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
725	20-09-2025	Part of : Kapas Hera Extension Kapas Hera,	610	Other Outage	Unplanned Outage	20-09-2025	11:45	20-09-2025	12:35	0:50	0.000806	REPLACEMENT OF RMU SOCKETS
726	20-09-2025	Part of : Avenue Bouganvillea Rangpuri,West End Greens Rangpuri,Harijan Basti Rajokri,Avenue Jhakaranda Golden Griters Rangpuri,	221	Other Outage	Planned Outage	20-09-2025	11:01	20-09-2025	11:39	0:38	0.000000	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
727	20-09-2025	Part of : Sector D Vasant Kunj,	19	Other Outage	Planned Outage	20-09-2025	10:42	20-09-2025	14:26	3:44	0.003733	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
728	20-09-2025	Part of : Slash Pur Village Palam Farms,	3	Other Outage	Planned Outage	20-09-2025	10:06	20-09-2025	13:05	2:59	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF LUGS
729	22-09-2025	Part of : MEHRAULI VILLAGE, IB ARBINDO MARG (HTC)	1694	Other Outage	Unplanned Outage	22-09-2025	02:56	22-09-2025	03:44	0:48	0.001293	HT SYSTEM FAULT
730	22-09-2025	Part of : ANAND GRAM GHITORNI,GHITORNI VILLAGE	2	Other Outage	Planned Outage	22-09-2025	10:44	22-09-2025	12:30	1:46	0.000589	BIRD SPIKES INSTALLATION PER POLE,CLEANING OF INSULATORS PER POLE,CONDUCTOR REPLACEMET PER SPAN,CONNECTING OF NEW EARTHING PER EARTHING
731	22-09-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA,PALAM FARMS	3336	Other Outage	Planned Outage	22-09-2025	11:11	22-09-2025	12:28	1:17	0.001198	BIRD SPIKES INSTALLATION PER POLE
732	22-09-2025	Part of : POCKET 8 SECTOR C VASANT KUNJ	183	Other Outage	Planned Outage	22-09-2025	10:55	22-09-2025	13:55	3:00	0.004250	REPLACEMENT OF LT BUSHING ROD
733	22-09-2025	Part of : MASUDPUR VILLAGE SECTOR B VASANT KUNJ	1	Other Outage	Planned Outage	22-09-2025	11:00	22-09-2025	14:14	3:14	0.003772	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
734	22-09-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	666	Other Outage	Planned Outage	22-09-2025	10:38	22-09-2025	13:47	3:09	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMET OF HT BUSHING ROD
735	23-09-2025	Part of : BLOCK F MAHIPALPUR VILLAGE MAHIPALPUR,BLOCK R MAHIPALPUR VILLAGE MAHIPALPUR,	880	Other Outage	Unplanned Outage	23-09-2025	07:39	23-09-2025	08:28	0:49	0.000953	MAINTENANCE/REPAIR OF RMU
736	23-09-2025	Part of : KAPAS HERA EXTENSION KAPAS HERA,KAPAS HERA ESTATE,	2073	Other Outage	Planned Outage	23-09-2025	11:00	23-09-2025	11:57	0:57	0.000887	BIRD SPIKES INSTALLATION PER POLE
737	23-09-2025	Part of : GHITORNI VILLAGE GHITORNI,	45	Other Outage	Planned Outage	23-09-2025	10:17	23-09-2025	13:00	2:43	0.000906	BIRD SPIKES INSTALLATION PER POLE,CONDUCTOR REPLACEMET PER SPAN,TIGHTENING OF HARDWARE FITTINGS
738	23-09-2025	Part of : RUCHI VIHAR VASANT KUNJ,	1	Other Outage	Planned Outage	23-09-2025	10:48	23-09-2025	13:22	2:34	0.002994	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
739	24-09-2025	Part of : KAPAS HERA ESTATE,AVENUE BOUGANVILLEA RANGPURI,YAWANTIKA COLONY RANGPURI,AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	303	Other Outage	Planned Outage	24-09-2025	10:49	24-09-2025	11:44	0:55	0.000901	BIRD SPIKES INSTALLATION PER POLE
740	24-09-2025	Part of : SECTOR D VASANT KUNJ,GHITORNI VILLAGE	100	Other Outage	Planned Outage	24-09-2025	10:26	24-09-2025	14:53	4:27	0.001483	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
741	24-09-2025	Part of : RUCHI VIHAR VASANT KUNJ	643	Other Outage	Planned Outage	24-09-2025	11:06	24-09-2025	14:53	3:47	0.003153	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
742	24-09-2025	Part of : BLOCK A & L MAHIPALPUR VILLAGE,MAHIPALPUR EXTENSION,INDIRA GANDHI INTERNATIONAL AIRPORT	3829	Other Outage	Planned Outage	24-09-2025	10:28	24-09-2025	14:00	3:32	0.005594	REPLACEMENT OF LT BUSHING ROD
743	24-09-2025	Part of : LAKHI NATH KUTI MEHRAULI	556	Other Outage	Planned Outage	24-09-2025	10:46	24-09-2025	15:45	4:59	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING
744	24-09-2025	Part of : NAYAK PURA BIJWASAN	1253	Other Outage	Planned Outage	24-09-2025	10:19	24-09-2025	13:19	3:00	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,MEASUREMET OF INSULATION RESISTANCE
745	25-09-2025	Part of : SAMALKA	81	Other Outage	Unplanned Outage	25-09-2025	22:20	25-09-2025	22:53	0:33	0.001109	TREE TOUCHING
746	25-09-2025	Part of : RUCHI VIHAR,B-BLOCK NANGAL DEWAT & IAA COLONY SECTOR D VASANT KUNJ	2915	Other Outage	Unplanned Outage	25-09-2025	12:20	25-09-2025	13:08	0:48	0.000000	BIRDAGE
747	25-09-2025	Part of : AVENUE BOUGANVILLEA RANGPURI,WEST END GREENS	221	Other Outage	Planned Outage	25-09-2025	11:01	25-09-2025	12:07	1:06	0.001430	BIRD SPIKES INSTALLATION PER POLE
748	25-09-2025	Part of : GANDHI COLONY MEHRAULI	542	Other Outage	Planned Outage	25-09-2025	11:50	25-09-2025	14:11	2:21	0.000000	OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER
749	25-09-2025	Part of : ANAND GRAM GHITORNI	108	Other Outage	Planned Outage	25-09-2025	10:51	25-09-2025	13:57	3:06	0.001033	BIRD SPIKES INSTALLATION
750	25-09-2025	Part of : POCKET 11 SECTOR B VASANT KUNJ	141	Other Outage	Planned Outage	25-09-2025	10:54	25-09-2025	14:40	3:46	0.004394	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
751	25-09-2025	Part of : NAYAK PURA BIJWASAN	569	Other Outage	Planned Outage	25-09-2025	10:29	25-09-2025	14:06	3:37	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
752	26-09-2025	Part of : SECTOR D VASANT KUNJ, GHITORNI VILLAGE	156	Other Outage	Planned Outage	26-09-2025	10:45	26-09-2025	12:24	1:39	0.000550	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN,TAPPING OF JUMPERS
753	26-09-2025	Part of : SAMALKA	51	Other Outage	Planned Outage	26-09-2025	11:01	26-09-2025	12:09	1:08	0.001606	BIRD SPIKES INSTALLATION PER POLE
754	26-09-2025	Part of : ISLAM COLONY MEHRAULI	783	Other Outage	Planned Outage	26-09-2025	10:46	26-09-2025	13:30	2:44	0.000000	CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
755	26-09-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ	1	Other Outage	Planned Outage	26-09-2025	09:57	26-09-2025	13:14	3:17	0.002736	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
756	27-09-2025	Part of : INDIRA GANDHI INTERNATIONAL AIRPORT	1	Other Outage	Unplanned Outage	27-09-2025	11:17	27-09-2025	12:00	0:43	0.000287	CABLE FAULT
757	27-09-2025	Part of : POCKET 8 SECTOR B VASANT KUNJ,POCKET B 10 SECTOR B VASANT KUNJ	504	Other Outage	Unplanned Outage	27-09-2025	02:29	27-09-2025	03:11	0:42	0.000245	CABLE FAULT
758	27-09-2025	Part of : PALAM FARMS,	895	Other Outage	Planned Outage	27-09-2025	10:52	27-09-2025	12:52	2:00	0.005000	BIRD SPIKES INSTALLATION PER POLE,CONNECTING OF NEW EARTHING PER EARTHING,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
759	27-09-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ,	16	Other Outage	Planned Outage	27-09-2025	14:07	27-09-2025	16:59	2:52	0.002867	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
760	27-09-2025	Part of : ISLAM COLONY MEHRAULI,	579	Other Outage	Planned Outage	27-09-2025	10:29	27-09-2025	13:24	2:55	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
761	27-09-2025	Part of : AVENUE BOUGANVILLEA RANGPURI,WEST END GREENS RANGPURI,HARIJAN BASTI RAJOKRI,AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI,	221	Other Outage	Planned Outage	27-09-2025	10:59	27-09-2025	13:11	2:12	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
762	27-09-2025	Part of : ANAND GRAM GHITORNI,	3	Other Outage	Planned Outage	27-09-2025	10:29	27-09-2025	13:55	3:26	0.001144	BIRD SPIKES INSTALLATION PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
763	28-09-2025	Part of : MAHIPALPUR VILLAGE	628	Other Outage	Unplanned Outage	28-09-2025	01:41	28-09-2025	02:03	0:22	0.000116	CABLE FAULT
764	29-09-2025	Part of : GHITORNI VILLAGE, SECTOR D VASANT KUNJ	101	Other Outage	Planned Outage	29-09-2025	10:28	29-09-2025	12:24	1:56	0.000483	BIRD SPIKES INSTALLATION PER POLE
765	29-09-2025	Part of : AVENUE BOUGANVILLEA RANGPURI, WEST END GREENS RANGPURI, HARIJAN BASTI RAJOKRI	221	Other Outage	Planned Outage	29-09-2025	11:02	29-09-2025	12:33	1:31	0.000000	REGULAR TRIMMING AND REMOVAL OF TREES
766	29-09-2025	Part of : SLASH PUR VILLAGE PALAM FARMS	183	Other Outage	Planned Outage	29-09-2025	10:52	29-09-2025	12:22	1:30	0.000000	APPLY OF INSULATION TAPE HT BUSHINGS
767	29-09-2025	Part of : GHITORNI VILLAGE	413	Other Outage	Planned Outage	29-09-2025	11:43	29-09-2025	14:09	2:26	0.004461	3PH DB REPLACEMENT
768	29-09-2025	Part of : RANGPURI PAHARI	365	Other Outage	Planned Outage	29-09-2025	10:58	29-09-2025	14:04	3:06	0.004650	REPLACEMENT OF HT BUSHING
769	29-09-2025	Part of : IAA COLONY SECTOR D VASANT KUNJ	3	Other Outage	Planned Outage	29-09-2025	11:19	29-09-2025	14:12	2:53	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HTCABLES)
770	29-09-2025	Part of : TEACHER COLONY MEHRAULI	843	Other Outage	Planned Outage	29-09-2025	10:19	29-09-2025	13:48	3:29	0.000000	CHECKING OF EARTHING VALUE OF BODY
771	30-09-2025	Part of : DALMIA VIHAR BIJWASAN	332	Other Outage	Unplanned Outage	30-09-2025	10:20	30-09-2025	13:05	2:45	0.000000	MOBILE TRANSFORMER REPLACEMENT
772	30-09-2025	Part of : ANAND GRAM GHITORNI	398	Other Outage	Planned Outage	30-09-2025	11:46	30-09-2025	12:56	1:10	0.000000	3PH DB REVAMPING
773	30-09-2025	Part of : RAJOKRI VILLAGE, WEST END GREENS RANGPURI, AVENUE JHAKARANDA GOLDEN GRITERS RANGPURI	1653	Other Outage	Planned Outage	30-09-2025	10:58	30-09-2025	13:07	2:09	0.003118	BIRD SPIKES INSTALLATION PER POLE
774	30-09-2025	Part of : RUCHI VIHAR VASANT KUNJ	2	Other Outage	Planned Outage	30-09-2025	11:24	30-09-2025	14:02	2:38	0.002633	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
775	30-09-2025	Part of : SHAHABAD MUHAMMADPUR VILLAGE DWARKA	619	Other Outage	Planned Outage	30-09-2025	10:22	30-09-2025	12:39	2:17	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF LUGS,SUB STATION CLEANING TIGHTENFENG OF NUT BOLT
776	02-09-2025	Part of : CHANDAN PARK DWARKA, RAJU ENCLAVE SECTOR 15 DWARKA, PATEL GARDEN SECTOR 15 DWARKA, SURAJ VIHAR DWARKA	4498	Other Outage	Unplanned Outage	02-09-2025	00:08	02-09-2025	00:53	0:45	0.000988	CABLE FAULT
777	04-09-2025	Part of : BLOCK B POCKET 8 SECTOR 12 DWARKA,POCKET 1, 3 & 6 SECTOR 12 DWARKA	1194	Other Outage	Unplanned Outage	04-09-2025	00:02	04-09-2025	00:45	0:43	0.000693	CABLE FAULT
778	04-09-2025	Part of : NAND VIHAR SECTOR 16A DWARKA	1140	Other Outage	Unplanned Outage	04-09-2025	13:19	04-09-2025	15:06	1:47	0.000000	REPAIRING OF HVDS CIRCUIT
779	06-09-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR, JAIN COLONY MATIALA, OLD RAJAPURI	2806	Other Outage	Unplanned Outage	06-09-2025	00:44	06-09-2025	01:09	0:25	0.000528	HT SYSTEM FAULT
780	06-09-2025	Part of : BLOCK B POCKET 8 SECTOR 12 DWARKA,POCKET 1,3 & 6 SECTOR 12 DWARKA,BLOCK A SECTOR 12 DWARKA	1193	Other Outage	Unplanned Outage	06-09-2025	19:23	06-09-2025	20:23	1:00	0.001933	CABLE FAULT
781	07-09-2025	Part of : SECTOR 11 DWARKA,POCKET 1 SECTOR-5 MARKET SECTOR 5 DWARKA,SECTOR 5 DWARKA,POCKET 1 SECTOR 11 DWARKA	2130	Other Outage	Unplanned Outage	07-09-2025	14:05	07-09-2025	14:48	0:43	0.001111	HT SYSTEM FAULT
782	08-09-2025	Part of : HARI VIHAR SECTOR 16A DWARKA,NAND VIHAR SECTOR 16A DWARKA,KAKRAULA VILLAGE DWARKA	4868	Other Outage	Unplanned Outage	08-09-2025	11:28	08-09-2025	12:59	1:31	0.000000	REPAIRING OF HVDS CIRCUIT
783	08-09-2025	Part of : POCKET 1 SECTOR 2 DWARKA	186	Other Outage	Planned Outage	08-09-2025	11:13	08-09-2025	14:16	3:03	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
784	08-09-2025	Part of : POCKET 1 SECTOR 4 DWARKA	108	Other Outage	Planned Outage	08-09-2025	10:34	08-09-2025	14:28	3:54	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
785	10-09-2025	Part of : SECTOR 18B DWARKA	1742	Other Outage	Unplanned Outage	10-09-2025	10:02	10-09-2025	10:38	0:36	0.000470	CABLE FAULT
786	10-09-2025	Part of : D-BLOCK MADHU VIHAR	680	Other Outage	Planned Outage	10-09-2025	11:55	10-09-2025	15:26	3:31	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
787	11-09-2025	Part of : BLOCK G VISWAS PARK MATIALA,BLOCK B SANJAY ENCLAVE UTTAM NAGAR,BLOCK A SANJAY ENCLAVE UTTAM NAGAR,BHAGWATI VIHAR BINDAPUR,BLOCK B SUBHASH PARK MATIALA	2959	Other Outage	Unplanned Outage	11-09-2025	11:14	11-09-2025	11:58	0:44	0.000196	CABLE FAULT
788	11-09-2025	Part of : POCKET 1 SECTOR-5 MARKET SECTOR 5 DWARKA,SECTOR 11 DWARKA,POCKET 1 SECTOR 11 DWARKA,SECTOR 5 DWARKA	2130	Other Outage	Unplanned Outage	11-09-2025	01:56	11-09-2025	02:38	0:42	0.000898	TREE TOUCHING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
789	12-09-2025	Part of : BLOCK G VISWAS PARK MATIALA,BLOCK A & B SANJAY ENCLAVE UTTAM NAGAR,BHAGWATI VIHAR BINDAPUR	2959	Other Outage	Unplanned Outage	12-09-2025	16:58	12-09-2025	17:59	1:01	0.000000	REPARING OF RMU
790	12-09-2025	Part of : POCKET 1 SECTOR-5 MARKET SECTOR 5 DWARKA,SECTOR 11 DWARKA	2130	Other Outage	Unplanned Outage	12-09-2025	16:06	12-09-2025	17:57	1:51	0.000000	REPARING OF RMU
791	12-09-2025	Part of : BLOCK A3 UTTAM VIHAR BINDAPUR	1387	Other Outage	Planned Outage	12-09-2025	11:27	12-09-2025	15:32	4:05	0.000000	REPLACEMENT OF LT BUSHING ROD,TIGHTENEING OF NUT BOLT
792	12-09-2025	Part of : SECTOR 6 DWARKA	108	Other Outage	Planned Outage	12-09-2025	10:23	12-09-2025	13:37	3:14	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
793	13-09-2025	Part of : SECTOR 6 DWARKA	135	Other Outage	Planned Outage	13-09-2025	10:28	13-09-2025	14:06	3:38	0.000000	REPLACEMET OF LT BUSHING ROD
794	14-09-2025	Part of : POCKET 3 SECTOR 16B DWARKA	239	Other Outage	Unplanned Outage	14-09-2025	18:38	14-09-2025	19:26	0:48	0.000000	CABLE FAULT
795	14-09-2025	Part of : SUKH RAM PARK MATIALA, POCKET 1 SECTOR 3 MATIALA, SUBHASH PARK MATIALA	2884	Other Outage	Unplanned Outage	14-09-2025	12:47	14-09-2025	13:31	0:44	0.001088	CABLE FAULT
796	15-09-2025	Part of : SECTOR 6 DWARKA,	111	Other Outage	Planned Outage	15-09-2025	10:51	15-09-2025	14:26	3:35	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
797	16-09-2025	Part of : BLOCK RZ B & G RAJAPURI MATIALA,BLOCK G JAIN COLONY MATIALA,BLOCK B SUBHASH PARK MATIALA	3701	Other Outage	Unplanned Outage	16-09-2025	22:05	16-09-2025	22:57	0:52	0.002874	CABLE FAULT
798	16-09-2025	Part of : BLOCK B RAJAPURI MATIALA	857	Other Outage	Planned Outage	16-09-2025	11:16	16-09-2025	13:47	2:31	0.000000	REPLACEMENT OF LT BUSHING ROD
799	18-09-2025	Part of : SECTOR 3 DWARKA	1715	Other Outage	Unplanned Outage	18-09-2025	18:47	18-09-2025	19:37	0:50	0.000542	HT SYSTEM FAULT
800	18-09-2025	Part of : POCKET 3 SECTOR 11 DWARKA	214	Other Outage	Planned Outage	18-09-2025	11:02	18-09-2025	14:17	3:15	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
801	19-09-2025	Part of : JAIN COLONY MATIALA,	581	Other Outage	Planned Outage	19-09-2025	11:40	19-09-2025	14:40	3:00	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
802	19-09-2025	Part of : POCKET 1 SECTOR 11 DWARKA,	173	Other Outage	Planned Outage	19-09-2025	10:06	19-09-2025	13:34	3:28	0.000000	REPLACEMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
803	21-09-2025	Part of : HAR NAGAR SECTOR 16 DWARKA,D1-BLOCK MANSA RAM PARK,NISHAT PARK SECTOR,RAJU ENCLAVE,HARI VIHAR SECTOR 15 DWARKA,TARA NAGAR,TRANSIT CAMP	6992	Other Outage	Unplanned Outage	21-09-2025	23:53	22-09-2025	00:37	0:44	0.000134	CABLE FAULT
804	22-09-2025	Part of : BHARAT VIHAR DWARKA,RAJU PARAK EXTENSION DWARKA	5589	Other Outage	Unplanned Outage	22-09-2025	11:23	22-09-2025	13:13	1:50	0.000000	REPAIR/REPLACEMENT WORK OF HVDS CABLE
805	23-09-2025	Part of : POCKET 4 SECTOR 11 DWARKA,	322	Other Outage	Planned Outage	23-09-2025	10:15	23-09-2025	14:00	3:45	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
806	25-09-2025	Part of : SUKH RAM PARK MATIALA,SUBHASH PARK MATIALA	2885	Other Outage	Planned Outage	25-09-2025	10:31	25-09-2025	13:26	2:55	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
807	26-09-2025	Part of : CHANDAN PARK DWARKA, RAJU ENCLAVE SECTOR 15 DWARKA, HARI VIHAR SECTOR 16A DWARKA, SURAJ VIHAR DWARKA	4520	Other Outage	Unplanned Outage	26-09-2025	11:29	26-09-2025	12:22	0:53	0.000250	HT SYSTEM FAULT
808	27-09-2025	Part of : RMU NEAR 756LIG HOUSES SEC-14,DWK, S/STN -1 1568 DDA FLATS SEC-14,DWK, BHARAT VIHAR D BLK HVDS GALI NO-5, HTC:SARV PRIYA CGHS PLOT 14/1,SEC-14	0	Other Outage	Unplanned Outage	27-09-2025	05:59	27-09-2025	06:43	0:44	0.000367	BIRDAGE
809	27-09-2025	Part of : BLOCK G VISWAS PARK MATIALA,	629	Other Outage	Planned Outage	27-09-2025	11:16	27-09-2025	12:13	0:57	0.000000	SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
810	27-09-2025	Part of : POCKET 3 SECTOR 12 DWARKA,	160	Other Outage	Planned Outage	27-09-2025	10:51	27-09-2025	12:57	2:06	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
811	27-09-2025	Part of : SECTOR 3 DWARKA,SUBHASH PARK MATIALA,JAIN PARK OM VIHAR UTTAM NAGAR,BLOCK T PARAM PURI UTTAM NAGAR,PARAM PURI UTTAM NAGAR,NANHEY PARK OM VIHAR UTTAM NAGAR,BLOCK B SUBHASH PARK MATIALA,	1325	Other Outage	Planned Outage	27-09-2025	10:53	27-09-2025	12:57	2:04	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
812	28-09-2025	Part of : POCKET 1 SECTOR 4 DWARKA,POCKET 1 SECTOR-5 MARKET SECTOR 5 DWARKA	919	Other Outage	Unplanned Outage	28-09-2025	13:52	28-09-2025	14:24	0:32	0.000293	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
813	29-09-2025	Part of : SECTOR 3 DWARKA,A-BLOCK RAJAPURI MATIALA	1877	Other Outage	Unplanned Outage	29-09-2025	16:20	29-09-2025	16:59	0:39	0.001213	BIRDAGE
814	29-09-2025	Part of : POCKET 1 SECTOR 12 DWARKA	288	Other Outage	Planned Outage	29-09-2025	13:46	29-09-2025	15:44	1:58	0.000000	REPLACEMET OF LT BUSHING
815	30-09-2025	Part of : SECTOR 12 DWARKA	1669	Other Outage	Unplanned Outage	30-09-2025	13:32	30-09-2025	14:28	0:56	0.002473	TREE BRANCH FALLEN ON O/H LINE
816	30-09-2025	Part of : BHARAT VIHAR DWARKA, TRANSIT CAMP DWARKA, POCKET 1 SECTOR 14 DWARKA	5351	Other Outage	Unplanned Outage	30-09-2025	10:29	30-09-2025	11:18	0:49	0.000422	CABLE FAULT
817	30-09-2025	Part of : SECTOR 12 DWARKA	218	Other Outage	Planned Outage	30-09-2025	10:32	30-09-2025	12:49	2:17	0.000000	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
818	01-09-2025	Part of : KAIR VILLAGE,MANDHELA KHURD VILLAGE	1928	Other Outage	Unplanned Outage	01-09-2025	16:35	01-09-2025	17:33	0:58	0.000483	TREE TOUCHING
819	03-09-2025	Part of : JAIN PUR VILLAGE,	270	Other Outage	Planned Outage	03-09-2025	11:02	03-09-2025	13:00	1:58	0.001639	TRANSFORMER MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
820	03-09-2025	Part of : BAQAR GARH VILLAGE,	303	Other Outage	Planned Outage	03-09-2025	10:17	03-09-2025	12:45	2:28	0.002056	TRANSFORMER MAINTENANCE
821	04-09-2025	Part of : AIR FORCE STATION DHANSA (HTC)	0	Other Outage	Unplanned Outage	04-09-2025	08:20	04-09-2025	08:23	0:03	0.000005	HT SYSTEM FAULT
822	06-09-2025	Part of : KAIR VILLAGE, NIKHIL VIHAR EXTN., MANDHELA KHURD VILLAGE	1927	Other Outage	Unplanned Outage	06-09-2025	08:44	06-09-2025	09:59	1:15	0.000813	TREE BRANCH FALLEN ON HT LINE
823	06-09-2025	Part of : SARANGPUR VILLAGE	179	Other Outage	Planned Outage	06-09-2025	12:06	06-09-2025	15:01	2:55	0.002431	REPLACEMET OF HT BUSHING ROD
824	06-09-2025	Part of : GHUMAN HERA JAINPUR VILLAGE	246	Other Outage	Planned Outage	06-09-2025	12:50	06-09-2025	15:40	2:50	0.002361	REPLACEMET OF HT BUSHING ROD
825	06-09-2025	Part of : DARYAPUR KHURD VILLAGE	460	Other Outage	Planned Outage	06-09-2025	11:29	06-09-2025	14:28	2:59	0.002486	REPLACEMENT OF LT BUSHING ROD
826	06-09-2025	Part of : BADHOSRA	451	Other Outage	Planned Outage	06-09-2025	11:08	06-09-2025	13:43	2:35	0.002153	REPLACEMENT OF HT BUSHING ROD
827	06-09-2025	Part of : KHERA DABAS VILLAGE	692	Other Outage	Planned Outage	06-09-2025	10:49	06-09-2025	13:14	2:25	0.002014	REPLACEMENT OF LT BUSHING ROD
828	08-09-2025	Part of : BABA HARI DAS ENCLAVE JHARODA KALAN	470	Other Outage	Planned Outage	08-09-2025	12:46	08-09-2025	16:52	4:06	0.006833	REPLACEMENT OF HT BUSHING ROD
829	08-09-2025	Part of : KAIR VILLAGE	1	Other Outage	Planned Outage	08-09-2025	10:58	08-09-2025	14:26	3:28	0.002889	REPLACEMENT OF LT BUSHING ROD
830	08-09-2025	Part of : MALIKPUR ZER VILLAGE,SAMAZPUR KHALSA,JAFARPUR KALAN VILLAGE	1655	Other Outage	Planned Outage	08-09-2025	10:59	08-09-2025	15:22	4:23	0.007306	REPLACEMET OF HT BUSHING ROD
831	08-09-2025	Part of : DAURALA VILLAGE	184	Other Outage	Planned Outage	08-09-2025	11:01	08-09-2025	13:59	2:58	0.002472	REPLACEMET OF HT BUSHING ROD
832	08-09-2025	Part of : BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH	546	Other Outage	Planned Outage	08-09-2025	08:29	08-09-2025	12:09	3:40	0.003056	REPLACEMET OF HT BUSHING ROD
833	09-09-2025	Part of : GOPAL EXTENSION,Z-BLOCK CHETAN VIHA,NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	3018	Other Outage	Unplanned Outage	09-09-2025	14:08	09-09-2025	14:46	0:38	0.001056	ATTENDING WEAK POINTS/HOT SPOT
834	09-09-2025	Part of : D-BLOCK BANGALI COLONY NAVEEN PALACE JHARODA KALAN	657	Other Outage	Planned Outage	09-09-2025	16:22	09-09-2025	17:10	0:48	0.000667	REPLACEMET OF HT BUSHING ROD
835	09-09-2025	Part of : MITRAON VILLAGE NAJAFGARH	590	Other Outage	Planned Outage	09-09-2025	10:58	09-09-2025	14:26	3:28	0.002889	REPLACEMET OF HT BUSHING ROD
836	09-09-2025	Part of : DARYAPUR KHURD VILLAGE,GHUMAN HERA JAINPUR VILLAGE,SHERPUR DERI,JAIN PUR VILLAGE,SHERPUR EXTENTION,ASALATPUR KHAWAD	2888	Other Outage	Planned Outage	09-09-2025	10:02	09-09-2025	12:57	2:55	0.003889	REPLACEMET OF HT BUSHING ROD
837	09-09-2025	Part of : UJWA VILLAGE,JAFARPUR KALAN VILLAGE,DARYAPUR KHURD VILLAGE,MALIKPUR ZER VILLAGE,KHERA DABAS VILLAGE,QAZIPUR VILLAGE,SAMAZPUR KHALSA	2667	Other Outage	Planned Outage	09-09-2025	10:23	09-09-2025	14:56	4:33	0.003792	GUARD WIRES SAGGING
838	10-09-2025	Part of : QAZIPUR VILLAGE	273	Other Outage	Planned Outage	10-09-2025	11:22	10-09-2025	13:46	2:24	0.002000	REPLACEMET OF HT BUSHING ROD
839	10-09-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	970	Other Outage	Planned Outage	10-09-2025	11:03	10-09-2025	13:56	2:53	0.002403	REPLACEMENT OF LT BUSHING ROD
840	10-09-2025	Part of : JHULJHULI VILLAGE	262	Other Outage	Planned Outage	10-09-2025	11:00	10-09-2025	13:55	2:55	0.002431	REPLACEMET OF HT BUSHING ROD
841	10-09-2025	Part of : KAIR VILLAGE	6	Other Outage	Planned Outage	10-09-2025	11:22	10-09-2025	14:05	2:43	0.002264	REPLACEMET OF HT BUSHING ROD
842	11-09-2025	Part of : KAIR VILLAGE,	390	Other Outage	Planned Outage	11-09-2025	11:22	11-09-2025	12:48	1:26	0.000239	REPLACEMET OF HT BUSHING ROD
843	11-09-2025	Part of : DARYAPUR KHURD VILLAGE,GHUMAN HERA JAINPUR VILLAGE,SHERPUR DERI,JAIN PUR VILLAGE,SHERPUR EXTENTION,ASALATPUR KHAWAD,	2888	Other Outage	Planned Outage	11-09-2025	12:01	11-09-2025	15:00	2:59	0.002486	GUARD WIRE LACS INSTALLTION PER SPAN
844	11-09-2025	Part of : UJWA VILLAGE,	513	Other Outage	Planned Outage	11-09-2025	10:01	11-09-2025	12:55	2:54	0.002417	REPLACEMET OF HT BUSHING ROD
845	12-09-2025	Part of : KAIR VILLAGE	159	Other Outage	Planned Outage	12-09-2025	10:58	12-09-2025	12:40	1:42	0.002833	REPLACEMET OF HT BUSHING ROD
846	12-09-2025	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE JHARODA KALAN,KRISHAN VIHAR NAJAFGARH	13	Other Outage	Planned Outage	12-09-2025	13:36	12-09-2025	15:57	2:21	0.000392	REPLACEMET OF HT BUSHING ROD
847	12-09-2025	Part of : RAWTA VILLAGE,GHUMANHERA,GHUMAN HERA JAINPUR VILLAGE,DARYAPUR KHURD VILLAGE,DAURALA VILLAGE,GHALLBPUR VILLAGE	1908	Other Outage	Planned Outage	12-09-2025	11:12	12-09-2025	13:52	2:40	0.002222	GUARD WIRE LACS INSTALLTION PER SPAN
848	12-09-2025	Part of : DHANSA VILLAGE	380	Other Outage	Planned Outage	12-09-2025	11:02	12-09-2025	13:52	2:50	0.002361	REPLACEMET OF HT BUSHING ROD
849	12-09-2025	Part of : UJWA VILLAGE,JAFARPUR KALAN VILLAGE,DARYAPUR KHURD VILLAGE,MALIKPUR ZER VILLAGE,KHERA DABAS VILLAGE,QAZIPUR VILLAGE	2667	Other Outage	Planned Outage	12-09-2025	10:06	12-09-2025	12:55	2:49	0.005164	REPLACEMET OF HT BUSHING ROD
850	13-09-2025	Part of : MANDHELA KHURD VILLAGE	12	Other Outage	Planned Outage	13-09-2025	12:23	13-09-2025	13:46	1:23	0.002306	REPLACEMET OF HT BUSHING ROD
851	13-09-2025	Part of : GOPAL NAGAR NAJAFGARH	489	Other Outage	Planned Outage	13-09-2025	11:17	13-09-2025	14:58	3:41	0.003069	REPLACEMENT OF LT BUSHING ROD
852	13-09-2025	Part of : BLOCK D BANGALI COLONY NAVEEN PALACE,KRISHAN VIHAR NAJAFGARH,	7	Other Outage	Planned Outage	13-09-2025	11:22	13-09-2025	14:57	3:35	0.002986	REPLACEMET OF HT BUSHING ROD
853	13-09-2025	Part of : SUREHRA VILLAGE	10	Other Outage	Planned Outage	13-09-2025	10:04	13-09-2025	13:18	3:14	0.005389	REPLACEMET OF HT BUSHING ROD
854	15-09-2025	Part of : GOPAL NAGAR NAJAFGARH,SHYAM ENCAVE NAJAFGARH,MITRAON VILLAGE NAJAFGARH,BASCO COLONY ARYA NAGAR NAJAFGARH,KRISHAN VIHAR NAJAFGARH	3086	Other Outage	Unplanned Outage	15-09-2025	13:32	15-09-2025	14:10	0:38	0.000633	ELECTROCUTION OF SQUIRREL
855	15-09-2025	Part of : GHUMAN HERA JAINPUR VILLAGE,	245	Other Outage	Planned Outage	15-09-2025	14:03	15-09-2025	16:09	2:06	0.003500	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
856	15-09-2025	Part of : DARYAPUR KHURD VILLAGE,	460	Other Outage	Planned Outage	15-09-2025	11:05	15-09-2025	14:25	3:20	0.002778	REPLACEMET OF HT BUSHING ROD
857	15-09-2025	Part of : BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,	389	Other Outage	Planned Outage	15-09-2025	09:32	15-09-2025	12:01	2:29	0.002069	REPLACEMENT OF LT BUSHING ROD
858	16-09-2025	Part of : SURAKHPUR,MITRAON VILLAGE NAJAFGARH	8	Other Outage	Unplanned Outage	16-09-2025	11:20	16-09-2025	12:15	0:55	0.000092	HT SYSTEM FAULT
859	16-09-2025	Part of : KHARKHARI JATMAL VILLAGE	307	Other Outage	Planned Outage	16-09-2025	14:52	16-09-2025	16:26	1:34	0.001306	REPLACEMET OF HT BUSHING ROD
860	16-09-2025	Part of : RAWTA VILLAGE	277	Other Outage	Planned Outage	16-09-2025	10:59	16-09-2025	13:59	3:00	0.002500	REPLACEMET OF HT BUSHING ROD
861	16-09-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	970	Other Outage	Planned Outage	16-09-2025	11:31	16-09-2025	13:47	2:16	0.001889	REPLACEMET OF HT BUSHING ROD
862	16-09-2025	Part of : MITRAON VILLAGE NAJAFGARH	13	Other Outage	Planned Outage	16-09-2025	11:01	16-09-2025	14:04	3:03	0.002542	REPLACEMET OF HT BUSHING ROD
863	17-09-2025	Part of : BASCO COLONY ARYA NAGAR NAJAFGARH	42	Other Outage	Planned Outage	17-09-2025	12:48	17-09-2025	14:00	1:12	0.001000	REPLACEMET OF HT BUSHING ROD
864	17-09-2025	Part of : DHANSA VILLAGE	261	Other Outage	Planned Outage	17-09-2025	11:16	17-09-2025	13:11	1:55	0.001597	REPLACEMET OF HT BUSHING ROD
865	17-09-2025	Part of : MANDHELA KHURD VILLAGE,KAIR VILLAGE,MANDHELA KALAN VILLAGE,RAWTA JAFARPUR KALAN VILLAGE,MITRAON VILLAGE NAJAFGARH	841	Other Outage	Planned Outage	17-09-2025	13:22	17-09-2025	15:42	2:20	0.001944	REPLACEMET OF HT BUSHING ROD
866	17-09-2025	Part of : SAMAZPUR KHALSA	356	Other Outage	Planned Outage	17-09-2025	10:44	17-09-2025	14:02	3:18	0.000550	REPLACEMET OF HT BUSHING ROD
867	17-09-2025	Part of : MITRAON VILLAGE NAJAFGARH	240	Other Outage	Planned Outage	17-09-2025	10:09	17-09-2025	12:50	2:41	0.002236	REPLACEMET OF HT BUSHING ROD
868	18-09-2025	Part of : BLOCK Z CHETAN VIHAR, SHYAM ENCLAVE, GOPAL EXTENSION II NAJAFGARH, NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	3045	Other Outage	Unplanned Outage	18-09-2025	14:26	18-09-2025	15:16	0:50	0.000000	HVDS FAULT
869	18-09-2025	Part of : DARYAPUR KHURD VILLAGE	461	Other Outage	Planned Outage	18-09-2025	12:01	18-09-2025	14:12	2:11	0.000364	REPLACEMET OF HT BUSHING ROD
870	18-09-2025	Part of : GOPAL NAGAR NAJAFGARH	489	Other Outage	Planned Outage	18-09-2025	11:06	18-09-2025	14:04	2:58	0.002472	REPLACEMENT OF LT BUSHING ROD
871	18-09-2025	Part of : KAIR VILLAGE	674	Other Outage	Planned Outage	18-09-2025	11:05	18-09-2025	13:31	2:26	0.000811	INSTALLATION OF BUS BAR
872	18-09-2025	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH, NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	2316	Other Outage	Planned Outage	18-09-2025	10:00	18-09-2025	12:45	2:45	0.002292	REPLACEMET OF HT BUSHING ROD
873	19-09-2025	Part of : KAIR VILLAGE,	5	Other Outage	Planned Outage	19-09-2025	11:20	19-09-2025	12:33	1:13	0.002028	REPLACEMET OF HT BUSHING ROD
874	19-09-2025	Part of : BADHOSRA,	840	Other Outage	Planned Outage	19-09-2025	11:01	19-09-2025	13:49	2:48	0.002333	REPLACEMENT OF LT BUSHING ROD
875	19-09-2025	Part of : BABA HARI DAS ENCLAVE JHARODA KALAN,	471	Other Outage	Planned Outage	19-09-2025	11:06	19-09-2025	14:09	3:03	0.002542	REPLACEMENT OF LT BUSHING ROD
876	19-09-2025	Part of : SARANGPUR VILLAGE,GHALLBPUR VILLAGE,JHULJHULI VILLAGE,JAFARPUR KALAN VILLAGE,	2089	Other Outage	Planned Outage	19-09-2025	11:02	19-09-2025	14:04	3:02	0.002781	REPLACEMET OF HT BUSHING ROD
877	19-09-2025	Part of : BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,NEHA COLONY NEW GOPAL NAGAR NAJAFGARH,	316	Other Outage	Planned Outage	19-09-2025	10:17	19-09-2025	13:07	2:50	0.002361	REPLACEMET OF HT BUSHING ROD
878	19-09-2025	Part of : SAMAZPUR KHALSA,	357	Other Outage	Planned Outage	19-09-2025	10:02	19-09-2025	13:45	3:43	0.003097	REPLACEMET OF HT BUSHING ROD
879	20-09-2025	Part of : Surehra Village,	17	Other Outage	Planned Outage	20-09-2025	12:26	20-09-2025	14:53	2:27	0.002042	REPLACEMENT OF HT BUSHING ROD
880	20-09-2025	Part of : Rawta Village,	302	Other Outage	Planned Outage	20-09-2025	11:12	20-09-2025	13:47	2:35	0.002153	REPLACEMENT OF HT BUSHING ROD
881	20-09-2025	Part of : Ujwa Village,	461	Other Outage	Planned Outage	20-09-2025	10:00	20-09-2025	12:53	2:53	0.002403	REPLACEMENT OF LT BUSHING ROD
882	22-09-2025	Part of : GHUMAN HERA JAINPUR VILLAGE	243	Other Outage	Planned Outage	22-09-2025	11:08	22-09-2025	14:04	2:56	0.002444	REPLACEMENT OF HT BUSHING ROD
883	22-09-2025	Part of : SUREHRA VILLAGE	616	Other Outage	Planned Outage	22-09-2025	10:30	22-09-2025	12:58	2:28	0.002056	REPLACEMENT OF HT BUSHING ROD
884	23-09-2025	Part of : KAIR VILLAGE,	653	Other Outage	Planned Outage	23-09-2025	13:14	23-09-2025	15:12	1:58	0.001639	REPLACEMENT OF HT BUSHING ROD
885	23-09-2025	Part of : GHUMAN HERA JAINPUR VILLAGE,	247	Other Outage	Planned Outage	23-09-2025	12:03	23-09-2025	14:58	2:55	0.002431	REPLACEMENT OF HT BUSHING ROD
886	23-09-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE,	970	Other Outage	Planned Outage	23-09-2025	10:32	23-09-2025	13:08	2:36	0.002167	REPLACEMENT OF HT BUSHING ROD
887	24-09-2025	Part of : RAO TULA RAM HOSPITAL (HTC)	1	Other Outage	Planned Outage	24-09-2025	16:00	24-09-2025	17:30	1:30	0.001250	REPLACEMENT OF HT BUSHING ROD
888	24-09-2025	Part of : SHYAM ENCAVE NAJAFGARH	614	Other Outage	Planned Outage	24-09-2025	15:05	24-09-2025	16:40	1:35	0.001319	REPLACEMENT OF HT BUSHING ROD
889	24-09-2025	Part of : MANDHELA KALAN VILLAGE	8	Other Outage	Planned Outage	24-09-2025	13:56	24-09-2025	15:46	1:50	0.001528	REPLACEMENT OF HT BUSHING ROD
890	24-09-2025	Part of : RAWTA VILLAGE,GHUMANHERA,GHUMAN HERA JAINPUR VILLAGE,DARYAPUR KHURD VILLAGE,DAURALA VILLAGE,GHALLBPUR VILLAGE	1908	Other Outage	Planned Outage	24-09-2025	14:44	24-09-2025	16:48	2:04	0.001722	REPLACEMET OF HT BUSHING ROD
891	24-09-2025	Part of : NEHA COLONY NEW GOPAL NAGAR NAJAFGARH	1380	Other Outage	Planned Outage	24-09-2025	10:00	24-09-2025	13:19	3:19	0.002764	3PH HT AB CABLE REPLACEMENT PER SPAN
892	25-09-2025	Part of : MALIKPUR ZER VILLAGE	397	Other Outage	Planned Outage	25-09-2025	15:24	25-09-2025	16:52	1:28	0.002444	REPLACEMET OF HT BUSHING ROD
893	25-09-2025	Part of : ISSAPUR VILLAGE,BAQAR GARH ,BADHOSRA,JAFARPUR KALAN VILLAGE	2814	Other Outage	Planned Outage	25-09-2025	11:23	25-09-2025	12:54	1:31	0.001264	REPLACEMET OF HT BUSHING ROD
894	25-09-2025	Part of : SAMAZPUR KHALSA	359	Other Outage	Planned Outage	25-09-2025	14:02	25-09-2025	16:59	2:57	0.002458	REPLACEMENT OF HT BUSHING ROD
895	25-09-2025	Part of : MANDHELA KALAN VILLAGE	405	Other Outage	Planned Outage	25-09-2025	10:58	25-09-2025	13:32	2:34	0.002139	REPLACEMENT OF LT BUSHING ROD
896	25-09-2025	Part of : SRI HANS NAGAR	496	Other Outage	Planned Outage	25-09-2025	10:07	25-09-2025	13:07	3:00	0.003000	REPLACEMET OF HT BUSHING ROD
897	26-09-2025	Part of : MANDHELA KALAN VILLAGE	280	Other Outage	Planned Outage	26-09-2025	11:01	26-09-2025	13:51	2:50	0.002833	REPLACEMENT OF LT BUSHING ROD
898	26-09-2025	Part of : ISSAPUR VILLAGE	264	Other Outage	Planned Outage	26-09-2025	11:05	26-09-2025	13:51	2:46	0.002306	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
899	26-09-2025	Part of : SARSWATI ENCLAVE GOPAL NAGAR NAJAFGARH	675	Other Outage	Planned Outage	26-09-2025	10:35	26-09-2025	12:57	2:22	0.000789	REPLACEMET OF HT BUSHING ROD
900	26-09-2025	Part of : RAWTA JAFARPUR KALAN VILLAGE	701	Other Outage	Planned Outage	26-09-2025	10:03	26-09-2025	13:01	2:58	0.002472	REPLACEMENT OF LT BUSHING ROD
901	26-09-2025	Part of : GHUMAN HERA JAINPUR VILLAGE	398	Other Outage	Planned Outage	26-09-2025	10:39	26-09-2025	13:00	2:21	0.001958	REPLACEMENT OF LT BUSHING ROD
902	27-09-2025	Part of : DAURALA VILLAGE,	185	Other Outage	Planned Outage	27-09-2025	11:10	27-09-2025	13:56	2:46	0.004611	REPLACEMET OF HT BUSHING ROD
903	27-09-2025	Part of : MANDHELA KALAN VILLAGE,KAIR VILLAGE,	404	Other Outage	Planned Outage	27-09-2025	11:00	27-09-2025	13:12	2:12	0.000733	REPLACEMENT OF LT BUSHING ROD
904	27-09-2025	Part of : BLOCK B NANDA ENCLAVE NEW GOPAL NAGAR NAJAFGARH,	546	Other Outage	Planned Outage	27-09-2025	10:04	27-09-2025	13:15	3:11	0.002653	REPLACEMET OF HT BUSHING ROD
905	29-09-2025	Part of : KAIR VILLAGE,MANDHELA KHURD VILLAGE	1932	Other Outage	Unplanned Outage	29-09-2025	16:11	29-09-2025	16:57	0:46	0.000703	BIRDAGE
906	29-09-2025	Part of : KAIR VILLAGE	675	Other Outage	Planned Outage	29-09-2025	10:58	29-09-2025	13:33	2:35	0.002153	REPLACEMET OF HT BUSHING
907	29-09-2025	Part of : SARANGPUR VILLAGE	462	Other Outage	Planned Outage	29-09-2025	11:02	29-09-2025	14:01	2:59	0.002486	REPLACEMET OF HT BUSHING ROD
908	29-09-2025	Part of : JHULJHULI VILLAGE	213	Other Outage	Planned Outage	29-09-2025	11:02	29-09-2025	14:00	2:58	0.002472	REPLACEMENT OF LT BUSHING
909	29-09-2025	Part of : BLOCK Z CHETAN VIHAR NEW GOPAL NAGAR NAJAFGARH	661	Other Outage	Planned Outage	29-09-2025	10:16	29-09-2025	13:14	2:58	0.002472	REPLACEMET OF HT BUSHING ROD
910	30-09-2025	Part of : RAWTA VILLAGE	270	Other Outage	Planned Outage	30-09-2025	11:05	30-09-2025	14:00	2:55	0.004861	REPLACEMET OF HT BUSHING ROD
911	30-09-2025	Part of : DHANSA VILLAGE	256	Other Outage	Planned Outage	30-09-2025	10:59	30-09-2025	13:45	2:46	0.002306	REPLACEMET OF HT BUSHING ROD
912	03-09-2025	Part of : BLOCK A 4C P AND T COLONY JANAK PURI,	796	Other Outage	Unplanned Outage	03-09-2025	12:31	03-09-2025	13:17	0:46	0.000000	REPAIRING OF LT CIRCUIT
913	04-09-2025	Part of : BLOCK J RAJOURI GARDEN EXTENSION RAJOURI GARDEN,BLOCK 4, 5 & 6 SUBHASH NAGAR	2496	Other Outage	Unplanned Outage	04-09-2025	06:17	04-09-2025	07:13	0:56	0.000576	HT SYSTEM FAULT
914	04-09-2025	Part of : BLOCK BF JANAK PURI	321	Other Outage	Unplanned Outage	04-09-2025	12:50	04-09-2025	15:45	2:55	0.000486	REPAIRING OF HT O/H CIRCUIT
915	05-09-2025	Part of : J-BLOCK RAJOURI GARDEN EXTENSION,BLOCK 4,5 & 6 SUBHASH NAGAR	2496	Other Outage	Unplanned Outage	05-09-2025	15:50	05-09-2025	16:33	0:43	0.000920	HVDS FAULT
916	06-09-2025	Part of : BLOCK 15 & 16 PRESS COLONY MAYAPURI, BLOCK 10,14 & 15 SUBHASH NAGAR JANAKPURI	2276	Other Outage	Unplanned Outage	06-09-2025	02:59	06-09-2025	04:02	1:03	0.001575	HT SYSTEM FAULT
917	06-09-2025	Part of : BLOCK WZ PADAM BASTI NANGAL RAYA JANAK PURI	497	Other Outage	Unplanned Outage	06-09-2025	14:08	06-09-2025	17:32	3:24	0.000567	REPLACEMENT OF LT POLE
918	06-09-2025	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE II	511	Other Outage	Planned Outage	06-09-2025	12:09	06-09-2025	16:47	4:38	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
919	07-09-2025	Part of : BLOCK A 2B ASALATPUR VILLAGE JANAK PURI,DISTRICT CENTRE JANAK PURI,BLOCK A-1 JANAK PURI,BLOCK A-1/ A PART B JANAK PURI	2314	Other Outage	Unplanned Outage	07-09-2025	04:50	07-09-2025	06:21	1:31	0.000632	HT SYSTEM FAULT
920	07-09-2025	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	511	Other Outage	Planned Outage	07-09-2025	12:03	07-09-2025	16:43	4:40	0.003111	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
921	08-09-2025	Part of : POSSANGIPUR,DJB BPS JANAKPURI (HTC)	0	Other Outage	Unplanned Outage	08-09-2025	05:35	08-09-2025	06:27	0:52	0.000520	CABLE FAULT
922	08-09-2025	Part of : BLOCK C 2C JANAK PURI	419	Other Outage	Planned Outage	08-09-2025	12:21	08-09-2025	13:46	1:25	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
923	08-09-2025	Part of : BLOCK CB MAYA ENCLAVE HARI NAGAR	510	Other Outage	Planned Outage	08-09-2025	12:04	08-09-2025	14:09	2:05	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER
924	08-09-2025	Part of : BLOCK A KARAN MARKET NANGAL RAYA JANAK PURI	929	Other Outage	Planned Outage	08-09-2025	11:24	08-09-2025	14:23	2:59	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
925	08-09-2025	Part of : PREM NAGAR JANAK PURI	297	Other Outage	Planned Outage	08-09-2025	11:44	08-09-2025	14:52	3:08	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
926	08-09-2025	Part of : BLOCK R RAJOURI GARDEN	431	Other Outage	Planned Outage	08-09-2025	11:01	08-09-2025	13:49	2:48	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
927	09-09-2025	Part of : C3A-BLOCK RESIDENTIAL COMPLEX JANAK PURI	625	Other Outage	Planned Outage	09-09-2025	11:43	09-09-2025	16:24	4:41	0.001561	LT PRC REPLACEMET
928	09-09-2025	Part of : C-BLOCK FATEH NAGAR	768	Other Outage	Planned Outage	09-09-2025	11:09	09-09-2025	15:31	4:22	0.001456	LT CIRCUIT REPLACEMENT
929	09-09-2025	Part of : ADITI APARTMENTS JANAK PURI	426	Other Outage	Planned Outage	09-09-2025	11:13	09-09-2025	13:59	2:46	0.000922	LT CIRCUIT REPLACEMENT
930	09-09-2025	Part of : C-BLOCK JANAK PURI	147	Other Outage	Planned Outage	09-09-2025	11:07	09-09-2025	14:39	3:32	0.000589	LT CIRCUIT REPLACEMENT
931	09-09-2025	Part of : BLOCK 3 ASHOK NAGAR	322	Other Outage	Planned Outage	09-09-2025	10:58	09-09-2025	14:01	3:03	0.001017	FERRULE PUNCHING LT AB TO LT AB PER FEEDER
932	10-09-2025	Part of : BLOCK C 5B JANAK PURI	294	Other Outage	Planned Outage	10-09-2025	11:58	10-09-2025	14:39	2:41	0.000000	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
933	10-09-2025	Part of : NANGAL RAYA JANAK PURI	1169	Other Outage	Planned Outage	10-09-2025	11:59	10-09-2025	14:35	2:36	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,PRC REPLACEMET PER FEEDER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
934	10-09-2025	Part of : BLOCK A 4C P AND T COLONY JANAK PURI	795	Other Outage	Planned Outage	10-09-2025	11:02	10-09-2025	13:58	2:56	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
935	10-09-2025	Part of : BLOCK G RAJOURI GARDEN	318	Other Outage	Planned Outage	10-09-2025	11:11	10-09-2025	13:31	2:20	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
936	10-09-2025	Part of : BLOCK A NANAK PURA HARI NAGAR	843	Other Outage	Planned Outage	10-09-2025	11:42	10-09-2025	14:59	3:17	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
937	11-09-2025	Part of : BLOCK 6 SUBHASH NAGAR,	432	Other Outage	Planned Outage	11-09-2025	11:35	11-09-2025	14:12	2:37	0.000000	DT REPLACEMENT PER DT
938	11-09-2025	Part of : BLOCK BE HARI NAGAR,	992	Other Outage	Planned Outage	11-09-2025	11:46	11-09-2025	14:01	2:15	0.000000	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
939	11-09-2025	Part of : POSSANGIPUR VILLAGE JANAK PURI,	712	Other Outage	Planned Outage	11-09-2025	12:36	11-09-2025	15:29	2:53	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
940	11-09-2025	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN SAGARPUR,	490	Other Outage	Planned Outage	11-09-2025	11:47	11-09-2025	15:08	3:21	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
941	11-09-2025	Part of : BLOCK C4F JANAK PURI,	643	Other Outage	Planned Outage	11-09-2025	11:41	11-09-2025	14:01	2:20	0.000000	GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
942	12-09-2025	Part of : BLOCK C 2C JANAK PURI	361	Other Outage	Planned Outage	12-09-2025	11:04	12-09-2025	12:49	1:45	0.000000	3PH DB REVAMPING,PRC REPLACEMENT PER FEEDER
943	12-09-2025	Part of : POCKET B 1 B 1 MARKET SUPER BAZAR JANAK PURI	49	Other Outage	Planned Outage	12-09-2025	11:12	12-09-2025	13:59	2:47	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER
944	12-09-2025	Part of : BLOCK WZ NANGAL RAYA JANAK PURI	763	Other Outage	Planned Outage	12-09-2025	11:26	12-09-2025	14:01	2:35	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
945	12-09-2025	Part of : BLOCK A NANAK PURA HARI NAGAR	362	Other Outage	Planned Outage	12-09-2025	11:11	12-09-2025	14:40	3:29	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) CLEANING,TIGHTENEING OF NUT BOLT
946	12-09-2025	Part of : BLOCK 40 ASHOK NAGAR	1142	Other Outage	Planned Outage	12-09-2025	11:10	12-09-2025	14:06	2:56	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
947	13-09-2025	Part of : BLOCK C 2D JANAK PURI	725	Other Outage	Planned Outage	13-09-2025	10:44	13-09-2025	13:04	2:20	0.000778	LT ACB INSTALLATION
948	13-09-2025	Part of : BLOCK 11 RAJOURI GARDEN	693	Other Outage	Planned Outage	13-09-2025	11:00	13-09-2025	13:56	2:56	0.000978	3PH DB REVAMPING,FERRULE PUNCHING LT AB
949	13-09-2025	Part of : CHHOTI SUBJI MANDI JANAK PURI	410	Other Outage	Planned Outage	13-09-2025	11:46	13-09-2025	13:51	2:05	0.000694	APPLY OF INSULATION TAPE LT BUSHINGS
950	13-09-2025	Part of : POCKET J-C HARI ENCLAVE HARI NAGAR	868	Other Outage	Planned Outage	13-09-2025	11:08	13-09-2025	14:07	2:59	0.000994	LT CIRCUIT REPLACEMENT
951	13-09-2025	Part of : BLOCK WZ RC BASTI NANGAL RAYA JANAK PURI	840	Other Outage	Planned Outage	13-09-2025	11:01	13-09-2025	14:39	3:38	0.001211	LT CIRCUIT REPLACEMENT
952	15-09-2025	Part of : NANGAL VILLAGE DELHI CANTONMENT,	843	Other Outage	Planned Outage	15-09-2025	11:25	15-09-2025	15:06	3:41	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMENT PER FEEDER
953	15-09-2025	Part of : BLOCK A NANAK PURA HARI NAGAR,	1360	Other Outage	Planned Outage	15-09-2025	11:25	15-09-2025	14:07	2:42	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
954	15-09-2025	Part of : POCKET G HARI NAGAR JANAK PURI,	492	Other Outage	Planned Outage	15-09-2025	11:25	15-09-2025	15:05	3:40	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
955	15-09-2025	Part of : BLOCK 3 ASHOK NAGAR,	1201	Other Outage	Planned Outage	15-09-2025	10:54	15-09-2025	14:08	3:14	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
956	16-09-2025	Part of : BLOCK C4F JANAK PURI	640	Other Outage	Planned Outage	16-09-2025	14:34	16-09-2025	14:56	0:22	0.000061	RELAY REPLACEMET/VPI/FPI
957	16-09-2025	Part of : BLOCK C3 JANAK PURI	897	Other Outage	Planned Outage	16-09-2025	15:39	16-09-2025	16:12	0:33	0.000092	RELAY REPLACEMET/VPI/FPI
958	16-09-2025	Part of : BLOCK 16 PRESS COLONY MAYAPURI	136	Other Outage	Planned Outage	16-09-2025	14:58	16-09-2025	16:11	1:13	0.000203	SF6 GAS FILLING
959	16-09-2025	Part of : PREM NAGAR JANAK PURI	616	Other Outage	Planned Outage	16-09-2025	12:29	16-09-2025	14:30	2:01	0.000336	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
960	16-09-2025	Part of : BLOCK B FATEH NAGAR	471	Other Outage	Planned Outage	16-09-2025	11:12	16-09-2025	14:53	3:41	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
961	16-09-2025	Part of : BLOCK J 8 RAJOURI GARDEN EXTENSION RAJOURI GARDEN	331	Other Outage	Planned Outage	16-09-2025	11:08	16-09-2025	13:36	2:28	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
962	16-09-2025	Part of : POCKET D 1 JANAK PURI	528	Other Outage	Planned Outage	16-09-2025	11:41	16-09-2025	13:56	2:15	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
963	17-09-2025	Part of : POCKET D 1C LAJWANTI GARDEN JANAK PURI	381	Other Outage	Planned Outage	17-09-2025	12:02	17-09-2025	13:51	1:49	0.000606	LT CIRCUIT MAINTENANCE WORK
964	17-09-2025	Part of : PREM NAGAR JANAK PURI	297	Other Outage	Planned Outage	17-09-2025	12:14	17-09-2025	13:42	1:28	0.000489	APPLY OF INSULATION TAPE HT/LT BUSHINGS
965	18-09-2025	Part of : BLOCK A KARAN MARKET NANGAL RAYA JANAK PURI	204	Other Outage	Planned Outage	18-09-2025	11:35	18-09-2025	14:22	2:47	0.000464	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
966	18-09-2025	Part of : BLOCK 6 SUBHASH NAGAR	584	Other Outage	Planned Outage	18-09-2025	10:09	18-09-2025	13:18	3:09	0.001050	CONDUCTOR REPLACEMENT PER SPAN
967	18-09-2025	Part of : BLOCK CA HARI NAGAR	565	Other Outage	Planned Outage	18-09-2025	11:33	18-09-2025	13:43	2:10	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
968	18-09-2025	Part of : BLOCK 16 PRESS COLONY MAYAPURI	524	Other Outage	Planned Outage	18-09-2025	11:45	18-09-2025	14:36	2:51	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
969	19-09-2025	Part of : BLOCK 16 PRESS COLONY MAYAPURI,	867	Other Outage	Planned Outage	19-09-2025	15:10	19-09-2025	15:34	0:24	0.000067	SF6 GAS FILLING
970	19-09-2025	Part of : ADITI APARTMENTS JANAK PURI,	43	Other Outage	Planned Outage	19-09-2025	11:38	19-09-2025	12:28	0:50	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
971	19-09-2025	Part of : BLOCK V RAJOURI GARDEN,	244	Other Outage	Planned Outage	19-09-2025	11:04	19-09-2025	14:14	3:10	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
972	19-09-2025	Part of : BLOCK A 4C P AND T COLONY JANAK PURI,	795	Other Outage	Planned Outage	19-09-2025	12:26	19-09-2025	15:09	2:43	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
973	20-09-2025	Part of : Block D Mayapuri Industrial Area Phase II Mayapuri,	210	Other Outage	Planned Outage	20-09-2025	12:07	20-09-2025	13:14	1:07	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
974	20-09-2025	Part of : Possangipur Village Janak Puri,	712	Other Outage	Planned Outage	20-09-2025	12:12	20-09-2025	14:19	2:07	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
975	20-09-2025	Part of : Block F Delhi Milk Sscheme Colony Hari Nagar,	214	Other Outage	Planned Outage	20-09-2025	11:01	20-09-2025	13:30	2:29	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
976	20-09-2025	Part of : Block 5 Subhash Nagar,	617	Other Outage	Planned Outage	20-09-2025	10:49	20-09-2025	13:50	3:01	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
977	20-09-2025	Part of : Block 1 Subhash Nagar,	308	Other Outage	Planned Outage	20-09-2025	10:40	20-09-2025	15:31	4:51	0.000000	CONDUCTOR REPLACEMENT PER SPAN
978	22-09-2025	Part of : DDU HOSPITAL C BLOCK JANAK PURI, BLOCK C & C2C JANAK PURI, TRANSPORT DEPARTMENT HARI NAGAR (HTC), SURAJMAL COLLEGE JANAKPURI (HTC)	540	Other Outage	Unplanned Outage	22-09-2025	13:32	22-09-2025	14:23	0:51	0.000439	HT SYSTEM FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
979	22-09-2025	Part of : EV CHARGING DTC DEPOT MAYAPURI (HTC)	0	Other Outage	Unplanned Outage	22-09-2025	19:08	22-09-2025	21:05	1:57	0.000228	CABLE FAULT
980	22-09-2025	Part of : BLOCK 50 ASHOK NAGAR	582	Other Outage	Planned Outage	22-09-2025	11:06	22-09-2025	13:46	2:40	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
981	22-09-2025	Part of : BLOCK CB HARI NAGAR	613	Other Outage	Planned Outage	22-09-2025	11:10	22-09-2025	14:30	3:20	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
982	22-09-2025	Part of : BLOCK D MAYAPURI INDUSTRIAL AREA PHASE II	704	Other Outage	Planned Outage	22-09-2025	12:08	22-09-2025	14:26	2:18	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
983	22-09-2025	Part of : POCKET B 1 B 1 MARKET SUPER BAZAR JANAK PURI	49	Other Outage	Planned Outage	22-09-2025	11:19	22-09-2025	14:33	3:14	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
984	23-09-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE I MAYAPURI	442	Other Outage	Unplanned Outage	23-09-2025	02:59	23-09-2025	04:24	1:25	0.001039	HT SYSTEM FAULT
985	23-09-2025	Part of : POCKET E MAYAPURI INDUSTRIAL AREA PHASE II MAYAPURI,	458	Other Outage	Planned Outage	23-09-2025	12:38	23-09-2025	14:36	1:58	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
986	23-09-2025	Part of : BLOCK V RAJOURI GARDEN,	258	Other Outage	Planned Outage	23-09-2025	11:17	23-09-2025	15:31	4:14	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
987	23-09-2025	Part of : CHHOTI SUBJI MANDI JANAK PURI,	410	Other Outage	Planned Outage	23-09-2025	11:36	23-09-2025	15:33	3:57	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
988	23-09-2025	Part of : BLOCK WZ LAJWANTI GARDEN JANAK PURI,	556	Other Outage	Planned Outage	23-09-2025	11:14	23-09-2025	13:29	2:15	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
989	24-09-2025	Part of : POCKET G HARI NAGAR JANAK PURI	492	Other Outage	Planned Outage	24-09-2025	12:05	24-09-2025	15:38	3:33	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
990	24-09-2025	Part of : BLOCK WZ LAJWANTI GARDEN JANAK PURI	720	Other Outage	Planned Outage	24-09-2025	11:22	24-09-2025	14:39	3:17	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
991	24-09-2025	Part of : BLOCK J RAJOURI GARDEN	141	Other Outage	Planned Outage	24-09-2025	11:07	24-09-2025	14:25	3:18	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER
992	24-09-2025	Part of : BLOCK C NANAK PURA HARI NAGAR	879	Other Outage	Planned Outage	24-09-2025	11:31	24-09-2025	14:45	3:14	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER
993	25-09-2025	Part of : A 2,A 2B & A 3-BLOCK ASALATPUR VILLAGE JANAK PURI,CHANDAR NAGAR	2985	Other Outage	Unplanned Outage	25-09-2025	17:41	25-09-2025	18:34	0:53	0.001781	CABLE FAULT
994	25-09-2025	Part of : BLOCK C JANAK PURI	7	Other Outage	Planned Outage	25-09-2025	11:36	25-09-2025	13:28	1:52	0.000622	LT CIRCUIT MAINTENANCE
995	25-09-2025	Part of : MCD MARKET ASHOK NAGAR	513	Other Outage	Planned Outage	25-09-2025	11:23	25-09-2025	12:58	1:35	0.000528	LT CIRCUIT MAINTENANCE
996	25-09-2025	Part of : BLOCK C3A RESIDENTIAL COMPLEX JANAK PURI	555	Other Outage	Planned Outage	25-09-2025	11:11	25-09-2025	13:27	2:16	0.000756	OIL TOP UP IN TRANSFORMER
997	25-09-2025	Part of : BLOCK H NANAK PURA HARI NAGAR	654	Other Outage	Planned Outage	25-09-2025	11:35	25-09-2025	14:23	2:48	0.000933	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
998	25-09-2025	Part of : PREM NAGAR JANAK PURI	616	Other Outage	Planned Outage	25-09-2025	11:16	25-09-2025	15:05	3:49	0.001272	LT CIRCUIT MAINTENANCE
999	25-09-2025	Part of : BLOCK J BERI WALA BAGH HARI NAGAR	780	Other Outage	Planned Outage	25-09-2025	10:02	25-09-2025	14:20	4:18	0.000000	LT CIRCUIT MAINTENANCE
1000	26-09-2025	Part of : BLOCK-Q RAJOURI GARDEN	0	Other Outage	Unplanned Outage	26-09-2025	12:56	26-09-2025	14:07	1:11	0.001775	CABLE FAULT
1001	26-09-2025	Part of : BLOCK J BERI WALA BAGH HARI NAGAR	780	Other Outage	Planned Outage	26-09-2025	11:38	26-09-2025	13:19	1:41	0.000000	3PH DB REVAMPING,FERRULE PUNCHING LT AB TO LT AB PER FEEDER

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1002	26-09-2025	Part of : POCKET D2A NANGAL RAYA JANAK PURI	449	Other Outage	Planned Outage	26-09-2025	11:13	26-09-2025	14:47	3:34	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1003	26-09-2025	Part of : BLOCK B FATEH NAGAR	323	Other Outage	Planned Outage	26-09-2025	11:33	26-09-2025	14:26	2:53	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1004	26-09-2025	Part of : BLOCK C 2A JANAK PURI	474	Other Outage	Planned Outage	26-09-2025	11:39	26-09-2025	14:44	3:05	0.000000	3PH DB REVAMPING,PRC REPLACEMET PER FEEDER
1005	27-09-2025	Part of : BLOCK C NANAK PURA HARI NAGAR,	775	Other Outage	Planned Outage	27-09-2025	11:38	27-09-2025	14:24	2:46	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1006	27-09-2025	Part of : BLOCK C JANAK PURI,	147	Other Outage	Planned Outage	27-09-2025	11:20	27-09-2025	13:56	2:36	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
1007	27-09-2025	Part of : BLOCK 4 SUBHASH NAGAR,	551	Other Outage	Planned Outage	27-09-2025	11:13	27-09-2025	15:00	3:47	0.000000	DT REPLACEMET PER DT
1008	27-09-2025	Part of : BLOCK RZ MOHAN NAGAR SAGARPUR MAIN SAGARPUR,	1060	Other Outage	Planned Outage	27-09-2025	12:12	27-09-2025	14:23	2:11	0.000000	1PH DB REVAMPING,3PH DB REVAMPING,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE,PRC REPLACEMET PER FEEDER
1009	27-09-2025	Part of : BLOCK C3 JANAK PURI,	511	Other Outage	Planned Outage	27-09-2025	11:37	27-09-2025	15:54	4:17	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,REPLACEMET OF HT/LT CLEATS,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1010	29-09-2025	Part of : CA-BLOCK HARI NAGAR,CB-BLOCK MAYA ENCLAVE	3087	Other Outage	Unplanned Outage	29-09-2025	08:53	29-09-2025	09:41	0:48	0.001067	HT SYSTEM FAULT
1011	29-09-2025	Part of : POSSANGIPUR VILLAGE JANAK PURI	712	Other Outage	Planned Outage	29-09-2025	12:18	29-09-2025	14:32	2:14	0.000744	LT CIRCUIT MAINTENANCE
1012	29-09-2025	Part of : POCKET C HARI NAGAR	484	Other Outage	Planned Outage	29-09-2025	11:42	29-09-2025	14:12	2:30	0.000833	LT CIRCUIT MAINTENANCE
1013	29-09-2025	Part of : BLOCK WZ PADAM BASTI NANGAL RAYA JANAK PURI	497	Other Outage	Planned Outage	29-09-2025	11:44	29-09-2025	14:05	2:21	0.000783	LT CIRCUIT MAINTENANCE
1014	29-09-2025	Part of : BLOCK C 4D JANAK PURI	321	Other Outage	Planned Outage	29-09-2025	10:44	29-09-2025	13:14	2:30	0.000833	LT CIRCUIT MAINTENANCE
1015	30-09-2025	Part of : METAL FORGING (HTC)	0	Other Outage	Unplanned Outage	30-09-2025	09:05	30-09-2025	09:53	0:48	0.000733	CABLE FAULT
1016	30-09-2025	Part of : BLOCK A MAYAPURI INDUSTRIAL AREA PHASE II, POCKET D 1A JANAK PURI	754	Other Outage	Unplanned Outage	30-09-2025	19:59	30-09-2025	21:09	1:10	0.001400	FAULT IN HT CONSUMER PANEL (A-42)
1017	30-09-2025	Part of : POCKET GI MAYAPURI INDUSTRIAL AREA PHASE II, BLOCK A & B MAYAPURI INDUSTRIAL AREA PHASE II	717	Other Outage	Unplanned Outage	30-09-2025	11:29	30-09-2025	13:24	1:55	0.005207	CABLE FAULT
1018	30-09-2025	Part of : TIHAR CENTRAL JAIL JANAK PURI	67	Other Outage	Planned Outage	30-09-2025	14:06	30-09-2025	16:13	2:07	0.000000	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1019	01-09-2025	Part of : NETAJI SUBHASH VIHAR,HIRAN KUDNA,MUNDKA INDUSTRIAL AREA,NEELWAL VILLAGE	1673	Other Outage	Unplanned Outage	01-09-2025	18:14	01-09-2025	19:01	0:47	0.021829	HVDS FAULT
1020	02-09-2025	Kudna,MUNDKA INDUSTRIAL AREA MUNDKA	1673	Other Outage	Unplanned Outage	02-09-2025	06:03	02-09-2025	06:57	0:54	0.000000	REPLACEMENT OF JUMPER
1021	03-09-2025	Part of : HTC:RMU WATER W FEEDER NO-2 L&T PLANT, HTC:RMU - WATER WORKS NO-1 OLD PLANT	3	Other Outage	Unplanned Outage	03-09-2025	06:54	03-09-2025	07:30	0:36	0.000600	CABLE FAULT
1022	03-09-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR	1128	Other Outage	Unplanned Outage	03-09-2025	03:59	03-09-2025	04:41	0:42	0.000397	TRANSIENT FAULT
1023	06-09-2025	Part of : MUNDKA INDUSTRIAL AREA	318	Other Outage	Unplanned Outage	06-09-2025	14:19	06-09-2025	15:03	0:44	0.000000	CABLE FAULT
1024	06-09-2025	Part of : WEST CABIN BLOCK MUNDKA, SWARN PARK UDYOG NAGAR	195	Other Outage	Unplanned Outage	06-09-2025	09:12	06-09-2025	10:03	0:51	0.000000	BIRDAGE
1025	06-09-2025	Part of : BLOCK C MUNDKA, MUNDKA EXTENSION, SAVITA VIHAR MUNDKA	300	Other Outage	Unplanned Outage	06-09-2025	03:02	06-09-2025	03:37	0:35	0.000496	CABLE FAULT
1026	07-09-2025	Part of : MUNDKA EXTENSION MUNDKA,MUNDKA INDUSTRIAL AREA MUNDKA,JAI VIHAR KAMARUDDIN NAGAR,BLOCK C MUNDKA,MUNDKA VILLAGE MUNDKA,SAVITA VIHAR MUNDKA	300	Other Outage	Unplanned Outage	07-09-2025	14:35	07-09-2025	15:12	0:37	0.000730	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1027	07-09-2025	Part of : VEENA ENCLAVE WEST CABIN BLOCK MUNDKA,	50	Other Outage	Planned Outage	07-09-2025	12:53	07-09-2025	14:12	1:19	0.000768	CONDUCTOR REPLACEMET PER SPAN
1028	07-09-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA,	12	Other Outage	Planned Outage	07-09-2025	12:52	07-09-2025	15:44	2:52	0.001433	ACB REPLACEMENT PER ACB
1029	08-09-2025	Part of : TIKRI KALAN	1998	Other Outage	Planned Outage	08-09-2025	12:18	08-09-2025	13:09	0:51	0.002125	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
1030	08-09-2025	Part of : TIKRI KALAN	525	Other Outage	Planned Outage	08-09-2025	12:19	08-09-2025	16:08	3:49	0.003181	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1031	08-09-2025	Part of : BLOCK D MUNDKA	820	Other Outage	Planned Outage	08-09-2025	11:54	08-09-2025	14:43	2:49	0.005633	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
1032	08-09-2025	Part of : BLOCK 2C NANGLOI EXTENSION	162	Other Outage	Planned Outage	08-09-2025	09:24	08-09-2025	12:39	3:15	0.001083	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1033	09-09-2025	Part of : B,C & D-BLOCK MUNDKA,SAVITA VIHAR,FRIENDS COLONY	4523	Other Outage	Unplanned Outage	09-09-2025	10:20	09-09-2025	11:17	0:57	0.002058	HVDS FAULT
1034	09-09-2025	Part of : RATAN BAGH NANGLOI	1154	Other Outage	Planned Outage	09-09-2025	13:50	09-09-2025	15:47	1:57	0.001625	REPLACEMET OF HT BUSHING ROD
1035	10-09-2025	Part of : BLOCK C MUNDKA,MUNDKA EXTENSION, SAVITA VIHAR MUNDKA, SWARN PARK MUNDKA	300	Other Outage	Unplanned Outage	10-09-2025	18:32	10-09-2025	19:14	0:42	0.002123	CABLE FAULT
1036	10-09-2025	Part of : NEW PVC MARKET TIKRI KALAN	48	Other Outage	Planned Outage	10-09-2025	14:46	10-09-2025	16:16	1:30	0.002000	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1037	10-09-2025	Part of : TIKRI KALAN	746	Other Outage	Planned Outage	10-09-2025	10:43	10-09-2025	14:03	3:20	0.001111	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1038	10-09-2025	Part of : RAJENDRA PARK EXTENSION NANGLOI	734	Other Outage	Planned Outage	10-09-2025	09:56	10-09-2025	13:30	3:34	0.001189	ACB REPLACEMENT PER ACB
1039	11-09-2025	Part of : MUNDKA EXTENSION MUNDKA,	36	Other Outage	Planned Outage	11-09-2025	11:46	11-09-2025	15:01	3:15	0.001625	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1040	13-09-2025	Part of : C-BLOCK MUNDKA,MUNDKA EXTENSION,SAVITA VIHAR	300	Other Outage	Unplanned Outage	13-09-2025	01:59	13-09-2025	02:56	0:57	0.000538	TREE TOUCHING
1041	14-09-2025	Part of : BLOCK C MUNDKA	43	Other Outage	Planned Outage	14-09-2025	15:39	14-09-2025	17:58	2:19	0.000772	LT AB SAGGING PER SPAN
1042	14-09-2025	Part of : MUNDKA INDUSTRIAL AREA	11	Other Outage	Planned Outage	14-09-2025	13:30	14-09-2025	15:37	2:07	0.001058	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1043	15-09-2025	Part of : TIKRI KALAN,NEELWAL VILLAGE	1426	Other Outage	Unplanned Outage	15-09-2025	17:10	15-09-2025	17:38	0:28	0.000000	CABLE FAULT
1044	15-09-2025	Part of : TIKRI KALAN,MUNDKA INDUSTRIAL AREA MUNDKA,BLOCK A NANGLOI EXTENSION NANGLOI,MUNDKA INDUSTRIAL AREA MUNDKA,TIKRI KALAN,JAI VIHAR KAMARUDDIN NAGAR,NETAJI SUBHASH VIHAR MUNDKA,TILANGPUR KOTLA,FRIENDS COLONY MUNDKA,MUNDKA VILLAGE MUNDKA	444	Other Outage	Unplanned Outage	15-09-2025	15:44	15-09-2025	16:25	0:41	0.002574	CABLE FAULT
1045	15-09-2025	Part of : RAJENDRA PARK NANGLOI EXTENSION NANGLOI,TYAGI COLONY NANGLOI EXTENSION NANGLOI,BLOCK B YADAV PARK NANGLOI EXTENSION NANGLOI,	1133	Other Outage	Planned Outage	15-09-2025	10:53	15-09-2025	12:58	2:05	0.000868	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR
1046	15-09-2025	Part of : RATAN BAGH NANGLOI,	1154	Other Outage	Planned Outage	15-09-2025	10:15	15-09-2025	14:34	4:19	0.004317	REPLACEMET OF HT BUSHING ROD
1047	16-09-2025	Part of : BANI AIR FORCE CAMP JAI VIHAR BAPROLA	737	Other Outage	Planned Outage	16-09-2025	10:48	16-09-2025	15:28	4:40	0.002333	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,RELAY REPLACEMET/VPI/FPI
1048	17-09-2025	Part of : GULSHAN PARK,WEST CABIN BLOCK MUNDKA	194	Other Outage	Unplanned Outage	17-09-2025	07:30	17-09-2025	08:11	0:41	0.000410	CABLE FAULT
1049	17-09-2025	Part of : TILANGPUR KOTLA,GURDAYAL VIHAR CHANCHAL PARK	1064	Other Outage	Planned Outage	17-09-2025	11:15	17-09-2025	15:37	4:22	0.002183	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE
1050	17-09-2025	Part of : NETAJI SUBHASH VIHAR,NEELWAL VILLAGE,HIRAN KUDNA,INDUSTRIAL AREA MUNDKA	1674	Other Outage	Planned Outage	17-09-2025	11:01	17-09-2025	13:23	2:22	0.002367	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
1051	18-09-2025	Part of : NEW PVC MARKET TIKRI KALAN,TIKRI KALAN	337	Other Outage	Planned Outage	18-09-2025	14:37	18-09-2025	16:38	2:01	0.000672	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1052	19-09-2025	Part of : TIKRI KALAN,	525	Other Outage	Planned Outage	19-09-2025	13:22	19-09-2025	16:12	2:50	0.001889	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1053	20-09-2025	Part of : West Cabin Block Mundka,	543	Other Outage	Planned Outage	20-09-2025	15:04	20-09-2025	16:40	1:36	0.000533	LT AB SAGGING PER SPAN
1054	21-09-2025	Part of : RAJENDRA PARK EXTENSION,2A,2B,2D,C,D & 4ABC-BLOCK NANGLOI EXTENSION,C & D-BLOCK JJ COLONY	8826	Other Outage	Unplanned Outage	21-09-2025	12:09	21-09-2025	12:36	0:27	0.000180	HVDS FAULT
1055	21-09-2025	Part of : MUNDKA INDUSTRIAL AREA	4	Other Outage	Planned Outage	21-09-2025	13:08	21-09-2025	15:14	2:06	0.000875	REPLACEMENT OF GAS KIT AND OIL SEAL
1056	21-09-2025	Part of : MUNDKA INDUSTRIAL AREA	29	Other Outage	Planned Outage	21-09-2025	12:43	21-09-2025	15:20	2:37	0.001744	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
1057	21-09-2025	Part of : VEENA ENCLAVE WEST CABIN BLOCK MUNDKA	73	Other Outage	Planned Outage	21-09-2025	13:16	21-09-2025	16:51	3:35	0.004181	HT CONDUCTOR REPLACEMENT
1058	21-09-2025	Part of : MUNDKA INDUSTRIAL AREA	20	Other Outage	Planned Outage	21-09-2025	12:24	21-09-2025	15:13	2:49	0.001878	HT,REPLACEMENT OF LUGS
1059	22-09-2025	Part of : MUNDKA INDUSTRIAL AREA MUNDKA, NETAJI SUBHASH VIHAR MUNDKA, HIRAN KUDNA	444	Other Outage	Unplanned Outage	22-09-2025	18:35	22-09-2025	19:16	0:41	0.001868	CABLE FAULT
1060	22-09-2025	Part of : NETAJI SUBHASH VIHAR MUNDKA	3	Other Outage	Planned Outage	22-09-2025	10:29	22-09-2025	13:22	2:53	0.001442	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1061	22-09-2025	Part of : RANHOLLA	1160	Other Outage	Planned Outage	22-09-2025	10:45	22-09-2025	13:47	3:02	0.003033	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,END TERMINATION COVER REPLACEMENT
1062	23-09-2025	Part of : BLOCK B MUNDKA,SAVITA VIHAR MUNDKA,FRIENDS COLONY MUNDKA,BLOCK C MUNDKA,BLOCK D MUNDKA	4529	Other Outage	Unplanned Outage	23-09-2025	16:56	23-09-2025	17:36	0:40	0.001944	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1063	23-09-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,	1129	Other Outage	Unplanned Outage	23-09-2025	13:22	23-09-2025	14:25	1:03	0.000000	REPAIR/REPLACEMENT OF CONDUCTOR
1064	23-09-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR,	1	Other Outage	Planned Outage	23-09-2025	16:21	23-09-2025	17:29	1:08	0.001133	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1065	24-09-2025	Part of : BLOCK D KUNWAR SINGH NAGAR KAMARUDDIN NAGAR,LAXMI PARK COLONY KAMARUDDIN NAGAR	3839	Other Outage	Unplanned Outage	24-09-2025	21:38	24-09-2025	22:30	0:52	0.000578	TREE BRANCH FALLEN ON O/H LINE
1066	24-09-2025	Part of : RATAN BAGH NANGLOI,BLOCK 1B & 4 ABC NANGLOI EXTENSION NANGLOI,BLOCK A NANGLOI EXTENSION	5753	Other Outage	Planned Outage	24-09-2025	11:01	24-09-2025	16:10	5:09	0.003433	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1067	26-09-2025	Part of : BLOCK-B,C & D MUNDKA, FRIENDS COLONY MUNDKA	4530	Other Outage	Unplanned Outage	26-09-2025	19:14	26-09-2025	19:55	0:41	0.001253	CABLE FAULT
1068	26-09-2025	Part of : MUNDKA VILLAGE	2285	Other Outage	Planned Outage	26-09-2025	11:28	26-09-2025	14:51	3:23	0.002256	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1069	27-09-2025	Part of : TIKRI KALAN,	630	Other Outage	Planned Outage	27-09-2025	10:16	27-09-2025	13:21	3:05	0.001542	JUMPER REPLACEMENT PER POLE,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1070	27-09-2025	Part of : BANI AIR FORCE CAMP JAI VIHAR BAPROLA,	740	Other Outage	Planned Outage	27-09-2025	10:02	27-09-2025	14:29	4:27	0.002225	REPLACEMENT OF LT BUSHING ROD
1071	28-09-2025	Part of : MUNDKA INDUSTRIAL AREA	98	Other Outage	Planned Outage	28-09-2025	13:47	28-09-2025	16:40	2:53	0.003364	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1072	28-09-2025	Part of : MUNDKA INDUSTRIAL AREA	15	Other Outage	Planned Outage	28-09-2025	13:26	28-09-2025	15:50	2:24	0.002800	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1073	28-09-2025	Part of : MUNDKA INDUSTRIAL AREA	150	Other Outage	Planned Outage	28-09-2025	13:21	28-09-2025	15:49	2:28	0.002878	REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1074	29-09-2025	Part of : LAXMI PARK COLONY KAMARUDDIN NAGAR, BLOCK A NANGLOI EXTENSION NANGLOI, MUNDKA EXTENSION MUNDKA	6052	Other Outage	Planned Outage	29-09-2025	14:46	29-09-2025	16:01	1:15	0.002604	JUMPER REPLACEMENT
1075	29-09-2025	Part of : RATAN BAGH NANGLOI	1155	Other Outage	Planned Outage	29-09-2025	11:13	29-09-2025	13:53	2:40	0.003111	REPLACEMENT OF GAS KIT AND OIL SEAL
1076	29-09-2025	Part of : JOHAR VILLAGE NANGLOI EXTENSION	474	Other Outage	Planned Outage	29-09-2025	09:56	29-09-2025	12:31	2:35	0.000861	REPLACEMET OF HT BUSHING
1077	30-09-2025	Part of : BLOCK C MUNDKA, MUNDKA EXTENSION, SAVITA VIHAR MUNDKA	300	Other Outage	Unplanned Outage	30-09-2025	10:59	30-09-2025	11:37	0:38	0.001087	CABLE FAULT
1078	30-09-2025	Part of : RAJENDRA PARK EXTENSION, BLOCK 2C NANGLOI EXTENSION	764	Other Outage	Unplanned Outage	30-09-2025	10:56	30-09-2025	11:29	0:33	0.000477	CABLE FAULT
1079	01-09-2025	Part of : B-BLOCK BHAGWATI GARDEN,JAI BHARAT ENCLAVE,ROSHAN GARDEN NAWADA	2961	Other Outage	Unplanned Outage	01-09-2025	21:41	01-09-2025	22:25	0:44	0.000330	HVDS FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1080	01-09-2025	Part of : E-BLOCK BHAGWATI GARDEN,A & B-BLOCK MAHAVIR ENCLAVE,M & F-BLOCK ZAILDAR ENCLAVE,NAWADA EXTENSION	4057	Other Outage	Unplanned Outage	01-09-2025	10:14	01-09-2025	10:58	0:44	0.001002	HVDS FAULT
1081	01-09-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,SAI& SETHI ENCLAVE,SAINIK ENCLAVE,PANCHSHEEL ENCLAVE,VIKAS KUNJ ,VIKAS KUNJ EXTN.	5123	Other Outage	Unplanned Outage	01-09-2025	02:44	01-09-2025	03:39	0:55	0.001314	CABLE FAULT
1082	01-09-2025	Part of : VIPIN GARDEN EXTENSION NAWADA	616	Other Outage	Unplanned Outage	01-09-2025	13:32	01-09-2025	14:52	1:20	0.000578	REAPARING OF HVDS CIRCUIT
1083	01-09-2025	Part of : A-BLOCK SEWAK PARK DWARKA	189	Other Outage	Unplanned Outage	01-09-2025	12:59	01-09-2025	14:31	1:32	0.000639	REAPARING OF HVDS CIRCUIT
1084	01-09-2025	Part of : R 5-BLOCK MOHAN GARDEN RAZAPUR KHURD	2535	Other Outage	Unplanned Outage	01-09-2025	12:57	01-09-2025	14:28	1:31	0.000506	REAPARING OF HVDS CIRCUIT
1085	01-09-2025	Part of : NAWADA EXTENSION,A & B-BLOCK MAHAVIR ENCLAVE NAWADA	2078	Other Outage	Unplanned Outage	01-09-2025	12:25	01-09-2025	14:04	1:39	0.000000	REAPARING OF HVDS CIRCUIT
1086	02-09-2025	Part of : BLOCK B BHAGWATI GARDEN,JAI BHARAT ENCLAVE,BG BLOCK MOHAN GARDEN,AMAR SHOPPING COMPLEX	2961	Other Outage	Unplanned Outage	02-09-2025	20:29	02-09-2025	21:00	0:31	0.000078	CABLE FAULT
1087	02-09-2025	Part of : BLOCK P2 & R5 MOHAN GARDEN RAZAPUR KHURD,BLOCK H BHAGWATI GARDEN NAWADA	1160	Other Outage	Unplanned Outage	02-09-2025	15:03	02-09-2025	16:28	1:25	0.000236	REPAIRING OF HVDS CIRCUIT
1088	02-09-2025	Part of : BLOCK K4 & K5 ZAILDAR ENCLAVE HASTSAL,A,B&C-BLOCK MAHARANI ENCLAVE	1573	Other Outage	Unplanned Outage	02-09-2025	14:05	02-09-2025	15:42	1:37	0.000539	REPAIRING OF HVDS CIRCUIT
1089	03-09-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,	1085	Other Outage	Planned Outage	03-09-2025	12:08	03-09-2025	14:58	2:50	0.000472	TRANSFORMER MAINTENANCE
1090	03-09-2025	Part of : NAWADA EXTENSION NAWADA,BLOCK A MAHAVIR ENCLAVE NAWADA,BLOCK B MAHAVIR ENCLAVE NAWADA,	2068	Other Outage	Planned Outage	03-09-2025	11:15	03-09-2025	14:57	3:42	0.000617	HVDS MAINTENANCE
1091	04-09-2025	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD	1308	Other Outage	Unplanned Outage	04-09-2025	12:51	04-09-2025	14:37	1:46	0.000589	REPAIRING OF HVDS CIRCUIT
1092	04-09-2025	Part of : PHASE 2 OM VIHAR NAWADA	551	Other Outage	Unplanned Outage	04-09-2025	10:52	04-09-2025	12:01	1:09	0.000383	REPAIRING OF LT CIRCUIT
1093	05-09-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	1245	Other Outage	Unplanned Outage	05-09-2025	12:08	05-09-2025	13:17	1:09	0.000192	HVDS CIRCUIT MAINTENANCE
1094	06-09-2025	Part of : BLOCK C VIPIN GARDEN NAWADA	1994	Other Outage	Unplanned Outage	06-09-2025	00:11	06-09-2025	01:54	1:43	0.001431	TRANSFORMER HT BUSHING REPLACEMENT
1095	06-09-2025	Part of : NAWADA EXTENSION NAWADA	645	Other Outage	Planned Outage	06-09-2025	12:05	06-09-2025	14:04	1:59	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1096	06-09-2025	Part of : BLOCK P,P2 & R5 MOHAN GARDEN RAZAPUR KHURD,BLOCK H & L BHAGWATI GARDEN NAWADA,BLOCK H BHAGWATI GARDEN NAWADA	1883	Other Outage	Planned Outage	06-09-2025	13:59	06-09-2025	16:41	2:42	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1097	06-09-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	694	Other Outage	Planned Outage	06-09-2025	11:10	06-09-2025	14:09	2:59	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1098	07-09-2025	Part of : BLOCK L BHAGWATI GARDEN NAWADA,BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK F ZAILDAR ENCLAVE NAWADA,PHASE 2 OM VIHAR NAWADA,PHASE 1 OM VIHAR NAWADA	5307	Other Outage	Unplanned Outage	07-09-2025	04:14	07-09-2025	04:49	0:35	0.001079	CABLE FAULT
1099	08-09-2025	Part of : BLOCK D & H BHAGWATI GARDEN NAWADA,BHAGWATI GARDEN EXTENSION NAWADA,LAXMI VIHAR NAWADA	1750	Other Outage	Unplanned Outage	08-09-2025	12:30	08-09-2025	14:12	1:42	0.001530	MOBILE TRANSFORMER REPLACEMENT
1100	08-09-2025	Part of : BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD	869	Other Outage	Planned Outage	08-09-2025	15:08	08-09-2025	17:19	2:11	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1101	08-09-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK B, D & E BHAGWATI GARDEN NAWADA	3429	Other Outage	Planned Outage	08-09-2025	14:54	08-09-2025	17:20	2:26	0.000000	DT REPLACEMET PER DT
1102	08-09-2025	Part of : BLOCK P & P 2 MOHAN GARDEN RAZAPUR KHURD	1288	Other Outage	Planned Outage	08-09-2025	12:22	08-09-2025	15:01	2:39	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1103	08-09-2025	Part of : PHASE 4 OM VIHAR HASTSAL	256	Other Outage	Planned Outage	08-09-2025	10:42	08-09-2025	14:14	3:32	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1104	09-09-2025	Part of : SAINIK ENCLAVE,VIPIN GARDEN EXTENSION,LAXMI VIHAR NAWADA	8929	Other Outage	Unplanned Outage	09-09-2025	00:43	09-09-2025	01:28	0:45	0.001075	HT SYSTEM FAULT
1105	09-09-2025	Part of : C-BLOCK VIPIN GARDEN,R 5-BLOCK MOHAN GARDEN,SAINIK ENCLAVE NAWADA	4114	Other Outage	Unplanned Outage	09-09-2025	00:20	09-09-2025	02:35	2:15	0.000000	CABLE FAULT
1106	09-09-2025	Part of : LAXMI VIHAR NAWADA	391	Other Outage	Unplanned Outage	09-09-2025	12:39	09-09-2025	13:59	1:20	0.001200	REPAIRING OF HVDS CIRCUIT
1107	09-09-2025	Part of : R,R1 & R5-BLOCK MOHAN GARDEN RAZAPUR KHURD	1032	Other Outage	Planned Outage	09-09-2025	15:32	09-09-2025	17:28	1:56	0.000000	3PH HT AB CABLE REPLACEMENT
1108	09-09-2025	Part of : A & B-BLOCK MAHAVIR ENCLAVE NAWADA	700	Other Outage	Planned Outage	09-09-2025	13:56	09-09-2025	17:25	3:29	0.000000	3PH HT AB CABLE REPLACEMENT
1109	09-09-2025	Part of : N 2-BLOCK MOHAN GARDEN RAZAPUR KHURD	1735	Other Outage	Planned Outage	09-09-2025	12:19	09-09-2025	15:03	2:44	0.000000	3PH HT AB CABLE REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1110	09-09-2025	Part of : D,E,L & H-BLOCK E BHAGWATI GARDEN NAWADA	2573	Other Outage	Planned Outage	09-09-2025	11:44	09-09-2025	15:09	3:25	0.000000	3PH HT AB CABLE REPLACEMENT
1111	09-09-2025	Part of : E & L-BLOCK BHAGWATI GARDEN NAWADA,A-BLOCK RAMA PARK	1517	Other Outage	Planned Outage	09-09-2025	11:06	09-09-2025	13:55	2:49	0.000000	3PH HT AB CABLE REPLACEMENT
1112	10-09-2025	Part of : RAZA PUR KHURD VIKAS NAGAR,BLOCK WE MOHAN GARDEN RAZAPUR KHURD	1459	Other Outage	Unplanned Outage	10-09-2025	12:55	10-09-2025	14:38	1:43	0.000286	HVDS TRANSFORMER REPLACEMENT
1113	10-09-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA, BLOCK A MAHAVIR ENCLAVE NAWADA, BLOCK B BHAGWATI GARDEN NAWADA	456	Other Outage	Planned Outage	10-09-2025	14:55	10-09-2025	16:14	1:19	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1114	10-09-2025	Part of : LAXMI VIHAR NAWADA,BLOCK H BHAGWATI GARDEN NAWADA	1422	Other Outage	Planned Outage	10-09-2025	13:12	10-09-2025	16:09	2:57	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1115	11-09-2025	Part of : SHYAM PARK NAWADA MAJRA VILLAGE NAWADA,NAWADA EXTENSION NAWADA,PHASE 2 OM VIHAR NAWADA,NAWADA MAJRA VILLAGE NAWADA	2580	Other Outage	Unplanned Outage	11-09-2025	11:14	11-09-2025	11:56	0:42	0.000000	TREE TOUCHING
1116	11-09-2025	Part of : MOHAN GARDEN NAWADA,PHASE 1 OM VIHAR NAWADA,	1363	Other Outage	Unplanned Outage	11-09-2025	15:26	11-09-2025	17:05	1:39	0.000550	MAINTENANCE
1117	11-09-2025	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD,BLOCK RK MOHAN GARDEN RAZAPUR KHURD,	990	Other Outage	Planned Outage	11-09-2025	15:12	11-09-2025	16:33	1:21	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1118	11-09-2025	Part of : BLOCK RK MOHAN GARDEN RAZAPUR KHURD,BLOCK R MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,	551	Other Outage	Planned Outage	11-09-2025	12:30	11-09-2025	15:10	2:40	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1119	11-09-2025	Part of : PHASE 5 OM VIHAR HASTSAL,	2970	Other Outage	Planned Outage	11-09-2025	11:31	11-09-2025	13:58	2:27	0.000000	3PH DB REPLACEMENT
1120	12-09-2025	Part of : RAZAPUR KHURD,VIKAS KUNJ AND VIKAS KUNJ EXTN	859	Other Outage	Planned Outage	12-09-2025	12:33	12-09-2025	14:49	2:16	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1121	12-09-2025	Part of : BLOCK B1 SEWAK PARK DWARKA,NAWADA EXTENSION NAWADA	2101	Other Outage	Planned Outage	12-09-2025	11:23	12-09-2025	13:55	2:32	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1122	13-09-2025	Part of : WE & RK-BLOCK MOHAN GARDEN,RAZAPUR KHURD VIKAS NAGAR	4571	Other Outage	Unplanned Outage	13-09-2025	23:23	13-09-2025	23:55	0:32	0.002036	CABLE FAULT
1123	13-09-2025	Part of : E-BLOCK BHAGWATI GARDEN,A & B-BLOCK MAHAVIR ENCLAVE,M & F-BLOCK ZAILDAR ENCLAVE,NAWADA EXTENSION	4062	Other Outage	Unplanned Outage	13-09-2025	14:47	13-09-2025	15:27	0:40	0.000844	HVDS FAULT
1124	13-09-2025	Part of : M & F-BLOCK ZAILDAR ENCLAVE HASTSAL	1400	Other Outage	Unplanned Outage	13-09-2025	11:36	13-09-2025	13:31	1:55	0.000639	REPAIRING OF RMU
1125	13-09-2025	Part of : BLOCK D,E,L&H BHAGWATI GARDEN NAWADA	2573	Other Outage	Planned Outage	13-09-2025	13:09	13-09-2025	15:30	2:21	0.000000	3PH HT AB CABLE REPLACEMENT
1126	13-09-2025	Part of : RAZAPUR KHURD,SAI& SETHI ENCLAVE,SAINIK ENCLAVE AND PANCHSHEEL ENCLAVE	838	Other Outage	Planned Outage	13-09-2025	11:58	13-09-2025	14:53	2:55	0.000000	3PH HT AB CABLE REPLACEMENT
1127	15-09-2025	Part of : BLOCK B1 SEWAK PARK DWARKA,	331	Other Outage	Unplanned Outage	15-09-2025	15:48	15-09-2025	17:40	1:52	0.001244	MAINTENANCE ACTIVITY
1128	15-09-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL,	728	Other Outage	Unplanned Outage	15-09-2025	15:35	15-09-2025	17:14	1:39	0.002750	PREVENTIVE MAINTENANCE
1129	15-09-2025	Part of : BLOCK K 6 ZAILDAR ENCLAVE HASTSAL,	2198	Other Outage	Unplanned Outage	15-09-2025	14:31	15-09-2025	16:00	1:29	0.000000	MAINTENANCE ACTIVITY
1130	15-09-2025	Part of : RAZAPUR KHURD,RAZA PUR KHURD VIKAS NAGAR,	1054	Other Outage	Planned Outage	15-09-2025	13:38	15-09-2025	16:04	2:26	0.001622	3PH HT AB CABLE REPLACEMENT PER SPAN
1131	15-09-2025	Part of : LAXMI VIHAR NAWADA,BLOCK H BHAGWATI GARDEN NAWADA,	1422	Other Outage	Planned Outage	15-09-2025	12:05	15-09-2025	16:01	3:56	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1132	16-09-2025	Part of : BLOCK RK MOHAN GARDEN RAZAPUR KHURD	997	Other Outage	Unplanned Outage	16-09-2025	13:30	16-09-2025	14:55	1:25	0.000236	REPAIRING OF HVDS CIRCUIT
1133	16-09-2025	Part of : BLOCK F & M ZAILDAR ENCLAVE HASTSAL	1401	Other Outage	Unplanned Outage	16-09-2025	13:16	16-09-2025	14:54	1:38	0.002722	REPAIRING OF RMU
1134	16-09-2025	Part of : LAXMI VIHAR NAWADA	53	Other Outage	Unplanned Outage	16-09-2025	09:44	16-09-2025	11:41	1:57	0.001300	REPAIRING OF LT CIRCUIT
1135	17-09-2025	Part of : A & B-BLOCK RAMA PARK BHAGWATI GARDEN,NAWADA EXTENSION,A & B-BLOCK MAHAVIR ENCLAVE	4107	Other Outage	Unplanned Outage	17-09-2025	23:47	18-09-2025	00:26	0:39	0.002513	HVDS FAULT
1136	17-09-2025	Part of : E-BLOCK BHAGWATI GARDEN,A & B-BLOCK MAHAVIR ENCLAVE,M & F-BLOCK ZAILDAR ENCLAVE,NAWADA EXTENSION	4062	Other Outage	Unplanned Outage	17-09-2025	22:56	17-09-2025	23:42	0:46	0.002415	CABLE FAULT
1137	17-09-2025	Part of : R 1,R 5 & WE-BLOCK MOHAN GARDEN RAZAPUR KHURD	739	Other Outage	Planned Outage	17-09-2025	12:05	17-09-2025	15:03	2:58	0.001978	3PH HT AB CABLE REPLACEMENT
1138	17-09-2025	Part of : A,B,D & E-BLOCK RAMA PARK BHAGWATI GARDEN NAWADA	3428	Other Outage	Planned Outage	17-09-2025	11:08	17-09-2025	14:38	3:30	0.000000	3PH HT AB CABLE REPLACEMENT
1139	18-09-2025	Part of : SEWAK PARK DWARKA, GAHLOT SOCIETY SEWAK PARK, SHANTI PARK DWARKA	3715	Other Outage	Unplanned Outage	18-09-2025	14:47	18-09-2025	15:09	0:22	0.000489	TREE BRANCH FALLEN ON HT LINE
1140	18-09-2025	Part of : BLOCK RK & WE MOHAN GARDEN RAZAPUR KHURD	803	Other Outage	Unplanned Outage	18-09-2025	19:12	18-09-2025	20:32	1:20	0.000444	REPAIR/REPLACEMENT WORK OF HVDS CABLE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1141	18-09-2025	Part of : NAWADA EXTENSION,BLOCK A & B MAHAVIR ENCLAVE NAWADA	2083	Other Outage	Unplanned Outage	18-09-2025	15:40	18-09-2025	17:21	1:41	0.000561	REPAIRING OF HVDS CIRCUIT
1142	18-09-2025	Part of : MOHAN GARDEN NAWADA	1360	Other Outage	Unplanned Outage	18-09-2025	11:05	18-09-2025	12:28	1:23	0.000461	REPAIRING OF HVDS CIRCUIT
1143	18-09-2025	Part of : BLOCK R,RK,W & WE MOHAN GARDEN RAZAPUR KHURD, RAZA PUR KHURD VIKAS NAGAR	1882	Other Outage	Planned Outage	18-09-2025	14:07	18-09-2025	16:49	2:42	0.000000	DT REPLACEMET PER DT
1144	18-09-2025	Part of : BHAGWATI GARDEN EXTENSION NAWADA	2177	Other Outage	Planned Outage	18-09-2025	11:23	18-09-2025	15:03	3:40	0.000000	DT REPLACEMENT
1145	19-09-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA,	1521	Other Outage	Unplanned Outage	19-09-2025	15:15	19-09-2025	16:20	1:05	0.001806	REPAIRING OF RMU
1146	19-09-2025	Part of : BLOCK S MOHAN GARDEN RAZAPUR KHURD,RAZAPUR KHURD,BLOCK R MOHAN GARDEN RAZAPUR KHURD,BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,	2002	Other Outage	Planned Outage	19-09-2025	13:01	19-09-2025	16:07	3:06	0.002067	3PH HT AB CABLE REPLACEMENT PER SPAN
1147	20-09-2025	Part of : Mohan Garden Nawada,Phase 1 Om Vihar Nawada,Phase 2 Om Vihar Nawada,Block C JJ Colony Uttam Nagar,	3726	Other Outage	Planned Outage	20-09-2025	12:34	20-09-2025	14:00	1:26	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1148	20-09-2025	Part of : Raza Pur Khurd Vikas Nagar,Razapur Khurd,Block R Mohan Garden Razapur Khurd,	1403	Other Outage	Planned Outage	20-09-2025	12:11	20-09-2025	14:45	2:34	0.001711	3PH HT AB CABLE REPLACEMENT PER SPAN
1149	20-09-2025	Part of : Block A Sewak Park Dwarka,Block B1 Sewak Park Dwarka,Block B Sewak Park Dwarka,Block C Sewak Park Dwarka,Shanti Park Dwarka,	3332	Other Outage	Planned Outage	20-09-2025	11:27	20-09-2025	14:00	2:33	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1150	22-09-2025	Part of : NAWADA VILLAGE	437	Other Outage	Unplanned Outage	22-09-2025	13:01	22-09-2025	14:16	1:15	0.000417	LT POLE REPLACEMENT
1151	22-09-2025	Part of : BLOCK A RAMA PARK,BLOCK B,D & E BHAGWATI GARDEN NAWADA,ROSHAN GARDEN BHAGWATI GARDEN	1444	Other Outage	Planned Outage	22-09-2025	13:53	22-09-2025	16:28	2:35	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1152	22-09-2025	Part of : VIPIN GARDEN EXTENSION NAWADA	615	Other Outage	Planned Outage	22-09-2025	13:39	22-09-2025	15:57	2:18	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1153	22-09-2025	Part of : BLOCK R,RK,W & WE MOHAN GARDEN RAZAPUR KHURD,RAZA PUR KHURD VIKAS NAGAR	1864	Other Outage	Planned Outage	22-09-2025	12:27	22-09-2025	15:21	2:54	0.001933	3PH HT AB CABLE REPLACEMENT PER SPAN
1154	22-09-2025	Part of : BLOCK A MAHAVIR ENCLAVE NAWADA	1102	Other Outage	Planned Outage	22-09-2025	12:11	22-09-2025	15:58	3:47	0.000000	3PH DB REPLACEMENT
1155	23-09-2025	Part of : LAXMI VIHAR NAWADA,	393	Other Outage	Unplanned Outage	23-09-2025	13:22	23-09-2025	14:43	1:21	0.000540	REPAIRING OF HVDS CIRCUIT
1156	23-09-2025	Part of : NAWADA EXTENSION NAWADA,	871	Other Outage	Unplanned Outage	23-09-2025	10:57	23-09-2025	12:27	1:30	0.002500	ATTEND WEAK POINT/HOT SPOT
1157	23-09-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,	383	Other Outage	Planned Outage	23-09-2025	15:11	23-09-2025	16:55	1:44	0.000000	FEEDER PILLAR REPLACEMENT
1158	23-09-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA,	1517	Other Outage	Planned Outage	23-09-2025	14:09	23-09-2025	16:07	1:58	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1159	23-09-2025	Part of : BLOCK A MAHAVIR ENCLAVE NAWADA,BLOCK B MAHAVIR ENCLAVE NAWADA,	700	Other Outage	Planned Outage	23-09-2025	13:18	23-09-2025	16:05	2:47	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1160	23-09-2025	Part of : BLOCK R 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD,BLOCK N 1 MOHAN GARDEN RAZAPUR KHURD,BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK M ZAILDAR ENCLAVE HASTSAL,BLOCK N 2 MOHAN GARDEN RAZAPUR KHURD,BLOCK S MOHAN GARDEN RAZAPUR KHURD,	2847	Other Outage	Planned Outage	23-09-2025	12:43	23-09-2025	14:54	2:11	0.001456	3PH HT AB CABLE REPLACEMENT PER SPAN
1161	24-09-2025	Part of : BLOCK H BHAGWATI GARDEN NAWADA,BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	3279	Other Outage	Unplanned Outage	24-09-2025	11:50	24-09-2025	13:29	1:39	0.000715	REPAIRING OF HVDS CIRCUIT
1162	24-09-2025	Part of : BLOCK D MANSA RAM PARK UTTAM NAGAR	1383	Other Outage	Unplanned Outage	24-09-2025	11:40	24-09-2025	13:28	1:48	0.000780	REPAIRING OF HVDS CIRCUIT
1163	24-09-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK A MAHAVIR ENCLAVE NAWADA,BLOCK B BHAGWATI GARDEN NAWADA	456	Other Outage	Planned Outage	24-09-2025	15:26	24-09-2025	16:12	0:46	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1164	24-09-2025	Part of : BLOCK WE MOHAN GARDEN RAZAPUR KHURD	901	Other Outage	Planned Outage	24-09-2025	12:00	24-09-2025	15:01	3:01	0.002011	3PH HT AB CABLE REPLACEMENT PER SPAN
1165	24-09-2025	Part of : NAWADA EXTENSION,BLOCK A & B MAHAVIR ENCLAVE NAWADA	2069	Other Outage	Planned Outage	24-09-2025	11:29	24-09-2025	13:39	2:10	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1166	25-09-2025	Part of : B,D & H-BLOCK BHAGWATI GARDEN,LAXMI VIHARAA-,BLOCK BHAGWATI GARDEN EXTENSION	4102	Other Outage	Unplanned Outage	25-09-2025	22:59	25-09-2025	23:43	0:44	0.000636	CABLE FAULT
1167	25-09-2025	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA	1192	Other Outage	Planned Outage	25-09-2025	15:56	25-09-2025	17:11	1:15	0.000000	LT CONDUCTOR REPLACEMENT
1168	25-09-2025	Part of : BLOCK A MAHAVIR ENCLAVE NAWADA	1259	Other Outage	Planned Outage	25-09-2025	11:46	25-09-2025	13:51	2:05	0.000000	LT CIRCUIT MAINTENANCE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1169	25-09-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	533	Other Outage	Planned Outage	25-09-2025	11:02	25-09-2025	14:09	3:07	0.000000	LT CONDUCTOR REPLACEMENT
1170	26-09-2025	Part of : VIPIN GARDEN EXTENSION VIPIN GARDEN NAWADA	1321	Other Outage	Planned Outage	26-09-2025	14:20	26-09-2025	15:52	1:32	0.000000	3PH DB REPLACEMENT
1171	26-09-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	525	Other Outage	Planned Outage	26-09-2025	12:13	26-09-2025	15:17	3:04	0.002044	3PH HT AB CABLE REPLACEMENT PER SPAN
1172	26-09-2025	Part of : MOHAN GARDEN NAWADA, PHASE 1 & 2 OM VIHAR NAWADA, BLOCK C JJ COLONY UTTAM NAGAR	3726	Other Outage	Planned Outage	26-09-2025	11:17	26-09-2025	15:04	3:47	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1173	27-09-2025	Part of : BLOCK A RAMA PARK BHAGWATI GARDEN NAWADA,BLOCK E BHAGWATI GARDEN NAWADA,BLOCK L BHAGWATI GARDEN NAWADA,	1517	Other Outage	Planned Outage	27-09-2025	14:53	27-09-2025	16:45	1:52	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1174	27-09-2025	Part of : NAWADA EXTENSION NAWADA,	645	Other Outage	Planned Outage	27-09-2025	11:24	27-09-2025	13:22	1:58	0.000656	PROPOER CLEANING OF OPERATING MECHANISM USING CRCS PER WAY
1175	27-09-2025	Part of : NAWADA EXTENSION NAWADA,BLOCK A MAHAVIR ENCLAVE NAWADA,BLOCK B MAHAVIR ENCLAVE NAWADA,	2088	Other Outage	Planned Outage	27-09-2025	11:41	27-09-2025	13:23	1:42	0.000567	REPLACEMET OF FAULTY END BOX
1176	27-09-2025	Part of : BLOCK R MOHAN GARDEN RAZAPUR KHURD,	1094	Other Outage	Planned Outage	27-09-2025	13:02	27-09-2025	16:02	3:00	0.000500	1PH HT AB END TERMINATION REPLACEMENT
1177	27-09-2025	Part of : BLOCK N 1 MOHAN GARDEN RAZAPUR KHURD,	1360	Other Outage	Planned Outage	27-09-2025	12:31	27-09-2025	14:57	2:26	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1178	27-09-2025	Part of : NAWADA EXTENSION NAWADA,	871	Other Outage	Planned Outage	27-09-2025	10:52	27-09-2025	14:37	3:45	0.000000	FEEDER PILLAR REPLACEMENT
1179	28-09-2025	Part of : BHAGWATI GARDEN EXTENSION NAWADA	2192	Other Outage	Unplanned Outage	28-09-2025	14:46	28-09-2025	16:09	1:23	0.000461	REPAIRING OF HVDS CIRCUIT
1180	29-09-2025	Part of : B,D & H-BLOCK BHAGWATI GARDEN,LAXMI VIHAR,A-BLOCK A BHAGWATI GARDEN EXTENSION	4104	Other Outage	Unplanned Outage	29-09-2025	22:05	29-09-2025	22:43	0:38	0.000179	CABLE FAULT
1181	29-09-2025	Part of : H-BLOCK BHAGWATI GARDEN NAWADA	1424	Other Outage	Unplanned Outage	29-09-2025	19:03	29-09-2025	20:06	1:03	0.000875	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
1182	29-09-2025	Part of : LAXMI VIHAR NAWADA	1424	Other Outage	Planned Outage	29-09-2025	12:08	29-09-2025	15:13	3:05	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1183	29-09-2025	Part of : BLOCK P 2 MOHAN GARDEN RAZAPUR KHURD, BLOCK P MOHAN GARDEN RAZAPUR KHURD	1288	Other Outage	Planned Outage	29-09-2025	12:17	29-09-2025	14:31	2:14	0.001489	3PH HT AB CABLE REPLACEMENT
1184	29-09-2025	Part of : BLOCK A MAHAVIR ENCLAVE NAWADA	1102	Other Outage	Planned Outage	29-09-2025	10:43	29-09-2025	14:06	3:23	0.000000	3PH DB REPLACEMENT
1185	29-09-2025	Part of : NAWADA EXTENSION	1375	Other Outage	Planned Outage	29-09-2025	10:46	29-09-2025	14:07	3:21	0.000000	DT REPLACEMENT
1186	30-09-2025	Part of : BLOCK A,B,B1 & C SEWAK PARK DWARKA, SHANTI PARK DWARKA, DWARKA MOR	3727	Other Outage	Unplanned Outage	30-09-2025	11:56	30-09-2025	12:09	0:13	0.000271	TREE BRANCH FALLEN ON O/H LINE
1187	30-09-2025	Part of : BLOCK L BHAGWATI GARDEN NAWADA,BLOCK M & F ZAILDAR ENCLAVE HASTSAL, PHASE 2 OM VIHAR NAWADA	5323	Other Outage	Unplanned Outage	30-09-2025	11:47	30-09-2025	12:09	0:22	0.000617	HVDS FAULT
1188	30-09-2025	Part of : BLOCK R 5 MOHAN GARDEN RAZAPUR KHURD	1	Other Outage	Unplanned Outage	30-09-2025	00:03	30-09-2025	00:49	0:46	0.000639	REPAIR/REPLACEMENT WORK OF HVDS CABLE
1189	30-09-2025	Part of : BLOCK M ZAILDAR ENCLAVE HASTSAL	1827	Other Outage	Unplanned Outage	30-09-2025	14:42	30-09-2025	16:09	1:27	0.002417	ATTEND WEAK POINT/HOT SPOT
1190	30-09-2025	Part of : RAZA PUR KHURD VIKAS NAGAR	267	Other Outage	Planned Outage	30-09-2025	11:16	30-09-2025	13:17	2:01	0.000000	FEEDER PILLAR REPLACEMENT
1191	01-09-2025	Part of : UDAI VIHAR,RANJEET VIHAR	6312	Other Outage	Unplanned Outage	01-09-2025	23:02	01-09-2025	23:51	0:49	0.003512	TREE TOUCHING
1192	01-09-2025	Part of : A & H-BLOCK DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	33	Other Outage	Unplanned Outage	01-09-2025	17:11	01-09-2025	17:45	0:34	0.001776	HT SYSTEM FAULT
1193	01-09-2025	Part of : CHANDER VIHAR,VIKASPURI EXTN	5273	Other Outage	Unplanned Outage	01-09-2025	14:52	01-09-2025	15:41	0:49	0.001402	CABLE FAULT
1194	01-09-2025	Part of : HARPHOOL VIHAR	2037	Other Outage	Planned Outage	01-09-2025	11:41	01-09-2025	15:09	3:28	0.000578	REPLACEMENT OF LT BUSHING ROD
1195	02-09-2025	Part of : RANJEET VIHAR, CHANDER VIHAR, UDAI VIHAR, NIHAL VIHAR ADHYAPAK NAGAR, KESHAVPUR PUMP HOUSE (HTC)	5799	Other Outage	Unplanned Outage	02-09-2025	00:26	02-09-2025	00:44	0:18	0.000000	TREE TOUCHING
1196	02-09-2025	Part of : NARESH PARK NANGLOI, AMANPURI NANGLOI, AMANPURI DAWA FACTORY (HTC)	1663	Other Outage	Unplanned Outage	02-09-2025	09:35	02-09-2025	10:18	0:43	0.000561	HVDS FAULT
1197	02-09-2025	Part of : RANJEET VIHAR, CHANDER VIHAR, UDAI VIHAR, NIHAL VIHAR ADHYAPAK NAGAR, KESHAVPUR PUMP HOUSE (HTC)	5799	Other Outage	Unplanned Outage	02-09-2025	06:56	02-09-2025	07:48	0:52	0.001416	HT SYSTEM FAULT
1198	02-09-2025	Part of : PIRA GARHI VILLAGE PASCHIM VIHAR, EKTA ENCLAVE, NATIONAL MARKET PIRA GARHI VILLAGE	1289	Other Outage	Unplanned Outage	02-09-2025	01:29	02-09-2025	02:15	0:46	0.000537	TREE TOUCHING
1199	02-09-2025	Part of : NARESH PARK NANGLOI, AMANPURI NANGLOI, AMANPURI DAWA FACTORY (HTC)	1663	Other Outage	Unplanned Outage	02-09-2025	01:17	02-09-2025	02:15	0:58	0.000757	TREE TOUCHING
1200	03-09-2025	Part of : UDYOG NAGAR MANGOLPURI	378	Other Outage	Unplanned Outage	03-09-2025	20:35	03-09-2025	21:20	0:45	0.001075	FAULT IN HT CONSUMER PANEL (C-1 UDYOG NAGAR)
1201	03-09-2025	Part of : NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR,BHERA ENCLAVE PASCHIM VIHAR,PIRA GARHI VILLAGE PASCHIM VIHAR	1018	Other Outage	Unplanned Outage	03-09-2025	23:47	04-09-2025	01:22	1:35	0.000660	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1202	03-09-2025	Part of : BLOCK D NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,	922	Other Outage	Planned Outage	03-09-2025	11:22	03-09-2025	13:54	2:32	0.000000	LT TRANSFORMER MAINTENANCE
1203	03-09-2025	Part of : VIRAT APARTMENT PASCHIM VIHAR,	180	Other Outage	Planned Outage	03-09-2025	11:09	03-09-2025	13:54	2:45	0.000000	LT TRANSFORMER MAINTENANCE
1204	03-09-2025	Part of : GH 6 WHITE APPARTMENTS PASCHIM VIHAR,	321	Other Outage	Planned Outage	03-09-2025	11:11	03-09-2025	13:52	2:41	0.000000	LT TRANSFORMER MAINTENANCE
1205	03-09-2025	Part of : JAI VIHAR PH-1, PH-3,	985	Other Outage	Planned Outage	03-09-2025	11:14	03-09-2025	13:51	2:37	0.000000	LT TRANSFORMER MAINTENANCE
1206	04-09-2025	Part of : ADHYAPAK NAGAR NANGLOI	404	Other Outage	Unplanned Outage	04-09-2025	11:23	04-09-2025	12:49	1:26	0.000000	MOBILE TRANSFORMER REPLACEMENT
1207	04-09-2025	Part of : VIRAT APARTMENT PASCHIM VIHAR	89	Other Outage	Planned Outage	04-09-2025	11:40	04-09-2025	14:31	2:51	0.000950	LT CIRCUIT MAINTENANCE ACTIVITY
1208	04-09-2025	Part of : UDAI VIHAR	1341	Other Outage	Planned Outage	04-09-2025	11:38	04-09-2025	14:34	2:56	0.000489	LT CIRCUIT MAINTENANCE ACTIVITY
1209	05-09-2025	Part of : A & H-BLOCK DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	33	Other Outage	Unplanned Outage	05-09-2025	15:05	05-09-2025	15:53	0:48	0.002947	HT SYSTEM FAULT
1210	06-09-2025	Part of : BLOCK A & H DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	49	Other Outage	Unplanned Outage	06-09-2025	14:18	06-09-2025	14:44	0:26	0.000000	ATTEND WEAK POINT/HOT SPOT
1211	06-09-2025	Part of : BLOCK GH 8 PASCHIM VIHAR	201	Other Outage	Planned Outage	06-09-2025	11:05	06-09-2025	14:04	2:59	0.000000	REPLACEMENT OF LT BUSHING ROD
1212	06-09-2025	Part of : CHANDER VIHAR	1905	Other Outage	Planned Outage	06-09-2025	11:06	06-09-2025	13:55	2:49	0.000000	REPLACEMET OF HT BUSHING ROD
1213	06-09-2025	Part of : NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI	1232	Other Outage	Planned Outage	06-09-2025	11:16	06-09-2025	13:54	2:38	0.000658	REPLACEMET OF HT BUSHING ROD
1214	06-09-2025	Part of : NAMDHARI COLONY ADHYAPAK NAGAR NANGLOI	985	Other Outage	Planned Outage	06-09-2025	11:12	06-09-2025	13:53	2:41	0.000671	REPLACEMET OF HT BUSHING ROD
1215	07-09-2025	Part of : BLOCK 1 SUNDER VIHAR PASCHIM VIHAR,BLOCK 5 SUNDER VIHAR PASCHIM VIHAR,BLOCK 13 SUNDER VIHAR PASCHIM VIHAR,SUNDER VIHAR PASCHIM VIHAR,BLOCK GH10 SUNDER VIHAR PASCHIM VIHAR	2045	Other Outage	Unplanned Outage	07-09-2025	06:56	07-09-2025	07:42	0:46	0.000307	HT SYSTEM FAULT
1216	07-09-2025	Part of : BLOCK A DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI,BLOCK H DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI	279	Other Outage	Unplanned Outage	07-09-2025	21:50	07-09-2025	23:05	1:15	0.001354	CABLE FAULT
1217	07-09-2025	Part of : NARESH PARK NANGLOI,	506	Other Outage	Planned Outage	07-09-2025	10:51	07-09-2025	16:31	5:40	0.001417	REPLACEMET OF HT BUSHING ROD
1218	08-09-2025	Part of : BHERA ENCLAVE PASCHIM VIHAR,NATIONAL MARKET PIRA GARHI VILLAGE PASCHIM VIHAR	1702	Other Outage	Unplanned Outage	08-09-2025	12:01	08-09-2025	13:41	1:40	0.000000	ATTENDING WEAK POINTS/HOT SPOT
1219	08-09-2025	Part of : NILOTHI VILLAGE	465	Other Outage	Planned Outage	08-09-2025	11:25	08-09-2025	14:58	3:33	0.001183	REPLACEMET OF HT BUSHING ROD
1220	08-09-2025	Part of : DASS GARDEN	939	Other Outage	Planned Outage	08-09-2025	10:35	08-09-2025	15:25	4:50	0.001611	REPLACEMET OF HT BUSHING ROD
1221	08-09-2025	Part of : INDER ENCLAVE PASCHIM VIHAR	96	Other Outage	Planned Outage	08-09-2025	11:04	08-09-2025	13:51	2:47	0.000928	REPLACEMET OF HT BUSHING ROD
1222	08-09-2025	Part of : BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI	284	Other Outage	Planned Outage	08-09-2025	10:38	08-09-2025	15:48	5:10	0.000861	REPLACEMENT OF LT BUSHING ROD
1223	09-09-2025	Part of : B-BLOCK AMANPURI KAMRUDDIN NAGAR NANGLOI	1214	Other Outage	Planned Outage	09-09-2025	15:49	09-09-2025	16:56	1:07	0.000744	1PH HT AB END TERMINATION REPLACEMENT
1224	09-09-2025	Part of : DASS GARDEN	482	Other Outage	Planned Outage	09-09-2025	10:45	09-09-2025	14:21	3:36	0.002400	REPLACEMET OF LT BUSHING ROD
1225	09-09-2025	Part of : G-BLOCK UDAY VIHAR 2 ADHYAPAK NAGAR NANGLOI	1208	Other Outage	Planned Outage	09-09-2025	10:44	09-09-2025	14:22	3:38	0.002119	REPLACEMENT OF LT BUSHING ROD
1226	09-09-2025	Part of : S-BLOCK JAWALAPURI EXTENSION PASCHIM VIHAR	664	Other Outage	Planned Outage	09-09-2025	10:43	09-09-2025	13:49	3:06	0.002067	REPLACEMET OF LT BUSHING ROD
1227	09-09-2025	Part of : GH 12-BLOCK PASCHIM VIHAR	54	Other Outage	Planned Outage	09-09-2025	11:02	09-09-2025	14:22	3:20	0.000833	REPLACEMENT OF LT BUSHING ROD
1228	10-09-2025	Part of : BLOCK A & B NARESH PARK EXTENSION NANGLOI	2873	Other Outage	Planned Outage	10-09-2025	12:58	10-09-2025	15:32	2:34	0.001283	3PH HT AB CABLE REPLACEMENT PER SPAN,3PH HT AB END TERMINATION REPLACEMENT
1229	10-09-2025	Part of : BLOCK C JAWALAPURI PASCHIM VIHAR	359	Other Outage	Planned Outage	10-09-2025	11:15	10-09-2025	14:20	3:05	0.000000	REPLACEMET OF HT BUSHING ROD
1230	10-09-2025	Part of : GH 6 PASCHIM VIHAR	102	Other Outage	Planned Outage	10-09-2025	10:55	10-09-2025	14:48	3:53	0.000000	REPLACEMENT OF LT BUSHING ROD
1231	10-09-2025	Part of : JAI VIHAR PH-1, PH-3	528	Other Outage	Planned Outage	10-09-2025	10:45	10-09-2025	14:46	4:01	0.000000	REPLACEMET OF HT BUSHING ROD
1232	10-09-2025	Part of : BLOCK D VANDANA VIHAR NANGLOI	1174	Other Outage	Planned Outage	10-09-2025	10:28	10-09-2025	14:14	3:46	0.001883	REPLACEMET OF HT BUSHING ROD
1233	11-09-2025	Part of : CHANDER VIHAR,RISALA GARDEN NILOTHI,NILOTHI VILLAGE	2005	Other Outage	Unplanned Outage	11-09-2025	00:32	11-09-2025	01:13	0:41	0.001321	HT SYSTEM FAULT
1234	11-09-2025	Part of : CHANDER VIHAR,	1290	Other Outage	Planned Outage	11-09-2025	11:55	11-09-2025	14:03	2:08	0.000000	REPLACEMET OF HT BUSHING ROD
1235	11-09-2025	Part of : PRATAP VIHAR,	640	Other Outage	Planned Outage	11-09-2025	10:47	11-09-2025	14:01	3:14	0.001078	REPLACEMENT OF LT BUSHING ROD
1236	11-09-2025	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR,	1683	Other Outage	Planned Outage	11-09-2025	11:05	11-09-2025	13:58	2:53	0.000961	REPLACEMET OF HT BUSHING ROD
1237	11-09-2025	Part of : BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,	1560	Other Outage	Planned Outage	11-09-2025	11:03	11-09-2025	13:59	2:56	0.000978	REPLACEMET OF HT BUSHING ROD
1238	11-09-2025	Part of : BLOCK GH 7 PASCHIM VIHAR,	205	Other Outage	Planned Outage	11-09-2025	11:32	11-09-2025	14:02	2:30	0.000833	REPLACEMET OF HT BUSHING ROD
1239	12-09-2025	Part of : BLOCK A & B AMANPURI KAMRUDDIN NAGAR NANGLOI,BLOCK B NARESH PARK EXTENSION NANGLOI	2879	Other Outage	Planned Outage	12-09-2025	11:24	12-09-2025	15:44	4:20	0.002167	3PH HT AB CABLE REPLACEMENT PER SPAN
1240	12-09-2025	Part of : RANHOLLA	165	Other Outage	Planned Outage	12-09-2025	10:57	12-09-2025	15:46	4:49	0.001204	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1241	12-09-2025	Part of : CHANDER VIHAR	1939	Other Outage	Planned Outage	12-09-2025	10:48	12-09-2025	13:09	2:21	0.000979	REPLACEMET OF HT BUSHING ROD
1242	12-09-2025	Part of : INDER ENCLAVE PASCHIM VIHAR	286	Other Outage	Planned Outage	12-09-2025	11:14	12-09-2025	14:04	2:50	0.000708	REPLACEMET OF HT BUSHING ROD
1243	12-09-2025	Part of : NILOTHI VILLAGE	465	Other Outage	Planned Outage	12-09-2025	10:51	12-09-2025	15:13	4:22	0.001092	REPLACEMENT OF HT BUSHING ROD
1244	13-09-2025	Part of : CHANDER VIHAR	1121	Other Outage	Planned Outage	13-09-2025	11:06	13-09-2025	13:54	2:48	0.000000	REPLACEMENT OF LT BUSHING ROD
1245	13-09-2025	Part of : BLOCK E VANDANA VIHAR NANGLOI	1628	Other Outage	Planned Outage	13-09-2025	10:49	13-09-2025	13:50	3:01	0.000000	REPLACEMENT OF LT BUSHING ROD
1246	15-09-2025	Part of : NILOTHI VILLAGE,	467	Other Outage	Planned Outage	15-09-2025	11:14	15-09-2025	13:46	2:32	0.000633	REPLACEMENT OF LT BUSHING ROD
1247	15-09-2025	Part of : GRAM SABHA COLONY,	780	Other Outage	Planned Outage	15-09-2025	10:47	15-09-2025	13:47	3:00	0.000600	REPLACEMET OF HT BUSHING ROD
1248	16-09-2025	Part of : VANDANA VIHAR NANGLOI	1303	Other Outage	Planned Outage	16-09-2025	11:05	16-09-2025	13:55	2:50	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1249	16-09-2025	Part of : NANGLI VIHAR	536	Other Outage	Planned Outage	16-09-2025	11:06	16-09-2025	13:54	2:48	0.000000	REPLACEMENT OF HT BUSHING ROD
1250	16-09-2025	Part of : CAMP 5 JAWALAPURI PASCHIM VIHAR	677	Other Outage	Planned Outage	16-09-2025	11:03	16-09-2025	13:53	2:50	0.000000	REPLACEMET OF HT BUSHING ROD
1251	17-09-2025	Part of : D-BLOCK VANDANA VIHAR,B-BLOCK B LAXMI PARK	1145	Other Outage	Planned Outage	17-09-2025	12:49	17-09-2025	16:37	3:48	0.001900	3PH HT AB END TERMINATION REPLACEMENT
1252	17-09-2025	Part of : NANGLI VIHAR	1899	Other Outage	Planned Outage	17-09-2025	11:30	17-09-2025	14:18	2:48	0.001400	REPLACEMET OF LT BUSHING ROD
1253	17-09-2025	Part of : BLOCK 13 SUNDER VIHAR PASCHIM VIHAR	398	Other Outage	Planned Outage	17-09-2025	11:32	17-09-2025	14:17	2:45	0.001146	REPLACEMET OF LT BUSHING ROD
1254	17-09-2025	Part of : SHIV VIHAR NANGLOI	1348	Other Outage	Planned Outage	17-09-2025	11:45	17-09-2025	14:20	2:35	0.001722	REPLACEMET OF LT BUSHING ROD
1255	18-09-2025	Part of : VANDANA VIHAR NANGLOI, LAXMI PARK VANDANA VIHAR NANGLOI	5445	Other Outage	Unplanned Outage	18-09-2025	14:35	18-09-2025	15:26	0:51	0.001091	HVDS FAULT
1256	18-09-2025	Part of : UDYOG NAGAR MANGOLPURI	379	Other Outage	Unplanned Outage	18-09-2025	04:47	18-09-2025	05:37	0:50	0.000875	FAULT IN HT CONSUMER PANEL (K-8 UDYOG NAGAR)
1257	18-09-2025	Part of : NARESH PARK NANGLOI, BLOCK A & B NARESH PARK EXTENSION NANGLOI	1003	Other Outage	Planned Outage	18-09-2025	10:49	18-09-2025	13:44	2:55	0.001458	3PH HT AB END TERMINATION REPLACEMENT,DT REPLACEMET PER DT
1258	18-09-2025	Part of : CHANDER VIHAR	1260	Other Outage	Planned Outage	18-09-2025	12:22	18-09-2025	14:56	2:34	0.000642	REPLACEMET OF HT BUSHING ROD
1259	18-09-2025	Part of : JAI VIHAR BAPROLA	976	Other Outage	Planned Outage	18-09-2025	10:54	18-09-2025	13:42	2:48	0.000933	REPLACEMENT OF LT BUSHING ROD
1260	19-09-2025	Part of : BLOCK D DELHI STATE INDUSTRIAL DEVELOPMENT CORPORATION NANGLOI,	977	Other Outage	Planned Outage	19-09-2025	12:07	19-09-2025	14:08	2:01	0.000000	REPLACEMET OF HT BUSHING ROD
1261	19-09-2025	Part of : JAI VIHAR PH-1, PH-3,	644	Other Outage	Planned Outage	19-09-2025	10:59	19-09-2025	13:56	2:57	0.000000	REPLACEMENT OF LT BUSHING ROD
1262	19-09-2025	Part of : NILOTHI VILLAGE,	468	Other Outage	Planned Outage	19-09-2025	11:01	19-09-2025	13:53	2:52	0.000000	REPLACEMENT OF HT BUSHING ROD
1263	19-09-2025	Part of : BLOCK X JJ COLONY 3 NANGLOI,	903	Other Outage	Planned Outage	19-09-2025	10:56	19-09-2025	13:51	2:55	0.000000	REPLACEMENT OF HT BUSHING ROD
1264	20-09-2025	Part of : Rajiv Ratan Awas Flats,Pradhan Enclave,Nangli Vihar	7479	Other Outage	Unplanned Outage	20-09-2025	14:17	20-09-2025	15:13	0:56	0.001898	CABLE FAULT
1265	20-09-2025	Part of : Bhera Enclave Paschim Vihar,	204	Other Outage	Planned Outage	20-09-2025	11:12	20-09-2025	14:14	3:02	0.000000	REPLACEMENT OF LT BUSHING ROD
1266	20-09-2025	Part of : Block H Vandana Vihar Nangloi,	818	Other Outage	Planned Outage	20-09-2025	11:06	20-09-2025	14:15	3:09	0.000000	REPLACEMET OF HT BUSHING ROD
1267	20-09-2025	Part of : Jai Vihar Ph-1, Ph-3,	1499	Other Outage	Planned Outage	20-09-2025	10:14	20-09-2025	13:11	2:57	0.000000	REPLACEMET OF HT BUSHING ROD
1268	20-09-2025	Part of : Sihv Ram Park Adhyapak Nagar Nangloi,	864	Other Outage	Planned Outage	20-09-2025	10:13	20-09-2025	13:12	2:59	0.000000	REPLACEMET OF HT BUSHING ROD
1269	22-09-2025	Part of : NILOTHI VILLAGE	468	Other Outage	Planned Outage	22-09-2025	13:41	22-09-2025	15:36	1:55	0.000000	REPLACEMET OF HT BUSHING ROD
1270	22-09-2025	Part of : CHANDER VIHAR	980	Other Outage	Planned Outage	22-09-2025	11:59	22-09-2025	13:51	1:52	0.000311	REPLACEMENT OF LT BUSHING ROD
1271	22-09-2025	Part of : RAIL NEER PLANT NANGLOI	293	Other Outage	Planned Outage	22-09-2025	11:31	22-09-2025	13:49	2:18	0.000767	REPLACEMENT OF LT BUSHING ROD
1272	22-09-2025	Part of : RAIL NEER PLANT NANGLOI	284	Other Outage	Planned Outage	22-09-2025	11:31	22-09-2025	13:47	2:16	0.000756	REPLACEMET OF HT BUSHING ROD
1273	23-09-2025	Part of : CHANDER VIHAR,	1260	Other Outage	Planned Outage	23-09-2025	11:09	23-09-2025	14:24	3:15	0.000000	REPLACEMET OF HT BUSHING ROD
1274	23-09-2025	Part of : BLOCK C KAMRUDDIN NAGAR NANGLOI,ADHYAPAK NAGAR NANGLOI,BLOCK G NIHAL VIHAR ADHYAPAK NAGAR NANGLOI,SIHV RAM PARK ADHYAPAK NAGAR NANGLOI,	1111	Other Outage	Planned Outage	23-09-2025	10:49	23-09-2025	14:25	3:36	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1275	23-09-2025	Part of : BLOCK GH 8 PASCHIM VIHAR,	201	Other Outage	Planned Outage	23-09-2025	11:10	23-09-2025	14:01	2:51	0.000000	REPLACEMET OF HT BUSHING ROD
1276	24-09-2025	Part of : NARESH PARK EXTENSION,NANGLOI JAT NANGLOI,BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI,BLOCK B AMANPURI KAMRUDDIN NAGAR NANGLOI	2613	Other Outage	Unplanned Outage	24-09-2025	21:38	24-09-2025	22:29	0:51	0.002267	TREE BRANCH FALLEN ON O/H LINE
1277	24-09-2025	Part of : CHANDER VIHAR,VIKASPURI EXTN	5354	Other Outage	Unplanned Outage	24-09-2025	14:05	24-09-2025	15:07	1:02	0.000000	MOBILE TRANSFORMER REPLACEMENT
1278	24-09-2025	Part of : BAPROLA VILLAGE,JAI VIHAR PH-1, PH-3,TILANGPUR KOTLA VILLAGE,HARPHOOL VIHAR,PRASHANT ENCLAVE,NIRMAL VIHAR BAPROLA	6740	Other Outage	Unplanned Outage	24-09-2025	11:32	24-09-2025	12:33	1:01	0.000000	MOBILE TRANSFORMER REPLACEMENT
1279	24-09-2025	Part of : BLOCK GH 12 PASCHIM VIHAR	63	Other Outage	Planned Outage	24-09-2025	11:04	24-09-2025	14:04	3:00	0.000600	REPLACEMENT OF LT BUSHING ROD
1280	24-09-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	1194	Other Outage	Planned Outage	24-09-2025	11:13	24-09-2025	14:05	2:52	0.002867	REPLACEMENT OF LT BUSHING ROD
1281	25-09-2025	Part of : A & B-BLOCK JAWALAPURI PASCHIM VIHAR,RAO VIHAR,HANUMAN ENCLAVE,SHIV VIHAR NANGLOI	6962	Other Outage	Unplanned Outage	25-09-2025	17:32	25-09-2025	18:19	0:47	0.001149	HVDS FAULT
1282	25-09-2025	Part of : UDYOG NAGAR MANGOLPURI	27	Other Outage	Unplanned Outage	25-09-2025	07:46	25-09-2025	08:28	0:42	0.000875	BIRDAGE

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1283	25-09-2025	Part of : BLOCK A JAWALAPURI PASCHIM VIHAR	964	Other Outage	Planned Outage	25-09-2025	12:19	25-09-2025	14:50	2:31	0.000629	REPLACEMET OF LT BUSHING ROD
1284	25-09-2025	Part of : DDA PARK NIHAL VIHAR ADHYAPAK NAGAR NANGLOI	209	Other Outage	Planned Outage	25-09-2025	11:01	25-09-2025	13:58	2:57	0.000983	REPLACEMENT OF LT BUSHING ROD
1285	25-09-2025	Part of : GH 6 PASCHIM VIHAR	391	Other Outage	Planned Outage	25-09-2025	10:57	25-09-2025	14:01	3:04	0.001022	REPLACEMENT OF LT BUSHING ROD
1286	26-09-2025	Part of : JAI VIHAR PH-1, RANHOLLA, TILANGPUR KOTLA VILLAGE	2466	Other Outage	Planned Outage	26-09-2025	14:16	26-09-2025	16:33	2:17	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1287	26-09-2025	Part of : NILOTHI VILLAGE	469	Other Outage	Planned Outage	26-09-2025	13:26	26-09-2025	15:29	2:03	0.000513	REPLACEMENT OF LT BUSHING ROD
1288	26-09-2025	Part of : BLOCK B JAWALAPURI PASCHIM VIHAR	711	Other Outage	Planned Outage	26-09-2025	11:03	26-09-2025	13:45	2:42	0.000675	REPLACEMET OF HT BUSHING ROD
1289	26-09-2025	Part of : BLOCK A & B JAWALAPURI PASCHIM VIHAR, HANUMAN ENCLAVE NANGLOI	6538	Other Outage	Planned Outage	26-09-2025	11:03	26-09-2025	13:43	2:40	0.001333	REPLACEMET OF HT BUSHING ROD
1290	26-09-2025	Part of : BLOCK GH 7 PASCHIM VIHAR	262	Other Outage	Planned Outage	26-09-2025	11:01	26-09-2025	13:44	2:43	0.000453	REPLACEMET OF HT BUSHING ROD
1291	27-09-2025	Part of : BLOCK B LAXMI PARK VANDANA VIHAR NANGLOI,	1592	Other Outage	Planned Outage	27-09-2025	11:01	27-09-2025	13:53	2:52	0.000000	REPLACEMENT OF LT BUSHING ROD
1292	27-09-2025	Part of : BLOCK A MIRA BAGH PASCHIM VIHAR,	123	Other Outage	Planned Outage	27-09-2025	11:06	27-09-2025	13:54	2:48	0.000000	REPLACEMET OF HT BUSHING ROD
1293	27-09-2025	Part of : RANHOLLA,RISALA GARDEN NILOTHI,	181	Other Outage	Planned Outage	27-09-2025	10:09	27-09-2025	13:57	3:48	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1294	28-09-2025	Part of : BLOCK L, M & X JJ COLONY 3 NANGLOI	4228	Other Outage	Unplanned Outage	28-09-2025	01:23	28-09-2025	02:16	0:53	0.000000	CABLE FAULT
1295	28-09-2025	Part of : NARESH PARK NANGLOI	92	Other Outage	Planned Outage	28-09-2025	11:31	28-09-2025	14:19	2:48	0.000467	REPLACEMET OF HT BUSHING ROD
1296	29-09-2025	Part of : CHANDER VIHAR	1261	Other Outage	Planned Outage	29-09-2025	12:01	29-09-2025	15:11	3:10	0.000792	REPLACEMENT OF LT BUSHING
1297	29-09-2025	Part of : HANUMAN ENCLAVE NANGLOI, SHIV VIHAR NANGLOI, RAO VIHAR NANGLOI	1059	Other Outage	Planned Outage	29-09-2025	11:05	29-09-2025	13:55	2:50	0.000944	3PH HT AB CABLE REPLACEMENT
1298	30-09-2025	Part of : SH ISHWAR VATIKA ADHYAPAK NAGAR, Q BLOCK NIHAL VIHAR, SIHV RAM PARK ADHYAPAK NAGAR NANGLOI	4174	Other Outage	Unplanned Outage	30-09-2025	12:20	30-09-2025	12:52	0:32	0.000738	TREE TOUCHING
1299	01-09-2025	Part of : NEW & OLD DHARAMPURA MASUDABAD NAJAFGARH	4471	Other Outage	Unplanned Outage	01-09-2025	16:52	01-09-2025	17:28	0:36	0.000520	HT SYSTEM FAULT
1300	01-09-2025	Part of : ROSHAN PURA & ROSHAN VIHAR-1 NAJAFGARH	1429	Other Outage	Unplanned Outage	01-09-2025	11:33	01-09-2025	11:40	0:07	0.000097	REPLACEMENT OF SOCKETS
1301	01-09-2025	Part of : E-BLOCK NEW ROSHAN PURA NAJAFGARH,DHARAMPURA NAJAFGARH	4793	Other Outage	Unplanned Outage	01-09-2025	14:40	01-09-2025	15:31	0:51	0.000708	MOBILE TRANSFORMER REPLACEMENT
1302	03-09-2025	Part of : BLOCK E SHYAM VIHAR I NAJAFGARH,DURGA PARK NAJAFGARH,DINARPUR EXTENSION NAJAFGARH,SHYAM ENCLAVE DINPUR,SHIV PURI I DINPUR	3326	Other Outage	Unplanned Outage	03-09-2025	15:47	03-09-2025	16:26	0:39	0.001278	TREE TOUCHING
1303	03-09-2025	Part of : ROSHAN VIHAR 1 NAJAFGARH,ROSHAN PURA NAJAFGARH,	2036	Other Outage	Unplanned Outage	03-09-2025	16:41	03-09-2025	17:09	0:28	0.000272	REPAIRING OF HT O/H CIRCUIT
1304	03-09-2025	Part of : BABA HARIDAS ENCLAVE,	714	Other Outage	Planned Outage	03-09-2025	12:05	03-09-2025	14:52	2:47	0.003711	TRANSFORMER MAINTENANCE
1305	03-09-2025	Part of : ROSHAN VIHAR 1 NAJAFGARH,	277	Other Outage	Planned Outage	03-09-2025	12:04	03-09-2025	14:50	2:46	0.002767	TRANSFORMER MAINTENANCE
1306	03-09-2025	Part of : SAMTA ENCLAVE QUTUB VIHAR,	930	Other Outage	Planned Outage	03-09-2025	10:44	03-09-2025	13:37	2:53	0.000481	HVDS MAINTENANCE
1307	04-09-2025	Part of : 40-MGD WATER TREATMENT PLANT (HTC)	0	Other Outage	Unplanned Outage	04-09-2025	22:29	04-09-2025	23:12	0:43	0.001194	HT SYSTEM FAULT
1308	04-09-2025	Part of : SECTOR 27 DWARKA	40	Other Outage	Planned Outage	04-09-2025	10:26	04-09-2025	13:05	2:39	0.000442	MAINTENANCE OF TRANFORMER
1309	05-09-2025	Part of : SAI BABA ENCLAVE,ROSHAN MANDI,D-BLOCK LAXMI VIHAR COLONY,NAJAFGARH VILLAGE,NATHU RAM PARK,DHARAMPURA NAJAFGARH	5201	Other Outage	Unplanned Outage	05-09-2025	09:02	05-09-2025	09:23	0:21	0.000000	BIRDAGE
1310	06-09-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	0	Other Outage	Unplanned Outage	06-09-2025	04:40	06-09-2025	05:17	0:37	0.000411	BIRDAGE
1311	06-09-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH EXTENSION	841	Other Outage	Planned Outage	06-09-2025	12:07	06-09-2025	13:46	1:39	0.000550	REPLACEMET OF HT BUSHING ROD
1312	06-09-2025	Part of : BLOCK B POCHANPUR DWARKA	421	Other Outage	Planned Outage	06-09-2025	10:29	06-09-2025	12:43	2:14	0.000558	REPLACEMENT OF LT BUSHING ROD
1313	06-09-2025	Part of : DHARAMPURA NAJAFGARH	465	Other Outage	Planned Outage	06-09-2025	11:31	06-09-2025	13:38	2:07	0.001411	REPLACEMET OF HT BUSHING ROD
1314	06-09-2025	Part of : SARASWATI ENCLAVE HAIBUTPUR	53	Other Outage	Planned Outage	06-09-2025	12:07	06-09-2025	14:27	2:20	0.000778	REPLACEMET OF HT BUSHING ROD
1315	08-09-2025	Part of : POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA	570	Other Outage	Planned Outage	08-09-2025	12:27	08-09-2025	15:29	3:02	0.000506	REPLACEMENT OF LT BUSHING ROD
1316	08-09-2025	Part of : JHARODA KALAN	366	Other Outage	Planned Outage	08-09-2025	10:48	08-09-2025	13:47	2:59	0.002983	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1317	08-09-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	305	Other Outage	Planned Outage	08-09-2025	12:43	08-09-2025	15:30	2:47	0.004175	REPLACEMET OF HT BUSHING ROD
1318	08-09-2025	Part of : SHIKARPUR VILLAGE	279	Other Outage	Planned Outage	08-09-2025	11:11	08-09-2025	13:44	2:33	0.000425	REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1319	08-09-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH EXTENSION	841	Other Outage	Planned Outage	08-09-2025	11:37	08-09-2025	14:43	3:06	0.004133	REPLACEMENT OF LT BUSHING ROD
1320	08-09-2025	Part of : GANDHI PARK DINPUR,SHYAM VIHAR - II DINPUR	2044	Other Outage	Planned Outage	08-09-2025	10:36	08-09-2025	13:33	2:57	0.000983	3PH HT AB CABLE REPLACEMENT PER SPAN
1321	08-09-2025	Part of : ROSHAN VIHAR NAJAFGARH	781	Other Outage	Planned Outage	08-09-2025	10:28	08-09-2025	13:28	3:00	0.000500	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1322	08-09-2025	Part of : BHARTHAL VILLAGE DWARKA	464	Other Outage	Planned Outage	08-09-2025	10:32	08-09-2025	13:25	2:53	0.000481	REPLACEMENT OF LT BUSHING ROD
1323	09-09-2025	Part of : HASANPUR VILLAGE,ASALETUPUR KHAWAD VILLAGE,DAULATPUR VILLAGE,KHERA DABAS VILLAGE,JHATIKARA,PIND WALA KALAN VILLAGE,ASALATPUR KHAWAD,UJWA VILLAGE	2694	Other Outage	Unplanned Outage	09-09-2025	10:05	09-09-2025	11:09	1:04	0.000000	REPAIRING OF RMU
1324	09-09-2025	Part of : SECTOR 16D DWARKA	6	Other Outage	Planned Outage	09-09-2025	11:09	09-09-2025	13:39	2:30	0.000417	REPLACEMENT OF LT BUSHING ROD
1325	09-09-2025	Part of : NIRMAL VIHAR DICHANON KALAN	1030	Other Outage	Planned Outage	09-09-2025	11:17	09-09-2025	14:01	2:44	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1326	09-09-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	206	Other Outage	Planned Outage	09-09-2025	10:50	09-09-2025	13:59	3:09	0.000000	REPLACEMENT OF HT BUSHING ROD
1327	09-09-2025	Part of : SECTOR 27 DWARKA	171	Other Outage	Planned Outage	09-09-2025	11:45	09-09-2025	14:04	2:19	0.000386	HT SLEEVE INSTALLATION
1328	09-09-2025	Part of : KHAIRA VILLAGE	614	Other Outage	Planned Outage	09-09-2025	10:08	09-09-2025	12:35	2:27	0.000408	REPLACEMENT OF HT BUSHING ROD
1329	09-09-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	654	Other Outage	Planned Outage	09-09-2025	10:11	09-09-2025	14:00	3:49	0.000636	DT REPLACEMENT PER DT
1330	10-09-2025	Part of : PIND WALA KALAN VILLAGE, SHERPUR EXTENTION, KHERA DABAS VILLAGE	1643	Other Outage	Planned Outage	10-09-2025	11:36	10-09-2025	11:40	0:04	0.000028	REPLACEMENT OF CROSS-ARMS AND POLES
1331	10-09-2025	Part of : GOYLA KHURD, BLOCK A GOYLA VIHAR GOYLA KHURD	1162	Other Outage	Planned Outage	10-09-2025	13:23	10-09-2025	16:21	2:58	0.000989	INSTALLATION OF PHASE SEPERATOR PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1332	10-09-2025	Part of : AGARWAL COLONY HAIBUTPUR	534	Other Outage	Planned Outage	10-09-2025	10:40	10-09-2025	13:33	2:53	0.004325	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
1333	10-09-2025	Part of : SECTOR 27 DWARKA, BHARTHAL VILLAGE DWARKA	2108	Other Outage	Planned Outage	10-09-2025	10:06	10-09-2025	13:01	2:55	0.001215	CONDUCTOR REPLACEMENT PER SPAN,INSTALLATION OF PHASE SEPERATOR PER SPAN
1334	10-09-2025	Part of : KHAIRA VILLAGE	568	Other Outage	Planned Outage	10-09-2025	10:17	10-09-2025	12:17	2:00	0.000833	REPLACEMENT OF HT BUSHING ROD
1335	11-09-2025	Part of : BLOCK A QUTUB VIHAR PHASE 1 QUTUB VIHAR,GOYALA DAIRY QUTUB VIHAR	321	Other Outage	Unplanned Outage	11-09-2025	09:50	11-09-2025	10:19	0:29	0.000161	CABLE FAULT
1336	11-09-2025	Part of : BLOCK B POCHANPUR DWARKA,POCHANPUR DWARKA,	1502	Other Outage	Planned Outage	11-09-2025	11:55	11-09-2025	14:50	2:55	0.001458	CONDUCTOR REPLACEMENT PER SPAN
1337	11-09-2025	Part of : SECTOR 29 DWARKA,	1087	Other Outage	Planned Outage	11-09-2025	10:54	11-09-2025	13:51	2:57	0.000983	CONDUCTOR REPLACEMENT PER SPAN,INSTALLATION OF PHASE SEPERATOR PER SPAN
1338	11-09-2025	Part of : SAI BABA ENCLAVE MASUDABAD NAJAFGARH,	324	Other Outage	Planned Outage	11-09-2025	12:04	11-09-2025	14:59	2:55	0.000000	3PH DB REVAMPING
1339	11-09-2025	Part of : KHARKHARI NAHA VILLAGE,	342	Other Outage	Planned Outage	11-09-2025	11:45	11-09-2025	14:42	2:57	0.000492	REPLACEMENT OF LT BUSHING ROD
1340	11-09-2025	Part of : SHYAM VIHAR - II DINPUR,GANDHI PARK DINPUR,	571	Other Outage	Planned Outage	11-09-2025	10:13	11-09-2025	13:06	2:53	0.000961	REPLACEMENT OF HT BUSHING ROD
1341	11-09-2025	Part of : AGARWAL COLONY HAIBUTPUR,	535	Other Outage	Planned Outage	11-09-2025	11:46	11-09-2025	14:40	2:54	0.000000	3PH DB REVAMPING
1342	11-09-2025	Part of : SURYA VIHAR DINPUR,SHIV PURI II DINPUR,GANDHI PARK DINPUR,	496	Other Outage	Planned Outage	11-09-2025	10:51	11-09-2025	13:47	2:56	0.000733	3PH HT AB CABLE REPLACEMENT PER SPAN
1343	11-09-2025	Part of : ROSHAN VIHAR NAJAFGARH,	361	Other Outage	Planned Outage	11-09-2025	08:48	11-09-2025	11:38	2:50	0.000472	REPLACEMENT OF LT BUSHING ROD
1344	12-09-2025	Part of : KHAIRA VILLAGE	413	Other Outage	Planned Outage	12-09-2025	14:20	12-09-2025	15:41	1:21	0.000450	REPLACEMENT OF HT BUSHING ROD
1345	12-09-2025	Part of : SULTAN GARDEN,LOKESH PARK EXTN NAJAFGARH,INDRA MARKET,SAINIK ENCLAVE,LOKESH PARK NAJAFGARH,NIRMAL VIHAR DICHANON KALAN	4331	Other Outage	Planned Outage	12-09-2025	11:09	12-09-2025	13:42	2:33	0.003825	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
1346	12-09-2025	Part of : PIND WALA KALAN VILLAGE,SHERPUR EXTENTION,KHARKHARI ROND VILLAGE,PIND WALA KHURD VILLAGE	2552	Other Outage	Planned Outage	12-09-2025	12:08	12-09-2025	14:13	2:05	0.001042	REPLACEMENT OF CROSS-ARMS AND POLES
1347	12-09-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	7	Other Outage	Planned Outage	12-09-2025	09:23	12-09-2025	12:23	3:00	0.000000	3PH DB REPLACEMENT,3PH DB REVAMPING
1348	13-09-2025	Part of : PAPRAWAT VILLAGE,DELHI TEACHERS COLONY DINDARPUR NAJAFGARH	1005	Other Outage	Planned Outage	13-09-2025	10:17	13-09-2025	10:33	0:16	0.000178	REPLACEMENT OF CROSS-ARMS AND POLES
1349	13-09-2025	Part of : GOYLA KHURD	501	Other Outage	Planned Outage	13-09-2025	11:08	13-09-2025	14:58	3:50	0.003833	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1350	13-09-2025	Part of : BLOCK E,Q NEW ROSHAN PURA NAJAFGARH,DURGA PARK	1103	Other Outage	Planned Outage	13-09-2025	09:50	13-09-2025	12:44	2:54	0.000967	DT REPLACEMENT
1351	15-09-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH,	305	Other Outage	Planned Outage	15-09-2025	13:05	15-09-2025	16:02	2:57	0.000000	REPLACEMENT OF HT BUSHING ROD
1352	15-09-2025	Part of : BHARTHAL VILLAGE DWARKA,	621	Other Outage	Planned Outage	15-09-2025	11:19	15-09-2025	14:15	2:56	0.000000	3PH DB REPLACEMENT
1353	15-09-2025	Part of : AGARWAL COLONY HAIBUTPUR,	535	Other Outage	Planned Outage	15-09-2025	11:15	15-09-2025	14:09	2:54	0.000000	3PH DB REVAMPING
1354	16-09-2025	Part of : DHULSIRAS VILLAGE DWARKA	655	Other Outage	Planned Outage	16-09-2025	11:04	16-09-2025	13:59	2:55	0.000000	3PH DB REVAMPING
1355	16-09-2025	Part of : INDRA MARKET	318	Other Outage	Planned Outage	16-09-2025	12:44	16-09-2025	15:20	2:36	0.000000	REPLACEMENT OF LT BUSHING ROD
1356	17-09-2025	Part of : SARASWATI KUNJ JHARODA KALAN,LOKESH PARK EXTN NAJAFGARH	4361	Other Outage	Planned Outage	17-09-2025	10:15	17-09-2025	13:02	2:47	0.004175	REPLACEMENT OF LT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1357	18-09-2025	Part of : SULTAN GARDEN,SHIV ENCLAVE,SAINIK NIKETAN NAJAFGARH,NEW HEERA PARK NAJAFGARH,NEW HIRA NAGAR DICHAN KALAN	2490	Other Outage	Planned Outage	18-09-2025	12:25	18-09-2025	14:07	1:42	0.002550	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1358	18-09-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI, NAJAFGARH EXTENSION	842	Other Outage	Planned Outage	18-09-2025	12:29	18-09-2025	15:22	2:53	0.000000	REPLACEMENT OF LT BUSHING ROD
1359	18-09-2025	Part of : DURGA VIHAR II DINPUR	400	Other Outage	Planned Outage	18-09-2025	10:01	18-09-2025	12:32	2:31	0.001049	REPLACEMET OF HT BUSHING ROD
1360	18-09-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH	305	Other Outage	Planned Outage	18-09-2025	12:29	18-09-2025	15:28	2:59	0.000000	REPLACEMENT OF LT BUSHING ROD
1361	19-09-2025	Part of : POCKET 1 BEES SUTRI COLONY SECTOR 19 DWARKA,	570	Other Outage	Planned Outage	19-09-2025	12:04	19-09-2025	14:57	2:53	0.000000	REPLACEMENT OF GAS KIT AND OIL SEAL
1362	19-09-2025	Part of : NIRMAL VIHAR DICHAN KALAN,	1033	Other Outage	Planned Outage	19-09-2025	11:29	19-09-2025	14:15	2:46	0.000000	REPLACEMENT OF LT BUSHING ROD
1363	19-09-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH,	7	Other Outage	Planned Outage	19-09-2025	11:26	19-09-2025	14:14	2:48	0.002800	REPLACEMENT OF LT BUSHING ROD
1364	19-09-2025	Part of : PREM NAGAR NAJAFGARH,	403	Other Outage	Planned Outage	19-09-2025	10:21	19-09-2025	13:11	2:50	0.000472	REPLACEMET OF HT BUSHING ROD
1365	20-09-2025	Part of : Goyala Dairy Qutub Vihar,Goyla Khurd,Block A Goyla Vihar Goyla Khurd,Block A Qutub Vihar Phase 1 Qutub Vihar,Tajpur Khurd,Shyam Vihar - II Dinpur,Paharwa Colony Chawla,Chawla	2023	Other Outage	Unplanned Outage	20-09-2025	17:23	20-09-2025	18:13	0:50	0.001167	BIRDAGE
1366	20-09-2025	Part of : Prem Nagar Najafgarh,Roshan Pura Najafgarh	2343	Other Outage	Unplanned Outage	20-09-2025	10:47	20-09-2025	11:21	0:34	0.000463	CABLE DAMAGED BY OUTSIDE AGENCY (DJB)
1367	22-09-2025	Part of : KHARKHARI NAHA VILLAGE,PAPRAWAT VILLAGE,PREM NAGAR PAPRAWAT	3862	Other Outage	Unplanned Outage	22-09-2025	01:35	22-09-2025	02:26	0:51	0.002536	HT SYSTEM FAULT
1368	22-09-2025	Part of : GOYALA DAIRY QUTUB VIHAR	212	Other Outage	Unplanned Outage	22-09-2025	13:59	22-09-2025	14:09	0:10	0.000000	SAFEGUARDING OF CABLE
1369	22-09-2025	Part of : SANGAM VIHAR DHARAMPURA NAJAFGARH	37	Other Outage	Planned Outage	22-09-2025	14:49	22-09-2025	16:00	1:11	0.001775	REPLACEMET OF HT BUSHING ROD
1370	22-09-2025	Part of : TODARMAL COLONY NAJAFGARH	506	Other Outage	Planned Outage	22-09-2025	09:59	22-09-2025	11:10	1:11	0.000197	REPLACEMET OF HT BUSHING ROD
1371	22-09-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH EXTENSION	841	Other Outage	Planned Outage	22-09-2025	12:02	22-09-2025	15:12	3:10	0.001056	REPLACEMET OF HT BUSHING ROD
1372	22-09-2025	Part of : SAMTA ENCLAVE QUTUB VIHAR,QUTUB VIHAR PHASE 2	474	Other Outage	Planned Outage	22-09-2025	12:39	22-09-2025	15:08	2:29	0.003725	REPLACEMET OF HT BUSHING ROD
1373	22-09-2025	Part of : BLOCK A & B INDRA PARK MASUDABAD NAJAFGARH, ANAND VIHAR NANGLI SAKRAWATI,ARJUN PARK NANGLI SAKRAWATI	2989	Other Outage	Planned Outage	22-09-2025	09:29	22-09-2025	12:30	3:01	0.005028	3PH HT AB CABLE REPLACEMENT PER SPAN
1374	23-09-2025	Part of : BLOCK X NEW ROSHAN PURA NAJAFGARH	400	Other Outage	Unplanned Outage	23-09-2025	00:32	23-09-2025	01:19	0:47	0.000405	CABLE FAULT
1375	23-09-2025	Part of : SAINIK ENCLAVE,NIRMAL VIHAR DICHAN KALAN,AGARWAL COLONY HAIBUTPUR,	364	Other Outage	Planned Outage	23-09-2025	12:32	23-09-2025	12:51	0:19	0.000106	REPLACEMET OF HT BUSHING ROD
1376	23-09-2025	Part of : BLOCK B POCHANPUR DWARKA,POCHANPUR DWARKA,	837	Other Outage	Planned Outage	23-09-2025	12:24	23-09-2025	12:33	0:09	0.000225	REPLACEMET OF HT BUSHING ROD
1377	23-09-2025	Part of : BLOCK E NEW ROSHAN PURA NAJAFGARH,	791	Other Outage	Planned Outage	23-09-2025	10:44	23-09-2025	12:43	1:59	0.000661	REPLACEMET OF HT BUSHING ROD
1378	23-09-2025	Part of : NANAK HERI VILLAGE,RAGHOPUR VILLAGE,BADUSARAI,	468	Other Outage	Planned Outage	23-09-2025	12:27	23-09-2025	15:20	2:53	0.003844	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1379	24-09-2025	Part of : KHARKHARI NAHA VILLAGE,PIND WALA KALAN VILLAGE	714	Other Outage	Unplanned Outage	24-09-2025	15:50	24-09-2025	16:34	0:44	0.000183	BIRDAGE
1380	24-09-2025	Part of : DICHAN ENCLAVE DICHAN KALAN	150	Other Outage	Planned Outage	24-09-2025	15:14	24-09-2025	16:05	0:51	0.001275	REPLACEMET OF HT BUSHING ROD
1381	24-09-2025	Part of : BLOCK A QUTUB VIHAR PHASE 1	395	Other Outage	Planned Outage	24-09-2025	13:12	24-09-2025	16:06	2:54	0.000725	CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE
1382	24-09-2025	Part of : NAJAFGARH VILLAGE,LOKESH PARK	885	Other Outage	Planned Outage	24-09-2025	11:25	24-09-2025	14:19	2:54	0.000000	REPLACEMET OF HT BUSHING ROD
1383	24-09-2025	Part of : DHARAMPURA NAJAFGARH	718	Other Outage	Planned Outage	24-09-2025	10:24	24-09-2025	13:19	2:55	0.000000	CONDUCTOR REPLACEMENT PER SPAN,JUMPER REPLACEMENT PER POLE
1384	24-09-2025	Part of : PAPRAWAT VILLAGE	792	Other Outage	Planned Outage	24-09-2025	10:26	24-09-2025	12:55	2:29	0.000621	REPLACEMET OF HT BUSHING ROD
1385	25-09-2025	Part of : CHAWLA VILLAGE	448	Other Outage	Planned Outage	25-09-2025	11:36	25-09-2025	12:57	1:21	0.000000	MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES)
1386	25-09-2025	Part of : NAJAFGARH EXTENSION	340	Other Outage	Planned Outage	25-09-2025	11:49	25-09-2025	14:17	2:28	0.000000	REPLACEMET OF HT BUSHING ROD
1387	25-09-2025	Part of : SURYA VIHAR DINPUR,SHIV PURI II	495	Other Outage	Planned Outage	25-09-2025	11:52	25-09-2025	14:18	2:26	0.001217	REPLACEMET OF HT BUSHING ROD
1388	25-09-2025	Part of : SULTAN GARDEN,SHIV ENCLAVE,SAINIK NIKETAN NAJAFGARH	2490	Other Outage	Planned Outage	25-09-2025	08:47	25-09-2025	11:27	2:40	0.004000	REPLACEMET OF HT BUSHING ROD
1389	25-09-2025	Part of : SULTAN GARDEN,NEW HEERA PARK NAJAFGARH	1502	Other Outage	Planned Outage	25-09-2025	09:08	25-09-2025	11:29	2:21	0.003525	REPLACEMET OF HT BUSHING ROD
1390	26-09-2025	Part of : SECTOR 26 DWARKA	74	Other Outage	Planned Outage	26-09-2025	11:12	26-09-2025	13:02	1:50	0.000000	3PH DB REVAMPING
1391	26-09-2025	Part of : TODARMAL COLONY NAJAFGARH	572	Other Outage	Planned Outage	26-09-2025	10:16	26-09-2025	12:10	1:54	0.000633	REPLACEMENT OF LT BUSHING ROD
1392	26-09-2025	Part of : SECTOR 16D DWARKA, SECTOR 24 DWARKA	6	Other Outage	Planned Outage	26-09-2025	10:32	26-09-2025	13:24	2:52	0.000000	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMET OF HT BUSHING ROD
1393	26-09-2025	Part of : NANGLI SANKRANTI NANGLI SAKRAWATI	64	Other Outage	Planned Outage	26-09-2025	11:31	26-09-2025	14:24	2:53	0.000000	REPLACEMET OF HT BUSHING ROD

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1394	26-09-2025	Part of : NIRMAL VIHAR DICHAN KALAN	67	Other Outage	Planned Outage	26-09-2025	11:37	26-09-2025	13:42	2:05	0.003125	REPLACEMENT OF LT BUSHING ROD
1395	27-09-2025	Part of : BLOCK D LAXMI VIHAR COLONY NANGLI SAKRAWATI,NAJAFGARH EXTENSION NAJAFGARH,	841	Other Outage	Planned Outage	27-09-2025	10:06	27-09-2025	13:06	3:00	0.000000	REPLACEMENT OF LT BUSHING ROD
1396	27-09-2025	Part of : NAJAFGARH VILLAGE,	952	Other Outage	Planned Outage	27-09-2025	11:10	27-09-2025	14:06	2:56	0.000000	REPLACEMENT OF HT BUSHING ROD
1397	28-09-2025	Part of : PAPRAWAT VILLAGE,DELHI TEACHERS COLONY DINDARPUR NAJAFGARH,SARIKA VIHAR DINPUR,DURGA PARK NAJAFGARH,DURGA VIHAR I DINPUR,DATA RAM PARK DINPUR	3697	Other Outage	Unplanned Outage	28-09-2025	21:04	28-09-2025	21:34	0:30	0.000967	CABLE FAULT
1398	28-09-2025	Part of : SATYAMPURAM,JHARODA KALAN	851	Other Outage	Unplanned Outage	28-09-2025	09:14	28-09-2025	09:38	0:24	0.000907	CABLE FAULT
1399	28-09-2025	Part of : NAJAFGARH VILLAGE	637	Other Outage	Planned Outage	28-09-2025	07:05	28-09-2025	09:08	2:03	0.000000	REPLACEMENT OF LT BUSHING ROD
1400	29-09-2025	Part of : SECTOR 26 & 27 DWARKA,BHARTHAL VILLAGE	4117	Other Outage	Unplanned Outage	29-09-2025	00:41	29-09-2025	01:00	0:19	0.000686	TREE TOUCHING
1401	29-09-2025	Part of : CHAWLA	73	Other Outage	Planned Outage	29-09-2025	13:49	29-09-2025	16:35	2:46	0.005533	REPLACEMENT OF HT BUSHING ROD
1402	29-09-2025	Part of : DHARAMPURA NAJAFGARH	338	Other Outage	Planned Outage	29-09-2025	09:59	29-09-2025	12:42	2:43	0.000000	REPLACEMENT OF HT BUSHING
1403	29-09-2025	Part of : HASANPUR VILLAGE	247	Other Outage	Planned Outage	29-09-2025	11:21	29-09-2025	13:32	2:11	0.000546	REPLACEMENT OF GAS KIT AND OIL SEAL
1404	30-09-2025	Part of : BLOCK A,B & E INDRA PARK MASUDABAD NAJAFGARH, GEMINI PARK, NANGLI SANKRANTI NANGLI SAKRAWATI	2702	Other Outage	Unplanned Outage	30-09-2025	20:47	30-09-2025	21:22	0:35	0.000000	CABLE FAULT
1405	30-09-2025	Part of : NEW HIRA NAGAR DICHAN KALAN, 40-MGD WATER TREATMENT PLANT (HTC)	4	Other Outage	Unplanned Outage	30-09-2025	13:14	30-09-2025	13:53	0:39	0.000054	HT SYSTEM FAULT
1406	30-09-2025	Part of : BLOCK A QUTUB VIHAR PHASE 1, GOYALA DAIRY QUTUB VIHAR	322	Other Outage	Unplanned Outage	30-09-2025	11:51	30-09-2025	12:49	0:58	0.000886	TREE TRIMMING
1407	30-09-2025	Part of : OLD DHARAMPURA MASUDABAD NAJAFGARH	801	Other Outage	Planned Outage	30-09-2025	10:20	30-09-2025	11:49	1:29	0.000247	INSTALLATION OF BUS BAR
1408	30-09-2025	Part of : SECTOR 29 DWARKA, DHULSIRAS VILLAGE DWARKA	1271	Other Outage	Planned Outage	30-09-2025	10:45	30-09-2025	13:50	3:05	0.000000	REPLACEMENT OF LT BUSHING ROD,REPLACEMENT OF HT BUSHING ROD
1409	03-09-2025	Part of : MADIPUR PUNJABI BAGH,	1458	Other Outage	Planned Outage	03-09-2025	11:02	03-09-2025	14:29	3:27	0.001438	TRANSFORMER MAINTENANCE
1410	03-09-2025	Part of : BLOCK A 4 PASCHIM VIHAR,	658	Other Outage	Planned Outage	03-09-2025	10:33	03-09-2025	13:28	2:55	0.000000	TRANSFORMER MAINTENANCE
1411	04-09-2025	Part of : BLOCK A 2 & A2B PASCHIM VIHAR	1585	Other Outage	Unplanned Outage	04-09-2025	03:05	04-09-2025	04:00	0:55	0.000688	CABLE FAULT
1412	04-09-2025	Part of : BLOCK C SURYA ENCLAVE SHAKURBASTI	367	Other Outage	Planned Outage	04-09-2025	11:17	04-09-2025	14:02	2:45	0.000000	MAINTENANCE OF TRANSFORMER
1413	04-09-2025	Part of : PUNJABI BAGH COOPERATIVE HOUSING SOCIETY PUNJABI BAGH EAST	331	Other Outage	Planned Outage	04-09-2025	10:23	04-09-2025	14:34	4:11	0.000000	MAINTENANCE OF TRANSFORMER
1414	07-09-2025	Part of : BLOCK B STATE BANK COLONY PASCHIM VIHAR,STATE BANK COLONY PASCHIM VIHAR	1906	Other Outage	Unplanned Outage	07-09-2025	20:08	07-09-2025	20:58	0:50	0.000417	HT SYSTEM FAULT
1415	08-09-2025	Part of : KARAMPURA INDUSTRIAL AREA,BLOCK C KARAMPURA MARKET	1639	Other Outage	Unplanned Outage	08-09-2025	14:05	08-09-2025	14:57	0:52	0.000592	HT SYSTEM FAULT
1416	08-09-2025	Part of : BLOCK GH 4 STATE BANK COLONY PASCHIM VIHAR	106	Other Outage	Planned Outage	08-09-2025	13:56	08-09-2025	16:51	2:55	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1417	08-09-2025	Part of : BLOCK GH 4 STATE BANK COLONY PASCHIM VIHAR	75	Other Outage	Planned Outage	08-09-2025	11:07	08-09-2025	13:39	2:32	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1418	08-09-2025	Part of : POCKET 3 PASCHIM PURI	434	Other Outage	Planned Outage	08-09-2025	11:01	08-09-2025	13:40	2:39	0.001104	DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
1419	09-09-2025	Part of : B 1-BLOCK PASCHIM VIHAR	240	Other Outage	Planned Outage	09-09-2025	13:49	09-09-2025	16:22	2:33	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1420	09-09-2025	Part of : B1-BLOCK PASCHIM VIHAR	261	Other Outage	Planned Outage	09-09-2025	11:10	09-09-2025	13:47	2:37	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1421	10-09-2025	Part of : BLOCK A 1B KRISHNA APARTMENT PASCHIM VIHAR	304	Other Outage	Planned Outage	10-09-2025	13:19	10-09-2025	15:24	2:05	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1422	10-09-2025	Part of : WEST PUNJABI BAGH PUNJABI BAGH	245	Other Outage	Planned Outage	10-09-2025	10:59	10-09-2025	13:43	2:44	0.001367	DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMENT OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES) (DRY DT),REPLACEMENT OF SILICAGEL IN BREATHER,REPLACEMENT OF HT BUSHING ROD,REPLACEMENT OF HT/LT CLEATS,REPLACEMENT OF LUGS,SUB STATION CLEANING,TIGHTENING OF NUT BOLT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1423	10-09-2025	Part of : BLOCK A 1B KRISHNA APARTMENT PASCHIM VIHAR	99	Other Outage	Planned Outage	10-09-2025	10:23	10-09-2025	13:19	2:56	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1424	11-09-2025	Part of : A-3 BLOCK PASCHIM VIHAR	332	Other Outage	Planned Outage	11-09-2025	12:54	11-09-2025	14:26	1:32	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1425	11-09-2025	Part of : KARAMPURA INDUSTRIAL AREA KARAMPURA,	440	Other Outage	Planned Outage	11-09-2025	10:01	11-09-2025	13:18	3:17	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1426	11-09-2025	Part of : A-3 BLOCK PASCHIM VIHAR	151	Other Outage	Planned Outage	11-09-2025	10:17	11-09-2025	12:52	2:35	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1427	12-09-2025	Part of : STATE BANK COLONY PASCHIM VIHAR	304	Other Outage	Planned Outage	12-09-2025	11:11	12-09-2025	13:08	1:57	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING
1428	12-09-2025	Part of : WEST PUNJABI BAGH	576	Other Outage	Planned Outage	12-09-2025	11:04	12-09-2025	14:50	3:46	0.001569	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING
1429	15-09-2025	Part of : BLOCK G PUSHKAR ENCLAVE PASCHIM VIHAR,	467	Other Outage	Planned Outage	15-09-2025	13:01	15-09-2025	15:14	2:13	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1430	15-09-2025	Part of : BLOCK A PASCHIM PURI PASCHIM VIHAR,	523	Other Outage	Planned Outage	15-09-2025	11:05	15-09-2025	14:02	2:57	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1431	15-09-2025	Part of : BLOCK G PUSHKAR ENCLAVE PASCHIM VIHAR,	360	Other Outage	Planned Outage	15-09-2025	10:10	15-09-2025	12:53	2:43	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1432	16-09-2025	Part of : BLOCK C JAIDEV PARK PUNJABI BAGH EAST ,GOLDEN PARK TRI NAGAR,BLOCK B MADAN PARK PUNJABI BAGH EAST ,ASHOK PARK EXTENSION PUNJABI BAGH	1892	Other Outage	Unplanned Outage	16-09-2025	13:57	16-09-2025	14:49	0:52	0.000794	CABLE FAULT
1433	16-09-2025	Part of : PASCHIM VIHAR EXTENSION	4273	Other Outage	Unplanned Outage	16-09-2025	13:51	16-09-2025	14:30	0:39	0.000596	HT SYSTEM FAULT
1434	16-09-2025	Part of : AVTAR ENCLAVE PASCHIM VIHAR	164	Other Outage	Planned Outage	16-09-2025	10:13	16-09-2025	12:46	2:33	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS
1435	17-09-2025	Part of : BG 3-BLOCK PASCHIM VIHAR	173	Other Outage	Planned Outage	17-09-2025	12:04	17-09-2025	13:48	1:44	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1436	17-09-2025	Part of : BG 3-BLOCK PASCHIM VIHAR	259	Other Outage	Planned Outage	17-09-2025	10:16	17-09-2025	12:04	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1437	18-09-2025	Part of : BLOCK BG 5 PASCHIM VIHAR	402	Other Outage	Planned Outage	18-09-2025	12:08	18-09-2025	13:53	1:45	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER SUB STATION CLEANING
1438	18-09-2025	Part of : PUNJABI BAGH EXTENSION	88	Other Outage	Planned Outage	18-09-2025	11:01	18-09-2025	13:55	2:54	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER SUB STATION CLEANING
1439	18-09-2025	Part of : BLOCK C KARAMPURA	690	Other Outage	Planned Outage	18-09-2025	10:34	18-09-2025	13:54	3:20	0.001111	DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF GAS KIT AND OIL SEAL
1440	18-09-2025	Part of : BLOCK BG 5 PASCHIM VIHAR	237	Other Outage	Planned Outage	18-09-2025	10:04	18-09-2025	12:09	2:05	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1441	19-09-2025	Part of : BLOCK B 2 PASCHIM VIHAR,	302	Other Outage	Planned Outage	19-09-2025	12:49	19-09-2025	15:05	2:16	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
1442	19-09-2025	Part of : BLOCK B 2 PASCHIM VIHAR,	110	Other Outage	Planned Outage	19-09-2025	10:36	19-09-2025	12:50	2:14	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL
1443	22-09-2025	Part of : BLOCK G PUSHKAR ENCLAVE PASCHIM VIHAR, ANKUR ENCLAVE PASCHIM VIHAR, RBI ENCLAVE PASCHIM VIHAR, DELHI JAL BOARD (HTC)	1790	Other Outage	Unplanned Outage	22-09-2025	03:08	22-09-2025	04:00	0:52	0.001343	CABLE FAULT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1444	22-09-2025	Part of : NEW MULTAN NAGAR SHAKURBASTI	410	Other Outage	Planned Outage	22-09-2025	10:26	22-09-2025	13:02	2:36	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1445	22-09-2025	Part of : ARIHANT NAGAR PUNJABI BAGH	191	Other Outage	Planned Outage	22-09-2025	10:37	22-09-2025	13:03	2:26	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1446	23-09-2025	Part of : BLOCK A 2B PASCHIM VIHAR,	341	Other Outage	Planned Outage	23-09-2025	13:58	23-09-2025	14:52	0:54	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING.TIGHTENEING OF NUT BOLT
1447	23-09-2025	Part of : A-2 MIG PASCHIM VIHAR	345	Other Outage	Planned Outage	23-09-2025	11:07	23-09-2025	13:56	2:49	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING
1448	24-09-2025	Part of : BLOCK A NEW MOTI NAGAR MOTI NAGAR	456	Other Outage	Unplanned Outage	24-09-2025	11:00	24-09-2025	12:54	1:54	0.000475	MOBILE TRANSFORMER REPLACEMENT
1449	25-09-2025	Part of : BLOCK M SURYA ENCLAVE SHAKURBASTI	277	Other Outage	Planned Outage	25-09-2025	10:26	25-09-2025	12:22	1:56	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1450	26-09-2025	Part of : BLOCK A 2 PASCHIM VIHAR	605	Other Outage	Planned Outage	26-09-2025	10:39	26-09-2025	12:27	1:48	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1451	26-09-2025	Part of : BLOCK A 2 PASCHIM VIHAR	575	Other Outage	Planned Outage	26-09-2025	12:26	26-09-2025	14:27	2:01	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMENT OF GAS KIT AND OIL SEAL,SUB STATION CLEANING
1452	26-09-2025	Part of : LAL QUARTER ARIHANT NAGAR PUNJABI BAGH	449	Other Outage	Planned Outage	26-09-2025	11:24	26-09-2025	14:03	2:39	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1453	26-09-2025	Part of : BLOCK B 1 PHASE 1 NEW MOTI NAGAR MOTI NAGAR	436	Other Outage	Planned Outage	26-09-2025	10:53	26-09-2025	12:59	2:06	0.000525	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),REPLACEMENT OF HT BUSHING INULATOR,REPLACEMET OF HT/LT CLEATS,REPLACEMET OF LUGS,SUB STATION CLEANING
1454	27-09-2025	Part of : WEST PUNJABI BAGH PUNJABI BAGH,	388	Other Outage	Unplanned Outage	27-09-2025	12:56	27-09-2025	14:29	1:33	0.000517	REPLACEMENT OF RMU
1455	27-09-2025	Part of : GREEN APPARTMENT PASCHIM VIHAR	220	Other Outage	Planned Outage	27-09-2025	11:05	27-09-2025	12:49	1:44	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF SILICAGEL IN BREATHER,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1456	28-09-2025	Part of : BLOCK C, D & M SURYA ENCLAVE SHAKURBASTI,NEW MULTAN NAGAR SHAKURBASTI	2081	Other Outage	Unplanned Outage	28-09-2025	15:53	28-09-2025	16:36	0:43	0.000191	CABLE FAULT
1457	29-09-2025	Part of : BLOCK B 3 PASCHIM VIHAR	331	Other Outage	Planned Outage	29-09-2025	12:58	29-09-2025	14:47	1:49	0.000000	APPLY OF INSULATION TAPE HT BUSHINGS,CHECKING ,OIL TOP UP IN TRANSFORMER
1458	29-09-2025	Part of : BLOCK B 3 PASCHIM VIHAR	363	Other Outage	Planned Outage	29-09-2025	11:06	29-09-2025	12:58	1:52	0.000000	APPLY OF INSULATION TAPE HT BUSHINGS
1459	29-09-2025	Part of : BLOCK C SHIVAJI PARK PUNJABI BAGH	30	Other Outage	Planned Outage	29-09-2025	11:13	29-09-2025	12:59	1:46	0.000000	APPLY OF INSULATION TAPE HT BUSHINGS
1460	30-09-2025	Part of : PASCHIM VIHAR EXTENSION, RAILWAY COLONY NORTH SHAKURBASTI, MADHUBAN ENCLAVE PUNJABI BAGH	2493	Other Outage	Unplanned Outage	30-09-2025	21:41	30-09-2025	22:27	0:46	0.000831	FAULT IN HT CONSUMER PANEL (C.O.D)
1461	30-09-2025	Part of : NEAR A-2 POLICE STATION PASCHIM VIHAR	349	Other Outage	Planned Outage	30-09-2025	11:11	30-09-2025	12:56	1:45	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,REPLACEMET OF HT BUSHING ROD
1462	01-09-2025	Part of : F & G BLOCK RAJ NAGAR,TOGAN PUR SECTOR - 9 DWARKA	5131	Other Outage	Unplanned Outage	01-09-2025	16:50	01-09-2025	17:32	0:42	0.000525	TREE TOUCHING
1463	02-09-2025	Part of : DURGA PARK COLONY, POCKET 10 SECTOR I DASRATHPURI, BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR, DURGA PURI SAGARPUR WEST	1545	Other Outage	Unplanned Outage	02-09-2025	23:53	03-09-2025	00:18	0:25	0.000299	HT SYSTEM FAULT
1464	02-09-2025	Part of : BLOCK G RAJ NAGAR 2,SECTOR 9 DWARKA	1794	Other Outage	Unplanned Outage	02-09-2025	10:48	02-09-2025	10:50	0:02	0.000000	MAKING OF END TERMINATION
1465	03-09-2025	Part of : VAISHALI COLONY DASRATHPURI,BLOCK RZ SAINIPURA RAJ NAGAR 1 RAJ NAGAR,MIRZAPUR MAHAVIR ENCLAVE,BALMIKI VIHAR SADH NAGAR II PALAM	367	Other Outage	Unplanned Outage	03-09-2025	16:08	03-09-2025	16:44	0:36	0.000090	TREE TOUCHING
1466	03-09-2025	Part of : SECTOR 9 DWARKA,POCKET 1 SECTOR 9 DWARKA	932	Other Outage	Unplanned Outage	03-09-2025	15:20	03-09-2025	15:55	0:35	0.000438	TREE TOUCHING
1467	03-09-2025	Part of : SEC 1PKT 2 S/STN 1, PETROL PUMP SEC 1, SEC 1PKT 1 S/STN 1, SEC 1PKT 1 S/STN 2, HTC:MAHARAJA AGARSEN HOSPITAL,SEC-1, H-2, BLK BENGALI COLONY	1474	Other Outage	Unplanned Outage	03-09-2025	14:53	03-09-2025	15:33	0:40	0.000000	TREE TOUCHING
1468	03-09-2025	Part of : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE,	73	Other Outage	Planned Outage	03-09-2025	11:47	03-09-2025	16:58	5:11	0.001728	TRANSFORMER REPLACEMENT
1469	03-09-2025	Part of : BLOCK F RAJ NAGAR EXTENSION RAJ NAGAR,	1281	Other Outage	Planned Outage	03-09-2025	11:47	03-09-2025	15:20	3:33	0.001183	NEW LT CIRCUIT LAYING
1470	03-09-2025	Part of : BLOCK T GANDHI MARKET SAGARPUR,	1686	Other Outage	Planned Outage	03-09-2025	11:46	03-09-2025	16:59	5:13	0.001739	RMU REPLACEMENT
1471	03-09-2025	Part of : PALAM VILLAGE PALAM,	596	Other Outage	Planned Outage	03-09-2025	11:43	03-09-2025	16:58	5:15	0.001750	NEW LT CIRCUIT LAYING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1472	04-09-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1	1483	Other Outage	Planned Outage	04-09-2025	12:02	04-09-2025	16:23	4:21	0.001450	O/H LT AB CABLE MAINTENANCE
1473	05-09-2025	Part of : HARIJAN BASTI PALAM EXTENSION	822	Other Outage	Unplanned Outage	05-09-2025	00:47	05-09-2025	01:03	0:16	0.000040	CABLE FAULT
1474	06-09-2025	Part of : BLOCK R INDRA PARK PALAM KAILASHPURI MAIN	684	Other Outage	Planned Outage	06-09-2025	12:59	06-09-2025	15:38	2:39	0.000883	LT ACB REPLACEMENT
1475	06-09-2025	Part of : BLOCK B CHANDAR VIHAR PALAM EXTENSION	609	Other Outage	Planned Outage	06-09-2025	12:13	06-09-2025	17:08	4:55	0.001639	LT AB SAGGING PER SPAN
1476	06-09-2025	Part of : NAVEEN KUNJ SOCIETY NARSIRPUR	51	Other Outage	Planned Outage	06-09-2025	10:36	06-09-2025	17:07	6:31	0.002172	LT AB SAGGING PER SPAN
1477	06-09-2025	Part of : SECTOR 21 DWARKA	168	Other Outage	Planned Outage	06-09-2025	10:25	06-09-2025	15:05	4:40	0.000000	LT AB SAGGING PER SPAN
1478	08-09-2025	Part of : MAHAVIR ENCLAVE PART 2,PALAM COLONY MAHAVIR ENCLAVE PART 2	2119	Other Outage	Planned Outage	08-09-2025	10:41	08-09-2025	12:42	2:01	0.000672	ST.TH JOINT ON 1PH HT AB
1479	08-09-2025	Part of : BLOCK A SITAPURI PART	100	Other Outage	Planned Outage	08-09-2025	10:43	08-09-2025	15:49	5:06	0.001700	BIRD SPIKES INSTALLATION PER POLE,HT SLEEVE INSTALLATION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES
1480	08-09-2025	Part of : SECTOR 23 DWARKA	1	Other Outage	Planned Outage	08-09-2025	13:28	08-09-2025	16:34	3:06	0.001033	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1481	08-09-2025	Part of : BLOCK C MAHAVIR ENCLAVE PART 1	1488	Other Outage	Planned Outage	08-09-2025	12:27	08-09-2025	15:51	3:24	0.001133	APPLY OF INSULATION TAPE HT/LT BUSHINGS
1482	08-09-2025	Part of : POCKET 13 MANGALPURI II PALAM	451	Other Outage	Planned Outage	08-09-2025	10:15	08-09-2025	13:53	3:38	0.001211	LT AB SAGGING PER SPAN
1483	08-09-2025	Part of : BLOCK J PALAM	972	Other Outage	Planned Outage	08-09-2025	10:18	08-09-2025	17:01	6:43	0.002239	LT AB SAGGING PER SPAN
1484	09-09-2025	Part of : RZ-BLOCK GEETANJALI PARK SAGARPUR WEST	3841	Other Outage	Unplanned Outage	09-09-2025	14:18	09-09-2025	14:55	0:37	0.000596	CABLE FAULT BY OUTSIDE AGENCY (IGL)
1485	09-09-2025	Part of : R-BLOCK INDRA PARK PALEM KAILASHPURI MAIN	685	Other Outage	Planned Outage	09-09-2025	14:44	09-09-2025	16:45	2:01	0.000672	LT AB SAGGING
1486	09-09-2025	Part of : J-BLOCK SAGARPUR WEST SAGARPUR	821	Other Outage	Planned Outage	09-09-2025	13:05	09-09-2025	16:35	3:30	0.001167	LT AB SAGGING
1487	09-09-2025	Part of : C-BLOCK VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE	645	Other Outage	Planned Outage	09-09-2025	12:13	09-09-2025	14:15	2:02	0.000678	LT AB SAGGING
1488	09-09-2025	Part of : B-BLOCK RAJ NAGAR 2	1450	Other Outage	Planned Outage	09-09-2025	11:46	09-09-2025	16:36	4:50	0.001611	LT AB SAGGING
1489	09-09-2025	Part of : C-BLOCK PALAM EXTENSION	828	Other Outage	Planned Outage	09-09-2025	11:53	09-09-2025	14:22	2:29	0.000828	LT AB SAGGING
1490	09-09-2025	Part of : SANT MOHALLA SAGARPUR MAIN	1246	Other Outage	Planned Outage	09-09-2025	11:56	09-09-2025	16:57	5:01	0.001672	LT AB SAGGING
1491	09-09-2025	Part of : I-BLOCK MAHAVIR ENCLAVE PART 1	410	Other Outage	Planned Outage	09-09-2025	10:49	09-09-2025	16:43	5:54	0.001967	LT AB SAGGING
1492	09-09-2025	Part of : A 1-BLOCK VIJAY ENCLAVE MAHAVIR ENCLAVE	807	Other Outage	Planned Outage	09-09-2025	11:14	09-09-2025	14:09	2:55	0.000972	LT CIRCUIT REPLACEMENT
1493	09-09-2025	Part of : SECTOR 23 DWARKA	4	Other Outage	Planned Outage	09-09-2025	11:44	09-09-2025	15:54	4:10	0.001389	LT CIRCUIT REPLACEMENT
1494	10-09-2025	Part of : RAJ NAGAR, SECTOR 20 DWARKA, DDA SEC-9 DWARKA	2	Other Outage	Unplanned Outage	10-09-2025	08:02	10-09-2025	08:58	0:56	0.000031	HT SYSTEM FAULT
1495	10-09-2025	Part of : SECTOR 23 DWARKA	3	Other Outage	Planned Outage	10-09-2025	15:32	10-09-2025	17:11	1:39	0.000000	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1496	10-09-2025	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN	1300	Other Outage	Planned Outage	10-09-2025	14:29	10-09-2025	16:08	1:39	0.000550	LT AB SAGGING PER SPAN
1497	10-09-2025	Part of : BLOCK G RAJ NAGAR 2	1793	Other Outage	Planned Outage	10-09-2025	12:10	10-09-2025	15:06	2:56	0.000978	DT REPLACEMENT
1498	10-09-2025	Part of : BLOCK T GANDHI MARKET SAGARPUR	1686	Other Outage	Planned Outage	10-09-2025	10:48	10-09-2025	15:52	5:04	0.000844	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1499	10-09-2025	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN	1176	Other Outage	Planned Outage	10-09-2025	11:08	10-09-2025	14:31	3:23	0.001128	LT AB SAGGING PER SPAN
1500	10-09-2025	Part of : PALAM COLONY SADH NAGAR 1	1385	Other Outage	Planned Outage	10-09-2025	11:09	10-09-2025	15:44	4:35	0.001528	LT AB SAGGING PER SPAN
1501	10-09-2025	Part of : BLOCK F MAHAVIR ENCLAVE PART 1	1892	Other Outage	Planned Outage	10-09-2025	10:56	10-09-2025	15:30	4:34	0.001522	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS,SUB STATION CLEANING
1502	11-09-2025	Part of : BLOCK G RAJ NAGAR 2 RAJ NAGAR,SECTOR 9 DWARKA	1793	Other Outage	Unplanned Outage	11-09-2025	01:08	11-09-2025	02:04	0:56	0.001229	HT SYSTEM FAULT
1503	11-09-2025	Part of : SECTOR 23 DWARKA,	118	Other Outage	Planned Outage	11-09-2025	14:57	11-09-2025	16:13	1:16	0.000422	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1504	11-09-2025	Part of : BLOCK J RAJ NAGAR 2 RAJ NAGAR,	1403	Other Outage	Planned Outage	11-09-2025	12:06	11-09-2025	14:57	2:51	0.000950	LT AB SAGGING PER SPAN
1505	11-09-2025	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,	962	Other Outage	Planned Outage	11-09-2025	11:42	11-09-2025	16:32	4:50	0.001611	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1506	11-09-2025	Part of : VAISHALI EXTENSION DASRATHPURI,	604	Other Outage	Planned Outage	11-09-2025	11:45	11-09-2025	16:19	4:34	0.001522	LT AB SAGGING PER SPAN

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1507	11-09-2025	Part of : SECTOR 23 DWARKA,	25	Other Outage	Planned Outage	11-09-2025	10:49	11-09-2025	14:59	4:10	0.001389	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1508	11-09-2025	Part of : BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR,	701	Other Outage	Planned Outage	11-09-2025	11:14	11-09-2025	14:27	3:13	0.001072	LT AB SAGGING PER SPAN
1509	11-09-2025	Part of : BLOCK H SITAPURI PART 2 SITAPURI,	1361	Other Outage	Planned Outage	11-09-2025	11:27	11-09-2025	16:57	5:30	0.001833	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1510	12-09-2025	Part of : BLOCK J RAJ NAGAR 2	4675	Other Outage	Unplanned Outage	12-09-2025	22:17	12-09-2025	22:55	0:38	0.002428	HT SYSTEM FAULT
1511	12-09-2025	Part of : SECTOR 23 DWARKA	29	Other Outage	Planned Outage	12-09-2025	11:42	12-09-2025	13:08	1:26	0.000478	REPLACEMET OF FAULTY END BOX
1512	12-09-2025	Part of : BLOCK C PALAM EXTENSION	828	Other Outage	Planned Outage	12-09-2025	11:26	12-09-2025	14:56	3:30	0.001167	LT AB SAGGING PER SPAN
1513	12-09-2025	Part of : BLOCK G 1 MAHAVIR ENCLAVE PART 1	1748	Other Outage	Planned Outage	12-09-2025	11:29	12-09-2025	15:17	3:48	0.001267	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT)
1514	12-09-2025	Part of : POCKET 13 MANGALPURI II PALAM	451	Other Outage	Planned Outage	12-09-2025	11:24	12-09-2025	15:33	4:09	0.001383	LT AB SAGGING PER SPAN
1515	12-09-2025	Part of : BLOCK J SAGARPUR WEST	824	Other Outage	Planned Outage	12-09-2025	11:26	12-09-2025	16:13	4:47	0.001594	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER
1516	12-09-2025	Part of : BLOCK J PALAM	972	Other Outage	Planned Outage	12-09-2025	09:55	12-09-2025	16:06	6:11	0.002061	LT AB SAGGING PER SPAN
1517	13-09-2025	Part of : SECTOR 23 DWARKA	52	Other Outage	Planned Outage	13-09-2025	15:02	13-09-2025	17:02	2:00	0.000667	APPLY OF INSULATION TAPE LT BUSHINGS
1518	13-09-2025	Part of : BLOCK I MAHAVIR ENCLAVE PART 1	410	Other Outage	Planned Outage	13-09-2025	10:42	13-09-2025	14:13	3:31	0.001172	LT AB SAGGING
1519	13-09-2025	Part of : SECTOR 23 DWARKA	64	Other Outage	Planned Outage	13-09-2025	10:45	13-09-2025	16:07	5:22	0.001789	APPLY OF INSULATION TAPE LT BUSHING
1520	13-09-2025	Part of : BLOCK B 3 MAHAVIR ENCLAVE PART 1	1295	Other Outage	Planned Outage	13-09-2025	11:19	13-09-2025	14:26	3:07	0.001039	APPLY OF INSULATION TAPE LT BUSHINGS
1521	13-09-2025	Part of : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE	479	Other Outage	Planned Outage	13-09-2025	10:53	13-09-2025	15:09	4:16	0.001422	LT AB SAGGING
1522	14-09-2025	Part of : BLOCK B 3 MAHAVIR ENCLAVE PART 1	1298	Other Outage	Unplanned Outage	14-09-2025	11:20	14-09-2025	12:36	1:16	0.000000	REPAIR OF RMU
1523	15-09-2025	Part of : SECTOR 23 DWARKA,	219	Other Outage	Planned Outage	15-09-2025	14:24	15-09-2025	16:50	2:26	0.000811	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1524	15-09-2025	Part of : MANGALPURI I PALAM,	1076	Other Outage	Planned Outage	15-09-2025	13:13	15-09-2025	16:59	3:46	0.001256	LT AB SAGGING PER SPAN
1525	15-09-2025	Part of : BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR,	325	Other Outage	Planned Outage	15-09-2025	11:27	15-09-2025	15:05	3:38	0.001211	CONDUCTOR REPLACEMET PER SPAN
1526	15-09-2025	Part of : BLOCK A POCKET 9 PINK APARTMENTS NARSIRPUR,	641	Other Outage	Planned Outage	15-09-2025	11:15	15-09-2025	16:03	4:48	0.001600	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1527	15-09-2025	Part of : POCHANPUR DWARKA,	1	Other Outage	Planned Outage	15-09-2025	11:03	15-09-2025	13:28	2:25	0.000806	REPLACEMET OF FAULTY END BOX
1528	15-09-2025	Part of : BLOCK A 1 VIJAY ENCLAVE MAHAVIR ENCLAVE,	807	Other Outage	Planned Outage	15-09-2025	10:29	15-09-2025	15:23	4:54	0.001633	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1529	15-09-2025	Part of : BLOCK C PALAM EXTENSION PALAM,	828	Other Outage	Planned Outage	15-09-2025	10:16	15-09-2025	14:55	4:39	0.001550	LT AB SAGGING PER SPAN
1530	15-09-2025	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN SAGARPUR,	1176	Other Outage	Planned Outage	15-09-2025	10:13	15-09-2025	16:02	5:49	0.001939	LT AB SAGGING PER SPAN
1531	16-09-2025	Part of : SECTOR 23 DWARKA	63	Other Outage	Planned Outage	16-09-2025	11:30	16-09-2025	13:00	1:30	0.000500	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
1532	16-09-2025	Part of : MAHAVIR ENCLAVE PART 2	183	Other Outage	Planned Outage	16-09-2025	11:02	16-09-2025	14:33	3:31	0.001172	GUARD WIRES SAGGING PER SPAN
1533	16-09-2025	Part of : SECTOR 23 DWARKA	186	Other Outage	Planned Outage	16-09-2025	14:03	16-09-2025	16:50	2:47	0.000928	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1534	16-09-2025	Part of : DABRI EXTENSION EAST DABRI	1047	Other Outage	Planned Outage	16-09-2025	11:26	16-09-2025	16:07	4:41	0.001561	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
1535	16-09-2025	Part of : MIRZAPUR MAHAVIR ENCLAVE	1278	Other Outage	Planned Outage	16-09-2025	11:08	16-09-2025	15:06	3:58	0.001322	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
1536	16-09-2025	Part of : POCKET 13 MANGALPURI II PALAM	451	Other Outage	Planned Outage	16-09-2025	11:03	16-09-2025	13:18	2:15	0.000750	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS
1537	17-09-2025	Part of : RZ-BLOCK KAMAL PARK KAILASHPURI MAIN,POCKET B KAILASHPURI	1787	Other Outage	Planned Outage	17-09-2025	10:42	17-09-2025	13:22	2:40	0.000889	DB REVAMPING,HT BUSHING REPLACEMENT
1538	17-09-2025	Part of : SECTOR 23 DWARKA	21	Other Outage	Planned Outage	17-09-2025	14:37	17-09-2025	16:58	2:21	0.000783	APPLY OF INSULATION TAPE LT BUSHINGS
1539	17-09-2025	Part of : H-BLOCK RAGHU NAGAR DABRI	1272	Other Outage	Planned Outage	17-09-2025	10:47	17-09-2025	15:50	5:03	0.001683	APPLY OF INSULATION TAPE LT BUSHINGS
1540	17-09-2025	Part of : J-BLOCK RAJ NAGAR 2	1635	Other Outage	Planned Outage	17-09-2025	11:26	17-09-2025	16:59	5:33	0.001850	LT AB SAGGING
1541	17-09-2025	Part of : SECTOR 23 DWARKA	49	Other Outage	Planned Outage	17-09-2025	11:01	17-09-2025	13:42	2:41	0.000894	APPLY OF INSULATION TAPE LT BUSHINGS
1542	17-09-2025	Part of : C-BLOCK MAHAVIR ENCLAVE PART 1	1050	Other Outage	Planned Outage	17-09-2025	11:11	17-09-2025	15:09	3:58	0.001322	APPLY OF INSULATION TAPE LT BUSHINGS
1543	18-09-2025	Part of : MADAN PURI HANS PARK, BLOCK RZ GEETANJALI PARK SAGARPUR WEST	1699	Other Outage	Unplanned Outage	18-09-2025	17:17	18-09-2025	18:01	0:44	0.000684	CABLE FAULT
1544	18-09-2025	Part of : BLOCK G VIJAY ENCLAVE MAHAVIR ENCLAVE	1020	Other Outage	Planned Outage	18-09-2025	11:05	18-09-2025	16:32	5:27	0.001817	APPLY OF INSULATION TAPE HT/LT BUSHINGS,CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,INSTALLATION OF BUS BAR,MEASUREMET OF INSULATION RESISTANCE(INCLUDING DISCONNECTION OF HT/LT CABLES),OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1545	18-09-2025	Part of : SECTOR 23 DWARKA	83	Other Outage	Planned Outage	18-09-2025	11:02	18-09-2025	15:41	4:39	0.001550	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1546	18-09-2025	Part of : BLOCK A SADH NAGAR II PALAM	520	Other Outage	Planned Outage	18-09-2025	10:36	18-09-2025	15:36	5:00	0.001667	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1547	19-09-2025	Part of : BLOCK B SADH NAGAR II PALAM	1435	Other Outage	Unplanned Outage	19-09-2025	12:32	19-09-2025	13:15	0:43	0.000358	CABLE DAMAGE BY OUTSIDE AGENCY (DJB)
1548	19-09-2025	Part of : BLOCK A MAHAVIR ENCLAVE,	4	Other Outage	Planned Outage	19-09-2025	11:37	19-09-2025	13:28	1:51	0.000617	BIRD SPIKES INSTALLATION PER POLE,HT SLEEVE INSTALLATION PER SPAN,REGULAR TRIMMING AND REMOVAL OF TREES OR BRANCHES NEAR OVERHEAD LINES TO AVOID ELECTRICAL HAZARDS PER SPAN
1549	19-09-2025	Part of : MAHAVIR ENCLAVE PART 2 MAHAVIR ENCLAVE,	1064	Other Outage	Planned Outage	19-09-2025	10:48	19-09-2025	12:38	1:50	0.000611	DB REVAMPING
1550	19-09-2025	Part of : BLOCK B DABRI EXTENSION EAST DABRI,	1249	Other Outage	Planned Outage	19-09-2025	10:49	19-09-2025	15:13	4:24	0.001467	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1551	19-09-2025	Part of : SECTOR 23 DWARKA,	43	Other Outage	Planned Outage	19-09-2025	10:54	19-09-2025	16:13	5:19	0.001772	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1552	19-09-2025	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN SAGARPUR,	982	Other Outage	Planned Outage	19-09-2025	11:01	19-09-2025	16:38	5:37	0.001872	LT AB SAGGING PER SPAN
1553	20-09-2025	Part of : Sector 23 Dwarka,	89	Other Outage	Planned Outage	20-09-2025	15:30	20-09-2025	17:02	1:32	0.000511	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1554	20-09-2025	Part of : Block H Palam Extension Palam,	542	Other Outage	Planned Outage	20-09-2025	11:07	20-09-2025	15:34	4:27	0.001483	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unserved (MU) due to outage	Remarks
						Date	Time	Date	Time			
1555	20-09-2025	Part of : Block J Raj Nagar 2 Raj Nagar,	594	Other Outage	Planned Outage	20-09-2025	11:00	20-09-2025	17:01	6:01	0.002006	LT AB SAGGING PER SPAN
1556	20-09-2025	Part of : Sector 23 Dwarka,	59	Other Outage	Planned Outage	20-09-2025	11:01	20-09-2025	14:15	3:14	0.001078	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1557	22-09-2025	Part of : PALAM VILLAGE	465	Other Outage	Planned Outage	22-09-2025	12:45	22-09-2025	13:15	0:30	0.000167	LT AB SAGGING PER SPAN
1558	22-09-2025	Part of : BLOCK C VINODPURI VIJAY ENCLAVE MAHAVIR ENCLAVE	646	Other Outage	Planned Outage	22-09-2025	13:13	22-09-2025	16:21	3:08	0.001044	LT AB SAGGING PER SPAN
1559	22-09-2025	Part of : BLOCK B RAJ NAGAR 2	1461	Other Outage	Planned Outage	22-09-2025	12:24	22-09-2025	16:06	3:42	0.001233	LT AB SAGGING PER SPAN
1560	22-09-2025	Part of : BLOCK F MAHAVIR ENCLAVE PART 1	1895	Other Outage	Planned Outage	22-09-2025	11:18	22-09-2025	16:37	5:19	0.001772	LT AB SAGGING PER SPAN
1561	22-09-2025	Part of : BLOCK RZ PALAM	504	Other Outage	Planned Outage	22-09-2025	11:45	22-09-2025	15:27	3:42	0.001233	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1562	22-09-2025	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN	982	Other Outage	Planned Outage	22-09-2025	11:19	22-09-2025	14:18	2:59	0.000994	LT AB SAGGING PER SPAN
1563	22-09-2025	Part of : POCKET 1 SECTOR 23 DWARKA	187	Other Outage	Planned Outage	22-09-2025	11:30	22-09-2025	16:19	4:49	0.001606	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1564	22-09-2025	Part of : BLOCK B PATEL BLOCK RAGHU NAGAR DABRI	1017	Other Outage	Planned Outage	22-09-2025	11:12	22-09-2025	15:28	4:16	0.001422	APPLY OF INSULATION TAPE HT/LT BUSHINGS,DT OIL SAMPLING TO CHECK BDV VALUE,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1565	22-09-2025	Part of : PALAM VILLAGE	594	Other Outage	Planned Outage	22-09-2025	11:18	22-09-2025	16:06	4:48	0.001600	LT AB SAGGING PER SPAN
1566	23-09-2025	Part of : BLOCK M RAJIV PARK SAGARPUR,BLOCK RZ GEETANJALI PARK SAGARPUR WEST SAGARPUR	5641	Other Outage	Unplanned Outage	23-09-2025	00:16	23-09-2025	00:48	0:32	0.001804	CABLE FAULT
1567	23-09-2025	Part of : BLOCK B DASRATHPURI,DABRI VILLAGE DABRI,BLOCK A MAHAVIR ENCLAVE,VAISHALI EXTENSION DASRATHPURI,	2097	Other Outage	Planned Outage	23-09-2025	16:19	23-09-2025	17:21	1:02	0.000344	DB REVAMPING,DT REPLACEMET PER DT
1568	23-09-2025	Part of : PALAM VIHAR SADH NAGAR 1 PALAM,	725	Other Outage	Planned Outage	23-09-2025	11:37	23-09-2025	15:52	4:15	0.001417	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1569	23-09-2025	Part of : POCKET 1 SECTOR 23 DWARKA,	82	Other Outage	Planned Outage	23-09-2025	10:49	23-09-2025	15:42	4:53	0.001628	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1570	23-09-2025	Part of : JAGDAMBA VIHAR SAGARPUR WEST SAGARPUR,	1421	Other Outage	Planned Outage	23-09-2025	10:47	23-09-2025	14:46	3:59	0.001328	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1571	24-09-2025	Part of : BLOCK G RAJ NAGAR 2 RAJ NAGAR	932	Other Outage	Planned Outage	24-09-2025	11:52	24-09-2025	16:45	4:53	0.001628	LT AB SAGGING PER SPAN
1572	24-09-2025	Part of : SECTOR 22 DWARKA	65	Other Outage	Planned Outage	24-09-2025	10:55	24-09-2025	16:43	5:48	0.001933	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1573	25-09-2025	Part of : BLOCK G&J SAGARPUR WEST	647	Other Outage	Planned Outage	25-09-2025	11:06	25-09-2025	15:14	4:08	0.001378	HT BUSHING ROD REPLACEMENT
1574	25-09-2025	Part of : KHERA VILLAGE SADH NAGAR 1 PALAM	358	Other Outage	Planned Outage	25-09-2025	12:27	25-09-2025	16:29	4:02	0.001344	APPLY OF INSULATION TAPE LT BUSHINGS
1575	25-09-2025	Part of : SECTOR 22 DWARKA	41	Other Outage	Planned Outage	25-09-2025	11:30	25-09-2025	16:30	5:00	0.001667	APPLY OF INSULATION TAPE LT BUSHINGS
1576	25-09-2025	Part of : BLOCK J RAJ NAGAR 2 RAJ NAGAR	1638	Other Outage	Planned Outage	25-09-2025	10:58	25-09-2025	13:34	2:36	0.000867	LT AB SAGGING
1577	25-09-2025	Part of : BLOCK J PALAM	1434	Other Outage	Planned Outage	25-09-2025	10:55	25-09-2025	15:34	4:39	0.001550	LT CIRCUIT MAINTENANCE
1578	26-09-2025	Part of : JAGDAMBA VIHAR SAGARPUR WEST SAGARPUR	1253	Other Outage	Planned Outage	26-09-2025	10:46	26-09-2025	12:06	1:20	0.000444	LT AB SAGGING PER SPAN
1579	26-09-2025	Part of : MAHAVIR ENCLAVE PART 2	1362	Other Outage	Planned Outage	26-09-2025	12:01	26-09-2025	16:49	4:48	0.001600	LT AB SAGGING PER SPAN
1580	26-09-2025	Part of : SECTOR 22 DWARKA	36	Other Outage	Planned Outage	26-09-2025	11:05	26-09-2025	16:45	5:40	0.001889	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEAINING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1581	26-09-2025	Part of : PALAM EXTENSION	80	Other Outage	Planned Outage	26-09-2025	11:18	26-09-2025	15:23	4:05	0.001361	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1582	26-09-2025	Part of : BLOCK A SITAPURI PART 1	525	Other Outage	Planned Outage	26-09-2025	11:33	26-09-2025	14:55	3:22	0.001122	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1583	26-09-2025	Part of : BLOCK RZB SABZI MANDI SAGARPUR MAIN	355	Other Outage	Planned Outage	26-09-2025	10:45	26-09-2025	15:03	4:18	0.001433	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1584	26-09-2025	Part of : BLOCK A 1 VIJAY ENCLAVE MAHAVIR	810	Other Outage	Planned Outage	26-09-2025	10:28	26-09-2025	15:45	5:17	0.001761	REPLACEMENT OF LT BUSHING ROD
1585	27-09-2025	Part of : BLOCK RZ GEETANJALI PARK SAGARPUR WEST SAGARPUR	1699	Other Outage	Unplanned Outage	27-09-2025	15:50	27-09-2025	16:28	0:38	0.000728	CABLE FAULT
1586	27-09-2025	Part of : NANDA BLOCK MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	280	Other Outage	Planned Outage	27-09-2025	10:52	27-09-2025	14:50	3:58	0.001322	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1587	27-09-2025	Part of : BLOCK B 3 MAHAVIR ENCLAVE PART 1 MAHAVIR ENCLAVE,	2449	Other Outage	Planned Outage	27-09-2025	11:33	27-09-2025	17:07	5:34	0.001856	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1588	27-09-2025	Part of : SECTOR 22 DWARKA,	511	Other Outage	Planned Outage	27-09-2025	11:30	27-09-2025	16:44	5:14	0.001744	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1589	27-09-2025	Part of : BLOCK J SAGARPUR WEST SAGARPUR,	827	Other Outage	Planned Outage	27-09-2025	11:09	27-09-2025	16:22	5:13	0.001739	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS,OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,SUB STATION CLEANING
1590	29-09-2025	Part of : SECTOR 8 DWARKA,F & P-BLOCK RAJ NAGAR EXTENSION	4952	Other Outage	Unplanned Outage	29-09-2025	04:23	29-09-2025	05:09	0:46	0.001891	HT SYSTEM FAULT
1591	29-09-2025	Part of : MAHAVIR ENCLAVE PART 2, PALAM COLONY MAHAVIR ENCLAVE PART 2	1832	Other Outage	Planned Outage	29-09-2025	10:48	29-09-2025	13:20	2:32	0.000844	LT BUSHING REPLACEMENT
1592	29-09-2025	Part of : BLOCK B CHANDAR VIHAR PALAM EXTENSION PALAM	608	Other Outage	Planned Outage	29-09-2025	10:53	29-09-2025	12:57	2:04	0.000689	LT CIRCUIT MAINTENANCE
1593	29-09-2025	Part of : SECTOR 22 DWARKA	79	Other Outage	Planned Outage	29-09-2025	11:23	29-09-2025	14:10	2:47	0.000928	LT CIRCUIT MAINTENANCE
1594	30-09-2025	Part of : MAHAVIR ENCLAVE PART 2	1354	Other Outage	Planned Outage	30-09-2025	14:51	30-09-2025	16:29	1:38	0.000544	LT AB SAGGING PER SPAN
1595	30-09-2025	Part of : SECTOR 22 DWARKA	9	Other Outage	Planned Outage	30-09-2025	13:43	30-09-2025	14:43	1:00	0.000167	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1596	30-09-2025	Part of : PALAM COLONY SADH NAGAR 1 PALAM	1384	Other Outage	Planned Outage	30-09-2025	12:13	30-09-2025	14:01	1:48	0.000600	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1597	30-09-2025	Part of : BLOCK A SITAPURI PART 1	967	Other Outage	Planned Outage	30-09-2025	11:24	30-09-2025	14:18	2:54	0.000967	APPLY OF INSULATION TAPE HT/LT BUSHINGS,GENERAL SURFACE CLEANING OF HT/LT BUSHINGS (DRY DT),SUB STATION CLEANING
1598	01-09-2025	Part of : WZ-BLOCK MUKERJI PARK CHAUKHANDI VISHNU GARDEN	1509	Other Outage	Unplanned Outage	01-09-2025	21:32	01-09-2025	22:20	0:48	0.000560	HT SYSTEM FAULT
1599	03-09-2025	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION,	1339	Other Outage	Planned Outage	03-09-2025	10:39	03-09-2025	15:04	4:25	0.000736	TRANSFORMER MAINTENANCE
1600	04-09-2025	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	1296	Other Outage	Planned Outage	04-09-2025	10:43	04-09-2025	12:55	2:12	0.000550	MAINTENANCE OF TRANFORMER
1601	06-09-2025	Part of : BLOCK B GANESH NAGAR TILAK NAGAR	1099	Other Outage	Planned Outage	06-09-2025	10:40	06-09-2025	12:38	1:58	0.000328	REPLACEMET OF HT BUSHING ROD,REPLACEMET OF LUGS,SUB STATION CLEANING
1602	06-09-2025	Part of : MUKHERJI PARK CHAUKHANDI VISHNU GARDEN	1266	Other Outage	Planned Outage	06-09-2025	13:47	06-09-2025	16:00	2:13	0.000369	REPLACEMENT OF HT BUSHING ROD,SUB STATION CLEANING
1603	08-09-2025	Part of : BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION	424	Other Outage	Planned Outage	08-09-2025	13:06	08-09-2025	14:03	0:57	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1604	09-09-2025	Part of : M-BLOCK SHAM NAGAR VISHNU GARDEN	1707	Other Outage	Unplanned Outage	09-09-2025	12:49	09-09-2025	14:28	1:39	0.000275	REPAIRING OF RMU
1605	09-09-2025	Part of : S4-BLOCK MAHAVIR NAGAR NEW TILAK NAGAR	974	Other Outage	Planned Outage	09-09-2025	11:45	09-09-2025	14:39	2:54	0.000725	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1606	10-09-2025	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN	1266	Other Outage	Planned Outage	10-09-2025	11:39	10-09-2025	15:20	3:41	0.000921	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1607	10-09-2025	Part of : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION	735	Other Outage	Planned Outage	10-09-2025	10:55	10-09-2025	13:51	2:56	0.000489	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1608	11-09-2025	Part of : BLOCK EC VISHAL ENCLAVE TAGORE GARDEN EXTENSION,BLOCK EA VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	1871	Other Outage	Unplanned Outage	11-09-2025	10:08	11-09-2025	11:55	1:47	0.000446	REPAIR/REPLACEMENT OF GUARD WIRE/LACES
1609	11-09-2025	Part of : BLOCK WZ SHAHPURA CHAUKHANDI VISHNU GARDEN,	815	Other Outage	Planned Outage	11-09-2025	11:08	11-09-2025	14:04	2:56	0.000489	REPLACEMENT OF GAS KIT AND OIL SEAL,REPLACEMENT OF HT BUSHING INULATOR,REPLACEMENT OF SILICAGEL IN BREATHER,REPLACMET OF HT BUSHING ROD
1610	12-09-2025	Part of : BLOCK 14 TILAK NAGAR	244	Other Outage	Planned Outage	12-09-2025	11:07	12-09-2025	13:55	2:48	0.000467	OIL TOP UP IN TRANSFORMER ,OIL TOP UP IN TRANSFORMER ,REPLACEMENT OF GAS KIT AND OIL SEAL
1611	12-09-2025	Part of : RAVI NAGAR VISHNU GARDEN	511	Other Outage	Planned Outage	12-09-2025	10:10	12-09-2025	13:14	3:04	0.000000	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1612	13-09-2025	Part of : KRISHNA PARK EXTENSION TILAK NAGAR	868	Other Outage	Planned Outage	13-09-2025	11:19	13-09-2025	14:31	3:12	0.000800	REPLACMET OF HT BUSHING ROD
1613	14-09-2025	Part of : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION, SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	2422	Other Outage	Unplanned Outage	14-09-2025	06:50	14-09-2025	07:37	0:47	0.001214	HT SYSTEM FAULT
1614	15-09-2025	Part of : BLOCK 1 TILAK NAGAR,BLOCK 24 TILAK NAGAR,BLOCK 16 TILAK NAGAR,BLOCK 17 CENTRAL MARKET TILAK NAGAR,	2840	Other Outage	Unplanned Outage	15-09-2025	12:41	15-09-2025	13:18	0:37	0.000103	INSTALLATION OF TRANSFORMER
1615	15-09-2025	Part of : BLOCK N RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	528	Other Outage	Planned Outage	15-09-2025	11:27	15-09-2025	13:42	2:15	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1616	15-09-2025	Part of : BLOCK E OLD MAHAVIR NAGAR TILAK NAGAR,	759	Other Outage	Planned Outage	15-09-2025	10:49	15-09-2025	14:39	3:50	0.000639	CHECKING OF EARTHING VALUE OF BODY EARTHING AND NEUTRAL EARTHING USING ONLINE EARTH TESTER,CHECKING VALUE OF FENCING EARTHING,DT OIL SAMPLING TO CHECK BDV VALUE,REPLACMET OF HT BUSHING ROD
1617	16-09-2025	Part of : POCKET A SHAM NAGAR VISHNU GARDEN	594	Other Outage	Planned Outage	16-09-2025	15:36	16-09-2025	17:18	1:42	0.000425	REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
1618	16-09-2025	Part of : BLOCK K RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	1290	Other Outage	Planned Outage	16-09-2025	12:33	16-09-2025	14:37	2:04	0.000517	REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
1619	16-09-2025	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	1213	Other Outage	Planned Outage	16-09-2025	11:26	16-09-2025	14:36	3:10	0.000792	CHECKING VALUE OF FENCING EARTHING,INSTALLATION OF BUS BAR,INSTALLATION OF HT BOOTS
1620	16-09-2025	Part of : BLOCK WZ MAJ BHUPENDRA SINGH NAGAR CHAUKHANDI VISHNU GARDEN	424	Other Outage	Planned Outage	16-09-2025	11:00	16-09-2025	14:11	3:11	0.000796	REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
1621	16-09-2025	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN	1006	Other Outage	Planned Outage	16-09-2025	10:46	16-09-2025	13:48	3:02	0.000758	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1622	16-09-2025	Part of : CHAUKHANDI VISHNU GARDEN	592	Other Outage	Planned Outage	16-09-2025	10:43	16-09-2025	13:46	3:03	0.000000	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1623	17-09-2025	Part of : S1-BLOCK & POCKET A KRISHNA PURI TILAK NAGAR	1143	Other Outage	Planned Outage	17-09-2025	11:04	17-09-2025	14:37	3:33	0.000888	REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
1624	17-09-2025	Part of : R-BLOCK JANTA COLONY TAGORE GARDEN EXTENSION	1340	Other Outage	Planned Outage	17-09-2025	11:15	17-09-2025	14:38	3:23	0.000846	REPLACMET OF HT BUSHING ROD,SUB STATION CLEANING
1625	18-09-2025	Part of : BLOCK EA & EC VISHAL ENCLAVE, A-BLOCK RAGHUBIR NAGAR, BLOCK A TAGORE GARDEN EXTN.	1870	Other Outage	Unplanned Outage	18-09-2025	08:11	18-09-2025	08:58	0:47	0.000535	HT SYSTEM FAULT
1626	18-09-2025	Part of : SHIVAJI ENCLAVE TAGORE GARDEN EXTENSION	769	Other Outage	Planned Outage	18-09-2025	15:04	18-09-2025	16:11	1:07	0.000186	REPLACMET OF HT BUSHING ROD,TIGHTENEING OF NUT BOLT
1627	18-09-2025	Part of : BLOCK S1 POCKET A KRISHNA PURI TILAK NAGAR	1175	Other Outage	Planned Outage	18-09-2025	10:58	18-09-2025	14:15	3:17	0.000547	REPLACEMENT OF LT BUSHING INSULATOR,REPLACEMENT OF LT BUSHING ROD
1628	18-09-2025	Part of : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION	398	Other Outage	Planned Outage	18-09-2025	10:46	18-09-2025	14:32	3:46	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1629	19-09-2025	Part of : BLOCK S1 POCKET A KRISHNA PURI TILAK NAGAR,KRISHNA PARK EXTENSION TILAK NAGAR	3552	Other Outage	Unplanned Outage	19-09-2025	14:14	19-09-2025	15:21	1:07	0.001824	CABLE DAMAGE BY OUTSIDE AGENCY (PWD)

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1630	19-09-2025	Part of : CHAUKHANDI VISHNU GARDEN,	592	Other Outage	Planned Outage	19-09-2025	10:42	19-09-2025	14:07	3:25	0.000000	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1631	19-09-2025	Part of : BLOCK S4 MAHAVIR NAGAR NEW TILAK NAGAR,	723	Other Outage	Planned Outage	19-09-2025	10:48	19-09-2025	14:24	3:36	0.000900	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1632	19-09-2025	Part of : RAVI NAGAR VISHNU GARDEN,	511	Other Outage	Planned Outage	19-09-2025	10:06	19-09-2025	13:33	3:27	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1633	20-09-2025	Part of : Block N Raghubir Nagar Tagore Garden Extension,	528	Other Outage	Planned Outage	20-09-2025	11:27	20-09-2025	13:53	2:26	0.000000	CONDUCTOR REPLACEMENT PER SPAN,FERRULE PUNCHING LT AB TO LT AB PER FEEDER ,JUMPER REPLACEMENT PER POLE
1634	22-09-2025	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN	908	Other Outage	Planned Outage	22-09-2025	11:07	22-09-2025	12:58	1:51	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1635	22-09-2025	Part of : BLOCK EF JANTA COLONY TAGORE GARDEN EXTENSION	397	Other Outage	Planned Outage	22-09-2025	11:33	22-09-2025	13:00	1:27	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1636	22-09-2025	Part of : CHAUKHANDI VISHNU GARDEN	786	Other Outage	Planned Outage	22-09-2025	11:33	22-09-2025	14:39	3:06	0.000775	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING
1637	22-09-2025	Part of : BLOCK WZ MBS NAGAR CHAUKHANDI VISHNU GARDEN	1291	Other Outage	Planned Outage	22-09-2025	11:35	22-09-2025	14:39	3:04	0.000767	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1638	22-09-2025	Part of : CHAUKHANDI VISHNU GARDEN	592	Other Outage	Planned Outage	22-09-2025	11:09	22-09-2025	14:35	3:26	0.000858	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1639	23-09-2025	Part of : SHIVAJI PALACE VISHAL ENCLAVE TAGORE GARDEN EXTENSION,	59	Other Outage	Planned Outage	23-09-2025	12:02	23-09-2025	13:48	1:46	0.000442	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1640	23-09-2025	Part of : BLOCK G TILAK NAGAR,	535	Other Outage	Planned Outage	23-09-2025	10:39	23-09-2025	15:00	4:21	0.000725	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1641	23-09-2025	Part of : MUKHRAM GARDEN CHAUKHANDI VISHNU GARDEN,	601	Other Outage	Planned Outage	23-09-2025	11:04	23-09-2025	13:57	2:53	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1642	24-09-2025	Part of : BLOCK H KHAYALA VISHNU GARDEN	2922	Other Outage	Unplanned Outage	24-09-2025	08:04	24-09-2025	10:04	2:00	0.001000	REPAIRING OF U/G CABLE
1643	24-09-2025	Part of : BLOCK A NURSIGH GARDEN KHAYALA VISHNU GARDEN	484	Other Outage	Planned Outage	24-09-2025	12:37	24-09-2025	15:59	3:22	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1644	25-09-2025	Part of : BLOCK 21 TILAK NAGAR	1343	Other Outage	Planned Outage	25-09-2025	11:20	25-09-2025	14:04	2:44	0.000683	REPLACEMENT OF HT BUSHING ROD
1645	26-09-2025	Part of : BLOCK B GANESH NAGAR TILAK NAGAR	662	Other Outage	Planned Outage	26-09-2025	11:03	26-09-2025	13:51	2:48	0.000700	REPLACEMENT OF LT BUSHING ROD,REPLACEMET OF HT BUSHING ROD
1646	26-09-2025	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN	908	Other Outage	Planned Outage	26-09-2025	10:51	26-09-2025	13:50	2:59	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1647	26-09-2025	Part of : CHAUKHANDI VISHNU GARDEN	591	Other Outage	Planned Outage	26-09-2025	10:51	26-09-2025	13:53	3:02	0.000000	AL LUGS PUCHING ON LT XLPE TO LT AB PER FEEDER ,LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1648	27-09-2025	Part of : BLOCK 6 TILAK NAGAR,	256	Other Outage	Planned Outage	27-09-2025	10:29	27-09-2025	13:28	2:59	0.000497	REPLACEMENT OF LT BUSHING ROD,SUB STATION CLEANING,TIGHTENEING OF NUT BOLT
1649	27-09-2025	Part of : BLOCK WZ MUKERJI PARK CHAUKHANDI VISHNU GARDEN,	568	Other Outage	Planned Outage	27-09-2025	11:05	27-09-2025	14:09	3:04	0.000767	REPLACEMET OF HT BUSHING ROD,SUB STATION CLEANING
1650	27-09-2025	Part of : BLOCK N RAGHUBIR NAGAR TAGORE GARDEN EXTENSION,	528	Other Outage	Planned Outage	27-09-2025	11:02	27-09-2025	14:08	3:06	0.000000	LT AB SAGGING PER SPAN,OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1651	29-09-2025	Part of : BLOCK 21 TILAK NAGAR,C-BLOCK GANESH NAGAR	3270	Other Outage	Unplanned Outage	29-09-2025	12:44	29-09-2025	13:33	0:49	0.001470	TREE TOUCHING
1652	29-09-2025	Part of : RAVI NAGAR VISHNU GARDEN,BLOCK WZ KHAYALA VISHNU GARDEN	1992	Other Outage	Unplanned Outage	29-09-2025	01:29	29-09-2025	02:19	0:50	0.002667	CABLE FAULT
1653	29-09-2025	Part of : BLOCK R JANTA COLONY TAGORE GARDEN EXTENSION	797	Other Outage	Planned Outage	29-09-2025	12:54	29-09-2025	15:40	2:46	0.000000	LT CIRCUIT MAINTENANCE
1654	29-09-2025	Part of : CHAUKHANDI VISHNU GARDEN	592	Other Outage	Planned Outage	29-09-2025	10:44	29-09-2025	13:55	3:11	0.000000	LT CIRCUIT MAINTENANCE
1655	30-09-2025	Part of : BLOCK J SHAM NAGAR VISHNU GARDEN, BLOCK J,N & S KHAYALA VISHNU GARDEN	3848	Other Outage	Unplanned Outage	30-09-2025	11:34	30-09-2025	12:32	0:58	0.002658	HT SYSTEM FAULT
1656	30-09-2025	Part of : 72 SFS FLATS MAHAVIR NAGAR, BLOCK C MAHAVIR NAGAR, BLOCK K MAHAVIR NAGAR NEW TILAK NAGAR	1269	Other Outage	Unplanned Outage	30-09-2025	11:26	30-09-2025	12:23	0:57	0.000602	TREE TOUCHING

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1657	30-09-2025	Part of : BLOCK N RAGHUBIR NAGAR TAGORE GARDEN EXTENSION	528	Other Outage	Planned Outage	30-09-2025	12:27	30-09-2025	14:40	2:13	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1658	01-09-2025	Part of : OLD JANKI PURI BINDAPUR	499	Other Outage	Unplanned Outage	01-09-2025	14:55	01-09-2025	15:50	0:55	0.000000	REPAIRING OF LT ACB
1659	04-09-2025	Part of : OLD JANKI PURI BINDAPUR	500	Other Outage	Planned Outage	04-09-2025	10:31	04-09-2025	13:43	3:12	0.000000	LT CIRCUIT MAINTENANCE ACTIVITY
1660	06-09-2025	Part of : INDIRA PARK BINDAPUR	958	Other Outage	Planned Outage	06-09-2025	11:06	06-09-2025	13:42	2:36	0.000000	DT REPLACEMENT
1661	07-09-2025	Part of : OLD JANKI PURI BINDAPUR,BLOCK C MAHINDRA PARK BINDAPUR,BLOCK D 2 MAHINDRA PARK BINDAPUR	3613	Other Outage	Unplanned Outage	07-09-2025	09:32	07-09-2025	10:08	0:36	0.000730	CABLE FAULT
1662	08-09-2025	Part of : GULABHI BAGH OM VIHAR UTTAM NAGAR	1622	Other Outage	Unplanned Outage	08-09-2025	19:13	08-09-2025	20:06	0:53	0.001737	CABLE FAULT
1663	08-09-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	994	Other Outage	Unplanned Outage	08-09-2025	14:50	08-09-2025	15:33	0:43	0.000908	BIRDAGE
1664	08-09-2025	Part of : BLOCK C CHANAKYA PLACE I SITAPURI	1544	Other Outage	Planned Outage	08-09-2025	11:03	08-09-2025	15:18	4:15	0.000000	DT REPLACEMENT
1665	08-09-2025	Part of : BLOCK D UTTAM VIHAR BINDAPUR	600	Other Outage	Planned Outage	08-09-2025	11:16	08-09-2025	13:35	2:19	0.000000	DT REPLACEMENT
1666	09-09-2025	Part of : OLD JANKI PURI BINDAPUR	494	Other Outage	Planned Outage	09-09-2025	11:48	09-09-2025	14:56	3:08	0.000000	LT CIRCUIT REPLACEMENT
1667	09-09-2025	Part of : B-BLOCK UTTAM VIHAR BINDAPUR	599	Other Outage	Planned Outage	09-09-2025	11:04	09-09-2025	14:54	3:50	0.000000	LT CIRCUIT REPLACEMENT
1668	10-09-2025	Part of : BLOCK B UTTAM NAGAR	1129	Other Outage	Planned Outage	10-09-2025	11:06	10-09-2025	15:07	4:01	0.000000	DT REPLACEMENT
1669	10-09-2025	Part of : BINDAPUR	434	Other Outage	Planned Outage	10-09-2025	11:03	10-09-2025	15:06	4:03	0.000000	DT REPLACEMENT
1670	10-09-2025	Part of : BLOCK A SITAPURI PART 2	907	Other Outage	Planned Outage	10-09-2025	11:17	10-09-2025	13:56	2:39	0.000000	DT REPLACEMENT
1671	11-09-2025	Part of : UTTAM NAGAR EAST UTTAM NAGAR,BLOCK D2 MILAP NAGAR UTTAM NAGAR,NEW UTTAM NAGAR UTTAM NAGAR	3259	Other Outage	Unplanned Outage	11-09-2025	18:41	11-09-2025	19:23	0:42	0.001423	TRANSIENT FAULT
1672	11-09-2025	Part of : BHAGAT ENCLAVE BINDAPUR,UTTAM VIHAR BINDAPUR	3388	Other Outage	Unplanned Outage	11-09-2025	15:24	11-09-2025	16:05	0:41	0.000854	CABLE FAULT
1673	11-09-2025	Part of : UTTAM VIHAR BINDAPUR,	2401	Other Outage	Planned Outage	11-09-2025	13:42	11-09-2025	15:24	1:42	0.000000	DT REPLACEMENT
1674	11-09-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,	373	Other Outage	Planned Outage	11-09-2025	11:12	11-09-2025	13:56	2:44	0.000000	DT REPLACEMENT
1675	11-09-2025	Part of : OLD JANKI PURI BINDAPUR,	416	Other Outage	Planned Outage	11-09-2025	11:04	11-09-2025	13:55	2:51	0.000000	DT REPLACEMENT
1676	12-09-2025	Part of : MANAS KUNJ NEW UTTAM NAGAR	999	Other Outage	Planned Outage	12-09-2025	10:42	12-09-2025	14:47	4:05	0.000000	DT REPLACEMENT
1677	12-09-2025	Part of : BLOCK E UTTAM VIHAR BINDAPUR	571	Other Outage	Planned Outage	12-09-2025	11:22	12-09-2025	14:50	3:28	0.000000	DT REPLACEMENT
1678	12-09-2025	Part of : BLOCK A SITAPURI PART 2	907	Other Outage	Planned Outage	12-09-2025	10:12	12-09-2025	13:54	3:42	0.000000	DT REPLACEMENT
1679	13-09-2025	Part of : JAIN COLONY MATIALA,PARAM PURI & SANTOSH PARK,C-BLOCK UTTAM NAGAR,BHAGWATI VIHAR BINDAPUR	7810	Other Outage	Unplanned Outage	13-09-2025	04:25	13-09-2025	05:17	0:52	0.000014	CABLE FAULT
1680	13-09-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	268	Other Outage	Planned Outage	13-09-2025	11:39	13-09-2025	14:17	2:38	0.000000	LT CIRCUIT REPLACEMENT
1681	15-09-2025	Part of : BHAGAT ENCLAVE BINDAPUR,UTTAM VIHAR BINDAPUR	3394	Other Outage	Unplanned Outage	15-09-2025	12:17	15-09-2025	13:09	0:52	0.000852	CABLE FAULT
1682	15-09-2025	Part of : INDIRA PARK BINDAPUR,	623	Other Outage	Unplanned Outage	15-09-2025	12:35	15-09-2025	12:58	0:23	0.000192	RELAY REPLACEMENT
1683	15-09-2025	Part of : OLD JANKI PURI BINDAPUR,	780	Other Outage	Unplanned Outage	15-09-2025	14:08	15-09-2025	15:44	1:36	0.000800	REPAIR/REPLACEMENT OF DEFECTIVE MECHANISM
1684	15-09-2025	Part of : BLOCK A KIRAN GARDENS UTTAM NAGAR,	460	Other Outage	Unplanned Outage	15-09-2025	11:41	15-09-2025	13:37	1:56	0.000000	FEEDER PILLAR MAINTENANCE
1685	15-09-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR,	662	Other Outage	Unplanned Outage	15-09-2025	11:20	15-09-2025	13:37	2:17	0.000000	MAINTENANCE ACTIVITY
1686	15-09-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR,	2381	Other Outage	Planned Outage	15-09-2025	11:15	15-09-2025	14:39	3:24	0.000000	DT REPLACEMENT
1687	16-09-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR	2374	Other Outage	Planned Outage	16-09-2025	12:03	16-09-2025	15:15	3:12	0.000000	DT REPLACEMENT
1688	16-09-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	10	Other Outage	Planned Outage	16-09-2025	11:52	16-09-2025	14:21	2:29	0.000000	DT REPLACEMENT
1689	16-09-2025	Part of : BLOCK T PARAM PURI UTTAM NAGAR	1175	Other Outage	Planned Outage	16-09-2025	11:17	16-09-2025	14:21	3:04	0.000000	DT REPLACEMENT
1690	17-09-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	995	Other Outage	Unplanned Outage	17-09-2025	05:05	17-09-2025	05:57	0:52	0.001329	CABLE FAULT
1691	17-09-2025	Part of : E-BLOCK PARAM PURI UTTAM NAGAR,OM VIHAR,PREM NAGAR	2405	Other Outage	Unplanned Outage	17-09-2025	01:11	17-09-2025	02:03	0:52	0.002744	CABLE FAULT
1692	17-09-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	156	Other Outage	Planned Outage	17-09-2025	12:38	17-09-2025	14:39	2:01	0.000000	DT REPLACEMENT
1693	17-09-2025	Part of : E-BLOCK SITAPURI PART 2	388	Other Outage	Planned Outage	17-09-2025	13:01	17-09-2025	16:10	3:09	0.000000	LT CIRCUIT MAINTENANCE WORK
1694	18-09-2025	Part of : PARJAPAT COLONY, BINDAPUR, ANUP NAGAR ADARSH NAGAR, NAND RAM PARK NEW UTTAM NAGAR	2995	Other Outage	Unplanned Outage	18-09-2025	18:59	18-09-2025	19:49	0:50	0.001528	HVDS FAULT
1695	18-09-2025	Part of : SANTOSH PARK UTTAM NAGAR, BLOCK T UTTAM NAGAR	1925	Other Outage	Unplanned Outage	18-09-2025	17:17	18-09-2025	18:01	0:44	0.001173	CABLE FAULT
1696	18-09-2025	Part of : MANAS KUNJ NEW UTTAM NAGAR	1249	Other Outage	Unplanned Outage	18-09-2025	10:09	18-09-2025	10:10	0:01	0.000000	ATTEND WEAK POINT / HOT SPOT
1697	18-09-2025	Part of : BHAGWATI VIHAR BINDAPUR	2431	Other Outage	Planned Outage	18-09-2025	10:58	18-09-2025	14:41	3:43	0.000000	DT REPLACEMENT
1698	18-09-2025	Part of : MANAS KUNJ NEW UTTAM NAGAR	1249	Other Outage	Planned Outage	18-09-2025	11:52	18-09-2025	15:39	3:47	0.000000	DT REPLACEMENT
1699	19-09-2025	Part of : BLOCK F UTTAM VIHAR BINDAPUR,	2829	Other Outage	Planned Outage	19-09-2025	11:49	19-09-2025	15:16	3:27	0.000000	DT REPLACEMENT
1700	19-09-2025	Part of : UTTAM VIHAR BINDAPUR,	1421	Other Outage	Planned Outage	19-09-2025	11:50	19-09-2025	15:15	3:25	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1701	19-09-2025	Part of : BLOCK C MAHINDRA PARK BINDAPUR,	792	Other Outage	Planned Outage	19-09-2025	10:00	19-09-2025	15:13	5:13	0.000000	DT REPLACEMENT
1702	19-09-2025	Part of : BLOCK T PARAM PURI UTTAM NAGAR,	1304	Other Outage	Planned Outage	19-09-2025	11:01	19-09-2025	15:13	4:12	0.000000	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1703	19-09-2025	Part of : BLOCK E PARAM PURI UTTAM NAGAR,	779	Other Outage	Planned Outage	19-09-2025	11:12	19-09-2025	15:14	4:02	0.000000	DT REPLACEMENT
1704	19-09-2025	Part of : BLOCK C MAHINDRA PARK BINDAPUR,	794	Other Outage	Planned Outage	19-09-2025	09:59	19-09-2025	14:08	4:09	0.000000	DT REPLACEMENT
1705	22-09-2025	Part of : BLOCK A SITAPURI PART 2	262	Other Outage	Planned Outage	22-09-2025	12:42	22-09-2025	14:20	1:38	0.000000	DT REPLACEMENT
1706	22-09-2025	Part of : INDIRA PARK BINDAPUR	624	Other Outage	Planned Outage	22-09-2025	14:16	22-09-2025	16:30	2:14	0.000000	GUARD WIRES SAGGING PER SPAN
1707	22-09-2025	Part of : BLOCK C UTTAM VIHAR BINDAPUR	1573	Other Outage	Planned Outage	22-09-2025	11:26	22-09-2025	14:21	2:55	0.000000	DT REPLACEMENT
1708	23-09-2025	Part of : BLOCK G UTTAM NAGAR,	1637	Other Outage	Planned Outage	23-09-2025	11:24	23-09-2025	14:37	3:13	0.000000	RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1709	23-09-2025	Part of : BLOCK F JEEVAN PARK BINDAPUR,	1390	Other Outage	Planned Outage	23-09-2025	10:47	23-09-2025	14:36	3:49	0.000000	DT REPLACEMENT
1710	23-09-2025	Part of : OLD JANKI PURI BINDAPUR,	500	Other Outage	Planned Outage	23-09-2025	10:24	23-09-2025	14:37	4:13	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1711	23-09-2025	Part of : PARJAPAT COLONY BINDAPUR,	682	Other Outage	Planned Outage	23-09-2025	11:24	23-09-2025	14:35	3:11	0.000000	DT REPLACEMENT
1712	23-09-2025	Part of : PARJAPAT COLONY BINDAPUR,	1335	Other Outage	Planned Outage	23-09-2025	11:25	23-09-2025	14:38	3:13	0.000000	DT REPLACEMENT
1713	24-09-2025	Part of : MAHINDRA PARK BINDAPUR,POCKET 4 CHANAKYA PLACE I SITAPURI,BLOCK A 3 HARJAN COLONY SITAPURI PART 1 SITAPURI,BLOCK C CHANAKYA PLACE I SITAPURI	5265	Other Outage	Unplanned Outage	24-09-2025	01:20	24-09-2025	02:06	0:46	0.000703	CABLE FAULT
1714	24-09-2025	Part of : BLOCK E UTTAM VIHAR BINDAPUR	771	Other Outage	Planned Outage	24-09-2025	12:53	24-09-2025	14:19	1:26	0.001194	REPLACEMENT OF CROSS-ARMS AND POLES
1715	24-09-2025	Part of : JAIN COLONY MATIALA,BHAGWATI VIHAR BINDAPUR	1035	Other Outage	Planned Outage	24-09-2025	11:01	24-09-2025	14:20	3:19	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1716	24-09-2025	Part of : BHAGAT ENCLAVE BINDAPUR	991	Other Outage	Planned Outage	24-09-2025	12:30	24-09-2025	16:08	3:38	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1717	25-09-2025	Part of : ANUP NAGAR ADARSH NAGAR BINDAPUR	995	Other Outage	Unplanned Outage	25-09-2025	01:32	25-09-2025	02:09	0:37	0.001059	CABLE FAULT
1718	25-09-2025	Part of : BLOCK F JEEVAN PARK BINDAPUR	503	Other Outage	Planned Outage	25-09-2025	11:26	25-09-2025	15:06	3:40	0.000000	DT REPLACEMENT
1719	25-09-2025	Part of : BHAGWATI VIHAR BINDAPUR	1812	Other Outage	Planned Outage	25-09-2025	11:34	25-09-2025	15:09	3:35	0.000000	LT CIRCUIT MAINTENANCE
1720	26-09-2025	Part of : BLOCK C CHANAKYA PLACE I SITAPURI	788	Other Outage	Planned Outage	26-09-2025	11:46	26-09-2025	15:06	3:20	0.000000	DT REPLACEMENT
1721	26-09-2025	Part of : BLOCK E PARAM PURI UTTAM NAGAR	1140	Other Outage	Planned Outage	26-09-2025	11:57	26-09-2025	15:53	3:56	0.000000	DT REPLACEMENT
1722	26-09-2025	Part of : PARAM PURI UTTAM NAGAR	823	Other Outage	Planned Outage	26-09-2025	11:53	26-09-2025	15:03	3:10	0.000000	DT REPLACEMENT
1723	27-09-2025	Part of : MAHINDRA PARK BINDAPUR,	1466	Other Outage	Planned Outage	27-09-2025	10:46	27-09-2025	14:36	3:50	0.000000	DT REPLACEMENT
1724	27-09-2025	Part of : NEW UTTAM NAGAR UTTAM NAGAR,	862	Other Outage	Planned Outage	27-09-2025	11:04	27-09-2025	14:33	3:29	0.000000	DT REPLACEMENT
1725	29-09-2025	Part of : BLOCK A 3 HARJAN COLONY SITAPURI PART 1	1113	Other Outage	Planned Outage	29-09-2025	11:13	29-09-2025	14:04	2:51	0.000000	DT REPLACEMENT
1726	29-09-2025	Part of : BLOCK D JJ COLONY UTTAM NAGAR	1131	Other Outage	Planned Outage	29-09-2025	11:21	29-09-2025	14:04	2:43	0.000000	DT REPLACEMENT
1727	30-09-2025	Part of : BLOCK B UTTAM NAGAR	2914	Other Outage	Unplanned Outage	30-09-2025	11:47	30-09-2025	12:09	0:22	0.000526	CABLE FAULT
1728	30-09-2025	Part of : VANI VIHAR, MANAS KUNJ NEW UTTAM NAGAR	2378	Other Outage	Unplanned Outage	30-09-2025	12:14	30-09-2025	12:58	0:44	0.000672	HVDS FAULT
1729	02-09-2025	Part of : RELIANCE MALL A BLK VIKAS PURI (HTC)	0	Other Outage	Unplanned Outage	02-09-2025	22:50	02-09-2025	23:31	0:41	0.000023	CABLE FAULT
1730	02-09-2025	Part of : SHIV VIHAR HASTSAL	950	Other Outage	Unplanned Outage	02-09-2025	10:21	02-09-2025	12:26	2:05	0.000000	REPAIRING OF LT CIRCUIT
1731	02-09-2025	Part of : SHIV VIHAR WEST	176	Other Outage	Planned Outage	02-09-2025	10:35	02-09-2025	13:21	2:46	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1732	03-09-2025	Part of : SHIV VIHAR WEST,	17	Other Outage	Unplanned Outage	03-09-2025	13:12	03-09-2025	14:20	1:08	0.000000	REPAIRING OF LT CIRCUIT
1733	03-09-2025	Part of : BLOCK B JJ COLONY UTTAM NAGAR,	932	Other Outage	Planned Outage	03-09-2025	10:55	03-09-2025	14:19	3:24	0.000000	LT TRANSFORMER REPLACEMENT
1734	03-09-2025	Part of : K-5 EXTN. AND DEEPAK VIHAR,	832	Other Outage	Planned Outage	03-09-2025	10:22	03-09-2025	14:18	3:56	0.000000	LT TRANSFORMER REPLACEMENT
1735	03-09-2025	Part of : BLOCK H2 VIKAS PURI,	328	Other Outage	Planned Outage	03-09-2025	10:41	03-09-2025	14:18	3:37	0.000000	LT TRANSFORMER REPLACEMENT
1736	04-09-2025	Part of : BLOCK D DDA MARKET VIKAS PURI	319	Other Outage	Unplanned Outage	04-09-2025	11:06	04-09-2025	12:02	0:56	0.000000	REPAIRING OF LT CIRCUIT
1737	04-09-2025	Part of : SHIV VIHAR WEST	176	Other Outage	Unplanned Outage	04-09-2025	10:49	04-09-2025	11:59	1:10	0.000000	LAYING OF NEW LT CABLE
1738	06-09-2025	Part of : SHIV VIHAR HASTSAL	950	Other Outage	Unplanned Outage	06-09-2025	03:43	06-09-2025	04:10	0:27	0.000308	CABLE FAULT
1739	06-09-2025	Part of : B-BLOCK VIKAS VIHAR (EAST)	1730	Other Outage	Unplanned Outage	06-09-2025	13:44	06-09-2025	15:44	2:00	0.000000	LAYING OF NEW LTAB
1740	06-09-2025	Part of : BLOCK B JJ COLONY UTTAM NAGAR	936	Other Outage	Planned Outage	06-09-2025	15:26	06-09-2025	16:42	1:16	0.000000	DAMAGED BUSHING REPLACEMENT BY WORKSHOP PER PHASE,RMU REPLACEMENT INCLUDING MAKE OF END TERMINATION
1741	08-09-2025	Part of : SHIV VIHAR HASTSAL	534	Other Outage	Planned Outage	08-09-2025	15:03	08-09-2025	17:17	2:14	0.000000	DT REPLACEMENT
1742	08-09-2025	Part of : BLOCK H2 VIKAS PURI	360	Other Outage	Planned Outage	08-09-2025	10:35	08-09-2025	14:15	3:40	0.000000	DT REPLACEMENT
1743	08-09-2025	Part of : PHASE 1 OM VIHAR NAWADA	1075	Other Outage	Planned Outage	08-09-2025	10:37	08-09-2025	14:16	3:39	0.000000	DT REPLACEMENT
1744	08-09-2025	Part of : SHIV VIHAR COLONY	1784	Other Outage	Planned Outage	08-09-2025	10:20	08-09-2025	12:53	2:33	0.000000	OD END BOX INSTALLATION ON ACB END AND POLE END PER XLPE CABLE
1745	09-09-2025	Part of : VIKAS KUNJ EXTN.	2240	Other Outage	Planned Outage	09-09-2025	14:59	09-09-2025	17:30	2:31	0.000000	DT REPLACEMENT
1746	09-09-2025	Part of : A 3-BLOCK UTTAM NAGAR	34	Other Outage	Planned Outage	09-09-2025	10:43	09-09-2025	14:59	4:16	0.000000	LT CIRCUIT REPLACEMENT
1747	09-09-2025	Part of : DEEP ENCLAVE	1312	Other Outage	Planned Outage	09-09-2025	11:11	09-09-2025	14:58	3:47	0.000000	LT CIRCUIT REPLACEMENT
1748	09-09-2025	Part of : L-BLOCK VIKAS PURI	162	Other Outage	Planned Outage	09-09-2025	10:13	09-09-2025	13:54	3:41	0.000000	LT CIRCUIT REPLACEMENT
1749	10-09-2025	Part of : D-BLOCK JJ COLONY	19	Other Outage	Planned Outage	10-09-2025	15:08	10-09-2025	16:13	1:05	0.000000	DT REPLACEMENT
1750	10-09-2025	Part of : BLOCK AG 1 VIKAS PURI, BLOCK A VIKAS PURI	712	Other Outage	Planned Outage	10-09-2025	10:31	10-09-2025	13:56	3:25	0.000000	DT REPLACEMENT

Sr. No.	Date	Area Effected	No. of consumer affected	Capacity of DT	Wether Planned Outage or Unplanned Outage	Outage Detail						
						From		To		Duration	Unservd (MU) due to outage	Remarks
						Date	Time	Date	Time			
1751	10-09-2025	Part of : SHIV VIHAR COLONY	1784	Other Outage	Planned Outage	10-09-2025	13:02	10-09-2025	16:12	3:10	0.000000	CONDUCTOR REPLACEMENT PER SPAN
1752	12-09-2025	Part of : HOSTAL VIHAR OM VIHAR HASTSAL,PHASE 2 OM VIHAR HASTSAL	664	Other Outage	Planned Outage	12-09-2025	11:09	12-09-2025	14:48	3:39	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1753	12-09-2025	Part of : BLOCK JG 3 VIKAS PURI	844	Other Outage	Planned Outage	12-09-2025	10:29	12-09-2025	13:56	3:27	0.000000	DT REPLACEMENT
1754	13-09-2025	Part of : SHIV VIHAR COLONY	1765	Other Outage	Planned Outage	13-09-2025	11:10	13-09-2025	14:13	3:03	0.000000	LT CIRCUIT REPLACEMENT
1755	13-09-2025	Part of : GUPTA ENCLAVE	1062	Other Outage	Planned Outage	13-09-2025	11:11	13-09-2025	14:15	3:04	0.000000	LT CONDUCTOR REPLACEMENT
1756	13-09-2025	Part of : BLOCK A VIKAS PURI	229	Other Outage	Planned Outage	13-09-2025	10:17	13-09-2025	14:12	3:55	0.000000	LT CIRCUIT REPLACEMENT
1757	15-09-2025	Part of : JJ COLONY UTTAM NAGAR,	582	Other Outage	Planned Outage	15-09-2025	12:09	15-09-2025	16:02	3:53	0.000000	DT REPLACEMENT
1758	15-09-2025	Part of : BHIM ENCLAVE,	1355	Other Outage	Planned Outage	15-09-2025	12:05	15-09-2025	15:45	3:40	0.000000	DT REPLACEMENT
1759	15-09-2025	Part of : BLOCK GG2 VIKAS PURI,	437	Other Outage	Planned Outage	15-09-2025	10:54	15-09-2025	14:40	3:46	0.000000	REPLACEMENT OF CROSS-ARMS AND POLES
1760	16-09-2025	Part of : SHIV VIHAR HASTSAL,LIG MIG FLATS POCKET C HASTSAL,BLOCK M ZAIDAR ENCLAVE HASTSAL,BLOCK P MOHAN GARDEN RAZAPUR KHURD	4776	Other Outage	Unplanned Outage	16-09-2025	05:55	16-09-2025	06:27	0:32	0.000000	HVDS FAULT
1761	16-09-2025	Part of : YADAV ENCLAVE AND VIKAS VIHAR	1484	Other Outage	Planned Outage	16-09-2025	11:20	16-09-2025	14:47	3:27	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1762	16-09-2025	Part of : BLOCK A 2 UTTAM NAGAR	390	Other Outage	Planned Outage	16-09-2025	10:55	16-09-2025	14:42	3:47	0.000000	DT REPLACEMENT
1763	16-09-2025	Part of : BLOCK KG 1 VIKAS PURI	389	Other Outage	Planned Outage	16-09-2025	10:55	16-09-2025	14:20	3:25	0.000000	DT REPLACEMENT
1764	17-09-2025	Part of : VIKAS KUNJ & VIKAS KUNJ EXTN.	2238	Other Outage	Unplanned Outage	17-09-2025	12:27	17-09-2025	13:46	1:19	0.000000	REPAIRING OF LT ACB
1765	18-09-2025	Part of : B-BLOCK VIKAS NAGAR	119	Other Outage	Planned Outage	18-09-2025	11:48	18-09-2025	15:40	3:52	0.000000	DT REPLACEMENT
1766	19-09-2025	Part of : K-5 EXTN. AND DEEPAK VIHAR,PRESS ENCLAVE,SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK,VIKAS ENCLAVE AND B-BLOCK VIKAS NAGAR EXTN.,	1695	Other Outage	Unplanned Outage	19-09-2025	11:14	19-09-2025	12:37	1:23	0.000000	REPAIRING OF HVDS CIRCUIT
1767	19-09-2025	Part of : PHASE 3 OM VIHAR HASTSAL,PHASE 5 OM VIHAR HASTSAL,	1244	Other Outage	Planned Outage	19-09-2025	14:10	19-09-2025	16:09	1:59	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1768	19-09-2025	Part of : BLOCK H2 VIKAS PURI,	360	Other Outage	Planned Outage	19-09-2025	10:32	19-09-2025	14:09	3:37	0.000000	DT REPLACEMENT
1769	20-09-2025	Part of : Krishna Colony Hastsal Village Hastsal,	517	Other Outage	Planned Outage	20-09-2025	13:19	20-09-2025	16:15	2:56	0.000000	DT REPLACEMENT
1770	20-09-2025	Part of : VIKAS NAGAR EXTN.,	2	Other Outage	Planned Outage	20-09-2025	11:01	20-09-2025	14:46	3:45	0.000000	DT REPLACEMENT
1771	20-09-2025	Part of : Block JG 1 Vikas Puri,	362	Other Outage	Planned Outage	20-09-2025	10:22	20-09-2025	14:02	3:40	0.000000	DT REPLACEMENT
1772	22-09-2025	Part of : TENNERS COLONY, BLOCK H2 & H3 VIKAS PURI, BLOCK H KESHOPUR INDUSTRIAL AREA VIKAS PURI, KESHOPUR VIKAS PURI	1104	Other Outage	Unplanned Outage	22-09-2025	17:11	22-09-2025	18:00	0:49	0.001552	CABLE FAULT
1773	22-09-2025	Part of : YADAV ENCLAVE AND VIKAS VIHAR	931	Other Outage	Unplanned Outage	22-09-2025	14:30	22-09-2025	15:55	1:25	0.000236	CONNECTION OF NEW LT CABLE
1774	22-09-2025	Part of : BLOCK C JJ COLONY UTTAM NAGAR	1024	Other Outage	Planned Outage	22-09-2025	11:27	22-09-2025	14:19	2:52	0.000000	DT REPLACEMENT
1775	22-09-2025	Part of : BLOCK FG1 VIKAS PURI	451	Other Outage	Planned Outage	22-09-2025	10:10	22-09-2025	13:50	3:40	0.000000	DT REPLACEMENT
1776	23-09-2025	Part of : BLOCK A 3 UTTAM NAGAR,	34	Other Outage	Planned Outage	23-09-2025	11:35	23-09-2025	14:34	2:59	0.000000	DT REPLACEMENT
1777	23-09-2025	Part of : BLOCK L VIKAS PURI,	344	Other Outage	Planned Outage	23-09-2025	10:35	23-09-2025	14:32	3:57	0.000000	DT REPLACEMENT
1778	24-09-2025	Part of : BLOCK C JJ COLONY UTTAM NAGAR	1991	Other Outage	Planned Outage	24-09-2025	14:44	24-09-2025	16:07	1:23	0.000000	DT REPLACEMENT
1779	24-09-2025	Part of : SURKAKHA ENCLAVE AND M- BLOCK COMMONDER CHOWK,VIKAS NAGAR EXTN,SAINIK ENCLAVE	1798	Other Outage	Planned Outage	24-09-2025	11:40	24-09-2025	14:48	3:08	0.000000	3PH HT AB CABLE REPLACEMENT PER SPAN
1780	24-09-2025	Part of : BLOCK H2 VIKAS PURI	328	Other Outage	Planned Outage	24-09-2025	10:23	24-09-2025	14:15	3:52	0.000000	DT REPLACEMENT
1781	25-09-2025	Part of : H 2 & H 3-BLOCKVIKAS PURI,H-BLOCK KESHOPUR INDUSTRIAL AREA	1105	Other Outage	Unplanned Outage	25-09-2025	16:50	25-09-2025	17:35	0:45	0.001425	CABLE FAULT
1782	25-09-2025	Part of : A 2-BLOCK UTTAM NAGAR,OM VIHAR PHASE 2 HASTSAL	1442	Other Outage	Unplanned Outage	25-09-2025	10:56	25-09-2025	11:28	0:32	0.000000	ATTENDING WEAK POINTS/HOT SPOT
1783	25-09-2025	Part of : VIKAS KUNJ AND VIKAS KUNJ EXTN	2240	Other Outage	Planned Outage	25-09-2025	11:09	25-09-2025	12:33	1:24	0.000000	LT CIRCUIT MAINTENANCE
1784	25-09-2025	Part of : VIKAS NAGAR EXTN	110	Other Outage	Planned Outage	25-09-2025	11:08	25-09-2025	14:36	3:28	0.000000	3PH HT AB CABLE REPLACEMENT
1785	26-09-2025	Part of : JJ COLONY UTTAM NAGAR	1061	Other Outage	Planned Outage	26-09-2025	11:10	26-09-2025	15:03	3:53	0.000000	DT REPLACEMENT
1786	26-09-2025	Part of : BHIM ENCLAVE	1356	Other Outage	Planned Outage	26-09-2025	10:40	26-09-2025	14:24	3:44	0.000000	3PH DB REPLACEMENT
1787	26-09-2025	Part of : BLOCK C VIKAS PURI	412	Other Outage	Planned Outage	26-09-2025	10:29	26-09-2025	14:24	3:55	0.000000	DT REPLACEMENT
1788	26-09-2025	Part of : VIKAS ENCLAVE AND B-BLOCK VIKAS NAGAR EXTN	50	Other Outage	Planned Outage	26-09-2025	10:40	26-09-2025	14:23	3:43	0.000000	DT REPLACEMENT
1789	28-09-2025	Part of : ANAND KUNJ VIKAS PURI,BLOCK GG1 VIKAS PURI,GUJRANWALA VIKAS PURI	1243	Other Outage	Unplanned Outage	28-09-2025	20:38	28-09-2025	21:08	0:30	0.001250	CABLE FAULT
1790	29-09-2025	Part of : YADAV ENCLAVE AND VIKAS VIHAR	931	Other Outage	Unplanned Outage	29-09-2025	15:04	29-09-2025	16:33	1:29	0.001236	REPAIR/REPLACEMENT OF LT AB
1791	29-09-2025	Part of : VIKAS KUNJ AND VIKAS KUNJ EXTN.	2240	Other Outage	Planned Outage	29-09-2025	15:02	29-09-2025	17:28	2:26	0.000000	OD END BOX INSTALLATION ON ACB END
1792	29-09-2025	Part of : GUPTA ENCLAVE	1062	Other Outage	Planned Outage	29-09-2025	15:01	29-09-2025	17:29	2:28	0.000000	LT CIRCUIT MAINTENANCE
1793	29-09-2025	Part of : KRISHNA COLONY HASTSAL VILLAGE	823	Other Outage	Planned Outage	29-09-2025	11:03	29-09-2025	14:03	3:00	0.000000	DT REPLACEMENT
1794	30-09-2025	Part of : DDA LIG FLATS HASTSAL, LIG-2 HASTAL	861	Other Outage	Unplanned Outage	30-09-2025	18:02	30-09-2025	18:43	0:41	0.000569	HT SYSTEM FAULT