

Name of Company

BSES Yamuna Power Ltd, Delhi

Period of Report

August

Year

2026

Service Area	Standard wrt AT&C Losses			Pending Complaint of the Previous Month	Complaint Received During the Month	Total Complaint	Complaints Attended During the Month			Balance Complaint to be Attended
	Upto 10%	More than 10% and Upto 20%	More than 20%				Within Specified Time	Beyond Specified Time	Total	
3										
1	2			3	4	5=3+4	6	7	8=6+7	9=5-8
Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement	Within three hours	Within four hours	Within six hours	167	41003	41170	40684	272	40956	214
Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.	Within two hours	Within three hours	Within four hours	0	597	597	590	7	597	0
Continuous power supply failure requiring replacement of distribution transformer	Within six hours			0	2	2	2	0	2	0
Continuous Scheduled Power Outages	Within 12 hours or restoration of power supply by 6PM			0	276	276	276	0	276	0
Replacement of Burnt Meter or Stolen Meter	Restoration of supply within three hours either by bypassing the			2	1808	1810	1809	0	1809	1
Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS)				0	46	46	45	1	46	0