

Summary of Overall Standards of Performance:-August-2026

Sr No	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance Achieved (C)%
				Within Specified Time	Beyond Specified time	
1	Power Supply Failure					
(i)	Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.	At least 95% calls received should be rectified within prescribed time limits	41170	40684	272	98.82%
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.		597	590	7	98.83%
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		2	2	0	100.00%
(iv)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above	At least 95% calls received should be rectified within prescribed time limits	46	45	1	97.83%
(v)	Continuous scheduled power outages	At least 95% of cases resolved within time limit	276	276	0	100.00%
(vi)	Replacement of burnt meter or stolen Meter		1810	1809	0	99.94%
Period of Scheduled Outage						
2	Maximum duration in a single stretch	At least 95% of cases resolved within time limit	276	276	0	100.00%
	Restoration of supply by 6:00 PM		276	276	0	100.00%
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	2196	2144	52	97.63%
	Reliability Indices					
4	SAIFI	To be laid down by the Commission based on SAIDI the targets proposed by the Licensees.	0.12			
	SAIDI		0.08			
	CAIDI		0.66			
5	Frequency variation	To maintain supply frequency within range as per IEGC.				
6	Voltage imbalance	Maximum of 3% at point of commencement of supply		No. of Bills Served	Bills with Mistakes	
7	Percentage billing mistakes	Shall not exceed 0.2%		2141671	471	0.02%