

Restoration of Power Supply

Name of Company

BSES Yamuna Power Ltd, Delhi

Format-III

Period of Report

October

Year

2025

Service Area	Standard wrt AT&C losses			Pending complaint of the previous	Complaint received during the month	Total Complaint	Complaints attended during the			Balance complaint to be attended
3	Upto 10%	More than 10% and upto 20%	More than 20%				Within Specified Time	Beyond specified time	Total	
1	2			3	4	5=3+4	6	7	8=6+7	9=5-8
Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement	Within three hours	Within four hours	Within six hours	78	25606	25684	25445	198	25643	41
Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.	Within two hours	Within three hours	Within four hours	0	57	57	56	1	57	0
Continuous power supply failure requiring replacement of distribution transformer	Within six hours			0	2	2	2	0	2	0
Continuous Scheduled Power Outages	Within 12 hours or restoration of power supply by 6PM			0	354	354	354	0	354	0
Replacement of Burnt Meter or Stolen Meter	Restoration of supply within three hours either by bypassing the			1	1259	1260	1259	0	1259	1
Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS)				0	8	8	8	0	8	0