

Summary of Overall Standards of Performance:-Q2 FY24-25

Sr No	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (C)%
				Within Specified Time	Beyond specified time	
1	Power Supply Failure					
(i)	Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.	At least 95% calls received should be rectified within prescribed time limits	166851	165413	724	99.14%
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.		1520	1459	42	95.99%
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		10	10	0	100.00%
(iv)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above	At least 95% calls received should be rectified within prescribed time limits	181	175	4	96.69%
(v)	Continuous scheduled power outages	At least 95% of cases resolved within time limit	956	956	0	100.00%
(vi)	Replacement of burnt meter or stolen Meter		5139	5138	0	99.98%
Period of Scheduled Outage						
2	Maximum duration in a single stretch	At least 95% of cases resolved within time limit	956	956	0	100.00%
	Restoration of supply by 6:00 PM		956	956	0	100.00%
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	6688	6529	159	97.62%
Reliability Indices						
4	SAIFI	To be laid down by the Commission based on SAIDI the targets proposed by the Licensees.	0.60			
	SAIDI		0.41			
	CAIDI		0.68			
5	Frequency variation	To maintain supply frequency within range as per IEGC.				
6	Voltage imbalance	Maximum of 3% at point of commencement of supply		No. of bills served	Bills with mistakes	
7	Percentage billing mistakes	Shall not exceed 0.2%		6003291	1091	0.02%