

**SUPPLY, INSTALLATION OF DT SMART METERS & ITS INTEGRATION WITH HES AT BYPL NIT No.: CMC/BY/24-25/RS/Sks/APT/57**

**Amendment No. 2**

Sr. No.	Section	Page No.	Clause No.	Existing Clause	Amendment/Clarification
1.	2	17	15.04	The Bidder, along with the bid documents has to submit four samples along with detailed GTP & Drawings.	<b>Amendment–</b> The Bidder, along with bid document has to submit <b>TWO SAMPLES</b> along with detail GTP, tamper thresholds and drawings.

**2.00 Qualification Criteria (a) Technical Criteria**

Sr. No.	Section	Page No.	Clause No.	Existing Clause	Amendment / Clarification
1.	1	6	2.00 (a) - 7(C)	Meter Burn In system: In order to ensure the reliability of components and that there is no drift in meter accuracy with time; the manufacturer should have burn in facility -- Running meter with load at elevated temperature.	<b>Clause 7.c. stands deleted</b>
2.	1	6	2.00 (a)– 7(H)	-	<b>Clause Addition -</b> <b>7.h.-</b> The bidder should have in-house NABL (ISO:17025:2017) accredited Laboratory for acceptance test for the relevant IS

**All other Terms &Conditions of the referred Request for Proposal (RFP)/ Tender and/or Amendments shall remain unchanged.**