

NIT NO: CMC/BY/22-23/RS/SV/26

## CORRIGENDUM-3

Dated 25.10.2022

Refer NIT No. CMC/BY/22-23/RS/SV/26 dated 25.06.2022 for "TURNKEY PACKAGE FOR CONVERSION OF 33 KV SYSTEM AT GT ROAD GRID FROM OUTDOOR AIS TO INDOOR GIS WITH DOUBLE BUS BAR SYSTEM, AUGMENTATION OF 1 NO 33/11 kV POWER TRANSFORMER FROM 16 TO 31.5 MVA AND INSTALLATION OF 3 NOS 11KV SWITCHBOARD ALONG WITH ASSOCIATED CIVIL WORKS"

Following revision(s) has been done in the NIT:

| S.<br>No | Specification<br>Name   | Specification<br>Number  | Header                | Clause<br>Number | Page<br>Number | Corrigendum Points   | Remarks                   |
|----------|---|--------------------------|-----------------------|------------------|----------------|--|---------------------------|
| 1        | SCOPE OF<br>TURNKEY<br>EXECUTION<br>FOR GT ROAD<br>GRID<br>SUBSTATION | BSES-TS-109-             | SCOPE<br>OF<br>SUPPLY | 3.2.6.4          |                | Point (b) states that "It Excludes Illumination and Lighting system for New building containing 33 kV GIS". Kindly read it as "It Includes Illumination and Lighting system for New building containing 33 kV GIS" | Typo Error                |
| 2        | SCOPE OF<br>TURNKEY<br>EXECUTION<br>FOR GT ROAD<br>GRID<br>SUBSTATION | BSES-TS-109-<br>TEGTS-R0 | Scope of<br>Work      | 3.3.13.2         | 165 of<br>811  | Soil Investigation Report has been attached.   | Attachment                |
| 3        | SCOPE OF<br>TURNKEY<br>EXECUTION<br>FOR GT ROAD<br>GRID<br>SUBSTATION | BSES-TS-109-             | Scope of<br>Work      | 3.3.13.20        | 811            | Fire wall shall be of RCC type.  | Clarification             |
| 4        | SCOPE OF<br>TURNKEY<br>EXECUTION<br>FOR GT ROAD<br>GRID<br>SUBSTATION | BSES-TS-109-             | SCOPE<br>OF<br>SUPPLY | 3.2.17           | 750 of<br>811  | SCADA Specification has been revised and attached. Kindly refer "TECHNICAL SPECIFICATION FOR SCADA RTU/ DCU & NETWORK AUTOMATION BASED ON IEC 61850 PROTOCOL" for SCADA works.                                     | Requirement<br>Revised    |
| 5        | NA  | NA                       | NA                    | NA               | NA             | Dismantling of RTU and Its<br>Associated Items   | Additional<br>Requirement |
| 6        | NA  | NA                       | NA                    | NA               | NA             | Dismantling of Existing RTCC panels and Existing Trays shall be in bidder's scope.   | Additional<br>Requirement |
| 7        | NA  | NA                       | NA                    | NA               | NA             | Pit for NIFPS if required shall be in Bidder's scope.  | Additional<br>Requirement |
| 8        | NA  | NA                       | NA                    | NA               | NA             | Any Tree branch cutting shall be in Bidder's scope.  | Additional<br>Requirement |

All other terms and conditions as mentioned in the NIT No. CMC/BY/22-23/RS/SV/26, subsequent addendum / corrigendum if any, BYPL reply to pre bid queries shall be applicable. This Corrigendum shall be the integral part of the subject tender documents and to be submitted along with bid.