

BYPL NIT NO:		CMC/BY/23-24/RS/SvS/VK/11 DT: 16.05.2023		
Work:		Laying of Sewer line at BSES Colony, Delhi		
Sl. No	NIT Clause Reference	Description	Bidders Query	BYPL Reply
1	Section -VI Price bid Page 95 to 101 of 129	Amendment in price bid	>where the residential building and drains are there and the soil is predominantly loose, having a very low N value. There is every chance of ground collapse during open excavation which may lead to structural collapse in buildings. >Hence, it is advisable that we adopt the trenchless technique of Micro-tunnelling to execute the primary sewer of 600mm.	>Refer revised Price Bid (Section - VI) attached along with this corrigendum. >Bidder are requested to submit the quotation as per revised price bids.