

CORRIGENDUM 2		Reply of pre-bid queries and extension of Bid Submission date		
Date:		09.06.2022		
BYPL NIT NO:		CMC/BY/21-22/RS/SvS/AS/12 DT: 13.05.2022		
Work:		Award of Contract for Repairing and Servicing of Damaged/Failed Oil Filled Distribution Transformers of varrious Rating at BYPL's Workshop		
Sl.No	Clause Reference	Description	Bidder's Query	BYPL Response
1	Section-I, RFQ, Cl 1.1.....Bid Submission	Bid Submission upto 06.06.2022	Extension of Bid submission Date by 7-10 days	Bid submission date is extended upto 16.06.2022
2	Section-I, RFQ, Cl 1.3.....QR	Solvency certificate	Waiver of the solvency certificate clause	Tender conditions shall prevail
3	Section-I, RFQ, Cl 1.1.....EMD	EMD	Reduced the EMD amount	Tender conditions shall prevail
4	Section-III, T&C, Cl 4.....	Cost of new Copper & Old windings.	Waive of the cutting of old coil into smaller pieces	Tender conditions shall prevail
5	Section-IV, Scope of Work, Annexure -1	Repairing : terms & condition for Repairing of DT : Vendors to provide : Supervisor with technician and labors, Minimum 01 No supervisor (Qualification- Minimum Diploma) + 03 No's Technician (ITI holder), 01 No certified Welder + 10 No's skilled workers & 15 No's semiskilled, 1 painter & 1 no's for housekeeping workers shall be provided by the contractor.	Remove this point as manpower requirement is changed as per requirement	Minimum no. of 19 nos. of dedicated Manpower is reqd to maintain quantity ,quality, decorum, safety and proper monitoring. Supervisor - 1 no.,Main Technician -01 No.,Certified Welder – 1 no. ,Skilled workers – 10 nos. (Winder or coil fabricator, Core coil tanker and un-tanker , Core coil assembler),Semiskilled – 4 nos.Painter – 1 no. ,Housekeeping – 1 no.
6	Section-IV, Scope of Work, Annexure -1	Hazardous waste handling, storage & disposal	Waiver of this clause as DPCC has authorized only Tamil Nadu waste management Ltd, who deals directly with principal employer	As per DPCC guidelines , the agreement is to be made between BSES and the authorized hazardous waste collector (Tamil Nadu waste management ltd or Bharat oil or any other agency authorized by DPCC) is required however the handling of hazardous waste to be continued by the vendor as is being done currently .
7	Section-III-Clause 4	Calculation of old & new copper should be as per given formula only	Calculation of old & new copper fomula is not feasible	Tender conditions shall prevail