

Sr. no.	tender requirement	ABB comment	BSES Reply
1	Numerical Relay make	kindly consider the ABB make relays	Kindly put the point at the time of technical evaluation
2	Ethernet switches	kindly consider the make O ring and phoenix	No deviation in this regard. Kindly adhere to specification
3	SCADA work	We request to provide the detailed scope of work for SCADA	Kindly refer tender document
4	Control cables	Kindly clarify Control cables need to be used for interpanel wiring of supply panels only	Control cable for installation of Switchgear shall be in bidder's scope. That also includes control cables related to Station Transformer, Capacitor bank also.
5	Auxiliary power cable	Kindly provide us the sizes and QTY for the Auxiliary power cable	Bidder has to calculate the quantity of control cable required. Size shall be finalised in detailed engineering.
6	Insulated floor coating	Insulated floor coating need to be provide in forn tof the supply panels or need to be provide for complete substation	Insulated floor coating shall be provided in complete Switchgear room.
7	Dismantling of existing panels	Kindly confirm dismantling of existing panels will be BHEL make and the QTY is 17	Kindly get the confirmation from site itself
8	Civil work	Civil work replated to the panel installation will be BYPL scope	Civil work shall be in BYPL scope.
9	Cable trench	Any Cable trench related work not in our scope	Noted
10	Power cable	our understading is Power supply cable & laying not in our scope of work	Kindly refer tender document
11	BOQ	Our understanding is to supply the material as per the BOQ and apart form BOQ any material not in our scope of supply / work	Noted
12	Site storage & watch and ward	we request BYPL to provide the store for the proper storage of material at site also Watch and ward will be in BYPL scope	BYPL has many stores in Delhi. Bidder may store its equipment there.