

Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI

Period of Report: APRIL 2017-OCT 17

Year: 2017

Sl. No.	Location of accident and details of victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI/AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	H.no. 556/31, Gali-15, Vijay Park, Division-YVR Victim: Mr. Ashok(Public)	4 MAY 17	FATAL	ELECTROCUTION FROM POLE	No earth connection of street light pole			Earth connection provided	
2	Near C-4/90A, gantry of 66kV Ghonda to Bhagirathi Ckt no 2 Victim: Unknown (Public)	14 MAY 17	NON FATAL	INTERFERENCE WITH ELECTRICAL INSTALLATION	Report not received				
3	H.no. D-21/4, Gali No 3, Shastri Park, Division- YVR Victim: Ms. Nisha (Public)	15 MAY 17	NON FATAL	INTERFERENCE WITH ELECTRICAL INSTALLATION	Report not received				
4	Gate no 1, Pocket A, Dilshad Garden, Division- GTR Victim: Mr. Robin (Public)	21 MAY 17	FATAL	SNAPPING OF CONDUCTOR	No earth guarding			Guarding provided	
5	Cycle market, New Lajpat Rai Mkt, Division- Chandni Chowk Victim: Unknown	21 MAY 17	FATAL	CURRENT LEAKAGE AT METER OUTGOING	Report not received				
6	2A/22, Geeta Colony, Division- KNR Victim: Unknown	7 AUG 17	FATAL	ELECTROCUTION	Report not received				

	(Public)								
7	B-Block s/stn, Shriram Colony, Sonia Vihar, Division- KWN Victim: Master Ayaan, S/o Sh. Sattar	25 AUG 17	NON FATAL	INTERFERENCE WITH ELECTRICAL INSTALLATION	Report not received				

(Signature of the Licensee)