Inspection Report

(This Installation Test Report is to be certified by a Licensed Electrical Contractor. This is for reference of consumer.) From: M/s..... (Wiring Contractor) Reg. No.... To: M/s. BSES Yamuna Power Limited (Name of the Licensee) We hereby inform that Electrical Inspection at the premises bearing No. / situated on Road / Street (as per address given below) occupied by (as per Applicant's name and signature as given below) has been completed by us and is ready for your engineer to test and connect up with your mains (As per CEA measures relating to safety and electric supply) regulation 2015 was tested by us on dateand the installation resistance as per regulation 34 was mega ohms. ELCB (as per regulation 42) found installed: Yes () NO () Make : Capacity : No. of circuits left Fans Total kW Lamps Plugs Plugs Other Domestic to right on Distribution Conductor (5 Amp) (15 Amp) appliances Watt Watt Watt Watt Description Watt No Nο Nο No Circuit No. 1 Circuit No. 2 Circuit No. 3 Circuit No. 4 Circuit No. 5 Circuit No. 6 D Μ License No. Date M Licensed wiring Contractor Name, Seal & Signature Address City PIN Name of the S/o Applicant Address where supply is required City PIN Address where bill is to be sent City PIN Signature of Applicant Signature of AMPS/DGM (Licensee) Date:

Note: As per notification no F.11(149)/2004 Power/2386 & 2387, Use of ISI marked motor pump sets, power capacitors, Foot/Reflex Valves in Agriculture sectors and use of CFL and electronic chokes in Govt. buildings/Govt. aided institutions/Boards/Corporations is mandatory.

As per CEA guideline Regulation 14 Suitable cut out should be provided at the consumer premises.

As per CEA guideline Regulation 16 earth terminal on consumer premises.

As per CEA guideline Regulation 42 earth leakage circuit breaker whose maximum earth leakage threshold for tripping should not exceed 30 milli amp. for domestic connection and 100 milli amp. for all other installation.